



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

October 9, 1990

Docket No. 50-390

MEMORANDUM FOR: Frederick J. Hebdon, Director  
Project Directorate II-4  
Division of Reactor Projects II-4, NRR

FROM: Peter S. Tam, Senior Project Manager  
Project Directorate II-4  
Division of Reactor Projects - I/II

SUBJECT: WATTS BAR UNIT 1 -- CLOSEOUT OF GENERIC LETTER  
(GL) 83-28, ITEM 4.5.1, "REACTOR TRIP  
FUNCTIONAL TESTING (TAC 64349)

By letter dated November 7, 1983, TVA responded to GL 83-18. By letter dated June 4, 1984, TVA committed to follow the Westinghouse Owners Group generic design package, including provisions for on-line surveillance testing.

The staff's acceptance criterion is documented in a memorandum, Frank J. Miraglia to Robert M. Bernero et al. dated February 11, 1985. This memorandum transferred review responsibilities of a number of GL 83-28 items, including Item 4.5.1, to the NRC regional offices. Specifically, it stated that Item 4.5.1 "should be considered complete when the licensee has submitted a statement committing to independent, on-line functional testing of the diverse trip features".

With the commitment in TVA's November 7, 1983 letter, and the fact that the developing Watts Bar Technical Specifications contain requirements for such functional testing, this item can be considered closed for Watts Bar. The date of this memorandum will be entered into WISP as the closeout date for TAC 64349.

Peter S. Tam, Senior Project Manager  
Project Directorate II-4  
Division of Reactor Projects

Distribution : Docket files  
NRC and local PDR  
B. Mozafari, 14 B 20

9010120197 901009  
PDR ADCK 05000390  
A PDC

LF 01  
1/0