



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

October 10, 1991

Docket No. 50-390  
and 50-391

MEMORANDUM FOR: Document Control Desk Personnel

FROM: Peter S. Tam, Senior Project Manager  
Project Directorate II-4  
Division of Reactor Projects - I/II

SUBJECT: WATTS BAR NUCLEAR PLANT -- TRANSMITTING  
DOCUMENT TO CENTRAL FILES AND MAKING IT PDR-  
AVAILABLE (TAC/79718 and/80345)

Please file the enclosed document, which is the handout prepared by TVA for the site review of September 24-25, 1991, on the issue of feedwater check valve slam (Watts Bar SER Supplement No. 6, Outstanding Issues 20(a)).

By copy of this memorandum, NRC and local PDR personnel are provided with a copy of the same document for PDR display.

A handwritten signature in cursive script that reads "Peter S. Tam".

Peter S. Tam, Senior Project Manager  
Project Directorate II-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc. NRC and local PDR  
J. Fair 7 E 23

9111190216 911010  
PDR ADOCK 05000390  
E PDR

*Memo*  
*[Handwritten initials]*

**NRC FILE CENTER COPY**

**Evaluation of Feedwater Line  
For Concurrent  
Feedwater Check Valve Slam  
and Seismic Loads**

**Discussion  
of  
Analysis Methodology**

**9-24-91**

## **Outline**

- **Introduction**
- **Analysis Model**
- **Loading Conditions**
- **Acceptance Criteria**
- **Summary**
- **Conclusions**

## **Introduction**

**Purpose:** To demonstrate pressure boundary integrity of the feedwater system following a simultaneous main feedwater header break, check valve slam, and seismic event. The check valve slam event was identified in Westinghouse Bulletin 79-9.

**Method:** Nonlinear time history analysis using ANSYS.

**Scenario:** Initial conditions include deadweight, pressure, and thermal expansion (including anchor motion at steam generator) at normal operating temperature.

**SSE initiates break at onset of strong motion.**

**Check valve slam transient occurs concurrent with seismic strong motion.**

**Seismic load continues after check valve slam transient ends.**

**Status:**

**Model and load generation for loop 4  
feedwater line completed.**

**Time history analysis of loop 4 feedwater  
line in progress.**

## **Background**

### **Identification of Transient:**

**Westinghouse Bulletin 79-9. Initial transient loads developed in early 80's using RELAP4.**

### **TVA Analysis:**

**RELAP5 used to generate transient loads. Linear analysis for check valve slam loads performed in 1982. Adequacy of cut-off frequency in mode superposition method questioned in 1986.**

### **Bechtel Analysis:**

**SWEC regenerated transient loads in 1989 using RELAP5. Bechtel performed exploratory linear analyses to determine feasibility of support modifications to qualify feedwater line.**

**Bechtel performed non-linear analysis in 1990 using check valve slam loads.**

## **Analysis Model - Piping Geometry**

### **Loop**

**Selection:** Loop 4 feedwater line selected for analysis has highest strain from initial checkvalve slam analysis.


**Geometry:** 16"/18" feedwater line from steam generator to flued head anchor in the auxiliary building.

2" bypass line around the feedwater check valve.

4" wet lay-up line up to isolation valve and adequate overlap region.


1" drain line.

All other lines will be evaluated as necessary to ensure pressure boundary integrity.



Loop 4 Feedwater Line  
Figure 1





Analysis Model  
Figure 2

## **Analysis Model - Piping Elements**

### **Material**

**Properties:** Bilinear stress-strain curves, based on ASME Code values of  $E$ ,  $S_y$ , and  $S_u$  and published values of  $\epsilon_u$ .

## **Analysis Model - Supports**

**Supports:** Ductile supports (capable of yielding and undergoing predictable deformation) modeled using elastic-perfectly plastic load deflection curves. See Figure 3a.

Non-ductile supports modeled using "break-away" curves. See Figure 3b.


Single-directional supports also appropriately considered (eg., downward only supports). See Figure 3c.

Support load properties/behavior developed.


### **Rupture**

**Restraints:** Gap elements used to account for clearance between pipe and shims.


ANSYS tracks gap open-close status during analysis and includes closure effects in solution.



Ductile Support Load-Deflection Curve  
Figure 3a



Non-Ductile Support Load-Deflection Curve  
Figure 3b



One-Way Ductile Support Load-Deflection Curve  
Figure 3c

## **Loading Conditions - Initial**

- **Maximum feedwater check valve slam loads are used with normal operating conditions:**

**Temperature**

**Pressure**

**Deadweight of pipe, components, and contents.**

**Thermal anchor movements at steam generator.**

## **Loading Conditions - Seismic**

- **Three orthogonal (NS, EW, and Vertical) input time histories generated to envelop spectra for three structures.**
- **Envelope of OBE and SSE for Sets B + C.**
- **Reg. Guide 1.61 damping (2%/3%).**
- **Event duration - 19 sec.  
Strong motion duration - approx. 6 sec.  
Time step - .005 sec., except .001 sec. during  
check valve slam event.**
- **SRP requirements met for time history development.**

## **Loading Conditions - Check Valve Slam**

- **Force time history developed based on guillotine rupture of 32" feedwater header. Break development time of .001 sec. used per SRP 6.2 guidance.**
- **Event duration - 0.5 sec.  
Time step - .001 sec.**
- **CVS transient begins at 4.5 sec. into seismic event at initiation of strong motion.**

## **Acceptance Criteria**

- Piping:** Calculated stresses compared to maximum allowable values as specified in ASME Appendix F.
- Supports:** Load-deflection output time history reviewed against behavior model to ensure compatibility.
- Rupture Restraints:** Gap closure output time history reviewed, maximum loads reviewed against capacities to determine accuracy of modeling.



## **Results to Date**

- **First pass exploratory analysis performed with combined check valve slam and seismic load.**
- **Results show exceedance of calculated capacities for nine supports. Three supports remain functional after the check valve slam event.**
- **Highest stresses in exploratory run occur at first elbow near the steam generator.**

## **Final Analysis Refinements**

- **Refine model to obtain proper distribution of elastic and plastic elements for appropriate response.**
- **Refine support and rupture restraint models as required for analysis compatibility.**
- **Reexamine conservatism of seismic time histories.**

## Summary

- **The purpose is to demonstrate pressure boundary integrity of the feedwater system following a simultaneous header break and seismic event.**
- **Nonlinear analysis is performed for loop 4 feedwater line. Pipe, support, and rupture restraint nonlinearities are considered.**
- **Operating, seismic, and feedwater check valve slam transient loads are applied concurrently.**
- **The acceptability of stresses are checked against ASME Section III Appendix F allowables.**
- **The other 3 feedwater lines will be qualified by comparison with the loop 4 feedwater analysis after the final results are obtained.**

## **Conclusions**

- **Analysis methods and loads consistent with SRP requirements.**
- **Acceptance criteria consistent with ASME Code requirements.**
- **Pressure boundary integrity will be demonstrated for applicable Level D load combination.**