

From: Kimberly Green
To: "MICHAEL D STROUD" <MSTROUD@entergy.com>
Date: 12/17/2007 9:40:47 AM
Subject: Draft Telecon Summary — Decemeber 3, 2007
cc: <dytner@entergy.com>, <IPNonPublicHearingFile@nrc.gov>

Mike,

Please look over the draft telecon summary (that I remembered to attach this time) and let me know if there are any errors or discrepancies.

Thanks,

Kim Green
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop O11 F1
Rockville, Maryland 20852-2738
phone: 301-415-1627
fax: 301-415-3313
email: kjg1@nrc.gov

Hearing Identifier: IndianPointUnits2and3NonPublic
Email Number: 306

Mail Envelope Properties (47723FAD.HQGWDO01.OWGWPO04.200.2000008.1.15AA14.1)

Subject: Draft Telecon Summary — Decemeber 3, 2007
Creation Date: 12/17/2007 9:40:47 AM
From: Kimberly Green

Created By: KJG1@nrc.gov

Recipients

<dtynr@entergy.com>
<IPNonPublicHearingFile@nrc.gov>
"MICHAEL D STROUD" <MSTROUD@entergy.com>

Post Office

OWGWPO04.HQGWDO01

Route

nrc.gov

Files

MESSAGE

Telecon Summary 12-3-07.doc
AM

Size

370

48640

Date & Time

12/17/2007 9:40:47 AM

12/26/2007 11:49:01

Options

Priority: Standard

Reply Requested: No

Return Notification: None
None

Concealed Subject: No

Security: Standard

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Indian Point Nuclear Generating Unit Nos. 2 and 3

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON DECEMBER 3, 2007, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE INDIAN POINT NUCLEAR GENERATING UNIT NOS. 2 AND 3, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc. (Entergy), held a telephone conference call on December 3, 2007, to discuss and clarify the staff's requests for additional information (RAIs) concerning the Indian Point Nuclear Generating Unit Nos. 2 and 3, license renewal application. By letter dated October 29, 2007, the NRC staff sent Entergy RAIs on the Reactor Vessel Surveillance Program and the Reactor Neutron Embrittlement Time-Limited Aging Analyses. Entergy responded by letter dated November 28, 2007. During the telephone call, the NRC staff informed Entergy that for the RAI questions in section 4.2, where the staff refers to neutron fluence and flux, it is asking for specific fluence and flux values and the source of those calculated values. In addition, the NRC staff also requested that Entergy provide confirmation that the referenced source of the surveillance data complies with Regulatory Guide 1.190, and that the surveillance data has been used in the Pressurized Thermal Shock and Charpy Upper-Shelf Energy analyses. Entergy indicated that they would review the information requested again and supplement the response, as appropriate.

The enclosure provides a listing of the participants.

The applicant had an opportunity to comment on this summary.

Bo Pham, Senior Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-247 and 50-286

Enclosure:
List of Participants

cc w/encl: See next page

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Indian Point Nuclear Generating Unit Nos. 2 and 3

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON DECEMBER 3, 2007, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE INDIAN POINT NUCLEAR GENERATING UNIT NOS. 2 AND 3, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc. (Entergy), held a telephone conference call on December 3, 2007, to discuss and clarify the staff's requests for additional information (RAIs) concerning the Indian Point Nuclear Generating Unit Nos. 2 and 3, license renewal application. By letter dated October 29, 2007, the NRC staff sent Entergy RAIs on the Reactor Vessel Surveillance Program and the Reactor Neutron Embrittlement Time-Limited Aging Analyses. Entergy responded by letter dated November 28, 2007. During the telephone call, the NRC staff informed Entergy that for the RAI questions in section 4.2, where the staff refers to neutron fluence and flux, it is asking for specific fluence and flux values and the source of those calculated values. In addition, the NRC staff also requested that Entergy provide confirmation that the referenced source of the surveillance data complies with Regulatory Guide 1.190.

The enclosure provides a listing of the participants.

The applicant had an opportunity to comment on this summary.

Bo Pham, Senior Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-247 and 50-286

Enclosure:
List of Participants

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: G:\ADRO\DLR\RPB2\Indian Point\Safety Review\Telecon Summaries\Telecon Summary 12-3-07.doc

OFFICE	LA:DLR	PM:RPB2:DLR	BC:RPB2:DLR
NAME		BPham	RFranovich
DATE	12/ /07	12/ /07	12/ /07

OFFICIAL RECORD COPY

**TELEPHONE CONFERENCE CALL
INDIAN POINT NUCLEAR GENERATING UNIT NOS. 2 AND 3
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS
DECEMBER 3, 2007**

PARTICIPANTS

AFFILIATIONS

Bo Pham,
Barry Elliot

U.S. Nuclear Regulatory Commission (NRC)
NRC

Mike Stroud

Entergy Nuclear Operations, Inc. (Entergy)

Ted Ivy

Entergy

Floyd Gumble

Entergy

John Curry

Entergy

Nelson Azevedo

Entergy

Charles Caputo

Entergy

Alan Cox

Entergy

Don Fronabarger

Entergy

Ron Finnin

Areva