

January 17, 2008

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Vermont Yankee Nuclear Power Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON DECEMBER 18, 2007, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING A REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on December 18, 2007, to discuss and clarify the staff's request for additional information (RAI) concerning the Vermont Yankee Nuclear Power Station license renewal application. The telephone conference call was useful in clarifying the intent of the staff's RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

**/RA/**

Jonathan G. Rowley, Project Manager  
Projects Branch 2  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:  
As stated

cc w/encls: See next page

January 17, 2008

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Vermont Yankee Nuclear Power Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON DECEMBER 18, 2007, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING A REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on December 18, 2007, to discuss and clarify the staff's request for additional information (RAI) concerning the Vermont Yankee Nuclear Power Station license renewal application. The telephone conference call was useful in clarifying the intent of the staff's RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

**/RA/**

Jonathan G. Rowley, Project Manager  
Projects Branch 2  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:

As stated

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: **ML073600752**

|        |             |             |             |
|--------|-------------|-------------|-------------|
| OFFICE | LA:RPOB:DLR | PM:RPB2:DLR | BC:RPB2:DLR |
| NAME   | IKing       | JRowley     | RFranovich  |
| DATE   | 12/27/07    | 12/27/07    | 01/17/08    |

OFFICIAL RECORD COPY

TELEPHONE CONFERENCE CALL  
VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION

LIST OF PARTICIPANTS  
DECEMBER 18, 2007

PARTICIPANTS

Jonathan Rowley  
Kenneth Chang  
On Yee  
Qi Gan  
David Mannai  
David Lach  
Michael Metell  
Scott Goodwin  
James Fitzpatrick  
Alan Cox  
David Gerber  
Terry Herrmann

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
NRC  
NRC  
Entergy Nuclear Operations, Inc. (Entergy)  
Entergy  
Entergy  
Entergy  
Entergy  
Entergy  
Structural Integrity Associates (SIA)  
SIA

REQUESTS FOR ADDITIONAL INFORMATION  
VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION

DECEMBER 18, 2007

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc. held a telephone conference call on December 18, 2007, to discuss and clarify the following request for additional information (RAI) concerning the Vermont Yankee Nuclear Power Station (VYNPS) license renewal application.

**RAI 4.3.3-2**

Your response to audit question # 387 in your November 14, 2007, letter states that "In most cases the maximum component stress difference with time matched the maximum stress intensity calculated by ANSYS. This shows that shearing stresses are negligible for the thermal transient at that location and the maximum component stress difference is the maximum stress intensity."

Please identify the exceptions where maximum component stress difference with time did not match the maximum stress intensity calculated by ANSYS. In addition, please justify the exceptions, based on quantitative evaluations, that the shearing stresses are negligible and the maximum component stress difference is the maximum stress intensity for the branch nozzle blend radius (nozzle corner) locations with geometrical discontinuities for the applicable thermal transients. Your response should cover the shearing stress differences at the 0-180 degree axis and the 90-270 degree axis to the pipe run axis.

**Discussion:** The response to RAI 4.3.3-2, submitted by VY on December 11, 2007, was reviewed by several staff and discussed during the conference call. The staff indicated that the response did not adequately demonstrate that the shearing stresses are negligible and that the response also raised uncertainty of the validity of the methodology used to calculate stresses.

The NRC and Entergy staffs discussed alternative approaches for addressing environmentally assisted fatigue (EAF) for all NUREG/CR-6260 nozzle locations at VY and the use of the industry accepted computer code ANSYS.

Entergy indicated that some terminology misunderstanding may exist between the two sides. Entergy requested a face-to-face meeting to ensure the understanding pertaining to this highly technical issue was properly and effectively communicated.

Letter to Entergy Nuclear Operations, Inc. From J. Rowley Dated January 17, 2008

**DISTRIBUTION:**

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON DECEMBER 18, 2007, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING A REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION

**HARD COPY:**

DLR RF

**E-MAIL:**

PUBLIC

SSmith (srs3)

SDuraiswamy

RidsNrrDlr

RidsNrrDlrRIra

RidsNrrDlrRIrb

RidsNrrDlrRIrc

RidsNrrDlrReba

RidsNrrDlrRebb

RidsNrrDciCvib

RidsNrrDciCpnb

RidsNrrDraAfpb

RidsNrrDeEmcb

RidsNrrDeEeeb

RidsNrrDssSrxb

RidsNrrDssSbpb

RidsNrrDssScvb

RidsOgcMailCenter

-----

JRowley

RLaufer

JShea

RPowell, RI

DScrenci, RI

MModes, RI

DPelton, SRI

MYoung

RidsOpaMail

Vermont Yankee Nuclear Power Station

cc:

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406-1415

Mr. David R. Lewis  
Pillsbury, Winthrop, Shaw, Pittman, LLP  
2300 N Street, N.W.  
Washington, DC 20037-1128

Mr. David O'Brien, Commissioner  
Vermont Department of Public Service  
112 State Street  
Montpelier, VT 05620-2601

Mr. James Volz, Chairman  
Public Service Board  
State of Vermont  
112 State Street  
Montpelier, VT 05620-2701

Chairman, Board of Selectmen  
Town of Vernon  
P.O. Box 116  
Vernon, VT 05354-0116

Operating Experience Coordinator  
Vermont Yankee Nuclear Power Station  
320 Governor Hunt Road  
Vernon, VT 05354

G. Dana Bisbee, Esq.  
Deputy Attorney General  
33 Capitol Street  
Concord, NH 03301-6937

Chief, Safety Unit  
Office of the Attorney General  
One Ashburton Place, 19th Floor  
Boston, MA 02108

Ms. Carla A. White, RRPT, CHP  
Radiological Health  
Vermont Department of Health  
P.O. Box 70, Drawer #43  
108 Cherry Street  
Burlington, VT 05402-0070

Mr. David Mannai  
Manager, Licensing  
Entergy Nuclear Operations  
Vermont Yankee Nuclear Power Station  
P.O. Box 500  
185 Old Ferry Road  
Brattleboro, VT 05302-0500

Resident Inspector  
Vermont Yankee Nuclear Power Station  
U. S. Nuclear Regulatory Commission  
P.O. Box 176  
Vernon, VT 05354

Director, Massachusetts Emergency  
Management Agency  
ATTN: James Muckerheide  
400 Worcester Road  
Framingham, MA 01702-5399

Jonathan M. Block, Esq.  
Main Street  
P.O. Box 566  
Putney, VT 05346-0566

Mr. John F. McCann  
Director, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. John T. Herron  
Sr. Vice President  
Entergy Nuclear Operations, Inc.  
1340 Echelon Parkway  
Jackson, MS 39213

Vermont Yankee Nuclear Power Station

cc:

Mr. Oscar Limpias  
Vice President, Engineering  
Entergy Nuclear Operations, Inc.  
1340 Echelon Parkway  
Jackson, MS 39213  
Mr. Christopher Schwartz  
Vice President, Operations Support  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Michael J. Colomb  
Director of Oversight  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. William C. Dennis  
Assistant General Counsel  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Theodore Sullivan  
Site Vice President  
Entergy Nuclear Operations, Inc.  
Vermont Yankee Nuclear Power Station  
P.O. Box 500  
185 Old Ferry Road  
Brattleboro, VT 05302-0500

Mr. James H. Snizek  
5486 Nithsdale Drive  
Salisbury, MD 21801

Mr. Garrett D. Edwards  
814 Waverly Road  
Kennett Square, PA 19348

Ms. Stacey M. Lousteau  
Treasury Department  
Entergy Services, Inc.  
639 Loyola Avenue  
New Orleans, LA 70113

Mr. Norman L. Rademacher

Director, NSA  
Vermont Yankee Nuclear Power Station  
P.O. Box 0500  
185 Old Ferry Road  
Brattleboro, VT 05302-0500

Mr. Raymond Shadis  
New England Coalition  
Post Office Box 98  
Edgecomb, ME 04556

Mr. James P. Matteau  
Executive Director  
Windham Regional Commission  
139 Main Street, Suite 505  
Brattleboro, VT 05301

Mr. William K. Sherman  
Vermont Department of Public Service  
112 State Street  
Drawer 20  
Montpelier, VT 05620-2601

Mr. Michael D. Lyster  
5931 Barclay Lane  
Naples, FL 34110-7306

Diane Curran, Esq.  
Harmon, Curran, Spielberg &  
Eisenberg, L.L.P.  
1726 M Street, NW, Suite 600  
Washington, DC 20036

Ronald A. Shems, Esq.  
Shems, Dunkiel, Kassel & Saunders, PLLC  
91 College Street  
Burlington, VT 05401

Karen Tyler, Esq.  
Shems, Dunkiel, Kassel & Saunders, PLLC  
91 College Street  
Burlington, VT 05401

Sarah Hofmann, Esq.

Vermont Yankee Nuclear Power Station

cc:

Director of Public Advocacy  
Department of Public Service  
112 State Street - Drawer 20  
Montpelier, VT 05620-2601

Jennifer J. Patterson, Esq.  
Office of the New Hampshire Attorney  
General  
33 Capitol Street  
Concord, NH 03301

Matias F. Travieso-Diaz, Esq.  
Pillsbury, Winthrop, Shaw, Pittman, LLP  
2300 N Street, NW  
Washington, DC 20037-1128

Matthew Brock, Esq.  
Assistant Attorney General  
Office of the Massachusetts Attorney  
General  
Environmental Protection Division  
One Ashburton Place, Room 1813  
Boston, MA 02108-1598

Anthony Z. Roisman, Esq.  
National Legal Scholars Law Firm  
84 East Thetford Road  
Lyme, NH 03768

John Sipos, Assistant Attorney General  
Office of the Attorney General  
The Capitol  
State Street  
Albany, NY 12224