



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

October 6, 1992

Docket Nos. 50-390  
and 50-391

APPLICANT: Tennessee Valley Authority (TVA)  
FACILITY: Watts Bar Nuclear Plant, Units 1 and 2  
SUBJECT: MEETING SUMMARY - September 21, 1992, ROUTINE CONFERENCE  
ON LICENSING STATUS (TAC M72494, AND M72495)  
REFERENCE: Meeting notice by P. S. Tam, September 2, 1992

On September 21, 1992, NRC and TVA representatives met at the Watts Bar site to discuss the status, needed actions, priorities and schedules of various licensing issues. These include all unresolved outstanding issues, confirmatory issues, proposed license conditions, corrective action programs (CAPs), special programs (SPs), TVA's response to generic letters and bulletins, and upcoming NRR-led team inspections. The discussion was based on the latest licensing status as published in the Watts Bar Safety Evaluation Report Supplement 9 (NUREG-0847, Supp. 9). The Office of Nuclear Reactor Regulation (NRR) issues the Safety Evaluation Report (NUREG-0847) and supplements (SSERs) as its principal licensing basis documents for Watts Bar. Section 1 of the latest SSER (SSER 9) officially documents the issues that NRR considers needing resolution before an operating license can be granted.

Enclosure 1 is the list of meeting participants.

Schedular information and other comments were exchanged between TVA and NRR personnel, agreed upon, and subsequently used to update the NRR staff's work control system, Workload Information and Scheduling Program (WISP). The output of WISP (Enclosure 2) records the staff's understanding of the status of each active NRR action. TVA participants described the status of TVA's top 10 actions. These are so indicated in Enclosure 2.

**NRC FILE CENTER COPY**

*Memo of*  
*DFOI 11*

9210160186 921006  
PDR ADOCK 05000390  
P PDR

The staff agreed to regard the issue of use of Thermolag materials as having the highest priority. TVA proposed to meet with the staff in the near future (early October) to discuss what measures TVA would undertake in order to continue installing Thermolag materials at Watts Bar. All staff activities on Thermolag materials at Watts Bar will be tracked by TAC M63648.

Original signed by

Peter S. Tam, Senior Project Manager  
Project Directorate II-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Participant list
2. WISP report

cc w/enclosures:  
See next page

Distribution

Docket File  
NRC & Local PDR  
WBN Rdg.  
TMurley/FMiraglia 12-G-18  
JPartlow 12-G-18  
SVarga 14-E-4  
GLainas 14-H-1  
PTam  
VNerses  
MSanders  
OGC 15-B-18  
EJordan MNBB-3302  
GWalton RII  
BWilson RII  
EMerschhoff RII  
ACRS(10)

| OFFICE | PDII-4/LA          | PDII-4/PM          | PDII-4/D          |
|--------|--------------------|--------------------|-------------------|
| NAME   | MSanders <i>ms</i> | PTam:as <i>PST</i> | FHebdon <i>FH</i> |
| DATE   | 10/6/92            | 10/6/92            | 10/6/92           |

Watts Bar Nuclear Plant

cc:

Mr. John B. Waters, Chairman  
Tennessee Valley Authority  
ET 12A  
400 West Summit Hill Drive  
Knoxville, Tennessee 37902

Mr. D. E. Nunn, Vice President  
3B Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

Mr. W. J. Museler, Vice President  
Watts Bar Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Spring City, Tennessee 37381

Mr. M. J. Burzynski, Manager  
Nuclear Licensing and Regulatory Affairs  
Tennessee Valley Authority  
5B Lookout Place  
Chattanooga, Tennessee 37402-2801

Mr. G. L. Pannell, Site Licensing Manager  
Watts Bar Nuclear Plant  
Tennessee Valley Authority  
3B Lookout Place  
Spring City, Tennessee 37381

TVA Representative  
Tennessee Valley Authority  
11921 Rockville Pike  
Suite 402  
Rockville, Maryland 20852

Mr. Michael H. Mobley, Director  
Division of Radiological Health  
3rd Floor, L and C Annex  
401 Church Street  
Nashville, Tennessee 37243-1532

General Counsel  
Tennessee Valley Authority  
ET 11H  
400 West Summit Hill Drive  
Knoxville, Tennessee 37902

The Honorable Robert Aikman  
County Judge  
Rhea County Courthouse  
Dayton, Tennessee 37321

The Honorable Johnny Powell  
County Judge  
Meigs County Courthouse  
Route 2  
Decatur, Tennessee 37322

Regional Administrator  
U.S.N.R.C. Region II  
101 Marietta Street, N.W.  
Suite 2900  
Atlanta, Georgia 30323

Senior Resident Inspector  
Watts Bar Nuclear Plant  
U.S.N.R.C.  
Route 2, Box 700  
Spring City, Tennessee 37381

Dr. Mark O. Medford, Vice President  
Nuclear Assurance, Licensing & Fuels  
3B Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

LIST OF PARTICIPANTS

ROUTINE LICENSING STATUS MEETING

September 21, 1992

| <u>Name</u>              | <u>Affiliation</u>               |
|--------------------------|----------------------------------|
| Fred Hebdon              | NRC/NRR/Project Directorate II-4 |
| Becky Mays               | TVA Watts Bar Site Licensing     |
| Vic Nerses               | NRC/NRR/Project Directorate II-4 |
| Paul Pace                | TVA Watts Bar Site Licensing     |
| Peter Tam                | NRC/NRR/Project Directorate II-4 |
| John Vorees              | TVA Watts Bar Site Licensing     |
| Glenn Walton (part-time) | NRC Senior Resident Inspector    |

Condensed Project Manager Report

| TaskID                     | MPA Num | Age (Mon) | Rev Mth | Pri | Actyp | Title   | Appl Date  | RAI Issued | RAI Response | Licensing Action Complete | Licensee Impl. | Comments   |
|----------------------------|---------|-----------|---------|-----|-------|---|------------|------------|--------------|---------------------------|----------------|--|
| ***** Active Actions ***** |         |           |         |     |       |   |            |            |              |                           |                |  |
| M63590                     |         | [ 40]     | TS      | 2   | RN    | WATTS BAR 1 - CORRECTIVE ACTION PROGRAM: Q - LIST.  | (05/22/89) | (08/16/90) | (11/07/90C)  | (12/31/92T)               | (10/31/92T)    | Submittal to modify scope by 10/92. (Top 3)                  |
| M63591                     |         | [ 17]     | TS      | 2   | RN    | WATTS BAR 1 - SPECIAL PROGRAM: EQUIPMENT QUALIFICATION OPEN ISSUE 4                                   | (04/30/91) | (05/01/92) | (09/30/92T)  | (03/31/93T)               | (03/31/93T)    | RAI response by 9/92.  |
| M63595                     |         | [ 42]     | TS      | 2   | RN    | WATTS BAR 1 - SPECIAL PROGRAM: MODERATE ENERGY LINE BREAK FLOODING (SECTION 3.6.1)                    | (03/22/89) | (--/--/--) | (06/30/92C)  | (12/31/93T)               | (05/31/93T)    | 6/30/92 submittal under review.                              |
| M63597                     |         | [ 47]     | TS      | 3   | RN    | "WATTS BAR 1 - CONTAINMENT ISOLATION REVIEW"  | (10/20/88) | (03/15/89) | (05/12/89C)  | (07/31/93T)               | (07/31/93T)    | Proposed site review 5/93. Kudrick OKed (if similar to BF-2) |
| M63632                     |         | [ 28]     | TS      | 2   | RN    | "WATTS BAR 1 - MSLB OUTSIDECONTAINMENT (SECT 3.11.3.3)"   | (05/04/90) | (06/04/90) | (11/30/92T)  | (12/30/92T)               | (--/--/--)     | TVA: submittal by 11/92.                                     |
| M63647                     |         | [ 25]     | TS      | 3   | RN    | "WATTS BAR 1 - HEALTH PHYSICS PROGRAM (SECT 12.6)"  | (08/15/90) | (10/19/90) | (08/24/92C)  | (06/30/93T)               | (--/--/--)     | FSAR to be updated by Amend. 73 (?) to reflect new Part 20.  |
| M63648                     |         | [ 7]      | TS      | 2   | RN    | WATTS BAR 1 - CORRECTIVE ACTION PROGRAM: FIRE PROTECTION, OPEN ISSUE 12, CONF. ISSUE 38, LIC. COND 20 | (02/05/92) | (--/--/--) | (08/28/92C)  | (05/31/93T)               | (08/30/93T)    | Meeting on Thermomag early 10/92 (Top 1).                    |
| M63649                     |         | [ 91]     | TS      | 2   | RN    | WATTS BAR 1 - POWER SYSTEM CONCERNS, CONF. 28-35, LIC. COND.13,17                                     | (02/06/85) | (06/20/91) | (06/18/92C)  | (10/31/92T)               | (--/--/--)     | Draft FSAR pages received. Expect to close several issues.   |
| M63655                     |         | [ 40]     | TS      | 2   | RN    | WATTS BAR 1 - SPECIAL PROGRAM: CONTROL ROOM DESIGN REVIEW   | (05/22/89) | (04/28/89) | (10/24/90C)  | (07/31/93T)               | (01/31/93T)    | Program review complete, SSER 6. Audit HEDs 6/93.            |
| M63656                     |         | [ 0]      | TS      | 3   | RN    | WATTS BAR 1 - EMERGENCY PLANNING LIC. COND. 27  | (--/--/--) | (--/--/--) | (--/--/--)   | (06/30/93T)               | (11/30/92T)    | TVA submittal app. 12/92. NRR does pre-OL review.            |
| M63657                     |         | [ 26]     | TS      | 2   | RN    | "WATTS BAR 1 - PHYSICALSECURITY PLAN (SECT 13.6)"   | (07/24/90) | (--/--/--) | (06/17/92C)  | (09/30/93T)               | (12/31/92T)    | SSER 10 will eliminate PLC 38. Review of 6/17 ltr. ongoing.  |
| M68624                     | A022    | [ 5]      | TS      | 2   | LL    | "WATTS BAR 1 - IMPLEMENTATION OF THE STATION BLACKOUT RULE, 10CFR50.63"                               | (04/22/92) | (--/--/--) | (--/--/--)   | (12/31/92T)               | (01/31/94T)    | SE target 11/92. TVA to consider implementation target date. |
| M71917                     |         | [ 40]     | TS      | 2   | RN    | "WATTS BAR 1 - CORRECTIVE ACTION PROGRAM (CAP) FOR CABLE ISSUES"                                      | (05/22/89) | (--/--/--) | (11/21/91C)  | (12/30/92T)               | (12/31/93T)    | NRR action complete in SSER 9. Will monitor impl. (Top 5)    |
| M71923                     |         | [ 40]     | TS      | 2   | RN    | "WATTS BAR 1 CORRECTIVE ACTION PROGRAM (CAP) FOR QA RECORDS"  | (05/22/89) | (04/10/91) | (05/15/92C)  | (03/31/93T)               | (09/30/93T)    | NRR preparing position on App. B-required QA records.        |
| M72106                     |         | [ 40]     | TS      | 2   | RN    | "WATTS BAR 1 - CORRECTIVE ACTION PROGRAM (CAP) FOR WELDING ISSUES"                                    | (05/22/89) | (--/--/--) | (07/31/90C)  | (10/30/92T)               | (09/30/92T)    | Closeout ltrs. on CAP and Welding Project by 10/92.          |
| M72181                     | X811    | [ 6]      | TS      | 2   | RN    | "WATTS BAR 1 - BULLETIN 88-11 PRESSURIZER SURGELINE THERMAL STRATIFICATION"                           | (03/30/92) | (--/--/--) | (--/--/--)   | (10/31/92T)               | (--/--/--)     | Clean SE on Item 2.a expected by 9/30/92.                    |
| M72693                     | X809    | [ 0]      | TS      | 2   | RN    | "WATTS BAR 1 - THIMBLE THINNING IN PWR'S (BULLETIN 88-09)"  | (--/--/--) | (--/--/--) | (--/--/--)   | (12/31/93T)               | (--/--/--)     | No need for submittal until after plant start.               |
| M73723                     | F072    | [ 38]     | TS      | 2   | RN    | "WATTS BAR- MPA F-72: SAFETY PARAMETER DISPLAY SYSTEM- RESPONSE TO GL 89-06"                          | (07/11/89) | (--/--/--) | (11/01/90C)  | (07/31/93T)               | (06/30/93T)    | SSER 6. "Functional" SPDS audit by 6/93.                     |
| M74488                     | B111    | [ 0]      | TS      | 3   | RN    | "WATTS BAR 1- INDIVIDUAL PLANT EVALUATIONS (GL 88-20)"  | (09/01/92) | (--/--/--) | (09/30/92T)  | (06/30/93T)               | (--/--/--)     | IPE under review; IPEEE has separate TAC number.             |
| M74801                     | A025    | [ 0]      | TS      | 3   | RN    | "WATTS BAR 1 - ACCEPTABLE 1ST PROGRAMS(GL 89-04)"   | (--/--/--) | (--/--/--) | (--/--/--)   | (09/30/93T)               | (--/--/--)     | Per GI 89-04. Relief requests by 7/93.                       |
| M76631                     | X001    | [ 8]      | PM      | 3   | RN    | "WATTS BAR 1 - RESPONSE TO NRCB 90-01 LOSS OF FILL-OIL IN ROSEMOUNT TRANSMITTER"                      | (01/31/92) | (--/--/--) | (--/--/--)   | (12/31/92T)               | (12/31/92T)    | Supplemental bulletin being prepared, date uncertain.        |
| M76742                     |         | [ 33]     | TS      | 2   | RN    | WATTS BAR 1 - TECHNICAL SPECIFICATION REVIEW  | (12/29/89) | (--/--/--) | (--/--/--)   | (09/30/93T)               | (--/--/--)     | Schedule agreed to in 9/15/92 meeting.                       |

Enclosure 2

Report Date 09/25/92

## Condensed Project Manager Report

| TaskID | MPA Num | Age (Mo) | Rev Mth | Pri | Actyp | Title  | Appl Date  | RAI Issued | RAI Response | Licensing Action Complete | Licensee Impl. | Comments  |
|--------|---------|----------|---------|-----|-------|--|------------|------------|--------------|---------------------------|----------------|---|
| M76881 |         | [ 0]     | TS      | 3   | RN    | WATTS BAR 1 - INSERVICE INSPECTION   | (--/--/--) | (--/--/--) | (--/--/--)   | (09/30/93T)               | (--/--/--)     | Submittal by 7/93.  |
| M76972 |         | [ 33]    | TS      | 2   | RN    | WATTS BAR UNIT 1 - QUALITY ASSURANCE PROGRAM (SER SECTION 17.0)                          | (12/07/89) | (--/--/--) | (--/--/--)   | (03/31/93T)               | (--/--/--)     | Response to SSER 5 by Amendment 73. SSER 10 has update.     |
| M76974 |         | [ 17]    | TS      | 2   | RN    | WATTS BAR UNIT 1 - SPECIAL PROGRAM : MECHANICAL EQUIPMENT QUALIFICATION                  | (04/30/91) | (04/09/92) | (--/--/--)   | (01/31/93T)               | (12/31/92T)    | MEQ submittal by 10/92, together with response to EQ RAI.   |
| M77132 |         | [ 84]    | TS      | 2   | RN    | WATTS BAR 1 - TMI II.F.2, ON INADEQUATE CORE COOLING INSTRUMENTATION, LIC. COND. 3       | (09/19/85) | (08/16/90) | (01/24/92C)  | (08/31/93T)               | (07/31/93T)    | SSER10 accepts 1/24/92 submittal. TVA impl. ltr. by 7/93.   |
| M77222 |         | [ 26]    | TS      | 2   | RN    | WATTS BAR UNIT 1 - SEVERE ACCIDENT MITIGATION DESIGN ALTERNATIVES (SAMDA) IN THE FES     | (07/30/90) | (01/29/91) | (--/--/--)   | (06/30/93T)               | (--/--/--)     | Conference call needed to determine next milestone.         |
| M77543 |         | [ 92]    | TS      | 2   | RN    | WATTS BAR 1 - PROCEDURE TO ESTIMATE CORE DAMAGE, (SECTION 9.3.2)                         | (01/31/85) | (--/--/--) | (01/31/93T)  | (06/30/93T)               | (--/--/--)     | SSER 5. TVA submittal by 1/93.                              |
| M77553 |         | [ 1]     | TS      | 2   | RN    | WATTS BAR 1 - OFFSITE DOSE CALCULATION MANUAL (ODCM)                                     | (08/27/92) | (--/--/--) | (--/--/--)   | (03/31/93T)               | (--/--/--)     | A. Massey is reviewer. Target date 3/93.                    |
| M77560 |         | [ 96]    | TS      | 3   | RN    | WATTS BAR 1 - HEAVY LOADS (LICENSE CONDITION 39)   | (09/24/84) | (--/--/--) | (12/31/92T)  | (03/31/93T)               | (--/--/--)     | TVA submittal by 1/93.                                      |
| M77569 |         | [ 90]    | TS      | 2   | RN    | WATTS BAR 1 - STEAM GENERATOR TUBE RUPTURE ANALYSIS PER WCAP - 11698                     | (03/31/85) | (--/--/--) | (--/--/--)   | (12/31/92T)               | (--/--/--)     | See SSER 5, 15.6.3. TVA submittal by 4/93. (Top 9)          |
| M77896 | A021    | [ 27]    | TS      | 2   | LL    | WATTS BAR 1 PRESSURIZED THERMAL SHOCK, 10 CFR 50.61                                      | (06/26/90) | (--/--/--) | (07/13/92C)  | (10/31/92T)               | (--/--/--)     | 7/13/92 letter under review, target late 1992.              |
| M79692 |         | [ 20]    | TS      | 2   | RN    | WATTS BAR 1 - PIPE BREAK SPECTRA USED AS RESULT OF LLB APPROVAL                          | (01/29/91) | (--/--/--) | (09/20/91C)  | (11/15/92T)               | (--/--/--)     | Under review by Fair and DAngelo. SE by 10/92.              |
| M79717 |         | [ 20]    | PM      | 2   | RN    | WATTS BAR 1 - SEISMIC DESIGN CONCERNS ORIGINATING FROM FSAR AMEND 64 OPEN ISSUE 19       | (01/04/91) | (08/22/91) | (04/06/92C)  | (03/31/93T)               | (--/--/--)     | Outstanding issue 19 g to be resolved in audit, early 1993. |
| M79718 |         | [ 17]    | TS      | 2   | RN    | WATTS BAR 1 - MECHANICAL SYSTEMS CONCERNS ORIGINATING FROM FSAR AMEND. 64, OPEN ISSUE 20 | (04/18/91) | (01/04/91) | (08/04/92C)  | (01/31/93T)               | (--/--/--)     | 8/4/92 letter on FW check valve slam under review, 12/92.   |
| M79992 |         | [ 18]    | TS      | 2   | RN    | WATTS BAR 1 - SAFETY AND RELIEF VALVE TESTING (TMI II.D.1)                               | (03/21/91) | (10/10/91) | (07/11/91C)  | (12/31/92T)               | (12/31/92T)    | Response to 10/10/91 RAI by 10/92.                          |
| M80143 |         | [ 17]    | TS      | 2   | RN    | WATTS BAR 1 - FSAR AMENDMENT NO. 65 REVIEW   | (04/10/91) | (07/11/91) | (09/13/91C)  | (09/30/92T)               | (--/--/--)     | SSER 10 has Sec. 4.2 review. Only Chap. 12 remaining.       |
| M80152 |         | [ 23]    | TS      | 3   | RN    | WATTS BAR 1 - CONTAINMENT EFFECTS DUE TO REMOVAL OF BORON INJECTION TANK                 | (10/18/90) | (--/--/--) | (01/21/92C)  | (10/15/92T)               | (--/--/--)     | Started by TVA 5/2/84 letter. Amend. 69 info. under review. |
| M81063 |         | [ 7]     | TS      | 2   | RN    | WATTS BAR 1 - USE OF EAGLE 21 PROCESS PROTECTION SYSTEM                                  | (02/26/92) | (--/--/--) | (--/--/--)   | (02/28/93T)               | (--/--/--)     | More info. by 10/92. No site review planned. (Top 3)        |
| M81887 |         | [ 1]     | TS      | 2   | RN    | WATTS BAR UNIT 1 - USE OF VANTAGE - 5H FUEL DESIGN                                       | (08/24/92) | (--/--/--) | (--/--/--)   | (12/31/92T)               | (--/--/--)     | Under review by S.L. Wu, target 12/92.                      |
| M81959 |         | [ 11]    | TS      | 2   | LL    | WATTS BAR 1 - ASME CODE CASE N-491   | (10/23/91) | (--/--/--) | (--/--/--)   | (10/30/92T)               | (--/--/--)     | Per McLellan, SE by 9/92, if not sooner.                    |
| M82032 |         | [ 12]    | TS      | 2   | RN    | WATTS BAR 1 - FIFTH DIESEL GENERATOR NON-ELECTRICAL ISSUES                               | (09/24/91) | (--/--/--) | (--/--/--)   | (05/31/93T)               | (--/--/--)     | SSER 10. Address tornado damage to air intake by 4/93.      |
| M82367 |         | [ 11]    | TS      | 2   | RA    | WATTS BAR 1 - SHALLOW UNDER ANCHORS  | (10/16/91) | (--/--/--) | (04/30/92C)  | (10/31/92T)               | (--/--/--)     | Awaiting revised information per 8/25 telecon.              |
| M82644 |         | [ 8]     | TS      | 2   | RN    | WATTS BAR 1 - FSAR AMENDMENT 69.   | (01/21/92) | (07/14/92) | (09/30/92T)  | (12/31/92T)               | (--/--/NA)     | Awaiting response to 7/14/92 RAI on Chapter 14, 9/92.       |
| M82878 |         | [ 7]     | TS      | 2   | LL    | WATTS BAR 1 - ALTERNATIVE TO ASME III, SUBSECTION NC/ND PARA7153                         | (02/25/92) | (--/--/--) | (09/08/92C)  | (10/30/92T)               | (--/--/--)     | 9/8/92 revision under review by J. Huang.                   |
| M83202 |         | [ 5]     | PM      | 2   | RO    | WATTS BAR 1 - DOCUMENTATION OF STAFF ACTIVITIES RELATED TO QTC                           | (04/30/92) | (--/--/--) | (--/--/--)   | (12/30/92T)               | (--/--/--)     | NRR staff activities only, no TVA involvement.              |

Condensed Project Manager Report

| TaskID                            | MPA Num | Age (Mon) | Rev Mth | Pri | Actyp | Title   | Appl Date  | RAI Issued | RAI Response | Licensing Action Complete | Licensee Impl. | Comments   |
|-----------------------------------|---------|-----------|---------|-----|-------|---|------------|------------|--------------|---------------------------|----------------|--|
| M83261                            |         | [ 5]      | TS      | 2   | RN    | WATTS BAR 1 - TVA NUCLEAR POWER   | (04/17/92) | (--/--/--) | (--/--/--)   | (10/31/92T)               | (--/--/--)     | Under review by Mary-Ann Biamonte.                     |
| M83322                            |         | [ 4]      | TS      | 2   | RN    | WATTS BAR UNIT 1 - FSAR AMENDMENT 70  | (05/06/92) | (--/--/--) | (--/--/--)   | (12/30/92T)               | (--/--/--)     | Under review.  |
| M83525                            | B120    | [ 2]      | TS      | 3   | RR    | WATTS BAR 1 - GENERIC LETTER 92-01 REACTOR VESSEL STRUCTURAL INTEGRITY.                               | (07/07/92) | (--/--/--) | (--/--/--)   | (12/31/93T)               | (12/31/93T)    | Under review; will contact TVA if staff sees problems. |
| M83693                            | B118    | [ 9]      | PM      | 3   | RR    | WATTS BAR 1 - IPEEE FOR EXTERNAL EVENTS (GL 88-20) SUPPLEMENT 4                                       | (12/20/91) | (--/--/--) | (--/--/--)   | (12/31/95T)               | (--/--/--)     | Awaiting 1994 submittal.                               |
| M83837                            |         | [ 3]      | TS      | 2   | RN    | WATTS BAR 1-APPLICATION OF LEAK-BEFORE-BREAK TO PRESSURIZER SURGE LINE.                               | (06/22/92) | (--/--/--) | (--/--/--)   | (06/30/93T)               | (--/--/--)     | S. Sheng to begin review 11/92. OK with TVA?           |
| M84234                            |         | [ 25]     | TS      | 2   | RN    | WATTS BAR 1 - FSAR AMENDMENT 71.  | (08/05/90) | (--/--/--) | (--/--/--)   | (01/31/93T)               | (--/--/--)     | Under review by 8 NRR branches.                        |
| M84249                            |         | [ 2]      | TS      | 2   | RN    | WATTS BAR 1 - CONTROL ROD DRIVE MECHANISM SEISMIC QUALIFICATION.                                      | (07/30/92) | (--/--/--) | (--/--/--)   | (12/31/92T)               | (--/--/--)     | Awaiting infor. in Amend. 72?                          |
| M84367                            |         | [ 0]      | TS      | 2   | RO    | WATTS BAR 1 - FIVE STAR PRODUCTS - REQUEST FOR INFORMATION.   | (--/--/--) | (--/--/--) | (--/--/--)   | (12/31/92T)               | (--/--/--)     |  |
| M84429                            |         | [ 1]      | TS      | 2   | RN    | WATTS BAR 1 - SOLID RAD. WASTE PROCESS CONTROL PROGRAM.   | (08/27/92) | (--/--/--) | (--/--/--)   | (12/31/92T)               | (--/--/--)     | Plant Systems Branch to decide what review is needed.  |
| R00514                            |         | [ 40]     | TS      | 2   | RN    | "WATTS BAR UNIT 1: CORRECTIVE ACTION PROGRAM (CAP) PLAN FOR SEISMIC ANALYSIS" AND CIVIL CALC. PROGRAM | (05/22/89) | (01/04/91) | (07/27/92C)  | (12/31/92T)               | (01/31/93T)    | Response on Civil Calc. audit target for 12/92. OK?    |
| ..... Not Scheduled Actions ..... |         |           |         |     |       |   |            |            |              |                           |                |  |
| M40309                            |         | [ 42]     | TS      | 2   | DZ    | "WATTS BAR 1 - PROJECT MANAGEMENT ADMINISTRATION"   | (03/15/89) | (--/--/--) | (--/--/--)   | (--/--/--)                | (--/--/--)     |  |
| M72374                            |         | [ 0]      | TS      | 3   | DZ    | "WATTS BAR 1 LICENSEE PERFORMANCE EVALUATION"   | (--/--/--) | (--/--/--) | (--/--/--)   | (--/--/--)                | (--/--/--)     | Ongoing NRR work only, no TVA action needed.           |
| M72494                            |         | [ 0]      | PM      | 2   | DZ    | "WATTS BAR 1 - HEADQUARTERS FOCAL POINT FOR INFORMATION AND COMMUNICATIONS"                           | (--/--/--) | (--/--/--) | (--/--/--)   | (--/--/--)                | (--/--/--)     | Ongoing NRR work only, no TVA action needed.           |
| M72613                            |         | [ 0]      | PM      | 3   | DZ    | "WATTS BAR 1 - SALP REPORT PREPARATION AND MEETING ATTENDANCE"  | (--/--/--) | (--/--/--) | (--/--/--)   | (--/--/--)                | (--/--/--)     | Ongoing NRR work only, no TVA action needed.           |
| M83948                            | X201    | [ 0]      | TS      | 1   | RR    | WATTS BAR 1 - THERMO-LAG (BULLETIN 92-01)   | (--/--/--) | (--/--/--) | (--/--/--)   | (--/--/--)                | (--/--/--)     | Bulletin is for info. only for CP holders.             |