

January 14, 2008

Mr. Charles G. Pardee
Chief Nuclear Officer and Senior Vice President
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: LASALLE COUNTY STATION, UNIT 1 - WITHDRAWAL OF AN AMENDMENT
REQUEST TO TECHNICAL SPECIFICATION 5.5.13, "PRIMARY CONTAINMENT
LEAKAGE RATE TESTING" (TAC NO. MD5798)

Dear Mr. Pardee:

By letter dated June 18, 2007, as supplemented by letter dated September 7, 2007, Exelon Generation Company, LLC applied for an amendment to the LaSalle County Station (LSCS), Unit 1, Facility Operating License No. NPF-11. The proposed change would have modified facility Technical Specification (TS) 5.5.13 pertaining to primary containment leakage rate testing to reflect a one-time extension of the LSCS, Unit 1 primary containment Type A Integrated Leak Rate Test date from the current requirement of no later than June 13, 2009, to prior to startup following the thirteenth LSCS refueling outage for Unit 1. Subsequently, by letter dated October 12, 2007, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Stephen P. Sands, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-373

Enclosure: Notice of Withdrawal

cc w/encl: See next page

Mr. Charles G. Pardee
Chief Nuclear Officer and Senior Vice President
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

January 14, 2008

SUBJECT: LASALLE COUNTY STATION, UNIT 1 - WITHDRAWAL OF AN AMENDMENT
REQUEST TO TECHNICAL SPECIFICATION 5.5.13, "PRIMARY CONTAINMENT
LEAKAGE RATE TESTING" (TAC NO. MD5798)

Dear Mr. Pardee:

By letter dated June 18, 2007, as supplemented by letter dated September 7, 2007, Exelon Generation Company, LLC applied for an amendment to the LaSalle County Station (LSCS), Unit 1, Facility Operating License No. NPF-11. The proposed change would have modified facility Technical Specification (TS) 5.5.13 pertaining to primary containment leakage rate testing to reflect a one-time extension of the LSCS, Unit 1 primary containment Type A Integrated Leak Rate Test date from the current requirement of no later than June 13, 2009, to prior to startup following the thirteenth LSCS refueling outage for Unit 1. Subsequently, by letter dated October 12, 2007, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,
/RA/

Stephen P. Sands, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-373

Enclosure: Notice of Withdrawal

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

LPL3-2 R/F

RidsAcrsAcnwMailCenter

RidsNrrDorlLpl3-2

RidsRgn3MailCenter

RidsNrrPMSSands

RidsOgcRp

RidsNrrLAEWhitt

RidsNrrDorlDpr

ADAMS DOCUMENT: ML073610533

NRR-106

OFFICE	LPL3-2/PM	LPL3-2/LA	LPL3-2/BC
NAME	SSands:sp	EWhitt	RGibbs
DATE	1/14/08	1/14/08	1/14/08

OFFICIAL RECORD COPY

UNITED STATES NUCLEAR REGULATORY COMMISSION

EXELON GENERATION COMPANY, LLC

DOCKET NO. 50-373

NOTICE OF WITHDRAWAL OF APPLICATION FOR

AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Exelon Generation Company, LLC (the licensee), to withdraw its June 18, 2007, application for proposed amendment, as supplemented by letter dated September 7, 2007, to Facility Operating License No. NPF-11, for the LaSalle County Station (LSCS), Unit 1, located in Will County.

The proposed amendment would have revised the facility Technical Specification 5.5.13 pertaining to primary containment leakage rate testing, to reflect a one-time extension of the LSCS, Unit 1 primary containment Type A Integrated Leak Rate Test date from the current requirement of no later than June 13, 2009, to prior to startup following the thirteenth LSCS refueling outage for Unit 1.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on July 31, 2007 (72 FR 41784). However, by letter dated October 12, 2007, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated June 18, 2007, as supplemented by letter dated September 7, 2007, and the licensee's letter dated October 12, 2007, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located

at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by email to pdr@nrc.gov.

Dated at Rockville, Maryland, this 14th day of January, 2008.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Stephen P. Sands, Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

LaSalle County Station, Units 1 and 2

cc:

Corporate Distribution
Exelon Generation Company, LLC
via e-mail

LaSalle Distribution
Exelon Generation Company, LLC
via e-mail

LaSalle Senior Resident Inspector
U.S. Nuclear Regulatory Commission
via e-mail

Phillip P. Steptoe, Esquire
Sidley and Austin
One First National Plaza
Chicago, IL 60603

Assistant Attorney General
100 W. Randolph St. Suite 12
Chicago, IL 60601

Chairman
LaSalle County Board
707 Etna Road
Ottawa, IL 61350

Attorney General
500 S. Second Street
Springfield, IL 62701

Chairman
Illinois Commerce Commission
527 E. Capitol Avenue, Leland Building
Springfield, IL 62706

Robert Cushing, Chief, Public Utilities Division
Illinois Attorney General's Office
100 W. Randolph Street
Chicago, IL 60601

Illinois Emergency Management Agency
Division of Disaster Assistance &
Preparedness
via e-mail