




## Survey Unit Release Record

<b>Design #</b>	EP-1.51C-4	<b>Revision #</b>	Original	<b>Page 1 of 3</b>
<b>Survey Unit #(s)</b>	1.51C-4			
<b>Description</b>	<p>1) Embedded Pipe (EP) Survey Unit 1.51C-4 meets the definition of embedded pipe for Plum Brook Reactor Facility (PBRF).</p> <p>2) EP 1.51C-4 is a Class 1, Group 1 survey unit as per the PBRF Final Status Survey Plan (FSSP) and Technical Basis Document (TBD)-06-004.</p> <p>3) Surveys in EP 1.51C-4 were performed using a scintillation detector optimized to measure gamma energies representative of Co-60. Sample #EP 3-9 from Survey Request (SR)-13 was referenced for this decision.</p> <p>4) Survey Instructions for this survey unit are incorporated into and performed in accordance with (IAW) the Babcock Services Incorporated (BSI)/LVS-002, Work Execution Package (WEP) 05-006. Survey instructions described in this document constitute "Special Methods" and the survey design used in the acquisition of survey measurements.</p> <p>5) Instrument efficiency determinations are developed in accordance with the BSI/LVS-002, WEP 05-006, these determinations are appropriate for the types of radiation involved and the media being surveyed.</p>			
<b>Approval Signatures</b>				<b>Date:</b>
FSS/Characterization Engineer				11-24-07
Technical Reviewer (FSS/Characterization Engineer)				12-5-07
FSS/Characterization Manager	R. Case 			12/10/07

## Survey Unit: 1.51C-4

**1.0** History/Description

- 1.1 The subject pipe system is a 4" drain line located on the drain system for the annulus on the -25' elevation of the Reactor Building.
- 1.2 EP 1.51C-4 is approximately 37 feet in length.

**2.0** Survey Design Information

- 2.1 EP 1.51C-4 was surveyed IAW Procedure #BSI/LVS-002.
- 2.2 100% of the 4" ID pipe was accessible for survey. The accessible 4" ID pipe was surveyed by static measurement at one foot increments, for a total of 37 survey measurements.
- 2.3 Surface area for the 4" ID piping is 973 cm<sup>2</sup> for each foot of piping, corresponding to a total 4" ID piping surface area of 35,996 cm<sup>2</sup> (3.5 m<sup>2</sup>) for the entire accessible length of (37') of 4" piping.

**3.0** Survey Unit Measurement Locations/Data

- 3.1 Pipe interior radiological survey forms are provided in Attachment 2 of this release record.

**4.0** Survey Unit Investigations/Results

- 4.1 None

**5.0** Data Assessment Results

- 5.1 Data assessment results are provided in the EP/Buried Pipe (BP) Survey Report provided in Attachment 1.
- 5.2 All measurement results are less than the Derived Concentration Guideline Level (DCGL) for radionuclide specific EP that corresponds to the 1 mrem/yr dose goal established in Table 3-3 of the FSSP.
- 5.3 When implementing the Unity Rule, provided in Section 3.6.3 of the FSSP, and applying the Nuclide Fraction (NF), provided in TBD-06-004, the survey unit that is constituted by EP 1.51C-4 passes FSS.
- 5.4 Background was not subtracted from the survey measurements and the Elevated Measurement Comparison (EMC) was not employed for the accessible portion of this survey unit.

Survey Unit: 1.51C-4

## Statistical Summary Table

Statistical Parameter	4" Pipe
Total Number of Survey Measurements	37
Number of Measurements >MDC	31
Number of Measurements Above 50% of DCGL	0
Number of Measurements Above DCGL	0
Mean	0.0196
Median	0.0141
Standard Deviation	0.0150
Maximum	0.0637
Minimum	0.0047

**6.0** Documentation of evaluations pertaining to compliance with the unrestricted use limit of 25 mrem/yr and dose contributions from Embedded Pipe and radionuclides contributing 10% in aggregate of the total dose for both structural scenarios and soils.

6.1 A review of the survey results has shown that the dose contribution for the accessible portion of EP 1.51C-4 to be less than 1 mrem/yr. The dose contribution is estimated to be 0.020 mrem/yr based on the average of the actual gross counts.

**7.0** Attachments

Attachment 1 – BSI EP/BP Survey Report

Attachment 2 -Pipe Interior Radiological Survey Form

Attachment 3 – DQA Worksheet

Attachment 4 –Disc containing RR for EP 1.51C-4 & Spreadsheet

**SECTION 7**  
**ATTACHMENT 1**  
3 **PAGE(S)**



## BSI EP/BP SURVEY REPORT

Pipe ID	EP 1.51C-4	Survey Location	Annulus Floor Drain 25' el.
Survey Date	15-Feb-06	2350-1 #	203488
Survey Time	13:20	Detector-Sled #	Bicron 1MG1 LVS-1/101
Pipe Size (in.)	4	Detector Efficiency	0.00052
DCGL (dpm/100cm2)	2.41E+05	Pipe Area Incorporated by Detector Efficiency (in cm2)	973
Pipe Area Incorporated by Survey Data (m <sup>2</sup> )	3.6	Field BKG (cpm)	24.4
Routine Survey	X	Field MDCR (cpm)	20.0
QA Survey		Nominal MDC (dpm/100cm2)	1,577
Survey Measurement Results			
Total Number of Survey Measurements			37
Number of Measurements >MDC			31
Number of Measurements Above 50% DCGL			0
Number of Measurements Above DCGL			0
Mean			0.0196
Median			0.0141
Standard Deviation			0.0150
Maximum			0.0637
Minimum			0.0047
Survey Technician(s)		DEBRAUX	
Survey Unit Classification		1	
TBD 06-004 Piping Group		1	
SR-13 Radionuclide Distribution Sample		EP 3-9	
Measured Nuclide		Co-60	
Area Factor/EMC Used		No	
Pass/Fail FSS		Pass	
MREM/YR Contribution		<1	
COMMENTS: ACTIVITY VALUES NOT BACKGROUND CORRECTED			
RP Engineer   Date		Dal Randall 11-29-07	

**EP 1.51C-4**  
**4" Pipe**  
**TBD 06-004 Group 1**

Measurement #	gcpm	ncpm	Co-60 activity (total dpm)	Co-60 activity (dpm/100cm2)	Cs-137 activity (dpm/100cm2)	Eu-152 activity (dpm/100cm2)	Eu-154 activity (dpm/100cm2)	Nb-94 activity (dpm/100cm2)	Ag-108m activity (dpm/100cm2)	Unity
1	23	23	44,231	4,546	180	4,313	1,146	133	32	0.027
2	14	14	26,923	2,767	110	2,625	698	81	19	0.017
3	28	28	53,846	5,535	219	5,250	1,396	162	39	0.033
4	12	12	23,077	2,372	94	2,250	598	69	17	0.014
5	14	14	26,923	2,767	110	2,625	698	81	19	0.017
6	11	11	21,154	2,174	86	2,063	548	63	15	0.013
7	4	4	7,692	791	31	750	199	23	6	0.005
8	12	12	23,077	2,372	94	2,250	598	69	17	0.014
9	16	16	30,769	3,163	125	3,000	798	92	22	0.019
10	9	9	17,308	1,779	71	1,688	449	52	12	0.011
11	9	9	17,308	1,779	71	1,688	449	52	12	0.011
12	15	15	28,846	2,965	118	2,813	748	87	21	0.018
13	11	11	21,154	2,174	86	2,063	548	63	15	0.013
14	17	17	32,692	3,360	133	3,188	847	98	23	0.020
15	10	10	19,231	1,977	78	1,875	498	58	14	0.012
16	10	10	19,231	1,977	78	1,875	498	58	14	0.012
17	7	7	13,462	1,384	55	1,313	349	40	10	0.008
18	10	10	19,231	1,977	78	1,875	498	58	14	0.012
19	11	11	21,154	2,174	86	2,063	548	63	15	0.013
20	12	12	23,077	2,372	94	2,250	598	69	17	0.014
21	7	7	13,462	1,384	55	1,313	349	40	10	0.008
22	13	13	25,000	2,570	102	2,438	648	75	18	0.015
23	15	15	28,846	2,965	118	2,813	748	87	21	0.018
24	17	17	32,692	3,360	133	3,188	847	98	23	0.020
25	11	11	21,154	2,174	86	2,063	548	63	15	0.013
26	7	7	13,462	1,384	55	1,313	349	40	10	0.008
27	7	7	13,462	1,384	55	1,313	349	40	10	0.008
28	13	13	25,000	2,570	102	2,438	648	75	18	0.015
29	12	12	23,077	2,372	94	2,250	598	69	17	0.014
30	16	16	30,769	3,163	125	3,000	798	92	22	0.019
31	7	7	13,462	1,384	55	1,313	349	40	10	0.008

**EP 1.51C-4**  
**4" Pipe**  
**TBD 06-004 Group 1**

Measurement #	gcpm	ncpm	Co-60 activity (total dpm)	Co-60 activity (dpm/100cm2)	Cs-137 activity (dpm/100cm2)	Eu-152 activity (dpm/100cm2)	Eu-154 activity (dpm/100cm2)	Nb-94 activity (dpm/100cm2)	Ag-108m activity (dpm/100cm2)	Unity
32	16	16	30,769	3,163	125	3,000	798	92	22	0.019
33	18	18	34,615	3,558	141	3,375	897	104	25	0.021
34	46	46	88,462	9,093	360	8,625	2,293	265	63	0.054
35	50	50	96,154	9,883	392	9,375	2,492	288	69	0.059
36	54	54	103,846	10,674	423	10,126	2,692	311	74	0.064
37	50	50	96,154	9,883	392	9,375	2,492	288	69	0.059
									MEAN	0.020
									MEDIAN	0.014
									STD DEV	0.015
									MAX	0.064
									MIN	0.005

**SECTION 7**  
**ATTACHMENT 2**  
3 **PAGE(S)**



### Pipe Interior Radiological Survey Form

Date: 2-15-06 Time: 1320  
 Pipe ID#: 1.51 Pipe Diameter: 4" Access Point Area: 1.51C  
 Building: RX Elevation: -2.5 System: ANNULUS FLOOR DRAIN  
 Type of Survey Investigation \_\_\_\_\_ Characterization \_\_\_\_\_ Final Survey X Other \_\_\_\_\_  
 Gross \_\_\_\_\_ Co60 ✓ Cs \_\_\_\_\_  
 Detector ID# / Sled ID# BICRON IMG-1 / LVS-1 101  
 Detector Cal Date: 12-20-05 Detector Cal Due Date: 12-20-06  
 Instrument: 2350-1 Instrument ID #: 203488  
 Instrument Cal Date: 11-17-05 Instrument Cal Due Date: 11-17-06

From the Daily Pipe Survey Detector Control Form for the Selected Detector

Background Value 24.4 cpm gn  
 MDCR<sub>static</sub> 20 cpm gn  
 Efficiency Factor for Pipe Diameter 0.00052 (from detector efficiency determination)  
 MDC<sub>static</sub> 1577 dpm/ 100 cm<sup>2</sup>  
 Is the MDC<sub>static</sub> acceptable? (Yes) No (if no, adjust sample count time and recalculate MDCR<sub>static</sub>)  
 Comments: INITIAL SURVEY

Technician Signature C. DEBRAUX / [Signature]

### Pipe Interior Radiological Survey

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm <sup>2</sup>
1	1	1	23	n/a	n/a	n/a
2	2	1	14			
3	3	1	28			
4	4	1	12			
5	5	1	14			
6	6	1	11			
7	7	1	4			
8	8	1	12			
9	9	1	16			
10	10	1	9			

Package Page 1 of 2

REFERENCE COPY



1.51 4"

275-06

I

I

SECTION 375  
SCALE 1/2" = 1'-0"

1 1/2" DRIP RISER UP TO  
AIR CONDITIONER #13  
AT EL. 8'-0"

REFERENCE COPY

Point B

51

37

FLOOR EL. -25'-0"

Point C

51

31

32

Sump A

Sump B

QUADRANT "D"  
FLOOR EL. -25'-0"

FOR CONTINUATION  
SEE DWG. PF-00406

POW-SHUTDOWN PUMPS  
SEAL BOX DRAINS

PF-00375

Elect.  
Junction  
Box - pt. D

18" x 32" ELECTRICAL PIT  
BOT TO: ELEVATION -25'-6"

Elect.

(FI)

(FI)

AP OFF  
1.5 S.S.  
1.0 S.S.  
PER 10'

iter

SLOPE 1/8" PER FT

SEE CONTAINMENT VESSEL  
RISER DIAG. (THIS SHEET)

DISCHARGE FROM LOCKHEED  
CAVE SUMP (EL. -25'-0")

PITCH 4" HOT DRAIN - 1" PER 10'-0"

26'-10 3/4" EL

4" FLOOR DRAIN  
-25'-5 3/8" EL

4" FLOOR DRAIN

2" DRAIN RISER - FOR  
CONTINUATION  
SEE DWG. PF-00259

JOSAM 5586 WITH  
CHROME GATE

SEE 3/4" FOR TYPICAL PURGE

JOSAM TYPE 0412  
ANGLE DRAIN

2" DRAIN RISER - FOR CONTINUATION  
SEE DWG. PF-00259

3" QEC RECIRC-PURGE QUAD. D

10" QEC PUMP OUT DRAIN

26'-7 1/2" EL

27'-6" EL

PITCH 4" HOT - COLD DRAIN 1/8"

I

**SECTION 7**  
**ATTACHMENT 3**  
**1     PAGE(S)**



### DQA Check Sheet

Design #	EP 1.51C-4	Revision #	Original			
Survey Unit #	EP 1.51C-4					
<b>Preliminary Data Review</b>						
<b>Answers to the following questions should be fully documented in the Survey Unit Release Record</b>				Yes	No	N/A
1. Have surveys been performed in accordance with survey instructions in the Survey Design?				X		
2. Is the instrumentation MDC for structure static measurements below the DCGL <sub>W</sub> for Class 1 and 2 survey units, or below 0.5 DCGL <sub>W</sub> for Class 3 survey units?						X
3. Is the instrumentation MDC for embedded/buried piping static measurements below the DCGL <sub>W</sub> ?				X		
4. Was the instrumentation MDC for structure scan measurements, soil scan measurements, and embedded/buried piping scan measurements below the DCGL <sub>W</sub> , or, if not, was the need for additional static measurements or soil samples addressed in the survey design?						X
5. Was the instrumentation MDC for volumetric measurements and smear analysis < 10% DCGL <sub>W</sub> ?						X
6. Were the MDCs and assumptions used to develop them appropriate for the instruments and techniques used to perform the survey?				X		
7. Were the survey methods used to collect data proper for the types of radiation involved and for the media being surveyed?				X		
8. Were "Special Methods" for data collection properly applied for the survey unit under review?				X		
9. Is the data set comprised of qualified measurement results collected in accordance with the survey design, which accurately reflects the radiological status of the facility?				x		
<b>Graphical Data Review</b>						
1. Has a posting plot been created?						X
2. Has a histogram (or other frequency plot) been created?						X
3. Have other graphical data tools been created to assist in analyzing the data?						X
<b>Data Analysis</b>						
1. Are all sample measurements below the DCGL <sub>W</sub> (Class 1 & 2), or 0.5 DCGL <sub>W</sub> (Class 3)?				X		
2. Is the mean of the sample data < DCGL <sub>W</sub> ?				X		
3. If elevated areas have been identified by scans and/or sampling, is the average activity in each elevated area < DCGL <sub>EMC</sub> (Class 1), < DCGL <sub>W</sub> (Class 2), or < 0.5 DCGL <sub>W</sub> (Class 3)?						X
4. Is the result of the Elevated Measurements Test < 1.0?						X
5. Is the result of the statistical test ( <i>S</i> + for Sign Test or <i>W</i> <sub>r</sub> for WRS Test) ≥ the critical value?						X
Comments:						
FSS/Characterization Engineer (print/sign)		<i>Date Randall / Oak Parkall</i>			Date	11-29-07
FSS/ Characterization Manager (print/sign)		<i>R. Case</i>			Date	12/10/07

**SECTION 7**  
**ATTACHMENT 4**  
**1 DISC**