

ENCLOSURE 6
WATTS BAR NUCLEAR PLANT (WBN)
CALCULATION WBN-EEB-MS-TI11-0062
DIESEL GENERATOR CONTROL POWER SYSTEM

9206260082 920615
PDR ADOCK 05000390
A PDR

QA Record

EBASCO SERVICES INCORPORATED
DNE CALCULATIONS

Page 1A

TITLE 125V DC DIESEL GENERATOR (DG) CONTROL POWER SYSTEM EVALUATION		Plant/Unit WATTS BAR UNIT 1 & 2	
PREPARING ORGANIZATION NE, Ebasco Services Inc.		KEY NOUNS (Consult RIMS DESCRIPTORS LIST) DIESEL GEN, PWR SYS, CALC, BATTERIES	
BRANCH/PROJECT IDENTIFIERS WBN-EEB-MS-TI11-0062		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in. Rev (for RIMS' use) RIMS accession number RO 90021480004 826 90 0202406 <i>11-2-77 3/31/92</i>	
APPLICABLE DESIGN DOCUMENT(S) WB-DC-30-27		R4 APR 08 1992	85 B18 '92 0331 255 B26 '92 0411 400
SAR SECTION(S) 8.3	UNID SYSTEM(S) 82	R	
Revision 0	R4	R5	R
ECN NO. (or indicate Not Applicable) N/A <i>M.L.M 3/25/92</i>	SEE REV. LOG	<i>See rev. Log.</i>	Safety-related? Yes [X] No [] Statement of Problem VERIFY ADEQUACY OF DESIGN AND COMPLIANCE WITH DESIGN CRITERIA AND SAR REQUIREMENTS.
Prepared C.G. Peterson*	<i>M.L. Madson 3-25-92</i>	<i>4/10/92 Peterson</i>	
Checked W.J. Holbert*	<i>3-26-92 E. J. Johnson</i>	<i>4/10/92</i>	
Reviewed G.L. Nicely*	<i>3-26-92 G.L. Nicely</i>	<i>4/11/92</i>	
Approved M.C. Brickey*	<i>3/30/92 M.C. Brickey</i>	<i>4/11/92</i>	
Date 2-2-90	3/30/92	4/11/92	
USE FORM TVA 10534	List all pages added by this revision See rev. Log.	See rev. Log.	
IF MORE SPACE REQUIRED	List all pages deleted by this revision Log	See rev. Log.	
	List all pages changed by this revision Log	See rev. Log.	

ORIGINAL

Abstract:

These calculations contain an unverified assumption(s) that must be verified later. Yes [X] No []

This calculation evaluates the adequacy of the 125V DC DG control power system for battery sizing, charger sizing, protective device sizing, short circuit and coordination, Appendix R, Reg Guide 1.75-Associated circuits, cascade fuses and maximum voltage to control circuit components. Adequacy of minimum voltage to control circuit components is verified through pre-op test TVA-14D. *See sections 8.0 and 9.0 for results and conclusions.*

* See sheet 1 for original signatures.

See revision log for total number of pages and FSAR compliance review.

[] Microfilm and store calculations in RIMS Service Center
[X] Microfilm and return calculations to: ~~DCRM, TSOB, WBNP~~ Calculation Control Center
RIMS, SL 26 C-K D. Kilgore, TR-E7 WBNP Address: ~~CCC, A-10B, WBNP~~ 100 IE, WBN

THIS SHEET ADDED BY REV 4..

TITLE <i>125VDC Diesel Generator (DG) Control Power System Evaluation</i>		PLANT/UNIT <i>Watts Par Unit 1 & 2</i>	
PREPARING ORGANIZATION <i>NE-EE-WBER</i>		KEY NOUNS (Consult RIMS DESCRIPTORS LIST) <i>Diesel Gen, Pur Sys, Calc, Batteries</i>	
BRANCH/PROJECT IDENTIFIERS <i>WBA-EEB-MS-TII-0062</i>		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in.	
APPLICABLE DESIGN DOCUMENT(S) <i>WB-DC-30-27</i>		Rev (for RIMS' use) (136)	RIMS accession number
SAR SECTION(S) <i>8.3</i>	UNID SYSTEM(S) <i>82</i>	RO <i>900214B0004</i>	<i>B26 '90 0202 40</i>
		R1 <i>900327B0009</i>	<i>B26 '90 0308 40</i>
		R2 <i>911022C0041</i>	<i>B26 '91 0919 40</i>
		R3 <i>920110C0010</i>	<i>B26 '91 1219 40</i>

Revision 0	R1	R2	R3
ECN No. (or indicate Not Applicable) <i>N/A</i>	<i>N/A</i>	<i>see rev. log</i>	<i>SEE REV. LOG</i>
Prepared <i>C. Peterson</i>	<i>3/8/90</i>	<i>9/18/91</i>	<i>12/19/91</i>
Checked <i>W.S. Herbert</i>	<i>3/8/90</i>	<i>9/18/91</i>	<i>12/19/91</i>
Reviewed <i>[Signature]</i>	<i>3/8/90</i>	<i>9/18/91</i>	<i>12/19/91</i>
Approved <i>[Signature]</i>	<i>3/8/90</i>	<i>9/18/91</i>	<i>12/19/91</i>
Date <i>2-2-90</i>	<i>3-8-90</i>	<i>9-19-91</i>	<i>12/19/91</i>
List all pages added by this revision.		<i>see rev. log</i>	<i>SEE REV LOG</i>
List all pages deleted by this revision.		<i>see rev. log</i>	<i>SEE REV LOG</i>
List all pages changed by this revision.		<i>see rev. log</i>	<i>SEE REV LOG</i>

Safety-related? Yes No

Statement of Problem
Verify adequacy of design and compliance with design criteria and SAR requirements.

ORIGINAL

Abstract

These calculations contain an unverified assumption(s) that must be verified later. Yes No

This calculation evaluates the adequacy of the 125VDC DG Control Power System for battery sizing, charger sizing, protective device sizing, short circuit and coordination, Appendix R, Reg Guide 1.75 associated circuits, cascade fuses and maximum voltage to components. Adequacy of minimum voltage to control circuit components is verified through pre-op test TNA-14P.

R1, FSAR Compliance Review [Signature] 3-8-90

R0, FSAR Compliance Review [Signature] 1-22-90

For the total number of pages see the revision log

Microfilm and store calculations in RIMS Service Center.

Microfilm and return calculations to: *Calculation Control Center*

Microfilm and destroy. *EEB*

Address: *QAC-EC-WBN* *EEB*

cc: RIMS, SL 26 C-K

Title: 125VDC D6 Control Power System Evolution

REVISION LOG
WB-EEB-140-TFI
0062

Revision No.	DESCRIPTION OF REVISION	Date Approved
0	<p>Initial issue 136 pages.</p> <p>FSAR Review:</p> <p>FSAR section 8.3 and 9.5.6 were reviewed to verify compliance. The specific values for battery loading require revision to reflect the results of this calculation. GP 1/29/90 WTH 1/30/90</p>	
1	<p>Affected design inputs were reviewed and were corrected as necessary. Affected engineering judgements and assumptions were reviewed and were revised as necessary to ensure adequacy. Revised the cable insulation damage temperature for polyethylene cable from 125°C to 150°C per R2 of Design Criteria WB-DC-30-13 dated 2/13/90. Revised time-current curves and short circuit values to reflect the change in insulation damage temperature to 150°C. Changed assumption 5.9 to an unverified assumption and expanded the conclusions in paragraph 9.13. There is no impact to the above FSAR review. Pages revised are coversheet, 6, 11, 21, 26, 27, 29, 36, 37, 39, 41, & 45. Total number of pages 136. WTH 3/8/90 GP 3/3/90</p>	<p>DEC 10</p> <p>↑</p>

TITLE: 125V DC DG CONTROL POWER SYSTEM EVALUATION		REVISION LOG
		WBN EEB-MS-TI11-0062
REVISION NUMBER	DESCRIPTION OF REVISION	DATE APPROVED
4	<p>ADDED ATTACHMENT S-15660-A (PAGES 1 THRU 7)</p> <p>1. DOCUMENTED REPLACEMENT FUSE FOR "MIS 1"</p> <p>ADDED PAGES: 1A, 2B, 3C DELETED PAGES: NONE REVISED PAGES: 4 TOTAL PAGES IN ENTIRE CALCULATION: 85</p> <p>REVIEWED REV. 4 TO VERIFY THAT THE UVA'S WERE APPROPRIATELY CONSIDERED FOR THE EFFECT ON DESIGN MARGINS AND THAT THE RESULTS AND CONCLUSIONS ARE UNCHANGED. EXISTING DESIGN MARGINS ARE NOT ADVERSELY AFFECTED BY THIS REVISION AND, THEREFORE, EXISTING DESIGN INPUTS AND PREVIOUSLY MADE ENGINEERING JUDGEMENTS AND ASSUMPTIONS ARE NOT INVALIDATED.</p> <p>SECTION 8.3.2 OF THE FSAR WAS REVIEWED AND NO DISCREPANCIES IDENTIFIED. <i>m.e.m 3/25/92</i></p> <p>R4 FSAR COMPLIANCE REVIEW <i>ABC/LE 3/30/92</i></p>	<p>SEE COVER SHEET</p> <p><i>m.e.m 3/25/92</i> <i>3-26-92</i></p>
5	<p><i>Revised per corrective action for WOPER 920037 to re-evaluate battery and battery charger sizing for corrected dc fuel oil and dc lube oil pump motor starting transients. Added evaluation of KER-7 replacement cells (Dew M11793A) for capacity only.</i></p> <p><i>Revised pages 1A, 2B, 4, 6, 9, 10, 11, 13, 14, 29, 31, 12</i></p> <p><i>Added pages 3D, 12A, 13a-13d, 47-55.</i></p> <p><i>Total Pages R5 = 100</i></p> <p><i>Reviewed R5 to verify that the UVAs were appropriately considered for effect on design margins and that the results and conclusions are unchanged. Existing design margins are not adversely affected by this revision and therefore, existing design margins inputs and previously made engineering judgements and assumptions are not invalidated.</i></p> <p><i>FSAR section 8.3 was reviewed and does not require changes for this revision.</i></p> <p><i>R5 FSAR Compliance C.C. Lyke for MCB / 4/11/92</i></p>	<p><i>See cover sheet for approval and date.</i></p> <p><i>4/10/92</i> <i>EB 4/10/92</i></p>

THIS SHEET ADDED BY REV 4

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEB-MS-T111-0062
Calculation No.

3
Revision

Method of design verification (independent review) used (check method used):

- | | | |
|----|-----------------------|-------------------|
| 1. | Design Review | <u> *</u> |
| 2. | Alternate Calculation | <u> NR</u> |
| 3. | Qualification Test | <u> NR</u> |

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

* Design verification has been performed by the design review method in accordance with the guidelines set forth by Project Procedure E-76-TVA.

~~_____

_____~~

J. J. H.
Design Verifier
(Independent Reviewer)

12-19-91 J.J.H.
12-17-91
Date

THIS SHEET ADDED BY REV 3

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEB-MS-T111-0062
Calculation No.

4
Revision

Method of design verification (independent review) used (check method used):

- | | |
|--------------------------|-------------------|
| 1. Design Review | <u> *</u> |
| 2. Alternate Calculation | <u> NR</u> |
| 3. Qualification Test | <u> NR</u> |

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

*Design verification has been performed by the design review method in accordance with the guidelines set forth by project procedure E-76-TVA.



Design Verifier
(Independent Reviewer)

3-26-92
Date

THIS SHEET ADDED BY REV 4

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEBMSTII 0062
Calculation No.

R5
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Independently reviewed calculation WBN EEB-MS-TI-0062 revision 5 for technical adequacy as addressed in NEP 3.1, Attachment 10.

The design input data and assumptions were verified and were found appropriate and reasonable. The methodology, results and conclusions are technically adequate.

E. J. Iglesias
Design Verifier
(Independent Reviewer)

4/10/92
Date

TABLE OF CONTENTS	Page
Cover Sheet	1
Revision Log	2
Calculation Design Verification	3
Table of Contents	4
1.0 Purpose	5
2.0 Assumptions	5
3.0 References and Sources of Design Input	5
4.0 Design Input Data	6
5.0 Documentation of Assumptions	8
6.0 Calculation/Analysis	11
7.0 Supporting Graphics	23
8.0 Summary of Results	29
9.0 Conclusions	31
10.0 Attachments	
10.1 Chart Recording from Preop Test WBN-TVA-14D, step 5.4.1.35	36
10.2 C&D Batteries, Discharge Characteristics, Type DC and DCU.	39
10.2 Square D - FA Cahracteristic Curve	40
10.4 Buss Time-Current Characteristic; KLM	41
10.5 Buss Time-Current Characteristic; FNM	42
10.6 Square D Molded Case Circuit Breaker Cat. Data	43
10.7 Buss Time-Current Characteristic; Average Melting Time - Type NON	44
10.8 C&D Batteries, DCU Cell Specifications	45
10.9 Telecopy, MKW Power Suystems, DC Lube Oil Pumps	46
10.10 Maintenance Request, MR A-617680	47
10.11 C&D Batteries, KCR Cell Specifications	54
10.12 C&D Batteries, Discharge Characteristics, Type KCR	55
 P04575A, Evaluation of DCN Modification	 26 pp
S15660A, Evaluation of DCN Modification	7 pp

R5
up 4/10/4:
E194/10/4

R3
R4
R5
up 4/10/4:
E194/10/4

1.0 Purpose

The purpose of this calculation is to evaluate the adequacy of the 125VDC Diesel Generator Control Power System for compliance with FSAR and design criteria requirements for the following:

- battery sizing
- battery charger sizing
- protective device sizing
- short-circuit protection and coordination
- Appendix R power supply and associated circuits
- Reg Guide 1.75 associated circuits
- cascade fuse analysis
- voltage to components

2.0 Assumptions

Refer to Section 5.0 for documentation and justification of assumptions.

3.0 References and Sources of Design Input Data

- 3.1 WBN FSAR Sections 8.3.
- 3.2 Design Criteria WB-DC-30-27, "AC and DC Control Power Systems", DIMS WB-DC-30-27-1 (B26890324040), WB-30-27-2 (B26900510078).
- 3.3 WBN Preop Test 14D R0.
- 3.4 TVA drawings and vendor documents listed in Table 3.4, (page 7).
- 3.5 DS-E8.1.1 R7, "Substitution Standard for Low-Voltage Power and Control Fuses (600 Volts or Less)".
- 3.6 IEEE Standard 485 (1978), IEEE Recommended Practice for Sizing Large Lead Storage Batteries for Generating Stations and Substations".
- 3.7 SQN Calculation SQN-CPS-007 R0, "Diesel Generator Battery Capacity", B43861210901.
- 3.8 SQN Calculation SQN-CPS-012 R0, "Diesel Generator Lube Oil Pump Voltage", B43870401904.
- 3.9 Walkdown data for DG distribution panels included as attachment to memo from R.W. Bradford to H.B. Bounds, dated Nov. 28, 1988, "Watts Bar Nuclear Plant-Unit 1 and 2-Walkdown of Electrical Equipment -Walkdown Procedure WP-37", C24881128629.

- 3.10 National Electric Code, Chapter 9, Table 8, "Properties of Conductors" (dc resistance at 25°C).
- 3.11 DS-E12.6.3 R2, "Auxiliary and Control Power Cable Sizing, up to 15,000 Volts".
- 3.12 Design Criteria WB-DC-30-13 R2, "10 CFR 50, Appendix R, Type I, II, and III Circuits".
- 3.13 C & D Batteries, Discharge Characteristics, Type DU and DCU (Att. 10.2); Type KCR (Att. 10.12).
- 3.14 Buss fuse time-current characteristics for KLM and FNM fuses, Form FSB, (Attachments 10.4 and 10.5).
- 3.15 Square-D FA characteristic curve for 15A breaker, curve no. 650-241, (Attachment 10.3).
- 3.16 Square-D molded-case circuit breaker catalog data, (Attachment 10.6).
- 3.17 EEB-TI-7, "AC/DC Short-Circuit Analysis".
- 3.18 EEB-TI-8, "AC/DC Short-Circuit Protection".
- 3.19 EE PM87-26 R2, "Cable Length/Impedance to be Used in Electrical Calculations".
- 3.20 EE PM88-03 R0, "Calculations Which Identify Limiting Conditions".
- 3.21 IEEE Sed 946-1985, "IEEE Recommended Practice for the Design of Safety-Related DC Auxiliary Power Systems for Nuclear Power Generating Stations".
- 3.22 Telecopy from MKW Power Systems to TVA (J. Mannone, ESI), start time for DC lube oil pumps.
- 3.23 Maintenance Request Form A-617680, DC lube oil and DC fuel oil motor starting currents, (Att. 10.10).

RS 4/10/82
ESJ 4/10/82

RS 4/10/82
ESJ 4/10/82

4.0 Design Input Data

The design input data, provided by sources listed in Section 3.0, is specifically documented in the analysis in Section 6.0.

TABLE 3.4-REFERENCE DRAWINGS

15N210-4 R10
 15W814-5 R24
 45W727 R9
 45W728-1 R6
 45W760-82-1 R9,-2 R7,-3 R9,-4 R13,-5 R12,-6 R13,-11 R6,
 -12 R5,-13 R8,-14 R8,-15 R7,-16 R5
 45W1761-1 R20
 45W1762-1 R14
 45W1763-1 R19
 45W1780-1 R15,-2 R8,-3 R14,-4 R10,-5 R5,-6 R10
 45W1781-1 R16,-2 R8,-3 R13,-4 R10,-5 R2,-6 R8
 45W1782-1 R8,-2 R6,-3 R6,-4 R7,-5 R2,-6 R7
 45W1787-1 R14
 45W2761-1 R17
 45W2763-1 R19
 45W2780-1 R14,-2 R9,-3 R13,-4 R11,-5 R2,-6 R9
 45W2781-1 R16,-2 R9,-3 R14,-4 R10,-5 R2,-6 R8
 47E235-29 R2,-30 R2

Pull Card Data

PL2512A	PL3336B	PL3349B	PP504A
PL2517A	PL3337B	PL3350B	PP508A
PL2564B	PL3338B	PL3351B	PP622B
PL2569B	PL3339B	PL3354S	PP624B
PL3293S	PL3340A	PL3355S	PP628B
PL3323A	PL3341A	PL3356S	PP742B
PL3329A	PL3342A	PL3357S	PP744B
PL3330A	PL3343A	PL3358S	PP748B
PL3331A	PL3344A	PL3359S	PP1627S
PL3332A	PL3345A	PP382A	PP1628S
PL3333A	PL3346B	PP384A	PP1640S
PL3334B	PL3347B	PP388A	PP1678S
PL3335B	PL3348B	PP502A	PP1880S

Vendor Documents

Contract 83090
 DG Manual Vol 1&2,TVA IDs 979,980 (DG 1A-A,1B-B,2A-A,2B-
 B);DG Manual Vol 1&2,TVA IDs 1548,1549 (DG C-S)
 650-242,244;655-241
 6036B11010 RC, SH 1-10
 6036C04501 RA
 C379C11501 R905
 6036C11501 R904
 6036F07006 RO
 6036F07001 RO

5.0 Documentation of Assumptions

- 5.1 The minimum ambient temperature of the rooms containing the diesel batteries is 50°F.

Justification: TVA drawings 47E235-29R2 and 47E235-30R2 list the average DG room temperature at 75°F and a normal minimum of 50°F. Supplemental heat will be provided to assure the room temperature is 50°F or higher. Ref. DCN M11594A.

- 5.2 The diesel batteries shall support two start attempts; one at the beginning of its 30 minute duty cycle and the other at the end.

Justification: If the diesel fails to reach 200 rpm within 5 seconds of initial start, a fail to start condition exists and the diesel is locked out, requiring a manual reset for a restart attempt. Experience with the diesel has proven that if it does not start at the initial start command, the time required for response and problem correction is significant such that it is reasonable to assume one subsequent restart attempt in the 30 minute period. Assuming the second attempt occurs in the final minute is conservative.

- 5.3 It is assumed for short-circuit analysis that the DG battery system voltage is determined by the base emf of the battery at 2.06 volts-per-cell such that the battery voltage used in analysis is 117.4V (57 cells x 2.06V).

Justification: Under short-circuit conditions, the charger voltage declines as the output is current-limited. The use of 2.06 volts per cell will provide conservative results.

- 5.4 Resistance of components on the 125VDC DG distribution panel such as breakers, fuses, busbars, connections, etc., and the short cables between the battery and the distribution panel is negligible.

Justification: This assumption is conservative since it maximizes short-circuit currents.

- 5.5 Cable temperature of 25°C is used for short-circuit calculations.

Justification: This assumption is conservative since it maximizes short-circuit currents.

- 5.6 The battery short-circuit current is ten times the batteries one-minute rate.

Justification: The factor of ten is recommended by EEB-TI-7 and IEEE Std 946-1985 for estimating short-circuit currents.

- 5.7 Diesel generator field flash current is assumed to be 45 amps.

Justification: Preop test TVA-14D attachment for section 5.4.1.35, records a field flash current at 25.2 amps. 45 amps is an approximate value based on field impedance and is conservative.

- 5.8 A DG battery minimum terminal voltage of 105VDC is sufficient to support diesel generator start and operation. Preop test TVA-14D will be revised to simulate the battery duty cycle contained in this calculation such that a diesel start is attempted with the battery discharged to 105V.

Justification: FSAR Table 14-2-1, Lists of Preoperational Tests, sheet 139, Test Objectives Summary of Testing and Acceptance Criteria, includes the requirement to verify the capability of the DG batteries to properly supply actual loads. This method was used to successfully verify adequate minimum voltage at SQN in preoperational test TVA-14DRT1. The SQN diesel control circuits and diesel battery system use the same type components and have similar physical arrangements.

This assumption requires later verification.

- 5.9 The DG distribution panel main breaker adjustable instantaneous trips are adjusted to the high limit.

Justification: Adjustment to the high limit maximizes selective coordination with the branch circuit breakers. Reference DCN M08699A.

- 5.10 ~~The 1/2 hp fuel oil pumps and the 3/4 hp lube oil each have starting currents of four times full load current.~~

R5
C4410
8/14/10

~~Justification: Preop test TVA 14D, section 5.4.1.35, recorded the combined starting currents of the control circuits and fuel oil pumps at 26 amps (the lube oil pumps were not included). This would correlate to value of approximately three times full load current, thus, a factor of four provides margin. Since the lube oil motors are similar in size, type and application, the factor of four is valid approximation for those as well.~~

R5
CP 4/10/92
EJH/0/92

- 5.11 The diesel generator control circuits require 2.0 amps.

Justification: 2.0 amps is consistent with the value used SQN's battery sizing calculation (reference 3.7). The SQN value was determined by testing for diesels having similar control circuits.

- 5.12 Buss KLM3 fuses will be used for the instrument circuit for the DG Distribution Panels. Reference DCN M08699A.

Justification: The Buss KLM3 fuse has an adequate dc rating and will provide selective coordination with the main breaker (section 6.4.3.b).

6.0 Analysis

The design basis of the 125VDC DG control power system is to provide control power for the control and field flashing of the DG sets under normal conditions, a loss of all AC power and any single failure within the DG control power system.

6.1 Battery Sizing

The loss of AC power event imposes the greatest demands on the battery. The design criteria (ref 3.2), section 8.2.1, requires that the batteries supply diesel generator loads - without benefit of chargers - for a period of 30 minutes. The following sequence of events and operating conditions are used in evaluating worst-case battery loading.

Sequence of Events


- at time equal 0, an emergency start signal is received by the diesel control circuits
- at time equal 0+, the fuel oil pumps start while the air starting circuits cycle attempting to start the diesel
- at time equal 5.0 seconds, the shutdown relay is actuated terminating the start attempt and causing the fuel oil pumps to stop.
- at time equal 10 to 60 seconds, the lube oil pressure decreases to setpoint causing the dc lube oil pumps to start.
- from time 1 minute, 0 seconds to 29 minutes, 50 seconds; the load consists of the control circuit demand plus two lube oil pump running currents.
- at 29minutes, 50+ seconds, the second start attempt begins with the fuel oil pumps again starting followed by the field flash current. The lube oil pumps are shut off at 450 rpm and the field is flashed at 550 rpm.

Battery Duty Cycle Loads

-control circuits (cc)	2.0a	assumption 5.11, SQN-TVA-14DRT1
-fuel oil pump starting (fops)	36.0a, ea.	reference 3.23, MR A-617680
-fuel oil pump running (fopr)	4.0a, ea.	motor data
-lube oil pump starting (lops)	53.0a, ea.	reference 3.23, MR A-617680
-lube oil pump running (lopr)	7.4a, ea.	motor data
-field flash (ff)	45.0a	assumption 5.7, WBN-TVA-14D


RG
CPA/10/92
EJA/10/92

Battery Duty Cycle - Simultaneous Motor Starts




R5
6/4/10/2
EJ4/10


Battery Duty Cycle - Nonsimultaneous Motor Starts



Simplified Duty Cycle - Simultaneous Motor Starts



Simplified Duty Cycle - Nonsimultaneous Motor Starts



The IEEE 485 worksheets are completed using the above simplified battery duty cycle, a 50 F ambient, an aging factor of 1.25, and a minimum cell voltage of 1.84V. Both the 3-DCU-9 battery cell and the KCR-7 battery cell (DCN M11793A) are evaluated. The KCR-7 is evaluated in Section 6.1 only to confirm viability as a replacement.

An alternative worst-case scenario is a successful diesel start on the first attempt with consideration given to DC lube oil pump starting transients concurrent with field flash. Contrary to Attachment 10.9, the DC lube oil pumps started as soon as 2.5 seconds in testing performed at SQN. This could result in a one-minute demand of 161a for simultaneous motor starts and 115.4a for nonsimultaneous motor starts where the loads are the control circuits (2a), the fuel oil pumps (8a), the field flash (45a), and the lube oil pumps (60.4a or 106a). The one-minute rate to 1.84v considering derating factors for temperature and aging is 67.2a for the 3DCU-9 cell and 117.4a for the KCR-7 cell.

RE
694
EJ

CELL SIZING WORKSHEET

WBN EEB-MG-T111-0062 R2 Page

(For Ref. See ESC-291)

Project Watts Bar Nuclear Plant

Date:

Page:

Lowest Expected Electrolyte Temp °F	Minimum Cell Voltage	Cell Mfg:	Cell Type	Sized By:			
(1)	(2)	(3)	(4)	(5)	(6)	(7)	
Period	Load (amperes)	Change in Load (amperes)	Duration of Period (minutes)	Time to End of Section (minutes)	Capacity at T Min Rate (6A) Amps/Pos (RT) or (6B) K Factor (KT)	Required Section Size (3) (6A) = Positive Plates or (3) x (6B) = Rated Amp Hrs	
						Pos Values	Neg Values

Superseded by Pages 13a for R5 6/4/10/10 ESB/10

Section 1 - First Period Only - If A2 is greater than A1, go to Section 2.

1	A1 = 61.2	A1-0 = 61.2	M1 = 1	T = M1 = 1	25	2.45	...
Sec 1 Total						2.45	...

Section 2 - First Two Periods Only - If A3 is greater than A2, go to Section 3

1	A1 =	A1-0 =	M1 =	T = M1 + M2 =			
2	A2 =	A2-A1 =	M2 =	T = M2 =			
Sec 2						Sub Tot	...
						Total	...

Section 3 - First Three Periods Only - If A4 is greater than A3, go to Section 4

1	A1 = 61.2	A1-0 = 61.2	M1 = 1	T = M1 + M2 + M3 = 30	14.8	4.14	
2	A2 = 16.8	A2-A1 = 44.4	M2 = 28	T = M2 + M3 = 29	14.8		3.00
3	A3 = 59.0	A3-A2 = 38.2	M3 = 1	T = M3 = 1	25	1.53	
Sec 3						Sub Tot	5.67
						Total	2.67

Section 4 - First Four Periods Only - If A5 is greater than A4, go to Section 5

1	A1 =	A1-0 =	M1 =	T = M1 + M2 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M3 + M4 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M4 =			
4	A4 =	A4-A3 =	M4 =	T = M4 =			
Sec 4						Sub Tot	...
						Total	...

Section 5 - First Five Periods Only - If A6 is greater than A5, go to Section 6

1	A1 =	A1-0 =	M1 =	T = M1 + M5 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M5 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M4 + M5 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 =			
5	A5 =	A5-A4 =	M5 =	T = M5 =			
Sec 5						Sub Tot	...
						Total	...

Section 6 - First Six Periods Only - If A7 is greater than A6, go to Section 7

1	A1 =	A1-0 =	M1 =	T = M1 + M6 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M6 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M6 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 + M6 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 =			
6	A6 =	A6-A5 =	M6 =	T = M6 =			
Sec 6						Sub Tot	...
						Total	...

Section 7 - First Seven Periods Only - If A8 is greater than A7, go to Section 8

1	A1 =	A1-0 =	M1 =	T = M1 + M7 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M7 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M7 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M7 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 + M7 =			
6	A6 =	A6-A5 =	M6 =	T = M6 + M7 =			
7	A7 =	A7-A6 =	M7 =	T = M7 =			
Sec 7						Sub Tot	...
						Total	...

Random Equipment Load Only (if needed)

R	AR =	AR-0 =	MR =	T = MR =			...
---	------	--------	------	----------	--	--	-----

Maximum Section Size (8) 2.67 + Random Section Size (9) = Uncorrected Size - (US) (10) 2.67
 US (11) 2.67 x Temp Corr (12) 1.19 x Design Marg (13) 1.00 x Aging Factor (14) 1.25 = (15) 3.97
 When the cell size (15) is greater than a standard cell size, the next larger cell is required.

Required cell size (16) 4 (A) - Positive Plates

(B) - Ampere Hours. Therefore cell (17) is required.

CELL SIZING WORKSHEET
(For Ref. See ESC-291)

WJEEBMS1110062
Page 17a
4/10/92
EJS 4/10/92
Page

Project Watts Bar Nuclear Plant Date _____

Lowest Expected Electrolyte Temp °F 50 Minimum Cell Voltage 1.84 Cell Mfg. CE'D Cell Type 3DCU-9 Sized By _____

(1) Period	(2) Load (amperes)	(3) Change in Load (amperes)	(4) Duration of Period (minutes)	(5) Time to End of Section (minutes)	(6) Capacity at T Min Rate (16A) Amps/Pos (RT) or (16B) K Factor (KT)	(7) Required Section Size	
						(3) (6A) = Positive Plates or (3) x (6B) = Rated Amp Hrs Pos Values	Neg Values

Section 1 - First Period Only - If A2 is greater than A1, go to Section 2.

1	A1 = <u>108.0</u>	A1-0 = <u>108.0</u>	M1 = <u>1</u>	T = M1 = <u>1</u>	<u>25</u>	<u>4.32</u>	...
Sec 1 Total						<u>4.32</u>	...

Section 2 - First Two Periods Only - If A3 is greater than A2, go to Section 3

1	A1 =	A1-0 =	M1 =	T = M1 + M2 =			
2	A2 =	A2-A1 =	M2 =	T = M2 =			
Sec 2						Sub Tot	...
						Total	

Section 3 - First Three Periods Only - If A4 is greater than A3, go to Section 4

1	A1 = <u>108.0</u>	A1-0 = <u>108.0</u>	M1 = <u>1</u>	T = M1 + M2 + M3 = <u>30</u>	<u>14.8</u>	<u>7.30</u>	
2	A2 = <u>16.8</u>	A2-A1 = <u>91.2</u>	M2 = <u>28</u>	T = M2 + M3 = <u>29</u>	<u>14.8</u>		<u>-6.16</u>
3	A3 = <u>88.8</u>	A3-A2 = <u>72</u>	M3 = <u>1</u>	T = M3 = <u>1</u>	<u>25</u>	<u>2.88</u>	
Sec 3						Sub Tot	<u>10.18</u>
						Total	<u>4.02</u>

Section 4 - First Four Periods Only - If A5 is greater than A4, go to Section 5

1	A1 =	A1-0 =	M1 =	T = M1 + M2 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M3 + M4 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M4 =			
4	A4 =	A4-A3 =	M4 =	T = M4 =			
Sec 4						Sub Tot	...
						Total	

Section 5 - First Five Periods Only - If A6 is greater than A5, go to Section 6

1	A1 =	A1-0 =	M1 =	T = M1 + M5 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M5 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M4 + M5 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 =			
5	A5 =	A5-A4 =	M5 =	T = M5 =			
Sec 5						Sub Tot	...
						Total	

Section 6 - First Six Periods Only - If A7 is greater than A6, go to Section 7

1	A1 =	A1-0 =	M1 =	T = M1 + M6 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M6 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M6 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 + M6 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 =			
6	A6 =	A6-A5 =	M6 =	T = M6 =			
Sec 6						Sub Tot	...
						Total	

Section 7 - First Seven Periods Only - If A8 is greater than A7, go to Section 8

1	A1 =	A1-0 =	M1 =	T = M1 + M7 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M7 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M7 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M7 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 + M7 =			
6	A6 =	A6-A5 =	M6 =	T = M6 + M7 =			
7	A7 =	A7-A6 =	M7 =	T = M7 =			
Sec 7						Sub Tot	...
						Total	

Random Equipment Load Only (if needed)

R	AR =	AR-0 =	MR =	T = MR =			...
---	------	--------	------	----------	--	--	-----

Maximum Section Size (8) 4.32 + Random Section Size (9) 0 = Uncorrected Size - (US) (10) 4.32
 US (11) 4.32 x Temp Corr (12) 1.19 x Design Marg (13) 1.00 x Aging Factor (14) 1.25 = (15) 6.47
 When the cell size (15) is greater than a standard cell size, the next larger cell is required.

Required cell size (16) 7 (A) - Positive Plates.
 (B) - Amperes Hours. Therefore cell (17) _____ is required.

CELL SIZING WORKSHEET
(For Ref. See ESC-291)

WBNEEDMSTII10062
Page 136
6/4/92
EH 4/10/92
Page

Project Watts Bar Nuclear Plant

Date _____

Lowest Expected Electrolyte Temp °F 50 Minimum Cell Voltage 1.84 Cell Mfg: CEC Cell Type 3DCU-9 Sized By _____

(1) Period	(2) Load (amperes)	(3) Change in Load (amperes)	(4) Duration of Period (minutes)	(5) Time to End of Section (minutes)	(6) Capacity at T Min Rate (6A) Amps/Pos (RT) or (6B) K Factor (KT)	(7) Required Section Size	
						(3) x (6A) = Positive Plates or (3) x (6B) = Rated Amp Hrs Pos Values	Neg Values

Section 1 - First Period Only - If A2 is greater than A1, go to Section 2.

1	A1 = <u>62.4</u>	A1-0 = <u>62.4</u>	M1 = <u>1</u>	T = M1 = <u>1</u>	<u>25</u>	<u>2.50</u>	...
Sec 1 Total							...

Section 2 - First Two Periods Only - If A3 is greater than A2, go to Section 3

1	A1 =	A1-0 =	M1 =	T = M1 + M2 =			
2	A2 =	A2-A1 =	M2 =	T = M2 =			
Sec 2 Sub Tot							...
2 Total							...

Section 3 - First Three Periods Only - If A4 is greater than A3, go to Section 4

1	A1 = <u>62.4</u>	A1-0 = <u>62.4</u>	M1 = <u>1</u>	T = M1 + M2 + M3 = <u>30</u>	<u>14.8</u>	<u>4.22</u>	
2	A2 = <u>16.8</u>	A2-A1 = <u>45.6</u>	M2 = <u>28</u>	T = M2 + M3 = <u>29</u>	<u>14.8</u>		<u>3.08</u>
3	A3 = <u>46.8</u>	A3-A2 = <u>40</u>	M3 = <u>1</u>	T = M3 = <u>1</u>	<u>25</u>	<u>1.60</u>	
Sec 3 Sub Tot						<u>5.82</u>	<u>3.08</u>
3 Total						<u>2.74</u>	...

Section 4 - First Four Periods Only - If A5 is greater than A4, go to Section 5

1	A1 =	A1-0 =	M1 =	T = M1 + M1 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M3 + M4 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M4 =			
4	A4 =	A4-A3 =	M4 =	T = M4 =			
Sec 4 Sub Tot							...
4 Total							...

Section 5 - First Five Periods Only - If A6 is greater than A5, go to Section 6

1	A1 =	A1-0 =	M1 =	T = M1 + M5 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M5 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M4 + M5 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 =			
5	A5 =	A5-A4 =	M5 =	T = M5 =			
Sec 5 Sub Tot							...
5 Total							...

Section 6 - First Six Periods Only - If A7 is greater than A6, go to Section 7

1	A1 =	A1-0 =	M1 =	T = M1 + M6 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M6 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M6 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 + M6 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 =			
6	A6 =	A6-A5 =	M6 =	T = M6 =			
Sec 6 Sub Tot							...
6 Total							...

Section 7 - First Seven Periods Only - If A8 is greater than A7, go to Section 8

1	A1 =	A1-0 =	M1 =	T = M1 + M7 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M7 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M7 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M7 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 + M7 =			
6	A6 =	A6-A5 =	M6 =	T = M6 + M7 =			
7	A7 =	A7-A6 =	M7 =	T = M7 =			
Sec 7 Sub Tot							...
7 Total							...

Random Equipment Load Only (if needed)

R	AR =	AR-0 =	MR =	T = MR =			...
---	------	--------	------	----------	--	--	-----

Maximum Section Size (8) 2.74 + Random Section Size (9) 0 = Uncorrected Size - (US) (10) 2.74
US (11) 2.74 x Temp Corr (12) 1.19 x Design Marg (13) 1.60 x Aging Factor (14) 1.25 = (15) 4.08
When the cell size (15) is greater than a standard cell size, the next larger cell is required.

Required cell size (16) 4 (A) - Positive Plates

(B) - Ampere-Hours. Therefore cell (17) _____ is required.

CELL SIZING WORKSHEET

(For Ref. See ESC-291)

WANEEDMSTI110062

Page 13C

6/4/92
6/9/92
Page

Project Watts Bar Nuclear Plant

Date 4/7/92

Lowest Expected Minimum
Electrolyte Temp °F 50 Cell Voltage 1.84 Cell Mfg. CE'D Cell Type KCR-7 Sized By

(1) Period	(2) Load (amperes)	(3) Change in Load (amperes)	(4) Duration of Period (minutes)	(5) Time to End of Section (minutes)	(6) Capacity at T Min Rate (6A) Amps/Pos (RT) or (6B) K Factor (KT)	(7) Required Section Size (3) (6A) = Positive Plates or (3) x (6B) = Rated Amp Hrs	
						Pos Values	Neg Values

Section 1 - First Period Only - If A2 is greater than A1, go to Section 2.

1	A1 = <u>108.0</u>	A1-0 = <u>108.0</u>	M1 = <u>1</u>	T = M1 = <u>1</u>	<u>51(1.141) = 58.2</u>	<u>1.86</u>	...
Sec 1 Total						<u>1.86</u>	...

Section 2 - First Two Periods Only - If A3 is greater than A2, go to Section 3

1	A1 =	A1-0 =	M1 =	T = M1 + M2 =			
2	A2 =	A2-A1 =	M2 =	T = M2 =			
Sec 2						Sub Tot	...
Total							

Section 3 - First Three Periods Only - If A4 is greater than A3, go to Section 4

1	A1 = <u>108.0</u>	A1-0 = <u>108.0</u>	M1 = <u>1</u>	T = M1 + M2 + M3 = <u>30</u>	<u>40(1.141) = 45.6</u>	<u>2.97</u>	
2	A2 = <u>16.8</u>	A2-A1 = <u>91.2</u>	M2 = <u>28</u>	T = M2 + M3 = <u>29</u>	<u>40(1.141) = 45.6</u>		<u>2.00</u>
3	A3 = <u>88.8</u>	A3-A2 = <u>72</u>	M3 = <u>1</u>	T = M3 = <u>1</u>	<u>51(1.141) = 58.2</u>	<u>1.24</u>	
Sec 3						Sub Tot	<u>2.00</u>
Total						<u>3.61</u>	<u>1.61</u>

Section 4 - First Four Periods Only - If A5 is greater than A4, go to Section 5

1	A1 =	A1-0 =	M1 =	T = M1 + M2 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M3 + M4 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M4 =			
4	A4 =	A4-A3 =	M4 =	T = M4 =			
Sec 4						Sub Tot	...
Total							

Section 5 - First Five Periods Only - If A6 is greater than A5, go to Section 6

1	A1 =	A1-0 =	M1 =	T = M1 + M5 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M5 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M1 + M5 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 =			
5	A5 =	A5-A4 =	M5 =	T = M5 =			
Sec 5						Sub Tot	...
Total							

Section 6 - First Six Periods Only - If A7 is greater than A6, go to Section 7

1	A1 =	A1-0 =	M1 =	T = M1 + M6 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M6 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M6 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 + M6 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 =			
6	A6 =	A6-A5 =	M6 =	T = M6 =			
Sec 6						Sub Tot	...
Total							

Section 7 - First Seven Periods Only - If A8 is greater than A7, go to Section 8

1	A1 =	A1-0 =	M1 =	T = M1 + M7 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M7 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M7 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M7 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 + M7 =			
6	A6 =	A6-A5 =	M6 =	T = M6 + M7 =			
7	A7 =	A7-A6 =	M7 =	T = M7 =			
Sec 7						Sub Tot	...
Total							

Random Equipment Load Only (if needed)

R	AR =	AR-0 =	MR =	T = MR =			...
---	------	--------	------	----------	--	--	-----

Maximum Section Size (8) 1.86 + Random Section Size (9) 0 = Uncorrected Size (US) (10) 1.86
 US (11) 1.86 x Temp Corr (12) 1.19 x Design Marg (13) 1.00 x Aging Factor (14) 1.25 = (15) 2.77
 When the cell size (15) is greater than a standard cell size, the next larger cell is required.

Required cell size (16) 3 (A) - Positive Plates.

(B) - Ampere Hours. Therefore cell (17) _____ is required.

CELL SIZING WORKSHEET

WNEEDMST110062
 Page 13d
 6/4/10/92
 235 + 1/15/92
 Page

(For Ref. See ESC-291)

Project Watts Bar Nuclear Plant

Date _____

Lowest Expected Electrolyte Temp °F 50 Minimum Cell Voltage 1.84 Cell Mfg. CE'D Cell Type KCR-7 Sized By _____

(1) Period	(2) Load (amperes)	(3) Change in Load (amperes)	(4) Duration of Period (minutes)	(5) Time to End of Section (minutes)	(6) Capacity at T Min Rate (6A) Amps/Pos (R _T) or (6B) K Factor (K _T)	(7) Required Section Size	
						(3) (6A) = Positive Plates or (3) x (6B) = Rated Amp Hrs Pos Values	Neg Values

Section 1 - First Period Only - If A2 is greater than A1, go to Section 2.

1	A1 = <u>62.4</u>	A1-0 = <u>62.4</u>	M1 = <u>1</u>	T = M1 = <u>1</u>	51(1.141) = <u>58.2</u>	<u>1.07</u>	...
Sec 1 Total:						<u>1.07</u>	...

Section 2 - First Two Periods Only - If A3 is greater than A2, go to Section 3

1	A1 =	A1-0 =	M1 =	T = M1 + M2 =			
2	A2 =	A2-A1 =	M2 =	T = M2 =			
Sec 2						Sub Tot	...
Total							

Section 3 - First Three Periods Only - If A4 is greater than A3, go to Section 4

1	A1 = <u>62.4</u>	A1-0 = <u>62.4</u>	M1 = <u>1</u>	T = M1 + M2 + M3 = <u>30</u>	40(1.141) = <u>45.6</u>	<u>1.37</u>	
2	A2 = <u>16.8</u>	A2-A1 = <u>45.6</u>	M2 = <u>28</u>	T = M2 + M3 = <u>29</u>	40(1.141) = <u>45.6</u>		<u>1.00</u>
3	A3 = <u>56.8</u>	A3-A2 = <u>40</u>	M3 = <u>1</u>	T = M3 = <u>1</u>	51(1.141) = <u>58.2</u>	<u>0.69</u>	
Sec 3						Sub Tot	<u>1.00</u>
Total						<u>1.06</u>	...

Section 4 - First Four Periods Only - If A5 is greater than A4, go to Section 5

1	A1 =	A1-0 =	M1 =	T = M1 + M1 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M3 + M4 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M4 =			
4	A4 =	A4-A3 =	M4 =	T = M4 =			
Sec 4						Sub Tot	...
Total							

Section 5 - First Five Periods Only - If A6 is greater than A5, go to Section 6

1	A1 =	A1-0 =	M1 =	T = M1 + M5 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M5 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M1 + M5 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 =			
5	A5 =	A5-A4 =	M5 =	T = M5 =			
Sec 5						Sub Tot	...
Total							

Section 6 - First Six Periods Only - If A7 is greater than A6, go to Section 7

1	A1 =	A1-0 =	M1 =	T = M1 + M6 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M6 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M6 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M5 + M6 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 =			
6	A6 =	A6-A5 =	M6 =	T = M6 =			
Sec 6						Sub Tot	...
Total							

Section 7 - First Seven Periods Only - If A8 is greater than A7, go to Section 8

1	A1 =	A1-0 =	M1 =	T = M1 + M7 =			
2	A2 =	A2-A1 =	M2 =	T = M2 + M7 =			
3	A3 =	A3-A2 =	M3 =	T = M3 + M7 =			
4	A4 =	A4-A3 =	M4 =	T = M4 + M7 =			
5	A5 =	A5-A4 =	M5 =	T = M5 + M6 + M7 =			
6	A6 =	A6-A5 =	M6 =	T = M6 + M7 =			
7	A7 =	A7-A6 =	M7 =	T = M7 =			
Sec 7						Sub Tot	...
Total							

Random Equipment Load Only (if needed)

R	AR =	AR-0 =	MR =	T = MR =			...
---	------	--------	------	----------	--	--	-----

Maximum Section Size (8) 1.06 + Random Section Size (9) 0 = Uncorrected Size - (US) (10) 1.06
 US (11) 1.06 x Temp Corr (12) 1.19 x Design Marg (13) 1.00 x Aging Factor (14) 1.25 = (15) 1.98
 When the cell size (15) is greater than a standard cell size, the next larger cell is required.

Required cell size (16) 2 (A) - Positive Plates.
 (B) - Ampere-Hours - Therefore cell (17) _____ is required.

6.2 Charger Sizing

DG battery 2B-B configured with 57 C&D DCU cells was tested during the performance of Preop Test TVA-14D. Control loads during standby and run were measured and recorded in test section 5.4.1.35.

Inspection of the recording provides the following:

1. Control load current during standby is 2.0 amps.
2. Control load current during run is 10.0 amps.
This includes fuel oil pumps but not lube oil pumps.

The charger is required to continuously supply all steady state loads and maintain the batteries in the design maximum charged state or to fully recharge the batteries from the design minimum discharge state within an acceptable time interval. No specific time requirement is given in either FSAR Section 8.3 or Design Criteria WB-DC-30-27, section 8.2.2.2.

The ampere-hours to be recharged are taken from the worst-case simplified duty cycle in Section 6.1:

$$\begin{aligned} \text{AH} &= 108.0(1/60) + 16.8(28/60) + 88.8(1/60) \\ &= 11.12 \end{aligned}$$

The battery charger supplied for the DG battery system is a LaMarche All-20-130V-C3, having a continuous output current rating of 20 amps. The battery recharge time is calculated as follows:

$$I_{\text{ch}} = I_{\text{load}} + (1.1)(\text{AH})/T$$

$$\begin{aligned} T &= (1.1)(\text{AH})/(I_{\text{ch}} - I_{\text{load}}) = (1.1)(11.12)/(20 - 10.0) \\ &= 1.22 \text{ hrs} \end{aligned}$$

The battery recharge time is slightly over one hour. In comparison, the recharge time for the 125VDC Vital Batteries is 36 hours following a plant blackout and 12 hours following an accident with a 30 minute AC power outage.

6.3 Protective Device Sizing

The main and branch circuit protective devices on the 125VDC DG distribution panels should be sized such that continuous load does not exceed 80% of the trip (or fuse) rating and that circuit transients should not cause the device to actuate.

RS
4/10/92
ES 4/10/92

RS
4/10/92
ES 4/10/92

The 125VDC DG Distribution Panel protective devices are tabulated as follows:

-main breaker	150a,	SQD KAP26150
-main fuses	150a,	Buss NON150
-engine cont pnl	20a,	SQD FA26020
-gen prot relays	20a,	SQD FA26020
-excitation	80a,	SQD FA26080
-battery charger	20a,	SQD FA26020
-dc lube oil pumps	20a,	SQD FA26020
-swgr cntrl (5 th diesel).....	20a,	SQD FA26020

From sections 6.1 and 6.2, the total continuous load on all DG control circuits was 10.0 amps. Since this is less than 80% of the smallest breaker (20a), all DG control branch circuit breakers are acceptable for continuous loading.

The branch circuit breaker for the excitation controls is 80a. Since the field flash is 45a, this breaker is properly sized for transient conditions.

The breaker for the dc lube oil pumps is 20a. This circuit supplies the pump motors which experience a transient current of less than 59.2a (four times full load current). Since the Square D type FA circuit breakers have time-delay overload trip characteristics, it is acceptably sized.

The breaker for the battery charger is 20a. Since the battery charger rated output current is 20a and is current-limited at 140% (28a) this breaker is not acceptable.

The total continuous current and maximum transient currents are less than 80% of the continuous ratings of the main breaker and fuse, thus, these devices are also acceptable.

6.4 Short Circuit Protection and Coordination

The 125VDC Diesel Generator Control Power System is to be designed to provide adequate short circuit protection and coordinated in accordance with the following criteria from WB-DC-30-27, paragraph 8.2.6:

- Protective devices shall be rated to properly interrupt maximum fault current.
- Each circuit shall be protected by a thermal-magnetic circuit breaker.

- The battery charger input breaker shall be considered a branch circuit.
- The battery input circuit shall be protected by a thermal-magnetic breaker and a coordinated fuse.

6.4.1 Computation of Maximum Short Circuit Current

Battery (I_{bsc}) - Battery one-minute rate for 3DCU-9 cell is 148a (one-minute rate to 1.75vpc). The short circuit current is ten times the one-minute rate, or 1480 amps.

Battery Charger (I_{bcsc}) - The battery charger is current-limited to 140% of full load current or 28a.

Motor Contribution (I_{msc}) - The short circuit current provided by the motors is based on the sum of the horsepower ratings of both fuel oil pump motors and both lube oil pump motors, or 2 1/2 hp.

$I_{msc} = v/R'd$, where v is rated voltage and $R'd$ is the transient armature resistance

$R'd = (r'd)(R)$; $r'd$ is the per unit transient armature resistance

$$R = v^2 / (\text{hp})(746\text{w}/\text{hp}) = (125)^2 / (2.5)(746)$$

$$r'd = 0.07, \text{ from EEB-TI-07, section 7.5.2}$$

$$R'd = 0.07(125)^2 / (2.5)(746) = 213a$$

Total Short Circuit Current -

$$I_{sc} = I_{bsc} + I_{bcsc} + I_{msc} \\ = 1480 + 28 + 213 = 1721a$$

6.4.2 Evaluation of Protective Device Ratings - DG Distribution Panel

component	type	rating(aic)
main cb	SQD KAP26150	10,000 @ 250VDC
main fuse	BUSS NON150	10,000 @ 250VDC*
branch cb	SQD FA26100	10,000 @ 250VDC
branch cb	SQD FA26080	10,000 @ 250VDC
branch cb	SQD FA26020	10,000 @ 250VDC
chgr out cb	West EB2035	5,000 @ 250VDC
instr fuse	BUSS KTK3	no dc rating

All protective components on the DG distribution panel have adequate interrupting ratings except for the fuses for the nonsafety-related instrumentation circuits which are not rated for dc

applications.

6.4.3 Coordination of DG Distribution Panel Protective Devices

- a. Branch Circuits - Selective coordination between the branch circuit breakers and the main circuit breaker or fuse is desirable but not essential for all possible fault current values. The cables and loads involved are all located within their respective diesel generator room and will be exposed only to the hazards/failures within that room. Since the cables remain within their respective diesel generator room, any failure/event requiring protective actuation of the circuit breakers is bounded by the single failure criteria.

From SQD curve #655-241 (Figure 7.3), the minimum pickup at the high limits setting of the magnetic element of the type KA main breaker is 8-times rated current, or 1200a. Although selective coordination will be lost for any fault in excess of that value, that is acceptable.

- b. Instrument Circuit - Since the fused circuit to the panel instrumentation is nonsafety-related, selective coordination is required between the fuse and the main circuit breaker. (Note: the shunt circuits, inherently energy limited and in a single pole, do not pose a protection concern). The Buss KTK3 fuse used in the circuit as determined by walkdown does not have a dc rating. The dc-rated counterpart is the Buss KLM3 which has the same time-current characteristic and is analyzed in the following:

Verification of selective coordination between the main breaker and the KLM3 fuse is accomplished by verifying coordination first with the Littelfuse FLA55 for which data is available for peak let-through current for times less than 0.01 seconds, then demonstrating that the Buss KLM3 is more current-limiting. Peak let-through current testing performed on the FLA55 as documented by memorandum from Richard L.

Morley, Chief, Central Laboratories Services Branch to W. S. Raughley, Chief, Electrical Engineering Branch, "Peak Let Through Current Test", dated October 27, 1987 (E13871027167), provided fuse characteristics for time periods less than 0.01 seconds. From Table I, of the test report, it was determined that the fuse would clear a 3400a fault with a peak let-through current of less than 300a at a time less than 0.800 milliseconds. This point would be on the fuses total clearing time curve and the fuse characteristic can be interpolated from 0.01 seconds from published curves to the 0.008 seconds from the test. Comparison of the FLAS5 fuse and SQD KA26150 curve indicates a substantial margin of coordination as shown in Figure 7.4. Comparison of the KLM3 fuse curve with the FLAS5 in the 0.01 seconds to 100.0 seconds time period indicates that the KLM3 is more current-limiting. It is therefore concluded that coordination of the main breaker with a Buss KLM3 fuse is verified.

6.4.4 Cable Insulation Damage

Evaluation of branch circuit cables for protection from cable insulation damage is accomplished by comparison of the branch circuit time-current curves with the cable damage curves as determined by IPCEA formula for copper cables:

$$(I/A)^2 t = 0.0297 \log_{10} (T_f + 234 / T_o + 234)$$

where I = short circuit current in amperes
 A = conductor csa in circular mils
 t = time of short circuit current in seconds

T_o = max operating temp - °C
 T_f = cable damage temp - °C
 for 75°C cable, $T_f = 150°C$
 90°C cable, $T_f = 250°C$

CABLE INSULATION DAMAGE CURRENT

mk no	size	T _o	csa	t=0.010	t=0.016	t=0.10	t=1.0	t=10.0
	#14	75	4110	2176	1720	688	218	69
wgb-1, wlb	#12	90	6530	4698	3714	1486	470	149
wfb	#10	75	10380	5495	4344	1738	550	174
wfb-1	#10	90	10380	7468	5904	2362	747	236
	#2	75	66360	35132	27775	11110	3513	1111
wdg, wdg-1	#2	90	66360	47746	37746	15098	4775	1510

Figures 7.1a, 7.1b and 7.2 show the cable insulation damage curves plotted with the branch and main circuit breaker curves. Figures 7.1a and 7.1b show that a SQD FA26020 will prevent cable insulation damage for all possible ranges of fault current for the #12 and #10 cables. Figure 7.2 shows that a SQD FA26080 will similarly protect #2 cables.

6.4.5 Appendix R

Design Criteria WB-DC-30-13 requires an evaluation to ensure that the upstream protective devices that supply a board or panel will not trip as a result of a high impedance fault. The condition to be evaluated is the total current loading of all the normal loads that could be operating plus all required Appendix R loads plus a high impedance fault on the largest non-required Appendix R load. For the faulted non-required load, the current drawn is just below the continuous rating of the protective device.

Review of the diesel generator control circuits indicates that only the alarms are non-required Appendix R circuits. All other circuits are required. From drawing D379F02501 sh3 and 6036F02501 sh3, the alarm circuits are supplied through a 10a fuse. The total continuous current measured during

diesel operation is SQN preop test TVA-14DRT1 (see Assumption 5.11) was 2.0a. Using the 2.0a value for the engine controls plus 10a for the faulted alarm relay circuit would be 12a which is less than the 20a rating of the branch circuit breaker.

6.4.6 Reg Guide 1.75 - Associated Circuits

From review of the DG control schematics and connection diagrams, associated circuits were identified in the alarm circuits of the engine controls. The alarm portion of the engine controls is fused with Buss FNM10 fuses in DG 1A-A, 1B-B, 2A-A and 2B-B and fused with Buss KLM10 fuses in DG C-S. Figure 7.4 shows that these fuses are sufficient to prevent insulation damage in the associated circuits. The cables identified as associated circuits for each DG are #14. The cable damage curve is taken from data from section 6.4.4.

6.4.7 Cascade Fuse Analysis

From section 6.4.6, the alarm circuit portion of the engine controls are associated circuits and as such, are required to have short circuit protection which isolates them from the balance of the engine control circuits.

The alarm circuit is fused with Buss FMN10 fuses in DG 1A-A, 2A-A, 1B-B, and 2B-B and Buss KLM10 fuses in DG C-S. These fuses are in series with a SQD FA22015 circuit breaker. The engine controls are supplied by a SQD FA26020 circuit breaker located in the DG distribution panel. The trip/fuse characteristics are plotted in Figure 7.4.

From figure 7.4, it is seen that there is no selective coordination above 180a due to overlap between the 20a breaker and the 15a breaker or 10a fuses. Short circuit current at the engine control panel is calculated:

Equivalent source impedance, Z_s , equals the supply voltage divided by the maximum available short circuit current from section 6.1 $Z_s = 117.4/1721a = 0.0682$

Cable impedance using straight line

distance between the DG distribution panel and the engine control panel for 30 feet of #10 cable at 25°C, Z_C :

$$Z_C = 2(30)(1.04 / 1000) = 0.0624$$

(ref 3.19, 15N210-4)

Short circuit current at the control panel,

$$I_{SC} = 117.4v / (Z_S + Z_C) = 117.4v / (0.0630 + 0.0624) = 936a$$

Thus selective coordination does not exist for worst-case conditions.

6.5 Voltage Analysis

6.5.1 Minimum Voltage to Components

Adequate minimum voltage for functioning of of essential components under worst-case operating conditions will be verified through preoperational test TVA-14D in accordance with Assumption 5.8.

6.5.2 Maximum Voltage to Components

Exceeding component maximum voltage ratings is a concern during battery equalizing. The overall battery voltage during equalizing is 132.8v (2.33vpc x 57 cells).

The diesel generator control circuits were reviewed to identify all type components which may be continuously energized during diesel standby and run modes. Components having only momentary actuations were excluded. The identified components with their nominal and maximum values are listed in Table 6.5.2.

Review of the component maximum voltage ratings indicates that all exceed battery equalizing voltage except the contactor and control relay used in the DC lube oil pump circuits. Their rating is 132v versus the equalizing voltage of 132.8v. This difference in voltage is negligible since (1) the difference in voltage is small, (2) the voltage drop in supply cables was not considered, (3) the diesel generators are run during testing only two hours per month and (4) battery equalizing occurs infrequently.

TABLE 6.5.2

component	nom volt	max volt	note
Square D KPD-13 relay	120v	140v	1
Agastat 7012 TD relay	120v	140v	1
Agastat 7022 TD relay	120v	140v	1
West. MG-6 relay	125v	137.5v	2
GE HGA relay	125v	137.5v	2
Square D HCO-1 contactor	120v	140v	1
Synchrostart speedswitch		140v	1
Dynalco speedswitch	125v	137.5v	2
West. KLF-1 relay	125v	137.5v	2
GE IAV relay		140v	1
Potter-Brumfield MDR-5065-1		140v	1
DC lube oil pump motor	125v	137.5v	2
Square D HCO-2 contactor	120v	132v	3,2
Square D KPD-13 relay	120v	132v	3,2
DC fuel oil pump motor	125v	137.5v	2
Woodward governor control	125v	137.5v	2

Notes:

1. Maximum value per Engine-Generator Control Panel Material List, 6036B11010 RC, Sheets 1-10.
2. Maximum value per standard +10% rating.
3. Components identified on 15W814-5 R24.

7.0 Supporting Graphics

Figure 7.1A - Square D FA26020 trip characteristic with cable damage curve.

Figure 7.1B - Square D FA26020 trip characteristic with cable damage curve.

Figure 7.2 - Square D FA26080 trip characteristic with cable damage curve.

Figure 7.3 - Square D KA26160 trip characteristic with cable damage curve.

Figure 7.4 - Square D FA26020, FA22015, KAL26150; Buss FNM10, KLM10, KLM3; cable damage curve.


20 & 25 AMPERES—1, 2 & 3 POLES
 600 V. AC, 250 V. DC

INTERRUPTING CAPACITY—R.M.S. SYMMETRICAL AMPERES

Catalog No. Poles	No. Phases	Volts AC				Volts DC	
		120	240	277	480	675	250
FA FAL 240 V. Frame	1	18,000					3,000
	2		10,000				5,000
	3		10,000				
FA FAL 480 V. Frame	1	4,000		14,000			10,000
	2		2,000		14,000		10,000
	3		18,000				
FA FAL 600 V. Frame	2		18,000		14,000	14,000	10,000
	3		18,000		14,000	14,000	
	1			55,000			10,000
FM FHL 600 V. Frame	2		48,000		29,000	18,000	12,000
	3		48,000		25,000	18,000	
	1						

40°C AMBIENT COLD START

FA 26020
 CABLE INSULATION DAMAGE (CID)



FOR INFORMATION OF BUYER CURRENT X 20



SQUARE D COMPANY
 DATE MAY 18 1977
 BY D. R. PATTERSON
 MAY 12 1977

FA CHARACTERISTIC CURVE
 Prep WTH 3/3/90


20 & 25 AMPERES—1, 2 & 3 POLES Checked CGP 3/8/90
 600 V. AC, 250 V. DC

INTERRUPTING CAPACITY—R.M.S. SYMMETRICAL AMPERES

Catalog No. Poles	No. Poles	Volts AC				Volts DC		
		120	240	277	480	500	125	250
FA, FAL 240 V. Frame	1	10,000	5,000
	2	10,000	5,000
	3	10,000
FA, FAL 480 V. Frame	1	18,000	14,000	10,000
	2	18,000	14,000	10,000
	3	18,000	14,000
FA, FAL 600 V. Frame	2	16,000	14,000	14,000	10,000
	3	16,000	14,000	14,000
	1	65,000	10,000
FM, FML 600 V. Frame	2	65,000	25,000	18,000	10,000
	3	65,000	10,000
	1	18,000

40°C AMBIENT COLD START

FA 26020
 Cable Insulation Damage (CD)



FOR INFORMATION OF RATED CURRENT X 20

DATE MAY 18 1977

I_{sc} TVMAY 12 1977

I_{sc} = 1863A 1721A
 4/9/18/91

SQUARE D CO.

MULTIPLES OF RATED CURRENT

52M

FA CHARACTERISTIC CURVE


15-60 AMPERES—1, 2 & 3 POLES
 600 V. AC, 250 V. DC

INTERRUPTING CAPACITY—R.M.S. SYMMETRICAL AMPERES

Catalog No. Poles	No. Poles	Volts AC				Volts DC		
		120	240	777	480	600	125	250
FA FAL 240 V. Frame	1	10,000	5,000
	2	10,000	5,000
	3	10,000
FA FAL 480 V. Frame	1	18,000	14,000	10,000
	2	18,000	14,000	10,000
	3	18,000	14,000
FA FAL 600 V. Frame	2	18,000	14,000	14,000	10,000
	3	18,000	14,000	14,000
FH, FHL 600 V. Frame	1	65,000	25,000	10,000
	2	65,000	25,000	18,000	10,000
	3	65,000	25,000	18,000

40°C AMBIENT COLD START

FA 26080
 Cable Insulation Damage (CD)



MULTIPLES OF RATED CURRENT X 80

WENTZ 8-175-121-5005
 Figure 7.3 KA CHARACTERISTIC CURVE
 Date: 08/10/90 Check: 282
 with 1/30

70-225 AMPERES—2 & 3 POLES
 600 V. AC, 250 V. DC


INTERRUPTING CAPACITY—A. S. I. SYMMETRICAL AMPERES

Circuit No. Poles	No. Poles	Volts AC			Volts DC
		700	480	480	250
KA, KAL	2	75,000	77,000	77,000	10,000
	3	75,000	77,000	77,000	10,000
KH, KHL	2	65,000	35,000	75,000	10,000
	3	65,000	35,000	75,000	10,000

40°C AMBIENT COLD START

KA 26150

CABLE AUTO-IGNITION (A-I)



SQUARE D COMPANY

Information Only
 MAY 18 1977

TVA MC 12 1977
 74062-9300

Curve No. 666-261
 Curve No. 666-2617 (1977 Edition)
 March, 1974

8.0 Summary of Results

8.1 Battery Sizing

The 3DCU-9 battery cell has 4 positive plates per cell and is inadequate when considering simultaneous motor starting transient currents; 6.43 positives required by the calculated results. The 3DCU-9 is marginally adequate when considering nonsimultaneous motor starting transients; 4.08 positives by the calculated result.

The KCR-7 has 3 positive plates per cell and is adequate when considering the simultaneous motor starting transients; 2.77 positives by the calculated result. 1.58 positives are required for the nonsimultaneous starts.

The 3DCU-9 and the KCR-7 are inadequate for DC lube oil pump motor starts concurrent with field flash.

8.2 Battery Charger Sizing

The battery charger is capable of carrying normal loads and recharging the battery in less than 1 1/2 hours for the worst case load profile.

8.3 Protective Device Sizing

The branch circuit protective devices on the DG Distribution Panels are properly sized for full load and transient conditions with the exception of the battery charger breaker which is undersized for battery charger current-limit and full load current ratings.

8.4 Short Circuit Protection and Coordination

8.4.1 Short Circuit Current - Maximum short circuit current available at the DG distribution panel is a maximum of 1721a.

8.4.2 Protective Device Ratings - All protective devices on the DG distribution panel have adequate interrupting ratings except for the instrument fuses. Buss KLM3 fuses are an acceptable substitute for the instrument fuses having an adequate dc rating and coordinating selectively with the main breaker. Additionally, the main fuses are not covered by the fuse substitution standard DS-E8.1.1.

8.4.3 Selective Coordination - Selective coordination between the branch circuit breakers and the main breaker is not required. Replacement of the instrument fuses with Buss KLM3 is acceptable.

R5
6/4/10/92
E334/10/94

- 8.4.4 Cable Insulation Damage Protection - All cables have adequate protection to prevent cable insulation damage.
 - 8.4.5 Appendix R - The diesel engine controls have alarm circuits which are non-required for Appendix R. A high impedance fault occurring in these circuits would not result in a loss of required engine control circuits.
 - 8.4.6 Associated Circuits - Associated circuits in the alarm circuits of the engine controls have adequate protection to prevent cable damage. The #14 cables are shown to be protected by the 10a fuses supplying the circuit.
 - 8.4.7 Cascade Fuses - Selective coordination is not provided for the engine control alarm circuits for DG 1A-A, 2A-A, 1B-B, and 2B-B. These circuits have Buss FNM10 fuses which must coordinate with SQD FA26020 breakers. Selective coordination cannot be verified for DG C-S alarm circuit which is fused with Buss KLM10 fuses.
- 8.5 Voltage Analysis
- 8.5.1 Minimum Voltage - Adequacy of minimum voltage to components is to be verified through performance of preop test WBN-TVA-14D.
 - 8.5.2 Maximum Voltage - The voltage ratings of continuously energized components are adequate for the maximum applied voltage during battery equalizing.

9.0 Conclusions

- 9.1 The 3DCU-9 battery cell is inadequate considering simultaneous motor starting transient currents and marginally adequate with no margin considering nonsimultaneous starts. Circuit modifications would be required to assure that the motors would not start simultaneously.

The KCR-7 is adequate with 8.3% margin considering simultaneous starts and 89.9% margin considering nonsimultaneous starts.

A time delay or interlock feature should be added to the DC lube oil pumps to provide assurance that they will not start concurrent with field flashing. (DCN M08699A)

- 9.2 Battery charger size is adequate.
- 9.3 Existing 20a breakers on the battery charger supply should be replaced with 40a breakers. (DCN M08699A)
- 9.4 All protective devices on the DG distribution panel have adequate interrupting ratings except for instrument and main fuses which should be replaced with fuses having adequate dc ratings (e.g., Buss KLM3 for the instrument fuses; Buss KWNR150 for the main fuses). (DCN M08699A)
- 9.5 Protective devices provide sufficient cable thermal damage protection.
- 9.6 Protective device sizes are adequate for Appendix R requirements.
- 9.7 Protective devices are adequate to prevent cable damage for Reg Guide 1.75 - associated circuit requirements.
- 9.8 The Buss FMN10 and KLM10 fuses used in the engine control alarm circuits should be replaced with fuses that provide selective cascade coordination between safety and non-safety circuits. (DCN M08699A)
- 9.9 Adequacy of minimum voltage to components will be verified by preoperational test WBN-TVA-14D.
- 9.10 The voltage ratings of continuously energized components are adequate for maximum voltage requirements.
- 9.11 The requirement to have the DG distribution panel main breaker adjustable trip set to the high limit should be included in a design output document in accordance with EE PM88-03. (DCN M08699A)

RS
 GP 4/10/92
 EJ 4/10/92

RS
 GP 4/10/92
 EJ 4/10/92

RS
 GP 4/10/92
 EJ 4/10/92

RS
 GP 4/10/92
 EJ 4/10/92

RS
 GP 4/10/92
 EJ 4/10/92

ATTACHMENT


STEP 5.4.1.35

CN-13

TVA-14D

RT

OFFICIAL
COPY



HOW RESET
27 9/13/55


AC

AC

14.6m

60 MA PCC MOTOR
 1.2 AMPERES NO LOAD
 OFF 3/3/85
 OSL RTB

26
25
24
23
22
21
20
19
18
17
16
15
14
13
12
11
10
9
8
7
6
5
4
3
2



{ 1CM = 10MM

DSL 28-B
Start signal

13.6m

Cⁿ DC


CH 1 AA RANGE
DC

9.35 am
RTB 3/2/85
Running load.

Ch 3 Low RANGE
DC

Ch 1 All RANGE
DC

AMPERE HOURS PER POSITIVE PLATE



WBY GED-MS-T111-0062 Attachment 10.2


PAGE 5 of 9

15 AMPERES—1, 2 & 3 POLES
 600 V. AC, 250 V. DC

INTERRUPTING CAPACITY—R.M.S. SYMMETRICAL AMPERES


Catalog No. Prefix	No. Poles	Volts AC					Volts DC
		120	240	277	480	600	
FA, FAL 240 V. Frame	1	10,000	5,000
	2	10,000
	3	10,000
FA, FAL 480 V. Frame	1	10,000
	2	18,000	14,000
	3	18,000	14,000
FA, FAL 600 V. Frame	1	18,000	14,000
	2	18,000	14,000	14,000
	3	18,000	14,000	14,000
FH, FHL 600 V. Frame	1	65,000	25,000
	2	65,000	25,000	18,000
	3	65,000	25,000	18,000

40°C AMBIENT COLD START




Time Current Characteristic Curves


BUSS Fuses and FUSETRON dual-element Fuses




BUSS GLH Fuses $\frac{1}{4}$ x $1\frac{1}{4}$ inch.




BUSS BAF, BAN Fuses $1\frac{1}{32}$ x $1\frac{1}{2}$ inch.




LIMITRON fast-acting KLM, KTK Fuses
 $1\frac{1}{32}$ x $1\frac{1}{2}$ inch.




FUSETRON FNA dual-element, Indicating Fuses
 $1\frac{1}{32}$ x $1\frac{1}{2}$ inch.




BUSS FNQ time-delay Fuses $1\frac{1}{32} \times 1\frac{1}{2}$ inch.



FUSETRON FNQ dual-element Fuses $1\frac{1}{32} \times 1\frac{1}{2}$ inch.



FUSETRON FNM dual-element Fuses $1\frac{1}{32} \times 1\frac{1}{2}$ inch.



BUSS ANL Limiters

THERMAL-MAGNETIC MOLDED CASE CIRCUIT BREAKERS


UNIT BREAKER ONLY WITHOUT ENCLOSURES

WBN EEB-MS-111-0062
 PAGE 54A3
 of 11/10/76
 ATTACHMENT 10.6

Thermal-magnetic molded case circuit breakers shown on Pages 60-62 are UL listed, CSA certified, IEC rated, and also meet the requirements of Federal Specification W-C-375B/GEN as indicated on Page 54. For I-LINE molded case circuit breakers, see listings on Pages 102-105.

FA 100 AMPERE FRAME—PERMANENT TRIP

Ampere Rating	One Pole 120V. ac, 125V. dc		Two Pole 240V. ac, 250V. dc		Three Pole 240V. ac, 250V. dc		Terminal Lug Wire Size
	Catalog Number	Price	Catalog Number	Price	Catalog Number	Price	
15	FAL12015	\$63.	FAL22015	\$107.	FAL32015	\$157.	#14-4 Cu #12-4 Al
20	FAL12020	63.	FAL22020	107.	FAL32020	157.	
25	FAL12025	63.	FAL22025	107.	FAL32025	157.	
30	FAL12030	63.	FAL22030	107.	FAL32030	157.	
35	FAL12035	63.	FAL22035	107.	FAL32035	157.	
40	FAL12040	63.	FAL22040	107.	FAL32040	157.	
45	FAL12045	63.	FAL22045	107.	FAL32045	157.	
50	FAL12050	63.	FAL22050	107.	FAL32050	157.	
60	FAL12060	63.	FAL22060	107.	FAL32060	157.	
70	FAL12070	85.	FAL22070	173.	FAL32070	225.	
80	FAL12080	85.	FAL22080	173.	FAL32080	225.	
90	FAL12090	85.	FAL22090	173.	FAL32090	225.	
100	FAL12100	85.	FAL22100	173.	FAL32100	225.	




FA 100 AMPERE FRAME—PERMANENT TRIP

Ampere Rating	One Pole 277V. ac, 125V. dc		Two Pole 480V. ac, 250V. dc		Three Pole 480V. ac, 250V. dc		Terminal Lug Wire Size
	Catalog Number	Price	Catalog Number	Price	Catalog Number	Price	
15	FAL14015	\$80.	FAL24015	\$194.	FAL34015	\$249.	#14-4 Cu #12-4 Al
20	FAL14020	80.	FAL24020	194.	FAL34020	249.	
25	FAL14025	80.	FAL24025	194.	FAL34025	249.	
30	FAL14030	80.	FAL24030	194.	FAL34030	249.	
35	FAL14035	80.	FAL24035	194.	FAL34035	249.	
40	FAL14040	80.	FAL24040	194.	FAL34040	249.	
45	FAL14045	80.	FAL24045	194.	FAL34045	249.	
50	FAL14050	80.	FAL24050	194.	FAL34050	249.	
60	FAL14060	80.	FAL24060	194.	FAL34060	249.	
70	FAL14070	100.	FAL24070	252.	FAL34070	295.	
80	FAL14080	100.	FAL24080	252.	FAL34080	295.	
90	FAL14090	100.	FAL24090	252.	FAL34090	295.	
100	FAL14100	100.	FAL24100	252.	FAL34100	295.	




FA 100 AMPERE FRAME—PERMANENT TRIP

Ampere Rating	One Pole		Two Pole 600V. ac, 250V. dc		Three Pole 600V. ac, 250V. dc		Terminal Lug Wire Size
	Catalog Number	Price	Catalog Number	Price	Catalog Number	Price	
15	FAL26015	\$225.	FAL36015	\$289.	#14-4 Cu #12-4 Al
20	FAL26020	225.	FAL36020	289.	
25	FAL26025	225.	FAL36025	289.	
30	FAL26030	225.	FAL36030	289.	
35	FAL26035	225.	FAL36035	289.	
40	FAL26040	225.	FAL36040	289.	
45	FAL26045	225.	FAL36045	289.	
50	FAL26050	225.	FAL36050	289.	
60	FAL26060	225.	FAL36060	289.	
70	FAL26070	285.	FAL36070	355.	
80	FAL26080	285.	FAL36080	355.	
90	FAL26090	285.	FAL36090	355.	
100	FAL26100	285.	FAL36100	355.	



KA 225 AMPERE FRAME—600V. AC, 250V. DC PERMANENT TRIP

Ampere Rating	AC Magnetic* Trip Settings Amperes		Two Pole		Three Pole		Terminal Lug Wire Size
	Low	High	Catalog No.	Price	Catalog No.	Price	
70	350	700	KAL26070	\$662.	KAL36070	\$830.	One #4-300 MCM Cu or Al
80	400	800	KAL26080	662.	KAL36080	830.	
90	450	900	KAL26090	662.	KAL36090	830.	
100	500	1000	KAL26100	662.	KAL36100	830.	
110	550	1100	KAL26110	662.	KAL36110	830.	
125	625	1250	KAL26125	662.	KAL36125	830.	
150	750	1500	KAL26150	662.	KAL36150	830.	
175	875	1750	KAL26175	662.	KAL36175	830.	
200	1000	2000	KAL26200	662.	KAL36200	830.	
225	1125	2250	KAL26225	662.	KAL36225	830.	



*UL 489 magnetic trip setting tolerances are ±25% (Low) and ±20% (High) from the nominal values shown.



Additional Information
 Accessories Pages 76-77
 Lugs Pages 78-79
 Dimensions Page 63
 Interrupting Data Page 54
 DP CATALOG REFERENCE FAL CLASS 650
 KAL CLASS 655

I-LINE is a Registered Trademark of Square D Company.



ONE-TIME General Purpose—NON And NOS

Time-Current Characteristic Curves—Average Melt



Note—Contact Bussmann for Latest Performance Data.

ATTACHMENT 10.8




STATIONARY BATTERIES

25 to 200 AMP. HOURS
DU - Lead Antimony
DCU - Lead Calcium




SPECIFICATIONS

CAPACITY	25 to 200 Amp. Hrs. at 8 Hr. Rate to 1.75 F.V.		
PLATES	Height	Width	Thickness
Positive	5 7/8"	5 5/8"	.266"
Negative	5 7/8"	5 5/8"	.170"
Outside Neg.	5 7/8"	5 5/8"	.110"
SPECIFIC GRAVITY	1.210 @ 77° F.		
CONTAINERS	Thermoplastic		
CELL COVERS	Thermoplastic		
SEPARATORS	Microporous		
RETAINERS	Fibrous glass mats		
SEDIMENT SPACE	1/2" (9/16" - 11 plate)		
ELECTROLYTE	Height above plate 1 3/4" (1 5/8" - 11 plate)		



3DCU-9



- 1 Saffee-Vent (optional) — Prevents accidental spark or flame from entering cell. Water can be added without removing vent.
- 2 Hi-Impac Cover — Virtually eliminates cover breakage.
- 3 Shock-Resistant, Transparent Container — Thermoplastic containers have high impact resistance and virtually eliminate breakage.
- 4 Close-Set Plates — Reduce internal resistance. This design provides the high current rates needed for short term, high-draw loads.

Type of Cell		Cells Per Unit	Rated Capacities (Amp. Hrs. to 1.75 V. per Cell)			1 Minute Rate (Amperes)		Overall Dimensions (Inches)			Approx. Wt. (Pounds)		Elect. per Cell (Lbs.)
Calcium	Antimony		8 Hrs.	3 Hrs.	1 Hr.	To FV 1.75	To FV 1.50	L	W	H	Net Filled	Dom. Packed	
2DCU-3	2DU-3	2	25	19	12.5	37.5	71	3 1/32	7 3/8	10 1/16	18	22	3
3DCU-3	3DU-3	3	25	19	12.5	37.5	71	5 3/32	7 3/8	10 1/16	27	32	3
2DCU-5	2DU-5	2	50	38	25	75	142	3 1/32	7 3/8	10 1/16	22	26	2.8
3DCU-5	3DU-5	3	50	38	25	75	142	5 3/32	7 3/8	10 1/16	33	38	2.8
2DCU-7	2DU-7	2	75	57	38	111	212	6 3/8	7 3/8	10 1/16	36	40	5.8
3DCU-7	3DU-7	3	75	57	38	111	212	9 1/32	7 3/8	10 1/16	53	58	5.8
2DCU-9	2DU-9	2	100	76	50	148	282	6 3/8	7 3/8	10 1/16	40	44	5.3
3DCU-9	3DU-9	3	100	76	50	148	282	9 1/32	7 3/8	10 1/16	60	65	5.3
2DCU-11	2DU-11	2	120	90	60	184	342	7 1/2	7 3/16	10 1/4	48	55	5.8
3DCU-11	3DU-11	3	120	90	60	184	342	11 1/8	7 1/16	10 1/4	71	79	5.8
DCU-13	DU-13	1	150	114	75	220	405	6 3/8	7 3/8	10 1/4	38	44	12.5
DCU-15	DU-15	1	175	132	88	253	465	6 3/8	7 3/8	10 1/4	40	46	11.5
DCU-17	DU-17	1	200	150	100	288	524	6 3/8	7 3/8	10 1/4	42	48	10.5

MKW POWER SYSTEMS, Inc.

Post Office Box 1928
Rocky Mount, NC 27802-1928
Phone: (919) 977-2720
TWX: (510) 929-0725
FAX: (919) 446-1134

WPN EEB-M5-T11-0062
WDPED 829104002
6/9/10/91

ATTACHMENT

10.9
Page 1 of 1

TELEFAX

DATE: 12/12/90
COMPANY: _____
FAX NUMBER: 615/368-1142
ATTENTION: JOHN MANNONE - EBASCO
REFERENCE: D.C. PUMPS
FROM: DON GALBREATH

YOU DO NOT RECEIVE ALL PAGES LISTED. PLEASE CALL OUR WORD PROCESSING DEPARTMENT.
(919) 977-2720, EXTENSION 212.

PAGES (INCLUDING COVER SHEET): 1

Response to your telecon with our Milton Sharpe this morning
Upon loss of AC power, DC lube oil pumps will
come on in approx. 1 minute or less.

DC FUEL OIL PUMP COMES ON ONLY DURING ENGINE
STARTING (UPON ACTIVATION OR START SIGNAL) AND TURNS
OFF ONCE ENGINE FUEL PUMP PRESSURE BUILDS (10 SECS MAX).
IF WHILE THE ENGINE IS RUNNING, THE ENGINE PUMP LOOSES
PRESSURE, THE DC FUEL PUMP WILL START AS A BACKUP
IN A MATTER OF A FEW SECONDS.

* 12-12-90 2:20 PM Telephone conversation w/ Don
Expanded on start times for dc lube oil pump motors
depending on temperature, typically min time 6.5 sec
30 sec but not less than 10 sec

12/12/90

MAINTENANCE REQUEST

DAY: 21 YEAR: 90 TIME: CST.

EQUIPMENT IDENTIFIER: UNIT: FUNCTION: SYSTEM: ADDRESS: 5

IDENT NAME: EQUIPMENT REFER TO AC 2
2AA DC Lube Oil & DC Fuel Pump Motors

LOCATION: BLDG: DGB ELEV: 1A

ASSIGNED TO: MECH. ELEC. INSTRUMENT OUTAGE OTHER

DESCRIPTION REQUESTED: NEED STARTING CURRENTS FOR EACH DC LUBE OIL CIRC PUMP & EACH DC FUEL PUMP ON DG 2A Train A WITH HARD COPY (RECOMMEN VISICORDER). ORIGINATOR DESIRES TO BE PRESENT DURING DATA COLLECTION

INITIATOR: John C. Mannone EXT: 1096 SECTION: ELEC SUPV. INITIALS: cel

APPLICABLE LCO TECH: SPEC. TIME LIMIT: HRS

EQUIPMENT CATEGORY: CLASS 1E YES NO CLASS 2E YES NO CLASS 3E YES NO CLASS 4E YES NO CLASS 5E YES NO

INSTRUCTIONS (INCLUDING APPLICABLE PLANT INSTRUCTIONS): See ATT 1

WBNEEBMSTH0062
CALC. WPPE 0829174002
ATTACHMENT
10.10
Page 1 of 7 47

ACTIONS/POST MAINT. COMMENTS: None

WORK/QE REVIEW (CSSC ONLY): WORK CREW SIZE: 2 TOTAL ESTIMATED MANHOURS: 1

SUPV. SIGNATURE: [Signature] DATE: 11-27-90 QE SIGNATURE: [Signature] DATE: 11-1-90

OPER. REVIEW: [Signature] DATE: 11-29-90

JOB SAFETY PLANNING (SEE FORM TVA 613601): [Signature] DATE: 11-29-90

WORK AUTHORIZATION: [Signature] DATE: 11-29-90

ACTIVE ACTION/PERFORMED: Assisted T&CS in obtaining start and run data on motors listed. Starting amps obtained using T&CS recorder 561333 Due 9-25-91 40 amp & 90 amp scale. About 471567 Due 9-23-91 (T&F 1000 not quick enough for starting amps). See attachment I for start & run amp data

RE: No failure

MATERIAL PROCUREMENT No's: 625, 4421, 4139, 209, 201, 144's) No material used

TECHNICIANS: J. Boyd, J. Watson, R. B. [Signature]

POST MAINTENANCE TEST(S) COMPLETE: [Signature] DATE: 11-30-90

ALL WORK/TESTING COMPLETE: [Signature] DATE: 12/3/90

MR COMPLETE - QE REVIEW (CSSC ONLY): [Signature] DATE: 1/1

CALL. ~~W3PC002910~~ ^{SPALVA?} ~~W3NEEBMSTII10062~~
ATTACHMENT
10.10
Page ~~3 of 7~~ 49

ATTACHMENT I
MR#A-617680
PAGE 1 OF 1

STANDARD PROCEDURES TO USE DURING MAINT. ACTIVITIES.

APP. B OF AI-9.2.3: Configuration control during maint activities.
AI-1.8: Housekeeping.

OBTAIN AMP READINGS
REFER TO A.E.L.

Reference drawings: 45W760-82-2; 45W760-82-6.

Extreme caution will need to be observed during performance of this task since it will require working close to energized equipment.

Contact MR originator prior to starting performance of this MR.

Assist TC&S personnel in connecting a visicorder to obtain amp readings on referenced motors as requested by MR originator. Also take amp readings using model TIF 1000 ammeter and record data below.
NOTE: System Engineer John Tucker will be available for lending technical assistance if needed.

Motor ID#	<u>2MTR-092-DOPA-A</u>	Amp reading	<u>53</u> / <u>4</u> Amp
Motor ID#	<u>2MTR-092-DOPB-B</u>	Amp reading	<u>53</u> / <u>3</u> AMP
Motor ID#	<u>2MTR-082-0054/3</u>	Amp reading	<u>36</u> / <u>1</u> AMP
Motor ID#	<u>2MTR-082-0055/3</u>	Amp reading	<u>36</u> / <u>1</u> Amp

MT&E ID# 542789 Due Date 3-6-91

TIF 1000 RAID 11-29-90

Craft shall verify that the device/devices that has/have been worked upon is/are properly reinstalled after maintenance. By the installation of all bolts, screws, parts, covers, fasteners, etc. and that they are snug tight.

"Snug tight"--The tightness that exists when all of the parts of the joint are in firm contact.

Jacquelyn M. Boyd 11-30-90

Richard W. B... 11-30-90

NOV 15 1990

MAINTENANCE REQUEST PLANNING CHECKLIST		MR NO. <u>A-617680</u>		YES	NO
ITEM	YES	NO			
Order/Clearance Needed		✓	Confined Space Entry Permit AI-12.6.6		✓
2.12		✓	Transient Fire Load Permit AI-12.3		✓
Inactive Sources			Fire Barrier Breaching Permit AI-12.3		✓
2.17 (Series)			Removal of Fire Protection AI-12.3		✓
Radiator Support Needed	✓		Welding AI-9.4.2, AI-9.9, and AI-9.12		✓
RA Preplanning			Spray Painting, Cleaning, Sealing—AI-9.12		✓
2.7.3, AI-2.7.11			Coating Service Level I AI-9.12 and AI-9.2.2		✓
Per Craft Support Needed	✓		Grinding, Open Flame, Spark Producing AI-9.9		✓
(Per Craft)			Drilling and Chipping Concrete AI-9.8		✓
Fire Watch Needed			Excavating Earth and Backfill AI-9.8		✓
IE Section XI (Repair/Replacement) AI-9.15			Scaffold & Temp Platform AI-12.8.2		✓
Appendix B			Open Reactor Coolant System AI-2.6		✓
Environmental Qualification (EQ)			Open Piping Systems/ Cleanliness II-27 Para III		✓
Record-keeping	✓		Torch Cutting AI-9.9 and AI-9.12		✓
Common Mode Failure Potential			Ice Condenser Access AI-2.6		✓
Environmental Review			Post Maintenance Test or Inspection		✓
AI-1.34			Radiation Work Permit (RWP) RGI-13		✓
Special Tools/Equipment Required			NDE AI-9.7		✓
None Required	✓		QA Hold Points AI-7.1		✓
Hot Temperature Work			Pre Maint Test of Containment Isol Valve II-31.4		✓
AI-9.14					
Respiratory Protection Needed					
AI-12.6.5					
Lifting					
AI-6.4					
Chemical Use					
Material Safety Data Sheets					

REMARKS:

Planner John G. [Signature]
Date 11/20/90

CALL WPNEERMSTE110062
CALL WEPF0824104002
6/4/92

ATTACHMENT
10.10

Page 4 of 7 50

WE NEEDS STILL 0062
 ATTACHMENT
 TO IC
 PAGE 7 of 7 53

AUX DC DIESEL OIL CIRC PUMP (2A-A DG) 2-MTR-8L-DOPA-A

27.15 20.75 20.5

20.5 sec

20.1




DC DIESEL FUEL PRIMING PUMP FPA

CHART NO. PRA10-2B

27.15 20.75 20.5

20.5 sec

20.1






CHARTER POWER SYSTEMS

WBNEEBMSTII10062
Attachment 10.11 page 5A

KCR LEAD-CALCIUM

Standby Batteries - 20-year environmental and seismic qualified
- 100 percent capacity on delivery




Specifications

- | | | | |
|-------------------------|----------------------|---------------------|----------------------|
| PLATES | Height | Width | Thickness |
| • Positive..... | 11.38 in
(289 mm) | 8.75 in
(222 mm) | 0.312 in
(7.9 mm) |
| • Negative..... | 11.38 in
(289 mm) | 8.75 in
(222 mm) | 0.210 in
(5.3 mm) |
| • Outside negative..... | 11.38 in
(289 mm) | 8.75 in
(222 mm) | 0.130 in
(3.3 mm) |
- SPECIFIC GRAVITY**.....1.215 nominal @77 F (25 C)
- CONTAINER** †.....Transparent thermoplastic
- CELL COVER**.....High-impact, flame-retardant thermoplastic with tongue-and-groove seal; flammability ratings: UL 94-V0, ASTM D-635 self-extinguishing
- SEPARATORS**.....Microporous
- RETAINERS**.....Fibrous glass mats
- ELECTROLYTE HEIGHT ABOVE PLATES**.....2.06 in (52 mm)
- WITHDRAWAL TUBES**.....Two per cell
- SEDIMENT SPACE**.....0.75 in (19.1 mm)
- TERMINALS**.....3KCR-5: two 0.5 in x 1.38 in (12.7 mm x 35 mm) cast lead terminals; KCR-7 through 21: two 1 in (25 mm) square posts per cell (Copper inserts are used with 15 through 21 plates.)
- VENT CAPS**.....Flame arrester type with dust cap
- †**OPTIONAL CONTAINER**.....Transparent, flame-retardant polycarbonate; flammability ratings: UL 94-V2, ASTM D-635, self-extinguishing

Type of Cell	Nominal capacities to 1.75 average VPC @ 77 F (25 C) (Includes connector voltage drop)*						Overall dimensions			Approx wt. (lbs) (kgs)		Elec- trolyte per cell (lbs) (kgs)
	Ampere-hours			Amperes			L (in) (mm)	W (in) (mm)	H (in) (mm)	Net filled	Dom. packed	
Calcium	8 hrs	3 hrs	1 hr	30 min	15 min	1 min	8.53 217	10.44 265	18.25 464	122 55.3	135 61.2	13 5.9
3KCR-5	180	132	81	109	134	177	3.63 92.2			56 25.4	61 27.7	15 6.8
KCR-7	250	195	126	172	219	303	4.63 118			73 33.1	80 36.3	20 9.1
KCR-9	330	260	168	230	292	404	4.63 118			82 37.2	89 40.4	19 8.6
KCR-11	410	326	204	285	362	500	5.59 142			97 44.0	105 47.6	23 10.4
KCR-13	495	390	255	351	444	639	6.59 167			114 51.7	124 56.2	26 12.7
KCR-15	577	456	298	410	522	777	8.53 217			134 60.8	145 65.8	39 17.7
KCR-17	660	521	340	468	596	852	8.53 217			143 64.9	155 70.3	38 17.2
KCR-19	742	586	378	517	657	929	8.53 217			152 68.9	165 74.8	36 16.3
KCR-21	825	650	410	568	723	1010	8.53 217					

Note: Electrolyte weights approximately 10 lbs per gallon (1.210 kgs per liter).
*Data based on discharge directly from a 72-hour float condition, 60-cell battery discharged to 105 terminal volts.
IEEE-450 acceptance testing - optional, 100 percent testing of all cells at name plate rating (1 hour).

AMPERE-HOURS PER POSITIVE PLATE
 WATT-HOURS PER POSITIVE PLATE



DISCHARGE RATE OR CELL SIZING CORRECTION FACTORS FOR DETERMINING INDIVIDUAL CELL TYPE CAPABILITY (INTERPOLATE BETWEEN TIME PERIODS)

DISCHARGE TIME PERIOD

TYPE	2 hr	3 hr	4 hr	5 hr	10 hr	15 hr	20 hr	30 hr
HE-5	1.031	1.015	1.000	1.000	1.000	1.000	1.000	1.000
HE-5	1.011	1.015	1.000	1.000	1.000	1.000	1.000	1.000
HE-7	1.000	1.000	1.042	1.034	1.024	1.040	1.107	1.141
HE-9	1.000	1.000	1.042	1.024	1.024	1.040	1.107	1.141
HE-11	1.000	1.000	1.017	1.016	1.044	1.047	1.091	1.129
HE-13	1.000	1.000	1.035	1.024	1.048	1.102	1.134	1.204
HE-13	1.000	1.000	1.035	1.024	1.096	1.120	1.190	1.254
HE-17	1.000	1.000	1.035	1.024	1.096	1.102	1.134	1.204
HE-19	1.000	1.000	1.042	1.034	1.024	1.043	1.107	1.164
HE-21	1.000	1.000	1.017	1.013	1.043	1.049	1.071	1.141

TO DETERMINE THE PERFORMANCE CAPABILITY OF A MODEL (RATE IN AMPS OR CAPACITY IN AMP-HRS), MULTIPLY AMPS OR AMP-HRS PER POSITIVE PLATE, FOR SPECIFIED TIME AND VOLTAGE, BY THE APPLICABLE CORRECTION FACTOR.
 TO CALCULATE HOW LONG A MODEL CAN CARRY A LOAD, FIRST DIVIDE THE LOAD (AMPS) BY THE APPLICABLE CORRECTION FACTOR.

Page 1 3/24/10/12
 WANEEDMST1110062
 ATTACHMENT 10.12
 PAGE 55




TABLE OF CONTENTS

<u>Section</u>	<u>Description</u>	<u>Page No.</u>	<u>Number of Pages</u>
--	Table of Contents	1,2	2
1.0	Purpose & Scope	3,4	2
2.0	Criteria	4	-
3.0	Applicable Codes and Standards	4	-
4.0	Assumptions	4	-
5.0	References (Sources of Design Input Infor.)	4,5	1
6.0	Design Input Data	5,6	1
7.0	Computation/Analysis	6-9	3
8.0	Summary of Results	10	1
9.0	Conclusions	10	-
Appendix "A"	Sketch - Typical Schematics- Control Circuits for Diesel Generator Priming Fuel Pumps and Air Start Solenoids		3
Appendix "B"	Field Verification		2
Appendix "C"	Record of Telephone Conversation between James Dunlea of Pacific Scientific and James Parrish of ESI dated July 24, 1989 DG Priming Fuel Pump Motors - OL's		1
Appendix "D"	Temperature Effects and T-C Curves and FNM Application Data per Record of Telephone Conversation		3

THIS SHEET ADDED BY REV 3

TABLE OF CONTENTS

<u>Section</u>	<u>Description</u>	<u>Page No.</u>	<u>Number of Pages</u>
Appendix "E"	Gould Shawmut Applications Data per Facsimile Message		1
Appendix "F"	Record of Telephone Conversation between James Dunlea of Pacific Scientific and David Martin of ESI dated May 12, 1989 DG Priming Fuel Pump Motors		1
Appendix "G"	Facsimile Message from Mike Cromer of Graham-White Mfg. Co., dated June 12, 1989 Salem 3160-020 Coil-Electrical Information		1
Appendix "H"	Application data sheet for square D KPD 13 control relay - from square D Company Digest 67R, 1988		1
Appendix "I"	Cable Data		2
Appendix "J"	Characteristics Trip Curves - Square D FA/FH Family Molded Case CB's		1

This Attachment Package contains 26 total pages.

THIS SHEET ADDED BY REV. 3.

1.0 PURPOSE AND SCOPE

1.1 Purpose

- The purpose of this attachment is to evaluate and support the modifications to be implemented under DCN P-04575-A.

This attachment documents the roll-up of mini-calculation No. WBPE 0828905039.

The attachment affects the following baseline calculation:

<u>Baseline Calculation</u>	<u>Calculation No.</u>
125V DC Diesel Generator (DG) Control Power System Evaluation	WBN EEB-MS-TI11-0062

THIS SHEET ADDED BY REV 3

1.2 Scope

The scope of this calculation is to Verify and document the adequacy of the size and types of fuses installed in circuits for the diesel generator priming fuel pumps and air start solenoid valves. The fuses in the C-S engine control panels are Bussmann KLM-10 installed to implement the corrective action for NCR W-326-P R0 (Ref. 5.6) per ECN 6180 (Ref. 5.7).

2.0 CRITERIA

Each protective device (fuse) shall have a continuous rating greater than the circuit load current but less than or equal to the allowable circuit ampacity. The current interrupting capacity (AIC) shall be greater than the maximum credible fault current. The melting times must be less than the upstream breaker trip initiation time during fault conditions to assure adequate fuse-breaker coordination..

3.0 APPLICABLE CODES AND STANDARDS

3.1 Electrical Design Standard DS-E12.6.3, R2.

3.2 Electrical Design Guide DG-E2.4.6, R0.

3.3 National Fire Protection Association, NFPA 70, National Electrical Code, 1990 Edition, Articles 210-22, 240-3 (Exception No. 1) and 240-6.

4.0 ASSUMPTIONS

4.1 Justified Assumptions

The Gould Shawmut TRM-1 fuse has not been tested for maximum DC current interrupting capacity (AIC), however, typical DC ratings range from 10 to 50 percent of the AC ratings. This calculation demonstrates that the maximum SC current to which the TRM-1 would be subjected is 137 amperes (Section 7.3.2) which is less than 1.5 percent of the AC rating of 10 K AIC. Based on the above, it is assumed that the fuse will safely interrupt this small SC current.

There are no unverified assumptions.

5.0 REFERENCES

5.1 TVA Drawings - 1-45W760-82-2 (R1) and -4 (R1), Wiring Diagrams - Standby Diesel Generator System - Schematic Diagrams.

5.2 TVA Drawings - 1-45W760-82-12 (R1) and -14 (R0), Wiring Diagrams - Standby Diesel Generator SC-S - Schematic Diagrams.

5.3 Vendor Drawings - Power Systems Division Morrison-Knudsen Company, Inc. Contract 83090 - 6036F02501 Sheet 1 (R905, C) and Sheet 7 (R904, C) - Schematic Diagram - Engine Controls and Alarms.

5.0 REFERENCES (Continued)

- 5.4 Vendor Drawings - Power Systems Division Bruse GM Diesel, Inc. - Contract 83090 - D379F02501 Sheet 1 (R904, C) and Sheet 7 (R902, E) - Schematic Diagram - Engine Controls and Alarms.
- 5.5 WBNP Computerized Cable Routing System, CCRS - WBNP Cable Schedule Complete Summary.
- 5.6 Nonconforming Condition Report NCR W-326-P R0.
- 5.7 Engineering Change Notice ECN 6180.
- 5.8 Field Verification of priming fuel pump motor and air-start solenoid valves.
- 5.9 TVA Drawings - Diesel Generator Connection Diagrams

45W1780-1 RG
45W1781-1 NN
45W1782-1 RE
45W2780-1 RK
45W2781-1 RL

(TVA Contract No. 74C63-83090)

- 5.10 TVA Drawings - Environmental Data - Mild
 - 47E235-29 R2
 - 47E235-29 R2
- 5.11 Departmental Guidelines for Electrical Mini Calculation Roll-Up ELEC-004 of 4-30-91.

6.0 DESIGN INPUT DATA

- 6.1 Cable Data (See Appendix I)
- 6.2 Priming Fuel Pump Motor, (Appendix F and B)

Manufacturer: Honeywell
Model: BA36-40-1524-48BP (Nameplate)
Size: 1/2 hp
Voltage: 90VDC
FLA: 4.7 Amp
LRA: 75.0 Max

- 6.3 Air-Start Solenoid Valves, (Appendix G & B)

Manufacturer: Graham-White Mfg Co.
Type: Salem Model 712-051
Coil: 3160-020
I Holding: 0.094 Amps
I Inrush: 0.131 Amps

6.0 DESIGN INPUT DATA (Continued)

6.4 Relay (Blown Fuse), (Ref. 5.9 & Appendix H)

- Mfr/Model: Square D/KPD13
- Voltage Rating: 125VDC
- Power: 1.2 watt standard; 3 watt maximum
- I(MAX) = $3w/125\text{ VDC} = 0.024\text{ Amp}$

6.5 Fuse: Bussmann FNM-10, (Appendix D)

AIC: 10 K AIC @ 125 VDC

6.6 Fuse: Gould Shawmut TRM-1, (Ref. 4.0 & Appendix E)

Resistance Range: 0.690 - 0.795 ohm
AIC: (see 4.0)

6.7 Circuit Breaker, Molded Case (Ref. 5.9)

Mfr/Model: Square D/FAL 22015
Rating: 15 Amp, 125 VDC

7.0 ANALYSIS/COMPUTATION

7.1 Priming Fuel Pump Motor Circuits

The simplified control circuit schematic for this calculation is shown in Appendix A (Sh. 2). These circuits are identical to the similar circuits in the other DG sets; the following calculation will be generic for all circuits.

- 7.1.1 The fuse protecting a combination motor circuit must be greater than 125% of the motor load (4.7 Amps) plus 100% of the relay load (0.024 Amps)(reference 3.3), or
Minimum fuse rating = F_R

$$F_R \geq 1.25 \times 4.7 + 0.024 \geq 5.9\text{ Amps}$$

Because the ambient temperature within the diesel engine rooms can reach 120°F (reference 5.10), fuse derating is required. Adding an estimated 30°F panel internal temperature for conservatism, the derating factor of 0.85 (Appendix D) yields minimum fuse size of;

$$F_R \geq \frac{5.9\text{ Amp}}{0.85} \geq 6.94\text{ Amp}$$

THIS SHEET ADDED BY REV 3

7.0 ANALYSIS/COMPUTATION (Continued)

All conductors listed in Appendix I table 1 are #14 AWG routed in V3 (Ref. 5.5) and rated 6 amp per DS-E12.6.3 (Ref. 3.1). Therefore, per NEC section 240-6 and 240-3 exception 1, a 10 amp fuse will provide protection to the conductors and meet the above minimum requirements.

Use Bussmann style FNM or similar 10 amp dual-element, time delay fuse due to DC motor inrush. The FNM-10 is a standard stores stock item at Watts Bar Nuclear Plant.

7.2 Air Start Solenoid Valves

The simplified control circuit schematic for this calculation is shown in Appendix A (sh. 3). The other air start solenoid circuits may be treated generically for all diesel engine control panels.

The holding current for each valve coil is 0.094 Amps (Reference 6.3). The blown fuse relay current is 0.024 Amps (Reference 6.4). The load current, I_L , is

$$I_L = 2 \times 0.094 + 0.024 = 0.212 \text{ Amps}$$

$$F_R \geq 1.25 \times 0.212 \geq 0.31 \text{ Amp}$$

Again applying temperature effect fuse derating

$$\text{Min } F_R \geq 0.265/0.85 \geq 0.31 \text{ Amp}$$

The next NEC standard fuse rating above this value is 1 amp (reference 3.3). The Gould Shawmut dual-element, TRM-1 would satisfy the above criteria. The TRM-1 is a standard stores stock item at Watts Bar Nuclear Plant.

7.3 Short Circuit Coordination

7.3.1 Fuel pump motor circuits:

A review of all feeder and end device cable combinations resulted in a worst case (minimum resistance) for fuel pump FPA circuit for the 1B-B diesel generator. The resistance of Bussmann fuse FNM-10 is negligible (See Appendix D).

$$R_{PP628B} = 2 \times \frac{1.04}{1000} \times 58 = 0.12 \text{ Ohm (Appendix I)}$$

$$R_{PP527B} = 2 \times \frac{2.62}{1000} \times 58 = 0.30 \text{ Ohm (Appendix I)}$$

THIS SHEET ADDED BY REV 3

$$R_{CKT} = Z_S^* + R_{PP628B} + R_{PP527B} \text{ ohm } \text{WJH } 12-19-91 \text{ J.L.H. } 12-19-91$$

(ref. baseline calculation, 6.5 and Appendix I)

$$= (0.0682 + 0.12 + 0.30) \text{ Ohm} = 0.49 \text{ Ohms}$$

This resistance represents a SC current of

$$I_{SC} = 117.4V/R_{CKT}^* = 117.4/0.49 = 239 \text{ Amps}$$

7.0 ANALYSIS/COMPUTATION (Continued)

For this SC value, the minimum breaker trip initiation time would be approximately 0.4 seconds. The fuse melting time would be approximately 0.025 seconds and coordination is assured for a solid short circuit near the end device and the FNM has adequate current interrupting capacity of 10KAIC (reference 6.5).

Based on motor manufacturer's recommendation (Appendix E) diesel operating experience, the dual-element fuse will permit proper motor operation.

7.3.2 Air start solenoid circuits:

A short circuit at the load side of the fuse, assuming the worst case cable lengths, would involve cable PP508A (or PP748B, both are of equal length, Appendix-1 Table II).

$$R_{PP508A} = 2 \times \frac{1.04}{1000} \times 48 = 0.100 \text{ Ohm}$$

Per reference 6.6, the minimum resistance of a TRM-1 fuse is 0.690 ohm. The circuit resistance is

$$R_{CKT} = Z_S^* + R_{PP508A} + R_{TRM-1} \text{ ohm } \text{WJH } 12-19-91 \text{ J.L.H. } 12-19-91$$

$$R_{CKT} = (0.0682 + 0.100 + 0.690) \text{ ohm} = 0.86 \text{ Ohm}$$


$$I_{SC} = 117.4 \text{ VDC}^*/0.86 = 137 \text{ Amps}$$

For this SC value, this minimum breaker trip initiator time would be approximately 0.95 seconds. The fuse melting time would be less than 0.01 seconds, thus coordination is assured.

* Z_S (0.0682 Ohms) and source voltage (117.4V) from Section 6.4.7 of base calculation. Z_S is the equivalent source impedance of the battery, battery changes, fuel oil pump motors and lube oil pump motors.

THIS SHEET ADDED BY REV 3

7.3.3 Superimposed time-current characteristics curves for square D, 15 Amp FAL breaker and fuses.



8.0 SUMMARY OF RESULTS


- 8.1 The optimum fuse size/type for the priming fuel pump circuits, incorporating a derating factor due to high ambient temperature, should be a dual element, 10 Amp Bussmann FNM-10 or equivalent.
- 8.2 The load current for the air start solenoid circuits is 0.212 Amps. Application of temperature effect derating requires a dual element 1 Amp fuse Gould Shawmut TRM-1 or equivalent.
- 8.3 The coordination of fuse TRM-1 and FNM-10 with SQ-D FAL 15A breaker is shown in sheet 9.

9.0 CONCLUSION

- 9.1 The fuses presently installed in the fuel pump motor circuits in the C-S diesel generator control panels should be changed to dual element 10A fuses, Bussmann type FNM-10.
- 9.2 The fuses presently installed in the air start solenoid circuits for all diesels should be changed to 1 Amp dual element, Gould Shawmut type TRM-1.
- 9.3 These fuses will allow the circuit devices to perform their design functions. The fuses coordinate with the breakers.

THIS SHEET ADDED BY REV 3


SKETCH-TYPICAL SCHEMATIC
DIESEL GENERATOR DC CONTROL POWER (REF. 5.1 & 5.2)



* 15A, SQUARE D, FAL 22015, 2P, 125VDC

THIS SHEET ADDED BY REV 3

SKETCH - TYPICAL SCHEMATIC
CONTROL CIRCUIT FOR DIESEL
GENERATOR PRIMING FUEL PUMPS
(REF. 5.1 & 5.2)



FPA, B : PRIMING FUEL PUMP MOTORS
BF3, 4 : BLOWN FUSE RELAYS
FU3 P, N : FUSES
FU4 P, N : FUSES


NOTE: SEE SCH. 4.1 FOR CABLE KEY/IDENTIFIERS

THIS SHEET ADDED BY REV 3

J. PARRISH
1/1/89

SKETCH - TYPICAL SCHEMATIC CONTROL
 CIRCUIT FOR DIESEL GENERATOR
 AIR START SOLENOIDS (REF. 51 & 52)

LEGEND:
 ASA-A,B: AIR START SOLENOID VALVES A & B
 BF5,6: BLOWN FUSE RELAYS
 FL5(N&P): FUSES
 FL6(N&P)
 * DIESEL GEN. 1A-A, 1B-B, 2A-A, & 2B-B ONLY



NOTE: SEE ATTACHMENT D FOR CABLE KEYS
 VERSUS CABLE IDENTIFIERS

THIS SHEET ADDED BY REV 3

FIELD VERIFICATION

Priming Fuel Pump Motor

1. Manufacturer: Honeywell

Model: BA36-46-1524-48BP (Nameplate)

Size: $\frac{1}{2}$ HP

FLA: 4.7 Amp

2. Manufacturer: Applied Motor

FLA: 4.0 Amp

Other details not visible on nameplate

Honeywell motor has higher FLA of 4.7 Amp,
is worst case.

RECORDED BY *[Signature]* DATE 12-16-91

VERIFIED BY *[Signature]* DATE 12-16-91

Attachment No. P-04575-A

CALCULATION NO. WBN EEB-MS-TE11-0062

APPENDIX NO. B

Page 2 of 2

FIELD VERIFICATION

Air-Start Solenoid Valve

Manufacturer: Graham-White Mfg. Co.

Type: Salem Model 712-50

RECORDED BY *Wei for H* DATE 12-16-91

VERIFIED BY *hany* DATE 12-16-91

THIS SHEET ADDED BY REV 3

RECORD OF TELEPHONE CONVERSATION

Appendix C

Attachment No. P-04575-A

Calculation No. GUBN-EEB-MS-T111-0062

DATE July 24, 1989

TO : Files: Calc WBPE0828905039
Name/File No.

FROM : James S. Parrish, ESI

CLIENT/PROJECT: TVA - WBNP

SUBJECT: DG Pumper Fuel Pump Motors - OL's

CHARGE : DEPT. NO. _____ CLIENT SYMBOL _____ OFS NO. _____

DISCUSSION WITH James Dunlea
Pacific Scientific
(815) 226-3100

Requested whether subject pump motors had internal overload protection, and their recommendations for adequate protection.

(Reference record of tele. conversation between J. Dunlea and D. Martin dated May 12, 1989)

COMMENTS

Dunlea confirmed the motors did not contain OL's and their "maintenance bulletins" recommended 115% of FLA for adequate protection in branch circuit using dual-element, time-delay fuse.

BY: James S. Parrish, ESI
NAME TITLE DEPT. NO.

cc:

5755a

Fuse Time-Current Characteristic Curves * and Temperature Effects


*Average Total Clearing Time

Effects of Ambient Temperatures

The operating characteristics of fuses are based on a nominal ambient temperature level. Higher ambients will, to some extent, reduce the current carrying capacity and the fuse opening time. Conversely, lower ambients result in a somewhat increased current carrying capacity and opening time.

As indicated in the Fuselron graph below, for example, an ambient of 100°F (40°C) reduces the current carrying capacity of this type of fuse by 5%.

The graphs below show the effects of ambient temperatures for Fuselron and "Non-Time-Delay" fuses.



1150°F / APPROX MAX PANEL INTERNAL TEMP

Effects of Ambient Temperature on the Operating Characteristics of Fuselron Dual-Element Fuses. Nominal Fuse Ratings Based on Ambient Temperatures in the Range of 70°F (21.0°C) thru 80°F (26.7°C). Change in Opening Time Occurs with Loads of 500% (or less) of the Nominal Current Rating of the Fuse.

THIS SHEET ADDED BY REV 3

Calculation No. WBN-EEB-MS-T111-0062

Type FNM
 1 7/32" x 1 1/2" (10.3mm x 38.1mm)
 Time-Delay

Fibre. Formerly designated 5A8. A dual-element Fusetron fuse. For circuits with high inrush currents. Mount in Buss fuseholders, fuseblocks, and clips. Shipping weight per 100—1.5 lbs. (680g). U.L. File E19180; Guide JOYX. CSA File 53787; Class 1422-01.




Electrical Ratings (Catalog Symbol and Amperes)

250 Volts	250 Volts	125 Volts	250 Volts
FNM-1/10	FNM-1 1/8	FNM-3	FNM-8
FNM-1 1/100	FNM-1 1/2	FNM-3 1/10	FNM-9
FNM-2/10	FNM-1 5/10	FNM-3 1/2	FNM-10 U.L. Listed & CSA
FNM-1/2	FNM-1 1/2	FNM-4	125 Volts
FNM-3/10 U.L. Listed & CSA	FNM-1 9/10 U.L. Listed & CSA	FNM-4 1/2 U.L. Listed & CSA	FNM-12
FNM-5/10	FNM-1 11/10	FNM-5	FNM-15
FNM-7/10	FNM-2	FNM-5 1/10	32 Volts
FNM-9/10	FNM-2 1/2	FNM-6	FNM-20
FNM-11/10	FNM-2 1/2	FNM-5 1/2	FNM-25
FNM-1	FNM-2 1/10	FNM-7	FNM-30

LEGIBILITY EVALUATED and ACCEPTED for issue

G. Pan 10/11/89
 Signature Date



50861 (1985) 6
 Time-Current Curves - Typical
 LRA 75A
 I_{SC} = ~245A

U.L. File E19180; CSA File 53787

THIS SHEET ADDED BY REV 3

DATE 7/10/89
9/20/89 (supplement)

TO : Files: Calc
Name/File No.
FROM : JIM PARRISH, EST
CLIENT/PROJECT : TVA WBN
SUBJECT : AIC for Busman FNM fuses
CHARGE : DEPT. NO. _____ CLIENT SYMBOL _____ OFS NO. _____

DISCUSSION WITH Jim Catzouz
Busman Fuses
(314)-394-2877

Per Jim, the AIC for the FNM
is 10 KAIC @ 125VDC.

9/20/89 - Supplementing
contacted Jim again requesting FNM resistances with
following results:

	OHMS RESISTANCE RANGE (COLD)
FNM-1	0.450 - 0.750
FNM-8	0.011 - 0.0135
FNM-10	0.0072 - 0.00730

COMMENTS

BY: [Signature] S. Enr EE
NAME TITLE DEPT. NO.

cc:
5755e

THIS SHEET ADDED BY REV 3

DATE 8/23/89

TO CINDY CLINE - GOULD SHAWMUT
NAME/FILE NO.

FROM BRIAN FORTENBERY - EBASCO SERVICES, INC.

CLIENT/PROJECT TVA / WATTS BAR NUCLEAR PLANT

SUBJECT FUSE RESISTANCE

CHARGE# _____ DEPT. NO. _____ CLIENT SYMBOL _____ OFFS NO. _____

DISCUSSION WITH CINDY CLINE OF GOULD-SHAWMUT REVEALED

THAT ^{COLD} THE RESISTANCE OF T&M-1 FUSES IS
0.690 - 0.795 OHMS.

The above info is correct.

Brian Fortenbery
Applications Engineer

COMMENTS

BY Brian Fortenbery ANGR. ELEC.
NAME TITLE DEPT. NO.

THIS SHEET ADDED BY REV 3

DATE May 12, 1989

TO Pacific Scientific (EIS) 226-3100
FROM David Martin NE-EGASCO WBNP
CLIENT PROJECT TVA/WBNP
SUBJECT Diesel Generator Primer Fuel Pump
CHARGE: DEPT. NO. _____ CLIENT SYMBOL _____ OFS NO. _____

DISCUSSION WITH

James Dunlea referred by John Tucker TVA/WBNP maintenance ext. 8591
Honeywell sold this motor division to Pacific Scientific
base on information given to Pacific Scientific:
see appendix B.

~~90VDC, 4.7 amp 12~~ DM 5/12/89

- (1) Replacement motor in TVA shop Honeywell model BA36-40-152A-488B 1/2 HP 125VDC 2300RPM FLA
- (2) Motor in service Honeywell 90VDC, 4.7 amp
- (3) Pump supplied to Morrison Knudsen Co for TVA contract # 74C63-834

COMMENTS

James Dunlea provide the following information

Honeywell 90VDC
FLA 4.7 AMP
LRA 75.0 MAX
RPM 1750
1/2 H.P.

LEGIBILITY EVALUATED and ACCEPTED for Issue

G. Pan 10/11/89
Signature Date

CC:

BY David Martin EE NE-EGASCO
TVA DEPT. NO.

THIS SHEET ADDED BY 3

EXT 1768



Attachment No. P 04575-A

Appendix G

Calculation No. WBN EEB-MS-T111-0062

Graham-White Sales DIVISION

GRAHAM-WHITE MANUFACTURING COMPANY

Pneumatic and Electro-Pneumatic Devices

FAX NO.: 615/363-1142

TO: Mr. David Martin
Tennessee Valley Authority

DATE: 6/12/89

SUBJECT: Salem 3160-020 Coil Electrical Information

MESSAGE: Dear Mr. Martin,

With reference to our conversation this morning, I am pleased to furnish the following information on the Salem 3160-020 coil:
in rush current 131 milliamps
holding current 94 milliamps

Should you require additional information, please advise.

Mike Cromer

THIS SHEET ADDED BY REV. 3

1242 COLORADO STREET

P.O. BOX 1098

SALEM, VA 24183-1098

PHONE (703) 387-8820

FAX (703) 387-8830

P. 11

JUN 12 1989 11:29 AM GRAHAM WHITE SALEM, VA

GENERAL PURPOSE CONTROL RELAYS

TYPE K

8501

APPLICATION DATA — TYPE K
 CONTACT RATINGS

AC					DC			
Volts	Amperes				HP	Volts	Amperes	
	Inductive 35% PF		Resistive 75% PF				Make Break	Con- tinuous
	Make	Break	Con- tinuous	Make, Break & Continuous				
120	30	3	10	10	1/20	60 VA	10 A	
240	15	1.5	10*	10*	1/4			

* 3 pole devices have 60 Amps max. continuous rating.
 Δ Type KP rated 1/4 HP.

OPERATING DATA

- Pick-Up Time:
 - Types KF, KP, KU — Approximately 15 ms
 - Type KL — Approximately 25 ms
- Drop-Out Time:
 - Types KF, KP, KU — Approximately 10 ms
 - Type KL — Approximately 25 ms
- Operating Temperature Ranges:
 - Types KF, KP, KU
 - AC: 2 pole: -45°C to +55°C (-49°F to +131°F)
 - 3 pole: -45°C to +45°C (-49°F to +113°F)
 - DC: -45°C to +70°C (-49°F to +158°F)
 - Type KL
 - AC/DC: -45°C to +70°C (-49°F to +158°F)

LEGIBILITY EVALUATED and
 ACCEPTED for issue

Glenn 10/11/89
 Signature Date

CONTACTS

- Configuration: 2 or 3PDT (2 or 3 Form C)
- Material: Silver cadmium oxide
- Rating: See table above

UL/CSA

- UL Component Recognized and CSA Certified
- UL listed with appropriate Class 8501 Types NR-51, NR-52, NR-61, NR-62 and NR-82 sockets.

COILS

- Duty: Continuous rated coils
- Standard Voltages:

	Type KP	Types KU, KF	Type KL
AC	8, 12, 24, 48, 110, 125, 130	8, 12, 24, 48, 120, 240	24, 120, 240
DC	8, 12, 24, 48, 110, 125, 130	8, 12, 24, 48, 110	12, 24


DC: 75% of Nominal Voltage at 25°C (77°F)

Type KP:
 DC: 1.2 watts standard
 3 watts maximum


AC: 2 pole — 3 VA inrush,
 2 VA sealed
 3 pole — 3.4 VA inrush,
 2.7 VA sealed

DC: 1.2 watts standard
 3 watts maximum
 Type KL:
 AC: 2.0 VA latch, 0.6 VA unlatch
 DC: 1.22 watts

WIRING DIAGRAMS



APPROXIMATE DIMENSIONS



THIS SHEET ADDED BY REV 3



Appendix I

TABLE I
END DEVICE BRANCH CABLES

KEY (1) LETTER	CABLE I.D. (2)	FUSE	DG (3)	CIRCUIT	LENGTH (5)
A	PP1646-S	FU3P, N	C-S	FPA	74
B	PP1651-S	FU4P, N	C-S	FPB	96
C	PP1648-S	FU5P, N	C-S	ASSA	74
D	PP1653-S	FU5P, N	C-S	ASSB	96
E	PP1649-S	FU6P, N	C-S	ASSA	74
F	PP1654-S	FU6P, N	C-S	ASSB	96
A	PP287-A	FU3P, N	1A-A	FPA	53
B	PP288-A	FU4P, N	1A-A	APB	75
C	PP284-A	FU5P, N	1A-A	ASSA	53
D	PP285-A	FU5P, N	1A-A	ASSB	75
E	PP281-A	FU6P, N	1A-A	ASSA	53
F	PP282-A	FU6P, N	1A-A	ASSB	75
A	PP527-B	FU3P, N	1B-B	FPA	58
B	PP528-B	FU4P, N	1B-B	FPB	70
C	PP524-B	FU5P, N	1B-B	ASSA	58
D	PP525-B	FU5P, N	1B-B	ASSB	70
E	PP521-B	FU6P, N	1B-B	ASSA	58
F	PP522-B	FU6P, N	1B-B	ASSB	70
A	PP407-A	FU3P, N	2A-A	FPA	68
B	PP408-A	FU4P, N	2A-A	FPB	80
C	PP404-A	FU5P, N	2A-A	ASSA	68
D	PP405-A	FU5P, N	2A-A	ASSB	80
E	PP401-A	FU6P, N	2A-A	ASSA	68
F	PP402-A	FU6P, N	2A-A	ASSB	85
A	PP647-B	FU3P, N	2B-B	FPA	68
B	PP648-B	FU4P, N	2B-B	FPB	80
C	PP644-B	FU5P, N	2B-B	ASSA	68
D	PP645-B	FU5P, N	2B-B	ASSB	80
E	PP641-B	FU6P, N	2B-B	ASSA	68
F	PP642-B	FU6P, N	2B-B	ASSB	80

THIS SHEET ADDED BY REV 3

Appendix I (continued)

TABLE II

ENGINE CONTROL PANEL FEEDERS

Cable I.D. (4)	Length (5)	DG
PP388A	53	1A-A
PP508A	48	2A-A
PP628B	58	1B-B
PP748B	48	2B-B
PP1640S	59	C-S

NOTES:

1. Refer to Appendix A for key letter vs. cable identifier
2. Cable identifiers obtained from Diesel Generator Connection Diagrams (Reference 5.9).
3. Cables are type WHB or WHB-1, No. 14 AWG (reference 5.5). Resistance (min) @ 25°C = 2.62 ohm/1000 ft (ref. 3.2).
4. All feeder cables are #10 AWG per CCRS (reference 5.5). Resistance (min) @ 25°C = 1.04 ohm/1000 ft (ref. 3.2)
5. CCRS design lengths (reference 5.5)
6. Vendor supplied feeder cables from battery to DC distribution panels are 2-1/C #2/0; field estimated at approximately 8 to 10 feet. The resistance (min) @ 25°C is


$$2 \times \frac{0.0812}{1000} \times 8 = 0.0013 \text{ ohm (reference 3.2)}$$

THIS SHEET ADDED BY REV 3.

FAITH FAMILY MOLDED CASE CIRCUIT BREAKERS
CHARACTERISTIC TRIP CURVE NO. 850-1

CIRCUIT BREAKER INFORMATION			
Current Breaker Poles	Current Rating	Maximum AC Voltage	Number of Poles
1A	15 A	700	10 1/2"
2A		700	10 1/2"
3A		700	10 1/2"
3A 3M		700	12 1/2"

This curve is to be used for application and coordination purposes only. The EZ-AMP overlay feature at the bottom of the page should be used during coordination studies.
All time/current characteristic curve data is based on 10° C ambient cold start. Terminations are made with conductors of appropriate length and ratings.



SQUARE D

MULTIPLES OF RATED CURRENT

EZ-AMP

TABLE OF CONTENTS

	<u>SHEET NO.</u>	<u>NUMBER OF PAGES</u>
-- Table of Contents	1	1
1.0 Purpose & Scope	2	1
2.0 Criteria	2	-
3.0 Applicable Codes and Standards	3	1
4.0 Assumptions	3	-
5.0 References	3	-
6.0 Design Input Data	3	-
7.0 Analysis	4	1
8.0 Summary of Results	4	-
9.0 Conclusions	4	-
10.0 Appendixes (Including Supporting Graphics)		
Appendix "A" Telephone Call and Visit Report	-	2
Appendix "B" Buss Small Dimension Fuses Fuse Holders & Accessories-Pg 20	-	1

This attachment contains 7 pages.

THIS SHEET ADDED BY REV 4

1.0 PURPOSE AND SCOPE

1.1 Purpose

The purpose of this attachment is to evaluate the modification to be implemented under Design Change Notice (DCN) S-15660-A. This DCN was issued to document the replacement of fuses "MIS 1". As referenced in DCN S-15660-A the replacement of fuses "MIS 1" will be for the standby diesel generator system (system 82) fuses as follows:

- a. 0-FU-82-DC3-S
- b. 1-FU-82-DA3
- c. 1-FU-82-DB3
- d. 2-FU-82-DA3
- e. 2-FU-82-DB3

1.2 Scope

The following problem and its corresponding resolution are addressed by this calculation.

"MIS-1" is being used as a blown fuse indicator. This is a misapplication (Appendix "A") and a replacement actuator must be selected.

2.0 CRITERIA

2.1 The "MIS 1" replacement must meet the following criteria:

- A. Have an operating voltage rating which equals or exceeds the circuit voltage.
- B. Have a fault current interrupting capacity rating greater than 1721A (Ref. 5.2 Pg 16).
- C. Is physically interchangeable with the original fuse.
- D. Must meet performance requirements necessary to be an actuating device.

THIS SHEET ADDED BY REV 4

Calculation No. WBN EEB-MS-TI11-0062
Attachment No. S-15660-A
125V DC Diesel Generator
Control Power System Evaluation

Prepared by M. S. Madala Date 3-26-92

Checked by [Signature] Date 3-26-92

Sheet 3

3.0 APPLICABLE CODES AND STANDARDS

See Baseline Calculation. (Section 3.3)

4.0 ASSUMPTIONS

JUSIFIED

See assumptions identified in the Baseline Calculation (Section 2.0 & 5.0).

UNVERIFIED

None per this attachment (see baseline for existing UVA's)

5.0 REFERENCES

5.1 DCN S-15660-A substitute fuses

5.2 TVA Baseline Calculation WBN EEB-MS-TI11-0062 R3, 125C DC, Diesel Generator (DG) Control Power System Evaluation.

5.3 1-45W703-1, R1 Wiring Diagrams 125V Vital Battery Board I, Single Line Sheet 1.

5.4 TVA Electrical Design Standard "DS-E8.1.1" R7 fuses

6.0 DESIGN INPUT DATA

See Design Input Data identified in Baseline calculation (Section 4.0).

THIS SHEET ADDED BY REV 4

7.0 COMPUTATION/ANALYSIS

7.1 "MIS 1" replacement (Section 1.2 & 2.1), analysis will be done with a KAZ Actuator.

7.1.1 The circuit nominal voltage is 125V DC with a range of 135V DC to 105V DC (Ref. 5.3). The KAZ Actuator rating is 150V (Ref. 5.4).

7.1.2 The fault current rating of the KAZ Actuator is 10,000 A (Ref. 5.4).

7.1.3 The "MIS 1" and the KAZ Actuator are both 13/32" x 2" in dimension (Appendix "B").

7.1.4 The KAZ Actuator is a device that provides blown fuse indication. (Appendix "B")

8.0 SUMMARY OF RESULTS

8.1 An acceptable qualified replacement for the "MIS 1" is the KAZ Actuator.

8.1.1 The circuit nominal voltage is 125V DC with a range of 135V DC to 105V DC (Ref. 5.3). The KAZ Actuator rating is 150V (Ref. 5.4).

8.1.2 The fault current rating of the KAZ Actuator is 10,000 A (Ref. 5.4).

8.1.3 The "MIS 1" and the KAZ Actuator are both 13/32" x 2" in dimension (Appendix "B").

8.1.4 The KAZ is an actuator device to provide blown fuse indication (Appendix "B").

9.0 CONCLUSIONS

9.1 The KAZ Actuator performs the required functions of a blown fuse indicator and should be used as a replacement for the "MIS-1" fuse.

THIS SHEET ADDED BY REV 4

TELEPHONE CALL AND VISIT REPORT

CALCULATION: WAW EEB-MS-T111-006

ATTACHMENT B (Page 1 of 2)

APPENDIX 'A' Sh 1 of

TV (OS-3-80)	To	Telephone Number	Date	Time
Telephone Call	From		9/27/90	

Name
George Martin - CEG, Aaron Lambert, Ed Eggers Flc, Cedric Graham - EQ

Title

Company or Organization

Location

Subject(s) Watts Bar Nuclear Plant.
Fuse Procurement, EQ review JBOX 001.

Follow-Up	By Letter	By Telephone	Other
-----------	-----------	--------------	-------

Remarks

1) Met with Geo. Martin. He is requested to buy class 1E MIS-5, MIN-3, and MIS-1 fuses. Fuse list shows few applications. The MIS-5 has in the past failed seismic tests and is not really suitable for 1E applications. Recommendation is that MIS-5 be replaced with FLAS-5 which is a qualified fuse which can be bought and dedicated by TVA.

MIN-3 is a pin indicating type fuse and is not a class 1E fuse, it can be bought as QAIII ~~and~~ and seismic provided by TVA for 1E if necessary.

The MIS-1 is being used as a blown fuse indicator and is a misapplication. This fuse should be replaced with a KA2 actuator.

Recommend DCN to replace the MIS-1 with a KA2. Also need DCN to replace MIS-5 with FLAS-5 and correct the use of FRN 15 in one MIS-5 slot (Incorrect fuse list).

The MIN-3 is non 1E application. Fuse info. coordinated with Aaron Lambert, Ed. I

2) Fuse list and PR's show Federal Pacific fuses which field apparently used to replace Bussman's, Shawmut fuses originally furnished. These cannot be bought as commercial grade and dedicated, need to be replaced with Bussman or Gould-Shawmut. Geo. has written DCN requesting this. If agree it should be done to make procurement easier and reduce different types of fuses stocked.

3) Met with Cedric Graham, signed JBOX 001 binder per telecon with JKG.

Material Given (OVER)


THIS SHEET ADDED BY REV 4

Signed J.R. Smith, Eng. Specialist

APPENDIX 'A' sheet 2 of 2

ATTACHMENT B
(Page 2 of 2)

- Item 1 above indicates problem with the fuse list. The list is based on field walkdown data for "as constructed" configuration. This represents a snapshot at the time of the walkdown. Certain fuse changes were reviewed and calculations verified acceptability of installed fuses. This was not done for all fuses as is evident in the situation where we had a control circuit fused in both legs. One fuse was a 5A MIS-5 fuse. The other fuse is shown to be a 15A FRN installed by mistake.



Also the "as constructed" configuration showed a MIS-1 installed where you would expect to find a KAZ actuator.


The FPE fuses are apparently replacements for the fuse originally qualified with the equipment. Since Civil agrees that the non-indicating type fuses are not seismically sensitive this is not a real problem other than the difficulty in procuring the FPE fuses for IE applications. From a procurement perspective it is to TVA's advantage to use Busstrom or Gould-Shawmut fuses to replace the FPE's.

THIS SHEET ADDED BY REV. 4.

Pin Indicating, Ferrule Fuses and Devices

Arranged by physical size, and grouped by non-time-delay and delay (dual-element) types

13/32" x 2" (10.3mm x 50.8mm)



For mounting in signal blocks 2778, 2788-2 thru -5, 2838, and 2837 (page 50) for signal activation.

- **Non-Time-Delay Device** to call attention to the opening of a paralleled 50 ampere or larger fuse.
- Opens at 10 amperes or more.
- Interrupting Rating of 200,000A.
- Only to be used in parallel with a fuse—KAZ is an actuating device, not a fuse.

Device Symbol	Current Rating (Amperes)	Voltage Rating (Volts or Less)
*KAZ	—	600ac

*UL listed as "Fuse Accessory."

Request Form KAFS for more information.

For mounting in signal block mounts in all KAZ blocks (page 34) for signal activation.

- **Non-Time-Delay Fuse**
- Interrupting Rating of 200,000A.
- MIS is an indicating fuse—can be used as fuse or in parallel with larger fuses to indicate open fuse.


Fuse Symbol	Current Rating (Amperes)	Voltage Rating (Volts or Less)
MIS 1	1	600ac, 250dc
MIS 2	2	600ac, 250dc
MIS 3	3	600ac, 250dc
MIS 4	4	600ac, 250dc
MIS 5	5	600ac, 250dc
MIS 6	6	600ac, 250dc
MIS 8	8	600ac, 250dc
MIS 10	10	600ac, 250dc
MIS 12	12	600ac, 250dc

Test Specifications:	
Load	Opening Time
100%	Indefinitely
MIS 1 to MIS 5	
150%	6 Minutes, Max.
MIS 6 to MIS 12	
150%	12 Minutes, Max.

Special Fuses and Devices

Arranged by similar body and terminal configurations

Low Voltage Limiters



For mounting in block 4164 (page 50).

- ANL is **Non-Time-Delay** limiter to isolate faults in equipment systems such as lift trucks or batteries.
- Visual indication of link element.

Time Current Curve on pages 53 to 57.

Note: Silver-plated copper link
 Mica window
 Slot width: 1/16"
 Distance between slot centers: .214"

Fuse Symbol	Current Rating (Amperes)	Voltage Rating (Volts or Less)
ANL	35	32
ANL	40	32
ANL	50	32
ANL	80	32
ANL	100	32
ANL	130	32
ANL	150	32
ANL	175	32
ANL	200	32

Fuse Symbol	Current Rating (Amperes)	Voltage Rating (Volts or Less)
ANL	225	32
ANL	250	32
ANL	275	32
ANL	325	32
ANL	350	32
ANL	400	32
ANL	500	32