

December 18, 2007

U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

ATTENTION: Document Control Desk

Subject: Duke Power Company LLC d/b/a
Duke Energy Carolinas, LLC (Duke)
McGuire Nuclear Station, Unit 2
Docket Nos. 50-370

Withdrawal of License Amendment Request (LAR) for
Technical Specification 3.7.5, Auxiliary Feedwater System

Reference: Duke letter to NRC dated November 7, 2007

As proposed in the referenced letter above, Duke requested an amendment to the McGuire Nuclear Station (McGuire) Technical Specifications (TS) for a one time limited duration extension of the Required Action Completion Time to TS 3.7.5, Auxiliary Feedwater System (AFW). The proposed TS change was to allow the Unit 2 AFW "A" train to be declared inoperable for an additional 72 hours beyond the allowed 72 hours for piping modifications and testing of the Nuclear Service Water System (NSW).

As a result of changes to the piping modification implementation schedule, McGuire no longer requires the proposed one time limited duration TS extension and has decided to withdraw the referenced LAR.

If additional questions arise, contact Lee A. Hentz at 704-875-4187.

U.S. Nuclear Regulatory Commission
Page 2
December 18, 2007

Sincerely,

A handwritten signature in black ink, appearing to read "Gary R. Peterson". The signature is fluid and cursive, with a large, sweeping flourish at the end.

Gary R. Peterson

cc:

W. D. Travers
Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, GA 30303

J. F. Stang, Jr. (addressee only)
Project Manager
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Mail Stop O-8-G9A
Washington, D.C. 20555

J. B. Brady
NRC Senior Resident Inspector
McGuire Nuclear Station

B. O. Hall
Section Chief
Division of Radiation Section
1645 Mail Service Center
Raleigh, NC 27699