

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
400 Chestnut Street Tower II

November 3, 1980

79-033-03L ✓  
79-031-03N ✓

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - STEAM GENERATOR WATER LEVEL  
REFERENCE COLUMN ERROR - NCR MEB 79-33 - FIFTH INTERIM REPORT


The subject deficiency was initially reported to NRC-OIE Inspector M. Thomas on July 6, 1979, in accordance with 10 CFR 50.55(e). Interim reports were submitted on July 30, 1979, September 27, 1979, June 20, 1980, and August 22, 1980. We expect to provide additional information by January 15, 1981.

Technical and contractual evaluations are being made between TVA and Westinghouse for the installation of microprocessors to compensate the level transmitter outputs for water density changes. A test is to be run to determine the number of temperature sensors required for each microprocessor.

If you have any questions, please get in touch with D. L. Lambert at FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager  
Nuclear Regulation and Safety

cc: Mr. Victor Stello, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

B019  
s  
1/0

8011140067

An Equal Opportunity Employer

OFFICIAL COPY