



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JAN 11 1980

Docket Nos: 50-311, 50-339, 50-275,  
50-327, 50-369, 50-364,  
50-395, 50-361, 50-390

APPLICANTS: Public Service Electric & Gas Company  
Virginia Electric & Power Company  
Pacific Gas & Electric Company  
Tennessee Valley Authority  
Duke Power Company  
Alabama Power Company  
Southern California Edison & San Diego Gas & Electric Company  
South Carolina Electric & Gas Company

FACILITIES: Salem 2, North Anna 2, Diablo Canyon 1, Sequoyah 1, McGuire 1,  
Farley 2, Summer 1, San Onofre 2, Watts Bar 1

SUBJECT: SUMMARY OF DECEMBER 13, 1979 MEETING TO DISCUSS WITH PWR APPLICANTS  
REVISION 2 TO REGULATORY GUIDE 1.97, "INSTRUMENTATION FOR LIGHT-  
WATER-COOLED NUCLEAR POWER PLANTS TO ASSESS PLANT AND ENVIRONS  
CONDITIONS DURING AND FOLLOWING AN ACCIDENT"

Mr. Benaroya summarized the development of Regulatory Guide 1.97 from 1973 to the present Revision 2, which was issued for comment in December 1979.\* The Three Mile Island accident demonstrated the need for additional qualified instruments and instruments having a much wider range (e.g., radiation monitors and core exit thermocouples) in order to effectively assess plant conditions and the actual and potential offsite release of radioactive effluents during accidents. In response to this need, the nuclear industry is developing ANS Standard 4.5 "Functional Requirements for Accident Monitoring in a Nuclear Power Generating Station." Draft 4 of ANS 4.5 was issued in November 1979.\*\* The scope of ANS 4.5 is limited to information needed by the control room operator to bring the plant to a planned stable condition. Revision 2 to Regulatory Guide 1.97 endorses most of ANS 4.5 and extends the scope to include information needed to initiate unplanned action should the plant not respond as expected and to initiate action to protect the public. Regulatory Guide 1.97 also extends the scope of ANS 4.5 to include specific guidance for the range and design criteria of instruments to measure specific variables during an accident. The specification of design criteria in Regulatory Guide 1.97

\*Available from the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director of Technical Information and Document Control.

\*\*Copies may be obtained from the American Nuclear Society, 555 North Kensington Avenue, LaGrange Park, Illinois 60525.

A  
8001280 242  
1/11/80  
MEMO

JAN 11 1980

is required to assure that qualified instruments will be installed and operational in all reactors by December 1981, as indicated in the Staff's Draft Action Plan (Memo Denton to Commissioners, December 11, 1979, Task II.F).

The December 13, 1979 meeting was the first of several meetings with applicants and licensees to answer questions regarding the design criteria for these instruments and to obtain advance comments for the final issue of Revision 2 to Regulatory Guide 1.97. This meeting was held with those applicants that expect to have PWR plants ready for operation in 1980. A list of attendees at the December 13, 1979 meeting is enclosed.

On December 14, 1979, a similar meeting was held with operating license applicants that expect to have BWR plants ready for operation in 1980. In January, similar meetings will be held with licensees of operating reactors and their representatives. The results of these meetings will be considered in determining the portion of the requirements in the guide that will be implemented for near term operating license plants and for operating reactors. The full scope of instruments listed in the active guide will be required for new plants that are docketed after April 15, 1980.

Although guidance was provided by the staff in this meeting, final positions will only be developed after all written comments are received. Among other changes, positions in Regulatory Guide 1.97 will be made consistent with those positions that will be approved for other post-Three Mile Island matters.

Mr. John Davis (Virginia Electric & Power Company) summarized major comments by utility representatives attending the meeting. (1) Revision 2 to Regulatory Guide 1.97 gives detailed design requirements for specific instruments rather than general requirements to provide increased in-plant safety and the utilities believe this is inappropriate. (2) The requirements in Regulatory Guide 1.97 appear to conflict in many places with draft requirements for control room design studies; utilities believe that integrated design requirements should be developed on a priority basis so that clutter and misinformation to the operator will not result from the redesign of control rooms for near term operating license plants and operating reactors. (3) The criteria of the guide appear to be inflexible, and may cause undesirable reduced accuracy of measurements for normal operating functions. (4) The 200 day long term cooling qualification time interval eliminates the validity of presently purchased equipment that was qualified to 100 day time interval. (5) Many of the specified design instrument ranges are beyond the state-of-the-art.

Applicants requested that the reasons for selecting certain variables, the range of the measurement, the design criteria and the purpose be provided to them so they can better meet the intent of the staff's requirements. In response, the staff said that the reasons for selecting specific measurements were generally stated in the discussion and tables of the guide. There is an

JAN 11 1980

engineering basis for the range specified for each instrument. However, since it would be a monumental task to provide written detailed bases, further discussion and response to questions on specific applications may be obtained by telephoning V. Benaroya (301) 492-8057. The guide uses general terms to envelope the range of designs used by different reactor manufacturers and architect engineers. In the interpretation of the requirements, applicants should use a reasonable interpretation, based on their knowledge of accidents and engineering judgement.

The staff recognizes that most of the instruments listed are already designed and installed in nearly completed and operating plants, and that they may not meet all the design criteria specified in Table 1 of the guide. For these instruments, it may be possible to show that the instrument will perform satisfactorily during accidents by analysis or by tests of environmentally sensitive components of the measurement system. For example, the guide requires that instrumentation be qualified to function for 200 days following an accident if it will be inaccessible for replacement or repair. Currently purchased instruments have been tested in accident environments for 120 days. It may be possible to demonstrate their acceptability for a shorter period than 200 days by analysis, additional tests of sensitive components, or even by cost effectiveness.

Table 1 of the guide requires "continuous recording" for Type A, B and C instruments, including valve positions. It is not intended that such information, that does not vary with time, be placed on chart recorders; a typeout from the computer may be acceptable.

The specific instruments listed in Tables 2 & 3 have been grouped within five categories, according to the function to be performed during an accident. (Types A, B, C, D or E). The criteria for these categories are listed and defined in Table 1. Many of these instruments perform other functions during normal operation and so are designed to other criteria. Obviously, all applicable criteria need to be met for these instruments. Sometimes a separate instrument needs to be provided. For example, it may be necessary to use an additional instrument to measure natural circulation flow of reactor coolant in the forward and reverse direction.

Revision 2 of Regulatory Guide 1.97 issued for comment in December 1979 does not address instrument display location. Location of accident monitoring instrument displays in the control room will be considered by the staff when it reviews control room design, that is a part of the staff's draft Action Plan. Section C. 1 of Task 1.D.1 requires a review by each licensee of control room design, taking into consideration lessons learned from the Three Mile Island accident. Some instruments may use local indication (e.g., emergency ventilation damper position) and others by appropriately displayed in the emergency center (e.g., environs radioactivity exposure rate); however, local indication and displays located outside the control room should be installed where they can be read in a timely manner under accident conditions without exceeding acceptable limits for radiation exposure provided in staff's Short Term Lessons Learned requirements.\*

\*November 9, 1979 letter from D. B. Vassallo to all pending operating license applicants enclosing "Discussion of TMI Lessons Learned Short Term Requirements; pages 19, 20, 21.

JAN 11 1980

The applicants provided comments and questions on the specific instrument criteria listed in Table 2 of Regulatory Guide 1.97. Significant comments and clarification by the staff follow:

1. Core Exit Temperature - Applicants stated that "continuous recording" recording by Types B and C is interpreted by instrument engineers to mean a continuous chart recording for each of the 50 thermocouples. They suggested that a computer display or typeout should be adequate. Staff indicated that a flow, multipoint recorder with a computer display may be adequate. It is not necessary to meet single failure criteria for each thermocouple - 50 thermocouples provide ample redundancy. Thermocouples currently installed in some PWR's may be satisfactory; however, the recorder should cover the range of 150°F to 2300°F.
2. Control Rod Position - Applicants said that control rod position indicators may not survive for 5 days; further there appeared to be no need for them beyond 5 seconds - when rods are inserted. Applicants believed five minutes a suitable environmental qualification period. Staff said the purpose was to provide an indication for an operator to try to insert the rods by some action in the event some of the rods fail to insert for an automatic trip, as has some times occurred.
3. Neutron Flux - Several applicants propose to use 2 compensated in chambers instead of the fission counter listed in the guide.
4. Reactor Coglant System Hot/Cold Leg Temperature - The upper limit of the range (750°F) was selected to include the critical temperature (705.4°F); therefore, a temperature between 705.4°F to 750°F may be justifiable. Since the RCS contains redundant loops, one instrument on each loop may be acceptable (redundancy on each loop not needed).
5. Reactor Coolant System Pressure - The upper limit of pressure range (4000 psig) was selected to include the peak transient pressure calculated for anticipated transients without scram (ATWS) using staff assumptions. Applicants said there is only one manufacturer for qualified instruments to measure pressure greater than 3000 psig; and that deliveries of these instruments would be after 12/81.
6. Degree of Subcooling - The 35°F superheat requirement was based on the TMI-2 experience. Actually a wider range would be better.
7. Reactor Coolant Loop Flow - Instruments are not expected to measure flow with fine accuracy in the low flow range (-12% to +12%). A rough accuracy may be acceptable. The intent is to know when there is forward or reverse flow under natural circulation or accident conditions. The applicants indicate that natural circulation flow rates will not be measurable with these instruments.
8. Radiation Level in Primary Coolant Water - Staff said that instruments to measure radiation in the range of 10  $\mu$ Ci/cc to 10 Ci/cc are within the state-of-the-art; however, they may not be widely available. The purpose is to measure gross activity - extreme accuracy is not intended to be required. The type of failed fuel monitors on the let down lines of Westinghouse reactors may be satisfactory if located on a line that

JAN 11 1980

9. Containment Hydrogen Concentration - The upper limit of the range was selected to provide margin above the explosive range (4% - 8%). A wider range is feasible with a decreased accuracy.
10. Containment Isolation Valve Position - One position indicator per valve meets the intent of the single failure requirement if there is a second isolation valve in the containment penetration or a backup means for isolation.
11. High Range Containment Area Radiation Monitor - Staff said that radiation monitors having a range of 1 to  $10^7$  R/hr are within the state-of-the-art; two manufacturers offer such instruments and, as an example, Wyle Laboratories is capable of qualifying them in an accident environment.
12. Steam Generator Pressure - A range to 10% above safety valve setting may be acceptable.
13. Steam Generator Level - The wide range level instruments currently used on steam generators may be satisfactory: The intent of the specified range ("from tube sheet to separators") is to assure that level can be measured over the full height of the tube bundle; e.g., a bottom water level tap one foot above the tube sheet is satisfactory.
14. Radioactivity in Effluent from Steam Generator Safety Relief Valves or Atmospheric Dump Valves - The location of monitors should permit measurement of efflux activity; readout should be in control room.
15. Condensate Storage Tank Level - This instrument was designated Type B because it is the primary measurement of quantity of water available as auxiliary feedwater.
16. Flow in Ultimate Heat Sink Loop - Staff indicated that this measurement was intended for small man-made water reservoirs (cooling tower basin or cooling pond) where makeup water supply is required after 30 days.
17. Sump Level in Spaces of Equipment Required for Safety - If the sump is subject to overflow (due to abnormal relief valve flow, pump seal failure, or pipe failure) the water level in the room should be measured.
18. Temperature of Space in Vicinity of Equipment Required for Safety - The intent is to measure temperature in spaces where heat sources exist and make possible to exceed design temperature (e.g., by failure of a heating, ventilating and air conditioning system, or a high energy line break). The range for BWR's (Table 3) has a typographical error - the range should be the same as for PWR's (Table 2) i.e., 30° F to 180° F. Also the design criteria for BWR's should be the same as for PWR's, i.e., Type D.
19. Post Accident Sampling Capability - Provide separate guidance for sumps inside the reactor building and the auxiliary building.

JAN 11 1980

The staff recommended that plant specific comments on Tables 1 and 2 of Regulatory Guide 1.97 be provided on the docket by each applicant and that generic comments on Regulatory Guide 1.97 applicable to several plants be provided to V. Benaroya by a representative of the utilities.

Plant specific comments should describe instruments proposed in that plant that are different from those required by Revision 2 to Regulatory Guide 1.97, issued for comment in December 1979. Alternate designs or design requirements should be justified on the basis of capability to meet the intent of the guide or excessive cost for the potential benefit derived. In the latter case only realistic cost estimates will be considered. Plant specific comments on backfitting should be provided by January 15, 1980 to be considered for incorporation into the effective guide to be issued in May 1980.

Generic comments, which are expected to be fewer in number, will be considered for incorporation into the effective guide if they are received within the 60-day comment period ending in February 1980.



L. L. Kintner, Project Manager  
Light Water Reactors Branch No. 1  
Division of Project Management

Enclosure:  
As Stated

cc:  
See following pages

ENCLOSURE

ATTENDEES

REGULATORY GUIDE 1.97 MEETING

DECEMBER 13, 1979

Bechtel Power Corporation

Wm. G. Gordon  
H. G. Huff

Southern California Edison

C. G. Moore  
R. L. Phelps

Westinghouse

T. F. Timmons

Southern Company Services

P. A. Hermann  
T. M. Milton  
D. M. Crowe  
Kenneth W. Kopecky

Pacific Gas & Electric Co.

T. N. Crawford

Duke Power

T. C. McMeekin  
W. A. Coley  
R. F. Johnston

Public Service Electric & Gas

R. W. Skwarek  
R. L. Gura  
J. P. Gagliardi

TVA

C. S. Walker  
L. T. Perry  
Wang Lau  
Mork Burzynski  
Mark Wisenburg

VEPCO

G. L. Pannell  
J. M. Davis

WPS

M. E. Stern

South Carolina Electric  
and Gas

Ronald Clary  
Stephen M. Cunningham  
Carl A. Price

NBC

L. Soffer  
V. Benaroya  
P. Stoddart  
J. F. Stolz  
L. L. Kintner  
A. Dromerick  
A. S. Hintze  
John Buchanan  
D. Tibbitts  
Shou-Nien Hou

Gilbert Associates Inc.

Gerald J. Braddick

DOE

Paul Havenstein

JAN 11 1980

Mr. R. L. Mittl, General Manager  
Licensing and Environment  
Engineering and Construction Department  
Public Service Electric and Gas Company  
80 Park Place  
Newark, New Jersey 07101

cc: Richard Fryling, Jr., Esq.  
Assistant General Counsel  
Public Service Electric & Gas Company  
80 Park Place  
Newark, New Jersey 07100

Mark Wetterhahn, Esq.  
Conner, Moore & Cober  
1747 Pennsylvania Avenue, N.W.  
Suite 1050  
Washington, D.C. 20006

Mr. Leif J. Norrholm  
U. S. Nuclear Regulatory Commission  
Region I  
Drawer I  
Hancocks Bridge, New Jersey 08038



JAN 11 1980

Mr. W. L. Proffitt  
Senior Vice President - Power  
Operations  
Virginia Electric & Power Company  
P. O. Box 26666  
Richmond, Virginia 23261

cc: Mr. Anthony Gambaradella  
Office of the Attorney General  
11 South 12th Street - Room 308  
Richmond, Virginia 23219

Richard M. Foster, Esq.  
Musick, Williamson, Schwartz  
Leavenworth & Cope, P. C.  
P. O. Box 4579  
Boulder, Colorado 80306

Michael W. Maupin, Esq.  
Hunton, Williams, Gay & Gibson  
P. O. Box 1535  
Richmond, Virginia 23212

Mrs. June Allen  
412 Owens Drive  
Huntsville, Alabama 35801

Mrs. James Torson  
501 Leroy  
Socorro, New Mexico 87801

Mrs. Margaret Dietrich  
Route 2, Box 568  
Gordonsville, Virginia 22942

William H. Rodgers, Jr., Esq.  
Georgetown University Law Center  
600 New Jersey Avenue, N. W.  
Washington, D. C. 20001

Mr. Peter S. Hepp  
Executive Vice President  
Sun Shipping & Dry Dock Company  
P. O. Box 540  
Chester, Pennsylvania 19013

Mr. R. B. Briggs  
Associate Director  
110 Evans Lane  
Oak Ridge, Tennessee 37830

Clarence T. Kipps, Jr., Esq.  
1700 Pennsylvania Avenue, N.W.  
Washington, D. C. 20006

Carroll J. Savage, Esq.  
1700 Pennsylvania Avenue, N.W.  
Washington, D. C. 20006

Mr. James C. Dunstan  
State Corporation Commission  
Commonwealth of Virginia  
Blandon Building  
Richmond, Virginia 23209

Alan S. Rosenthal, Esq.  
Atomic Safety and Licensing Appeal Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Michael C. Farrar, Esq.  
Atomic Safety and Licensing Appeal Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. John H. Buck  
Atomic Safety and Licensing Appeal Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Atomic Safety and Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Michael S. Kidd  
U.S. Nuclear Regulatory Commission  
P. O. Box 128  
Spotsylvania, Virginia 22553

Dr. Paul W. Purdom  
Department of Civil Engineering  
Drexel University  
Philadelphia, Pennsylvania 19104

JAN 11 1980

Mr. W. L. Proffitt

cc: Dr. Lawrence R. Quarles  
Apartment No. 51  
Kendal-at-Longwood  
Kennett Square, Pennsylvania 19348

Mr. Irwin B. Kroot  
Citizens Energy Forum  
P. O. Box 138  
McLean, Virginia 22101

James B. Dougherty, Esq.  
Potomac Alliance  
1416 S Street, N.W.  
Washington, D. C. 20009

Mr. John C. Morrissey

JAN 11 1960

Mr. John C. Morrissey  
Vice President & General Counsel  
Pacific Gas & Electric Company  
77 Beale Street  
San Francisco, California 94106

cc: Philip A. Crane, Jr., Esq.  
Pacific Gas & Electric Company  
77 Beale Street  
San Francisco, California 94106

Janice E. Kerr, Esq.  
California Public Utilities Commission  
350 McAllister Street  
San Francisco, California 94102

Mr. Frederick Eissler, President  
Scenic Shoreline Preservation  
Conference, Inc.  
4623 More Mesa Drive  
Santa Barbara, California 93105

Ms. Elizabeth E. Apfelberg  
1415 Cazadero  
San Luis Obispo, California 93401

Ms. Sandra A. Silver  
1760 Alisal Street  
San Luis Obispo, California 93401

Mr. Gordon A. Silver  
1760 Alisal Street  
San Luis Obispo, California 93401

Paul C. Valentine, Esq.  
321 Lytton Avenue  
Palo Alto, California 94302

Yale I. Jones, Esq.  
19th Floor  
100 Van Ness Avenue  
San Francisco, California 94102

Mr. Richard Hubbard  
MHB Technical Associates  
1723 Hamilton Avenue  
Suite K  
San Jose, California 95125

Mr. John Marrs  
Managing Editor  
San Luis Obispo County  
Telegram - Tribune  
1321 Johnson Avenue  
P. O. Box 112  
San Luis Obispo, California 93406

Elizabeth S. Bowers, Esq., Chairman  
Atomic Safety & Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Glenn O. Bright  
Atomic Safety & Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Tolbert Young  
P. O. Box 219  
Avila Beach, California 93424

Richard S. Salzman, Esq., Chairman  
Atomic Safety & Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. W. Reed Johnson  
Atomic Safety & Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Alan S. Rosenthal, Esq.  
Atomic Safety & Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Ms. Raye Fleming  
1920 Mattie Road  
Shell Beach, California 93440

Brent Rushforth, Esq.  
Center for Law in the Public Interest  
10203 Santa Monica Boulevard  
Los Angeles, California 90067

Arthur C. Gehr, Esq.  
Snell & Wilmer  
3100 Valley Center  
Phoenix, Arizona 85073

JAN 11 1980

Mr. John C. Morrissey

Mr. James O. Schuyler, Nuclear  
Projects Engineer  
Pacific Gas & Electric Company  
77 Beale Street  
San Francisco, California 94106

Bruce Norton, Esq.  
3216 North 3rd Street  
Suite 202  
Phoenix, Arizona 85012

Mr. W. C. Gangloff  
Westinghouse Electric Corporation  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Michael R. Klein, Esq.  
Wilmer, Cutler & Pickering  
1666 K Street, N. W.  
Washington, D. C. 20006

David F. Fleischaker, Esq.  
Suite 709  
1735 Eye Street, N. W.  
Washington, D. C. 20006

Dr. William E. Martin  
Senior Ecologist  
Battelle Memorial Institute  
Columbus, Ohio 43201

W. Andrew Baldwin, Esq.  
124 Spear Street  
San Francisco, California 94105

Tennessee Valley Authority

JAN 11 1960

CCS:  
Herbert S. Sanger, Jr. Esq.  
General Counsel  
Tennessee Valley Authority  
400 Commerce Avenue  
E 11B 33  
Knoxville, Tennessee 37902

Mr. H. G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street Tower II  
Chattanooga, Tennessee 37401

Mr. E. G. Beasley  
Tennessee Valley Authority  
W10C131 C  
400 Commerce Avenue  
Knoxville, Tennessee 37902

Mr. Michael Harding  
Westinghouse Electric Corporation  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Mr. David Lambert  
Tennessee Valley Authority  
400 Chestnut Street Tower II  
Chattanooga, Tennessee 37401

JAN 11 1980

Mr. E. H. Crews, Jr., Vice President  
and Group Executive - Engineering  
and Construction  
South Carolina Electric & Gas Company  
P. O. Box 764  
Columbia, South Carolina 29218

cc: Mr. H. T. Babb  
General Manager - Nuclear Operations  
and System Planning  
South Carolina Electric & Gas Company  
P. O. Box 764  
Columbia, South Carolina 29218

G. H. Fischer, Esq.  
Vice President & Group Executive  
South Carolina Electric & Gas Company  
P. O. Box 764  
Columbia, South Carolina 29218

Mr. William C. Mescher  
President & Chief Executive Officer  
South Carolina Public Service Authority  
223 North Live Oak Drive  
Moncks Corner, South Carolina 29461

Mr. William A. Williams, Jr.  
Vice President  
South Carolina Public Service Authority  
223 North Live Oak Drive  
Moncks Corner, South Carolina 29461

Wallace S. Murphy, Esq.  
General Counsel  
South Carolina Public Service Authority  
223 North Live Oak Drive  
Moncks Corner, South Carolina 29461

Troy B. Conner, Jr., Esq.  
Conner, Moore & Corber  
1747 Pennsylvania Avenue, N. W.  
Washington, D. C. 20006

Mr. Mark B. Whitaker, Jr.  
Manager, Nuclear Licensing  
South Carolina Electric & Gas Company  
P. O. Box 764  
Columbia, South Carolina 29218

Mr. O. W. Dixon  
Group Manager, Production Engineering  
South Carolina Electric & Gas Company  
P. O. Box 764  
Columbia, South Carolina 29218

Mr. William O. Parker, Jr.

JAN 11 1980

cc: Anthony Z. Roisman, Esq.  
Natural Resources Defense Council  
917 - 15th Street, N. W.  
Washington, D. C. 20555

Richard P. Wilson, Esq.  
Assistant Attorney General  
State of South Carolina  
2600 Bull Street  
Columbia, South Carolina 29201

Mr. Alan R. Barton

JAN 11 1980

Mr. Alan R. Barton  
Senior Vice President  
Alabama Power Company  
600 North 18th Street  
Birmingham, Alabama 35291

cc: George F. Trowbridge, Esq.  
Shaw, Pittman, Potts & Trowbridge  
1800 M. Street, N.W.  
Washington, D. C. 20036

Mr. Ruble A. Thomas, Vice President  
Southern Company Service  
P. O. Box 2625  
Birmingham, Alabama 35202



JAN 11 1980

Mr. James H. Drake  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Mr. B. W. Gilman  
Senior Vice President - Operations  
San Diego Gas and Electric Company  
101 Ash Street  
P. O. Box 1831  
San Diego, California 92112

cc: Charles R. Kocher, Esq.  
James A. Beoletto, Esq.  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Chickering and Gregory  
ATTN: David R. Pigott, Esq.  
Counsel for San Diego Gas  
& Electric Company and  
Southern California  
Edison Company  
Three Embarcadero Center, 23rd Floor  
San Francisco, California 94112

Mr. Kenneth E. Carr  
City Manager  
City of San Clemente  
100 Avenida Presidio  
San Clemente, California 92672

Alan R. Watts, Esq.  
Rourke & Woodruff  
1055 North Main Street  
Suite 1020  
Santa Ana, California 92701

Lawrence Q. Garcia, Esq.  
California Public Utilities Commission  
5066 State Building  
San Francisco, California 94102

JAN 11 1980

Mr. E. H. Crews, Jr.                    - -

cc: Mr. Brett Allen Bursey  
Route 1 Box 93C  
Little Mountain, South Carolina 29076

Resident Inspector/Summer Power Station  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box 1047  
Irmo, South Carolina 29063

JAN 11 1980

Mr. James H. Drake  
Mr. B. W. Gilman

cc: Mr. R. W. DeVane, Jr.  
Combustion Engineering, Inc.  
1000 Prospect Hill Road  
Windsor, Connecticut 06095

Mr. P. Dragolovich  
Bechtel Power Corporation  
P. O. Box 60860, Terminal Annex  
Los Angeles, California 90060

Mr. Mark Medford  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Henry Peters  
San Diego Gas & Electric Company  
Post Office Box 1831  
San Diego, California 92112

Ms. Lyn Harris Hicks  
Advocate for GUARD  
3908 Calle Ariana  
San Clemente, California 92672

Richard J. Wharton, Esq.  
Wharton and Pogalies  
2667 Camino Del Rio South  
Suite 106  
San Diego, California 92108

Phyllis M. Gallagher, Esq.  
1695 West Crescent Avenue  
Suite 222  
Anaheim, California 92701

Mr. A. S. Carstens  
2071 Caminito Circulo Norte  
Mt. La Jolla, California 92037

Resident Inspector/San Onofre Nuclear Power Station  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box 3550  
San Onofre, California 92672

JAN 11 1980

cc: Mr. P. Higgins  
Atomic Industrial Forum  
12th Floor  
7101 Wisconsin Avenue  
Bethesda, Maryland 20014

Mr. R. H. Leyse  
NSAC - Washington Office  
Electric Power Research Institute  
1800 Massachusetts Avenue, N. W.  
Washington, D. C. 20036