

PPL SUSQUEHANNA, LLC

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-387

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 246
License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for the amendment filed by PPL Susquehanna, LLC, dated October 11, 2006, as supplemented on as supplemented by letters dated October 25, December 4 and 26, 2006, February 13, March 14 and 22, April 13, 17, 23, 26, and 27, May 3, 9, 14, and 21, June 1, 4, 8, 14, 20, and 27, July 6, 12, 13, 30, and 31, August 3, 13, 15, and 28, September 19, October 5, November 30, December 10, 2007, and January 9, 24, and 29, 2008, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of the Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 246 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PPL Susquehanna, LLC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

In addition, the license is amended to revise paragraph 2.C.(1) of Facility Operating License No. NPF-14 to reflect the new maximum licensed reactor core power level of 3952 megawatts thermal. The licensee is also amended to add new license conditions 2.C.(36), (37), (38), and (39) as follows:

(36) Potential Adverse Flow Effects

These license conditions provide for monitoring, evaluating, and taking prompt action in response to potential adverse flow effects as a result of power uprate operation on plant structures, systems, and components (including verifying the continued structural integrity of the steam dryer).

- (a) The following requirements are placed on operation of the PPL Susquehanna, LLC (PPL) facility above the licensed thermal power (CLTP) level of 3489 megawatts thermal (MWt):
1. PPL shall obtain at each 3.5% power ascension step up to 107% of 3489 MWt, dryer strain gauge data and compare it to the acceptance criteria during power ascension above 3489 MWt. PPL shall obtain at each 3.5% power ascension step above 107% of 3489 MWt, main steam line strain gauge data and compare it to the limit curve for the dryer strains during power ascension.
 2. PPL shall monitor the main steam line (MSL) strain gauges during power ascension testing above 3489 MWt for increasing pressure fluctuations in the steam lines.
 3. PPL shall hold the facility at each 3.5% ascension step to collect data from License Condition 2.C.(36)(a) and conduct plant inspections and walk-downs, and evaluate steam dryer performance based on the data; shall provide the evaluation to the NRC staff by facsimile or electronic transmission to the NRC project manager upon completion of the evaluation; and shall not increase power above each hold point until 96 hours after the NRC project manager confirms receipt of the transmission.

4. If any acceptance criteria for steam dryer strains at each 3.5% power ascension step up to 107% of 3489 MWt or frequency peak from the MSL strain gauge data exceeds the limit curve for the MSL strains above 107% of 3489 MWt, PPL shall return the facility to a power level at which the acceptance criteria is not exceeded. PPL shall resolve the discrepancy, document the continued structural integrity of the steam dryer, and provide that documentation to the NRC staff by facsimile or electronic transmission to the NRC project manager prior to further increases in reactor power.
 5. In addition to evaluating the dryer instrumentation data and MSL strain gauge data, PPL shall monitor reactor pressure vessel water level instrumentation and MSL piping accelerometers during power ascension above 3489 MWt. If resonance frequencies are identified as increasing above nominal levels in proportion to instrumentation data, PPL shall stop power ascension, document the continued structural integrity of the steam dryer, and provide that documentation to the NRC staff by facsimile or electronic transmission to the NRC project manager prior to further increases in reactor power.
 6. Following CPPU start-up testing, PPL shall resolve any discrepancies in the steam dryer analysis and provide that resolution to the NRC staff by facsimile or electronic transmission to the NRC project manager. If the discrepancies are not resolved within 90 days of identification, PPL shall return the facility to a power level at which the discrepancy does not exist.
- (b) PPL shall implement the following actions:
1. PPL shall provide to NRC the as-built dryer stress reconciliation and load limit curves 45 days prior to operation above 3489 MWt.
 2. After the dryer stress analysis is benchmarked to the Unit 1 startup test data (Unit 1 data taken up to 107 % of 3489 MWt), the benchmark results and updated MSL limit curves shall be provided to the NRC 90 days prior to operation above 107% of 3489 MWt.
 3. In the event that acoustic signals are identified that challenge the limit curve during power ascension above 107%, PPL shall evaluate dryer loads and re-establish the acceptance criteria based on the new data, and shall perform an assessment of ACM uncertainty at the acoustic signal frequency
 4. After reaching 107% of CLTP , PPL shall obtain measurements from the steam dryer instrumentation and establish the steam dryer flow-induced vibration load fatigue margin for the facility, update the dryer stress report, and re-establish the limit curve with the updated ACM load definition and revised instrument uncertainty, which will be provided to the NRC staff.

5. During power ascension above 107 % CLTP, if an engineering evaluation for the steam dryer is required because a Level 1 acceptance criteria is exceeded, PPL shall perform the structural analysis to address frequency uncertainties up to ± 10 % and assure that peak responses that fall within this uncertainty band are addressed.
 6. PPL shall revise the Post Constant Pressure Power Uprate (CPPU) Monitoring & Inspection Program to reflect long-term monitoring of plant parameters potentially indicative of steam dryer failure; to reflect consistency of the facility's steam dryer inspection program with General Electric Service Information Letter (SIL) 644, "BWR/3 Steam Dryer Failure," Revision 2; and to identify the NRC Project Manager for the facility as the point of contact for providing Power Ascension Test Plan (PATP) information during power ascension.
 7. PPL shall submit CPPU steam dryer reports to the NRC. Two written reports will be provided to the NRC. These reports will be issued following completion of testing of Unit 1 power ascension to 107% CLTP and 114% CLTP. Each report will include evaluations or corrective actions that were required to assure steam dryer structural integrity. Additionally, they will include relevant data collected at each power step, comparisons to performance criteria (design predictions), and evaluations performed in conjunction with steam dryer structural integrity monitoring.
 8. PPL shall submit the flow-induced vibration related portions of the CPPU startup test procedure to the NRC, including methodology for updating the limit curve, prior to initial power ascension above 3489 MWt.
- (c) PPL shall prepare the CPPU startup test procedure to include the:
1. steam dryer strain gauge acceptance criteria to be used up to 107% of CLTP and the main steam line strain gauge limit curves to be applied for evaluating steam dryer performance above 107% CLTP;
 2. specific hold points and their duration during CPPU power ascension;
 3. activities to be accomplished during hold points;
 4. plant parameters to be monitored;
 5. inspections and walk-downs to be conducted for steam, feedwater, and condensate systems and components during the hold points;
 6. methods to be used to trend plant parameters;
 7. acceptance criteria for monitoring and trending plant parameters, and conducting the walk-downs and inspections;
 8. actions to be taken if acceptance criteria are not satisfied; and

9. verification of the completion of commitments and planned actions specified in its application and all supplements to the application in support of the CPPU license amendment request pertaining to the steam dryer prior to power increase above 3489 MWt. PPL shall provide the related CPPU startup test procedure sections to the NRC by facsimile or electronic transmission to the NRC project manager prior to increasing power above 3489 MWt.
- (d) The following key attributes of the PATP shall not be made less restrictive without prior NRC approval:
1. During initial power ascension testing above 3489 MWt, each test plateau increment shall be approximately 3.5% of 3489 MWt;
 2. Level 1 performance criteria; and
 3. The methodology for establishing the stress criteria used for the Level 1 and Level 2 performance criteria.

Changes to other aspects of the PATP may be made in accordance with the guidance of Nuclear Energy Institute (NEI) 99-04, "Guidelines for Managing NRC Commitments," issued July 1999.

- (e) During each scheduled refueling outage until at least two full operating cycles at full CPPU conditions have been achieved, a visual inspection shall be conducted of all accessible, susceptible locations of the steam dryer in accordance with BWRVIP-139 and General Electric inspection guidelines.
- (f) The results of the visual inspections of the steam dryer shall be reported to the NRC staff within 60 days following startup. The results of the PATP shall be submitted to the NRC staff in a report within 60 days following the completion of all CPPU power ascension testing.
- (g) This license condition shall expire upon satisfaction of the requirements in License Conditions 2.C.(36)(e) and 2.C.(36)(f) provided that a visual inspection of the steam dryer does not reveal any new unacceptable flaw or unacceptable flaw growth that is due to fatigue.

(37) Transient Testing

- (a) PPL will demonstrate through performance of transient testing on each SSES unit that the loss of one condensate pump will not result in a complete loss of reactor feedwater. The test shall be performed on each unit during the unit's CPPU power ascension test program within 336 hours of achieving and prior to exceeding a nominal power level of 3733 MWt with feedwater and condensate flow rates stabilized. PPL shall confirm that the plant response to the transient is as expected in accordance with the acceptance criteria that are established. If a loss of all reactor feedwater occurs as a result of the test, the test failure shall be

addressed in accordance with corrective action program requirements and the provisions of the power ascension test program prior to continued operation of the SSES Unit above 3489 MWt.

- (b) Unless the NRC issues a letter notifying the licensee that the tests specified by License Condition 2.C.(37)(a) adequately demonstrate that a single condensate pump trip will not result in a loss of all feedwater while operating at the full CPPU power level of 3952 MWt, PPL shall perform the transient test on either SSES unit (whichever unit is first to achieve the following specified operating conditions) specified by License Condition 2.C.(37)(a) during the power ascension test program while operating at 3872 MWt to 3952 (98% to 100% of the full CPPU power level) with feedwater and condensate flow rates stabilized. The test shall be performed within 90 days of operating at greater than 3733 MWt and within 336 hours of achieving a nominal power level of 3872 MWt with feedwater and condensate flow rates stabilized. PPL will demonstrate through performance of transient testing on either Susquehanna Unit 1 or Unit 2 (whichever unit is first to achieve the specified conditions) that the loss of one condensate pump will not result in a complete loss of reactor feedwater. PPL shall confirm that the plant response to the transient is as expected in accordance with the acceptance criteria that are established. If a loss of all feedwater occurs as a result of the test, the test failure shall be addressed in accordance with corrective action program requirements and the provisions of the power ascension test program prior to continued operation of either SSES Unit above 3733 MWt.

(38) Neutronic Methods

- (a) An OPRM amplitude setpoint penalty will be applied to account for a reduction in thermal neutrons around the LPRM detectors caused by transients that increase voiding. This penalty will reduce the OPRM scram setpoint according to the methodology described in Response No. 3 of PPL letter, PLA-6306, dated November 30, 2007. This penalty will be applied until NRC evaluation determines that a penalty to account for this phenomenon is not warranted.
- (b) For SSES SLMCPR, a conservatively adjusted pin power distribution uncertainty and bundle power correlation coefficient will be applied as stated in Response No. 4 of PPL letter, PLA-6306, dated November 30, 2007, when performing the analyses in accordance with ANF-524(P)(A), "Critical Power Methodology for Boiling Water Reactors," using the uncertainty parameters associated with EMF-2158(P)(A) "Siemens Power Corporations Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2."

(39) Containment Operability for EPU

PPL shall ensure that the CPPU containment analysis is consistent with the SSES 1 and 2 operating and emergency procedures. Prior to operation above CLTP, PPL shall notify the NRC project manager that all appropriate actions have been completed.

3. This license amendment is effective as of its date of issuance and shall be implemented in accordance with License Conditions 2.C.(36), (37), (38), and (39) above.

FOR THE NUCLEAR REGULATORY COMMISSION

/ra/

J. E. Dyer, Director
Office of Nuclear Reactor Regulation

Attachment: Changes to the Operating License
and Technical Specifications

Date of Issuance: January 30, 2008

PPL SUSQUEHANNA, LLC
ALLEGHENY ELECTRIC COOPERATIVE, INC.
DOCKET NO. 50-388
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 224
License No. NPF-22

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for the amendment filed by PPL Susquehanna, LLC, dated October 11, 2006, as supplemented on as supplemented by letters dated October 25, December 4 and 26, 2006, February 13, March 14 and 22, April 13, 17, 23, 26, and 27, May 3, 9, 14, and 21, June 1, 4, 8, 14, 20, and 27, July 6, 12, 13, 30, and 31, August 3, 13, 15, and 28, September 19, October 5, November 30, December 10, 2007, and January 9, 24, and 29, 2008, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of the Facility Operating License No. NPF-22 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 224 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PPL Susquehanna, LLC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

In addition, the license is amended to revise paragraph 2.C.(1) of Facility Operating License No. NPF-22 to reflect the new maximum licensed reactor core power level of 3952 megawatts thermal. The licensee is also amended to add new license conditions 2.C.(20), (21), (22), and (23) as follows:

(20) Potential Adverse Flow Effects

These license conditions provide for monitoring, evaluating, and taking prompt action in response to potential adverse flow effects as a result of power uprate operation on plant structures, systems, and components (including verifying the continued structural integrity of the steam dryer).

- (a) The following requirements are placed on operation of the PPL Susquehanna, LLC (PPL) facility above the licensed thermal power (CLTP) level of 3489 megawatts thermal (MWt):

1. PPL shall obtain at each 3.5 % power ascension step, main steam line strain gauge data and compare it to the limit curve for the dryer strains during power ascension.
2. PPL shall monitor the main steam line (MSL) strain gauges during power ascension above 3489 MWt for increasing pressure fluctuations in the steam lines.
3. PPL shall hold the facility at each 3.5% ascension step to collect data from License Condition 2.C.(20)(a) and conduct plant inspections and walk-downs, and evaluate steam dryer performance based on the data; shall provide the evaluation to the NRC staff by facsimile or electronic transmission to the NRC project manager upon completion of the evaluation; and shall not increase power above each hold point until 96 hours after the NRC project manager confirms receipt of transmission.
4. If any frequency peak from the MSL strain gauge data exceeds the limit curve for dryer strains above 3489 MWt, PPL shall return the facility to a power level at which the acceptance criteria is not exceeded. PPL shall resolve the discrepancy, document the continued structural integrity of the steam dryer, and provide that documentation to the NRC staff by facsimile

or electronic transmission to the NRC project manager prior to further increases in reactor power.

5. In addition to evaluating the dryer strain and MSL strain gauge data, PPL shall monitor reactor pressure vessel water level instrumentation or MSL piping accelerometers during power ascension above 3489 MWt . If resonance frequencies are identified as increasing above nominal levels in proportion to instrumentation data, PPL shall stop power ascension, document the continued structural integrity of the steam dryer, and provide that documentation to the NRC staff by facsimile or electronic transmission to the NRC project manager prior to further increases in reactor power.
6. Following CPPU start-up testing, PPL shall resolve the discrepancies in the steam dryer analysis and provide that resolution to the NRC staff by facsimile or electronic transmission to the NRC project manager. If the discrepancies are not resolved within 90 days of identification, PPL shall return the facility to a power level at which the discrepancy does not exist.

(b) PPL shall implement the following actions:

1. PPL shall provide to NRC the as-built dryer stress analysis and load limit curves 45 days prior to operation above 3489 MWt.
2. After the dryer stress analysis is benchmarked to the Unit 1 startup test data (Unit 1 data taken up to 107 % of 3489 MWt), the benchmarked PATP and MSL limit curves shall be provided to the NRC 90 days prior to operation above 107% of 3489 MWt..
3. In the event that acoustic signals are identified that challenge the limit curves during power ascension above 3489 MWt, PPL shall evaluate dryer loads and re-establish the acceptance criteria based on the new data, and shall perform an assessment of ACM uncertainty at the acoustic signal frequency.
4. After reaching full CPPU, PPL shall obtain measurements from the MSL strain gauges and establish the steam dryer flow-induced vibration load fatigue margin for the facility, update the dryer stress report, if required, and re-establish the limit curve with the updated ACM load definition and revised instrument uncertainty, which will be provided to the NRC staff.
5. During power ascension above 3489 MWt, if an engineering evaluation for the steam dryer is required because a Level 1 acceptance criteria is exceeded, PPL shall perform the structural analysis to address frequency uncertainties up to $\pm 10\%$ and assure that peak responses that fall within this uncertainty band are addressed.
6. PPL shall revise the Post Constant Pressure Power Uprate (CPPU) Monitoring & Inspection Program to reflect long-term monitoring of plant parameters potentially indicative of steam dryer failure; to reflect consistency of the facility's steam dryer inspection program with General

Electric Service Information Letter (SIL) 644, "BWR/3 Steam Dryer Failure," Revision 2; and to identify the NRC Project Manager for the facility as the point of contact for providing PATP information during power ascension.

7. PPL shall submit a CPPU steam dryer report to the NRC. The report will be issued following completion of Unit 2 ascension to 114 % CLTP. The report shall include evaluations or corrective actions that were required to assure steam dryer structural integrity. Additionally, it shall include relevant data collected at each power step, comparisons to performance criteria (design predictions), and evaluations performed in conjunction with steam dryer structural integrity monitoring.
 8. PPL shall submit the flow-induced vibration related portions of the CPPU startup test procedure to the NRC, including methodology for updating the limit curve, prior to initial power ascension above 3489 MWt.
- (c) PPL shall prepare the CPPU startup test procedure to include the:
1. main steam line strain gauge limit curves to be used up to 114 % of CLTP;
 2. specific hold points and their duration during CPPU power ascension;
 3. activities to be accomplished during hold points;
 4. plant parameters to be monitored;
 5. inspections and walk-downs to be conducted for steam, feedwater, and condensate systems and components during the hold points;
 6. methods to be used to trend plant parameters;
 7. acceptance criteria for monitoring and trending plant parameters, and conducting the walk-downs and inspections;
 8. actions to be taken if acceptance criteria are not satisfied; and
 9. verification of the completion of commitments and planned actions specified in its application and all supplements to the application in support of the CPPU license amendment request pertaining to the steam dryer prior to power increase above 3489 MWt . PPL shall provide the related CPPU startup test procedure sections to the NRC by facsimile or electronic transmission to the NRC project manager prior to increasing power above 3489 MWt.
- (d) The following key attributes of the PATP shall not be made less restrictive without prior NRC approval:
1. During initial power ascension testing above 3489 MWt, each test plateau increment shall be approximately 3.5 % of 3489 MWt;

2. Level 1 performance criteria; and
3. The methodology for establishing the stress criteria used for the Level 1 and Level 2 performance criteria.

Changes to other aspects of the PATP may be made in accordance with the guidance of Nuclear Energy Institute (NEI) 99-04, "Guidelines for Managing NRC Commitments," issued July 1999.

- (e) During the first two scheduled refueling outages after reaching full CPPU conditions, a visual inspection shall be conducted of all accessible, susceptible locations of the steam dryer in accordance with BWRVIP-139 and General Electric inspection guidelines.
 - (f) The results of the visual inspections of the steam dryer shall be reported to the NRC staff within 60 days following startup. The results of the PATP shall be submitted to the NRC staff in a report within 60 days following the completion of all CPPU power ascension testing.
 - (g) This license condition shall expire upon satisfaction of the requirements in License Conditions 2.C.(20)(e) and 2.C.(20)(f) provided that a visual inspection of the steam dryer does not reveal any new unacceptable flaw or unacceptable flaw growth that is due to fatigue.
- (21) Transient Testing
- (a) PPL will demonstrate through performance of transient testing on each SSES unit that the loss of one condensate pump will not result in a complete loss of reactor feedwater. The test shall be performed on each unit during the unit's CPPU power ascension test program within 336 hours of achieving and prior to exceeding a nominal power level of 3733 MWt with feedwater and condensate flow rates stabilized. PPL shall confirm that the plant response to the transient is as expected in accordance with the acceptance criteria that are established. If a loss of all reactor feedwater occurs as a result of the test, the test failure shall be addressed in accordance with corrective action program requirements and the provisions of the power ascension test program prior to continued operation of the SSES Unit above 3489 MWt.
 - (b) Unless the NRC issues a letter notifying the licensee that the tests specified by License Condition 2.C.(21)(a) adequately demonstrate that a single condensate pump trip will not result in a loss of all feedwater while operating at the full CPPU power level of 3952 MWt, PPL shall perform the transient test on either SSES unit (whichever unit is first to achieve the following specified operating conditions) specified by License Condition 2.C.(21)(a) during the power ascension test program while operating at 3872 MWt to 3952 (98% to 100% of the full CPPU power level) with feedwater and condensate flow rates stabilized. The test shall be performed within 90 days of operating at greater than 3733 MWt and within 336 hours of achieving a nominal power level of 3872 MWt with feedwater and condensate flow rates stabilized. PPL will demonstrate through performance of

transient testing on either Susquehanna Unit 1 or Unit 2 (whichever unit is first to achieve the specified conditions) that the loss of one condensate pump will not result in a complete loss of reactor feedwater. PPL shall confirm that the plant response to the transient is as expected in accordance with the acceptance criteria that are established. If a loss of all feedwater occurs as a result of the test, the test failure shall be addressed in accordance with corrective action program requirements and the provisions of the power ascension test program prior to continued operation of either SSES Unit above 3733 MWt.

(22) Neutronic Methods

- (a) An OPRM amplitude setpoint penalty will be applied to account for a reduction in thermal neutrons around the LPRM detectors caused by transients that increase voiding. This penalty will reduce the OPRM scram setpoint according to the methodology described in Response No. 3 of PPL letter, PLA-6306, dated November 30, 2007. This penalty will be applied until NRC evaluation determines that a penalty to account for this phenomenon is not warranted.
- (b) For SSES SLMCPR, a conservatively adjusted pin power distribution uncertainty and bundle power correlation coefficient will be applied as stated in Response No. 4 of PPL letter, PLA-6306, dated November 30, 2007, when performing the analyses in accordance with ANF-524(P)(A), "Critical Power Methodology for Boiling Water Reactors," using the uncertainty parameters associated with EMF-2158(P)(A) "Siemens Power Corporations Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2."

(23) Containment Operability for EPU

PPL shall ensure that the CPPU containment analysis is consistent with the SSES 1 and 2 operating and emergency procedures. Prior to operation above CLTP, PPL shall notify the NRC project manager that all appropriate actions have been completed.

- 3. This license amendment is effective as of its date of issuance and shall be implemented in accordance with License Conditions 2.C.(20), (21), (22), and (23) above.

FOR THE NUCLEAR REGULATORY COMMISSION

/ra

J. E. Dyer, Director
Office of Nuclear Reactor Regulation

Attachment: Changes to the Operating License
and Technical Specifications

Date of Issuance: January 30, 2008

ATTACHMENT TO LICENSE AMENDMENT NO. 246

FACILITY OPERATING LICENSE NO. NPF-14

DOCKET NO. 50-387

Replace the following page of the License with the attached revise pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
3	3
13	13
14	14
15	15
---	16
---	17
---	18
---	19
---	20

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
1.1-6	1.1-6
TS/2.0-1	TS/2.0-1
3.2-1	3.2-1
3.2-2	3.2-2
3.2-3	3.2-3
3.2-4	3.2-4
3.2-5	3.2-5
3.2-6	3.2-6
3.3-2	TS/3.3-2
3.3-3	TS/3.3-3
3.3-4	3.3-4
3.3-5	TS/3.3-5
3.3-6	TS/3.3-6
3.3-7	TS/3.3-7
3.3-8	TS/3.3-8
TS/3.3-9	TS/3.3-9
3.3-10	---
3.3-21	3.3-21
3.3-29	3.3-29
3.3-30	3.3-30
3.3-31	3.3-31
3.3-57	TS/3.3-57
3.4-7	3.4-7
3.4-8	3.4-8
3.4-27	3.4-27
3.4-28	3.4-28

TS/3.6-15	TS/3.6-15
TS/3.7-1	TS/3.7-1
TS/3.7-3	TS/3.7-3
TS/3.7-3a	TS/3.7-3a
TS/3.7-3b	TS/3.7-3b
---	TS/3.7-3c
---	TS/3.7-3d
TS/3.7-15	TS/3.7-15
TS/3.7-18	TS/3.7-18
TS/3.7-19	TS/3.7-19
TS/5.0-18	TS/5.0-18
TS/5.0-21	TS/5.0-21
TS/5.0-22	TS/5.0-22
TS/5.0-23	TS/5.0-23

ATTACHMENT TO LICENSE AMENDMENT NO. 224

FACILITY OPERATING LICENSE NO. NPF-22

DOCKET NO. 50-388

Replace the following page of the License with the attached revise pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
3	3
9	9
10	10
---	11
---	12
---	13
---	14

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
1.1-6	1.1-6
TS/2.0-1	TS/2.0-1
3.2-1	3.2-1
3.2-2	3.2-2
3.2-3	3.2-3
3.2-4	3.2-4
3.2-5	3.2-5
3.2-6	3.2-6
3.3-2	3.3-2
3.3-3	3.3-3
3.3-4	3.3-4
3.3-5	3.3-5
3.3-6	3.3-6
3.3-7	TS/3.3-7
TS/3.3-8	TS/3.3-8
TS/3.3-9	3.3-9
3.3-10	---
3.3-21	3.3-21
3.3-30	3.3-30
3.3-31	3.3-31
3.3-32	3.3-32
TS/3.3-57	TS/3.3-57
3.4-7	3.4-7
3.4-8	3.4-8
3.4-27	3.4-27
3.4-28	3.4-28
TS/3.6-15	TS/3.6-15
TS/3.7-1	TS/3.7-1

TS/3.7-3	TS/3.7-3
TS/3.7-3a	TS/3.7-3a
TS/3.7-3b	TS/3.7-3b
---	TS/3.7-3c
---	TS/3.7-3d
TS/3.7-15	TS/3.7-15
TS/3.7-18	TS/3.7-18
TS/3.7-19	TS/3.7-19
TS/5.0-18	TS/5.0-18
TS/5.0-21	TS/5.0-21
TS/5.0-22	TS/5.0-22
TS/5.0-23	TS/5.0-23