


PHOTOGRAPHED  
IN KNOXVILLE

20X10423


47E235-77

921590



PLAN - EL 685.0 & 692.0

BUILDING LOCATION AND ROOM NUMBER	OPERATIONAL CONDITION (NOTE 1)	TEMPERATURE (°F)	RELATIVE HUMIDITY (%)	PRESSURE (PSIA) (NOTE 2)	TOTAL 40 YEAR INTEGRATED DOSE (RADS) (NOTE 11)	INTEGRATED ACCIDENT DOSE (RADS) (NOTE 11)	AREA TYPE (NOTE 12)	FLOODING
AUXILIARY BUILDING RESIDUAL HEAT REMOVAL (RHR) VALVE ROOMS EL 685.0	1	AVG 80 MAX 104 MIN 60	SE 80 30	ATM ATM ATM	NA 10 <sup>4</sup> (UNIT 1) 10 <sup>4</sup> (UNIT 2)	NA NA NA	NA	NOTE 14
	2	MAX 110 MIN 50 (NOTE 8)	30 10 (NOTE 10)	ATM ATM	NA NA	NA NA		
	3	130 (NOTE 21 FIGURE 26A)	NOTE 21	NOTE 21	NA	1X10 <sup>7</sup> (UNIT 1 & 2)		
	5	NA	NA	NA	NA	NA		



- GENERAL NOTES: FIGURE AND NOTE NUMBERS CORRESPOND TO THOSE OF REFERENCE 1. ALL FIGURES AND NOTES REQUIRED FOR THE AREAS ARE GIVEN.
- NOTES:
1. OPERATIONAL CONDITION DEFINITIONS:
    1. NORMAL
    2. ABNORMAL
    3. LOCK/HELD INSIDE PRIMARY CONTAINMENT (WORST CASE SHALL BE USED FOR TEMPERATURE - LARGE BRANCH FOR PRESSURE)
    4. HELD OUTSIDE PRIMARY CONTAINMENT
    5. TORNED (SEE PRESSURE DROP OF 3 PSI)
    6. UNEXPECTED CONTAINMENT SPRAY INITIATION - SEE NOTES 19, 22
  2. ATM - INDICATES ATMOSPHERIC PRESSURE EXISTS. NORMAL ATMOSPHERIC PRESSURE AT MSL IS APPROXIMATELY 14.4 PSIA.
  - ATM(+/-) - INDICATES A POSITIVE PRESSURE WITH RESPECT TO THE ATMOSPHERE.
  - ATM(-) - INDICATES A NEGATIVE PRESSURE WITH RESPECT TO THE ATMOSPHERE. THE ANALYSIS IS MAINTAINED AT A NOMINAL PRESSURE OF -0.5 INCHES OF MERCURY (0.0068 PSI) FOR THE ENTIRE DURATION OF THE ANALYSIS. DURING AN ACCIDENT CONDITION (OPERATIONAL CONDITION 3) AND DURING PERIODS OF TESTING THE SYSTEM, ANALYSIS PRESSURE WILL BE MAINTAINED AT -0.5 INCHES OF MERCURY.
  3. THESE MAXIMUM AND MINIMUM TEMPERATURES COULD OCCUR AS A RESULT OF OUTSIDE TEMPERATURE EXCURSIONS; TEMPORARY GREATER THAN DESIGN (LWR) OR DEGRADED ENVIRONMENTAL CONTROL SYSTEM OPERATION. THIS CONDITION COULD EXIST FOR UP TO EIGHT HOURS PER EXCURSION AND WILL OCCUR LESS THAN 1% OF THE PLANT LIFE.
  4. THESE MAXIMUM AND MINIMUM HUMIDITIES COULD EXIST FOR UP TO 8 HRS PER EXCURSION AND WILL OCCUR LESS THAN 1% OF THE PLANT LIFE.
  5. ALL 40 YR INTEGRATED DOSES SHOWN ARE UPPER LIMITS FOR THE DURATION OF THE DESIGN AND BETA CONTRIBUTIONS UNLESS OTHERWISE INDICATED. RADIATION DOSE INFORMATION HAS BEEN TAKEN FROM THE PSAR SECTION 3.11.2. FIGURES 12.3-1 THRU 12.3-7.
  6. A LOCAL TOTAL RADIATION DOSE OBTAINED BY ADDING THE 40 YR INTEGRATED AND INTEGRATED ACCIDENT DOSES FOR SPACES WHICH HAVE 40 YR INTEGRATED DOSES  $\leq 1.75 \times 10^4$  USE  $1 \times 10^4$  RADS FOR AREAS WHICH HAVE 40 YR INTEGRATED DOSES  $\leq 1.75 \times 10^4$  RADS AND INTEGRATED ACCIDENT DOSES  $< 1 \times 10^4$  RADS.
  7. AREAS LISTED ARE DIVIDED INTO THREE CATEGORIES DEFINED AS FOLLOWS:
    - A. SPACES THAT ARE SERVED BY SAFETY-RELATED REDUNDANT ENVIRONMENTAL CONTROL SYSTEMS BACKED BY ONSITE EMERGENCY ELECTRICAL POWER.
    - B. SPACES NOT MAINTAINED BY REDUNDANT ENVIRONMENTAL CONTROL SYSTEMS BACKED BY ONSITE EMERGENCY ELECTRICAL POWER.
    - C. SPACES SERVED BY NON SAFETY-RELATED ENVIRONMENTAL CONTROL SYSTEMS DURING NORMAL CONDITIONS AND REDUNDANT SAFETY-RELATED SYSTEMS DURING ACCIDENT CONDITIONS.
  8. THESE SPACES ARE AFFECTED BY BREAKS IN THE FOLLOWING HIGH ENERGY SYSTEMS: AUXILIARY FEEDWATER (AFW) STEAM SUPPLY; AUXILIARY BOILER SYSTEM; RESIDUAL HEAT REMOVAL (RHR) SYSTEM AND CHEMICAL AND VOLUME CONTROL SYSTEM (CVCS) LETDOWN LINE. THE COMPANION DRAWINGS REFERENCED CONTAIN TEMPERATURE AND PRESSURE VS TIME PROFILES FOR ALL THE WORST CASE BREAK SCENARIOS INVOLVING THESE SYSTEMS. PROFILE TITLES EXPLAIN WHICH HIGH ENERGY SYSTEM EFFECT IS BEING DEPICTED. THE VALUE NUMBERS CORRESPOND TO AREAS OR PORTIONS OF THE AREAS HIGHLIGHTED ON THE KEY PLAN. EACH TEMPERATURE AND PRESSURE CURVE SHOULD BE ASSUMED TO DECREASE LINEARLY TO THE NORMAL MAXIMUM VALUE GIVEN IN THE ENVIRONMENTAL TABLE AT THE END OF 24 HOURS IF IT HAS NOT REACHED THAT VALUE WITHIN THE TIME SCALE OF THE FIGURE. THE SAME HUMIDITY VS TIME FIGURE APPLIES IN EACH CASE. FOR QUALIFICATION PURPOSES, THE WORST CASE HELD PROFILES REPRESENTING THE EVENTS FOR WHICH THE EQUIPMENT IN QUESTION IS REQUIRED TO FUNCTION SHOULD BE USED.
  9. THE COMPUTED MAXIMUM POSSIBLE FLOOD LEVEL OF 740.3 FT WILL NOT AFFECT THE SAFETY-RELATED EQUIPMENT IN THIS (THESE) AREAS. (REF PSAR SEC 2.4.2.21).
  10. DURING POST-LOCK CONDITIONS, THE TEMPERATURE INSIDE THIS SPACE WILL VARY ACCORDING TO THE ACTIVE SUMP CURVE SHOWN ON FIGURE 26A. RELATIVE HUMIDITY WILL REMAIN WITHIN THE ANOMALY RANGE WHILE PRESSURE CHANGE IS NEGLIGIBLE.
  11. NA INDICATES NOT APPLICABLE FOR THIS OPERATIONAL CONDITION.

REFERENCE:

1. SUMMARY OF HARSH ENVIRONMENTAL CONDITIONS FOR SEQUOYAH AND WATTS BAR NUCLEAR PLANTS (NEB 82-0726-235).

Docket # 50-390  
Control # 831160119  
Date 8/14/87 of Document  
REGULATORY DOCKET FILE

ECN NO	DATE	DESIGNED	CHECKED	APPROVED	REVIEWED	DATE
SCALE: NTS EXCEPT AS NOTED						
AUXILIARY BUILDING UNITS 1 & 2						
ENVIRONMENTAL DATA ENVIRONMENT - HARSH EL 685.0						
WATTS BAR NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF ENGINEERING DESIGN						
SUBMITTED		RECOMMENDED		APPROVED		
A. S. [Signature]		A. S. [Signature]		A. S. [Signature]		
KNOXVILLE 8-24-83 85 N 47E235-77						
RECORD NUMBER AS COMPLETED						

FURTHER REVIEWED	
DESIGNED	DATE
CHECKED	DATE
APPROVED	DATE
INSPECTED AND APPROVED FOR ISSUE	
[Signature]	
PRINT	DATE