





9193RD



PLAN-LOWER COMPARTMENT

BUILDING LOCATION AND ROOM NUMBER	OPERATIONAL CONDITION (NOTE 1)	TEMPERATURE (°F)	RELATIVE HUMIDITY (%)	PRESSURE (PSIA) (NOTE 2)	TOTAL 40 YEAR INTEGRATED DOSE (RADS) (NOTE 11)	INTEGRATED ACCIDENT DOSE (RADS) (NOTE 11)	AREA TYPE (NOTE 12)	FLOODING
REACTOR BUILDING CONTAINMENT ANNULUS AREA	1	Avg 105 MAX 110 MIN 50	55 80 30	ATN (-) ATN (-) ATN (-)	NA NOTE 24 NA	NA NA NA	C	NA
	2	MAX 120 MIN 40 } NOTE 8	90 10 } NOTE 10	ATN (-) ATN (-)	NA NA	NA NA		NA
	3	150 FIGURE 2	100	ATN (-)	NA	5 X 10 <sup>7</sup>	NOTE 5	
	5	NA	NA	NOTE 4 NODE 1	NA	NA	NA	
	6	NA	NA	ATN(-) NOTE 18	NA	NA	NOTE 5	



GENERAL NOTES: FIGURE AND NOTE NUMBERS CORRESPOND TO THOSE OF REFERENCE 1. ALL FIGURES AND NOTES REQUIRED FOR THE AREA(S) ARE GIVEN.

**NOTES:**

### 1. OPERATIONAL CONDITION DEFINITIONS:

1. NORMAL
2. AVAILABLE INSIDE PRIMARY CONTAINMENT (HIGHEST CASE SHALL BE USED FOR TEMPERATURE - LATEST MEASUR FOR PRESSURE)
3. HOLD OUTSIDE PRIMARY CONTAINMENT  
TOWARD (ELEVATION) AND (PRESSURE) OF (PSI)  
6. INDOVENT CONTAMINANT SPRAY INITIATION - SEE NOTES ON P. 22
7. ATH - INDICATED ATHEROSPHERIC PRESSURE EXISTS, NORMAL ATHEROSPHERIC PRESSURE NOT AT RISK
- ATH(+/-) - INDICATES A POSITIVE PRESSURE WITH RESPECT TO THE ATMOSPHERE.
- ATH(-) - INDICATES A NEGATIVE PRESSURE WITH RESPECT TO THE ATMOSPHERE. THE ANNULUS IS MAINTAINED AT A MINIMUM PRESSURE OF -0.9 INCHES OF WATER VACUUM DURING AN UNDESIRABLE CONDITION. DURING AN ACCIDENT CONDITION (OPERATIONAL CONDITION 3) FLOOD PROTECTION SHOULD BE MAINTAINED AT -0.8 INCHES OF WATER.
8. PRIMARY CONTAINMENT IS NOT AFFECTED BY DEPRESSURIZATION DURING TYPICAL OPERATION. IT MAY BE REQUIRED TO RECOVER FROM A LOSS OF 1-2% PER HOUR OR APPROXIMATELY ONCE EVERY 30,000 YEARS.
9. FOLLOWING AN ACCIDENT INSIDE PRIMARY CONTAINMENT THE CONTAINMENT SPRAY SYSTEM SHOULD BE ACTIVATED AND FLOODING WOULD LIKELY OCCUR. THIS WOULD REQUIRE THAT THE INDOVENT CONTAMINANT SPRAY (SEE OPERATIONAL CONDITION #1), SAFETY RELATED SYSTEMS INCLUDING THE CONTAINMENT SPRAY SYSTEM, BE MAINTAINABLE UNDER FLOOD ELEVATION. ON OTHERWISE HAVE FLOOD PROTECTION, ALL ACCESSES AND PENETRATIONS INTO THE CONTAINMENT ARE REMAINABLE UNDER FLOOD ELEVATION. BUILDING AREA DESIGNED TO BE WATER-TIGHT; THEREFORE, THE ANNULUS AND CONTAINMENT ARE NOT AFFECTED BY FLOOD. USE THE FLOOD FLOOR LEVEL, INSIDE THE CRAN, IS 723.8 FT (21.0 FT) WHILE THE STEADY STATE LEVEL IS 717.7 FT. THEREFORE, THE MAXIMUM FLOOD ELEVATION IS 723.8 FT. FLOOD ELEVATIONS, THE QUANTITY OF THE CONTAINMENT SPRAY IS 20 CFS DAYS. CONTAINMENT SPRAY CAPACITY IS 10 GPM PER LINEAL IN OR 0.52 GPM PER SQUARE FOOT OF CONTAINMENT CROSS SECTION.
10. THESE MAXIMUM AND MINIMUM ANOMALOUS TEMPERATURES COULD OCCUR AS A RESULT OF OUTSIDE TEMPERATURE EXCURSIONS; TEMPORARY GREATER THAN DESIGN NEED NOT BE MAINTAINED. IF THE CONTAINMENT SPRAY OPERATION, THIS CONDITION COULD EXIST FOR UP TO EIGHT HOURS PER DAY.
11. THESE MAXIMUM AND MINIMUM ANOMALOUS HUMIDITIES COULD EXIST FOR UP TO 8 HRS PER EXCURSION AND WILL OCCUR LESS THAN 1% OF THE PLANT LIFE.
12. ALL 40 YR INTEGRATED DOSES ARE UPPER LIMITS FOR THE COMBINATION OF THE DRAMA AND BETH CONTRIBUTIONS. UNLESS OTHERWISE INDICATED, RADIATION DOSE INFORMATION HAS BEEN TAKEN FROM THE OPERATIONAL CONDITION 3. THESE INTEGRATED ACCIDENT DOSE GIVEN IS FOR A LOCAL, TOTAL RADIATION DOSE. THE INTEGRATED ACCIDENT DOSE GIVEN IS FOR INTEGRATED AND INTEGRATED ACCIDENT DOSE FOR SPACES WHICH HAVE 40 YR INTEGRATED DOSES > 17,500 mrem. USE 1410 mrem FOR AREAS WHERE DOSES ARE 40 YR INTEGRATED DOSES < 17,500 mrem. THE PLANT LIFE AND INTEGRATED ACCIDENT DOSES < 1410 mrem.
13. AREAS LISTED ARE DIVIDED INTO THREE CATEGORIES DEFINED AS FOLLOWS:
  - A. AREAS THAT ARE SERVED BY SAFETY-RELATED REDUNDANT ENVIRONMENTAL CONTROL SYSTEMS BACKED BY ONSITE ELECTRICAL POWER.
  - B. SPACES NOT MAINTAINED BY REDUNDANT ENVIRONMENTAL CONTROL SYSTEMS BACKED BY OFFSITE ELECTRICAL POWER.
  - C. SPACES SERVED BY NON SAFETY-RELATED ENVIRONMENTAL CONTROL SYSTEMS DURING NORMAL CONDITIONS AND REDUNDANT SAFETY-RELATED SYSTEMS DURING ACCIDENT CONDITIONS.
14. ADVERSE CONDITIONS RESULTING FROM INDOVENT CONTAMINANT SPRAY INITIATION CONDITION 3 ARE LIMITED TO ONE HOUR AFTER RETURN TO NORMAL LINEARLY WITHIN 8 HOURS. THIS EVENT SHOULD BE CONFINED TO OCCUR WITHIN THE 40 YEAR INTEGRATED DOSE.
15. FIGURE 4 DEFINES THE 40 YEAR INTEGRATED DOSE INSIDE THE CONTAINMENT AND ANNULUS RELATIVE TO LOCATION.
16. NA INDICATES NOT APPLICABLE FOR THIS OPERATIONAL CONDITION.

#### REFERENCE :

1. SUMMARY OF HARSH ENVIRONMENTAL CONDITIONS FOR SEQUOYAH AND  
MATT'S BAR NUCLEAR PLANTS (NEB 82-0726-235).

**Docket #** 50-396

Control # 8311160119

Date 8/3/07 of Document

REGULATORY DOCKET FILE

REV NO	ECN NO	DATE	DESIGNED	CHECKED	DRAWN	ISSUED	REVISIONS	APPROVED
0890								
CHG								
ORD								
ISS								
SUPV								
SCALE:								EXCEPT AS NOTED
REACTOR BUILDING UNIT 1 & 2								
ENVIRONMENTAL DATA ENVIRONMENT - HARSH ANNULUS AREA								
HATTS BAR NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF ENGINEERING DESIGN								
SUBMITTED			RECOMMENDED			APPROVED		
<i>B.G. Harrison</i>			<i>A.H. Harrison</i>			<i>A.H. Harrison</i>		
KNOXVILLE			9-26-83	DS	N	47E235-44		
NOTES: SEE DRAWING FOR COMMENTS								