

January 11, 2008

MEMORANDUM TO: Thomas G. Hiltz, Chief
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

FROM: Jack Donohew, Senior Project Manager /RA/
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: FORTHCOMING CONFERENCE CALL WITH PRESSURIZED-WATER
REACTOR (PWR) LICENSEES AND NUCLEAR ENERGY INSTITUTE
(NEI) ON LICENSE AMENDMENTS NEEDED FOR SPRING
REFUELING OUTAGES (TAC NO. MD7762)

DATE & TIME: Wednesday, January 16, 2008
1:00 p.m. - 3:00 p.m.

LOCATION: U.S. Nuclear Regulatory Commission
Conference Call on NRC Bridge

PURPOSE: The NRC staff will discuss the new steam generator inspection license
amendments (LAs) needed by certain PWR licensees and answer
questions about why these LAs are needed.

CATEGORY: * This is a Category 1 conference call. The public is invited to attend the
call and will have an opportunity to communicate with the NRC after the
business portion, but before the call is adjourned.

PARTICIPANTS: NRC Participants are in the Office of Nuclear Reactor Regulation (NRR).

<u>NRC</u>	<u>UTILITY</u>
W. Bateman	PWR licensees
J. Lubinski	M. Melton, NEI, et. al.
J. Donohew, et al.	

Enclosure: Agenda (ML080110311)

The public should contact the persons below for the conference call number and password.

CONFERENCE CALL CONTACTS: Jack Donohew, NRR	Balwant Singal, NRR
301-415-1307	301-415-3016
jnd@nrc.gov	bks1@nrc.gov

* Commission's Policy Statement on "Enhancing Public Participation in NRC Meetings," 67 FR 36920, May 28, 2002.

January 11, 2008

MEMORANDUM TO: Thomas G. Hiltz, Chief
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

FROM: Jack Donohew, Senior Project Manager /RA/
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: FORTHCOMING CONFERENCE CALL WITH PRESSURIZED-WATER REACTOR (PWR) LICENSEES AND NUCLEAR ENERGY INSTITUTE (NEI) ON LICENSE AMENDMENTS NEEDED FOR SPRING REFUELING OUTAGES (TAC NO. MD7762)

DATE & TIME: Wednesday, January 16, 2008
1:00 p.m. - 3:00 p.m.

LOCATION: U.S. Nuclear Regulatory Commission
Conference Call on NRC Bridge

PURPOSE: The NRC staff will discuss the new steam generator inspection license amendments (LAs) needed by certain PWR licensees and answer questions about why these LAs are needed.

CATEGORY: * This is a Category 1 conference call. The public is invited to attend the call and will have an opportunity to communicate with the NRC after the business portion, but before the call is adjourned.

PARTICIPANTS: NRC Participants are in the Office of Nuclear Reactor Regulation (NRR).

NRC
W. Bateman
J. Lubinski
J. Donohew, et al.

UTILITY
PWR licensees
M. Melton, NEI, et. al.

Enclosure: Agenda (ML080110311)

The public should contact the persons below for the conference call number and password.

CONFERENCE CALL CONTACTS: Jack Donohew, NRR 301-415-1307 jnd@nrc.gov
Balwant Singal, NRR 301-415-3016 bks1@nrc.gov

* Commission's Policy Statement on "Enhancing Public Participation in NRC Meetings," 67 FR 36920, May 28, 2002.

ADAMS Accession No.: ML080110311

OFFICE	DORL/LPL4/PM	DORL/LPL4/LA	DORL/LPL4/BC
NAME	JDonohew	JBurkhardt	THiltz
DATE	1/11/08	1/11/08	1/11/08

OFFICIAL RECORD COPY

FORTHCOMING CONFERENCE CALL WITH PRESSURIZED-WATER
REACTOR (PWR) LICENSEES AND NUCLEAR ENERGY INSTITUTE (NEI)
ON LICENSE AMENDMENTS NEEDED FOR SPRING
REFUELING OUTAGES (TAC NO. MD7762) ON JANUARY 16, 2008

Dated: January 11, 2008

DISTRIBUTION:

PUBLIC

LPLIV R/F

RidsNrrAdro(BBoger)

RidsNrrDorl(CHaney/JLubinski)

RidsNrrDorlLpl4(THiltz)

RidsNrrPMJDonohew

RidsNrrLAJBurkhardt

RidsOpaMail

RidsOgcMailCenter

RidsAcrcAcnwMailCenter

RidsRgn4MailCenter(VGaddy)

DPelton, EDO RIV

VDricks, OPA RIV

WBateman, NRR

AHiser, NRR

EMurphy, NRR

KKarwoski, NRR

PMNS

AGENDA
CONFERENCE CALL WITH
PRESSURIZED-WATER REACTOR (PWR) LICENSEES
AND NUCLEAR ENERGY INSTITUTE (NEI) RELATED TO
LICENSE AMENDMENTS NEEDED FOR SPRING OUTAGES FOR
STEAM GENERATOR TUBE INSPECTION AND REPAIRS
JANUARY 16, 2008

- Introductions
- NRC Staff Presentation

The staff will explain the reason for the change in the license amendments needed by certain PWR licensees, with steam generators (SGs) with thermally-treated Alloy 600 tubes, which have had previously approved one-cycle 17-inch amendments to limit the inspection of the tubesheet in refueling outages. The staff will (1) address the reasons why the amendments needed are different from the previous 17-inch amendments approved for inspecting SG tubes, the information needed by staff for these amendments, the plants it sees will need amendments for the upcoming spring and fall outages, and the staff reviews needed to issue these amendments before the outages, and (2) answer any questions from the PWR licensees and NEI.

- NEI and PWR Licensees' Presentation

The NRC staff will present its concerns about the staff's plans for issuing amendments in time for the spring outages and any other questions they have.

- Comments, Questions, and Discussion
- End of Conference Call
- **Public Comments**