

**Southern Nuclear
Operating Company, Inc.**
Post Office Box 1295
Birmingham, Alabama 35201-1295
Tel 205.992.5000



January 11, 2008

Energy to Serve Your WorldSM

Docket No.: 50-364

NL-08-0001

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Joseph M. Farley Nuclear Plant – Unit 2
Withdrawal of Request for Relief, RR-59
Temporary Non-Code Repair of Service Water Piping

Ladies and Gentlemen:

On May 11, 2006, Southern Nuclear Operating Company (SNC) submitted a proposed request for relief (RR-59) for a temporary non-Code repair of a service water piping pinhole leak downstream of Q2P16V560. The request for relief was to remain in effect until the next refueling outage or the next Unit 2 cold shutdown greater than 30 days, whichever occurred first. Pursuant to the submittal of the request for relief, the subject pinhole leak was repaired during the Unit 2 outage (2R18). Therefore, SNC hereby withdraws the proposed request for relief, RR-59.

This letter contains no NRC commitments.

If you have any questions, please advise.

Sincerely,

A handwritten signature in black ink, appearing to read "B. J. George", written over a horizontal line.

B. J. George
Manager, Nuclear Licensing

BJG/JLS/phr

cc: Southern Nuclear Operating Company
Mr. J. T. Gasser, Executive Vice President
Mr. J. R. Johnson, Vice President – Plant Farley
Mr. D. H. Jones, Vice President – Engineering
RType: CFA04.054; LC# 14709

U. S. Nuclear Regulatory Commission
Mr. V. M. McCree, Acting Regional Administrator
Ms. K. R. Cotton, NRR Project Manager – Farley
Mr. E. L. Crowe, Senior Resident Inspector – Farley