

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)

3.5.3 ECCS – Shutdown

LCO 3.5.3 One ECCS train shall be OPERABLE.

-----NOTES-----

1. An RHR train may be considered OPERABLE during alignment and operation for decay heat removal, if capable of being manually realigned to the ECCS mode of operation.
 2. An SI train may be considered OPERABLE when the pump is capable of being manually started from the control room.
-

APPLICABILITY: MODE 4 when both RCS cold leg temperatures are > SI pump disable temperature specified in PTLR.

ACTIONS

-----NOTE-----
LCO 3.0.4.b is not applicable to ECCS safety injection (SI) subsystem.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Required ECCS residual heat removal (RHR) subsystem inoperable.	A.1 Initiate action to restore required ECCS RHR subsystem to OPERABLE status.	Immediately
B. Required ECCS safety injection (SI) subsystem inoperable.	B.1 Restore required ECCS SI subsystem to OPERABLE status.	1 hour