

January 24, 2008

LICENSEE: Entergy Nuclear Operations, Inc.
FACILITY: James A. FitzPatrick Nuclear Power Plant
SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON JANUARY 11, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING THE 115KV AC POWER SUPPLY CONNECTION PERTAINING TO THE JAMES A. FITZPATRICK NUCLEAR POWER PLANT LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on January 11, 2008, to discuss a concern regarding a cross-connect for the 115kV AC power supply sources and license renewal scoping for the James A. FitzPatrick Nuclear Power Plant's license renewal application.

Enclosure 1 provides a listing of the participants, and Enclosure 2 contains a brief description of the conference call.

The applicant had an opportunity to comment on this summary.

/RA/

N.B. (Tommy) Le, Sr. Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosures:
As stated

cc w/encls: See next page

January 24, 2008

LICENSEE: Entergy Nuclear Operations, Inc.
FACILITY: James A. FitzPatrick Nuclear Power Plant
SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON JANUARY 11, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING THE 115KV AC POWER SUPPLY CONNECTION PERTAINING TO THE JAMES A. FITZPATRICK NUCLEAR POWER PLANT LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on January 11, 2008, to discuss a concern regarding a cross-connect for the 115kV AC power supply sources and license renewal scoping for the James A. FitzPatrick Nuclear Power Plant's license renewal application.

Enclosure 1 provides a listing of the participants, and Enclosure 2 contains a brief description of the conference call.

The applicant had an opportunity to comment on this summary.

/RA/

N.B. (Tommy) Le, Sr. Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosures:
As stated

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: **ML080150534**

OFFICE	LA:DLR	PM:RLRB:DLR	BC:RLRB:DLR
NAME	IKing	TLe	RFranovich
DATE	01/16/08	01/17/08	01/24/08

OFFICIAL RECORD COPY

LIST OF PARTICIPANTS FROM THE
TELEPHONE CONFERENCE CALLS
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
LICENSE RENEWAL APPLICATION

JANUARY 11, 2008

PARTICIPANTS

AFFILIATIONS

Tommy Le	U.S. Nuclear Regulatory Commission (NRC)
Rani Franovich	NRC
Roy Mathew	NRC
Raj Auluck	NRC
Duc Nguyen	NRC
George Wilson	NRC
Sheila Ray	NRC
Rick Plasse	Entergy Nuclear Operations, Inc. (ENO)
Mike Stroud	ENO
Dan Ruddy	ENO
Larry Leiter	ENO
Alan Cox	ENO

JAMES A. FITZPATRICK NUCLEAR POWER PLANT
LICENSE RENEWAL APPLICATION
(Brief description of the conference call)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations, Inc. (Entergy), held a telephone conference call on January 11, 2008, to discuss a concern regarding the scoping of the station black-out (SBO) recovery paths, specifically, the offsite 115kV AC power supply sources, concerning the James A. FitzPatrick Nuclear Power Plant's (JAFNPP) license renewal application (LRA).

Discussion: During the teleconference call, the staff requested the applicant to discuss the offsite 115kV AC power supply sources in regards to the scoping of the SBO recovery paths. The NRC staff specifically asked if the disconnect switch 10017 is within the JAFNPP license renewal scoping.

The applicant indicated that based on the scoping and screening method used by Entergy, as described in the JAFNPP LRA, Section 2.5, the SBO recovery path would include in the review everything from the identified switchyard breakers (10022 and 10012) to the identified reserve transformers (T2 and T3) unless they are specifically stated as screened out.

The applicant stated that it understood the staff's specific question as to whether (1) the South 115kV bus and North 115kV bus cross-connect and (2) the normally closed electrically operated disconnect switch (10017) were included in the scope. The applicant stated that the cross-connect, which is part of the switchyard bus, and the electrically operated disconnect switch, both of which are located between the switchyard breakers 10022 and 10012 and the transformers T2 and T3, are in the scope of the JAFNPP license renewal. The applicant reiterated, during the conference phone call, that "LRA Table 2.5-1 states that switchyard bus is subject to aging management review; and LRA Table 3.6.2-1 includes the commodity type Switchyard bus (switchyard bus for SBO), connections." And as such, no changes are required for the JAFNPP LRA Sections 2.5, 3.6 or Appendix B.

Letter to Entergy Nuclear Operations from Tommy Le, dated January 24, 2008

DISTRIBUTION:

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALLS HELD ON JANUARY 11, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING THE 115KV AC POWER SUPPLY CONNECTION PERTAINING TO THE JAMES A. FITZPATRICK NUCLEAR POWER PLANT LICENSE RENEWAL APPLICATION

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

SSmith (srs3)

SDuraiswamy

RidsNrrDir

RidsNrrDirRlra

RidsNrrDirRlrb

RidsNrrDirRlrc

RidsNrrDirReba

RidsNrrDirRebb

RidsNrrDciCvib

RidsNrrDciCpnb

RidsNrrDraAfpb

RidsNrrDeEmcb

RidsNrrDeEeeb

RidsNrrDssSrxb

RidsNrrDssSbpb

RidsNrrDssScvb

RidsOgcMailCenter

GHunegs, SRI

ECobey

RLaufer

JBoska

FitzPatrick Nuclear Power Plant

cc:

Mr. Michael R. Kansler
President & CEO / CNO
Entergy Nuclear Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. John T. Herron
Sr. Vice President
Entergy Nuclear Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Sr. Vice President
Engineering & Technical Services
Entergy Nuclear Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. Peter T. Dietrich
Site Vice President
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Mr. Kevin J. Mulligan
General Manager, Plant Operations
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Mr. Oscar Limpias
Vice President Engineering
Entergy Nuclear Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. Joseph P. DeRoy
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. John A. Ventosa
GM, Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. John F. McCann
Director, Nuclear Safety & Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Charlene D. Faison
Manager, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Ernest J. Harkness
Director, Oversight
Entergy Nuclear Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. Michael J. Colomb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

Mr. James Costedio
Manager, Licensing
Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
P.O. Box 110
Lycoming, NY 13093

FitzPatrick Nuclear Power Plant

-2-

cc:

Mr. William C. Dennis
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
James A. FitzPatrick Nuclear Power Plant
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. Michael Balboni
Deputy Secretary for Public Safety
State Capitol, Room 229
Albany, NY 12224

Mr. Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. John P. Spath
New York State Energy, Research, and
Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Mr. Paul Eddy
New York State Depart. of Public Service
3 Empire State Plaza
Albany, NY 1223-1350

Oswego County Administrator
Mr. Steven Lyman
46 East Bridge Street
Oswego, NY 13126

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 3126

Mr. James H. Sniezek
BWR SRC Consultant
5486 Nithsdale Drive
Salisbury, MD 21801-2490

Mr. Michael D. Lyster
BWR SRC Consultant
5931 Barclay Lane
Naples, FL 34110-7306

Mr. John Doering
BWR SRC Consultant
P.O. Box 189
Parker Ford, PA 19457