



**Nebraska Public Power District**

*Always there when you need us*

10 CFR 50.55a

NLS2008007  
January 17, 2008

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555-0001

Subject: Correction to Inservice Inspection Summary Report  
Cooper Nuclear Station  
NRC Docket No. 50-298, DPR-46

Reference: Letter from Paul V. Fleming, Nebraska Public Power District, to U. S. Nuclear  
Regulatory Commission Document Control Desk, dated February 20, 2007,  
"Inservice Inspection Summary Report"

Dear Sir or Madam:

The purpose of this letter is to inform the Nuclear Regulatory Commission (NRC) of an error discovered in Attachment 1 to the Cooper Nuclear Station (CNS) Inservice Inspection (ISI) Summary Report sent February 20, 2007 (Reference). The error consisted of crediting American Society of Mechanical Engineers (ASME) Section XI Category B-G-2 bolting examinations performed in Refueling Outage 23. These examinations were performed while the bolting was in place instead of when disassembled as required by ASME Code. The specific components affected are MSB-BG2-16, MSB-BG2-21, MSC-BG2-19, MSC-BG2-24 (relief valve to pipe flange bolting) and MS-AO-86A (Main Steam Isolation Valve bolting) listed in Attachment 1 to the above reference, pages 2 and 3 of 56. The CNS ISI Program was revised to no longer credit these inspections. CNS documented this error in the CNS Corrective Action Program and notified the Authorized Nuclear Inservice Inspector (ANII) for CNS. The error correction does not require NRC approval.

The 2001 Edition/2003 Addenda of ASME Section XI is the current Code of Record for the 4<sup>th</sup> Inservice Interval of CNS. The provisions of the ASME Code, Category B-G-2 provided for examinations only when the bolting is disassembled. These examinations may be limited to one bolted connection among a group of bolted connections that are similar in design, size, function, and service or when a valve is examined per Code Category B-M-2. No ASME required examinations were missed.

**COOPER NUCLEAR STATION**

P.O. Box 98 / Brownville, NE 68321-0098

Telephone: (402) 825-3811 / Fax: (402) 825-5211

www.nppd.com

A047  
MERB

NLS2008007

Page 2 of 2

Should you have any questions concerning this matter, please contact David Van Der Kamp, Licensing Manager, at (402) 825-2904.

Sincerely,



David Van Der Kamp  
Licensing Manager

/dm

cc: Regional Administrator  
USNRC - Region IV

Cooper Project Manager  
USNRC - NRR Project Directorate IV-1

Senior Resident Inspector  
USNRC - CNS

ANII - Hartford Steam Boiler Inspection and Insurance Co. of Connecticut - CNS

NPG Distribution

CNS Records

ATTACHMENT 3 LIST OF REGULATORY COMMITMENTS©

ATTACHMENT 3 LIST OF REGULATORY COMMITMENTS©

Correspondence Number: NLS2008007

The following table identifies those actions committed to by Nebraska Public Power District (NPPD) in this document. Any other actions discussed in the submittal represent intended or planned actions by NPPD. They are described for information only and are not regulatory commitments. Please notify the Licensing Manager at Cooper Nuclear Station of any questions regarding this document or any associated regulatory commitments.

COMMITMENT	COMMITMENT NUMBER	COMMITTED DATE OR OUTAGE
None.	N/A	N/A