

3.7 PLANT SYSTEMS

3.7.5 Control Room Ventilation System

LCO 3.7.5 Two control room ventilation subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in the secondary containment,
During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One control room ventilation subsystem inoperable.	A.1 Restore control room ventilation subsystem to OPERABLE status.	30 days
B. Two control room ventilation subsystems inoperable.	B.1 Verify control room area temperature < 90°F. <u>AND</u> B.2 Restore one control room ventilation subsystem to OPERABLE status.	Once per 4 hours 72 hours
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4.	12 hours 36 hours
D. Required Action and associated Completion Time of Condition A not met during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.	-----NOTE----- LCO 3.0.3 is not applicable. ----- D.1 Place OPERABLE control room ventilation subsystem in operation.	Immediately

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
	<u>OR</u> D.2.1 Suspend movement of recently irradiated fuel assemblies in the secondary containment. <u>AND</u> D.2.2 Initiate action to suspend OPDRVs.	Immediately Immediately
E. Required Action and associated Completion Time of Condition B not met during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.	<p>-----NOTE----- LCO 3.0.3 is not applicable. -----</p> E.1 Suspend movement of recently irradiated fuel assemblies in the secondary containment. <u>AND</u> E.2 Initiate actions to suspend OPDRVs.	Immediately Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.5.1 Verify each control room ventilation subsystem has the capability to remove the assumed heat load.	24 months