



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

due → January 22, 2003

	SRI
<i>m</i>	RI
	SEC
	FILE
	INFO
	OWNER
	ADMIN

Mr. John L. Skolds, President
Exelon Nuclear
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: LICENSED THERMAL POWER - BYRON STATION, UNIT 1

Dear Mr. Skolds:

As a result of the Nuclear Regulatory Commission (NRC) staff review of technical information regarding the operation of Byron Station, Unit 1 (Byron 1), we are concerned that Byron 1 may be operating above its licensed thermal power level.

This concern is based, in part, on the following information:

Following installation of an ultrasonic feedwater flow instrument at Byron 1, differences appeared in the power levels between Byron 1 and Braidwood 1, its sister unit. This suggests differences in accuracy in the ultrasonic flowmeters. Presently, Byron 1 is producing more electrical power at approximately 98 percent power, than Braidwood 1 is producing at 100 percent power.

Several plant parameters reportedly have values that are consistent with a higher thermal power level than that indicated by the plant calorimetrics based upon the feedwater flow measurements. It has been postulated that these discrepancies may be explained as allowable and expected errors in each parameter within the associated uncertainty bands. It seems unlikely that such errors would all exhibit the same consistent bias: errors due to anticipated instrument measurement uncertainties would be expected to be positive or negative at random, and therefore to produce roughly as many low readings as high ones. The consistently positive direction of the reported errors suggests a consistent bias influenced by some common cause, and suggests that the power level may indeed be higher than the calorimetrics would indicate.

There appears to be evidence of higher fuel burn rate at Byron 1 compared to Braidwood 1.

Following approval of a 5 percent power uprate for the units at Byron and Braidwood, Byron 1 has not been able to fully utilize the power increase due to limitations in the high-pressure turbine or steam control valve capacities. Braidwood 1 has not experienced such limitations.

Mr. J. Skolds

- 2 -

As a consequence of the above observations, we request that Exelon Generation Company, LLC, expeditiously provide the NRC with assurance that Byron 1 is operating within its licensed thermal power limit or take the necessary and appropriate actions to assure that the unit is within the limit.

Please contact me if there are specific questions.

Sincerely,



John A. Zwolinski, Director
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. STN 50-454

cc w/encl: See next page

Byron Station Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, IL 62704

Document Control Desk-Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Ms. C. Sue Hauser, Project Manager
Westinghouse Electric Corporation
Energy Systems Business Unit
Post Office Box 355
Pittsburgh, PA 15230

Joseph Gallo
Gallo & Ross
1025 Connecticut Ave., NW, Suite 1014
Washington, DC 20036

Howard A. Learner
Environmental Law and Policy
Center of the Midwest
35 East Wacker Drive
Suite 1300
Chicago, IL 60601-2110

U.S. Nuclear Regulatory Commission
Byron Resident Inspectors Office
4448 North German Church Road
Byron, IL 61010-9750

Ms. Lorraine Creek
RR 1, Box 182
Manteno, IL 60950

Chairman, Ogle County Board
Post Office Box 357
Oregon, IL 61061

Mrs. Phillip B. Johnson
1907 Stratford Lane
Rockford, IL 61107

Attorney General
500 S. Second Street
Springfield, IL 62701

Byron Station Manager
Exelon Generation Company, LLC
4450 N. German Church Road
Byron, IL 61010-9794

Site Vice President - Byron
Exelon Generation Company, LLC
4450 N. German Church Road
Byron, IL 61010-9794

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President
Mid-West Operations Support
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Vice President
Mid-West Regional Operating Group
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Chairman
Will County Board of Supervisors
Will County Board Courthouse
Joliet, Illinois 60434

Illinois Emergency Management Agency
Division of Disaster Assistance &
Preparedness
110 East Adams Street
Springfield, Illinois 62701-1109

Director Licensing
Mid-West Regional Operating Group
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Regulatory Assurance Manager - Byron
Exelon Generation Company, LLC
4450 N. German Church Road
Byron, IL 61010-9794

Senior Counsel, Nuclear
Mid-West Regional Operating Group
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President
Licensing and Regulatory Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Braidwood and Byron
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555