

 Go Back

[Print](#) | [New Search](#) | [Home](#)

## Assignment Report

Assign #: 47

AR #: 00173510

<b>Aff Fac:</b> Byron	<b>Assign Type:</b> RCMT	<b>Status:</b> ACC/ASG
<b>Priority:</b> CAPR	<b>Assigned To:</b> BYRZE	<b>Due Date:</b> 01/30/2004
<b>Schedule Ref:</b>	<b>Prim Grp:</b> A8830NESTT	<b>Original Date:</b> 10/17/2003
<b>Unit Condition:</b>	<b>Sec Grp:</b>	

### Assignment Request

**Subject/Description:** CAPR to revise procedure and initiate new procedure

### Assignment Completion

**In Progress Notes:** 173510-47  
\*  
12/19/03 - M.Page - Due date extended to 01/30/04 as approved by the Plant Manager.  
\*  
Due date extended as approved by Plant Manger (ADB 10/13/03)  
\*  
CAPR1 Action: Revise BVP 800-44 and initiate a new procedure BVP 800-47 for the common header, to include in a step to check AMAG for noise. If noise exists that contaminates the signal, do not use AMAG to establish new correction factors (CFs). Include in the procedure an acceptance criteria for determining if the AMAG signal contains noise that adversely affects the AMAG results.

Responsible Organization: Byron PED (A8830NESTT)  
Due Date: 10/17/03

NOTE Per LS-AA-125 (revision 5) Step 4.5.6.1 If the intent of a CA cannot be performed as defined in Action Tracking, the assignee shall review and gain approval for the change with the "CR Owed To's" Senior Manager. If the intent of a CAPR cannot be performed as defined in Action Tracking, the responsible manager shall bring the changed issue back to MRC for review and approval of the change.

If additional CA's are identified, create the CA using the below format.  
\*  
New CA1:  
Description of Corrective Action To Be Taken:  
\*  
Assignee:  
\*  
Due Date:  
\*  
\*  
New CA2:  
Description of Corrective Action To Be Taken:  
\*  
Assignee:  
\*  
Due Date:  
\*  
\*

B-42

New CA3:  
Description of Corrective Action To Be Taken:  
\*  
Assignee:  
\*  
Due Date:  
\*

.....

**Completion Notes:**