

From: Steven Ray ^{RTT}
To: Skokowski, Richard; Snyder, Peter; Stone, Ann Marie
Date: 1/30/04 11:28AM
Subject: 50.59 on sodium tracer test

After my comments at my weekly management meeting yesterday, the design engineering manager took a look at the 50.59 screening for the tracer test and agreed that using the argument that the test is "described" in the UFSAR is not appropriate. He is going to have it rewritten but thinks it will still screen out as not needing a full 50.59 because of the minimal impact on the plant. I guess that's the best I can get out of them.

They are also going to revise the actual test procedure to include some comments I had about prereqs etc. The CRs are 198280 and 198423 for my concerns.