

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: ESBWR Subcommittee Meeting

Docket Number: (Not provided)

Process Using ADAMS Template
ACRS/ACNW-005
SUNSI Review Complete *CSH*
1-29-08

Location: Rockville, Maryland

RECEIVED
JAN 29 2008

Date: Wednesday, January 16, 2008

Work Order No.: NRC-1972

Pages 1-433

ORIGINAL

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

ACRS OFFICE COPY
DO NOT REMOVE FROM ACRS OFFICE

TROY

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

January 16, 2008

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on January 16, 2008, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARD
(ACRS)

+ + + + +

ESBWR SUBCOMMITTEE

+ + + + +

WEDNESDAY

January 16, 2008

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 8:30 a.m., Michael
Corradini, Chairman, presiding.

COMMITTEE MEMBERS:

MICHAEL CORRADINI, Chairman

SAID ABBEL-KHALIK, Member

J. SAM ARMIJO, Member

SANJOY BANERJEE, Member

DENNIS C. BLEY, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 COMMITTEE MEMBERS (continued):
2 JOHN D. SIEBER, Member
3 ROBERT E. UHRIG, Member
4 THOMAS S. KRESS, Consultant
5 GRAHAM B. WALLIS, Consultant
6 GARY HAMMER, Designated Federal Official

7

8

9

10

11

12

13

14

15

16

17

18

19

20

C-O-N-T-E-N-T-S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

<u>AGENDA ITEM</u>	<u>PAGE</u>
Opening Remarks	4
DCD Chapter 4, "Reactor"	7
SER with Open Items for Chapter 4	77
DCD Chapter 6, "Engineered Safety Features"	156
SER with Open Items for Chapter 6	261
Subcommittee Discussion	---

P R O C E E D I N G S

(8:31 a.m.)

OPENING REMARKS

CHAIRMAN CORRADINI: Okay, let's get started. The meeting will come to order.

This is a meeting of the ESBWR subcommittee. My name is Mike Corradini. I'm chair of the subcommittee.

Other ACRS members in attendance are Said Abdel-Khalik, Sam Armijo, Sanjoy Banerjee, on his way, Dennis Bley, Otto Maynard, Bill Shack and Jack Sieber.

Graham Wallis and Tom Kress will also be attending as consultant to the subcommittee. We have one of our consultants here.

Gary Hammer of the ACRS staff is the designated federal official for this meeting.

The purpose of the meeting is to review and discuss the safety evaluation report with open items for several chapters of the ESBWR design certification.

We will hear presentations from the NRC's Office of New Reactors, and GE-Hitachi Nuclear Energy America, LLC.

The subcommittee will gather information, analyze relevant issues and actions as appropriate for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deliberation by the full committee.

2 The rules for participation in today's
3 meeting have been announced as part of the notice of
4 this meeting previously published in the Federal
5 Register. Portions of this meeting may be closed for
6 the discussion of unclassified safeguards and
7 proprietary information.

8 We have received no written comments or
9 requests for time to make oral statements from members
10 of the public regarding today's meeting. A transcript
11 of the meeting is being kept, and will be made
12 available as stated in the Federal Register notice.

13 Therefore, we request that participants in
14 this meeting use the microphones located throughout
15 the meeting room when addressing the subcommittee.

16 Participants should first identify
17 themselves and speak with sufficient clarity and
18 volume that they may be readily heard.

19 We will proceed with the meeting, and I'll
20 call upon Jim Kinsey of GEH to kick us off.

21 Ken.

22 MR. KINSEY: Thank you, Jim. My name is
23 Jim Kinsey from GE-Hitachi. I work in the regulatory
24 affairs organization.

25 We appreciate the opportunity to make

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these presentations with you this morning. We've
2 brought a relatively large integrated team from GE-
3 Hitachi that includes a number of members from both
4 our technical and our licensing organization.

5 I understand the agenda for the morning is
6 to go over a presentation of our DCD Chapter 4, which
7 includes the basically the reactor and internals, and
8 then that will be supplemented or discussed by the NRC
9 staff, and then we would plan to move into a
10 discussion of stability after the Chapter 4
11 discussion.

12 And with that I guess I'd like to turn it
13 over to John Sorenson to introduce the team.

14 MR. SORENSON: My name is John Sorenson.
15 I work in regulatory affairs at GEH.

16 On my right is Russ Fawcett, who will be
17 discussing the price of DCD Chapter 4. And further on
18 my right is Jerry Deaver, who will also be discussing
19 the remaining part the DCD Chapter 4.

20 We have -- Jeff has -- Mr. Kinsey brought
21 a team that covers a fairly wide range of disciplines,
22 so we have a fairly large contingent of engineers to
23 support us.

24 Content of Chapter 4 includes a summary
25 discussion, and then in the details of the fuel system

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design. Mr. Fawcett will be discussing the fuel
2 system design and nuclear design and the thermal and
3 hydraulic design.

4 Mr. Deaver will discuss the acting
5 materials, and reactivity control system functional
6 design, and will give a brief summary.

7 Section 451 only provides a overview.
8 There is no detailed technical information. It only
9 provides an overview and a roadmap to the content of
10 the remainder of Chapter 4.

11 Now let me turn things over to Mr.
12 Fawcett, who will discuss Sections 4.2, 4.3 and 4.4.

13 MR. FAWCETT: Good morning, my name is
14 Russ, Russ Fawcett. And I'm the manager of core and
15 fuel advanced design for Global Nuclear Fuels.

16 And I'll provide a brief description of
17 BCD Section 4.2, .3 and .4, which describe the fuel,
18 assembly, design, evaluations and bases as well as the
19 control rod, the nuclear design of the core, as well
20 as the thermal hydraulic design.

21 Again this will be a brief description.
22 I think we conclude that brief is adequate, as the
23 ESBWR core is really just another BWR core comprised
24 of proven technologies with characteristics very
25 similar to the existing fleets.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The beginning of 4.2, the fuel system
2 design, similar in 4.3 and 4.4, we describe design
3 bases for the fuel assembly and the control rods; the
4 description of the design, as well as the evaluations
5 performed to demonstrate compliance.

6 In terms of the fuel rod design in the
7 evaluations, we performed thermal mechanical
8 evaluations based on either worst case or
9 statistically bounding limits including uncertainties.

10 And these analyses are performed to assure
11 that we comply with licensing requirements during both
12 steady state and anticipated operational occurrences.

13 Likewise the control design is evaluated
14 to coordinate stress, strain and fatigue limits; that
15 it's capable of being inserted during all modes of
16 plan operation in that it has mechanical compatibility
17 with the remainder of the reactor internals.

18 And again, by and large, the ESBWR fuel
19 system and control rods are similar to those used in
20 the operating fleet.

21 Next slide, please.

22 In terms of the fuel assembly, it is
23 identified as GE14E, which is really just a modest
24 variant of GE14 that we have been delivering for many
25 years and is operating throughout the fleet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 GE14E is comprised of the same components,
2 identical components and materials that were installed
3 in the GE14 that we got experience in taking fuel to
4 assembly, average exposures as high as 68,000
5 megawattage per ton.

6 That corresponds to approximately 80,000
7 peak pellet exposure, which is 15 percent higher than
8 our licensing limits.

9 So we have in-core radiation experience
10 far and above where we will be taking reload batches
11 of fuel.

12 MR. ARMIJO: Let me just interrupt.

13 When you say identical, do you truly mean
14 identical including cladding thickness, pellet
15 density, plenum to fuel volume ratio? I mean this
16 thing is really a scaled version of the standard GE14?

17 MR. FAWCETT: I would say at the component
18 level with the exception of the fuel rod the answer is
19 yes. The spaces are identical; the pellets are
20 identical; the tubing is identical; the area of
21 thickness is identical; pellet to clad gap is
22 identical.

23 One key difference that you noted was the
24 fuel plenum to fuel volume ratio is actually bigger
25 for the ESBWR fuel rod, so we have introduced some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 additional margins. So we anticipate and will project
2 some fairly significant reductions in fuel rod
3 internal pressure relative to our current experience.

4 MR. ABDEL-KHALIK: Hydraulically they are
5 not really similar. Because you have different length
6 of part-length rods, ratio between part-length rod and
7 full-length rod, location spacers, et cetera.

8 MR. FAWCETT: Well, I would say on a nodal
9 basis they are the same. The integral hydraulic
10 resistance --

11 MR. ABDEL-KHALIK: Yes.

12 MR. FAWCETT: -- is different because it's
13 shorter.

14 Now recognize that our analytical methods
15 are nodal-based, and our hydraulic models for losses
16 are nodal-based or component-based.

17 And I'll touch on this a little bit later.
18 Now we have performed GE14-specific testing to confirm
19 the adequacy of our hydraulic models.

20 CHAIRMAN CORRADINI: So if you do cover it
21 later I guess I'll add to Steve's question, which is
22 that because you are shorter you are trying to
23 preserve some sort of limit by reducing it so that you
24 can get the appropriate flow; I assume it's minimum
25 CPR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But when the time is right I'd appreciate
2 to be clear as to what's the limit you were bumping up
3 against to require the fuel to be shorter.

4 MR. FAWCETT: Well I think this is a good
5 time to discuss that. I don't know if you would say
6 that there was a hard limit per se, as much as what
7 was considered a good balance. And in developing
8 natural circulation reactors, and we've been doing
9 that for a very long time, it involves a composite
10 evaluation, looking at the pressure vessel height, the
11 core height, the power density, all the things that
12 influenced our recirculation flow, and the objective
13 is to construct or sample a good balance or balanced
14 performance.

15 And that's how we arrived at the preferred
16 assembly length that we have for GE14E, that gives us
17 adequate core flow and sufficient peak design
18 flexibility to manage assembly powers.

19 Is MCTR the most important design
20 consideration? Yes, it probably is. The remainder of
21 the things that the nuclear designer considers in fuel
22 application are very straightforward to address, and
23 critical power is straightforward to address, because
24 we do have adequate flow with very mild transient
25 response, the core with good operating limits.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. WALLIS: Your enrichment profile and
2 your burnable poisons and everything are all the same
3 as you already have?

4 MR. FAWCETT: I would say for a BWR fuel
5 application every cycle is different. The specific
6 nuclear design is tailored to meet a utility's
7 objective.

8 We used the same techniques in
9 distributing Gadilinium, the enrichment and the
10 assembly, that we do today.

11 So depending on cycle length and discharge
12 exposure, we may put Gadilinium preferred at the
13 bottom of the core to flatten axial power shapes.

14 I'll say, one of the things that are
15 inherent, that I will touch on a little bit later, is
16 that the N-lattice, which is the ESBWR is comprised
17 of, which is the same as the ABWR lattice, exhibits
18 significantly more hot-to-cold reactivity swing than,
19 say, BWR-2 through 6.

20 So we don't have to solve problems with
21 cold shutdown margin as significant -- in fact it's
22 almost a nondesign issue today in the ESBWRs.

23 So to answer your question, yes, standard
24 techniques.

25 MR. ARMIJO: You're not using any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 unusually high Gadilinium concentrations or loadings
2 or anything else? What is your maximum Gadilinia?

3 MR. FAWCETT: Eight percent for a two-year
4 cycle. It's really a function of the cycle length,
5 and the cycle exposure, given the power density, ESBWR
6 cycle exposures are similar to what we have today.

7 CHAIRMAN CORRADINI: Just to remind us, so
8 if you are going to start talking about things that we
9 need to talk about in a proprietary or closed session,
10 let us know, because we are not going to know.

11 MR. FAWCETT: Sure.

12 MR. ABDEL-KHALIK: Will you be talking
13 about the applicability of the GEXL14 correlation to
14 this short bundle?

15 MR. FAWCETT: Yes.

16 MR. ABDEL-KHALIK: Okay, in an open
17 session or closed session?

18 MR. FAWCETT: Open, to the extent we can.

19 MR. ARMIJO: Just one back issue that I
20 want to get and make sure before we leave this
21 prescription.

22 You are going to use a barrier fuel
23 design. And I looked up the composition in one of
24 your reports, topical reports.

25 And it showed it was just the pure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 version. I thought GEH was using an iron alloyed
2 barrier. I didn't find it in the SER or the DCE what
3 the actual line of composition is?

4 CHAIRMAN CORRADINI: That is probably a
5 good topic for a closed session.

6 MR. ARMIJO: Okay, we'll get to that.

7 MR. SIEBER: The overall dimensions of the
8 fuel are in the core such that you get more neutron
9 economy that you otherwise would get with a longer
10 fuel.

11 MR. FAWCETT: I will say that fuel
12 requirements for ESBWR fuel efficiency is comparable
13 to the top quartile in the fleet, perhaps slightly
14 higher leakage axially, but it is large radially, and
15 on balance it is similar.

16 Next slide.

17 In terms of the control rod design, it is
18 a derivative of the Marathon control rod design. The
19 key noteworthy item here is for ESBWR we have
20 introduced some additional margins, mechanical
21 margins, and have modified the design to accommodate
22 B4C 12 over and above what's available in the existing
23 product line.

24 Next slide, please.

25 Okay, 4.3: the nuclear design, again, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 described the design bases. That related to
2 reactivity management and assuring we do not have
3 positive reactivity coefficients, or such that would
4 allow a reactivity excursion as well as the overpower
5 bases that ultimately result in limits on the power
6 distribution.

7 Our analytical methods for steady state,
8 core simulations; how we calculate reactivity
9 coefficients as well as stability methods; and results
10 of our evaluations in terms of assuring negative
11 reactivity feedback; control requirements;
12 subcriticality during refueling; power distributions;
13 and stability.

14 Next slide, please.

15 A few words about the ESBWR core from,
16 again, from a core management --

17 MR. WALLIS: I'm sorry, you haven't yet
18 tested it for flow-induce vibration, I understand?

19 MR. FAWCETT: That is correct.

20 MR. WALLIS: Are you going to do that?

21 MR. FAWCETT: Yes.

22 MR. WALLIS: Is it going to be different?
23 Haven't you already tested the 14 fuel?

24 MR. FAWCETT: Yes, we have. And overall
25 from an FIV point of view, the ES GE14E will see less

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 duty or less susceptibility to vibrations, because
2 flow rates are lower, that's why. But we will pass it
3 anyway.

4 Again, from a fuel designer's point of
5 view, the ESBWR is just another large BWR core that
6 does operate at somewhat lower flow rates. The rate
7 of power is 4,500 Megawatts thermal, and the core is
8 1,132 bundles.

9 Within the BWR fleet there is a wide range
10 of core sizes from as small as 240 bundles, to as high
11 as 872 bundles, with the ABWR.

12 Core size is not particularly noteworthy
13 from a core management perspective, except that small
14 cores tend to have higher flux radiance and higher
15 peaking than do large cores.

16 The design has FMCRD spine motion control
17 rod drives, which have a smaller notch size, and the
18 locking piston CRD.

19 The attributes of the FMCRD, it has a fast
20 scram which is another asset that provides your
21 transient response with redundant insertion and
22 reduced fuel duty.

23 The power density of ESBWR is moderate at
24 about 54 kilowatts per liter. Within the fleet we see
25 and have experienced a range of power densities from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about 30 kilowatts per liter for the BWR2s to as high
2 as 60 kilowatts per liter or higher for BWR6s at power
3 uprated conditions.

4 So the power density of the ESBWR core is
5 moderate.

6 The --

7 MR. WALLIS: This is an average value
8 presumably?

9 MR. FAWCETT: Yes, it is.

10 MR. WALLIS: Are the peak values
11 comparable with existing -- they probably are, they
12 are probably within the same range?

13 MR. FAWCETT: Peaking, similar yes, to a
14 moderate to high power density plant.

15 Also peaking is really an output. We
16 design whatever peaking conforms to thermal limits.

17 MR. ARMIJO: That is a pretty picture
18 there. What are you trying to show us with that?

19 MR. FAWCETT: Oh, just the size of the
20 core.

21 MR. ARMIJO: Is there anything significant
22 about the colors?

23 MR. FAWCETT: Uh-uh.

24 MR. ARMIJO: Okay, the colors don't mean
25 anything?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter)

2 MR. FAWCETT: I think that -- it's hard
3 for me to see -- I think that maybe peak assembly
4 power where blue is higher than red, versus yellow,
5 which is the periphery which does give a sense for the
6 radial power distribution.

7 MR. SIEBER: Ones on the end are oval
8 cores, right? The flow rate is about 30 percent less?

9 MR. FAWCETT: Yes.

10 MR. SIEBER: And the number of assemblies
11 compared to BWR6 is like 850 to 1,100 roughly?

12 MR. FAWCETT: The ratio is proportional to
13 your reduction in core --

14 MR. SIEBER: Well, the core is about two
15 feet shorter I guess.

16 MR. FAWCETT: Yes.

17 MR. SIEBER: The way I seem to figure it
18 out.

19 CHAIRMAN CORRADINI: Will there be a
20 discussion about reducing the core height and
21 increasing the core radial size on the stability
22 later. And the effect, when we discuss stability, I'm
23 curious of its effect on stability.

24 MR. FAWCETT: There is a discussion of
25 stability planned.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Okay, then let's just
2 go ahead.

3 MR. FAWCETT: The N-lattice, again, the
4 assembly, it's after the fact that it's shorter, has
5 the same dimensions as the assembly for the existing
6 fleet.

7 The N-lattice, the primary aspect or
8 parameter of the N-lattice is a slightly larger bundle
9 pitch, so there is a little more space in between
10 assembly.

11 And in the hot operating condition, that
12 reduces the void coefficient slightly, which is good,
13 and in terms of reactivity characteristics, it
14 improves cold shutdown margins.

15 This is the same lattice again that the
16 AVBWR is comprised of. So the cold shutdown margin
17 benefit has been demonstrated with AVBWR.

18 Next slide, please.

19 This has a little more substantive
20 information in terms of power distribution. This is
21 beginning of cycle power distribution for the
22 equilibrium design.

23 For design certification we prepared an
24 equilibrium design as it is more representative of the
25 plant lifecycle.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We have also provided the staff with an
2 initial core design as well.

3 This illustrates the actual power shapes
4 that we observe are very consistent with that that we
5 observe with other BWR --

6 MR. WALLIS: No, in this picture,
7 presumably, red is hot?

8 MR. FAWCETT: Yes.

9 MR. WALLIS: Whereas in the previous
10 picture it was cold?

11 MR. FAWCETT: That is correct.

12 (Laughter)

13 MR. FAWCETT: So looking at those
14 distributions as is typical of assemblies that are
15 close to our design target, which is what the designer
16 is trying to achieve, is really a small population of
17 fuel.

18 And so those red assemblies would be
19 associated with assemblies having somewhere between 10
20 and 15 percent of thermal margin relative to the
21 operating limits. Likewise for LHGR.

22 Control rod patterns are the same kinds of
23 control rod patterns that we design for the operating
24 fleet.

25 MR. SIEBER: These power distributions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will change, significantly is not the right word but,
2 somewhat as burnup progresses because of the change in
3 reactivity and also because of the rod patterns?

4 MR. FAWCETT: Yes.

5 MR. SIEBER: This is beginning of life, I
6 take it?

7 MR. FAWCETT: Just an example of beginning
8 of life.

9 MR. SIEBER: If you were to look at it
10 through 10 slices in time, you would see variations
11 all of which are enveloped by your thermal hydraulic
12 calculations?

13 MR. FAWCETT: Yes, in fact you would see
14 the axial power shape move from the bottom as the core
15 is depleted, and in the power and the voids tend to
16 collapse, you would see the axial power shape start to
17 move up the core.

18 MR. SIEBER: That's because of the
19 gadolinium depletion power.

20 MR. FAWCETT: And the physical inventory
21 depletion at the bottom.

22 MR. SIEBER: But you never get to a top-
23 loaded core?

24 MR. FAWCETT: We concede, looking at the
25 top of the core with the peak, you know, and this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 nodalization as high as node 20. It's certainly --
2 it's an acceptable power shape.

3 So why do we need thermal limits?

4 And in terms of establishing thermal limits, we
5 certainly analyzed all the safe ones in the cycle that
6 exhibit all these different power shapes.

7 MR. SIEBER: And you are using this as an
8 example of an initial core but not a guarantee that an
9 initial core is going to react like that, other than
10 including the envelope that you designed, correct?

11 MR. FAWCETT: So this is the beginning of
12 cycle for an equilibrium cycle, yes. An initial cycle
13 would have somewhat different characteristics. You
14 know, again, really any power shape is acceptable, as
15 long as it meets thermal limits.

16 MR. SIEBER: Right.

17 MR. FAWCETT: Next slide, please.

18 Moving on to the thermal and hydraulic
19 design in Section 4.4, we describe the natural
20 circulation flow configuration, the power operating
21 map, and introducing feedwater temperature control.

22 We talk about the thermal and the
23 hydraulic design basis, ensuring that we have adequate
24 heat transfer, and that we comply with our specified
25 acceptable fuel design limits during normal operation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in AOOs.

2 And in terms of the methods and
3 evaluations focusing on compliance with critical power
4 limits, and core thermal hydraulics.

5 Again the ESBWR is very similar to the
6 existing plate.

7 MR. ABDEL-KHALIK: Is this where you are
8 going to talk about the applicability of the GEXL14
9 correlation?

10 MR. FAWCETT: Uh-huh, in two more slides.

11 MR. WALLIS: You are still using Finley
12 Dix (phonetic) after, whatever it is, 40 years or
13 something?

14 MR. FAWCETT: For the void correlation,
15 the Dix void correlation, yes.

16 MR. WALLIS: No attempt to upgrade it in
17 anyway? It just seems to keep working?

18 MR. FAWCETT: Uh-huh.

19 MR. WALLIS: Rather amazing.

20 MR. FAWCETT: It was well done.

21 MR. WALLIS: It has enough coefficients in
22 it, I think.

23 MR. FAWCETT: Next slide, please.

24 A boiling water reactor has good natural
25 circulation flow depending on the design, or let me

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 say that there is different capability depending on
2 the design.

3 The AVBWR has internal pumps, and a fair
4 amount of hydraulic resistance in the down-comer. The
5 BWR6 and other jet-pump plants have reduced hydraulic
6 resistance in the down-comer in higher natural
7 circulation flow.

8 The ESBWR has very little hydraulic
9 resistance in the down-comer. We had a reduced core
10 height, and an extended chimney that increases the
11 level height and driving head in the down-comer.

12 So the ESBWR has very good natural
13 circulation flow characteristics.

14 MR. WALLIS: So you have one curve on this
15 map. WE are used to seeing this map with all kinds of
16 things, regions and things, and here you have just --

17 MR. FAWCETT: Yes, it's natural
18 circulation flow is really -- the flow is a function
19 of the power system.

20 MR. WALLIS: This other map which is
21 referred to about a core power feedwater operating
22 map, are you going to show us that?

23 MR. SORENSON: We have a separate
24 presentation.

25 MR. WALLIS: You are going to get to that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at sometime?

2 MR. SORENSON: Yes.

3 MR. ABDEL-KHALIK: But compared to a rated
4 full power flow, this is natural circulation flow?

5 MR. FAWCETT: Uh-huh.

6 MR. ABDEL-KHALIK: So for the ESBWR mass
7 flux at full power is roughly half of the mass flux at
8 full power at BWR6 for example?

9 MR. FAWCETT: I would say that -- now
10 recognizing that the fleet with extended operating
11 domains has quite a range of core flows at rated
12 power. So if we compare say ESBWR at 100 percent
13 power to BWR6 at 100 percent power, we have a single
14 flow for ESBWR for either flow.

15 For BWR6 at 100 percent flow, ESBWR mass
16 flux is about 70 percent of the BWR6 at 100-100, 100
17 percent power, 100 percent flow.

18 MR. ABDEL-KHALIK: Point nine five times
19 ten to the sixth pounds per hour --

20 MR. FAWCETT: Yes.

21 MR. ABDEL-KHALIK: -- per square foot.

22 MR. FAWCETT: Right.

23 MR. ABDEL-KHALIK: Versus 1.8 times 10^6 .

24 MR. FAWCETT: No, actually in -- if -- I
25 should clarify, when we think of mass flux, or when we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 talk about mass flux, we tend to look at the active
2 in-channel mass flux, or four-circ plans like BWR6, at
3 100 percent flow.

4 The in-channel mass flux is approximately
5 one million pounds per hour per square foot. ESBWR is
6 approximately .6 and .7 depending on the assembly
7 power.

8 MR. SIEBER: The pressure drop is about
9 half, right?

10 MR. FAWCETT: Yes.

11 Next slide, please.

12 So here is where we talk about GEXL.
13 We've applied again GEXL14 is a boiling length
14 critical quality correlation that's been developed in
15 GEXL14, the GE14 specific correlation was developed on
16 an extensive database from several different
17 facilities to describe the onset of boiling transition
18 for GE14.

19 And we applied that GE14E with a shorter
20 overall length.

21 As part of the DC review we developed a
22 conservative set of correlation statistics for GEXL14
23 and applying it to GE14E. That conservatism manifests
24 itself in the operating limit MCPR. It's somewhat
25 higher by virtue of these conservative correlation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 statistics.

2 In being responsive to the staff, we
3 conducted a fullscale critical power test of GE14E.
4 What I'll say is a complete critical power and
5 pressure drop test to confirm the adequacy of GEXL14.

6 We completed that in November.

7 MR. ABDEL-KHALIK: Where was that done?

8 MR. FAWCETT: Stern Labs. And our --

9 MR. ABDEL-KHALIK: Will we have access to
10 that data?

11 MR. FAWCETT: You will. We'll be
12 providing a report on that. We are in the process of
13 completing our work on that analysis and the final
14 report that we will provide to the staff.

15 MR. ABDEL-KHALIK: When you talk about
16 conservative -- go ahead.

17 MR. SIEBER: I understand that's sending
18 two by diverse means, so that I get one.

19 MR. ABDEL-KHALIK: When you talk about
20 conservative statistics, I assume this is the way you
21 were applying of the correlation by assuming no
22 heating beyond the length of the GE14E.

23 And yet even with doing that, it seems
24 like the calculated CPR is higher than the measured
25 CPR as indicated in your topical report.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So how can that be conservative?

2 MR. FAWCETT: And it's a confusing thing
3 to understand why it's conservative. You are
4 absolutely right in that we declared GEXL14
5 nonconservative by an amount that we have established
6 throughout the DCD review. And so we say, GEXL14 is
7 a few percentage points nonconservative.

8 Now our process for establishing operating
9 limits is always to address any GEXL nonconservative
10 by increasing the operating limit. So that is how the
11 conservatism is propagated through the design.

12 So we have artificially declared GEXL
13 nonconservative.

14 MR. ABDEL-KHALIK: I don't know, maybe you
15 are not prepared to discuss the results of this
16 fullscale test for the GE14E, but how does that
17 compare to the level of nonsconservatism, the CPR
18 prediction of GEXL14 for the GE14E as explained in the
19 topical report?

20 MR. FAWCETT: And certainly we will
21 provide the detailed results to the staff. But
22 qualitatively, the test data shows that GEXL14 is a
23 very good prediction of critical power for GE14E, just
24 like it is for standard GE14, and with no significant
25 trends bias.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So that testing confirmed that GEXL14
2 really is just as good a best estimate critical power
3 predictor for GE14E as it is for GE14.

4 MR. ABDEL-KHALIK: To be seen?

5 MR. FAWCETT: To be seen.

6 MR. ABDEL-KHALIK: It implied that they
7 sort of declared GEXL14 to be nonconservative by X
8 percent because of the conservative way in which it
9 was applied.

10 MR. FAWCETT: Right.

11 MR. ABDEL-KHALIK: Can you sort of say
12 with confidence that GEXL14 is conservative?

13 MR. FAWCETT: GEXL and our overall
14 critical power methodology is -- or let me say our
15 licensing basis is conservative. GEXL is a best
16 estimate prediction of critical power.

17 The uncertainty in the prediction of
18 critical power is addressed in the formation of the
19 operating limit, or in the existing fleet, the safety
20 limit. So that is how uncertainties in the prediction
21 of critical power are addressed.

22 So GEXL is a best estimate prediction of
23 critical power. Uncertainties are addressed in the
24 operating limit.

25 Effectively we've increased the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conservativisms here in the operating limit by assigning
2 this penalty to the GEXL.

3 MR. ABDEL-KHALIK: But just looking at the
4 average one really can't tell whether there is a
5 consistent bias?

6 MR. FAWCETT: Right, but in looking at the
7 data GEXL is not showing any trends bias, or GE14E,
8 and that will be illustrated in the report.

9 MR. ABDEL-KHALIK: I guess we will just
10 have to wait and see. Thank you.

11 MR. SORENSON: That is the last slide we
12 have in Section 4.4.

13 MR. ARMIJO: Just one slide there, the one
14 showing the -- yeah, that curve of the ESBWR average
15 power per bundle versus average flow per bundle
16 curving back on itself, you know, does that imply you
17 could have for the same flow two different powers,
18 operating power per bundle?

19 MR. FAWCETT: Uh-huh.

20 MR. ARMIJO: Is that a problem? I don't
21 understand it, I guess that's what I'm telling you.

22 MR. FAWCETT: So I think I will ask Mr.
23 Wayne Marquino to perhaps --

24 MR. WALLIS: Isn't there something there
25 about the control rod position? It's not just one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 curve?

2 MR. MARQUINO: That's right.

3 MR. WALLIS: It's along the curve.

4 MR. MARQUINO: This is Wayne Marquino,
5 GEH, and at different control rod positions we can
6 have different power levels with the same flow. That
7 curve is showing how power increases as we pull
8 control rods out.

9 MR. MAYNARD: The key is that the power is
10 setting the flow, not the other way around. So for
11 any given power you can only have one flow. You are
12 not setting a flow and see what the power comes out to
13 be; you are setting a power and then you are going to
14 --

15 MR. WALLIS: In the normal map for BWR you
16 would have rod lines. But you don't --

17 MR. MARQUINO: That's right.

18 MR. DERWER: Okay, thank you.

19 My name Jerry Derwer with with GEH. The
20 lead in the nuclear island systems and components
21 group.

22 I'll be covering 4.5 and 4.6. 4.5 deals
23 with reactor materials, basically there are two
24 sections within -- or parts to Section 4.5. One deals
25 with control rod drive materials; the second deals

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with the reactor internals materials.

2 With respect to the control rod driver
3 materials, basically the fine motion control rod drive
4 is essentially the same as the ABWR design that has
5 been previously certified.

6 MR. ABDEL-KHALIK: Excuse me if you will,
7 but when are you going to talk about stability?

8 MS. CUBBAGE: They are going to have a
9 separate panel. Excuse me, this is Amy Cubbage. They
10 are going to do it right after Mr. Derwer.

11 MR. ABDEL-KHALIK: Thank you.

12 MR. DERWER: Two major differences in the
13 design are the change from induction motors -- or to
14 induction motors from stepper motors.

15 Basically the ABWR has been in operation
16 in Japan with the stepper motors for over 10 years
17 with successful operation. The induction motors have
18 been incorporated in their newer designs, and there is
19 one plant with operational experience over two years
20 at this point with the induction loaders.

21 And they have also incorporated a seal-less
22 design to minimize leakage and maintenance with -- for
23 the drives themselves. Basically the drives also are
24 two-foot shorter because of the fuel geometry. S o
25 those are the main differences. As far as materials

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are concerned, the drive is predominantly stainless
2 steel material. In a couple of areas we used XM19
3 where we needed higher strength or -- and corrosion
4 resistance.

5 But fundamentally the drive materials are
6 pretty much the same as we've been using in the past.

7 The next drive shows the configuration of
8 the drive itself. I'll just point out a couple of
9 features.

10 Basically we have the traditional CRD
11 housing. We have a middle flange and a lower flange.

12 These are all the pressure boundary
13 materials, and we provide those in accordance with the
14 ASME code.

15 Starting from the bottom we have the motor
16 which is different from traditional hydraulic designs.
17 The motor is what drives the ball screw which will
18 advance the drive into the core, or withdraw it as
19 needed.

20 Then we have insert line. This is for the
21 scram function. So for normal operation we'd have the
22 motor-driven drive, but in a scram condition we have
23 the hydraulic design which -- the hydraulic control
24 unit drives a piston within the drive to insert the
25 blade rapidly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We only have insert lines as opposed to
2 prior designs which had the withdrawal lines also.
3 And we don't have the discharge line anymore.

4 MR. WALLIS: So when the hydraulic system
5 scrams, what happens to the motor drive? Does it just
6 rotate or clutch out or what happens to it?

7 MR. DERWER: Yeah, it clutches out
8 allowing the drive to be inserted.

9 And we have the traditional ball check
10 valve here. If we had a break in the line the insert
11 line, then this would be blocked by the check valve.

12 Let's see, we have the traditional bayonet
13 lock at the top. This is the same interface that we
14 had between the blade and the drive.

15 And we have as with other drives we have
16 a position indicator probe which gives us an accurate
17 idea of where the blade is. And then we have a
18 separation probe which tells us whether we separated
19 between the drive and the cover.

20 MR. WALLIS: The whole thing hangs on the
21 valve, does it? The whole thing is supported by that
22 valve, or is there some other support?

23 MR. DERWER: Well, the housing -- the load
24 path for the fuel assembly and so forth is down
25 through the control rod guide tube.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Which is also fixed?

2 MR. DERWER: Yes, and this is the main
3 welded structure within the assembly. It transfers
4 the load into the vessel bottom head.

5 We have a locking feature in the drive
6 such that we don't need the pull out protection in the
7 drive, which is a difference from the hydraulic type
8 designs.

9 MR. BLEY: What keeps this drive in
10 position?

11 MR. DERWER: Well, basically, we have a
12 brake assembly that once it's moved it holds its
13 position.

14 MR. BLEY: What kind of assembly is that?
15 The motor has nothing to do with that, right?

16 MR. DERWER: The motor is powered to turn
17 it. And if the power is stopped, then there is a
18 break assembly in here that you know it's prevention
19 from dropping of the blade and moving of the blade
20 after the motor has moved it.

21 MR. BLEY: That is something that releases
22 when the motor is driving and grips otherwise?

23 MR. DERWER: Yes, there is magnetic
24 indicators in here that operate it.

25 CHAIRMAN CORRADINI: is there any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 difference between this drive and the ABWR line motion
2 control rods?

3 MR. DERWER: Fundamentally all these
4 components are the same basically. It's just a
5 difference in a motor down here that is really
6 different.

7 CHAIRMAN CORRADINI: Which you are
8 changing into some ABWRs is what I remember you
9 saying?

10 MR. DERWER: Yes, they have already
11 changed to the induction motor.

12 Basically it's just a cost factor that
13 they went to the induction motors, and easier to
14 control.

15 MR. ARMIJO: So mechanically, materials,
16 everything is the same --

17 MR. DERWER: Yes.

18 MR. ARMIJO: -- except for the induction
19 motors?

20 MR. DERWER: That's exactly right.

21 MR. ARMIJO: Okay.

22 MR. DERWER: I think that is all I wanted
23 to talk about.

24 MR. BLEY: I'm sorry to go back to this.

25 MR. DERWER: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BLEY: When you change from a stepper
2 motor, was the stepper motor involved in holding the
3 rod in position? Or was that still the same brake
4 arrangement?

5 MR. DERWER: Oh, the same brake
6 arrangement. All that is the same.

7 Moving forward, including on to the
8 reactor materials, reactor internals are predominantly
9 stainless steel materials which we control the carbon
10 content.

11 So as I explained in previous sessions we
12 control the materials to be resistant to intragranular
13 stress corrosion cracking, and then we control the
14 impurities and surface things that can occur with
15 materials.

16 And then we -- additionally we control
17 cwork and -- to avoid those kind of issues with the
18 stainless materials.

19 In some cases we use a modified Alloy 600
20 material. We use code case and 580-1, which allows
21 the niobium content to increase, and it stabilizes the
22 feed canal to be resistant to intragranular stress
23 corrosion cracking. A

24 MR. SHACK: What is the carbon limit on
25 that material?

1 MR. DERWER: Well, it's that ratio between
2 niobium and carbon that is important, you have to
3 establish a certain ratio there. So it can vary, but
4 there are ranges that it has to be within.

5 MR. ARMIJO: is that defined in the code
6 case? The range?

7 MR. DERWER: Yes, it is.

8 MR. SHACK: But if you just depend on that
9 ratio, don't you end up with a knife line attack
10 problem you had with the 347?

11 MR. DERWER: Brian, can you? We have
12 Brian Frew here who is our materials expert. He'd be
13 in a better position to answer that.

14 MR. FREW: Brian Frew from GEH. No, the -
15 - we haven't had issues with knife line attack in this
16 material. I mean you have to control that ratio.
17 There is sufficient chrome to avoid that problem.

18 MR. SHACK: What is the -- do you have a
19 range on the carbon? What is the upper limit on the
20 carbon?

21 MR. FREW: The upper limit is -- I'd have
22 to look at the code case to tell you the exact number.
23 But with that ratio the carbon content tends to be
24 lower.

25 MR. SHACK: You are following the Japanese

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 experience?

2 MR. FREW: Yes.

3 MR. SHACK: Their choice of these
4 materials?

5 MR. FREW: Yes.

6 MR. SHACK: And this has been used in all
7 the ABWRs?

8 MR. FREW: Yes. Yeah, it's been --

9 MR. SHACK: And there is a statement that
10 says your stresses everywhere are below the threshold
11 for intragranular IASCC. Does that mean you don't
12 have any welds, or all the welds are stress-relieved?

13 MR. DERWER: I wouldn't say that as a
14 positive statement.

15 MR. SHACK: I wouldn't think you would,
16 no.

17 MR. DERWER: We are working on things like
18 that, recognizing you know the shroud is a large
19 structure, and when we fabricate a structure we would
20 to solution heat treat it, but we are not there yet.
21 We are exploring those issues at the moment.

22 MR. SHACK: But this is a bolted shroud as
23 I understand, so it could be replaced if it had to be?

24 MR. DERWER: Yes. That's correct.

25 Looking at the components that use the
Alloy 600 materials, the shroud supports, which in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this case are brackets for the lower vessel. I'll
2 show you on the next slide.

3 Then we basically, the CRD penetration is
4 the typical penetration which provides us this
5 transition between the low alloy steel and the
6 stainless housing.

7 The chimney head bolts in prior BWRs, the
8 shroud head bolts, have the same basic design where we
9 use the Inconel material for thermal expansion
10 differential to apply the load actually in the bolt
11 when it heats up.

12 Then we have in-core guide tube
13 restraints. This is a lattice of materials that
14 stabilize the cores in the lower plenum area, and
15 again, we use this because of the thermal expansion
16 characteristics.

17 Then we use it in the guide rods. Guide
18 rods are just for guiding in components like the dryer
19 and the separator when we do refueling, so they don't
20 -- aren't in actual operation when the plant is
21 operating. They just -- they are sitting in there.

22 We do use castings. Basically the casting
23 applications are the same as we've always used for the
24 orifice fuel supports, the feedwater end brackets, and
25 the veins in the separator itself where it swirls the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 steam flow.

2 We use XM-19 for all bolting in the
3 reactor. In the past we've used stainless steel
4 without any real problems, but we feel that the XM-19
5 provides more corrosion resistance and higher
6 strength, so it's an improved material, and that's
7 what's been used on the BWR6, or the ABWRs, and we
8 haven't had any issues with that.

9 The X-750 is limited strictly to a
10 retainer screen in the shroud -- in the chimney head
11 assembly. It's -- we have a retainer that holds the
12 nut in place, and it only gets exercised when we are
13 trying to unbolt or bolt the chimney head. So that is
14 a very limited application, and it's not really
15 stressed in operation.

16 Going to the next slide --

17 MR. ARMIJO: Before you leave that, Jerry,
18 in the SER, in the DCD, the staff from GEH had some
19 exchanges related to the use of 304 and 316 stainless
20 steels, in which I believe GE made a commitment, or it
21 was your intent to limit the carbon content in those
22 alloys to effectively -- the same levels as the L-
23 grades. 304 would have an O2-carbon maximum of seven
24 three sixteen, the same as your L-grades. And that is
25 nice, but the implication was that you were using, or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you stated you were using these steels because they
2 were higher strength than the L-grades. And that
3 confused me.

4 Why -- what would you add to 304 or 316 to
5 get higher strength than a 304L or a 316L?

6 MR. DERWER: Well, yes, material suppliers
7 use a nitrogen addition to help.

8 MR. SHACK: So you'd use a nitrogen
9 strengthener?

10 MR. DERWER: Right.

11 MR. SHACK: Okay, so you'd get that, and
12 you'd increase the yield strength?

13 MR. DERWER: Exactly, and so we want them
14 -- the improved mechanical characteristics, properties
15 --

16 MR. SHACK: Without the sensitization
17 risk?

18 MR. DERWER: Right, and with still the low
19 carbon issues.

20 MR. ARMIJO: Have you tested these
21 nitrogen strengthened 300 series steels for IGSEC
22 resistance in high temperature oxygenated water tests
23 or anything?

24 MR. DERWER: Yes, they were tested. We
25 are performing on these.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ARMIJO: Okay, so they have been
2 tested and found to be acceptable?

3 MR. DERWER: Yes.

4 MR. SHACK: You said you were going to
5 give us detailed specifications once you had them. I
6 assume you are just pushing the nitrogen up to the 304
7 limit, you are not actually making this an LN series
8 steel?

9 MR. DERWER: Right.

10 MR. SHACK: So you just go up to that
11 limit. But the Japanese actually use the LN grades,
12 right? They take the nitrogen up to .12 or .14?

13 MR. DERWER: That could be; I'm not
14 familiar with what they have been doing.

15 MR. SHACK: But you are just going to push
16 it up so it stays at 304, but you are just taking the
17 --

18 (Telephonic interference)

19 MR. SHACK: -- as you do with the 316
20 nuclear -- the nuclear grade?

21 MR. DERWER: That's correct.

22 Going to the next slide, I was just going
23 to -- this is a small picture of the reactor, but I
24 will point out where we have been using these
25 materials. It's here at the attachment to the shroud,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these are brackets in the lower bottom head area.

2 In the stuff tubes as I've explained
3 before, the major change is the addition of the
4 chimney and partitions within the reactor. And these
5 are stainless steel materials.

6 And the other change is, the routing of
7 the standby liquid control line is different. We
8 bring it in from the upper part of the vessel now, and
9 bring it in, and we penetrate through the shroud so
10 that the injection of the sodium pentaborate solution
11 can be injected directly into the core region itself.

12 MR. SHACK: This is still the same -- so
13 you are going to have like the nickel weld pads, where
14 you make the attachment welds for things and the
15 internals and stuff as you do in the conventional BWR?

16 MR. DERWER: Yes, you are talking about
17 brackets?

18 MR. SHACK: Yes.

19 MR. DERWER: Well, typically, in the upper
20 part of the vessel we have stainless steel cladding,
21 and the brackets, you know, are welded onto structural
22 material as a base for those brackets.

23 When we get into the bottom head where we
24 have mainly Inconel components there, or welded on,
25 we've changed the cladding material to Inconel for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bottom head region only.

2 MR. SHACK: So the whole bottom head is
3 clad with an Inconel weld?

4 MR. DERWER: Yes, it is. So for
5 components like the scrub tubes and in-core housings,
6 and the shroud support, all those Inconel welds are
7 made to an Inconel clad structural material base.
8 Okay?

9 MR. ABDEL-KHALIK: What determines the
10 size of the cell in the chimney?

11 MR. DERWER: Well, that is -- basically
12 has 16 bundles within the cell itself. So it
13 encompasses four units that we typically had in --
14 associated with the control rod blades.

15 So we have four blades, and they are
16 associated with four fuel assemblies with -- in each
17 of those.

18 Wayne Marquino would be best to address
19 that issue.

20 MR. MARQUINO: We also considered the
21 range of data where we had the high diameter of our
22 chimney characterized. Initially we had I think it
23 was Wilson and EBWR reactor measurements, set the size
24 of the chimney partition.

25 And eventually we had the Ontario

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hydrotest specifically for the ESBWR.

2 MR. WALLIS: Why do you have partitions at
3 all?

4 MR. DERWER: Well, that is important to
5 make sure we straighten the steam flow up up to the
6 separator area?

7 MR. WALLIS: You don't want to have some
8 sort of swirling going on in there?

9 MR. DERWER: Exactly, we get some
10 vortexing otherwise that --

11 MR. WALLIS: It seems to me that you have
12 designed them to be as big as you have tested
13 essentially.

14 MR. SHACK: Again, your original design
15 was change three, wasn't it?

16 MR. MARQUINO: I think the very first
17 ESBWR design did not have them, but before -- I think
18 before we submitted anything we put partitions in.

19 CHAIRMAN CORRADINI: So you were going to
20 finish the statement when you said you had compromised
21 what with the vortexing, with the swirling?

22 MR. DERWER: Oh, yeah, if we didn't have
23 the partitions, you'd get the vortexing and steam, you
24 know, vortexing within the core. And so you'd get a
25 very unequal steam flow into the separators.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SIEBER: I think you would get
2 chugging.

3 CHAIRMAN CORRADINI: I was going to say,
4 you get a washing machine. You've got -- you could
5 have enormous wiggles in the system by having an
6 enormous washing machine.

7 But what I am curious about is, the four
8 by four sites, if this is the wrong place to discuss
9 it, that's fine, but eventually I'd like to discuss
10 this question, because I'm kind of curious, was it
11 picked or by the experiments, was four by four look
12 alike some sort of optimum because of some sort of
13 characteristics?

14 MR. MARQUINO: This is Wayne Marquino. It
15 was picked based on Dodoward (phonetic) and the total
16 experience at the time we had to set that design. And
17 there was the ESBWR reactor did not have a chimney.
18 It had a pretty big hydraulic diameter.

19 When we saw some -- it didn't have adverse
20 performance, but we saw some recirculation in there,
21 and basically we don't want to use a CF - you know, a
22 very complex CFD code to analyze the flow there, so to
23 keep it within the applicability range, or a TRACG
24 code, we set the chimney size, the partition side.

25 MR. WALLIS: So you wanted it to be one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 dimensional?

2 MR. MARQUINO: No. No.

3 CHAIRMAN CORRADINI: I know what you said,
4 but what you are telling me, I changed the design so
5 I could analyze it.

6 MR. MARQUINO: That's right. That helped.

7

8 MR. WALLIS: You want it to be one
9 dimensional, essentially, is that it?

10 MR. MARQUINO: Yes.

11 MR. ARMIJO: Just a quick question. Now
12 there is going to be a lot of welds in that chimney.
13 Is that correct, that these are going to be all welded
14 construction, all the lengths up and down those --

15 MR. DERWER: Are you talking about the
16 partitions specifically?

17 MR. ARMIJO: Yes.

18 MR. DERWER: There will be a considerable
19 number of welds.

20 MR. ARMIJO: Are these like full length?

21

22 MR. DERWER: Yes, they are. Our idea is
23 to use a cruciform for the intersections where the
24 cells are, and then we would have plates that are
25 welded full length, full penetration, and with a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cruciform design it allows us to take the weld away
2 from the discontinuity of the intersections. So --

3 MR. SIEBER: So that's sort of like an
4 extruded or --

5 MR. DERWER: An extruded -- it's like in
6 the blades where we have the tie rods.

7 MR. ARMIJO: Okay, and that material will
8 be the same as the shroud, it's not an L-grade?

9 MR. DERWER: Oh, it'll be stainless.

10 MR. ARMIJO: Stainless steel, very low
11 carbon.

12 MR. DERWER: Low carbon, and we have a
13 program where we are going to develop a mock up and
14 use the actual welding parameters, and then our GRC is
15 going to evaluate it for stress corrosion.

16 MR. WALLIS: Is there a follow up with
17 flow induced vibration in the chimney?

18 MR. DERWER: No, we actually had Hitachi
19 do a flow test for us.

20 MR. WALLIS: With a full sized chimney
21 matrix or just one cell?

22 MR. DERWER: Well, we did one cell. We
23 started out with a 1/12th scale. We went to a 1/16th,
24 one sixth, and then they openly did a full scale with
25 a single cell, and when we did that we saw that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 vibration characteristics improved for the full one.
2 And that is why we ultimately did that.

3 CHAIRMAN CORRADINI: WE may want to move
4 on, because we are going to hit them with the
5 stability.

6 MR. ABDEL-KHALIK: Just one question which
7 is related to this, which is again the size of the
8 cells, the projection of what you call super cell is
9 four by four, 16 bundles, is that correct?

10 MR. DERWER: Yes.

11 MR. ABDEL-KHALIK: So in either a fresh or
12 an equilibrium core, what is the largest radial power
13 gradient between a bundle and a bundle that is four
14 rows away?

15 MR. DERWER: I don't think I can quote a
16 number off the top of my head.

17 MR. ABDEL-KHALIK: I mean looking at the
18 power distribution maps, even though they are sort of
19 qualitative in nature, it is possible to have one of
20 these super cells where you have a very large power
21 gradient between the bundle that is on one edge of
22 this cell, and another bundle that is four rows away.

23 So the issue of one dimensionality of the
24 flow within the chimney can be sort of questionable in
25 situations of this sort.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. FAWCETT: I'd like to turn to Mr.
2 Marquino.

3 MR. MARQUINO: In terms of numbers we will
4 have to get back to you, but let me clarify something.

5 We have maybe a 2-1/2 dimensional analysis
6 of the chimney in our TRAK code. We model different
7 power bundles within a chimney partition. We have the
8 ability to do that, and we have the ability to monitor
9 different power partitions.

10 The biggest gradients are at the edge of
11 the core. You can kind of get that from the colors on
12 his map.

13 MR. ABDEL-KHALIK: But we would like to
14 find out if you don't mind, if you have that
15 information.

16 MR. MARQUINO: Okay, we can get you some
17 information on that.

18 CHAIRMAN CORRADINI: Please proceed.

19 MR. DERWER: Okay, I believe I have pretty
20 well covered most of what I wanted to on the figures.

21 Okay, the next is the 4.6 which is the
22 basically the system for reactivity control of -- this
23 is the control rod drive system.

24 This system is essentially the same as the
25 provision control rod drive system that you have seen

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the past, except that we've added one new feature,
2 and that is the high pressure make-up flow. This is
3 ju9st a belt and suspenders thing that adds a feature,
4 you know, if it's needed in an accident condition.

5 The three major components are the prime
6 motion control rod drives. There are 269. The
7 hydraulic control units, which are 135. So there are
8 two HCUs that support two drives.

9 And then we have the hydraulic subsystem
10 which is the system that provides flow to the system.

11 MR. WALLIS: How much water do you bring
12 in through these control rods? What does it
13 correspond to in terms of megawatts and boil off? Can
14 it supply the boil off after two hours of decay heat
15 or something?

16 MR. DERWER: Are you talking about the
17 amount of fluid that is injected?

18 MR. WALLIS: Well, you are introducing
19 here a sort of a pumped versus cooling system.

20 MR. MARQUINO: But you need a small
21 quantity of water, compared to the core volume.

22 MR. DERWER: It's a very small volume.

23 MR. WALLIS: Is it really?

24 MR. MARQUINO: It does have the capability
25 right after scram to go into high flow mode, and that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 makes up for boil off decay heat.

2 MR. WALLIS: It could cool the core?

3 MR. MARQUINO: Yes, so it's diverse from
4 the IC function.

5 MR. WALLIS: So if quality is turned off -

6 -

7 (Laughter)

8 MR. DERWER: So going to the next slide,
9 so the FMCRDs is a -- has been mentioned before, has
10 the electric motors to drive it during normal
11 operation, the hydraulic function during normal
12 conditions.

13 The HCUs as always have been the source of
14 hydraulic power for scram, and those fundamentally are
15 the same. As a matter of fact the HCUs for ABWR where
16 we used directly for ESBWR, and the hydraulic system
17 basically provides demin water, and regulates and
18 distributes it to the HCUs and the perch (phonetic)
19 flow within the drives. The perch flow helps keep the
20 drives clean, and does keep them cooler with the perch
21 flow.

22 MR. ABDEL-KHALIK: What is the total worth
23 of all the control rods in a cold clean core?

24 MR. FAWCETT: The cold rod worth?

25 MR. ABDEL-KHALIK: Yes, total.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. FAWCETT: In other words cold all rods
2 out to cold, all rods in?

3 MR. ABDEL-KHALIK: Correct.

4 MR. FAWCETT: I believe it's around 15
5 percent, but we would need to confirm that.

6 MR. ABDEL-KHALIK: Okay, thank you.

7 MR. DERWER: And moving forward, this is
8 a schematic of the CRD system. As I mentioned it is
9 provisional with prior systems. These are the FMCRDs
10 on this side. This box pertains to the hydraulic
11 control units. The new feature is the -- coming off
12 the pumps is, we have these valves that are normally
13 closed. This is the flow path --

14 (Telephonic interference)

15 MR. DERWER: -- flow into the reactor
16 water cleanup, and ultimately into the feedwater
17 system which would go back into the reactor vessel
18 itself.

19 In this system we draw out water from the
20 condensate storage tanks which is typical, and so
21 there's nothing really new about the system.

22 Okay, if you want to cover that, John?

23 MR. SORENSON: Well, I think the bottom
24 line is, we continue to work with NRC staff to resolve
25 and adjust open items.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ARMIJO: There are a lot of open
2 items. There's 31 in chapter four that I know of.
3 Maybe I got to ask that staff at some point.

4 MR. SHACK: Let's do that after break.

5 CHAIRMAN CORRADINI: Well, they'll have an
6 answer.

7 MS. CUBBAGE: And GE needs to switch teams
8 to continue with Chapter 4.

9 MR. ARMIJO: We still have one more
10 presentation for Chapter 4, so I want to move on to
11 it.

12 Any other questions for this group?

13 Okay, thank you very much. You are going
14 to have another member join you?

15 MR. SORENSON: We are ready to begin.

16 Let me introduce Dr. Jun Yang, who will
17 provide a discussion of the ESBWR stability
18 evaluations.

19 MR. YANG: Good morning, everyone. My
20 name is Jun Yang, and I am here to share with you the
21 evaluation results for ESBWR stability, including
22 recent events since our last meeting.

23 I'm going to start out today by specifying
24 the licensing requirements that ESBWR needs to
25 satisfy.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So the conditions that need to be examined
2 for stability through normal operation and also AOOs
3 and the JDC-12 requires that power oscillation is
4 either not possible or can be detected and suppressed.

5 Next slide, please.

6 And based on the stability results we have
7 seen so far, we can safely conclude that ESBWR are
8 stable during normal operations, and AOOs, and the
9 growth of large power oscillations is not a credible
10 event.

11 In addition GEH will implement a detect
12 and suppress solution to further protect --

13 MR. WALLIS: This isn't just based on
14 analysis, this is also based on comparison with
15 experiment, isn't it, this conclusion, first
16 conclusion?

17 MR. YANG: It is mainly based on the TRACG
18 analysis in terms of decay ratio.

19 MR. WALLIS: There had to be experiments
20 too. Maybe it's a different forum where we
21 investigate these.

22 MR. MARQUINO: There has been experiments.
23 We saw the Advisory Committee's view about two years
24 ago when we submitted our TRACG method for analyzing
25 ESBWR stability.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: I remember that. I'm just
2 thinking about what would they call it, the
3 experiments in Holland, the Genesis experiments. Have
4 you come to terms with those yet in TRACG? Because
5 they had difficulty modeling -- they had a Freon loop
6 that modeled the whole system and supposedly scaled
7 properly. They had some trouble modeling it
8 analytically.

9 Have you come to terms with that yet?
10 Maybe we should investigate this in a subcommittee or
11 some other subcommittee.

12 MR. MARQUINO: We didn't have any open
13 items.

14 MR. WALLIS: Well, I wondered about that.
15 Because they had real trouble -- this was presented in
16 Pittsburgh in the fall, and maybe you should look at
17 the Genesis experiments, because we are going to ask
18 about them again.

19 MR. MARQUINO: I think this is not exactly
20 the forum, but I think we have to talk about them.

21 MR. ABDEL-KHALIK: The DCD says that, in
22 Section 4(d)(1)(5), that therefore the stability
23 during AOOs is assured by the scram protection. And
24 in there you talk about a level -- low level trip, and
25 the high powered trip.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: There is a scram protection
2 on Level 3.

3 MR. ABDEL-KHALIK: Right. Now how does
4 that protect against regional instabilities during
5 AOOs?

6 MR. YANG: So basically all the density
7 being reduced the stability will be protected by
8 limiting the power level. So scram protection will
9 limit the power level.

10 MR. ABDEL-KHALIK: How does the high flux
11 trip protect against regional instability?

12 MR. YANG: Once you do the high level
13 height, similar to the high-power scram established,
14 and the power, the low ratio will decrease. So based
15 on the TRACG results the decay ratio will improve,
16 give you a lot of margin, so that the regional decay
17 ratio, regional performance, is protected.

18 And I will get to that in later slides.

19 MR. MARQUINO: I think your concern is
20 that if you are in a regional oscillation, the sides
21 of the core are oscillating, the APRM won't have a
22 good indication of that, right?

23 MR. ABDEL-KHALIK: Correct.

24 MR. MARQUINO: But what we're crediting is
25 the average power of the core which does increase in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the loss of feedwater heating event.

2 We are not saying that that is going to
3 detect the oscillations, but it's going to detect the
4 power increasing as the feedwater temperature drops.

5 MR. ABDEL-KHALIK: I guess you will talk
6 about that in more detail.

7 MR. WALLIS: So these oscillations never
8 occur?

9 MR. MARQUINO: Right.

10 MR. WALLIS: They never occur unless they
11 are really -- I guess with the MELLLA+ we go into some
12 discussion about, couldn't use the DIVOM curves
13 because of single channel oscillations. You ever get
14 into that? How do you know, because TRAC says so?

15 MR. MARQUINO: We will see numbers in a
16 minute.

17 MR. ABDEL-KHALIK: Back to the point you
18 are making, the high flux drift, I guess you're saying
19 it protects against overall increase in power level?

20 MR. MARQUINO: Right.

21 MR. ABDEL-KHALIK: During a loss of
22 feedwater heating event?

23 MR. MARQUINO: Right.

24 MR. ABDEL-KHALIK: Now are you sure that
25 you will actually hit that point sooner than the point

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 where these regional oscillations coupled on top of
2 the overall power increase would put you at a point
3 where you will exceed your CPR limits?

4 MR. MARQUINO: Yes, because we analyze
5 with the -- in order to get the regional oscillations,
6 the power has to be above that trip. So that is what
7 Dr. Yang is demonstrating with his calculations, that
8 from a loss of feedwater temperature, or a loss of
9 feedwater, or just normal operation, where enveloped
10 by a certain power level, and at that power level the
11 core is stable.

12 MR. YANG: There is less stress in AOO
13 stabilities.

14 Next slide, please.

15 These are all the major possible
16 conditions that can lead to instability at least here.
17 And all this scenarios have been analyzed by using
18 TRACG code, and the methodologies using stability LTR,
19 and has been approved by NRC.

20 So basically for density being induced
21 instability which is also called Type II instability,
22 there are three modes to consider.

23 The single channel mode is when the flow
24 of a single channel oscillate with small power
25 oscillation. And the core alignment mode is when the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power in the flow of all core channel, oscillating in
2 phase; while the regional model is when half the core
3 oscillates out of phase with the other half.

4 And also several other kind of instability
5 -- mode of instability are considered during the plant
6 start-up including the condensation in the region
7 instability, and also the flashing the void induced
8 LOOP instability also considered during plant startup.

9 Also the xenon transient effect on the
10 power distribution is also considered using TRACG
11 methodology for simulating the plant startup.

12 MR. ABDEL-KHALIK: Do you analyze
13 situations where some of these instability modes are
14 coupled, where you have single channel instabilities
15 on top of regional instabilities?

16 MR. YANG: I think, in a sense, there are
17 a couple actually. Because the regional instability,
18 there is a limiting bundle we analyze. So it is the
19 single channel we are considering in the original
20 model.

21 We see like the limiting bundle based on
22 the power peaking and also the harmonic peaking.

23 MR. ABDEL-KHALIK: So you don't ever
24 foresee a situation where the core is going like this,
25 and within that region a channel is going like this at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the same time?

2 MR. YANG: Right, we are monitoring the
3 limiting channel during the regional model also. So
4 inside there are a couple, we evaluate the performance
5 based on a single channel performance.

6 MR. WALLIS: I think when you do that the
7 limiting bundle has the same frequency as the regional
8 mode; it's not doing its own thing on top of that.

9 MR. YANG: That is covered by the
10 hydraulic single channel mode.

11 So basically for the single channel mode
12 it's purely concentrated on the hydraulic performance
13 of single channel. And I will get to that, showing
14 you the decay ratio value, you can see the margin.

15 Next slide, please.

16 This slide shows the decay ratio result
17 for the normal operating conditions, both the
18 equilibrium for any initial core. Since the last ACR
19 meeting, GEH has performed a series of additional
20 analysis for its colder level sensitivity, and it
21 determined that the peak hot access cycle point is the
22 limiting state.

23 MR. WALLIS: So you did use a Courant
24 number of one? You put enough nodes in that chimney?
25 Because this was a question we had before?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. YANG: Right, we addressed that by
2 using fine nodalization model.

3 MR. WALLIS: So you didn't artificially
4 damp the void perturbation?

5 MR. YANG: Right, and also in TRACG --

6 MR. WALLIS: I think in some other forum
7 we probably should look at the details of that, too,
8 again, visit that again.

9 MR. MARQUINO: Okay, I want to clarify
10 what Jake is discussing is the channel nodalization.
11 And we answered a lot of your questions and did
12 additional investigations of the chimney numerical
13 tracking, and we dispositioned that in the TRACG
14 review.

15 So what we did in --

16 MR. WALLIS: Well, we said we wanted to
17 revisit it again in our letter, I think, because you
18 hadn't actually reported your current number of one
19 results throughout the whole chimney at that time.

20 I understand you have done some better
21 simulations done.

22 MR. YANG: The calculations showed that
23 the chimney region has a minimum effect on stability
24 performance, especially with decay ratio value.

25 So you can see that all three mode decay

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ratio meet the acceptance criteria with very good
2 margin, and all the region can be made here is, among
3 this remote, if the channel, single channel mode, has
4 the largest margin, which means hydraulically, yes, we
5 believe our channels are very stable.

6 And the regional mode is limiting mode,
7 and -- but adequate modeling is --

8 Next slide, please.

9 So here we start talking about AOO
10 stability. So beyond normal operation, in the AOO
11 space, there are two limiting events that have been
12 identified. One is the lost feedwater heating event
13 where the power will increase as the feedwater
14 temperature reduces. Another one is loss feedwater
15 flow event, where the water level drops.

16 And the trajectories of these two events
17 are given on this power core fuel map, and you can see
18 that three lines of defense are established, to handle
19 the power level for the lost feedwater heating event.

20 So on detection of a temperature drop in
21 feedwater, the SCRRRI will be initiated through control
22 of power, overall power level.

23 And if power keeps rising, simulate
24 thermal power scram, and the trip from this
25 detect/suppress solution will further limit the power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 level.

2 And as far as the loss of feedwater flow
3 event, the scram on a level three will protect
4 stability.

5 Next slide, please.

6 MR. ABDEL-KHALIK: If I may just go back
7 to the previous table where you talk about the channel
8 decay ratio. You talk in the DCP about the
9 statistical analysis, or the channel decay ratio that
10 you have done 59 trials or something like that. And
11 you select the parameters from the distribution. And
12 you say that a TRACG calculation is made for the
13 perturbed set of parameters to obtain a steady state.

14 Were you able to obtain a steady state
15 result for each of the 59 trials?

16 MR. YANG: Yes.

17 MR. ABDEL-KHALIK: For each case?

18 MR. YANG: Yes, because to evaluate
19 stability performance, we need to have a variable
20 steady state first, using TRACG.

21 MR. MARQUINO: To evaluate the decay ratio
22 number, yes.

23 MR. ABDEL-KHALIK: Okay, thank you.

24 MR. YANG: Okay, back to AOs. From the
25 results for the normal operating condition, we know

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that regional mode is limiting mode. So here only the
2 regional decay ratios are given.

3 And you can see that for this two AOO
4 events, limiting events, the decay ratio value shows
5 adequate margin against acceptance criteria.

6 MR. WALLIS: Doesn't this vary with the
7 time in the cycle? Because the power distribution is
8 so very different in the beginning and end of cycle,
9 it must affect stability?

10 MR. YANG: Actually it --

11 MR. WALLIS: It's a worst condition there
12 or something?

13 MR. YANG: We determine the limiting cycle
14 point is at peak access, so we perform this --

15 CHAIRMAN CORRADINI: Sorry, the limiting
16 cycle point is what?

17 MR. YANG: Is at the peak of access,
18 reactivity cycle point. Is where the max reactivity
19 is the maximum during the cycle. And that would give
20 you the worst axial power shape.

21 CHAIRMAN CORRADINI: So it's near the
22 beginning of cycle.

23 MR. YANG: It's right in middle of --
24 middle of cycle and end of cycle.

25 MR. WALLIS: The bottom is worse for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 instability?

2 MR. YANG: Yes. So actually this decay
3 ratio obtained, and that peak of access point.

4 CHAIRMAN CORRADINI: So just so I
5 understand what you just said, so I were to plot the
6 overall core K effective, what you are saying is, with
7 gadilinium burn out, instead of going down you are
8 doing this, and you are picking that peak point?

9 MR. YANG: Yes, there is the peak during
10 the cycle.

11 CHAIRMAN CORRADINI: Okay.

12 MR. YANG: This decay ratio number recall
13 is the worst case.

14 MR. ARMIJO: In an initial care would you
15 expect it to be less? Would it meet the acceptance
16 criteria in an initial core? Would it be closer to --
17 the decay ratios be closer to your acceptance
18 criteria?

19 MR. YANG: Yes, we provided in the initial
20 core stability evaluation, the initial core LTR, and
21 the results were similar results to the palladium
22 core, and between these two cores, the equilibrium
23 core is a limiting condition for stability.

24 MR. ARMIJO: Equilibrium core is limiting?

25 MR. YANG: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ARMIJO: Okay.

2 MR. YANG: Next slide, please.

3 So following -- we are going to the
4 startup stability -- following the established startup
5 procedure, the voiding begins out of the core. So
6 there is no void reactivity oscillations during this
7 phase, so the core flow remains single phase sub
8 cooled. So largely CPR moderator is maintained during
9 the plant startup.

10 And there is no oscillation can challenge
11 the fuel design limit during the startup. So
12 stability is not of concern for plant startup.

13 MR. ABDEL-KHALIK: Do we have a complete
14 description of the startup procedure from cold
15 shutdown all the way to hot flow power step by step?

16 MR. YANG: In DCD 4B there is a startup
17 analysis up to 300 megawatts. And there is an in-
18 process effort to using Tri-G (phonetic) to get to the
19 full power rated commission.

20 MR. ABDEL-KHALIK: You know I looked
21 everywhere looking for -- from an operational
22 standpoint, a step-by-step procedure for how to go
23 from a cold shutdown to a hot full power. And I
24 couldn't find it.

25 MR. SIEBER: Well, you wouldn't find that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in this kind of a document. Procedures are a tier
2 lower than that, more detailed. The FSAR DCD sets the
3 envelope and the limits. The procedures themselves
4 are the product of the utility operator. So they
5 don't appear.

6 MR. MAYNARD: Typically they would be
7 inspected during startup and they wouldn't be
8 submitted as part of the FSAR.

9 MR. YANG: And for existing plant --

10 MR. ABDEL-KHALIK: But without knowing the
11 detail step by step procedure for this machine, I
12 would find it hard to say that, oh, we have no
13 stability problems there at startup.

14 MR. MAYNARD: I'm just saying where the
15 review normally takes place is at that point. But the
16 NRC still, they do review those. I'm not sure when
17 the ACRS would get something like that.

18 MR. SIEBER: You wouldn't. You wouldn't.

19 MR. MAYNARD: Without asking for it.

20 MR. SIEBER: The commission wouldn't get
21 it either. It's just part of a startup.

22 MR. MAYNARD: It would be -- there would
23 be some estimate of it in the COL phase I would
24 assume.

25 MR. SIEBER: Yeah, and the startup test

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 procedures would determine whether the procedures were
2 adequate to meet the limits that were set in the DCD
3 and the FSAR, and you would design and run tests to
4 show that.

5 MR. MARQUINO: And we have documented the
6 initial startup testing in Section 14.2 of the DCU.

7 MS. CUBBAGE: Yes, I was just going to
8 indicate that the staff has an open RAI at this time
9 requesting that the maximum heat up rate be specified,
10 and that limit would be implemented by the utility in
11 their startup procedure.

12 MR. KINSEY: And again this is Jim Kinsey
13 from GE-Hitachi, again getting back to the discussion
14 we just had.

15 It is not our intention to put a detailed
16 startup summary in the DCD, although we won't know
17 that one -- we recognize that one is needed as part of
18 the overall process, but it would be further down the
19 road in the process.

20 MR. ARMIJO: But to understand this plant,
21 how can you analyze it unless you think it through
22 what's going to happen at each step?

23 CHAIRMAN CORRADINI: I guess in 4(d)(6) on
24 a nondimensional map you kind of hand wave yourself
25 through the startup.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But I think what Sam is looking for is
2 some sort of progression. But you showed one slide
3 but the next figure in you DCD is the one that I'm
4 assuming you are eventually going to talk to relative
5 to how you proceed through -- you proceed through a
6 Type I instability in the chimney, but by doing that
7 avoid the Type II instability.

8 MR. YANG: There is I believe there is a
9 trajectory including 4(d) on the sub-cooling number
10 map, but that's a schematic figure, and there is an
11 effort to perform evaluating Type II instability over
12 the plant start to the full power. We will establish
13 several steps and achieve the steady state -- good
14 steady state at the different power level, and the
15 performance stability, and provide the decay ratio
16 values.

17 CHAIRMAN CORRADINI: I see. Okay. Can I
18 say that back to you one more time? So you are going
19 to use TRACG and have stop pourings to see how the
20 decay ratio evolves as you proceed down through low
21 whatever it is, low power but increasing temperatures,
22 and then come back up through your path, and look at
23 the various stability decay ratios all the way through
24 that?

25 MR. YANG: And those we can't see from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power flow map, my prediction is, the stability
2 performance will improve the power decrease, because
3 the power flow ratio decreases, because the power
4 changes more quickly than the flow changes.

5 MR. MARQUINO: Let me try and address what
6 you said and give you a brief like one minute
7 description of the startup.

8 We heat the vessel up with external
9 heating to get up to 80 Centigrade based on RT and DT
10 limit before we pull rods. And at that point we pull
11 rods, and that is the beginning of our TRAC analysis.
12 We start TRAC with the rods full in; pull the
13 critical; and then we are limited by a heat uprate
14 that is the same tech spec heat uprate as the
15 operating plants, 100 degrees Fahrenheit, and we've
16 shown that the reactor is stable, and it doesn't get
17 into a Type I or condensation slash flashing
18 instability during the heat up and pressurization that
19 we are limited by that thermal stress power level
20 versus the Type I instability power level.

21 So that was in Section 4D of the DCD. When one
22 unique feature of the ESBWR is because of the Type I
23 instability we minimize the steam load and the VOP
24 during startup. So we -- in the initial core
25 evaluation, analyze with some steam flowing from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactor based on condensation in the drains. But we
2 try and minimize the steam flow until we get to high
3 pressure, and we are out of any Type I instability
4 concern.

5 Now you were talking about what we are
6 going to do?

7 CHAIRMAN CORRADINI: Well, I'm just
8 repeating what I thought he said, which was, you will
9 take us through the startup path and at some selected
10 points in there look at a TRACG analysis to see that
11 your decay ratios and how they are evolving as you are
12 coming up in power and flow; that's what I thought I
13 heard.

14 MR. MARQUINO: No, we documented our
15 stability evaluation in 4D, and we were looking for --
16 we started out looking for flow instability in the
17 fuel channels. And three years ago the staff asked us
18 to do a kinetics evaluation, so we responded by
19 including a 3-D kinetic simulation, and that is in 4D
20 now.

21 We don't have to characterize the decay
22 ratio, because we show the power is stable during the
23 startup, and we have very large margins to CPR.

24 CHAIRMAN CORRADINI: Thank you.

25 MR. YANG: The next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In summary, based on the approved
2 methodology, the results show that ESBWR is stable
3 during normal operations and AOOs, and based on the
4 results, we can see -- we can say the ESBWRs meets the
5 GDC-10 and 12 requirements.

6 I will take -- I will use the next two
7 slides to go through the affirmatory items for this
8 stability LPR summation, and for the first three
9 items, GE's -- GEH's resolution is that there is no
10 change in the field design, the phase parameters.

11 And also we show that stability is not
12 sensitive to CPR correlations.

13 And also we have evaluated stability
14 performance during ATWS. And it show that stability
15 performance is not of concern during ATWS events.

16 Next slide, please.

17 And there is an ongoing effort to develop
18 the detect-suppress solution which will, based on
19 existing methodology, but it will consider the ESBWR
20 characteristics.

21 And for the startup stability, I think Mr.
22 Marquino summarized, and we will further evaluate with
23 different methodologies and also looking at xenon
24 trending effect.

25 MR. WALLIS: The ESBWR is stable during

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 startup as long as you startup slowly enough, but you
2 go into it for other reasons. It isn't inherently
3 stable. You've got to do things right. Isn't that
4 true?

5 MR. MARQUINO: That's true.

6 There was a lot of focus on this in some
7 universities and lab testing, and they did prove that
8 if you do something you can get the flashing
9 condensation instabilities.

10 But in the bundles, we are -- we're not
11 limited in that we -- as long as we comply with the
12 heat uprate, which we already had as a limit, we can
13 generate that regime.

14 MR. ABDEL-KHALIK: On item #5, will we
15 have the opportunity to review that design detail?

16 MR. YANG: Right, there is an open item on
17 this and GEH will address this.

18 MR. ABDEL-KHALIK: Right.

19 MR. YANG: So on the last item, we have
20 shown that for the gap conductance obtained from
21 different model, they are similar. One is from the
22 prime pallette model, another one is just for gap-
23 conducting model. And the results show there gave
24 similar results on the stability performance.

25 That will be all for stability.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Other questions?

2 MR. MAYNARD: On stability, what is your
3 current status on simulator? Do you have a simulator?

4 MR. MARQUINO: Yes.

5 MR. MAYNARD: Have you run a startup on
6 the simulator?

7 MR. MARQUINO: I have the simulator right
8 here on my laptop. I can show you during a break
9 maybe.

10 We --

11 MR. MAYNARD: I wonder if that might be a
12 way to go through a startup in similar -- you asked
13 for a detailed procedure. Well, a detailed startup
14 procedure is going to be involving a lot of system
15 line and some other things that are going on.

16 I think you are really interested in the
17 key aspects from the reactivity -- and there may be a
18 way to step through that without having a detailed
19 procedure --

20 MR. SIEBER: Well, Chapter 14 doesn't give
21 you the details. It tells you all the criteria you
22 have to meet.

23 MR. MAYNARD: I think what you are
24 interested in is what is going to occur, what limits
25 on rates and what parameters are really being looked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at from step to step there. If you have something
2 like that, I think it would help with the process.

3 MR. ARMIJO: You know, related to that,
4 one of the things that BWR used to be very good at,
5 the old BWR had flow controlling power, and so you
6 wanted to raise power very smooth, very slowly; for
7 example, preconditioning fuel that was -- had PCI
8 risk, that was a nice feature of the -- with the
9 conventional BWR.

10 With the ESBWR I personally don't know
11 exactly if you could do the same thing.

12 MR. MARQUINO: Dr. Perditza (phonetic) has
13 a presentation that will go through that shows how we
14 will do that.

15 MR. ARMIJO: Okay, I'll just hold on.

16 CHAIRMAN CORRADINI: Any other questions
17 from the members? Or
18 else we will go into a break.

19 Thank you very much, and we will have the
20 staff talking to us about their SER and open items
21 after a break at 10:30.

22 (Whereupon at 10:14 a.m. the
23 proceeding in the above-
24 entitled matter went off the
25 record to return on the record

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at 10:30 a.m.)

2 CHAIRMAN CORRADINI: All right, so let's
3 get started. The staff is here, so we will let them
4 begin.

5 SER WITH OPEN ITEMS FOR CHAPTER 4

6 MR. DONOGHUE: Before we get started, I'm
7 Joe Donoghue. I'm the branch chief in reactor systems
8 NRO. I just want to give you a couple of words on the
9 staff's perspective of getting ready for this meeting.

10 You see members, you will see some more
11 members, including people in front of you, from NRO
12 and from NRR. Remember that we formed NRO a little
13 over a year ago, so there are people that -- this is
14 a long review for ESBWR, and the people who had
15 started out, reviewing NRR, and there are some people
16 that are still in NRR. So don't be confused when you
17 see that on slides.

18 Just wanted to say that in preparing for
19 this, we have a -- the staff members here, we
20 contractor support, and we are also going to have
21 members of the staff of research, the Office of
22 Research here.

23 We prepare presentations to cover a lot of
24 ground. We do have to cover a lot of material, but
25 there is more for us to do, we realize that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So we basically have given you a status of
2 the review. There are many open items. I think that
3 was mentioned earlier.

4 There is also relatively new information
5 that has come in. In the earlier presentation you
6 heard about, I know you were interested in, the staff
7 is reviewing -- it's still reviewing. There are more
8 areas for us to inquire about, and we realize that.

9 And if you get into some areas of detailed
10 questioning, we are prepared for some of that, but
11 it's up to the committee how you want to spend the
12 time today and tomorrow.

13 We are prepared to do some of that detail
14 today. We can come back in future meetings and give
15 you some more detailed presentations.

16 And definitely by the time we are at the
17 final SER stage, when we think we have resolved the
18 open items, then we'll be ready to talk in a lot more
19 detail, okay?

20 CHAIRMAN CORRADINI: That sounds good.
21 Thank you very much. I would say just to answer one
22 of the points you raise is, we want to try to get
23 through at an appropriate level the four chapters over
24 the next four days.

25 If there are major things we have to note

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and come back and schedule an additional meeting on
2 this, I think staff will then have to decide, and
3 we'll try to find a mutually agreeable time to do
4 that, to get into more detail.

5 MR. DONOGHUE: Thank you.

6 MR. BAVOL: Well, good morning. My name
7 is Bruce Bavol. I'm the lead project manager for
8 Chapter 4, ESBWR.

9 This morning's presentation, the outline,
10 we are going to be briefing the subcommittee on the
11 staff's ongoing review, like Joe mentioned, of the DCD
12 application.

13 First up will be 4.2, fuel system design.
14 And we will be doing 4.6, functional design of fine-
15 motion control rod drive; 4.3, nuclear design; 4.4,
16 thermal hydraulic design; and finally 4 delta and 21.6
17 stability.

18 I left off 4.5, reactor materials. That's
19 not going to be part of the presentation, but we have
20 the technical reviewers in the audience today if there
21 are any questions.

22 Besides myself, Amy Cubbage is discussing
23 items this morning. She is the team lead for this
24 project. The lead technical reviewers are going to be
25 Paul Clipper (phonetic), George Thomas, Dr. Peter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Yarskey (phonetic), James Gilmer, Dr. Weidong Wang,
2 Dr. Jose March-Leuba, excuse me, you know who he is.
3 Robert Davis, and Nihar Ray.

4 This slide indicates a summary of
5 regulations and review guidance. Just wanted to post
6 that briefly.

7 REI status. The original number of REIs
8 started out 184, and we've resolved 150, and the
9 number of open items is currently 34, but as this is
10 an ongoing review, these numbers --

11 MR. WALLIS: Only 34? When you read these
12 documents, it seems like more than 34. Is that
13 because they are ongoing, or they are being tracked
14 for something? Is that why it seems so many?

15 MS. CUBBAGE: It should match with what
16 you have there.

17 MR. ARMIJO: I had 31, but close enough.

18
19 (Simultaneous voices)

20 (Laughter)

21 CHAIRMAN CORRADINI: We are also trying to
22 get them one at a time.

23 (Laughter)

24 MR. BAVOL: Each chapter will lay out the
25 specifics for that. But like you were saying there is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ongoing information still being reviewed. So these
2 numbers will definitely change.

3 The first section up for discussion is
4 Chapter 4.2, and I'd like to introduce Paul Clifford
5 from NRR.

6 MR. CLIFFORD: Good morning. I will begin
7 my presentation by describing the fuel design criteria
8 that is specified in the DCD, and then I'll move on to
9 discuss the topical reports which detail the hardware,
10 the fuel design and the control blade design, which
11 will be used by the ESBWR, and that meet the fuel
12 design criteria specified in the DCD.

13 The fuel design criteria that are
14 specified within ESBWR DCD, for example, shall not
15 fail fuel during an AOO, maintain a coolable geometry,
16 is consistent with the currently operating fleet, and
17 likewise, the control blade design requirements, such
18 as the ability to insert control blades during seismic
19 events and design basis events are consistent with the
20 current operating fleet.

21 MR. BANERJEE: This includes earthquakes,
22 right?

23 MR. CLIFFORD: Right.

24 Even though the criteria was identical to
25 the current fleet, the staff did identify a couple of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 open items with the criteria themselves.

2 The first issue we identified which is an
3 allowance for limited fuel centerline melting during
4 AOOs. That remains and open item.

5 And secondly, the staff had concerns with
6 the mechanical database according to 1 percent plastic
7 straining criteria at end-of-life conditions.

8 MR. ARMIJO: I have a question on that.
9 There seems to be an open item related to the use of
10 uniform strain or ultimate strain, the difference
11 between GEH and the staff.

12 Could you give us a little summary of
13 exactly what the issue is there?

14 MR. CLIFFORD: Sure. The cladding -- I'm
15 sorry, the staff prefers the use of uniform strain
16 based upon more typical stress characteristics such as
17 you would find in a balloon test, as opposed to the
18 ultimate tensile strength you would see -- I'm sorry,
19 the ultimate stress that you would get during like a
20 tensile test.

21 The type of loading that you see, and
22 also, there were sensitivities in the results with
23 gauge length, et cetera. And what we've seen from GE
24 to justify the 1 percent classic strain we feel needs
25 further support, and GE -- GEH I should say - actually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I've used to calling them G&F, but GEH -- has
2 indicated that they have some uniform strain data from
3 the Japanese counterparts which they will be providing
4 to close out this open item.

5 MR. ARMIJO: is that your understanding,
6 the GEH will move toward the uniform strain, and we'll
7 close it out that way? Is that your expectation?

8 MR. CLIFFORD: That is my expectation.
9 And also, that gets onto another slide here, they will
10 be providing corrosion limits and hydrogen limits from
11 which will be the basis of the uniform strength.

12 MR. ARMIJO: What is this word, prefers
13 uniform strain? Is the limit on the uniform strain,
14 or is it on the ultimate strain?

15 MR. CLIFFORD: The SRP, which is our
16 standard, provides a steady stream. This criterion
17 goes back more than 25 years. So I think we have seen
18 some mechanical testing data that has caused us to
19 rethink the previous acceptance criteria from many
20 many decades ago, and now we are moving toward uniform
21 stress based on other testings.

22 MR. MAYNARD: Are we changing the
23 requirement?

24 MR. CLIFFORD: We are not changing the
25 requirement. They are specifying the requirement. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guess our open item is, we don't see that they have
2 the capability of demonstrating that they meet their
3 own criteria.

4 We don't necessarily tell them that they -
5 - they define their own samples, when the point of
6 cladding failure occurs. And they specify this 1
7 percent plastic strain. And based on ultimate
8 tensile.

9 And we asked them to demonstrate that they
10 can meet that with their current cladding. And I
11 don't believe to this point that they provide enough
12 evidence.

13 And as I indicated, they have stated that
14 there is additional test data in their Japanese
15 counterparts which they will use to close this open
16 item.

17 MR. MAYNARD: And it's an important issue.
18 But you talk about the staff prefers. We are dealing
19 in a regulatory environment, there should be a
20 requirement, and are they meeting the requirements or
21 not, as opposed to redefining what the staff may want.

22 Is this stuff that is just not very well
23 covered in the regulations?

24 MR. CLIFFORD: There are is no regulation
25 specifying --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MAYNARD: Reg guides, sort of thing?

2 MR. CLIFFORD: The SRP, which was recently
3 updated, provides for clarification on what staff
4 would like to see.

5 MR. MAYNARD: Yes, but the SRP applies to
6 the staff review. What is the requirement on the
7 applicant? I just wondered whether we are going
8 beyond what the regulation requires just because -- I
9 want to make sure that when we have different staff
10 members that may come in to all of a sudden start
11 changing, say now, we really prefer this, or we really
12 prefer that.

13 MR. CLIFFORD: That's a very good point.
14 I think that that's one of the reasons we added
15 further details to the SRP so that we don't get into
16 different regulatory instability I guess you would
17 call it.

18 MR. SHACK: But there is this
19 interpretation. I mean you have a GAC requirement,
20 then what do you use to demonstrate that you are
21 meeting that requirement I think is where we begin to
22 get these interpretative differences.

23 MR. MAYNARD: That's where most of them
24 come.

25 MR. CLIFFORD: And now we are moving on to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the hardware section, the actual -- there are four
2 topical reports that were submitted, two for the fuel
3 assembly design, and two for the control blade design.

4 The two topical reports which were
5 submitted for GE14E were reviewed, and in addition,
6 the staff performed some FRAPCON benchmark or
7 independent calculations to verify that they met the
8 design requirements. And we performed an audit down
9 in GE Wilmington their engineering calculations.

10 GE previously identified that the GE14E is
11 almost identical to the GE14, except it's slightly
12 shorter components, materials, et cetera.

13 Of course that was important for the staff
14 to ensure that there was applicable operating
15 experience.

16 During the course of the interview we
17 identified a couple of open items with the GE14E. The
18 first is although the components are identical, the
19 space -- the distance between the spacers in effect
20 flow induced vibrations, and we have asked GE to
21 perform some full flow testing, and they agreed to.
22 And we are still waiting for the results. They may
23 have already performed it; I'm not sure. They are due
24 any time now.

25 The second is that we expected them to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provide us with the corrosion limits for both oxides
2 and hydrogen uptake.

3 The third item is that during the FRAPCON
4 benchmark we identified some discrepancies between the
5 JESTER-M model and the FRAPCON model, and subsequently
6 GE issued an evaluation, and the staff is reviewing
7 that.

8 And based upon these changes and potential
9 changes to the DCE requirements, we would expect that
10 both of these GE14E topical reports to be revised in
11 the very near future.

12 MR. ARMIJO: To that point, I looked at
13 one of the topical reports, and looked at the
14 composition of the liner, and it's different from what
15 I think GEH actually uses. It has -- and I don't
16 know, I don't want to mention numbers, because that
17 might be proprietary.

18 When can we talk about that?

19 MR. CLIFFORD: We could have a closed
20 session I guess, whenever we do that.

21 MR. ARMIJO: The topical report is the
22 basis for the DCP, which is the basis for the SER. I
23 just wondering if we've got the right material defined
24 here.

25 MR. CLIFFORD: It was our understanding,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 based on what was described in the topical report,
2 that the fuel design and the fuel barrier are
3 identical to the GE14.

4 MR. ARMIJO: The top report, it does give
5 specific composition, but I think it is different from
6 what is actually being used. Maybe GE --

7 (Simultaneous voices)

8 MR. CLIFFORD: Right, well, I'm going to
9 have to defer to GE.

10 MS. CUBBAGE: Does GE have an answer for
11 that at this time? Or is that a take away?

12 MR. ARMIJO: It may be just something that
13 we missed in updating that topical report.

14 MR. KINSEY: This is Jim Kinsey from GEH.
15 Maybe to help us address the question, what I think I
16 heard you say is that something that is depicted in
17 our topical is different from what you think we may be
18 doing. I just want to clarify that.

19 MR. ARMIJO: Let me just show you the
20 table that I copied. I don't think that is the
21 composition you wanted.

22 MS. CUBBAGE: Maybe sometime before the
23 end of the day tomorrow we could come back to that.

24 MR. ARMIJO: Is there a limiting location
25 for a fuel induced vibrations? And is that the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 location in GE14E as it is in GE14?

2 MR. CLIFFORD: I'm not sure if it's the
3 same location. I mean I'm sure it depends on the
4 hydraulic characteristics of the assembly between the
5 spacers, and maybe the introduction of different rods.
6 And that is really we asked for specific testing.

7 Initially GE's position was that the
8 testing that was done for GE14 was applicable to GE14,
9 and there were also other compensatory issues, such as
10 the flow in the core is significantly lower than the
11 porous flow. So they were saying it's really not --
12 it is not expected to be a damage mechanism, because
13 of the lower flow. And they have testing on similar
14 bundles, but we asked for them to validate that, and
15 then they said okay, we'll run the test. So I guess
16 we'll have a sense of the demonstrations whenever we
17 get the test results.

18 MR. BANERJEE: What are the vibration
19 frequencies?

20 MR. CLIFFORD: I don't know off the top of
21 my head.

22 MR. BANERJEE: How do these do these
23 tests?

24 MR. CLIFFORD: They have a chamber where
25 they insert a full bundle, and they perform full flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 testing. The test rig is in Wilmington.

2 MR. BANERJEE: The reason I ask is, in the
3 chimney you get a frequency do to the chugging of --
4 appeared at one to two seconds. Any potential for the
5 pressure waves coupling?

6 MR. CLIFFORD: I'm not sure. We have
7 asked GE -- the tests which were done in the past were
8 done -- were just broader. It wasn't done with two-
9 phase flow.

10 We've asked GE to either consider running
11 tests for two-phase flow, or to justify the use of
12 just saturated liquid.

13 CHAIRMAN CORRADINI: But the chugging
14 phenomena that at least to my understanding, the
15 chugging phenomena that Sandra is talking about is as
16 you're coming up the power, and you are going to be
17 doing full flow test at full power flow conditions.

18 MR. BANERJEE: It could be at power, too,
19 because a void fraction in the chimney is such that
20 you are in the channel turbulence regime. So you will
21 stop --

22 CHAIRMAN CORRADINI: It's not an
23 instability chugging. It's just a churn turbulence --

24

25 MR. BANERJEE: It is the full regime,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which is why I gave the one to two second period. So
2 and that's why I was asking what the frequency is
3 likely to be.

4 MR. CLIFFORD: We have asked that the test
5 encompass the full range of flow, and also we have
6 inquired about the quality.

7 MR. BANERJEE: Can GE give us an idea of
8 what the frequency is?

9 MR. MARQUINO: Are you asking about flow
10 induced vibration?

11 MR. BANERJEE: Yeah or frequency, what is
12 the peak frequency or mean, whatever.

13 MR. MARQUINO: Well, you have the natural
14 frequency of the bundle, right, to see if it couples
15 with the forcing frequency.

16 MR. BANERJEE: Well, natural frequency
17 without the added mass, because it is going to be a
18 high void fraction.

19 MR. DERWER: This is Jerry Derwer with
20 GEH. When we did the flow testing in the chimney,
21 they determined the frequency of the fluid going
22 through the chamber, and that was 2 Hertz, that's what
23 we reported.

24 MR. BANERJEE: Well, that I know. These
25 are the Ontario hydro tests, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DERWER: No, this is what Hitachi did
2 on the partitions.

3 MR. BANERJEE: You're doing a different
4 set of tests on the partition? The only void fraction
5 oscillation tests are the Ontario hydro ones. Is that
6 a different set?

7 MR. DERWER: It's a different test. I'm
8 not familiar with that test, though.

9 MR. BANERJEE: Who knows about the current
10 set? Where was this done?

11 Anyway I accept the 2 Hertz, because it's
12 in the range of what I know. But it's a question of
13 what is the bundle frequency which clarifies the
14 issue.

15 MR. MARQUINO: The bundle frequencies are
16 given in the DCB along with the decay ratio.

17 CHAIRMAN CORRADINI: For flow and -- I
18 just want to make sure we're talking about the same
19 thing. For flow induced vibration? That is what
20 Sanjoy is asking.

21 MR. WALLIS: Can they look it up and tell
22 us later?

23 CHAIRMAN CORRADINI: Can we just take it
24 and get back to it and move on for the moment.

25 MR. CLIFFORD: And I just would like to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 add, I think we will be in a better position to talk
2 about this once we have received the sample test data,
3 and that will probably be presented in a future
4 meeting.

5 I'd just briefly mention the two topical
6 reports which were submitted, which document the
7 Marathon control blade design. Which was the original
8 Rev. 0 of these documents was almost identical to the
9 current generation Marathon which is in operation
10 right now.

11 The staff completed a review of topical
12 reports and performed an audit down at GE of the
13 engineering calculations. We identified several open
14 items. Most of them were related to some operating
15 experience that we've see in the fleet, and we
16 believe it has to do with some assumptions in their
17 design analysis due to reasons I've already stated and
18 some of the irradiated stainless steel properties
19 related to strain capabilities, for the irradiated
20 stainless steel.

21 This remains an open item, and as a result
22 of some of these issues, GE has redesigned the ESBWR
23 Marathon control blade, and Rev. 1 was just received
24 a couple of weeks ago, and the staff is beginning its
25 review of Rev. 1 which has a slightly new design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Now this business of channel
2 bow, is it just the channels that bow? Or do these
3 control rods themselves have some dimensional changes
4 over the length of the rod?

5 MR. CLIFFORD: I think in general the
6 channels are flexible, but there is bowing on them as
7 a result of peaking, hydrogen corrosion, or
8 differential flow.

9 MR. WALLIS: Do the rods change their
10 dimension at all? Do they bow or swell?

11 MR. CLIFFORD: What we are concerned with
12 is that there is internal swelling in the chambers
13 that hold the B4C powder such that you can crack the
14 control blade, not necessarily -- -

15 (Simultaneous voices)

16 MR. WALLIS: -- changing their bowing, and
17 it's just cracking that you are worried about?

18 MR. CLIFFORD: That's what we are
19 primarily concerned with, yes.

20 MR. BANERJEE: And this Japanese
21 earthquake, there was some problem with one or more of
22 the control blades getting stuck. Have you heard
23 about that, and what happened, an understanding of
24 that?

25 This was a little bit beyond their safe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shutdown earthquake as you know of course; it went
2 beyond. But nonetheless, most of the systems were
3 okay. But there was something to do with control rod
4 getting stuck.

5 I only heard this at a presentation by
6 Commissioner Soda. I can probably give you a copy of
7 the slide

8 MR. CLIFFORD: Okay, in summary, we have
9 identified multiple issues, which should necessitate
10 revisions to both, some of the ESBWR design criteria,
11 and into the four topical reports which support the
12 hardware.

13 Further questions?

14 MR. WALLIS: These issues seem to be
15 completion issues. They don't seem to be something
16 that is really fundamental, show-stopping type
17 problems. It's just that they haven't done the
18 complete job of design yet, haven't completely
19 resolved some things. But it's not as though there is
20 a huge extrapolation from present practices for this
21 design.

22 MR. CLIFFORD: Right.

23 MR. WALLIS: So there is no real
24 fundamental question, is there? I think that's what
25 we should probably focus on, not all the details that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have to satisfy you for completeness. But something
2 which is a fundamental new question about ESBWR.

3 MR. CLIFFORD: As you mentioned, the
4 designs are extremely similar to what they've had
5 years of interactive experience with. So these
6 designs we've seen, there is nothing fundamentally
7 flawed in them that would prevent them from being
8 approved by the staff.

9 MR. BANERJEE: I guess one issue would be
10 if there is any coupling with this chimney.

11 MR. CLIFFORD: And that is maybe an area
12 we didn't look at, because it's similar to unique
13 designs, and the test rates we've seen for other
14 vendors and for GE, so it is limited.

15 MR. WALLIS: Well, it gets back to the
16 question that my colleague, Said, earlier that if you
17 get some channels which are exhausting into the same
18 chimney, with really conditions coming out of the
19 channel, some kind of adjustment goes on at the bottom
20 of the chimney. Does this produce some kind of
21 frequency, some sort of driving force from what's
22 happening at the bottom of the chimney, as it's
23 adjusting itself to being nonuniform.

24 You have a much greater flow coming out of
25 one passage, one channel, than another one, you can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 use vortices and things at the bottom of the chimney,
2 which hopefully will die away when you go --

3 CHAIRMAN CORRADINI: The next presentation
4 will be given by George Thomas of NRO, and we are
5 going to move right into 4.6, which is the control
6 drive system which we just were talking about.

7 MR. THOMAS: Good morning. Throughout the
8 system in ESBWR is very similar to the ABWR, approved
9 in 1997 and there are only very minor differences,
10 like the induction model, it has not changed. And
11 there is now high pressure coolant injection in the
12 reactor. There are only minor difference in the ESBWR
13 compared to the ABWR and now, as you know, in Japan
14 ESBWR operating this system now for some time. So
15 there is a good operating experience now, so based on
16 that experience, we know that system can be built and
17 operated to satisfy all the analysis.

18 Also they submitted the ABWR, they
19 submitted a thorough analysis. So they wanted to take
20 apart that one and they also identified all the
21 differences between the ABWR and the ESBWR. So based
22 on that we redid the CRD design.

23 Now he have only a few open items,
24 basically only two of them. And one of them is
25 related to the current GE tech for the information

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 system.

2 CHAIRMAN CORRADINI: And we are going to
3 talk about these open items in Chapter 15?

4 MR. THOMAS: We don't have any plans to go
5 into detail, but if you want to, basically we got an
6 open item basically because --

7 MR. CLIFFORD: When the staff reviews the
8 internal drive system, the first thing which seems
9 apparent is, you want to ensure that all the design
10 characteristics, how it moves the blade, et cetera.
11 Anything that is credited in Chapter 15 is
12 specifically captured in a testing for both tier one
13 ITAC, in other words, they'll test each blade, each
14 drive to ensure that it can meet the requirements as
15 assumed in Chapter 15.

16 And there will be tech specs and future
17 surveillance to make sure that the performance is
18 maintained for future cycles.

19 That is the obvious.

20 The next thing you always look at, if you
21 have a new system, you want to make sure that there
22 are not any new characters of that system that could
23 cause a transient, or cause the system to introduce
24 like a new anomaly that wasn't there in the previous
25 design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And really the REIs that are open right
2 now are really the second part. It's really that we
3 have asked some questions that, okay, here's the new
4 future of this new design. Could this cause a
5 different accident than we've previously analyzed?
6 And we are still waiting for some of the responses,
7 and waiting to go through some of the responses.

8 MR. KRESS: Do those have anything to do
9 with the induction motors as being a difference?

10 MR. CLIFFORD: No. One of them, for
11 instance, is the ability to move many rods at the same
12 time, whether or not that's been considered in the
13 accident analysis.

14 MR. ABDEL-KHALIK: You mean the fine rod
15 control?

16 MR. CLIFFORD: Right. And another one is
17 the control -- but there are drawbacks, and as you
18 know, as a limited reactivity initiated accident. And
19 there is many enhanced features of this design which
20 have been credited, and GE's position is that -- or
21 GEH's position is that that accident has now moved
22 beyond design space.

23 And the staff is questioning that
24 position, whether or not it is beyond design basis, or
25 whether it has to be or not.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We can talk more about that.

2 CHAIRMAN CORRADINI: At that time I think
3 we'll wait, unless you really want to talk about it
4 here.

5 MS. CUBBAGE: If you want to discuss this
6 issue, this is the time.

7 CHAIRMAN CORRADINI: This is the time?

8 MR. ARMIJO: What is the GEH basis for
9 saying it's moved off the table that the rod dropped?
10 I mean what mechanical changes or logical changes?

11 MR. CLIFFORD: For instance in order for
12 today's plants to get a control rod drop accident,
13 they've got to move the control blade up during normal
14 power, and then it's got to stick, and then it's got
15 to physically separate from the decoupling device, and
16 you withdraw the control arm, and then eventually it
17 just falls. It falls out of the core.

18 Some of it is unique design -- well, they
19 are all detailed in the DCD. But like for instance,
20 they have changed the coupling such that it is
21 physically impossible to decouple the control blade
22 from what they call the hollow piston. You would
23 actually have to rotate it 45 degrees, and you
24 couldn't do that when it's in the core and surrounding
25 by a shield.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ARMIJO: So they have a mechanical
2 change?

3 MR. CLIFFORD: They have a mechanical
4 change, went through a coupling, a bayonet coupling
5 they call it. And there are other features too.

6 And I guess the staff -- we have an open
7 REI on this -- but we have kind of looked at
8 probabilities, and more so deterministically, if you
9 don't analyze this event, if you just say it's beyond
10 design basis and you never look at it, in a sense you
11 have given up on any control blade worth.

12 You know there is no limit on control area
13 worth. You could have four high enrichment bundles in
14 the same control cell, and you could have significant
15 delta ro over H worth if something were to happen, and
16 our position is that even though the probability may
17 be slightly less for ESBWR than for the current plant,
18 still it's something that should be analyzed, since
19 the consequences are potentially so severe.

20 MR. MARQUINO: I can add something to what
21 Mr. Clifford said. We do have an REI in the process.
22 We start with REIs about the probability and failure
23 modes and effects analyses. We responded to that.

24 We quantified the probability, and now as
25 Mr. Clifford said, they are asking us about the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consequences, and our plan is to compare the ESBWR to
2 other control rod drop accident evaluations that we
3 have done on a rod work basis to show that our rod
4 works are similar to those for plants where we have
5 evaluated the consequences control rod drop, and when
6 that is the case, the rod drop is a local event.

7 We expect to be able to show that it is
8 bounded by the dose evaluation we provided for
9 infrequent events, which is 1,000 rod failures.

10 CHAIRMAN CORRADINI: So can I just get a
11 clarification? Because the way you discuss it, this
12 actually brings up this new categorization.

13 So is the GEH position that it moves out
14 of the DBA space or moves out of the AOO space into
15 the DBA space?

16 MR. CLIFFORD: Out of the DBA space.

17 CHAIRMAN CORRADINI: Okay, so we're not in
18 this new categorization, infrequent events.

19 MR. BLEY: May I ask you a question about
20 it? Because looking at the pictures it's hard for me
21 to fully understand the physical mechanisms of how
22 that rod drive works.

23 If it's explained that there is a clutch
24 that allows the hydraulic air to drive the rod in for
25 a scram, is there any way that clutch could fail and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the rod drop out when you are not facing a scram
2 criteria? Have you looked at that?

3 MR. CLIFFORD: There's two mechanisms
4 there, I can kind of visualize it and that is how you
5 have your control blade, which has a long what they
6 call hollow piston. And that thing is resting on a
7 small shelf which they call the ball nut.

8 And that's driven by an induction motor
9 which turns a screw which raises the shelf up and
10 down. And in the event of a scram you inject the high
11 pressure water into the system, and that then lifts
12 because of the hollow piston design, lifts the piston
13 off that shelf up into the core really fast.

14 And as soon as it gets into the core there
15 are latching mechanisms that will hold it in place in
16 its fully inserted position. And also during a scram
17 there is a signal sent to the motor to drive that
18 shelf up, and for whatever reason it wasn't to be
19 inserted, that's like an odd diverse scram in a sense.

20 MR. BLEY: And show the shelf is a
21 physical thing, so the rod can't go past that shelf?

22 MR. CLIFFORD: It doesn't -- correct. But
23 as they mentioned, there is a break, and the break
24 does have testing requirements to ensure that during
25 a full pressurization event the pressure on the rod

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 wouldn't cause that motor to turn backward in a sense
2 to try to push it out. And we have captioned those
3 testing requirements.

4 MR. BANERJEE: So more of these control
5 rod slip accidents were because of the flow control
6 valve being open, or does it have to be closed or
7 something?

8 MR. CLIFFORD: For the current flow, you
9 mean?

10 MR. BANERJEE: Yeah.

11 MR. CLIFFORD: Right. I mean there have
12 been incidents where flow control valves have
13 essentially decreased the pressure in the piston
14 region which caused the rod to drop up; we've seen
15 those in Japan the last couple of years -- or actually
16 it was about a dozen years ago; it was just reported.

17 But the classic event is that of it
18 sticking in the floor. And in that situation the
19 operators don't know where it is. As far as they're
20 concerned, it's been withdrawn. But it's sitting up
21 there and it falls at a future time; that is the
22 classic event.

23 I don't think we have had one of those.

24 CHAIRMAN CORRADINI: And that's -- by this
25 new design, I just want to make sure we get back to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it, so I understand -- in the new design there is some
2 sort of physical connection and turning; the point is
3 that it can't be unhitched once it's in the core?

4 MR. CLIFFORD: The new design has some
5 unique features that make the problem less, but there
6 are a couple of features which could make the
7 probability.

8 For instance, the only thing holding the
9 control blade and the hollow piston on that shelf is
10 its weight; gravity. So you could argue that if there
11 was a lot of channel bow, as soon as you move that
12 down it would stick. The shelf would go down, but the
13 hollow piston and the blade attached would stay there.
14 That was one of our concerns.

15 So you don't need it to decouple for it to
16 hang up into the core. You would still have the
17 hollow piston. The hollow piston can't physically
18 decouple from the blade, but the blade and the hollow
19 piston as one unit would hang up.

20 But they've introduced -- to counteract
21 that they've introduced redundant load sensors which
22 would identify if it were -- the hollow piston were to
23 leave that shelf, the weight sensors would say, oops,
24 it's not there anymore. Set off a rod block alarm;
25 set off an alarm into the control room, and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operators would respond.

2 MR. BLEY: So the issue is how much credit
3 can you give for an improved design and still address
4 the issues that you had?

5 MR. CLIFFORD: Right, exactly.

6 MR. CLIFFORD: This is a very gray area,
7 because the ABWR was approved. Acknowledging that the
8 event was non-design basis. On ESBWR the staff has
9 said, well, we think the way it was done before maybe
10 wasn't the right way.

11 CHAIRMAN CORRADINI: I missed that.

12 (Simultaneous voices)

13 MR. CLIFFORD: We should have known that
14 part. I don't think we knew that part. I didn't know
15 that part.

16 CHAIRMAN CORRADINI: DCD, the ABWR which
17 was approved what year?

18 MR. CLIFFORD: Ten years ago.

19 CHAIRMAN CORRADINI: Ten years ago, sorry,
20 the DCD took credit for all these advanced features,
21 and stated that the event was beyond design basis.

22 Now when the staff was evaluating it, the
23 staff didn't fully disagree with that position.
24 However, they did do an independent dose calculation.
25 They did an analysis of rod worths and they did the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 transient, and then they determined what the dose
2 would be. And they said, well, since the dose is
3 acceptable, the design was acceptable.

4 It's kind of a gray area, because the SE
5 is not the DCD. The DCD is captured in the rule; the
6 SE isn't necessarily captured in the rule. I think
7 it's kind of a gray area how that was approved.

8 And I don't think we wanted to do the same
9 thing here, because it leads to confusion, future --
10 regulatory confusion when you implement this decision
11 whether or not they have to maintain a dose calc in
12 the future, or whether or not they have to maintain
13 rod worth limits in the future.

14 So a regulatory gray area, and we didn't
15 want to repeat that; we wanted to have a definitive
16 regulatory position.

17 MR. SHUAIBI: Hey Paul, if I could -- this
18 Mohammed Shuaibi from the staff. I guess what we are
19 looking for is for GE to justify their position that
20 this does not to be addressed. We are looking for
21 them to do the analyses that were previously done on
22 the ABWR design by the staff, and then show us or
23 convince us that this is okay.

24 Where we will end up on this I don't know.
25 I guess we will be back to brief you on the closure of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these open items at a future meeting. But that's what
2 we're waiting for is for them to provide that
3 information to show that the probability is what it
4 is; the consequences are what they are; and then based
5 on probability and consequences together, we will
6 decide whether this is okay or not, and then you'll
7 hear about it at a future meeting.

8 MR. THOMAS: I want to say, my worst
9 problem with the review is the ABWR. C H A I R M A N
10 CORRADINI: Just to end this so we can let you go on,
11 just to repeat what you said, is even though that
12 might be in your heart, the DCD doesn't reflect it.

13 MR. THOMAS: That's my conclusion. If you
14 got any questions.

15 MR. ARMIJO: I just had one quick question
16 on the open items on the control blade design.

17 You have a statement, irradiated stainless
18 steel properties in question. Exactly what are you
19 concerned about there?

20 MR. CLIFFORD: We reviewed several
21 calculations to find that element analysis
22 calculations for the control blade design, and there
23 were some conflicting statements and different design
24 calcs as opposed to strain capability of the
25 irradiated stainless steel, what we call square tubes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ARMIJO: The square tube, these are
2 just mechanical limits, or related to stress corrosion
3 cracking susceptibility? Or just straight mechanical?

4 MR. CLIFFORD: This is straight
5 mechanical. MR. ARMIJO: Okay.

6 MR. CLIFFORD: The stress corrosion
7 cracking was addressed with material changes where
8 they changed the recipe of the 304 stainless steel.

9 MR. ARMIJO: Okay.

10 MR. CLIFFORD: But the new design, the rev
11 one design, is -- provides a lot more margin in the
12 sense that the maximum depletion of the B4C, the
13 maximum B force in swelling, they will maintain
14 margins. In other words there will be no contact
15 between the two capsules and other square tube.

16 So by not having contact or having stress
17 or strain, you don't have to worry about what the
18 strain capability of that cladding is. That's one way
19 of resolving that open issue.

20 MR. THOMAS: I will introduce Mr. Yarsey
21 who are we talking about Point 3.

22 MR. YARSKY: Yes, some will be talking
23 about our review of 4.3. Most of the review is
24 related to the review of these four topical reports
25 here, which is the gamma thermometer system for LPRM

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 calibration and power shape monitoring; the nuclear
2 design report; initial core nuclear design report; and
3 as you heard about earlier the feedwater temperature
4 power operating domain transient accident analysis.

5 So I'm going to focus on the presentation
6 of significant open items related to those topical
7 reports, and each is really unique to ESBWR.

8 The first would be the in-core
9 instrumentation design, which is how you meet general
10 design criteria 13. The ESBWR has a unique design
11 feature relative to operating BWRs, which is to
12 eliminate the traversing in-core probe system for
13 conventional BWRs, which allows complete axial mapping
14 of the axial power shape and replace that system with
15 an automated fixed import probe system.

16 That is currently under review, and has a
17 significant number of open items related to that
18 review.

19 The second open item in regards to review
20 is the applicability of neutronic methods and
21 historically determined uncertainties for establishing
22 safety and operating limits. And that is also
23 currently under review.

24 Next slide. Our plan for resolution of
25 these open items is, we'll be conducting an audit of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the core monitoring software method, and moving from
2 a traversing import probe type system to the automated
3 fixed import probe system. The staff right now is
4 reviewing -- relying more heavily on the neutronic
5 methods to characterize the axial power shape versus
6 direct measurement.

7 So in that review we are going to be
8 highly scrutinizing and reviewing the core monitoring
9 methods as they will be implemented.

10 And two, in the area of methods, apply
11 appropriate conservatisms where required to resolve
12 those issues.

13 MR. SIEBER: I have a couple of questions.
14 It seems to me this is a fixed system composed of
15 gamma thermometers, and also fission chambers; is that
16 correct?

17 MR. YARSKY: There are still going to be
18 local power range monitors, which are similar to the
19 local power range monitors in the operating fleet,
20 which are going to be neutron sensitive fission
21 chambers.

22 MR. SIEBER: Okay, so they deplete the
23 core. How do you accommodate calibration of those?
24 Is it just purely the depletion that you think is
25 going on?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. YARSKY: Well, talking about the
2 calibration would require going to core session.

3 MR. SIEBER: Right.

4 MR. YARSKY: So they are calibrated.

5 MR. SIEBER: Okay.

6 MR. ABDEL-KHALIK: How about OPRMs?

7 MR. YARSKY: The OPRMs right now -- right
8 now the DSS solution for ESBWR is still being
9 developed by GE, and will be reviewed by the staff.
10 I imagine that it will be based on the DSS CD --

11 MR. ABDEL-KHALIK: Is there an open item
12 with regard to them, considering the fact that there
13 is no detail?

14 MR. YARSKY: Well, as you'll recall from
15 this morning the licensing basis for ESBWR stability
16 is not the detect and suppress solution. So to date
17 our, when our review has been focused on, is the ESBWR
18 stable versus does the ESBWR have an acceptable means
19 for detecting and suppressing an oscillation.

20 Right now we have an open item, I believe,
21 which is for GE to provide the detect and suppress
22 solution. But that is a backup to the ESBWR just
23 being stable.

24 The ESBWR is stable, and that is their
25 licensing basis, then there is no regulatory

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requirement for detect and suppress solution.

2 MR. ABDEL-KHALIK: Okay.

3 MR. YARSKY: Okay. I hope that answers
4 your question.

5 MR. ABDEL-KHALIK: I guess we will wait
6 for GE's response.

7 MR. YARSKY: Yes. I think, yes, also we
8 had identified several COL action items in regard to
9 the initial core design. Many of these open items
10 have been identified and are now being resolved in the
11 design certification space, and are no longer COL
12 items. They are now being addressed through the IEI
13 process, since GE submitted the initial core nuclear
14 design; report initial core transient accident
15 analysis.

16 So we intend to resolve those previous
17 identified COL items through the RIF process related
18 to the recent submittal of topical reports.

19 And just the significant design changes in
20 the submittals that were in one case we're reviewing
21 for substance, in another case beginning the review
22 for are the feedwater temperature power operating
23 domain which you have heard about I believe briefly
24 this morning.

25 MR. WALLIS: We still haven't seen what it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is. We just heard the words.

2 MR. YARSKY: There will be a presentation
3 I believe being made by GE at some point. I don't
4 know when that is scheduled.

5 MS. CUBBAGE: At the end of the day.

6 MR. WALLIS: End of the day?

7 MR. YARSKY: But this particular topical
8 report which describes the operating domain is
9 currently under review by the staff for acceptance.
10 So it's not been formally accepted to date. It's just
11 to let you know that there is this new operating
12 domain, which we consider a significant design change.

13 And also the initial core nuclear design
14 is a significant addition to the review in the area of
15 the nuclear design.

16 So if you have any questions?

17 MR. BAVOL: At this point I'd like to
18 change out the team up here at the front table.

19 (Simultaneous voices)

20 MR. WALLIS: guys, get on the record if
21 you talk.

22 MR. BAVOL: Okay, I'd like to introduce
23 James Gilmer. He's going to be reviewing Chapter 4.4
24 for thermal and hydraulic design.

25 MR. GILMER: As Mr. Fawcett discussed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 earlier this morning, the proposed fuel is the GE14E
2 which is essentially identical to the current
3 operating fleet GE14 which we will accept the shorten
4 to optimize the natural circulation flow, and because
5 of the shortening the print spacers are closer,
6 separation, and in addition the rod heights are
7 shorter.

8 The staff has reviewed the method GE
9 proposes to use to evaluate core --

10 MR. WALLIS: did they have orifices at the
11 bottom of these channels to control the distribution?

12 MR. GILMER: Yes.

13 MR. WALLIS: Are they less restrictive in
14 order to promote natural circulation?

15 MR. GILMER: I believe they are identical
16 to the GE --

17 MR. WALLIS: They are identical to what
18 they have already?

19 MR. GILMER: Yes.

20 MR. WALLIS: So they haven't changed them?

21 MR. GILMER: Correct. And the debris
22 filters are the same.

23 MR. SIEBER: But they did have a slightly
24 different spacing between assemblies.

25 Well, the fuel assembly itself, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 nozzles, is the same. But I think the gap between
2 them is different to allow -- is that correct?

3 MR. WALLIS: But that's in the assembly
4 itself.

5 MR. FAWCETT: Hi, this is Russ Fawcett,
6 yes. Assembly hardware is the same. The bundle pitch
7 is increased by 100 mils, or a tenth of an inch.

8 MR. WALLIS: So there is no bypass flow or
9 something?

10 MR. FAWCETT: I'm sorry, what was the
11 question?

12 MR. WALLIS: Is there anymore bypass flow
13 in this than usual?

14 MR. FAWCETT: There is slightly more
15 bypass flow just looking at the assembly pitch
16 relative to, say, a C-lattice, which is six inches
17 bundle to bundle hitch.

18 The N-lattice was originally developed to
19 -- for nuclear reasons to reduce the magnitude of the
20 void reactivity coefficient in concert with BWR
21 development. It has other good characteristics
22 associated with the shutdown margin and control blade
23 spacing between channels.

24 MR. SIEBER: Is it undermoderated or
25 overmoderated? My suspicion is it's undermoderated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. FAWCETT: The void reactivity
2 coefficient is negative under all reactor conditions.
3 Specifically looking at what we call the isothermal
4 temperature coefficient in which at cold conditions
5 the temperature is increased. We can insert some
6 positive reactivity so the temperature coefficient can
7 be positive, and is allowed to be positive --

8 MR. SIEBER: But the void coefficient is
9 negative?

10 MR. FAWCETT: The void coefficient is
11 always negative, as is the prompt power coefficient,
12 as is the Doppler coefficient.

13 MR. SIEBER: Can you ever under any
14 circumstance -- that you can think of?

15 MR. FAWCETT: I know of no circumstance.

16 MR. SIEBER: So even if you have an
17 excursion you will get to some point and it will --
18 and that's below the power range?

19 MR. GILMER: Any others before we
20 continue?

21 Okay, the TRACG code is being used to
22 evaluate the core thermal hydraulics, and ACRS has
23 seen that before in the preauthorization phase, and we
24 will be discussing it further during tomorrow's
25 presentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: How far across is this TRACE
2 code model of this?

3 MR. GILMER: We are doing some independent
4 calculations with Trace Nuclear Development, versions
5 --

6 MR. WALLIS: It models the core and the
7 chimney and all that the same way that TRAC II does?

8 MR. GILMER: Yes.

9 MR. WALLIS: So some time we can see
10 comparisons?

11 MR. DONOGHUE: There is a commitment from
12 staff to show us a set of accidents.

13 MR. WALLIS: Okay, when are they going to
14 do that? They committed at some time in the future?

15 MR. DONOGHUE: Yes. This is Joe Donoghue.
16 There is a lot of work going on, as I mentioned in my
17 opening remarks, and there are calculations. There
18 are results that the staff is still evaluating.

19 MR. SIEBER: But the analysis of record is
20 TRACG.

21 MR. GILMER: Okay, the staff review of
22 Section 4.4 mainly consists of determining if all the
23 conditions and limitations of the current safety
24 evaluations for TRACG applications have been met.

25 And also looking at the input parameters,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 especially the local pressure drop measurements which
2 are documented in a separate topical report which I
3 didn't get the number of, I believe it's 333238 on
4 pressure drop characteristics.

5 The staff has proposed a safety evaluation
6 to apply an operating limit within the critical power
7 ratio penalty similar to what's currently being used
8 in the operating fleet to account for uncertainties
9 such as the power measurement, flow measurement,
10 feedwater temperature measurement, and others.

11 MR. WALLIS: Void fraction prediction?

12 MR. GILMER: Yes. The values are still
13 yet to be determined, because we have some open REIs
14 on void fraction and others that we will reserve the
15 determination of the final value.

16 MR. BANERJEE: So you only decided that
17 there will be a penalty?

18 MR. GILMER: Yes.

19 MR. BANERJEE: Not how much?

20 MR. WALLIS: I thought you said it was .01
21 or something, or you don't know what it is yet?

22 MR. GILMER: Well, that is what is in the
23 operating fleet, and it probably will be in the same
24 ballpark.

25 The GEXL14 correlation was based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 improved method for the GE14 fuel. If there is a
2 topical report, I didn't put the numbers 32851.

3 As Mr. Fawcett mentioned this morning, the
4 correlation uncertainties are based on the ATLAS
5 facility testing in San Jose, and also the STERN
6 Laboratory in Ontario.

7 MR. BANERJEE: But now your spaces are a
8 little different, right?

9 MR. GILMER: That's correct. Actually it
10 enhances the critical power performance with the short
11 part length per hour because of the stagnation
12 effects.

13 MR. WALLIS: But they have done
14 experiments -- yes, they have done experiments of GE
15 or TE?

16 MR. GILMER: Yes -- well, just recently --

17

18 MR. WALLIS: And I guess we're going to
19 get to look at the results some time?

20 MR. GILMER: Yes, that's still to be
21 determined. They have to look at them first, I think.

22

23 MR. BANERJEE: But were these done at the
24 STERN? The ATLAS is shut down, correct?

25

MR. GILMER: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BANERJEE: They were done at the STERN
2 labs?

3 MR. GILMER: The new tests were done at
4 the STERN lab.

5 MR. WALLIS: Did you approve their test
6 matrix at the time?

7 MR. GILMER: No, we haven't. Actually we
8 have an REI 4.4-1.

9 (Simultaneous voices)

10 MR. WALLIS: -- before they responded to
11 the REI?

12 MR. GILMER: Yes.

13 CHAIRMAN CORRADINI: How large is that
14 database?

15 MR. GILMER: Can GE address that?

16 MR. FAWCETT: Hi, this is Russ Fawcett.

17 The test that we just completed, the full
18 scale test of GE14E I think in qualitative terms it is
19 consistent with a full test of steady state data
20 covering the entire range of ESBWR under steady state
21 and transient conditions including transient tests.

22 MR. BANERJEE: What was the maximum power
23 that you get out of this facility?

24 MR. FAWCETT: I'm sorry, what was the
25 question?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BANERJEE: Maximum power in the
2 facility?

3 MR. FAWCETT: The name plate rating on the
4 power supplies is about 16 megawatts. We have
5 delivered power to the assembly in excess of 13
6 megawatts for a full-length assembly.

7 MR. ABDEL-KHALIK: Is the database large
8 enough so that you would not have to rely on prior
9 data for GE14 to establish the uncertainties?

10 MR. FAWCETT: In my judgment it is
11 sufficient to establish a correlation for GE14E.

12 I think we will conclude that the GEXL14
13 is adequate, and there is no need to make any changes.

14 MR. BANERJEE: Did you take any void
15 fraction data?

16 MR. FAWCETT: Not direct measurements, no.
17 By virtue of having assembly pressure drop data, and
18 we have done this, elsewhere, it is an indirect
19 affirmation of the void fraction predictions.

20 MR. BANERJEE: You didn't put a chimney on
21 top?

22 MR. FAWCETT: No, we didn't.

23 MR. BANERJEE: What a pity.

24 (Laughter)

25 MR. BANERJEE: The facility is run by one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of my ex-students, you know, Gord Hadalla.

2 CHAIRMAN CORRADINI: You should have
3 taught him better.

4 (Laughter)

5 MR. GILMER: Okay, the significant -- or
6 I should say ongoing review activities are several
7 topical reports. The key one is the critical power
8 correlation uncertainty of development, 33237. We
9 have reviewed up to revision two, and just recently
10 received revision three around Christmastime, which we
11 have not begun review on yet.

12 And we have been told that the new data
13 will be submitted as a revision to the topical report;
14 Jim, correct me if I'm wrong.

15 MR. FAWCETT: This is Russ Fawcett again.
16 Our plan is to provide a separate -- hi, this is Russ
17 Fawcett. Our plan is to provide a separate report .

18 MR. GILMER: The second one has been
19 mentioned earlier, the nature of core transients,
20 topical. We expect there will be some effects on the
21 core thermal hydraulics. We evaluated based on
22 equilibrium core that --

23 MR. WALLIS: When I was reading all this
24 stuff, I noticed there was an enormous number of
25 technical reports, and I was a little uncertain about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 how much we are supposed to get involved, and looking
2 at those, because it would be a huge task to go over
3 all these topical reports.

4 CHAIRMAN CORRADINI: I think the way we
5 are handling it is, we, are this point, we are looking
6 at the open items, and if we need to delve into it -

7 MR. WALLIS: They keep referring to
8 topical reports.

9 CHAIRMAN CORRADINI: We do have some
10 topical reports in this.

11 (Simultaneous voices)

12 MR. WALLIS: So I mean this isn't enough
13 to hold all the topical reports.

14 (Laughter)

15 CHAIRMAN CORRADINI: No, no, no, this one
16 is the one we've received already, and there is more
17 they are speaking about.

18 MR. GILMER: And 33237. Or the 33237, but
19 not the next two.

20 MS. CUBBAGE: We did not provide those at
21 this time because they were not included in the
22 staff's evaluation.

23 CHAIRMAN CORRADINI: That's fine.

24 MS. CUBBAGE: But we would be happy to get
25 you copies of those now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: When it's
2 appropriate.

3 MS. CUBBAGE: We didn't want you to get
4 confused with too much information.

5 CHAIRMAN CORRADINI: I can't imagine us
6 getting confused.

7 MR. GILMER: Okay, as mentioned, there are
8 several open RAIs on the 33237 that are currently in
9 the safety evaluation. The other topical report that
10 we know will have some affects on the protocol is the
11 order temperature operating domain, which I guess will
12 be discussed later this afternoon.

13 The primary concern, we believe, is the
14 cold water injection of feedwater for certain
15 transients, so we expect them to be done in detail.

16 Summary of current open items. These are
17 the significant ones. The critical power testing for
18 the GE14 fuel. We will start that evaluation as soon
19 as we receive written documentation.

20 The high void fraction data is basically
21 the same issue as in the operating fleet within the
22 Findlay-Dix and we -- the staff feels that the
23 pressure drop indirect determination that came in with
24 the methods topical as a supplement were the 10X10
25 fuel. That's nice to have. It's not all you need,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 since other vendors get the data, we would like to
2 have it from GE also.

3 MR. WALLIS: Did you look at the chimney
4 data? Don't they have some new data with the actual
5 box design? We don't have the Ontario hydro data, but
6 apparently they have some new data.

7 MR. BANERJEE: That was referred to. Do
8 we really have new data?

9 MR. BANERJEE: Have you looked at that?

10 MR. CLIFFORD: No, I have not seen it.

11 MR. WALLIS: You haven't seen it yet? So
12 that could be another open item that was part of the
13 results of these chimney tests.

14 MR. CLIFFORD: That's correct.

15 MR. BANERJEE: So let's clarify this,
16 because it wasn't clear in the statement. We are
17 aware of the Ontario hydro data on the void fraction,
18 but is there additional chimney void fraction data?
19 Do we have a clear answer to that?

20 MR. KRESS: I think I'd like to ask GE to
21 explain, because they were the ones who mentioned it
22 earlier.

23 MR. MARQUINO: There was an RAI, and we
24 provided data from our air-water FIV testing.

25 MR. WALLIS: That's all you have?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BANERJEE: So it's only air-water
2 data?

3 MR. MARQUINO: That's right.

4 MR. BANERJEE: Okay. It will be another
5 open item.

6 MR. MARQUINO: Yes.

7 MR. GILMER: Okay, this past summer the
8 Office of Research did a confirmatory study, or
9 several studies, with the subchannel code COBRAG,
10 which GE has used to evaluate the effects of those at
11 the spacial separation and the rod height and the
12 results of our studies studies, although they are
13 still preliminary, that indicate that nothing is
14 acceptable.

15 I included the critical power uncertainty
16 evaluation as an open item still, because we will have
17 to relook at it for the new test data.

18 Our factor method, we agree that the
19 method is acceptable using the same method as is used
20 for the GE 9 through 13 that we have at RAI that
21 requested a split for GE, 14E specific confirmation
22 based on the test data.

23 MR. BANERJEE: So on this you get this
24 data from the GE14E, you don't really know what files
25 been used and all this sort of stuff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Before you had come,
2 there was a discussion on how they are using the GE14
3 fuel, and doing a back-correction which they consider
4 conservative.

5 But in that discussion this is where we
6 learned about the STERN data, STERN Lab data to look
7 at and compare.

8 Did I characterize that correctly?

9 MR. BANERJEE: The shorter fuel with more
10 spaces.

11 MR. GILMER: Fewer spacers.

12 MR. BANERJEE: Fewer spacers.

13 MR. GILMER: It was two feet shorter, so
14 I don't think there are more spaces.

15 MR. BANERJEE: I mean the distance between
16 the spaces is shorter, right?

17 MR. GILMER: That is what I meant.

18 Okay, in summary, the staff has a
19 reasonable assurance that the methods being used by GE
20 for the core thermal hydraulic design are acceptable.
21 However, the actual determination of values we have to
22 evaluate later when we get to the new data.

23 The same applies to the --

24 MR. BANERJEE: Does GE have any plans to
25 reduce the uncertainties in the void fraction data?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Have they indicated this to you?

2 MR. GILMER: Not to my knowledge. We got
3 a response to the RAI that referred to the GE methods,
4 topical and supplement, the 10X10.

5 MR. FAWCETT: Hi, this is Russ Fawcett.
6 I'll say it's in our interest and in the interests of
7 the fleet to remove that penalty. So it's in our plan
8 to address this issue.

9 MR. GILMER: Okay, any questions?

10 (No response)

11 Okay, well, I'd like to introduce Dr.
12 Weidong Wang, and Jose March-Leuba who will talk about
13 the appendix 4D on stability.

14 MR. WANG: First, stability stability
15 review, actually the data was reviewed by Wilson, who
16 is sitting in the back. For the rest of the
17 presentation I would like to introduce Jose Leuba.

18 MR. MARCH-LEUBA: Yes, so we are going to
19 talk about stability. And I heard the whole morning
20 that everyone was waiting for this topic.

21 There are two items that we are covering.
22 The first is Appendix D of Chapter 4, which covers the
23 stability of ESBWR, and Chapter 21 which is the
24 coverage of the methodology which is TRACG. And we
25 were in there with the members especially this side of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the table on the review of strategy in 2006.

2 We had two full committee meetings one-day
3 long, one full committee, when we went through the
4 stability of ESBWR and the ability of TRACG to ESBWR.

5 MR. BANERJEE: I was there for one.

6 CHAIRMAN CORRADINI: Now that I'm trying to remember
7 it, but go ahead.

8 MR. MARCH-LEUBA: The issue that we had at
9 that time I remember was the nodalization.

10 There was an issue -- there has been an
11 ACRS issue from TRACG with a positive letter from this
12 committee saying that we should be approved for use of
13 --

14 MR. WALLIS: The issue was a courant
15 number, and the artificial dumping of fluctuations.

16 MR. MARCH-LEUBA: The only issue remaining
17 was the nodalization of the chimney. So let's
18 backtrack and talk about what the regulatory guidance
19 is, what does the law say.

20 And we have GDC 12 and 10 that tells us
21 what to do. GDC 12 tells you that oscillations should
22 not be possible. If they are possible, you should be
23 able to detect and suppress them.

24 If you go the route of detect and
25 suppression, then you invoke GDC 10 and say you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 suppress them, you have to suppress before SAFDL are
2 violated.

3 We also have guidance from SRP 15.9 which
4 is the BWR stability and 15.0.2 --

5 MR. WALLIS: When it says oscillations,
6 presumably it means growing oscillations?

7 MR. MARCH-LEUBA: Actually, the
8 possibility of --

9 MR. WALLIS: Because some sort of
10 minuscule oscillation is always possible.

11 MR. MARCH-LEUBA: That's correct. And
12 that's why the GDC actually says oscillations with the
13 possibility of causing damage to the reactor. And
14 that the deceleration is already 15.9 because you
15 always have noise. You always have oscillations.

16 The ESBWR designed team at GE has decided
17 to go the route of GDC 12 to demonstrate by analysis
18 that instabilities are not possible. And they do this
19 because in the most unstable point in the ESBWR is
20 actually the normal operating condition. So if you
21 don't design this reactor to be stable it will never
22 work. And the operating fleet, indeed, most reactors
23 now have a calculated deviation of greater than 1.
24 The reactors that are operating right now are unstable
25 at some operating condition which is very unlikely to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be reached.

2 So the ESBWR team decided to prove by
3 analysis that it's stable. The downside of that is,
4 any change they make like for example in the review of
5 GE14E they changed a spacer. You have to redo the
6 analysis again, and demonstrate with new spacer design
7 you are unstable. Let's go to the next slide.

8 MR. BANERJEE: There is nothing like
9 making assurance doubly sure.

10 MR. MARCH-LEUBA: I'm going to move on two
11 or three slides, there is a defense in depth in which
12 the DCD has committed to have an OPRM-type scram, and
13 the DCD actually mentions the SSCD. There is an RAI
14 open to specify exactly what I mean by that.

15 Do you want DSS/CD or what is it that you
16 are going to use, because it is only one sentence in
17 the DSS/CD.

18 But there is a commitment, and there will
19 be a defense in that with an OPRM scram, which answers
20 your question this morning that protection against the
21 out-of-phase type of instability will be produced in
22 case it happens, in case TRACG was mistaken, in case
23 our analysis is mistaken and we do have an
24 instability, it will be provided by the OPRM scram.

25 MR. BANERJEE: Will that guard against

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 also single channel type instability or small groups
2 of channels?

3 MR. MARCH-LEUBA: Without getting into
4 proprietary nature of all the presentations we have
5 seen in the last month, the argument on the long term
6 solution to stability is that before you have a single
7 channel instability, you have original instability.
8 So the issue you remember as you're trajecting, you
9 become unstable originally out of phase. A little
10 later, in addition to that --

11 CHAIRMAN CORRADINI: Well, if it is
12 proprietary we can go off the record in a closed
13 session.

14 MR. MARCH-LEUBA: It's not proprietary.
15 The proprietary is the use. So the argument is that
16 if a channel is going to become unstable, the
17 likelihood is that the whole core become unstable
18 before the channel becomes unstable, and therefore it
19 would be protected.

20 Or MR. BANERJEE: Not just a likelihood; it's
21 a certainty, right?

22 MR. MARCH-LEUBA: Certainty is such a
23 strong word. There have been two channel
24 instabilities in history. They were both because one
25 channel broke down. So if you -- you can have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 physical changes to one particular channel and make it
2 unstable with the core being stable. But you require
3 some accident or mismanagement of the loading.

4 So during the review we concentrated on
5 three items. First we have what we call the core
6 stability, which is what we are aware of. It's the
7 density-wave instability that all operating reactors
8 would worry about, and you have the channel core 1 and
9 regional oscillation.

10 But in addition because of the specific
11 features of the ESBWR which are new, we have to study
12 the stability of the chimney and the stability of the
13 stack.

14 MR. BANERJEE: The loop oscillation is
15 driven by the chimney.

16 MR. MARCH-LEUBA: In the chimney we were
17 worried about three types of instability modes. One
18 of them is a loop instability, which is a kind of a
19 normative type of instability where the down-comer
20 oscillates against the chimney. We were worried about
21 the floor region use instability. And thirdly, we
22 were worried about the fact that the chimney itself
23 could enhance the density-wave instability.

24 All three were evaluated and came out to
25 be that in the chimney place had no dynamic role in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the ESBWR.

2 The biggest recommendation from the
3 previous review of this --

4 MR. BANERJEE: Were there any -- there
5 were some experiments, or there is even a reactor in
6 the Netherlands which has a chimney, doesn't it?

7 MR. MARCH-LEUBA: There was a reactor in
8 the Netherlands, which was a nuclear reactor that
9 operated for in the U.S. about five or 10 years ago.

10 MR. BANERJEE: How big was the chimney?

11 MR. MARCH-LEUBA: Four or five meters, I
12 don't remember.

13 MR. BANERJEE: Comparable?

14 MR. MARCH-LEUBA: Comparable. It's a
15 smaller reactor, much smaller reactor.

16 (Simultaneous voices)

17 MR. MARCH-LEUBA: It was natural
18 circulation. It operated safely for many, many years.

19 Recently there was some experiments
20 conducted in the --

21 MR. WALLIS: The Genesis.

22 MR. MARCH-LEUBA: The Genesis, which
23 showed some different results. That's a separate
24 item.

25 On the startup stability issues -- all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactors, I mean Brown's Ferry, Susquehanna, starts
2 up, and they're all there. The difference between
3 ESBWR and the operating fleet is that ESBWR is started
4 with a nuclear hit so your reactor is critical when
5 you are at low pressure.

6 So therefore you operate -- and during low
7 pressure the difference in density between water and
8 steam is enormous. So any boiling that you produce
9 produces a tremendous feedback on the density, and you
10 can have very large oscillations on low pressure. You
11 should not operate on low pressure.

12 The solution to this for the ESBWR design
13 team was to start them very slowly. And the idea is
14 to startup and to produce flashing at the top of the
15 chimney by the difference in density -- in pressure,
16 and never ever get voids into the core while you are
17 at low pressure.

18 MR. WALLIS: The slow upgrades seem to be
19 very, very slow to me. I mean they seem to be so much
20 slower than any of the time constants for the system.
21 I didn't understand why it had to be so slow.

22 MR. MARCH-LEUBA: Well, I'll tell you, the
23 biggest constraint, and the reason they did it, is
24 for the heat uprate of the vessel. It's at 100
25 degrees per hour.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Well, that dominates
2 everything then. But the hydrodynamic transients are
3 so much quicker.

4 MR. MARCH-LEUBA: They are but because the
5 vessels have to heat up so slowly, they have to
6 produce heat very slowly, and that prevents having
7 boiling in the core.

8 So there will be instabilities during
9 startup. It's a Type I instability.

10 MR. WALLIS: In the chimney?

11 MR. MARCH-LEUBA: In the chimney.
12 Whenever you flash, you get more flow, and you
13 collapse.

14 MR. WALLIS: In fact, there is no way
15 around it.

16 MR. MARCH-LEUBA: There is no way around
17 it, but it has no consequence. As long as you are
18 still cooling the core, and your CPR is 20 to 40, who
19 cares.

20 MR. SIEBER: Well, they're not divergent.

21 MR. MARCH-LEUBA: They are not divergent.
22 They are not divergent.

23 And all these areas, like I said, we are
24 TRACG SER, which was presented this morning.

25 MR. BANERJEE: The concern is, I agree

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with everything you've said except what -- how did you
2 resolve the flow regime instability issue?

3 MR. MARCH-LEUBA: We resolved it, but we
4 analyzed and we have a small disagreement. We have an
5 RAI issue that has never been resolved. The flow
6 regime instability issue is like for example is when
7 you have bistable flow in the feedwater loop in
8 operating reactors, where you have two possible
9 solutions.

10 Imagine that you are in transition flow,
11 and you could be laminar or turbulent. So you have
12 two possible solutions. Then you have a flow regime
13 instability. You are jumping from laminar to
14 turbulent or from annular flow to slide, and you have
15 different void fractions on the two solutions. And
16 you could be jumping between the two.

17 We calculated a transition of the flow
18 regime, the staff did. And we estimated that the
19 transitions to the annular flow at about 60 percent
20 power. So when you operate at full power --

21 MR. WALLIS: In the chimney?

22 MR. MARCH-LEUBA: In the chimney.

23 MR. WALLIS: You do get annular flow in
24 the chimney, really? I don't think -- that doesn't
25 seem believable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MARCH-LEUBA: Tracking claims you
2 don't transition --

3 CHAIRMAN CORRADINI: You do or do not?

4 MR. MARCH-LEUBA: Do not.

5 CHAIRMAN CORRADINI: Good. It doesn't
6 sound like you would to me. I don't see how.

7 MR. MARCH-LEUBA: So you have slide four,
8 and is, you're far away from the transition rate.

9 MR. WALLIS: Well, the issue there in the
10 limited amount of data that we have seen in steam
11 water was that you see frequencies of oscillations
12 because of the slugging or whatever. I mean it's more
13 churn turbulent than slugging.

14 MR. MARCH-LEUBA: Which are, as I say, we
15 don't know --

16 MR. WALLIS: I think, according to Ishi,
17 you can never get slugging, so it's a big challenge.

18 MR. BANERJEE: Yes, you get churn
19 turbulent flow. It gives you oscillations.

20 CHAIRMAN CORRADINI: This is the concern
21 that you had expressed before, Sanjoy?

22 MR. BANERJEE: Yes, but I was asking how
23 has it been resolved, or is it still an open item.

24 MR. MARCH-LEUBA: The resolution is,
25 whenever you have two-phase flow, if you were to look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at an operating reactor now, you would see that the
2 power of oscillating about 3 percent, and it is
3 because the two-phase flow inside the core is
4 producing the noise, which is the slugging you are
5 talking about. It is the randomness of the voids are
6 causing changes in buoyancy, changes in friction. And
7 the flow is oscillating 3 percent. You will have some
8 noise.

9 MR. BANERJEE: Now you have a large system
10 there which could lead to somewhat larger
11 oscillations.

12 MR. MARCH-LEUBA: Or, well, because of
13 that, we do have oscillations that might cancel out --
14

15 MR. BANERJEE: This was the issue, really,
16 an issue that if you look back there was a question as
17 to whether these were correlated or not. And Ontario
18 hydro data was taken with two gamma densitometers, and
19 one of the issues really was whether cross-correlation
20 were done between those two.

21 Now apparently they weren't. They had
22 these data, but they didn't -- they have the real-time
23 signals, but they did not cross-correlate it to get
24 whether there was a concerted motion going on.

25 And the issue would be if there is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concerted motion, because then you would get fairly --
2 you'd get oscillations which are roughly the same
3 frequency as your core.

4 CHAIRMAN CORRADINI: We are running behind
5 a bit, so I'm -- I'll let you decide. But I guess
6 just one thing to take away, we may have to get back
7 to that, we may have to ask you, Sanjoy, so you think
8 one channel of the 16 could actually synergistically
9 feed the chimney or vice versa? That's what I'm
10 struggling with. You got 16 to 1?

11 MR. BANERJEE: No, it's not that. All of
12 them are feeding it, but in the chimney itself you can
13 start to get oscillations which are pretty -- you know
14 it's a question of how random they are, as you were
15 saying. It's correlated, the whole thing is jogging
16 up and down. It's different from --

17 CHAIRMAN CORRADINI: But the
18 characteristic natural frequency of one would have to
19 somehow intersect with the other to create some sort
20 of synergistic effect, right?

21 MR. BANERJEE: Well, in the chimney
22 itself, you could feed back a pressure wave.

23 MR. WALLIS: Maybe we just have to list
24 these things for our subcommittee meeting.

25 MR. BANERJEE: I think what probably needs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to be done at some point when these RAIs have been
2 answered or something, or even before. Some of these
3 topics will have to be looked at in more detail once
4 again. Maybe they are put to bed, maybe they're not,
5 I don't know.

6 MS. CUBBAGE: Are your questions
7 associated with open items?

8 MR. BANERJEE: I don't know if it's an
9 open item. That's why I asked, is it still an open
10 item, the floor regime stability, or have you closed
11 it?

12 MR. MARCH-LEUBA: We believe we closed it.

13
14 MR. WALLIS: Then we probably need to know
15 how it was closed.

16 MR. BANERJEE: It may be perfectly fine,
17 we just want to know how it was closed.

18 MR. MARCH-LEUBA: So all of these -- there
19 are two SERs associated with this review. One is the
20 TRACG SER which was previously issued, and it was a
21 very large, topical report, 33083, which covered a
22 large -- of applications of TRACG.

23 But in the staff SER for TRACG, we
24 approved the use of TRACG for decay ratio calculations
25 in steady state, and we did -- because of the nature

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the calculation, you cannot calculate a decay ratio
2 during a transient, but we approved that you can use
3 it to demonstrate that the decay ratio in the
4 transient was less than 1.0. So if you run the
5 transient with the proper numerics, and the proper
6 nodalization, and the oscillation does not develop
7 itself, then you can guarantee the decay ratio is less
8 than one, you just don't know how much less than one.

9 MR. BANERJEE: How do you guarantee that
10 the numerical damping isn't actually playing a role
11 here? By just changing the nodalization?

12 MR. MARCH-LEUBA: Two things, changing the
13 nodalization, see that it doesn't go, and do benchmark
14 against real, planned data.

15 MR. BANERJEE: Has there been any
16 confirmatory analysis done with trace?

17 (Simultaneous voices)

18 CHAIRMAN CORRADINI: That is one of the
19 promised calculations in Chapter 15 and 21 that will
20 be done. Audit calculations, is that what you're
21 asking about?

22 MR. BANERJEE: Yes.

23 (Simultaneous voices)

24 MS. WILSON: This is Veronica, I'm just
25 going to correct you for a second. I do believe Trace

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is capable of doing stability, as our friends in
2 research have told us, but it's not planned for the
3 DCD -- to support the DCD in the area of stability at
4 this time, although we've been told --

5 MR. WALLIS: Well, the trace is modeling
6 the tractor who probably --

7 (Simultaneous voices)

8 CHAIRMAN CORRADINI: This is on Chapter 6,
9 so we are going to get to it this afternoon. But what
10 I have written down from the staff SER was main steam
11 line both feedwater rate GDCS injection lines, a
12 number of LOC (phonetic) design basis, is that
13 correct?

14 MR. MARCH-LEUBA: Correct.

15 MR. BANERJEE: So what is the plan again?
16 I missed it.

17 MS. WILSON: LOCUS, AOOs and ATLAS.

18 MR. WALLIS: Once you have those running,
19 you can probably investigate stability without much
20 trouble.

21 MS. WILSON: At the time we did some
22 calculations to support the initial review trace was
23 not available to us as a tool for stability, but Jose
24 used LAPUR.

25 MR. MARCH-LEUBA: The confirmatories were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 done with LAPUR. The LAPUR is a frequency domain
2 code.

3 Next slide, please. This one in
4 conclusion is of the TRACG SER, and you can read them
5 on the SER. Next slide.

6 And all those conclusions were based on
7 the follow-up review of the physical walls inside
8 TRACG, and we did some of the numerical vamping
9 evaluation answering the questions by the members,
10 especially the finalized assessment of the chimney.

11 MR. WALLIS: Did you find that you did not
12 get the void fraction wave attenuating artificially,
13 that propagated all the way down the chimney?

14 MR. MARCH-LEUBA: This was cooler number
15 one.

16 MR. WALLIS: So it didn't change?

17 MR. MARCH-LEUBA: And the most important
18 analysis was the characterization with core
19 organization and the characterization with
20 finalization in that change.

21 MR. WALLIS: Because the core dominated
22 succinctly?

23 MR. WALLIS: Neutronic feedback, the void
24 dominated --

25 MR. MARCH-LEUBA: There's no friction

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pressure at all for the chimney. It's only buoyancy.
2 And in addition to those, we do have a very large
3 TRACG qualification that I include in lateral systems
4 and benchmarks against operating reactors.

5 MR. ABDEL-KHALIK: Now in these numerical
6 simulations was each super cell modeled as a one-
7 dimensional cell -- as a one-dimensional channel?

8 MR. MARCH-LEUBA: Well, the chimneys are
9 a one-dimensional channel, yes.

10 MR. ABDEL-KHALIK: Okay, so the effect of
11 radial variation in power within an individual super
12 cell has not been explored?

13 MR. MARCH-LEUBA: No. No. The issue per
14 cell is held by sixteen channels.

15 MR. ABDEL-KHALIK: Right.

16 MR. MARCH-LEUBA: And there will be a
17 radio power distribution, a significant radio power
18 distribution.

19 MR. ABDEL-KHALIK: Yes.

20 MR. MARCH-LEUBA: The expectation is that
21 all that power will mix shortly after --

22 MR. MARQUINO: Excuse me, are you asking
23 about the staff evaluation, or the GE evaluation?

24 MR. ABDEL-KHALIK: Both. I mean we
25 haven't seen any evaluation of this issue by either

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 GEH or the staff.

2 MR. MARQUINO: In the GE calculations in
3 the DCD there are 16 super bundles or partitions
4 modeled. So we grouped -- we have a grouping. We
5 modeled some individually and we lumped some together.

6 MR. ABDEL-KHALIK: Well, I'm talking about
7 an individual super channel

8 (Simultaneous voices)

9 CHAIRMAN CORRADINI: I think what he's
10 looking for is that, did somebody do an analysis of
11 the 16 flowing into the one, and looking at the entry
12 length where it essentially eventually becomes one
13 dimensional? That's what he's looking for.

14 MR. MARQUINO: We looked at one -- we have
15 one super channel modeled with 15 other ones --
16 actually we have six individual super channels modeled
17 with 10 other ones lumped ones, and we've executed
18 simulations where we perturbed one to come up with the
19 decay ratio. That was part of the LTR evaluation.

20 MR. ABDEL-KHALIK: I guess you are not
21 really answering the question that was posed, what
22 happens with an individual super cell.

23 MR. MARQUINO: You mean within one of them
24 --

25 MR. ABDEL-KHALIK: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: -- we have -- it's a one-
2 dimensional model, and there is something like --
3 well, we discussed finer and coarser nodalization
4 within that one-dimensional model.

5 MR. ABDEL-KHALIK: So no three-dimensional
6 effect within an individual super cell has either been
7 done by GEH or the staff; is that correct?

8 MR. MARQUINO: That's true for GE, yes.

9 MR. ABDEL-KHALIK: Okay.

10 MS. WILSON: This is Veronica Wilson, and
11 this is something I'm going to have to get back to you
12 on, but the staff did do -- in preapplication, a CFD
13 analysis of a super channel. And I unfortunately
14 don't remember the details. So I'll have to look at
15 that and get back to you.

16 But we did look at that in pre-
17 application.

18 CHAIRMAN CORRADINI: Well, we would
19 appreciate that. Thank you.

20 MR. ABDEL-KHALIK: Thank you.

21 MR. MARCH-LEUBA: Now, once we have a
22 TRACG methodology approved, that has been applied to
23 the ESBWR design, and the conclusions of their
24 applications of the ESBWR design is a stable -- as
25 advertised, and that is confirmed by the TRACG

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 calculations on our confirmatory LAPUR calculations.

2 The regional stability mode is the
3 dominant mode for several reasons. Number one is
4 because that's what the code says it is.

5 (Laughter)

6 MR. MARCH-LEUBA: You can generalize with
7 why, because it has a very large diameter. And the
8 decay ratio is approximately of the order of zero
9 point four, which was the design idea.

10 The acceptance criteria is zero point
11 eight. So that gives us a very large margin for
12 stability under the nominal conditions. And there was
13 a CSAU analysis performed on these numbers. I'm sure
14 that the error is less than the point four margin they
15 have.

16 The calculation I'm sure the chimney has
17 a very small effect on stability, and no loop flow
18 type of instabilities have been predicted.

19 And during the startup, as long as we keep
20 the heat-up rate at the prescribed limits, which is of
21 the order or 50 megawatts, and it's 100 degrees an
22 hour, you do not get so cool boiling into the core,
23 and there is no reactivity feedback involved, and the
24 flow oscillations that will happen have no
25 consequence.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. WALLIS: Now when you shut off -- when
2 it is subcritical, you've still got decay heat, and
3 you are cooling this thing. Now you have the
4 opportunity for loop oscillations, but you don't have
5 the feedback from neutron.

6 MR. MARCH-LEUBA: I would say yes.

7 MR. WALLIS: Has anyone looked at
8 oscillations during the long-term cooling or the post-
9 LOCA cooling, when you don't have the neutron feedback
10 which drives these other oscillations?

11 MR. MARCH-LEUBA: To my knowledge, we have
12 not done that.

13 MR. BANERJEE: Is there boiling in the
14 core in these situations?

15 MR. WALLIS: Maybe it's all single phase.
16 Well, they're boiling off, aren't they? So there must
17 be boiling presumably.

18 MR. BANERJEE: There is boiling somewhere.

19

20 MR. WALLIS: Boiling somewhere.

21 (Simultaneous voices)

22 MR. MARCH-LEUBA: So the conclusions for
23 the SER are the GDCS pool will be satisfied because
24 the stability is a highly unlikely in ESBWR, and by
25 going through this route, we have to demonstrate that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 instabilities are highly unlikely for every core
2 boiling, and indeed GD plans to calculate every core
3 boiling and guarantees compliance for future course,
4 and in addition we have a defense in there mechanism
5 which is a detecting supersolution.

6 MR. BANERJEE: Now this is still an open
7 item?

8 MR. MARCH-LEUBA: It is an open item for
9 a couple of reasons. Number one, the DSS/CD has not
10 been approved for use on the ESBWR.

11 MR. WALLIS: Nothing has been approved.

12 MR. MARCH-LEUBA: Yes, but specifically
13 it's mentioned in the last systemic report that is not
14 applicable to anything beyond BWR6s. I think it was
15 an oversight.

16 MR. BANERJEE: We get to approved it then?

17 MR. MARCH-LEUBA: We get to review it,
18 that's correct. We get to review why that statement
19 was made.

20 MR. BANERJEE: Well, we never reviewed the
21 SSCD. It never came to ACRS.

22 MR. MARCH-LEUBA: Maybe not in detail,
23 correct.

24 MR. BANERJEE: We reviewed everything else
25 in detail.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MARCH-LEUBA: I know. So there are a
2 number of open items which are really not related to
3 stability. They are related more to the input
4 parameters that we go into TRACG calculations.

5 So the staff has a number of reviews going
6 with physics -- directions of cross sections that are
7 now under review. And if those change significantly
8 then the stability operation have to be redone. And
9 that's why it's being tracked as the stability of an
10 item.

11 There is an issue with the dynamic of
12 conductance model. GE14E has been under review, and
13 should they come out with an GEXY, the reevaluation of
14 stability will have to be done.

15 So this is a type of stability oversight
16 that we have. The obvious stability analysis is not
17 complete. There was an RAI issue because they had
18 performed and now was transient, and so there is no
19 oscillation. So the characterization was less than
20 one. But we didn't know how much margin we had. So
21 they are supposed to do some steady state calculations
22 of several points and tell us how much margin we have.

23 And there was another question --

24 MR. BANERJEE: Is that analysis available
25 at the moment?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MARCH-LEUBA: Being performed.

2 MR. BANERJEE: Being performed?

3 MR. MARCH-LEUBA: That is a truly open
4 item.

5 MR. BANERJEE: And that -- preliminary
6 indications is there is no ATWAS instability?

7 MR. MARCH-LEUBA: Correct, because there
8 is no recirculation.

9 MR. BANERJEE: Right.

10 CHAIRMAN CORRADINI: Say it again.

11 MR. MARCH-LEUBA: There is no
12 recirculation.

13 MR. BANERJEE: Yes, you are all in natural
14 circulation.

15 MR. MARCH-LEUBA: Yes, you are already
16 there.

17 MR. BANERJEE: That would be a great --

18 MR. MARCH-LEUBA: It's a big selling
19 point.

20 MR. MARCH-LEUBA: It's a big selling
21 point. Finally, during the startup analysis, the
22 analysis assumes constant serum. And because it's so
23 slow, serum exchange. And so have issued some REI for
24 them to justify or do calculations.

25 MR. ABDEL-KHALIK: Now, what are the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operability requirements for this detect and suppress
2 stability solution?

3 MR. MARCH-LEUBA: I do not know, because,
4 again, that's part of the REI. It's not the licensing
5 basis. It's a defense in depth. So we have not seen
6 the tech specs, proposed tech specs. But they might
7 be different.

8 MR. BANERJEE: So you are basically
9 excluding the normal -- almost every situation from
10 stability problem, the wholesale map. If you get into
11 it, it's a good idea to have something.

12 MR. MARCH-LEUBA: It's a good thing to
13 have just in case.

14 MR. BANERJEE: You never know.

15 MR. MARCH-LEUBA: So it is a defense in
16 depth, so we are waiting for a proposal on the tech
17 specs.

18 MR. WALLIS: But this looks like the other
19 issues we heard about today. I mean there isn't any
20 sort of show stopper. There is nothing big. It's
21 just tidying up the issues which you think have
22 already been resolved.

23 MR. MARCH-LEUBA: That is correct.

24 MR. BANERJEE: The only thing that bothers
25 me is that we don't have a flow loop with even a small

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 number of channels that actually show this thing in
2 some sort of typical way. It's all calculations.

3 MR. WALLIS: This is this Genesis thing,
4 which is a Freon loop.

5 MR. MARCH-LEUBA: Near the land slope,
6 yes?

7 CHAIRMAN CORRADINI: You are more worried
8 about the coupling, Sanjoy? What are you worried
9 about?

10 MR. BANERJEE: I'm worried about
11 everything.

12 (Simultaneous voices)

13 MR. BANERJEE: There are so many things
14 that bite you in complicated systems.

15 (Simultaneous voices)

16 CHAIRMAN CORRADINI: Given that it behaves
17 as a one-dimensional system, there doesn't appear to
18 be a show stopper. And you are still concerned about
19 recoupling in between.

20 MR. BANERJEE: Yes.

21 CHAIRMAN CORRADINI: If I understand.

22 MR. BANERJEE: It would have been nice to
23 have had a facility like the stone facility with the
24 chimney running full height bundles. A bit of
25 assurance that the thing would work.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Other comments?
2 Thank you very much. We are due to come back at 1:00.

3

4

Are we going to discuss Chapter 6?

5

6

MR. ARMIJO: Before we leave Chapter 4 I
just have one thing. And that was, we didn't talk
7 about the conclusion on the materials.

7

8

CHAIRMAN CORRADINI: That was purposefully
9 -- I think they mentioned --

10

11

MR. ARMIJO: They are going to whip by
that?

12

13

14

CHAIRMAN CORRADINI: They said materials
won't be part of today's presentation, but we can ask
questions.

15

16

17

18

MS. CUBBAGE: And I will caution you as we
speak that our materials lead is going to be back this
afternoon as part of the Chapter 6 presentation, but
they are not here at the moment.

19

20

21

MR. ARMIJO: I'll hold it to Chapter 6.

CHAIRMAN CORRADINI: So let's adjourn, and
we'll get back at 1:00 o'clock.

22

23

24

25

(Whereupon at 12:12 p.m. the
proceeding in the above-
entitled matter went off the
record to return on the record

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at 1:05 p.m.)

2 CHAIRMAN CORRADINI: So let's go back into
3 session.

4 And we have GEH here to talk to us about
5 the engineered safety features.

6 Is it Mr. Watkins who is going to kick
7 off?

8 OVERVIEW DCD CHAPTER 6 - ENGINEERED SAFETY FEATURES

9 MR. WATKINS: Good afternoon. My name is
10 George Watkins. I am the regulatory affairs engineer
11 for Chapter 6, Engineered Safety Features.

12 Today we are going to present a brief
13 overview of the material section, the presource and
14 insource inspection program for the ESF system.

15 We will discuss containment design and the
16 containment performance analyses, and our emergency
17 core cooling system design features and performance
18 analysis.

19 I have Jerry Deaver here. We will be
20 primarily discussing system design features. We have
21 Brian Frew, who is our materials expert, who will talk
22 about material section in ESF materials.

23 And Dr. Chung (phonetic), who is the
24 performance analysis guru for us, who will discuss
25 our containment and ECCS performance analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 We are going to start with the materials
2 discussions and the preservice and inservice testing
3 programs. And then we're going to move to the
4 containment systems and emergency core cooling
5 systems.

6 So with that, Jerry, you can begin.

7 MR. DEEVER: I guess, maybe, before we
8 start here, there were at least one question from this
9 morning's session related to carbon content of alloy
10 600 materials. And Brian with the code case.

11 MR. FREW: The code case specifies maximum
12 carbon content of .050 percent.

13 MR. DEEVER: Okay, in 6.1, basically this
14 section covers engineered materials for engineered
15 safety systems, and the intent of this section is to
16 ensure that material interactions do not occur that
17 impair the operation of the safety related systems.

18 And related to that it wants to make sure
19 that the material selection also isn't impacted by
20 environmental conditions during either normal
21 operation or postulated accident events.

22 Basically materials with the engineered
23 safety systems and containment are fundamentally the
24 same as we did in the past. Specifically due to
25 debris, we specified that like for insulation, for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 piping and for the vessel and so forth, that only
2 metallic insulation is allowed in containment. And so
3 this hopefully will take care of issues related to
4 debris issues and that.

5 With regard to protected coatings, we to
6 the maximum extent possible will be meeting the
7 requirements of Reg Guide 154. But there are small
8 exceptions, things like valve handles and face plates
9 and things like that that come with standard
10 equipment, and in some cases may not have the approved
11 materials. But those should be very small.

12 And we basically have been minimizing the
13 amount of equipment in containment. It's pretty much
14 limited to valves and so forth.

15 MR. ABDEL-KHALIK: So you would depend on
16 these requirements that you list suppliers; is that
17 what you are saying?

18 MR. DEEVER: Definitely, yes. You know
19 the bigger surfaces are the containment liners and
20 surfaces like that that need to be painted. So we
21 would be using a glue epoxy material for that. But in
22 the procurement of valves we will, to the maximum
23 extent possible, try to limit the materials that are
24 not allowed.

25 So anyway, that's the material covered in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 6.1.

2 Going on to 6.6, which is the preservice
3 and inservice inspection, that's an area where
4 basically this section covers Class 2 and Class 3.
5 Class 1 was, the content of that is contained in
6 Chapter 5. So this pertains only to Class 2 and 3.

7 Fundamentally the approach is that we are
8 meeting the requirements and specifying the
9 requirements of ASME Section 11 as preservice and
10 inservice inspection, and because we are a new plant,
11 the inspection access, all those areas we expect to
12 fully comply with those kind of topics so that there
13 won't be any exceptions.

14 So there's quite a few topics covered in
15 this section, but they pretty much boil down to that
16 we're following the ASME code as a standard, and fully
17 expect to meet those requirements.

18 MR. SHACK: Okay, so you are saying you
19 are going to fully meet the accessibility
20 requirements?

21 MR. DEEVER: That is basically what we are
22 attempting to do. I don't know of any circumstances
23 at the moment where we wouldn't be able to meet them.
24 But we haven't gone through the detailed design yet.
25 So, but that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SHACK: But that was an issue in
2 Chapter 5, right, with some of the pressure bound
3 components?

4 MR. DEEVER: Well, that was a point of
5 discussion. Remember, we talked about a code case
6 that for ISI purposes narrowed the inspection area
7 down.

8 So using that code case we are fully
9 compliant with the pressure vessel.

10 So there was an issue of preservice
11 inspections. In some cases we are going to have to do
12 inspections from inside the vessel on the nozzle, the
13 feedwater nozzle.

14 But when it then goes to Section 11 for
15 ISI then the code case is invoked, and we are fully
16 committed to the requirements.

17 MR. MAYNARD: Due to the taller vessel and
18 similar components in there, will the existing ISI
19 type equipment, examination equipment, work? Or are
20 you going to have to design or build any new equipment
21 for testing?

22 MR. DEEVER: No, the same basic approach
23 will apply. The insulation will be a stand-off
24 insulation that will give us space of basically we've
25 been using automated inspection equipment that tracks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on the weld seams, and there is no reason that we
2 won't be able to use that same type of equipment.

3 You know our round nozzles and stuff, they
4 typically put tracks to go around. Actually a point
5 that we are stressing, and we're buying pressure
6 nozzles right now, is that we want everything
7 associated with ISI to be the same, so that if
8 somebody is going to an ESBWR plant they can fully
9 expect all weld seams to be in the same location, and
10 nozzle diameters and everything to be the same, such
11 that they can go in with standard equipment. Okay?

12 Any other questions on 6.6? Okay then,
13 now we move on to 6.2, which is containment systems.
14 Basically our containment system is typical of past
15 containment systems in that they include a dry well,
16 a wet well space. In our case we have the PCCS
17 system, the Passive Containment Cooling System, is
18 part of our containment boundary, and function of the
19 containment.

20 We have the containment isolation valves,
21 which are typical.

22 So I'll describe the next figure.

23 MR. WALLIS: So you say PCCS is part of
24 the containment. That means each tube is part of the
25 containment?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Basically it's part of the
2 containment valve.

3 MR. WALLIS: It's true it's part of the
4 containment.

5 MR. DEEVER: And in 6.2 we also cover the
6 performance analysis.

7 MR. WALLIS: The isolation condenser has
8 penetrations then, or how does that work?

9 MR. DEEVER: Yes, it has piping
10 penetrations. That is a little different scenario, in
11 that that's a system that is under full pressure, sees
12 the full pressure of the vessel. Whereas the PCCS
13 system only sees the containment conditions.

14 CHAIRMAN CORRADINI: But to follow up
15 Graham's question, that still penetrates and therefore
16 is part of the containment boundary, the IC?

17 MR. DEEVER: The IC system is, yes.

18 Okay, as I mentioned another part of 6.2
19 is the analysis of the containment systems, and that
20 will be covered by Mr. Chung later on.

21 The ESBWR incorporates a pressure
22 suppression containment design that has been used on
23 prior plants.

24 Next figure, let me see.

25 MR. WALLIS: This is peculiar. This is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 probably about the PCCS. And the PCCS doesn't have a
2 box around it like that.

3 MR. DEAVER: Well, here is the figure that
4 --

5 (Simultaneous voices)

6 MR. DEAVER: Basically --

7 MR. WALLIS: There is no box there.

8 MR. DEAVER: Well, the boundary, we have
9 defined the boundary to go around the PCCS.

10 MR. WALLIS: If you put a box in there,
11 then the water can't get to it. So I mean there is no
12 box around the tubes, right?

13 MR. DEAVER: No.

14 MR. WALLIS: No physical boundary like
15 that.

16 MR. DEAVER: The boundary is the tubes.

17 MR. WALLIS: It's misleading. It looks as
18 though you put a box around the whole thing.

19 CHAIRMAN CORRADINI: I think that's just -
20 - the let the artist have too much license.

21 (Simultaneous voices)

22 MR. DEAVER: But basically the boundary is
23 the -- you have a dome of the containment head here,
24 and so we have a little line around the PCCS
25 condensers. But in fact there is the penetration and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the tubes.

2 And then we have the upper dry well, the
3 suppression pool and wet well area, and the lower dry
4 well area. A little different in the ESBWR design is
5 the fact that the upper and lower dry well areas
6 communicated; previously we had a skirt that blocked
7 those two areas.

8 And the other key feature is that the
9 suppression pool is an elevated suppression pool as
10 compared to prior designs, which allows us some
11 ability to transport water into the vessel if
12 necessary under accident conditions.

13 What's also unique is the GDCS pool, which
14 is a capacity system which will inject water.

15 MR. WALLIS: There is no isolation of the
16 PCCS system?

17 CHAIRMAN CORRADINI: That is a matter of
18 debate for an open item, I think.

19 MR. WALLIS: In this design so far there
20 isn't?

21 MR. DEEVER: No, there are no valves.
22 It's truly a passive system in that it's an open
23 system, it'll function without any moving parts
24 currently.

25 And that -- we feel that that is a good

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 way to design the system.

2 Fundamentally with the low pressure that
3 the containment would experience, of the components
4 that make up the condenser are at very significant
5 design margins because --

6 MR. WALLIS: I think they are designed to
7 100 and something PSI, aren't they?

8 MR. DEEVER: Well, that is the containment
9 design pressure. But the components themselves, the
10 piping components, are fully capable of going up to
11 1000 psi. I mean there is no reason --

12 CHAIRMAN CORRADINI: You mean the piping
13 itself?

14 MR. DEEVER: The piping itself, yes.
15 Because they meet heavy duty components.

16 CHAIRMAN CORRADINI: So I guess I was
17 looking for this, and if this is the wrong time,
18 eventually. I'm curious on how you couple the piping
19 through the concrete pressure boundary and the shall
20 I say the details of how I take thousands of pipes
21 through a pressure boundary and they hit the next
22 pressure boundary.

23 That made me curious, and I couldn't find
24 a drawing of that. Where should I look?

25 MR. WALLIS: Is it thousands of pipes? Or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is it just one?

2 CHAIRMAN CORRADINI: Is it one big header?

3 MR. DEEVER: Well, are you talking
4 specifically the XE unit? The PCCS.

5 CHAIRMAN CORRADINI: Is there one big
6 header?

7 MR. DEEVER: There is one pipe, basically
8 you have an open-ended pipe in the containment here,
9 and that is the seed path into the unit. A little
10 hard to see.

11 CHAIRMAN CORRADINI: And then so that is
12 the transition. Then from then on it's essentially a
13 main header that goes into the actual tubing.

14 MR. DEEVER: Well, it's channeled to the
15 top, and then there is piping that goes across and
16 goes into the upper header and channels the steam down
17 into the unit itself.

18 So -- is that kind of clear then? Okay.

19

20 So that is the containment system. Then
21 this is a little more detail of the PCCS system. This
22 is the condenser unit itself. It's in the upper part
23 of the containment. We have two lines that come from
24 this unit, one that is the condensate water that comes
25 out of the unit, and it's taken to the GDCS pool where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it replenishes water supply in that pool. And the
2 other line is one that goes to the suppression pool.
3 This is where any non-condensable gases are vented in
4 the case of an accumulation of gases.

5 MR. WALLIS: Only if the drywell pressure
6 exceeds the suppression co-pressure.

7 MR. DEEVER: Yes.

8 MR. WALLIS: And can overcome the
9 hydrostatic head in the suppression pool?

10 MR. DEEVER: Right.

11 CHAIRMAN CORRADINI: We're talking a blow
12 down into a suppression pool, right?

13 MR. DEEVER: That is the venting of gases
14 we are talking about at the moment, yes.

15 CHAIRMAN CORRADINI: The initial phase?

16 MR. CHEUNG: In the long term phase.

17 CHAIRMAN CORRADINI: I'm sorry, could you
18 repeat it? I apologize, I misunderstood. I'm sorry.

19

20 MR. DEEVER: I was just discussing the
21 fact that there is a vent system for nondensables,
22 because that would affect the performance of the
23 condenser itself. So we have a -- we can open up the
24 system to be --

25 MR. WALLIS: But again, your analysis has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 done something very strange. And in fact the big pipe
2 goes through the containment. The big pipe there.

3 MR. DEAVER: This is the inlet.

4 CHAIRMAN CORRADINI: But that is a big
5 pipe.

6 MR. DEAVER: Concrete was across the
7 bottom.

8 CHAIRMAN CORRADINI: But that is the
9 pressure boundary.

10 MR. DEAVER: Yes.

11 CHAIRMAN CORRADINI: That's what I guess
12 I'm still looking for.

13 MR. DEAVER: The passive boundary is the
14 unit pipe, the branch piping, the IC unit itself, and
15 it clearly penetrates back into --

16 CHAIRMAN CORRADINI: So there is a main
17 header inlet and then two main header outlets that
18 essentially reconnect back up to the concrete
19 pressure valves?

20 MR. DEAVER: Yes.

21 CHAIRMAN CORRADINI: Okay.

22 MR. DEAVER: One additional feature that
23 is not shown on this figure that will be on revision
24 five of our DCD is a blower that will be installed in
25 the noncondensable side, gas side of this system. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's being put in there to facilitate, you know,
2 once everything reaches equilibrium condition, we
3 still want to facilitate the PCCS condensers to
4 operate, and with a blower it'll facilitate seed flow
5 or flow into the condenser, and it'll continue to
6 provide cooling within the containment.

7 And that's a feature we are depending on
8 between three and seven days.

9 CHAIRMAN CORRADINI: Can we just go back
10 to that branch coming out of the 300 BD (phonetic)
11 line?

12 MR. DEAVER: Yes.

13 CHAIRMAN CORRADINI: So one is a 100 AB
14 line and a 200 EB line, and there is a straight there
15 where the condensate will drain to the GDCS pool, and
16 supposedly the noncondensers will go into the
17 suppression pool?

18 MR. DEAVER: That's correct.

19 CHAIRMAN CORRADINI: And that is
20 accomplished how? By just drainage?

21 MR. DEAVER: Yes, of just natural --

22 CHAIRMAN CORRADINI: It's like a wet -- or
23 like a hot well collection point for the water, and
24 the gases will go in a separate direction? I'm just
25 trying to envisage -- not the inlet. I'm talking the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 outlet. You've got a line draining through the
2 suppression pool which takes the non-condensable
3 gases. And you've got a line which is the condensate
4 drain line back to the GDCS, right?

5 MR. DEEVER: I'll have Mr. Gels, he's the
6 system engineer for the system. He can better explain
7 that.

8 MR. GELS: My name is John Gels. The
9 physical arrangement is that the condensate line comes
10 off the bottom of the lower drome, returns to the
11 upper drywall to the GDCS pools. The event comes off
12 the upper portion of that drome, so the fluid will
13 collect in the bottom.

14 CHAIRMAN CORRADINI: So it's essentially
15 like a steam drome?

16 MR. GELS: Yes.

17 MR. WALLIS: So it's not as drawn here?

18 MR. GELS: Yes.

19 MR. ABDEL-KHALIK: Could you tell us
20 something about the flow water? You just mentioned
21 that you will add in?

22 MR. DEEVER: Yes, we are finalizing some
23 of the details on that. The fundamentals are that it
24 is to facilitate a forced flow to be able to pull flow
25 into the inlet of the IC unit. '

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ABDEL-KHALIK: Physically where is
2 that blower going to be mounted, where on the line at
3 the inlet?

4 MR. DEEVER: John, can you help me with
5 some of the details? We've had a couple of options.
6 One is to power it from the outside, or inside, and so
7 forth.

8 MR. GELS: Well, I believe the current
9 thinking, and I think Wayne can correct me if I'm
10 wrong, but the blower will be installed to come off of
11 the vent line, and there will be downstream from the
12 TM vent line, and it will blow its discharge into the
13 GDCS pool area.

14 CHAIRMAN CORRADINI: I'm not understanding
15 -- so one what you are talking about is not on the
16 picture.

17 MR. GELS: That's correct.

18 CHAIRMAN CORRADINI: Okay, and two, the
19 flow path is to the GDCS pool, not to the suppression
20 pool?

21 MR. GELS: That is correct.

22 MR. WALLIS: It seems strange.

23 CHAIRMAN CORRADINI: I'm confused then,
24 I'm really confused.

25 So this is an active system?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: You're going to start up the
2 blower when we have power.

3 MR. MARQUINO: When we get to some
4 response codes, Dr. Cheung will show --

5 (Simultaneous voices)

6 MR. MARQUINO: So the function of the
7 blower is to rapidly reduce the pressure in the
8 containment at three days, and it does this by
9 actively purging the condenser of non-condensable gas.

10 Without the blower the condenser will
11 exactly match the steam generated from the core. So
12 you will always match the core steam generation, but
13 you move -- drop the pressure --

14 CHAIRMAN CORRADINI: So can I say it to
15 you backwards?

16 MR. MARQUINO: Yes.

17 CHAIRMAN CORRADINI: So when the staff
18 asked you in the REI questions saying, how come it's
19 not coming down, to bring it down, what you are really
20 saying is you are coming to an equilibrium at a high
21 pressure. And without this you will never come down?

22 MR. MARQUINO: Bingo.

23 CHAIRMAN CORRADINI: Thank you.

24 MR. MAYNARD: But that only comes into
25 play after 72 hours, after three days?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: Yes.

2 CHAIRMAN CORRADINI: I just want to make
3 sure we are clear. All your curves are doing this
4 where the slope looks asymptotically going to zero in
5 their result.

6 So the question about why isn't it
7 negative. And the answer is, you are achieving a new
8 equilibrium in the containment by this passive
9 approach. You would just raise the whole atmospheric
10 condition up, and it would not come back down, save
11 heat leak out of the building which is almost zip. So
12 it would very slowly creep down.

13 MR. WALLIS: I think it's worse; at 72 it
14 was still going up.

15 CHAIRMAN CORRADINI: Well, that -- the
16 staff asked the question is it up, is it down. MR.
17 KINSEY: This is Jim Kinsey from GE Hitachi. In about
18 two or three slides further into this presentation I
19 think you will see some of that detail.

20 MR. DEAVER: Yes, this was meant to be a
21 little bit of an introduction of what we have added to
22 this.

23 CHAIRMAN CORRADINI: That helps, thank
24 you.

25 MR. DEAVER: Okay, next we'll turn it over

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to Chester to talk about the containment performance.

2 MR. CHEUNG: We will use the summary of
3 the containment performance analysis.

4 GEH uses the TRACG to analyze containment
5 analysis of performance. The TRACG have been rebuilt
6 in 2003, and the application for U.S. performance have
7 been approved, accepted in 2004.

8 Since then we have performed additional
9 study to address the SER confirmation items. We also
10 have performed quite a bit of parametric cases to
11 address an issue that relates to the design change and
12 also the nodalization change.

13 And the performance system -- containment
14 system performance analysis includes the containment
15 pressure, temperature, the nominal condition as well
16 as bounding conditions, and also TRACG is used to
17 analyze the negative pressure between the drywell and
18 wetwell.

19 MR. WALLIS: This is 1D code or is it 3D
20 code?

21 MR. CHEUNG: TRACG is a 3D code.

22 MR. WALLIS: But you don't do much 3D
23 analysis of the containment, do you?

24 MR. CHEUNG: We model the containment with
25 TRACG. We did a TRACG. We have a radial and axial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 margin more or less like a pseudo --

2 MR. WALLIS: Oh, you do? Okay.

3 MR. CHEUNG: And to go back a little bit,
4 we use the TRACG to model the whole containment. And
5 we believe that we have the --

6 MR. WALLIS: So it will show
7 stratification on the containment? It will model
8 stratification and the containment? Or is the
9 containment supposed to be mixed?

10 MR. CHEUNG: That's the next slide. We
11 forced it to maximize the pressure.

12 MR. WALLIS: To stratify?

13 MR. CHEUNG: We forced it to.

14 MR. WALLIS: You forced it to stratify.
15 So TRACG doesn't do that itself?

16 MR. CHEUNG: TRACG doesn't do a good job
17 on that. And we may have a hard time to certify how
18 much stratification is going to be forced.

19 CHAIRMAN CORRADINI: Hundred percent
20 stratification of what?

21 MR. CHEUNG: In a suppression pool
22 surface, and also in a wetwall top area. We are going
23 to the next slide.

24 MR. WALLIS: Because he will show us. Is
25 that in the containment vessel itself, you put the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 steam on the top or something?

2 MR. CHEUNG: Within the containment, we
3 have.

4 MR. WALLIS: But they are all separate
5 nodes. And then the drywall is no node, or is it lots
6 of nodes?

7 MR. CHEUNG: No, the drywall is in the
8 order of 30 or 40 nodes.

9 MR. WALLIS: And it can model
10 stratification in the drywall?

11 CHAIRMAN CORRADINI: No, no, no, that
12 isn't what they -- now I understand what he said. It
13 wants to make it two phase with the flow regime, and
14 they forced it to be a pool MR. CHEUNG: No.

15 CHAIRMAN CORRADINI: I thought that's what
16 I interpreted you --

17 MR. CHEUNG: The suppression pool is
18 single phase. We force the suppression pool -- energy
19 cool in the suppression pool, stay at the top of the
20 layer.

21 MR. WALLIS: Unrealistic.

22 MR. CHEUNG: You will also force the
23 leakage from the drywell in the wet well, stay on top
24 of the wet well -- the layer.

25 MR. BANERJEE: Was this methodology
outlined in the application that was --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Simultaneous voices)

2 MR. BANERJEE: So do we have a document to
3 look at?

4 MR. CHEUNG: It was outlined in the
5 application report. The relaxation somewhat change in
6 the code because one of the SER , that we need to have
7 a unique one modeled. And use the same nodalization
8 for containment analysis and also as well as for UCCS
9 analysis.

10 So it's one containment nodalization for
11 all applications.

12 MR. WALLIS: But what's conservative isn't
13 very clear. If you have too high a pressure on the
14 dry well then you pop the containment. But if you
15 have too low a pressure you don't work the PCCS very
16 well. So that's sort of iffy, isn't it?

17 MR. CHEUNG: No. The -- well, let me go
18 back. The containment pressure is simple way to
19 describe it, because -- give me one sec -- only three
20 things, the total amount of gas.

21 MR. WALLIS: We should have dropped into
22 the wet well.

23 MR. CHEUNG: Then you would really get a
24 maximized test. It also depends on the service
25 temperature in the suppression pool which gives you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the partial steam pressure that amount to that wet
2 well pressure.

3 It also depends on when there is leakage
4 from the drywell into the wet well, and the leakage
5 creates a high energy for the dry well, and how they
6 will mix. The contribution of that leakage or energy
7 will be lost.

8 Now going back to the performance of PCC.
9 The wet well always need a pressure. The dry well
10 trying to push same thing into it. If the steam not
11 condense the wet well pressure will be higher. It'll
12 push something into it, and you push too much in the
13 PCC tube, then the PCC can condense more steam than
14 the wet wall.

15 MR. WALLIS: It stops the steam source.

16 MR. CHEUNG: The cell adjust in the sense
17 that whatever amount of steam is generated, you push
18 a certain amount of non-condensable gas accumulating
19 to. You have to keep on going because there is always
20 seventy-two hour cases. You keep on going because
21 there is always small amount of non-condensable gas
22 generated in the core, and find a way to try to adjust
23 the amount being condensed and generated.

24 CHAIRMAN CORRADINI: So the last statement
25 you made is the reason I don't see a zero slip at 72

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hours is radiolytic decomposition?

2 MR. CHEUNG: Yes.

3 CHAIRMAN CORRADINI: And there is that
4 large amount of radiolytic decomposition that
5 essentially it's degrading the performance, or
6 lessening the performance of the PCCS? Because I'm
7 always achieving a new equilibrium and it's slightly
8 higher, slightly higher?

9 MR. CHEUNG: No, the equilibrium -
10 whatever is generated is always condensed. The PCC
11 about six hours, the PCC compartment always higher
12 than indicated.

13 CHAIRMAN CORRADINI: I understand that.
14 But when I said an equilibrium is that you are saying
15 you are generating more non-condensable gas, and
16 enough of it, that it is perceptibly higher and higher
17 pressure.

18 MR. CHEUNG: Because it going
19 into the wet wall --

20 MR. WALLIS: So the pressure on the wet
21 wall is governing.

22 CHAIRMAN CORRADINI: Well, sure. If they
23 are within delta P, they are in equilibrium.

24 MR. CHEUNG: Yes.

25 CHAIRMAN CORRADINI: But your performance
could be degraded by two things. One is leakage not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through the PCCS but undetermined leakage between the
2 dry wall and the wet wall. And second is degradation
3 of the tubes -- degradation of the heat transfer in
4 the tubes by other means.

5 MR. CHEUNG: Test data show that
6 degradation, we already account for that.

7 CHAIRMAN CORRADINI: So I have one
8 question here, but not to be answered here. So you
9 went through a lot of work in 6.1 talking about how
10 you are minimizing stuff. So if I create stuff from
11 a blow down like the main steam line break in
12 containment and generate debris, would it be
13 transported into PCCS tubes, and therefore create an
14 additional heat transfer resistance?

15 MR. DEEVER: Well, what we are doing, just
16 as a protection, we are putting a shield on the inlet
17 to the PCCS system such that debris can't basically go
18 up there and block it. So it's going to be a shield,
19 and it will enable the steam flow to go through it,
20 but it will shield and prevent stuff from getting into
21 the system.

22 MR. WALLIS: A screen?

23 MR. DEEVER: No, well, I envision maybe
24 more like a cone that -- if you come up and hit it it
25 will deflect off, but it won't go around and get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sucked into the pipe itself. It'll have -- that is
2 the visual picture I have that it's going to look
3 like.

4 CHAIRMAN CORRADINI: To be designed. So
5 there are no debris sources about the entry point?

6 MR. DEEVER: Well, initially things are
7 going to be flying around. But you know gravity is
8 going to settle everything down ultimately.

9 So because it's right in the top of the
10 containment, anything that would go up in the area
11 would simply be deflected away, and then it would just
12 drop down.

13 MR. BANERJEE: But even if it was dust.

14 MR. DEEVER: Dust?

15 MR. BANERJEE: Yes, really fine stuff. I
16 mean I guess the concern is whether some of this
17 could get into the tube.

18 CHAIRMAN CORRADINI: So let me tell you
19 where I am going with this, and then you can pick --
20 you choose to talk about it now or later.

21 But you went through a great amount of
22 effort at 6.1 to convince me that you have minimized
23 places that you could generate debris. And I kept on
24 asking myself a question: Why? Where? Why?

25 And then we talk about the performance of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this, and I have this vision of having such a pipe
2 break pointed at something where I generate debris.
3 I don't -- I don't want to use the word, aerosolize,
4 but creating a lot of stuff. And the stuff gets
5 transported in your PCCS, and essentially it creates
6 a fouling factor.

7 Now you are telling me you're going to put
8 in a shield so it doesn't follow it. But then I ask
9 myself, how small of a debris can pass through the
10 fouling, and therefore, what fouling factor penalty
11 must I have to consider. Because you are going to
12 have some; it's a heat exchanger, and with an action
13 such as this, it will follow to some extent.

14 MR. DEAVER: Well, we are basically
15 putting metallic components in containment. And the
16 other reason for minimizing debris is the strains that
17 we would have in the suppression rate.

18 MR. BANERJEE: Who designed the PCCS?

19 MR. CHEUNG: PCCS in the first six hours
20 is not mentioned, then after six hours it's over the
21 line.

22 CHAIRMAN CORRADINI: By how much?

23 MR. CHEUNG: By a factor of two.

24 MR. MARQUINO: This is Wayne Marquino of
25 GEH. As was said we have a fouling factor that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 included, and the spec on the PCCE transfer. The
2 system will be designed to provide more heat transfer
3 initially so that the end of its life, considering
4 fouling, it will perform per spec.

5 MR. BANERJEE: And then establishing this
6 fouling what did you take into account? Did you just
7 pick a number? Or did you do some evaluation?

8 MR. MARQUINO: We picked a number based on
9 the containment pressure analysis that's being
10 discussed.

11 MR. BANERJEE: You did some experiments,
12 and these were pretty close to full scale, right, of
13 PCCS, if I remember?

14 MR. DEEVER: We did one half.

15 MR. BANERJEE: Right.

16 MR. DEEVER: And created a mock up and
17 tested it.

18 MR. BANERJEE: Now did you -- remind me
19 what happened with the noncondensables? Did they
20 actually get pushed out? Or what happened there?
21 Because this was an issue which I remember back from
22 SBWR days.

23 What happened to the non-condensables?

24 MR. CHEUNG: They are pushed out.

25 MR. BANERJEE: They are all pushed out?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHEUNG: They get swept out.

2 MR. BANERJEE: And it doesn't matter what
3 they are, if there is a bit of hydrogen or something,
4 it doesn't matter.

5 MR. CHEUNG: Doesn't matter. But in
6 effect, we depend on the drywell, depend on the
7 location. Some air or some non-condensable do hide in
8 those walls. It takes a long time to mix with the
9 steam.

10 MR. WALLIS: But then they get pushed out?
11 I mean the steam that is pushing them gets condensed,
12 and then it doesn't do much pushing, does it? Because
13 you stick there. As long as the steam keeps
14 condensing, the non-condensables stay there too. They
15 don't have any effect because the steam is still being
16 condensed.

17 If it doesn't get condensed, then it
18 pushes out non-condensable --

19 (Simultaneous voices)

20 CHAIRMAN CORRADINI: If you plotted it
21 down to the non-condensable gas fraction, it starts
22 off high, and it starts coming down. But then it
23 comes to some point, and it now comes to an
24 equilibrium.

25 MR. WALLIS: And the thing could be off

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 code with non-condensables.

2 MR. BANERJEE: In fact, that is exactly
3 what happens.

4 MR. BLEY: So then why do you need the
5 blowers if it still works?

6 MR. WALLIS: It's a self-correcting
7 system. (Laughter)

8 MR. CHEUNG: I will explain that in about
9 two slides.

10 MR. WALLIS: It was trying to self correct
11 and didn't succeed?

12 (Simultaneous voices)

13 CHAIRMAN CORRADINI: Give us a slide
14 number.

15 MR. CHEUNG: Slide number eight. At least
16 the lower portion of it. We have performed a
17 percentage spectrum of rate that include the medium
18 RAI rate, which is the largest brake in the system and
19 the highest elevation.

20 CHAIRMAN CORRADINI: But smallest sizes?

21 MR. CHEUNG: Smallest sizes. And GDC, you
22 can keep in mind, is somewhere in the middle and
23 medium sized, and pre-waterline break is high
24 elevation, slightly higher flow air pickup rate area.

25 CHAIRMAN CORRADINI: If I might just make

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sure I understand.

2 So these are design basis accidents, but
3 particularly challenging given the design to the
4 containment rather than the reactor, because with
5 these, as I understood in a subsequent chapter, you
6 don't get core uncovering. These are ones that are
7 really determining the design basis for the
8 containment systems.

9 MR. CHEUNG: Let me go back. Let me
10 iterate, there is no change in core. We analyzed all
11 nine elevations, or nine penetrations; we analyzed it.
12 Then for containment we picked four, and then we
13 realized that the limiting case would be mentioned
14 right there.

15 CHAIRMAN CORRADINI: So that's how I
16 understood it. But thank you, I appreciate it.

17 MR. CHEUNG: Because we analyzed the
18 spectrum, high or low, and liquid break, steam
19 migrate.

20 Now the key measure for this analysis is
21 to -- is the dry wall pressure. For that matter we
22 have to try to maximize the effect that will give the
23 higher drive of pressure. And in that we assume in
24 the model, in a calculation, we force all the non-
25 condensable emissary in a dry well into the wet well -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1

-

2

MR. WALLIS: All is a big word.

3

MR. CHEUNG: All.

4

MR. WALLIS: All is a big word.

5

MR. CHEUNG: Yes, sir.

6

(Laughter)

7

MR. CHEUNG: And also, all this subsequent generating radial -- generating in the core, find its way into the wet well.

10

CHAIRMAN CORRADINI: But is it a fair -- I just want to make sure we're communicating -- but it's a fair characterization what Graham said before which is, you get this initial discharge, which blows your noxious emissible gases through your system, and then eventually makes it to the suppression pool.

16

But then you come to a point where you are still feeding it gases, which are still some fraction non-condensable, because that is the driving flow, right? You are not going to go to vacuum, so you are driving it with some non-condensable, at some rate.

21

We are communicating there? Because the way you explained it I guess I thought it was exactly the same way.

24

MR. BANERJEE: I think it would be nice if we had a diagram, and you showed us exactly what you

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are doing. Very confusing in words. I don't know
2 what all non-condensables means.

3 MR. CHEUNG: The non-condensable gas
4 usually in the dry well, lower dry well --

5 MR. WALLIS: But it goes through the
6 vents, the big vents.

7 (Simultaneous voices)

8 MR. WALLIS: And stays in there because
9 the valves don't leak.

10 MR. BANERJEE: The vacuum breakers.

11 MR. WALLIS: Don't open?

12 MR. CHEUNG: The vacuum breakers don't
13 open. Well, it opens, come back, and then you go back
14 into it. Because we used a multiple pipe -- we used
15 the nodalization that during the transient alteration,
16 we'll introduce additional force, too.

17 MR. WALLIS: Well, what do you do about
18 condensation in the wet well? I think you assume that
19 all the steam that goes in condenses.

20 MR. CHEUNG: Not all the --

21 MR. WALLIS: You say it is conservative to
22 say all the gas goes in there and pressurizes the wet
23 well. But you could get steam which goes in and isn't
24 condensed.

25 MR. CHEUNG: It stays on the top.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Stays on the top, and that
2 pressurizes away. I don't think you consider that, do
3 you? I think you consider it to be all condensed.

4 MR. CHEUNG: No.

5 MR. WALLIS: No? How do you know how much
6 is condensed?

7 MR. CHEUNG: It depends on the calculation
8 in the amount of steam processing pressure; it depends
9 on the temperature in the code calculation.

10 MR. WALLIS: The code calculation of how
11 much is condensed?

12 MR. UPTON: Chester, this is Hugh Upton
13 with GEH. Maybe it would be better if we walk you
14 through what's done on a containment system diagram.
15 Maybe that will give you a better feel for what's
16 happening.

17 MR. BANERJEE: You have to have a mike.

18 MR. DEEVER: One thing I didn't cover
19 earlier that I should have, and it's probably
20 important to this argument is, we have vacuum
21 breakers. We have three vacuum breakers that relieve
22 pressure between the wet well and dry well. And so
23 that is part of the -- of the interaction that is
24 going on.

25 (Simultaneous voices)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SIEBER: If I could have your
2 attention, it would be good if in your explanation to
3 tell us what happens --

4 MR. CHEUNG: Okay, let me try to go
5 through a little bit. In the very beginning we didn't
6 go out from the wet -- and flow out into the dry well.
7 And what it does is, you mix -- the steam we mix with
8 the initial non- condensable gas in the dry well, and
9 forces it -- the majority will force it through the
10 main way.

11 MR. BANERJEE: Can you stay to the side so
12 we can see?

13 MR. CHEUNG: And so this operation prove
14 that steam condense.

15 MR. WALLIS: But does it?

16 MR. CHEUNG: And the --

17 MR. WALLIS: Does it condense or not?

18 MR. CHEUNG: -- non-condensable gas goes
19 into the dry well.

20 MR. WALLIS: I'm concerned about the
21 condensing models in the wet well. Because you have
22 a big bubble comes out.

23 It can go to the surface without
24 condensing all that much. In which case you get two
25 feet of steam up above, which isn't going to condense

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 very readily.

2 I've never been very happy about the way
3 that is modeled.

4 (Simultaneous voices)

5 MR. CHEUNG: Because the tract is
6 calculated so that these will overpressurize, go right
7 to a dry well, for a time period and then you actually
8 get to an equilibrium point.

9 Now, that process go into -- roll down
10 process go into about a couple of hundred, one or two
11 hundred seconds.

12 MR. ABDEL-KHALIK: What is the volume
13 ratio between the dry well and the wet well?

14 MR. CHEUNG: The dry well is about 7,000
15 cubic meter; the wet well is about 5,000 cubic meter.

16 MR. ABDEL-KHALIK: The gas space in the
17 wet well.

18 MR. CHEUNG: The gas space in the wet
19 well, 5,000.

20 After a short time period, the water level
21 dropped, dropped to level one. Commencing RAI rate is
22 about five per second. Once the Level A initiate the
23 ADS, that means further depressurized RPV, and you set
24 upon that the RPV pressure is lower than the static
25 here, and the water will form. That will go on for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some time period. That's called GDCS period.

2 And what it does is that because --

3 MR. WALLIS: What comes out of the ADS?
4 Is it just steam? Or is it a mixture of steam and
5 water?

6 MR. CHEUNG: Pardon me?

7 MR. WALLIS: What comes out of the ADS?
8 Is it just steam? Or is it a mixture of steam and
9 water?

10 MR. CHEUNG: The ADS --

11 MR. WALLIS: It's up there, but you've got
12 a full swell in the vessel, too. So what comes out of
13 the ADS?

14 MR. CHEUNG: The SRV will see only steam.
15 At that point in time the compressor is steam
16 pressurized.

17 MR. WALLIS: The swell doesn't rise up
18 that high?

19 MR. CHEUNG: No.

20 MR. DEEVER: The RPV part of it just vents
21 to the upper driver.

22 MR. BANERJEE: Now do you have experience
23 of that? Or is it just a calculation, whether the
24 pool swelling will reach the SRV?

25 MR. MARAQUINO: Excuse me. The pool swell

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is in the suppression pool.

2 MR. WALLIS: No, we are talking within the
3 vessel.

4 MR. MARAQUINO: The level swell within the
5 vessel?

6 MR. WALLIS: Level swell, yes.

7 MR. CHEUNG: That -- one -- the reason
8 that the RPV in the SDS is tall. When it fresh, the
9 level not coming up all the way to the line.

10 MR. BANERJEE: But that depends on a lot
11 of things. Because even a small amount of surfactant
12 there would get it right to the top.

13 MR. CHEUNG: The TRACG code having
14 qualified against data on the swell rate.

15 MR. BANERJEE: Right, but this is very
16 tricky. In fact there is a very similar problem that
17 occurs during emergency relief of chemical reactors.
18 And what has been found is even tiny amounts of
19 impurities of one sort or another can change the level
20 swell enormously, because of its surfactant effect.

21 CHAIRMAN CORRADINI: Can I ask a question?

22
23 So you are talking us through the process.
24 So putting that issue aside for the moment, so I
25 discharge a GDCS pool in, and then can you just shut

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 down?

2 MR. CHEUNG: Okay, for some time period,
3 because it's cold water going into the RPV, and then
4 no steam coming out of the RPV. In the sense the
5 steam available in the dry well now is become less and
6 less. And no way to break it open because the PCC
7 condense more steam than a variable.

8 Now if I can break it open then the --

9 MR. DEEVER: (off mic)

10 MR. BLEY: Not anymore.

11 MR. CHEUNG: Some of the non-condensable
12 gas from the wet well going back into the dry well.
13 Now start over again the process.

14 Now you've got in a one hour period,
15 couple hour period, that this air, non-condensable gas
16 and steam, keep mixing and you're going to send that
17 because the system, the PCCS, the dry well pressure
18 always higher than the wet well pressure by amount of
19 that stirred-up heat, and the push, the mixture of
20 non-condensable gas and steam into these wet wells, in
21 the suppression board --

22 MR. WALLIS: It's possible the vent valves
23 of the vacuum breakers have closed.

24 MR. CHEUNG: Yes, because once at higher
25 pressure, then vacuum breakers that closed were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 knocked open again.

2 Now going back to one of those questions,
3 we keep saying that why we want to force --

4 MR. WALLIS: Something by the GDC as it's
5 trying to open the vacuum breakers, including while
6 the PCC is trying to close them.

7 MR. CHEUNG: Yes.

8 MR. WALLIS: So it's sort of a battle
9 between the two.

10 MR. CHEUNG: Yes, but after the GDC
11 injection period, no more sub-cooling in the core,
12 then the vacuum breaker will not open for a long, long
13 time unless external cold water like spray or things
14 like that.

15 Now where one -- a moment ago we keep seeing
16 that we forced all air, on account of a guess, one
17 other thing is one the GDC approved drain -- created
18 drain down water and suck whatever things stuck in the
19 dry well into it. And this is a hideout area because
20 this is a very small opening --

21 PARTICIPANT: High what?

22 MR. CHEUNG: This other level will stay
23 about the pressurization elevation with about 22
24 meter, and that creates water from here to here, about
25 three or four meter; that is 12 feet, and the steam in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here is keep going, going, going, and physically we
2 will have a hard time to go in and make steam and come
3 back out because only one way in. Then the pressure
4 would be lower because that amount of air a long time
5 ago is not going into the dry or wet well.

6 So what we've done is, in the model, is by
7 calculation, we put in another pair of pipes to get
8 some steam into and try to mix it and come back out,
9 and it's exactly purge, all the hideout non-
10 condensable gas in this water and then get it out in
11 here and get into a PCC and eventually get into the
12 wet well. So at the end of the calculation, 72 hours,
13 we can see that no more non-condensable gas in this
14 area or in all these areas.

15 MR. WALLIS: That's probably being
16 conservative.

17 MR. CHEUNG: Very conservative, but to
18 demonstrate that --

19 MR. WALLIS: It's pretty close.

20 MR. CHEUNG: Now that's the main steam
21 line on low air region break to prove we drop all the
22 way to this air region, the hideout void even bigger,
23 in over 15,000 kilometers. And the height, six
24 meters, two stories high. And in that situation, the
25 mixing of the steam with the non-condensable get high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and dry, will be even harder for this kind of gas to
2 get out.

3 CHAIRMAN CORRADINI: Which means that --
4 I just want to make sure I understand -- your point is
5 the fact that it's hiding out there reduces the amount
6 of non-condensable, which sets the pressure on the
7 volume?

8 MR. CHEUNG: Yes.

9 MR. WALLIS: He's doing that anyway to be
10 conservative.

11 CHAIRMAN CORRADINI: That's what he does.
12 But just to be clear it's still improving a driving
13 flow for the circulation to the PCCS. So you still
14 have some small amount of non-condensable gas fraction
15 that is driving the flow through the PCCS.

16 MR. CHEUNG: Yes, because it's a continued
17 channel, yes.

18 CHAIRMAN CORRADINI: And the difference by
19 letting it hide out versus forcing it to mix into the
20 suppression fuel is, what, a few PSI?

21 MR. CHEUNG: A few PSI.

22 CHAIRMAN CORRADINI: Okay. Then the
23 uncertainty of the following of the PCCS?

24 MR. WALLIS: It's a lot, if you take all
25 those non-condensables in the GDCS pool and put it in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the suppression pool you are going to get a fair
2 amount of low pressure, aren't you?

3 MR. CHEUNG: That's what we did. That's
4 what we saw --

5 MR. BANERJEE: Now when you say there is
6 no mixing in the gas space of the wet well --

7 MR. CHEUNG: Now the vacuum breaker is at
8 this elevation, and we assume the leakage. The
9 leakage could be anywhere, but we assume at the top of
10 it, and the hot energy go into it and stay in this
11 layer. It not mix, not mix with this water. Once it
12 mix it, then we have chance that the energy will go
13 down the suppression pool into the surface.

14 MR. WALLIS: If it sticks open then the
15 PCCS pool doesn't work; is that right?

16 MR. CHEUNG: What open?

17 MR. WALLIS: If the vacuum break sticks
18 open it doesn't work?

19 MR. CHEUNG: Oh, yes. It won't work
20 because vacuum breaker has about one square foot of
21 flow air in --

22 CHAIRMAN CORRADINI: Let's hold off on
23 picking on the vacuum breakers. That's Chapter 3.
24 We're still -- we don't want to go there just yet.

25 MR. WALLIS: We're going to give that to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 another meeting?

2 MR. CHEUNG: Let me go back --

3 MR. BANERJEE: I'm beginning to understand
4 what the effect is.

5 CHAIRMAN CORRADINI: I understand.

6 MR. CHEUNG: So we know the assumption is
7 the energy going into a pool. Think about it: 72
8 hour. We assume the non-condensable gas is coming in
9 with slightly higher temperature, and it will stay in
10 this layer. That means keep higher, partial pressure,
11 steam pressure, into the wet well. That's another
12 conservative assumption.

13 MR. BANERJEE: So you're saying it's all
14 coming out at saturation? Or what sort of -- your end
15 game, is it at saturation terms --

16 MR. CHEUNG: The energy goes into this
17 layer.

18 MR. WALLIS: So your bottom layer for the
19 suppression pool doesn't do you any good at all.

20 CHAIRMAN CORRADINI: Yes, well, they force
21 it not to do any good at all.

22 MR. CHEUNG: Yes. I can call you a
23 number. We have --

24 MR. WALLIS: Until you drain it, until you
25 equalize and even though it doesn't do you any good at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 all.

2 CHAIRMAN CORRADINI: You do in the
3 beginning.

4 MR. WALLIS: It doesn't even happen in the
5 beginning, because they don't mix them.

6 (Simultaneous voices)

7 CHAIRMAN CORRADINI: The main steam line
8 break, that is the only time when they are using the
9 full volume for essentially condensing. They need it.
10

11 MR. CHEUNG: Because in the beginning, the
12 physical distance is a blow-down force. You blow it
13 down.

14 MR. WALLIS: You use the liquid below the
15 bottom vent? You still use that?

16 MR. CHEUNG: No, after a couple of hours.
17 Now we have performed prime education. Physically
18 after a couple of hours, or 72 hours for that matter,
19 these pools were mixed by itself. If we turn on the,
20 take out the stratification model, that's 6.5 percent
21 margin we can gain. When we turn off --

22 MR. BANERJEE: Well, what would mix it
23 physically? You have hot liquid on the top. Now why
24 would it mix?

25 MR. CHEUNG: Know why, because this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concrete wall. It doesn't transfer much energy from
2 here to here, but the concrete wall will induce an
3 action flow. This is a large flow area, large water
4 area --

5 MR. BANERJEE: Is it because of heat
6 conduction or what?

7 MR. CHEUNG: The heat conduction from here
8 into the concrete wall. It's small amount, but small
9 amount and long time period, you will induce flow
10 naturally.

11 MR. UPTON: Chester, this is Hugh Upton
12 with GEH. We also have a stainless steel liner inside
13 the suppression pool, which also adds to conduction.

14
15 MR. CHEUNG: Does that answer your
16 question?

17 MR. ABDEL-KHALIK: Timeline, how long does
18 it take to force the non-condensable from the dry well
19 to the wet well?

20 MR. CHEUNG: In the calculation, it takes
21 about 22 hours.

22 MR. ABDEL-KHALIK: But there must be a
23 very high rate initially. So the initial period --

24 MR. CHEUNG: Initial period about half of
25 the mass went into the wet well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. ABDEL-KHALIK: In an hour?

2 MR. CHEUNG: In a matter of a couple of
3 hundred seconds.

4 CHAIRMAN CORRADINI: Just so to make sure
5 each question is understood, his point is, if you take
6 your limiting case, which is the main steam line
7 break, you dump 50 percent of it in the matter of two
8 or three minutes.

9 MR. CHEUNG: Yes, but then later on the
10 vacuum breaker open, and it come back.

11 Now let's move on a little bit before I go
12 on. The pressure keep going at 72 hour without any
13 active system. Now we have put in the PCC vent line.
14 You put in the vent fan from here, branch out, put a
15 blower or fan, and detach it back into the GDC pool,
16 up apart from it because any longer, the other part of
17 it will be drained down, and we'll see --

18 MR. BANERJEE: Now why is that necessary?
19 I mean, I can see it may improve things but is it
20 necessary?

21 MR. CHEUNG: I can give you a couple of
22 examples. The vent fan takes very little power, very
23 little. And what it does is blow the charge the water
24 valve accumulated in a tube to suck it out. When it
25 suck it out, the tube condensation power increase.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BANERJEE: But is it necessary?

2 MR. CHEUNG: Well, if we don't have that
3 fan, we don't have another active means. The pressure
4 will keep going slowly and slowly because in a model
5 we assume the RAI gas keep generating, even a small
6 amount.

7 CHAIRMAN CORRADINI: And you are
8 generating. So here is where I'm confused. You are
9 generating more of a radio ID composition and you have
10 a huge leak out of the building through the concrete?

11 MR. CHEUNG: Yes.

12 CHAIRMAN CORRADINI: And you've done a
13 hand calculation, those two things are not crossing
14 some time?

15 MR. CHEUNG: Well, it takes a long long
16 time, because this is two meter; two meter of
17 concrete, and the thermal layer, what's the conduction
18 in that only one foot in maybe a couple of days. That
19 means outside doesn't see anything happening inside.

20 MR. BANERJEE: Well, that's why you need
21 to suck it out.

22 MR. CHEUNG: Suck it out? Well, two
23 effect. Once you create -- suck the air out, then the
24 PCC condensation will increase right away and then
25 condense all the steam. Once it condense the steam,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 then the dry well pressure will be lower than wet well
2 pressure. Vacuum breaker open. Once they're open,
3 the air -- the amount of gas goes from wet well into
4 dry well. We make the pressure drop further until we
5 get the equilibrium point at the mixture, the non-
6 condensable gas and steam mixture, get into the
7 system, get to another equilibrium point.

8 MR. BANERJEE: But now let's say you
9 didn't have the fan, okay. There would be no
10 equilibrium because you are always getting a little
11 bit of addition of noncondensables.

12 MR. CHEUNG: Yes, that's the reason.

13 MR. WALLIS: From slowly rising.

14 MR. CHEUNG: Yes.

15 MR. MARQUINO: This is Wayne Marquino from
16 GEH. We also added in rev three I think it was gas or
17 oil catalytic recombiners to address the continuing
18 radiolytic gas generation.

19 But again that stabilizes at a high
20 pressure, and the fan allows us to drop the pressure
21 at three days.

22 CHAIRMAN CORRADINI: So there is another,
23 just to make sure I understand all this, what is the
24 state of the pool above the containment shell, which
25 I guess is a steel liner? Is there water above that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHEUNG: Yes.

2 CHAIRMAN CORRADINI: And then you also
3 have a filter -- I want to call it a filter vented,
4 but you can call it whatever you want -- when you get
5 to above a certain pressure you are actually then
6 discharged into another system. Or am I getting this
7 confused with some other design? There's a vent
8 valve, is there not?

9 MR. CHEUNG: I don't see it.

10 MR. UPTON: This is Hugh Upton with GEH.
11 We have a manual containment vent. Is that what you
12 are talking about, in the event, yes? But that's an
13 unfiltered vent.

14 CHAIRMAN CORRADINI: Oh, excuse me.

15 MR. UPTON: No, it's not filtered.

16 CHAIRMAN CORRADINI: It's not filtered?

17 MR. UPTON: No, it's not filtered.

18 CHAIRMAN CORRADINI: Okay. The thing that
19 concerns me is you've gone through all this effort to
20 make this passive. And now all of a sudden at 72
21 hours, bang, you need active. It sounds a bit
22 incredulous.

23 And I'd also I wonder about if it starts
24 operating somewhere else in the system when you don't
25 want it to operate, does it make it worse? What if I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 turn it on when I don't want it on? Is there a time
2 when that might occur?

3 MR. BLEY: You'd be pumping steam then.

4 MR. CHEUNG: The only true thing I can
5 think of, with the pool doesn't drain. You turn on
6 the fan, the air cannot go in because of a high static
7 head. Now --

8 MR. MAYNARD: I don't think GEH ever
9 represented that they could last forever; 72 hours
10 without active equipment and without operator action,
11 but at that point there would be action needed.

12 MR. UPTON: This is Hugh Upton with GEH.
13 The design assumption has always been that it would be
14 passive for 72 hours, and then we would have active
15 systems to deal with the transient.

16 CHAIRMAN CORRADINI: Okay, thank you.

17 MR. BANERJEE: Now if you just use
18 catalytic recombiners, how high does the pressure get?

19 MR. UPTON: It would not increase much
20 over the 72 hour pressure.

21 MR. BANERJEE: Which would be what?

22 MS. CUBBAGE: You might want to go to the
23 slide presentation.

24 (Simultaneous voices)

25 MR. CHEUNG: The key thing now is, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 next thing is in all the DCD calculations, we assume
2 a design base of one square centimeter of leakage. As
3 a design basis.

4 MR. WALLIS: There's a mystery to me. How
5 can you just assume something.

6 MR. CHEUNG: The design base.

7 MR. WALLIS: I mean that must have some
8 basis, beyond those words.

9 MR. UPTON: This is Huge Upton with GEH.
10 Based on his assumption, one square centimeter, the
11 SBWR and the ESBWR team went off with a design
12 requirement to come up with, well, the current
13 configuration that we have in the vacuum break or end
14 of the diaphragm floor to try and minimize the leakage
15 across the diaphragm floor. And we can address that
16 here or elsewhere if you want.

17 We have done extensive tests -- well, do
18 you want me to continue on on this subject?

19 CHAIRMAN CORRADINI: Well, I think if you
20 can quickly do it, but we are going to have to come
21 back to it, because this was something that I had on
22 my list of questions, which is, isn't it assumed? And
23 then you went through and said, well, even given that
24 it could be as big as X, and we would still have
25 performance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So the basis on how you come up with this
2 is bypassed, which I think eventually it's going to be
3 brought up.

4 There is a short answer, and we will come
5 back to it later.

6 MS. CUBBAGE: And that is a significant
7 staff open item at this point; we are waiting for
8 information from GE on that.

9 MR. UPTON: Let me give you a brief answer
10 then to it. The diaphragm floor itself has been
11 designed to minimize the number of penetrations across
12 the diaphragm floor. That's the critical are in the
13 containment.

14 We have -- the diaphragm floor itself is
15 a composite structure of steel, concrete and steel.
16 We have minimized the number of penetrations through
17 the diaphragm floor. We only have three vacuum
18 breaker penetrations, which are 24 inches. Then we've
19 got six PCCS penetrations, which are 10 inches; and
20 we've got four IC vent fans, net penetrations, which
21 are one inch penetrations.

22 These are the only penetrations coming
23 through the diaphragm floor that could possibly leak.
24 The most credible source of leakage would be through
25 the vacuum breaker. And we can go into the tests of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the vacuum breaker and the design of the vacuum
2 breaker later.

3 MR. WALLIS: It's a big vacuum breaker.

4 MR. UPTON: The vacuum breaker is 24
5 inches; that's correct.

6 MR. WALLIS: And they don't work very
7 well.

8 MR. UPTON: What you have to do is you
9 have to understand that the design of a vacuum breaker
10 is different than anything you have seen so far.

11 CHAIRMAN CORRADINI: It's like a pocket --

12

13 MR. UPTON: It's a pocket valve, that's
14 correct. And within full qualification testing on the
15 vacuum breaker.

16 CHAIRMAN CORRADINI: I guess if we get to
17 that, I'd like to wait. Because we have already asked
18 about the fact that there were three other meetings,
19 and and we've been told that Chapter 3 -- I learned.
20 So this is leakage, back leakage is the issue.

21 MR. WALLIS: This is all the other leakage
22 besides the vacuum break.

23 CHAIRMAN CORRADINI: Why don't we proceed
24 on? We are going to come back through the vacuum and
25 at least discuss this further.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHEUNG: We have performed zero to 72
2 hours three-day calculation based on percentage of the
3 DCD. And to highlight or to summarize it, normal
4 conditions, normal calculations, and maximum dry well
5 pressure with all these no mixing, all condensable
6 gases going to the wet well, we have about a 19
7 percent margin.

8 The bounding calculation, which is all the
9 bounding model and bounding initial condition,
10 operating conditions, we have 9 percent.

11 MR. WALLIS: What do you mean by margin?
12 What do you mean by 9 percent, means what divided by
13 what?

14 MR. CHEUNG: The fortified PSI G.

15 MR. WALLIS: The G part --

16 MR. CHEUNG: Yes.

17 MR. WALLIS: -- divided by the --

18 MR. CHEUNG: Divided by the calculated
19 pressure.

20 So you can see that the nominal value they
21 have about 19 percent margin; the bounding case on top
22 of our -- we put it on our conservative model,
23 penalize ourselves, we still have 9 percent margin.

24 MR. ABDEL-KHALIK: So the bounding
25 calculation is sort of the fudge calculation that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are talking about where you force the pool to be
2 stratified?

3 MR. CHEUNG: No, the pool certification
4 and the wet well stratification, these are
5 conservative models.

6 MR. WALLIS: So realistic is probably much
7 lower.

8 MR. CHEUNG: Much lower, yes.

9 MR. ARMIJO: If your bypass leakage was
10 greater than one square centimeter -- let's say it was
11 two or five -- how sensitive is that? When does your
12 margin disappear?

13 MR. CHEUNG: At two square centimeters, we
14 are just slightly below the design margin; 2.5,
15 slightly above the design margin. So it's somewhere
16 between two and 2.5.

17 MR. WALLIS: Well, it's important to get
18 that leakage right?

19 MR. CHEUNG: Yes. Now the next slide says
20 patient number 10. This table summarized what system
21 we have credited in a calculation. For the first
22 three days, we only credit the PCCS with a passive
23 ADS, GDCS, and the inventory in IC drain line, we do
24 not credit any IC heat transfer. We credit the scram
25 liquid void in a SLC system. The calculation of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percentage in DCD 6.2; three day press and on.

2 MR. WALLIS: What do you do about the
3 noncondensables that dried the SLCS system? Do you
4 let them come in?

5 MR. CHEUNG: No, the SLCS system has a ms2
6 failure proof. That means the N nitrogen would not go
7 into the --

8 MR. WALLIS: So what happens if your
9 calculation, if it did go in?

10 MR. CHEUNG: That would be a very high
11 pressure.

12 MR. WALLIS: That's not desirable, then?

13 MR. CHEUNG: Not desirable.

14 CHAIRMAN CORRADINI: There is an open item
15 on this also.

16 MR. WALLIS: Another open item?

17 CHAIRMAN CORRADINI: I'm pretty sure if I
18 remember correctly.

19 MS. CUBBAGE: Right, we were planning to
20 talk about that briefly.

21 MR. CHEUNG: At three days, the first
22 thing we can do, simple thing to do, is to make up, to
23 review the ICCG pool, we have cold water. And so we
24 can do it before that, but in the calculation, we do
25 it in three days. We can turn on the dry well fan,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the dry well gas and circulating fan at three hours.
2 And we are still in the process of doing the analysis
3 and seeing whether that would -- we could have, the
4 system with the fan thing, to have the system such as
5 FAPCS algorithmic system, which these two systems
6 have large capacity to heat changer. Take out the
7 energy from the containment and dump it outside.

8 MR. BLEY: Do you need all of these after
9 three days? Or will one or two of them suffice?

10 MR. CHEUNG: The next slide will show in
11 case the calculations, with no credit for past, with
12 no FAPCS or WCU, only at the fan and the refilling of
13 the pool.

14 Now I would like to explain a little bit
15 more. Now this is the calculations, bounding
16 calculations, presented in DCD from several days to 72
17 hours. If no additional system like the fan or
18 whatever, this will slowly graduate, keep going up and
19 up, and eventually cross the line of the design
20 threshold.

21 In 72 hours, when we fill the pool which
22 enhance the top condensation capacity, they turn on a
23 fan. Now in this calculation we have from three days
24 to seven days. We present two sets of calculations,
25 the upper set with dry well/wet well pressure for four

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 systems, four fans. Each fan has 700 cubic feet per
2 minute, per line. The lower set has six systems, six
3 vent line systems. And each system has 700 cubic feet
4 per minute.

5 And you can see that that's so in this
6 calculation, right on the 72 hour, we turn on,
7 initiate the system. The pressure, the dry well
8 pressure, drop rapidly, and continue to drop.

9 MR. WALLIS: Is it your intention to
10 switch these things on at 72 hours, or to wait until
11 something happens and then switch them on.

12 MR. CHEUNG: In the calculation, we assume
13 72 hours --

14 MR. WALLIS: What is the operator supposed
15 to do? Is he supposed to switch the fans on?

16 MR. MARQUINO: Excuse me, this is Wayne
17 Marquino, GEH. And we had to develop the emergency
18 procedures in much detail. We expect that these
19 active systems will be employed as they are available
20 to mitigate the event.

21 We will develop emergency procedures that
22 do that, certainly.

23 MR. ABDEL-KHALIK: It's remarkable that
24 there is such a huge difference between the case of
25 four vent fans and six vent fans. The only reason

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that could be true is if you are generating so much
2 gas that for such a long, long time we continue to
3 have a difference.

4 Now I would have expected that once you
5 pulled the uncondensable gases out of that heat
6 exchanger, within a few minutes, you know, it wouldn't
7 make any difference.

8 If your explanation of the function of
9 these fans is correct, then there shouldn't be a
10 steady state difference between the case of four fans
11 and six fans.

12 MR. BANERJEE: Well let's ask how many
13 cubic feet per minute of noncondensables generates it.

14

15 (Simultaneous voices)

16 MR. BANERJEE: So you multiply that by
17 six, and you get about -- how much is being generated?
18 Cubic feet per minutes from --

19 MR. CHEUNG: Going through the system.
20 That air has to go through that --

21 MR. BANERJEE: No, we're just asking how
22 much is being generated by radiolytic decomposition.

23 PARTICIPANT: Just hydrogen and oxygen,
24 that's all we're talking about.

25 MR. BANERJEE: How much is that? How many

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cubic feet per minute?

2 MR. CHEUNG: I don't have the number off
3 my head.

4 MR. BANERJEE: Maybe we should ask that.

5 CHAIRMAN CORRADINI: I guess that -- you
6 guys have probably done all these calculations, but
7 you may not have -- but the first question I ask is,
8 let me magically shut off radiolytic decomposition.
9 Do you come to a steady state?

10 MR. CHEUNG: Yes, we did that.

11 CHAIRMAN CORRADINI: Okay, and then the
12 second question was what Sanjoy and Said were asking
13 is what is the production rate relative to this. But
14 I have to admit, that doesn't strike you as odd that
15 you add the 50 percent capacity and you get more than
16 50 percent effect, if I understand this curve right.

17 MR. WALLIS: Something doesn't look right.

18

19 MR. CHEUNG: No, no, the fan only
20 circulates through the PCC2, and hands the -- you can
21 see that -- pick one set. It says wet well pressure
22 is slightly higher than the dry well pressure.

23 MR. WALLIS: Not much.

24 MR. CHEUNG: Not much. So that means some
25 of the air, trying to find a way from the dry well

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going into the wet well. Now once it goes into the
2 wet well, it will find a way back in the PCC because
3 everything mix.

4 MR. ABDEL-KHALIK: But you're saying that
5 the pressure in the dry well comes down because you
6 get better heat transfer in those heat exchanges. And
7 therefore the time constant for the decrease in
8 pressure depends on how fast you brow the gas out of
9 those heat exchangers. And to me, if you are pulling
10 gas at 4 times 700 cfm or six times 700 --

11 MR. CHEUNG: Let me try to explain to you.
12 I have not finished the arrangement. Let me try
13 again.

14 The noncondensable gas in the dry well
15 move from the dry well. Once it gets into -- finds a
16 way into the PCC, and then the PCC will degrade but
17 that way there will be mixture going in and eventually
18 get to an equilibrium point. That why this thing
19 tries to get to an equilibrium point. I mean, the gas
20 mixture, the noncondensable portion of it, is higher
21 than the fan, keep circulating the same amount, keep
22 circulating.

23 MR. MARQUINO: So that was a good
24 clarification, that the fans are circulating the
25 noncondensable gas through the dry well, so they are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 clearing it, but then it has the opportunity to go
2 back in the PCC. So that's one factor.

3 My mental picture of this is what the fan
4 is doing is stabilizing at a different noncondensable
5 gas pressure and the containment. So without a fan we
6 stabilize with zero-noncondensable mass fraction in
7 the dry well with a high pressure with six fans we
8 stabilize at a lower pressure and a higher
9 noncondensable gas fraction, and you see with four
10 fans there is an intermediate pressure and
11 noncondensable gas fraction.

12 The good thing about these calculations
13 is, we are doing them with our TRAC code, but I think
14 there -- we'd get similar results by using Excel
15 spreadsheets.

16 MR. CHEUNG: Let me go on a little.

17 MR. BANERJEE: Well, there was a question
18 asked of you, almost answered, but you didn't. If
19 there is no radiolitic hydrogen and oxygen generated,
20 what happens to that curve? Can you describe it?

21 MR. CHEUNG: The curve will stay flat.

22 MR. BANERJEE: Where will it stay flat?

23 MR. CHEUNG: We need fifty hours of
24 recording, clean up all the air, noncondensable gas,
25 in the drywell with no more noncondensable gas in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 wet well, then wet well gas is not going up --

2 MR. BANERJEE: So find the equilibrium
3 point in the PCCS. And what you are doing by blowing
4 -- sucking stuff out is just dropping that --

5 MR. CHEUNG: Equilibrium point.

6 MR. BANERJEE: -- level. So you still
7 have noncondensable material. You are just getting it
8 lower.

9 So your flow of noncondensables is a
10 pretty high amount for this, is that it? I think you
11 ought to equalize this.

12 CHAIRMAN CORRADINI: Can I just say it
13 back to you, because I want to make sure -- we're
14 going to come back to this anyway; we should move on
15 anyway.

16 It's not just -- it's not just the
17 noncondensable gas fractions. It's also the flow to
18 the PCCS by you moving the van fan, you are changing
19 the delta mass fraction, and the heat transfer
20 coefficient of condensation ought to be essentially
21 linearly proportional to the mass fraction,
22 approximately.

23 MR. BANERJEE: Approximately.

24 CHAIRMAN CORRADINI: Approximately, so the
25 energy pulled off. Because the condensation transfer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 coefficient at these very high mass fractions is like
2 small. And so like small times a delta X. So you
3 increase the delta X.

4 But the other thing is, the flow through
5 the PCC. And that is the only way I can explain this
6 nonlinear effect, is that you have almost very little
7 flow when you are stagnant, and by moving the vent fan
8 you are getting more flow through.

9 So some layer, at some time, not now, I'd
10 like to investigate that, just to make sure that I
11 feel all this is kosher, because it does look a bit
12 odd.

13 MR. BANERJEE: You need to look at the
14 heat transfer.

15 CHAIRMAN CORRADINI: Yes, and the other
16 thing is, the decomposition rate. I guess I'm still
17 surprised --

18 (Simultaneous voices)

19 CHAIRMAN CORRADINI: - it sounds to me
20 really large.

21 MR. CHEUNG: It's an indicator effect,
22 from --

23 (Simultaneous voices)

24 MR. BANERJEE: But we need to sit and look
25 at it in detail.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: I know you told us once, but
2 would you tell me again exactly where is this fan
3 drawing suction from, and exactly where is it
4 discharging?

5 MR. CHEUNG: Can we have the other
6 picture?

7 (Off the record comments.)

8 MEMBER ARMIJO: We're essentially creating
9 a forced flow through the PCCS.

10 MR. DEEVER: I don't know if it was clear,
11 but we have one dedicated fan per PCCS unit.

12 MR. CHEUNG: Okay. That will do it.

13 MR. WALLIS: Well, that figure, where is
14 it?

15 MR. CHEUNG: This is the vent line. We
16 have a fan going from the vent line for the blower or
17 fan, and then they chart into this area.

18 MR. WALLIS: Flows into the --

19 MEMBER BLEY: Into the air space of the --

20

21 MR. CHEUNG: Air space of the pool. The
22 air space will be created in the case of LOCA.

23 MEMBER BLEY: From the vent line into the
24 air space.

25 MR. CHEUNG: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Can we pressurize that air
2 space?

3 MR. CHEUNG: No.

4 MEMBER BLEY: Or is that in free
5 communication with the drywell?

6 MR. CHEUNG: Because it's free
7 communication between the wetwell and --

8 MR. WALLIS: It's part of the drywell
9 then.

10 MR. CHEUNG: There's a little opening
11 here.

12 MEMBER BANERJEE: Now if you just had the
13 recombiners, what would the pressure stabilizer --

14 MR. CHEUNG: Well, in the calculation we
15 saw, we didn't recombine --

16 MEMBER BANERJEE: These slides?

17 MR. CHEUNG: Well, I do not have that. In
18 the calculation we saw that we recombine what is
19 generally after 72 hour, but actually in reality, in
20 the real world, once you put a pass in a wet well,
21 whatever hydrogen, oxygen prior to 72 hours, they all
22 combine, so actually the amount of non-condensable gas
23 in the wet well is going to drop real fast, but in
24 proportion to the integrated effect of the time.

25 MEMBER BANERJEE: So if you go back to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 slide on page 11 or whatever it is, I can't see
2 without my glasses, 11. What happens to the special
3 curves if you have recombiners?

4 MR. CHEUNG: We have the recombiner. The
5 wet well pressure will go down, because of the effect
6 in the non-condensable gas.

7 MEMBER BANERJEE: Right.

8 MR. CHEUNG: We'll go down in proportion
9 to whatever lap over, that cannot be combined because
10 of a fraction of the hydrogen or oxygen. So we have
11 brought it down to, I would say somewhere around here,
12 is not going to drop down to atmospheric pressure.

13 MEMBER BANERJEE: The drywell?

14 MR. CHEUNG: The drywell.

15 MEMBER BANERJEE: So you don't have a
16 calculation done just with recombiners?

17 MR. CHEUNG: We have calculation. We have
18 recombiner, but only combine whatever is generated out
19 of the 72 hours.

20 MEMBER BANERJEE: Okay. Then what happens
21 if you just do it after 72 hours?

22 MR. CHEUNG: Then we have a curve that
23 look like this, drop down to here.

24 MR. WALLIS: What's the volume of this
25 drywell, again?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHEUNG: Seven thousand cubic meter.

2 MR. WALLIS: Seven thousand cubic meters.

3 MR. CHEUNG: Yes.

4 MR. WALLIS: What's that in cubic feet?

5 MR. CHEUNG: Cubic meter.

6 PARTICIPANT: Multiply by 27.

7 MEMBER BANERJEE: It is not cubic feet per
8 minute then.

9 MR. CHEUNG: Cubic feet per --

10 MR. WALLIS: Cubic feet per minute.

11 MEMBER BANERJEE: Now going back to, why
12 do you want these fans if your recombiners do the
13 jobs?

14 MR. CHEUNG: Well, I'm going to complete
15 it in two sentence saying that it's a defense-in-depth
16 system. Power is one thing, vent fan is another. The
17 vent fan is very easy to install, very low power, only
18 couple of horsepower would do it.

19 MEMBER BANERJEE: These vent fans.

20 MR. CHEUNG: Vent fans.

21 MEMBER BANERJEE: But you're going to put
22 recombiners, anyway, no?

23 MR. CHEUNG: Yes.

24 MEMBER BANERJEE: I mean, if you have the
25 recombiners anyway, what difference does it make?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHEUNG: It is not me to answer that
2 question.

3 MEMBER BLEY: The mechanics like the fans
4 --

5 PARTICIPANT: Mine just to do and die.

6 (Laughter.)

7 MR. CHEUNG: Let me -- a little bit more.
8 The vent fan have been tested in the PANDA test, in
9 the PANDA facility.

10 MEMBER BANERJEE: I know, but that doesn't
11 mean you install them --

12 MR. WALLIS: So four vent fans punched
13 down the entire drywell in an hour, even if it's all
14 full of gas.

15 MEMBER BLEY: But it's pumping back to
16 itself.

17 MR. WALLIS: It's just circulating.

18 (Simultaneous speech.)

19 CHAIRMAN CORRADINI: All it is is a forced
20 flow vacuum breaker right through the PCCS. They
21 basically have turned on a pump through the PCCS.

22 MR. WALLIS: All it does is pump gas
23 through it with no steam left. There should be no
24 pressure in there. It doesn't make any sense.

25 (Simultaneous speech.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. UPTON: Gentlemen, this is GEH. This
2 is Hugh Upton with GEH. I guess the question on the
3 table, I was in a separate discussion, but one of the
4 reasons why we do have the vent fans is we have to
5 show a dramatic drop in containment pressure at 72
6 hours to meet the GDC requirements, and so if we just
7 had PARS, it would go to a steady state condition at
8 high pressure. And here, with the vent fans, we show
9 a dramatic drop.

10 CHAIRMAN CORRADINI: So let me -- I was
11 hoping you wouldn't say that, but since you did, all
12 you've shown us was six fans. You went down 20
13 percent. Now if you want to call that dramatic, okay,
14 but you went from 3.7 bars to 3 bars.

15 MEMBER BANERJEE: Drama is the eye of the
16 beholder.

17 CHAIRMAN CORRADINI: I guess, when I saw
18 the open item originally, I had a feeling you guys
19 were going to answer it somehow. I find it very
20 creative, but if rather you come to some steady state,
21 I guess personally, I guess I would argue that you've
22 done -- personally, I was looking for what's happening
23 here. And after this, I wasn't so concerned, if I
24 could understand why you're coming to some
25 equilibrium. And so, your passive recombiners, you've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 answered that part of the question of how you could
2 come to an equilibrium.

3 MEMBER BANERJEE: It will be below the
4 design pressure. Right?

5 MR. CHEUNG: Well, from 90 percent down to
6 30 percent, and we have -- the other system will come
7 out.

8 MEMBER BANERJEE: Well, you've taken a
9 very elegant design and you really made --

10 PARTICIPANT: We're going to have to look
11 at this separately, I think.

12 MR. WALLIS: It doesn't make any sense to
13 me.

14 MEMBER ARMIJO: In this analysis, the
15 recombiners are not operational.

16 MR. CHEUNG: No.

17 MEMBER ARMIJO: But if they're truly
18 passive recombiners, they are operational.

19 MR. CHEUNG: Yes.

20 MEMBER BANERJEE: They have to be there.

21 (Simultaneous speech.)

22 MR. MARQUINO: Dr. Armijo, let me give you
23 some background on why. We started out with a passive
24 design for three days, and GE expected that we'd apply
25 our active systems at three days. After submitting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Rev 0, we learned about the regulatory treatment of
2 non-safety systems, the fact that makes systems tech
3 spec. If we want to use diesel generators we have to
4 have a four-day supply of fuel on site, so we
5 apologize for addressing some of these to the staff in
6 piecemeal fashion, but we first added the passive
7 recombiners to address the source of the
8 pressurization, the radiolytic gases. And then when
9 we showed the results for that, the GEC 38 concern
10 came up, and the staff will expand on what their
11 concerns are there. We've added the fans, so we
12 retain a design that's passive for three days, and it
13 minimizes the regulatory burden on the utilities in
14 terms of RTNA systems, so we use these small fans
15 which will be pretty easy to check, versus using the
16 standby diesel generators and their fuel supplies.

17 MEMBER ARMIJO: Yes, I see that, but it
18 seems like you have a passive recombiner. You're
19 going to put that in anyway. You ought to take credit
20 for it from day one, because it's there. That's the
21 whole idea of passive. Right? You can't stop it from
22 working.

23 MR. MARQUINO: The regulatory oversight is
24 higher if we credit it immediately versus at seven
25 days. The regulatory burden for having it, to get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 credit for it is so severe that you --

2 MEMBER MAYNARD: Well, you're talking
3 about credit. They still -- it doesn't mean they
4 won't use their active systems during the first 72
5 hours. So from a safety standpoint, they're going to
6 have available anything that they've got. It's just
7 what they --

8 MR. MARQUINO: The recombiner does not
9 have a clock in it, so it won't know that it's 72
10 hours or not.

11 CHAIRMAN CORRADINI: Does staff want to
12 say something to this point?

13 MS. CUBBAGE: I was just going to say it's
14 up to the vendor and their customers to make some of
15 these economic decisions, and they'd certainly be
16 welcome to credit anything they want early on with the
17 appropriate regulatory control, and before 72 hours it
18 would be safety related, and that was a burden they
19 weren't willing to take on.

20 MR. SNODDERLY: Also, Chairman Corradini,
21 this is Mike Snodderly from the staff. The Committee
22 in the letter concerning the AP-1000 in its review
23 pointed out uncertainties associated with the PARS,
24 and the fact that there had not been integrated
25 testing done in a post-accident atmosphere. And, also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 into the Phebus test where that had been done, and
2 showed some poisoning, so there is some uncertainty
3 associated with the PARS.

4 MEMBER ARMIJO: Is that still the case,
5 these things are --

6 MR. SNODDERLY: Right now, we are aware of
7 some Phebus testing with PARS that has shown poisoning
8 and a detrimental effect. They still function, but
9 there was some --

10 MEMBER ARMIJO: Not as well.

11 MR. SNODDERLY: Yes. So I just wanted to
12 remind the Committee of that uncertainty that was
13 pointed out to us by the Committee.

14 MEMBER MAYNARD: Well, whether they credit
15 them or not doesn't change the safety. I mean, that's
16 only a matter of what shows up on the graphs or the
17 outputs there, but they're still there.

18 CHAIRMAN CORRADINI: So it's our fault
19 you're behind, but can you move along?

20 (Laughter.)

21 MR. WALLIS: Well, can we have a
22 Subcommittee meeting on this 700 cubic feet thing,
23 which doesn't make any sense, 700 cubic feet from --

24 CHAIRMAN CORRADINI: Well, I'd propose
25 that you talk to the Chair of the Thermal Hydraulics

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Committee right to your right, and we can negotiate
2 that.

3 MEMBER BANERJEE: Just one last thing. I
4 think we can accumulate a number of topics, and then
5 set it up.

6 MEMBER ARMIJO: Are you guys really
7 convinced you generate that much radiolytic gases?
8 Did somebody triple check that?

9 MEMBER BANERJEE: Well, it's not the
10 radiolytic flow. It's basically, as Mike says, a
11 forced convection system --

12 MR. WALLIS: But the non-condensers have
13 all gone into the wet well anyway, so I mean what are
14 you circulating? You're sucking on nothing. It
15 doesn't make any sense. Okay. You're going to be
16 tell us all about it some other day.

17 MEMBER BANERJEE: Yes, I think it's --

18 MR. DEEVER: Okay. Section 6.3. This is
19 the emergency core cooling system section. Basically,
20 what we're going to go into more detail on, but we've
21 already had a lot of discussion, is the gravity-driven
22 cooling system, the iso condenser system, the standby
23 LOCA control system, and the ADS system for
24 depressurization. So I'll describe the systems, and
25 then Chester will give you some details on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis performed.

2 Basically, the ESBWR design incorporates
3 passive emergency core cooling systems in conjunction
4 with traditional systems, such as ADS, which enable
5 depressurization.

6 Some of these systems we've gone through
7 before, so I'll go through some of them quickly.
8 Gravity-driven cooling system I believe is a new
9 system that we haven't talked about before. It
10 basically has three sub-systems to it. The primary
11 function of the system is to deliver injection cooling
12 flow from the pool into the RPB, and the component
13 that opens the system up after the vessel is
14 depressurized is a squib valve. And another important
15 feature is the check valve in the line, which if for
16 some reason the system still had pressure in it, it
17 would prevent the backflow of pressure into the pool
18 itself.

19 MEMBER BANERJEE: Where is the check valve
20 again?

21 MR. DEEVER: The check valve is here, just
22 upstream of the squib valve.

23 This line actually branches into two
24 lines, so for any given system or train, this will
25 branch into two lines, and there will be two nozzles

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 into the vessel. There are four lines to the system.
2 There are three pools. Two pools are essentially the
3 same dimensions, but the third one is a larger pool
4 where we draw fluid from two pipes.

5 The second subsystem is what we call the
6 equalizing line. So the initial part of the system
7 would act early in an accident phase. The equalizing
8 line is a way to open up the suppression pool and
9 connect it with the reactor pressure vessel. And
10 this, if needed, would be a longer term sort of thing.
11 And it, likewise, is activated by a squib valve. So
12 this is a precaution if you need more water in the
13 core longer term.

14 MEMBER BANERJEE: It doesn't come on
15 automatically then.

16 MR. DEEVER: No.

17 CHAIRMAN CORRADINI: But it's squib-
18 related. And then if I understand it, by the
19 elevation -- by your normal calculation of where the
20 water is would not be needed. You would not normally
21 -- you would have drainage from the GDCS --

22 MR. DEEVER: Yes, you would.

23 CHAIRMAN CORRADINI: -- to the reactor,
24 and that would probably create the needed inventory.
25 You wouldn't open that up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Yes. This isn't normally
2 needed in that scenario.

3 MR. UPTON: Gentlemen, I want to at least
4 clarify a point. The equalizing line is automatically
5 initiated on level. Okay? So it's not a manual
6 initiation.

7 MEMBER BANERJEE: I think that's what I --

8
9 MR. DEEVER: Okay. I forgot about that
10 fact.

11 CHAIRMAN CORRADINI: But the expectation
12 is that that level, you won't get down to that level,
13 to finish that up.

14 MR. UPTON: That's correct. The level
15 initiation for the equalizing line is below the
16 initiation for the GDCS, so it's a backup.

17 MR. DEEVER: Thank you. And the third
18 function is the deluge line, which is shown on this
19 side of the figure. This basically, in the event
20 there was a severe accident, where cooling was needed
21 in the bottom of the reactor, or the bottom of the
22 drywell, the squib valves, again, would open up the
23 system and allow flow into the low area.

24 MR. WALLIS: If there's any water left in
25 the GDCS pool by then.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: And how would this logic
2 work? When would this --

3 MR. DEAVER: Well, what we have in the --

4 MEMBER BANERJEE: What happens if it
5 inadvertently opens, or something?

6 MR. UPTON: Gentlemen, this is Hugh Upton
7 with GEH. The initiation of the deluge system, which
8 ties to the BIMAC is coupled to extreme temperature in
9 the lower drywell, which you'd see based on core
10 ejection from the vessel. They're embedded
11 thermacouples, which will initiate the system.

12 MEMBER BANERJEE: What happens if it
13 inadvertently initiates? It makes a big mess.
14 Correct?

15 MR. UPTON: That's correct. If it
16 inadvertently initiates, you'll have a lot of water in
17 the lower drywell.

18 MEMBER BANERJEE: And none in the --

19 PARTICIPANT: Where you want it.

20 MR. UPTON: That's correct.

21 MR. DEAVER: But it is --

22 MEMBER BANERJEE: Did you consider severe
23 accidents?

24 CHAIRMAN CORRADINI: No, not today.

25 MEMBER BANERJEE: Why are we doing this?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: I was about to stop
2 you from asking this question, but you started this.

3 (Laughter.)

4 MEMBER MAYNARD: But you do have a motor-
5 operated valve to isolate. It looks like that's
6 normally open, but is that something that could be
7 closed? It would require operator action, it looks
8 like.

9 PARTICIPANT: You'd have to figure out
10 what was going on.

11 MEMBER MAYNARD: Yes.

12 PARTICIPANT: That's probably not very
13 likely.

14 MR. UPTON: Right. That's correct. I
15 mean, you can isolate that if it's draining.

16 MEMBER BANERJEE: But I think my question
17 is still valid, why are you doing this? I mean, I
18 just don't understand it.

19 MR. UPTON: This is defense-in-depth,
20 that's why we have it. It's being -- it's for severe
21 accident for core melts. And it also --

22 CHAIRMAN CORRADINI: This is part of their
23 design.

24 MR. UPTON: It's part of the design.

25 CHAIRMAN CORRADINI: For their design,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they want water down there. It's not designed - just
2 to repeat one thing I asked early in one of the things
3 - by the way you've designed it, well, your lower
4 cavity, or whatever you call that region below the
5 reactor vessel, is to be dry. The only way to get
6 water in is this way. It doesn't leak in naturally.

7 MR. DEEVER: That's correct.

8 MEMBER BANERJEE: This is not a
9 requirement of our licensing process, is it?

10 MR. UPTON: Yes.

11 MEMBER BANERJEE: Or is it?

12 MS. CUBBAGE: They're required to address
13 severe accidents. It's their option to choose a
14 system to do that. It was their design choice. I
15 think there's been a lot of talk about this in the PRA
16 Subcommittee, but they were trying to avoid some
17 uncertainty with the corium spreading area and things
18 like that.

19 CHAIRMAN CORRADINI: But I think we're a
20 bit off topic. Your biggest point is inadvertent
21 actuation that would then limit it for normal --

22 PARTICIPANT: Yes, for a real emergency.

23 CHAIRMAN CORRADINI: More normal accident
24 considerations.

25 MEMBER BANERJEE: But even a relatively

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 small break or something, the GDCS will be called on.
2 Right? And you don't want this to pour water into the
3 lower part of the floor.

4 MR. UPTON: It is a diverse control
5 system, so there's no possibility that a failure in
6 the control system could disable GDCS or during a LOCA
7 -- there's no relation to the initiation parameters
8 for the GDCS system core cooling function, and this
9 BIMAC cooling function.

10 MEMBER BLEY: Are these down in the lower
11 drywell?

12 MR. UPTON: Yes.

13 MR. DEEVER: Highly reliable valves built
14 into the INC system. Okay.

15 Next is the iso condenser system. We've
16 gone over this previously. I think one thing that I
17 didn't point out earlier is that we have a vessel
18 within the line which is, from a performance
19 viewpoint, adds more inventory of water in the event
20 of a LOCA accident, and so this inventory of condensed
21 water in the line is credited in the accident
22 analysis. So that's been an addition to the system.
23 Otherwise, it's the same components that we've
24 discussed earlier.

25 Okay. Moving ahead.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: So in the event of a small
2 break, you only need the isolation condenser? You
3 don't need to activate the other systems. Is that
4 right? If you have a small enough break, you don't
5 need to have the GDCS work at all, you don't need an
6 ADS?

7 MR. CHEUNG: It would depend on whether
8 that was very small break, and --

9 MR. WALLIS: You will handle it. Right.

10 CHAIRMAN CORRADINI: But in terms of --
11 so, since we're on Chapter 6, but in terms of the
12 progression of the four accidents you mentioned, you
13 took us through the performance of the containment,
14 assuming a main steam line break, but you have other
15 smaller break sizes down to the bottom drain line
16 break.

17 MR. CHEUNG: Yes.

18 CHAIRMAN CORRADINI: But all four of
19 those, given their size, they would activate all the
20 systems we're talking about, and challenge all the
21 systems we're talking about.

22 MR. CHEUNG: Except the equalization line.

23 CHAIRMAN CORRADINI: Oh, except the
24 equalization line?

25 MR. CHEUNG: Yes, because for all breaks,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 line penetration, all break within --

2 CHAIRMAN CORRADINI: Oh, I'm sorry. Okay.
3 I understand your -- I'm sorry. But in terms of
4 exercising everything --

5 MR. CHEUNG: Yes.

6 CHAIRMAN CORRADINI: Okay. Thank you very
7 much.

8 MR. DEEVER: Okay. Moving ahead, this is
9 the standby LOCA control system. Basically, this has
10 been revised to be a passive system. Previously, it
11 had a pump that would initiate and inject the sodium
12 pentaborate solution. What we do here is we basically
13 have accumulators that have the sodium pentaborate
14 solution with nitrogen system in these accumulators.
15 And the normal pressure in these accumulators is 2250
16 psi.

17 Again, we have parallel squib valves that
18 would have to open in order to initiate the system.
19 And we have two sides to the system, we have
20 accumulator on both sides of the reactor. The
21 combined capacity of these two systems equals 100
22 percent of the capacity needed for shutdown purposes.

23 Also part of the system is a mixing
24 system, and a sampling system so that we can check the
25 solution at periodic times to make sure it's mixed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: So they both have to work.

2 MR. DEEVER: Yes.

3 MR. WALLIS: It just equals 100 percent?
4 There's no margin, it's not 150 percent or something?
5 You say you just have 100 percent of what you need?
6 I would think you'd need to have a margin, have more
7 capacity than you need.

8 MR. DEEVER: Maybe, Wayne, you can address
9 the margins available.

10 MR. MARQUINO: Yes. If one of them didn't
11 work, which would require multiple failures, the core
12 would still be covered, but we wouldn't have as much
13 margin as we show in the LOCA analysis.

14 MR. WALLIS: Other flume can shut down --

15 MR. MARQUINO: And in terms of reactivity
16 control in the ATWS scenario, if one of them worked we
17 would reach a hot shutdown state, but before we cool
18 down, we'd have to inject more boron because we
19 wouldn't reach a cold shutdown state.

20 MR. DEEVER: Yes. I might explain that
21 this system initially was only in place because of
22 ATWS in the older plants, going forward into this
23 plant. But what we're also crediting it for now is
24 the water and sodium pentaborate solution as an
25 inventory for injection into the reactor.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Does that accumulator have
2 a rubber bladder in it?

3 MR. DEEVER: No. It's just simply a
4 solution gas interface. I might also mention that we
5 have level detectors in the accumulator, and we have
6 these two air actuated valves as shutoff valves. Once
7 the system is open, obviously, as the accumulator gets
8 down to a certain level, we want to shut it off, and
9 that's what these valves do, to make sure that none of
10 the nitrogen enters into the reactor system.

11 VICE CHAIRMAN ABDEL-KHALIK: Now does this
12 use enriched boron?

13 MR. DEEVER: Yes, it does.

14 VICE CHAIRMAN ABDEL-KHALIK: So is there
15 a trade-off between the pressure in this accumulator
16 and the enrichment, so that you'd get --

17 MR. DEEVER: Yes. I guess if you had
18 higher enrichment, you could use less pressure, but --

19
20 VICE CHAIRMAN ABDEL-KHALIK: What sets the
21 pressure currently in the accumulators?

22 MR. DEEVER: 2250.

23 VICE CHAIRMAN ABDEL-KHALIK: I mean what
24 sets that valve?

25 MR. DEEVER: Oh. That's a volume of --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: It's sized to get -- this
2 is Wayne Marquino. It's sized to get 86 gpm per a
3 certain volume which is written into 10 CFR 50.36, I
4 believe it is. So that determined what flow rate we
5 had to produce, and we designed the pressure and flow
6 areas of the system to meet that requirement.

7 VICE CHAIRMAN ABDEL-KHALIK: But that
8 depends on which ATWS you're talking about, which
9 pressurization ATWS.

10 MR. MARQUINO: Well, we'll get into that
11 more tomorrow, but it's way over-sized because that
12 requirement assumes like a normal water level, and we
13 automatically reduce the water level in an ATWS, so we
14 inject the boron into a much smaller volume. And
15 you'll see the results in Chapter 15.

16 VICE CHAIRMAN ABDEL-KHALIK: Okay. MEMBER
17 BANERJEE: You reduce the water levels by feedwater --

18

19 MR. MARQUINO: Yes. Run-back.

20 CHAIRMAN CORRADINI: So just so I -- I
21 think the staff is going to mention this about an open
22 item relative to this nitrogen going in and not being
23 stopped, because the current -- the way this should
24 work is you inject the liquid, and then you close off
25 before you start having a continued injection of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 nitrogen. Is that correct?

2 MR. DEEVER: Exactly.

3 CHAIRMAN CORRADINI: Okay. So just to get
4 a rule of thumb, if I didn't, and the nitrogen went
5 into the system, at normal containment pressure
6 conditions what's the -- how many cubic feet, or cubic
7 meters, or what's the inventory affect on
8 pressurization inside containment with this? Would
9 this be a small, insignificant amount of
10 pressurization?

11 MR. CHEUNG: Would be a very significant
12 increase in pressure.

13 CHAIRMAN CORRADINI: It would.

14 MR. WALLIS: Significant increase in non-
15 condensables.

16 CHAIRMAN CORRADINI: Well, that was the
17 second -- I was about to get there, but at least I
18 wanted to know the pressurization. And then you're
19 increasing your non-condensable fraction, but you're
20 already at a very high enough non-condensable
21 fraction, you're at the asymptote on how it affects H,
22 the transfer --

23 MR. WALLIS: How does it know when it's
24 got nitrogen instead of liquid?

25 MR. DEEVER: There's level sensors.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: Level sensors?

2 MR. DEEVER: Four levels.

3 MR. WALLIS: So it senses the level in the
4 accumulator?

5 MR. DEEVER: Yes.

6 PARTICIPATION: Then it closes a valve or
7 something. Right?

8 MR. DEEVER: Then it closes both of these
9 valves.

10 VICE CHAIRMAN ABDEL-KHALIK: What is the
11 volume of the accumulators?

12 MR. DEEVER: I think - what is it - 5.3
13 cubic meters, I believe is the --

14 MR. CHEUNG: Water volume, or the gas?

15 VICE CHAIRMAN ABDEL-KHALIK: No, the total
16 volume. The gas volume. I think that would be
17 sufficient. What's the gas volume?

18 MR. DEEVER: The gas volume versus the
19 water volume?

20 VICE CHAIRMAN ABDEL-KHALIK: Just the gas
21 volume.

22 MR. DEEVER: We'll have to look it up and
23 get you a specific number for that.

24 MR. UPTON: We can pull that out of the
25 DCD.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: It looks big in the picture.

2 (Off the record comments.)

3 MR. DEEVER: As I recall, the height of
4 this vessel is going to be about 5 meters -- it's a
5 fairly good size, yes.

6 MEMBER MAYNARD: These are operated valves
7 in your analysis for closing?

8 MR. CHEUNG: Yes.

9 MEMBER MAYNARD: They are credited. Okay.
10 I thought we were talking about in Chapter 9 on the
11 standby liquid control system, that it just
12 discharged, and you did get nitrogen in there.

13 MR. DEEVER: No.

14 MEMBER MAYNARD: Okay.

15 MR. MARQUINO: Okay. Shall we move on to
16 the next --

17 VICE CHAIRMAN ABDEL-KHALIK: So we could
18 translate 2250 psi, the amount of gas in those
19 accumulators, and dump them into the containment. How
20 much would the pressure go up?

21 MR. DEEVER: I don't know that number.

22 MR. CHEUNG: I forgot the number. It's
23 significant. More than likely than will exceed the
24 design pressure, because it's 22 psi.

25 VICE CHAIRMAN ABDEL-KHALIK: 2250.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: You'd need at least six fans
2 running to go in the --

3 (Simultaneous speech.)

4 MS. CUBBAGE: I think I've got the right
5 number here for you, but the DCD is talking about 14.8
6 cubic meters of nitrogen cover in the accumulator.

7 PARTICIPANT: What is that volume you
8 said?

9 MS. CUBBAGE: Yes, 14.8 cubic meters of
10 nitrogen cover.

11 MR. DEAVER: Yes. That's -- I probably
12 had my numbers confused.

13 MR. WALLIS: Say that again.

14 MS. CUBBAGE: I was just reading from the
15 DCD. It's talking about necessary to maintain 14.8
16 cubic meters of nitrogen cover gas at 14.82
17 megapascals in the accumulator for each slick train.

18 MR. DEAVER: That sounds like it's
19 probably right.

20 MEMBER ARMIJO: 225.

21 (Off the record comments.)

22 MS. CUBBAGE: You want feet? They have it
23 here, 523 cubic feet.

24 MR. WALLIS: So it's a big proportion of
25 the amount of nitrogen in the containment to start

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with, looks like.

2 CHAIRMAN CORRADINI: Keep on going.

3 MR. DEEVER: Okay. The ADS system we've
4 seen before. Again, it's just the SRV safety valves
5 and DPVs, which we discussed before. I won't go any
6 further into that.

7 Okay. Then we go into the performance
8 side of the presentation.

9 MR. WALLIS: Remind me how big the ADS
10 valves are.

11 MR. DEEVER: Which ones are we -- are we
12 talking about the DPVs?

13 MR. WALLIS: The flow area that comes out
14 of those DPVs.

15 MR. DEEVER: Oh, okay. The standpipes are
16 eight inches.

17 MR. WALLIS: They're all eight inches?

18 MR. DEEVER: Coming up to the DPV, and it
19 opens up to at least that much area.

20 MR. WALLIS: Open. Okay.

21 MEMBER BLEY: And the full ADV flow
22 converter main steam flow, number you know off-hand?

23 MR. DEEVER: I know there's a ratio that
24 we're required to have.

25 MR. CHEUNG: And, also, the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DEEVER: Both the IC and the steam
2 line both have the same restricting orifice on the
3 discharge. They're both upper vessel diameters with
4 steam --

5 PARTICIPANT: It's going to a lower
6 pressure, so it's a lot more flow.

7 MR. DEEVER: Okay?

8 MR. CHEUNG: For the ECCS performance,
9 again, the ESBWR with the TRACG code: the key part is
10 we use the same nodalization for ECCS and nodes used
11 in containment analysis. And for ECCS at NRC we have
12 performed more detailed time lines from zero to 2,000
13 seconds because during this time period all the blow-
14 down, all the GDC injection, and the things going on,
15 we have an interest in whether the core is covered or
16 not covered during this time period. After the GDC
17 injection, the core inventory increase or recover
18 after that, and then the water stay there for long
19 time, and we have analyzed that from zero to 72 hours,
20 and look at the output calculation. And, also, we
21 have evaluated the up and down to 72 hours.

22 The bottom line is for all breaks that no
23 core uncovers, and there's no core heat-up --

24 MR. WALLIS: Now this is water above the
25 core.

1 MR. CHEUNG: Water above the --

2 CHAIRMAN CORRADINI: Substantially above
3 it.

4 MR. WALLIS: Taking credit for the voids
5 in the core.

6 MR. CHEUNG: Yes.

7 MR. WALLIS: But if you collapse the voids
8 in the core you'd get a different number, wouldn't
9 you?

10 MEMBER BANERJEE: What's the average void
11 fraction in the core?

12 MR. CHEUNG: In the core, 80 percent, 90
13 percent. It's high, but now let me go back a little
14 bit.

15 CHAIRMAN CORRADINI: What was that number
16 you said?

17 MR. CHEUNG: 80 percent, 90 percent.

18 CHAIRMAN CORRADINI: Oh, 80 percent.

19 MR. CHEUNG: Yes.

20 CHAIRMAN CORRADINI: I thought you said
21 eight. Sorry.

22 MR. CHEUNG: Now in order to -- for a
23 figure of merit for comparison of LOCA evaluation,
24 using the PCT as operating parameter, is not going to
25 change because the core is not uncovered, so we used

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 another measure with that. We used the amount of
2 water step up on top of the extra fuel, the amount of
3 water in the accumulator region, and we collect it,
4 and calculate static head, including the water, 1.5
5 meter, whatever that is, and stick it on top of it,
6 and then that's the measure, the comparator from one
7 case to --

8 MR. WALLIS: As long as you've calculated
9 your core void, it's right.

10 MEMBER BANERJEE: And your chimney void.

11 MR. CHEUNG: I will calculate the amount
12 of water in the chimney.

13 MEMBER BANERJEE: So you have to get the
14 chimney right.

15 MR. CHEUNG: Yes.

16 MR. WALLIS: But, particularly, you've got
17 to get the core right because if there were no voids
18 in the core, that's the only water would be in the
19 core.

20 MR. CHEUNG: Well, depend on the pressure
21 during transient. Next slide, please. Okay. So we
22 have calculate all penetrations, a total of 9
23 penetrations in RPV, using the three creditable single
24 failure relays one PPV available, or one injection rod
25 available, or one safety valve not available. So in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 PCV 6.3 we have presented result maximum line break,
2 water line break, GDL, injection line break, and point
3 of entry line break. And for DPV Step Two, shutdown
4 cooling suction line break or ICU return line break,
5 or GDCS equalization line break we present in response
6 to RAI 6.3-46 , and the slick injection line break is
7 all presented in 6.3, RAI 6.3-65.

8 In summary, all this break for nominal
9 condition, the amount of water stack up in the chimney
10 is about 1.5 meters.

11 MR. WALLIS: What does this chimney static
12 head mean?

13 MR. CHEUNG: It means whatever that two-
14 phase stop in the chimney on top of the core, we
15 calculate amount of water in that.

16 CHAIRMAN CORRADINI: So there's 1.5 meters
17 of pure unadulterated liquid water.

18 MR. CHEUNG: Yes.

19 MR. WALLIS: What is 8.9 meters then?
20 What is that?

21 MR. CHEUNG: That reference to the bottom
22 of the RPV.

23 MR. WALLIS: The bottom of the RPV.
24 Right. So it doesn't really mean anything.

25 MR. CHEUNG: It doesn't mean anything in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the case of our --

2 MR. WALLIS: Much better to talk about
3 them,
4 talk back to --

5 MR. CHEUNG: Because internal calculation,
6 we reference RPV-0. Now we try to go back and say 1.5
7 is the water collected, amount of water stack up on
8 top of fuel. And after the GDCS injection, the water
9 coming in, the water level recover. And the limiting
10 break is the -- based on the evaluation on this
11 nominal calculation, we select the main steam line
12 break and the GDCS injection line break for a bounding
13 condition calculation. And the bounding calculation
14 so that -- which is a GDCS injection line break, we
15 have one injection mode failure. We still have more
16 than one liter of water on top of the field. Now
17 that's from zero to 2,000 seconds.

18 MR. WALLIS: This says during the first
19 three days.

20 MR. CHEUNG: No, this is during the first
21 2,000 seconds.

22 MR. WALLIS: Oh, 2,000 seconds.

23 MR. CHEUNG: The next slide we show the --
24 on the containment calculation we analyze the result.
25 We saw that depends on what break, for all this break

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we evaluate that the static head is more than one
2 meter of water from top of the field for 72 hours.

3 Now beyond 72 hours, we do not have an
4 actual calculation, so we used hand calculation, we
5 evaluate, because some of the water, some of the steam
6 generated in RPV could have condensed in the drywell
7 and the wall region, and then drop down to the lower
8 drywell region, and not going back in the RPV through
9 the recycling of the PCCS. However, we still see that
10 based on calculation that we have more than -- it
11 depends on the break evaluation. Is a low break
12 aeration that acts on the annulus water, we
13 communicate with RPV water, so the amount that would
14 get in the coolant pump. If high aeration break, the
15 RPV have more inventory to boil off, and not coming
16 back.

17 The bottom line is, for all these things,
18 we value the amount of water on top of the fuel of
19 more than one liter.

20 MR. WALLIS: So what does the long-term
21 cooling, is it the PCCS system with the fans, or is it
22 the isolation condenser?

23 MEMBER BANERJEE: Without the fans.

24 MR. CHEUNG: This is not just water in --

25 PARTICIPANT: This is in the first 72

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hours.

2 MR. WALLIS: The PCCS system, you refill
3 the pool. Is that what --

4 MR. CHEUNG: PCCS, refill the pool, and go
5 back to the --

6 MR. WALLIS: So refilling the pool is the
7 long-term cooling.

8 MR. CHEUNG: Yes.

9 MEMBER BANERJEE: Yes, it's the boil-off.

10 MR. CHEUNG: It's the boil-off and coming
11 back.

12 MEMBER BANERJEE: Well, what is the steam
13 velocity here in the chimneys?

14 MR. CHEUNG: Steam velocity in the
15 chimney, I don't have the number.

16 MR. WALLIS: In the chimney is tiny.

17 MEMBER BANERJEE: Well, no. I don't know.
18 That's what I'm asking you, is it just a boil-off,
19 because this is a fairly low pressure now. Right? So
20 you're taking 2 or 3 percent decay heat, and you're
21 generating steam.

22 MR. CHEUNG: Yes.

23 MEMBER BANERJEE: So that's -- just divide
24 by the latent heat in the water, flow area you can
25 give me a velocity. Right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHEUNG: Yes.

2 MEMBER BANERJEE: I'm looking for the
3 velocity.

4 CHAIRMAN CORRADINI: It's not a very high
5 velocity, because you've got 45 megawatts divided by
6 2.2 megawatts per kilogram, so you're producing about
7 22 kilograms a second of steam by boil-off.

8 MR. CHEUNG: Very small amount.

9 VICE CHAIRMAN ABDEL-KHALIK: How many
10 parallel channels are used in these models?

11 CHAIRMAN CORRADINI: You mean the TRACG?

12 VICE CHAIRMAN ABDEL-KHALIK: Right.

13 MR. CHEUNG: In the TRACG. Okay. In a
14 core we model, we have three --

15 CHAIRMAN CORRADINI: I'm sorry?

16 MR. CHEUNG: In the TRACG, the core which
17 we model in three rings, we call them ring one, two,
18 three. And with each ring, we have two different --
19 we beat the ring, we have two different we call
20 chimney addition. We simulate two separate partition,
21 so each ring is a partition, but within the ring we
22 have a single partition, chimney partition to simulate
23 that. So in terms of chimney addition, we have a
24 total of five group to simulate partition with
25 different flow area, or different grouping.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: So three radial
2 positions, and then within each radial position, can
3 you repeat that part again? I'm sorry.

4 MR. CHEUNG: Three radial positions, one,
5 you know, the center one and the next ring we have
6 additional partition --

7 CHAIRMAN CORRADINI: Thank you.

8 MR. CHEUNG: So we have inside the shroud
9 we have total of five parallel channel.

10 MEMBER BANERJEE: So what's the flow area
11 in the core, and the flow area in the chimney, meters
12 squared?

13 MR. CHEUNG: The core shroud diameter is
14 about --

15 MEMBER BANERJEE: No, I mean the flow
16 area.

17 MR. CHEUNG: I don't have the number.

18 VICE CHAIRMAN ABDEL-KHALIK: So the same
19 radial nodalization, five parallel channels, does that
20 carry over to the chimneys, as well?

21 MR. CHEUNG: Yes.

22 VICE CHAIRMAN ABDEL-KHALIK: Okay. Do you
23 think that's adequate for determining any radial
24 variability?

25 MR. CHEUNG: We look at the level response

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in all these five different channels. They all
2 similar.

3 VICE CHAIRMAN ABDEL-KHALIK: Well, sure,
4 because they're all smeared.

5 MR. CHEUNG: Well, in a real -- well,
6 we've got two -- those channel is only 16 bundle, with
7 16 bundle fitting, so that's a real simulation, 16
8 bundle what if the power go into 16 bundle, generally
9 the steam go in that partition.

10 VICE CHAIRMAN ABDEL-KHALIK: Would you say
11 that again? So one of the two in each of the two
12 outer radial zones corresponds to only 16 bundles?

13 MR. CHEUNG: We have two partitions
14 inside, we have total of five parallel channels. Two
15 of them -- each one of those simulates 16 bundles.
16 And out of the 16 bundles they go into the box for
17 this scenario, this partition. There are two.

18 VICE CHAIRMAN ABDEL-KHALIK: And the one
19 in the center?

20 MR. CHEUNG: The one in center.

21 MEMBER BANERJEE: And what about the core?

22 VICE CHAIRMAN ABDEL-KHALIK: Thank you.

23 MR. WALLIS: That's what I mean.

24 MR. WATKINS: That concludes our
25 presentation. I'd like to thank the ACRS Subcommittee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Members for your attention.

2 CHAIRMAN CORRADINI: Thank you for your
3 patience.

4 MR. WATKINS: And thank you to the NRC
5 staff for their thorough review of Chapter 6.

6 CHAIRMAN CORRADINI: Any other last
7 questions before we go to a break? None. So we'll
8 take a short break, 3:25.

9 (Whereupon, the proceedings went off the
10 record at 3:12 p.m., and went back on the record at
11 3:27 p.m.)

12 CHAIRMAN CORRADINI: Okay. So let's get
13 started. The staff will discuss their draft SER, and
14 I was told by Amy that following that, we might go a
15 little bit long because there is an expert here from
16 GE that can address some of the questions by the
17 members on the vacuum breakers. And they also want to
18 discuss the feedwater power flow map. Since they have
19 the ability to do that today, we want to get those
20 questions out of the way. All right?

21 So, Mr. Williams, are you the lead?

22 MR. WILLIAMS: Yes. Good afternoon. My
23 name is Shawn Williams, I'm the Project Manager for
24 Chapter 6. This afternoon the staff is going to
25 present mostly only significant open items within

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 certain sections of Chapter 6.

2 This is a list of the lead technical
3 reviewers. There were many significant contributions
4 by staff. They're in the audience today to also
5 speak, if necessary.

6 I'm going to outline the presentation.
7 I'm going to quickly go over the RAI status, hand it
8 over to Bob Davis to discuss his open items in 6.1 and
9 6.6. Hanry Wagage is going to discuss open items in
10 Chapter 6.2. Weidong Wang is going to discuss open
11 items in Chapter 6.3. If you recall, we've already
12 discussed Chapter 6.4, control room habitability at an
13 earlier ACRS meeting, and Jay Lee is going to discuss
14 Chapter 6.5 with 15.4 tomorrow morning.

15 We issued a total of 306 RAIs, which 215
16 resolved, and right now we have 91 open items, but I
17 do want to say GE responded to 42 out of those 91 open
18 items just recently, so maybe the next month that's
19 going to reduce drastically.

20 I'm going to hand it over to Bob Davis to
21 discuss 6.2 and 6.6.

22 MR. DAVIS: My name is Bob Davis, and I'm
23 in the Plant Integrity Branch, Division of
24 Engineering, and I reviewed Section 6.1.1 on engineer
25 safety features and materials. The ESF materials were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 found to comply with the requirements of ASME Code
2 Section 3, with one exception, which I'll discuss as
3 part of my description of the open items.

4 Fabrication of ESF components comply with
5 the appropriate requirements of ASME Section 3, and
6 materials and processing of stainless steels conform
7 with the guidance in NUREG 03-13, Reg Guide 1.44,
8 which is consistent with the reactor coolant pressure
9 boundary, the requirements are identical, and they met
10 all those. And the cleaning and climate controls, as
11 with the reactor coolant pressure boundary, conform
12 with Reg Guide 1.37.

13 There aren't really very many open items
14 in this section, but some of the ones that are -- we
15 still have a lot of issues with is the isolation
16 condenser, material specifications, fabrication, and
17 processing as the Niobium modified Alloy 600, which is
18 part case, and 580. GEH has indicated that they'll
19 using a tubing spec which is SB 163 for the Alloy 600,
20 as modified by the code case. The code case does not
21 include SB 163, so we're still working with GEH to try
22 to resolve that. Because the code case only includes
23 piping, plate, forging, and bar specs, it does not
24 include any tubing specs; so, therefore, it's not in
25 accordance with Section 3, or Reg Guide 1.84, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lists acceptable code cases.

2 We also have in addition to that material
3 issue, we've asked GEH questions on the effect of
4 induction bending of IC tubes. The testing following
5 bending to confirm the acceptability of the material
6 for use, the IC tubing support design structure to
7 insure there's no presence of crevices, and the
8 material properties of the most limiting vent tube.
9 These same issues, even though it's a different
10 material, are very similar to the CCS heat exchanger,
11 which is made out of 304L tubing, but we have RAIs
12 asking similar questions. And that's it for Section
13 6.1.

14 I also reviewed Section 6.6, which is pre-
15 service and in-service inspection.

16 MEMBER ARMIJO: Can I interrupt?

17 MR. DAVIS: Yes.

18 MEMBER ARMIJO: In RAI 4.5-21, the staff
19 asked questions about the adequacy of the material
20 selected for the ESBWR with respect to the water
21 chemistry. And then the staff closed it out with a
22 statement that says, "The staff finds that it is
23 appropriate for the ESBWR design to include features
24 to facilitate future installation of hydrogen water
25 chemistry", and by inference, that they were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 satisfied, the staff was satisfied that the choice of
2 materials and fabrication was acceptable. And my
3 question is, does the staff believe, and maybe GEH, as
4 well, does the staff believe that the material
5 selected for the ESBWR, primarily the stainless
6 steels, are going to operate for 60 years with normal
7 water chemistry without IASEC or IGSEC? Is that what
8 the staff is saying?

9 MR. DAVIS: Well, I think for the IASEC,
10 we'll have to direct that -- that probably wouldn't
11 apply to the ESF components. I guess you're talking
12 about reactor vessels internals for --

13 MEMBER ARMIJO: Yes, reactor vessel
14 internals, as well.

15 MR. DAVIS: So I'll address the ESF
16 components, and then for reactor vessel internals, we
17 have the gentleman here who reviewed that section.
18 But for the ESF materials, yes, we do believe that
19 they are using -- for the stainless steel materials,
20 they are using Category A materials per NUREG 03-13,
21 which we recognize as not even needing any additional
22 inspections as far as IGSEC. Now that's -- now for
23 the question on the vessel, I guess Nahir Ray could
24 speak to that.

25 MR. RAY: Hi. This is Nahir Ray from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff. I think this same subject we discussed as
2 Chapter --

3 MEMBER ARMIJO: And we'll discuss it
4 again, as long as I'm --

5 (Laughter.)

6 MR. RAY: And during that -- and, also, we
7 are currently reviewing and trying to address your
8 questions, which came to EDO's office. So to address
9 the subject is this way. Reactor internals in the
10 ESBWR are made up very low .02 carbon stainless steel,
11 and that's one thing. If you --

12 MEMBER SHACK: That's bad for IASEC.

13 MR. RAY: Right. I'm coming back to that.
14 I think they -- let's recognize one fact here. BWR
15 plates in current plans, almost all of them having
16 this problem of IGSEC and IASEC problems. We all know
17 that.

18 Now knowing that, what we can do, or what
19 GE can do, or what they have done - let me summarize
20 that. First of all, the internals, they used
21 basically the lowest possible carbon content there,
22 and the second question that you raised, and you asked
23 for is, are they going to do any water chemistry
24 control?

25 The answer - actually, we are trying to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 answer that question along with GE. We had several
2 phone calls with them, and the answer in a summary to
3 you is they are still thinking about it, and trying to
4 figure out what are the best solution for that
5 situation. And here are the four options they told us
6 yesterday over the phone.

7 One is the solution, and the second
8 solution is make it completely forged, no welding.
9 Third is use the water chemistry control, which in
10 their opinion, for all domestic potential customers,
11 they already decided to put that water chemistry
12 control in their plans, which is currently in the
13 ESBWR as an option. And, in addition, I suggested to
14 them what about frequent inspection of the internals,
15 and associated components. And they didn't comment
16 anything, so these are the four options basically on
17 the table. And we are planning to provide you the
18 response in that with all four options.

19 MEMBER ARMIJO: Okay. Well, the point
20 about the -- thank you. If domestic customers for
21 this plant are going to use the hydrogen water
22 chemistry to protect against IASEC, and, frankly, I
23 think also against IGSEC, even with the low carbon,
24 because there have been instances of low carbon 316
25 failing in Swedish reactors, piping, welds, so if the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 U.S. customers are going to specify that process, I
2 don't understand why it isn't part of the -- in the
3 DCD, and part of the design certification. Would they
4 have to come back later and do an amendment to the
5 certified design in order to have hydrogen water
6 chemistry?

7 MS. CUBBAGE: No. And I'd actually like
8 to turn to GE to answer that.

9 MR. UPTON: We don't believe that it will
10 require us to come back. It's in the DCD as an
11 option, and it's really an economic decision by the
12 customer whether he wants to install it or not. We
13 think that we recommend it, and that's our position
14 going in from day one, but we leave it to the
15 customer.

16 MEMBER ARMIJO: So GE recommends the
17 hydrogen water chemistry for protection of the
18 austenitic stainless steel components.

19 MR. UPTON: That's correct.

20 MEMBER ARMIJO: Okay. Thank you.

21 MR. DAVIS: And in addition to the -- on
22 the rad coolant pressure boundary pipe, we have
23 discussed with GE about information to DCD regarding
24 service preparation when they do have to grind, and
25 the grinding is held to a minimum. And that language

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that we've asked them to put in the DCD is similar to
2 what the staff requested for the BWR PIT for
3 addressing welds for internals.

4 I also reviewed Section 6.6, which is
5 Class II and III PSI and ISI. With the exception of
6 open items, PSI and ISI Class II and III systems were
7 found to comply with the requirements of 10 CFR
8 50.55a, and ASME Code Section 11. The development of
9 the pre-service and in-service inspection program is
10 the responsibility of the COL holder.

11 All items within the Class II and III
12 boundaries are designed to provide access for
13 examination as required by Section 11.

14 Augmented examinations include augmented
15 ISI to protect against postulated piping failure
16 between containment isolation valves. That will be
17 performed in accordance with the recommendations of
18 the Standard Review Plan, as acceptable. And
19 augmented inspections as described in Generic Letter
20 89-08 to detect and monitor potential wall thinning of
21 high energy piping by erosion, corrosion will be
22 implemented. And that will be included to all ASME
23 Code Class I, II, and III, and non-code class piping
24 that is susceptible.

25 The open items that we have, I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 somebody brought it up earlier about the accessibility
2 of welds. Well, we still have the same open item that
3 we had for reactor coolant pressure boundary. Yes,
4 all the welds can be inspected by Section 11. Our
5 concern is that those welds that cannot be inspected
6 by UT, that would have to be inspected by RG, that
7 later on licensees, as they do now, would come in and
8 say it's impractical to do an RT and would want a
9 relief request.

10 And the NT selected for each weld that
11 would be ISI, you can't select a method that is going
12 to be impractical, because you have to drain the pipe,
13 or you have to do something that you know that that's
14 going to be a hardship later on, so we're still
15 working to resolve those issues.

16 We also have issues with the inspection
17 for the isolation condenser and the PCCS heat
18 exchangers. Currently, the isolation condenser, the
19 only thing that's planned is a VT2, and we're not sure
20 that we're going to be able to accept that. The code
21 doesn't really address the isolation condenser, and
22 applying rules that are meant for pipe may not be
23 acceptable, especially given that they're submerged in
24 water, which makes it more difficult to do a VT2 on
25 them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The COL action items for this section, the
2 COL applicant will provide a description of the PSI
3 and ISI programs for Class II and III components, and
4 the milestones for the full program implementation.

5 MR. WILLIAMS: Any questions on 6.6? Then
6 we'll move to Handry Wagage, Chapter 6.2. Handry.

7 MR. WAGAGE: Good afternoon. My name is
8 Handry Wagage. I'm going to talk about the
9 significant open items in Section 6.2. I reviewed
10 Section 6.2.1 on containment functional design. I got
11 support from Alan Notafrancisco of Office of Research,
12 who is in the audience, for containment analyses.
13 Office of Research performed confirmatory analyses
14 with MELCOR computer code.

15 Andrzej Drozd, who is also in the
16 audience, reviewed Section 6.2.2 on passive
17 containment cooling system. Fred Goyle, who is also
18 in the audience, performed review on Section 6.2.4 on
19 containment isolation system, and 6.2.5 on combustible
20 gas control in the containment.

21 GEH went through the design features of
22 containment, drywell, and wetwell. I would like to
23 remind you that what we mean by drywell and wetwell,
24 just to make sure when I talk about bypass from
25 drywell to wetwell. Wetwell is --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: You might want the
2 pointer with the pad on it.

3 MR. WAGAGE: Oh, you have one? Okay.

4 CHAIRMAN CORRADINI: You don't want the
5 gas into the room. You never know what's going to
6 happen.

7 (Laughter.)

8 MR. WAGAGE: It shakes. That's why I
9 don't like this. This is the boundary of the -- this
10 is the wetwell. Oh, that's much better.

11 This is what they call wetwell, which
12 contain the suppression pool and the suppression pool
13 air space. And everything else in the containment
14 boundary, containment boundary is right here. And
15 this is the physical containment boundary. Everything
16 else is called drywell.

17 I have an open item in containment sub-
18 compartment analysis. In this containment, GEH
19 considered two sub-compartments. One is this drywell
20 head region, second one is not shown here. It is
21 reactor shield annulus. There's reactor shield around
22 the vessel, there's the annulus. About these two sub-
23 compartments, the first one did not have any high
24 energy line, so there was no need to analyze that.
25 GEH analyzed two high energy line breaks in this sub-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 compartment in reactor shield annulus. Those were
2 feedwater line break and reactor water coolant unit
3 line break. We had used TRACG computer code. Tough
4 plan to perform confirmatory analyses of sub-
5 compartment with TRACE computer code. To get ready
6 for these analyses, staff requested more information
7 on the details of GE analyses.

8 By reviewing the GE analyses, we found
9 that GEH mistakenly calculated half of the mass and
10 energy coming into the sub-compartment, so by that, it
11 was in error. GEH had to recalculate. We have not
12 seen the results yet.

13 CHAIRMAN CORRADINI: What's the error?

14 MR. WAGAGE: Error was that the mass and
15 energy coming into the sub-compartment, mass and
16 energy release head, by mistake GEH calculated half of
17 that coming in.

18 MR. WALLIS: Because it's a single-ended
19 break or something, or what is it?

20 MR. WAGAGE: No. What happened was that
21 this is an annulus, this is by symmetry, the
22 calculation assumed half of that for modeling. When
23 they assumed half for the modeling, then they have
24 calculated it ---- they have to get the half of the
25 mass and energy coming in. Then they got half of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mass and energy coming in. To get the velocity of
2 flow, they divide by the total area. Now we are
3 modeling half of the annulus, we have to use half the
4 area, by which they double --

5 CHAIRMAN CORRADINI: They dragged out the
6 time scale of the event.

7 MR. WAGAGE: Yes. It's slow energy coming
8 in, and also this is a short time scale, milliseconds
9 time -- it's a short, very short time scale. That
10 mean it pressurizes quickly, that mean it's completely
11 off, that means GEH has to recalculate, and we have to
12 see the results.

13 MR. MARQUINO: This is Wayne Marquino. We
14 concur with what's been said. This has to do with the
15 local pressures in the annulus area, and it doesn't
16 affect the containment pressure responses that you saw
17 earlier.

18 CHAIRMAN CORRADINI: Is this a
19 qualification-related issue relative to what's in that
20 region?

21 MR. WAGAGE: This is to find whether that
22 annulus can stay in tact.

23 CHAIRMAN CORRADINI: So, essentially, a
24 pressure loading, a local pressure loading.

25 MR. WAGAGE: Or loading on the annulus.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Okay. Thank you.

2 MR. WAGAGE: I have an open item on
3 containment debris protection for ECCS strainers.
4 There are no pumps in ESBWR for cooling for first
5 three days, so GEH suggested that there was no need to
6 do analyses for debris in the earlier DCD revisions.

7 Then we questioned that there may be
8 possibilities also, there are no pumps, the debris may
9 getting into water coming into the core. One
10 possibility, that this is PCCS condenser. During the
11 blow-down, debris may getting into these inlet pipe
12 and go through PCCS, and get into the GDCS pool.
13 That's one path. It gets into GDCS pool, where there
14 is GDCS injection into the core, the debris can get in
15 there.

16 CHAIRMAN CORRADINI: What would be the
17 composition of what you're worried about? What would
18 get in there?

19 MR. WAGAGE: During the blow-down, debris
20 is produced, because of blow-down. Some may getting
21 into this pipe.

22 CHAIRMAN CORRADINI: Yes.

23 MR. WAGAGE: And go through the condenser.
24 And when water drains into the GDCS pool, debris may
25 getting into GDCS pool.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Were you concerned
2 about any hold-up on the actual tubing?

3 MR. WAGAGE: Actually, we asked that
4 question. What GE said was that hole size of that
5 debris screen was one inch, whatever gets in go
6 through the condenser because that hole is smaller
7 than the size of the condenser. And there is another
8 possible part debris can getting into the system.
9 There is that opening in the GDCS air space to the
10 drywell. We asked questions on that later. GEH added
11 the debris screen to that so that during the blow-down
12 debris would not get into GDCS pool.

13 CHAIRMAN CORRADINI: Is there any -- so
14 let me ask the question differently, so you can see
15 where I'm worried about it. Is there any sort of
16 transport mechanism, that if I have small enough
17 particles that aren't trapped by the cone screen
18 entering the PCCS, and flow with the flow through the
19 tubes, that they wouldn't be transported, almost like
20 a cold trap, onto the heat transfer area. Right?
21 I've got dust in the flow, it condenses, I bring it to
22 the surface. What makes the dust want to stay with
23 the liquid and not essentially start affixing itself
24 and fouling the surface?

25 MR. WAGAGE: GEH used only metallic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 insulation, so it will be pieces of metals, not
2 regular dust, or any other pipe insulation. It may be
3 possible, some of the little pieces may stuck.

4 CHAIRMAN CORRADINI: So because it's
5 metallic, you don't think there would be any sort of
6 fouling issue.

7 MR. WAGAGE: No. This happens only during
8 the blow-down.

9 CHAIRMAN CORRADINI: No, I understand.
10 Yes, I understand that.

11 MEMBER SIEBER: What about biological
12 fouling? You've got a lot of open pools here
13 uncirculating basically. It would seem to me it's a
14 perfect for biological fouling.

15 MR. UPTON: This is Hugh Upton with GEH.
16 Let me address that. There is a pool cooling and
17 cleanup function for the ICPCP pools. It's
18 demineralized water, and we maintain the clarity, so
19 we don't believe that there's going to be biological
20 fouling.

21 MEMBER SIEBER: What about these other
22 open pools?

23 MR. UPTON: They're all cleaned and cool -
24 - FAPCS, actually, that's one of the functions of that
25 system is to cool and clean up those pools.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: You don't use any chemical
2 treatment I take it.

3 MR. UPTON: No, it's demineralized water.
4 We have no chemical treatment.

5 MEMBER SIEBER: So there's no way to kill
6 off bacteria or anything else that's in there. Right?

7 MR. UPTON: The system, the FAPCS systems
8 have demineralized filter beds, so that's where it
9 would get caught.

10 MR. WAGAGE: Other features of this ESBWR
11 is there is suppression pool liner which is made of
12 stainless steel, and GDCS liner made of stainless
13 steel. There is no way that rust getting into the
14 system, like other systems.

15 MEMBER ARMIJO: When you look at these
16 things, do you and GE assume that nothing will be in
17 the containment except what they designed? I mean,
18 people work in there, people do maintenance in there,
19 and sometimes things get left behind. Is any of that
20 under consideration?

21 MR. WAGAGE: Yes, because we are going to
22 insist that the system has to be designed according to
23 the guidance in Reg Guide 1.8-2, Revision 3, that has
24 latent debris, that mean that GE has to consider
25 latent debris.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Do you have some
2 specification on how of that they have to consider in
3 the containment?

4 MR. WAGAGE: How much -- early BWR
5 considers certain amount, but GSI 191 issue that
6 during the resolution of GSI 191 we learned more about
7 this latent debris, and we are working on it, how to
8 address those issues for BWRs.

9 There is suppression pool equalizers in
10 line. When the vessel water level comes down in the
11 long-term, water from suppression pool can inject into
12 the vessel. We asked GEH to explain how it's going to
13 prevent debris getting into the vessel through these
14 GDCS equalizers and line, because during the blow-
15 down, some of the debris can get into the suppression
16 pool through the vertical and horizontal vents. And
17 that debris can move into the vessel.

18 We have in RAI 6.2-6, GEH is working on it
19 as we had a telephone call to GEH. You recall that
20 GEH is going to use design this strainer according to
21 Reg Guide 1.8-2, Revision 3.

22 There is an other related issue.

23 CHAIRMAN CORRADINI: If I could just ask
24 a question here, just so, again for my own
25 understanding. Is there some sort of -- in your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussions with GEH, where they think if there is
2 debris produced, where it would end up being mainly
3 accumulated? Will it mainly accumulate in the bottom
4 of the suppression pool? Will it mainly be
5 accumulated on surfaces? What is the disposition,
6 given that the major, if I remember correctly, the
7 major limiting accident is the main steam line break,
8 and then feedwater. Where does the debris go,
9 primarily?

10 MR. WAGAGE: This is -- we are working on
11 it.

12 CHAIRMAN CORRADINI: Okay. Still in
13 process.

14 MR. WAGAGE: Still in progress. The main
15 reason was that because there are no pumps, this
16 wasn't an important issue. And as you saw some
17 results from GEH today, in the long term, GEH is going
18 to use suppression pool water to inject into the
19 vessel. Then there will be recirculation. Then we
20 have to consider -- then we have to ask how debris is
21 going to --

22 CHAIRMAN CORRADINI: You brought this up,
23 but I guess just to clean up, because we had asked
24 this of them earlier, maybe you weren't in the
25 audience. What I thought I heard was that given the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 way they see the accident going, in the first 72 hours
2 they're not seeing any need for the initiation of the
3 equalization line opening, unless I misunderstood
4 their discussion.

5 MR. WAGAGE: Agreed. I agree. During the
6 first 72 hours, yes. But in response to RAI, GEH
7 mentioned the long term, that when they use equalizing
8 the line, how to insure that this is not an issue
9 given the long term. For first 72 hours, yes.

10 CHAIRMAN CORRADINI: Okay. Thank you.

11 MR. WAGAGE: There is a related open item
12 coming from Section 6.1.1, which is on unqualified
13 core rings, because I insist that we are going to --
14 according to the guidance, that debris screens had to
15 be designed according to Reg Guide 1.82, Revision 3,
16 that GEH has to consider unqualified core rings that
17 are supposed to be damaged, and enter into the
18 atmosphere and come off then maybe into the pool, so
19 this open item is asking GEH to quantify it's
20 unqualified core rings.

21 We have an open item on GDC 50. GDC 50
22 states that containment structure shall accommodate
23 design leakage with sufficient margin containment
24 pressure and tempered following a LOCA. When we saw
25 that GEH calculated containment pressure, we found

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that pressure was gradually rising, and calculation
2 stopped at 72 hours. When we looked at the results,
3 there was no guarantee that after 72 hours the
4 pressure would not exceed design pressure.

5 We asked General Electric to explain. GEH
6 came up saying that there is a PCC pool refill after
7 72 hours using a FAPCS, that's supposed to solve the
8 problem. We wanted some analysis. When we saw the
9 analysis, we found only that PCC pool refill would not
10 help. There was more need for other systems to be --
11 we did staff confirmatory analyses with MELCOR
12 computer code. It confirmed the same. That was an
13 issue after 72 hours, although the pressure stayed
14 below design pressure within 72 hours, after 72 hours
15 the issue would come up.

16 CHAIRMAN CORRADINI: So let me ask you
17 about the MELCOR calculation. Does the MELCOR
18 calculation also estimate radiolytic composition, or
19 is that a separate calculation that's an input?

20 MR. WAGAGE: We use radiolytic gas
21 production after we found that GEH used that. We had
22 an --

23 CHAIRMAN CORRADINI: No. I'm asking once
24 you did it, did you have an independent check of the
25 rate?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WAGAGE: The rate --

2 CHAIRMAN CORRADINI: Not use their rate,
3 have somebody else go and do it to make sure they got
4 the same rate?

5 MR. WAGAGE: The Office of Research --

6 MR. SNODDERLY: Handry, this is Mike
7 Snodderly, NRC staff. I believe from our audit that
8 took place in December of last year at GE, I believe
9 GE said that they used the radiolytic source term that
10 was in Reg Guide, the previous source term that was in
11 Reg Guide 1.7 before it was updated as part of the
12 50.44 revision, it removed the radiolytic source term.
13 So it's the one that was in Rev 2 of Reg Guide 1.7, I
14 believe.

15 CHAIRMAN CORRADINI: Say that again
16 slower. I don't think I got it.

17 MR. SNODDERLY: They used the radiolytic
18 source term that was in Reg Guide 1.7, Revision 2,
19 which told you how much radiolysis to consider in
20 doing the 50.44 analysis. But when 50.44 was updated
21 to eliminate the need for recombiners, because the
22 risk was from the more bounding severe accident, that
23 source term was then taken out of Revision 3. But
24 that was my understanding of the source term that they
25 used.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: So they use it from -
2 - so let me ask a different question. So it's
3 realistic, conservative, it's what?

4 MR. SNODDERLY: Conservative.

5 CHAIRMAN CORRADINI: How conservative?

6 MR. SNODDERLY: Again, I'm going by --

7 CHAIRMAN CORRADINI: Got six fans.

8 MR. SNODDERLY: I'm going by memory, but
9 I believe it used a radiolytic factor of like .4,
10 which is very conservative. It has to do with a
11 number of factors, such as pH and other things, but
12 it's a very -- it's a conservative bounding factor.

13 CHAIRMAN CORRADINI: Okay. Thank you.

14 MR. SNODDERLY: But there is a basis for
15 that source term. It's the staff. It was in a
16 previous Reg Guide.

17 CHAIRMAN CORRADINI: But then just to --

18 MR. SNODDERLY: But no, it's not
19 realistic.

20 CHAIRMAN CORRADINI: That's okay. But
21 just to educate me, even though not realistic, it is
22 the only basis that they can use?

23 MR. SNODDERLY: There is no guidance for
24 that particular calculation. I mean, there was
25 guidance, as I said, for calculating radiolysis when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there was a 50.44. The new 50.44 doesn't require it.
2 And, again, I'm speaking for GEH, and they can jump in
3 when they would like to.

4 CHAIRMAN CORRADINI: You gave me the base
5 -- you just told me --

6 MR. SNODDERLY: My understanding is they
7 were looking for one, and that was one that exists,
8 and they used it.

9 CHAIRMAN CORRADINI: Thank you.

10 MR. SNODDERLY: And we, of course, didn't
11 have a problem with that one, because we understood
12 it, and we knew it was conservative.

13 CHAIRMAN CORRADINI: Okay. Thank you.

14 MR. WAGAGE: We have a policy paper, SECY
15 94-084 on RTNA system, figurative treatment of non-
16 safety systems. According to this policy, advance
17 reactors can use non-safety systems after 72 hours.
18 That's what we saw in GEH's results that they're using
19 non-safety systems after 72 hours.

20 The reason for this gradual increase of
21 pressure is -- the main reason is that this is
22 completely a passive containment cooling system, which
23 is not -- which is of less capacity as compared to
24 active system. Active system pumps start, and they
25 dump water into the core, and also containment space

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 coming and drop the pressure. But passive containment
2 cooling system, depend on how much steam is produced
3 in the core and then removed. That's one reason.

4 Second reason is that containment
5 suppression pool bypass. I'm going to talk about more
6 on suppression pool bypass later. Because of these
7 two reasons, contain pressure was rising, this was the
8 first time we have seen that containment pressure was
9 rising at the end of the calculation. Other advance
10 reactors calculated contained pressure, but they were
11 lower because of the active systems coming in, and
12 this was the first time, so we were asking RAI on that
13 one. We asked RAI 6.2-140.

14 We saw the GEH new results, that new
15 results are encouraging. This new system, the PCC gas
16 recirculation system has several advantages. One, the
17 reason that contained pressure was rising more, that
18 PCC was degrading because of accumulation of non-
19 condensables, and non-condensables have to be purged
20 into the wetwell. GEH -- this gas recirculating
21 system, what it does is that it creates a flow path
22 through PCC condensers by which it removes the non-
23 condensables, then it increases the PCC efficiency and
24 increase heat transfer. And because there is higher
25 flow rate than before, that increases heat transfer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 coefficient, and it increases flow to PCC. And, more
2 importantly, that bypass will not be an issue after
3 this new system starts working at 72 hours.

4 CHAIRMAN CORRADINI: Pardon me. Can I ask
5 a question about the first of the three effects?

6 MR. WAGAGE: Yes.

7 CHAIRMAN CORRADINI: You had in your SER -
8 now I can't find it - but you had in your SER a table
9 where you showed timing of the TRACG calculation
10 versus MELCOR. Maybe it was just the MELCOR
11 calculation. In the absence of radiolytic
12 decomposition, does MELCOR show a turn-around, or just
13 essentially reaching a stable equilibrium pressure?

14 MR. WAGAGE: We did not see turn-around,
15 even we turn off radiolytic decomposition.

16 CHAIRMAN CORRADINI: But was it rising?
17 I would expect --

18 MR. WAGAGE: Yes, it was rising. I mean,
19 it was not the major reason. The major reason is that
20 the bypass, I think bypass discussion come in the
21 earlier presentation. What bypass does is that it
22 continually leaks steam into the wetwell air space
23 which pressurizes the wetwell air space. And all the
24 other BWRs, including ABWR, this bypass is an issue
25 only during the initial blow-down, because after

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 suppression pool sprays come in and drop, condenses
2 the steam, that then the active systems inject water
3 into the core. The pressure is low. But in this
4 case, the design of PCCS is such that it depends on
5 purging of non-condensable into the suppression pool.
6 For that we have to have a pressure gradient between
7 drywell and wetwell to purge non-condensables. That's
8 why this vent line is submerged, that pressure
9 difference is equal to that pressure different coming
10 from the vent line submerges.

11 Now in this case, because there is -- the
12 PCC depend on these pressure difference for purge of
13 non-condensables, that works against us. Now there is
14 a pressure gradient between drywell and wetwell. That
15 same pressure gradient causes bypass to continue
16 during a low time period. That's why you see there is
17 a pressure difference. Drywell pressure is slightly
18 higher than wetwell pressure, that difference you see
19 because of the submerging. So bypass is a major issue
20 in this one.

21 CHAIRMAN CORRADINI: So it's not -- I'm
22 sorry. It's not the radiolytic decomposition in terms
23 of the MELCOR analysis, it's the bypass amount? So
24 let me ask the question slightly different. If the
25 bypass amount in the audit calculation with MELCOR,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with TRACG if you had the same bypass, would you come
2 to the same, essentially the same qualitative
3 behavior? It may not be the same number, but the same
4 qualitative behavior?

5 MR. WAGAGE: Yes. Our analyses confirmed
6 that decomposition concludes in same, similar results
7 like TRACG analysis of GEH.

8 CHAIRMAN CORRADINI: Okay. Because your
9 answer with bypass seems to answer what the pressure
10 level would end up at. It doesn't answer the rate to
11 get to it. It seems to me in the absence of adding
12 more non-condensable gas, with bypass all I do is
13 essentially have a less efficient heat exchanger,
14 which means the absolute magnitude of the pressure I
15 get to would be different. It might be higher, or
16 lower, depending on the amount of bypass, but I
17 eventually would get to essentially a zero slope line;
18 whereas, with radiolytic decomposition, I'm adding
19 mass, which has continued to pressurize. So I
20 understand your explanation, but for a different
21 reason.

22 MR. WAGAGE: I think one important point
23 missing here is that by bypass what you mean is that
24 some steam bypassing the suppression pool water, and
25 without condensing, getting into this air space.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Yes.

2 MR. WAGAGE: If you do that, then steam
3 keeps coming into this air space, and keep
4 pressurizing. That's the reason the pressure was
5 going up.

6 CHAIRMAN CORRADINI: Right, but just to
7 push the point one last -- I've got all that water
8 down there, so it's a different amount of heat
9 exchange. It's less efficient than the PCCS, but I'm
10 still condensing it on the water of the surface of the
11 water. It's just a slower rate, so I come to a
12 different equilibrium value, not to a different -- not
13 to a continually increasing slope. See my point?

14 MR. WAGAGE: Yes. There is some
15 condensation at the surface. That's significantly
16 smaller than condensing in the pool. To find the
17 effect of this, we assumed in our confirmatory
18 analysis -- in one case we assume there is no bypass
19 at all. In that case, what we found was that pressure
20 would not go higher. It was going slightly higher and
21 higher, but at much slower rate. The reason is that
22 although there is no bypass, still there is effect of
23 non-condensables affecting PCCS efficiency, reducing
24 heat transfer rate.

25 MEMBER BANERJEE: Now, can you give me a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 physical picture of how that bypass occurs, actually,
2 what is happening? So the pressure in the drywell is
3 higher than the wetwell.

4 MR. WAGAGE: Yes.

5 MEMBER BANERJEE: So there's some flow,
6 which is a mixture of steam and non-condensables
7 flowing in. Exactly where is it flowing in?

8 MR. WAGAGE: Okay. That's --
9 unfortunately, we don't show those vacuum breaker
10 valves. The vacuum breaker valves are between drywell
11 and wetwell. That's the main bypass path. And in
12 addition to that, there may be some minor openings.

13 CHAIRMAN CORRADINI: Some what? I'm
14 sorry.

15 MR. WAGAGE: Some small openings. We
16 don't know where the openings, cracks, or whatever.

17 MR. UPTON: This is Hugh Upton with GEH.
18 In our opinion, the most credible path is through the
19 vacuum breakers.

20 MR. WAGAGE: Yes, I agree with that
21 completely. I mean, that's the most credible, but
22 there may be other flow paths. That's the point I was
23 making.

24 MEMBER BANERJEE: Now, what is the
25 physical dimensions of the space above the water level

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the wetwell?

2 MR. WAGAGE: I have it somewhere in a
3 later figure.

4 MEMBER BANERJEE: The vacuum breakers are
5 right on top, they're not on the side. Right?

6 MR. WAGAGE: Yes, right on the top, and
7 they are to be protected from hydrodynamic loads.
8 There is another section, hydrodynamic loads, GEH has
9 --

10 MEMBER BANERJEE: Whatever is seeping
11 through them, mixture of non-condensables and steam,
12 you are saying accumulating at the top, and not
13 communicating very much with the water below.

14 MR. WAGAGE: Yes. There is no mixing in
15 the wetwell air space. If you had wetwell space, then
16 --

17 MEMBER BANERJEE: Well, clearly because
18 steam is a little bit lighter than air, so it tends to
19 --

20 CHAIRMAN CORRADINI: It's not going to
21 unmix.

22 MEMBER BANERJEE: No, it's not going to
23 unmix. And the temperatures are the same?

24 MR. WAGAGE: Same, temperature were --

25 MEMBER BANERJEE: Drywell and wetwell?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WAGAGE: The air space, consider air
2 space here is similar, not much different. But water
3 is much lower than that.

4 VICE CHAIRMAN ABDEL-KHALIK: Perhaps GE
5 can answer this. Order of magnitude, what is the tube
6 side volume of the PCCS heat exchanger? Order of
7 magnitude, not exact number.

8 MR. CHEUNG: This is Chester Cheung. The
9 tube water into the warmer is about couple of meter,
10 couple of cubic meter.

11 VICE CHAIRMAN ABDEL-KHALIK: Okay. So
12 let's say 50 cubic feet. And you have -- if you put
13 one of those vent valves running at 700 CFM, how long
14 do you think it would take to pull any and all gas out
15 of the tubes?

16 MR. CHEUNG: Now it takes some time to
17 take it out, but remember that it's coming in back
18 from the other end and recirculate. The non-
19 condensable gas coming from the wetwell into the
20 drywell because vacuum breaker open, and then they
21 will find their way into the tube again. And then you
22 eventually get your creeping point that the gas
23 mixture going into the tube, a certain percentage, a
24 certain mass fraction, and then stay there.

25 MEMBER BANERJEE: I think, Mike, we will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 need to understand this. I do agree with you that we
2 should do --

3 CHAIRMAN CORRADINI: Okay. Keep on going.
4 We've confirmed something for ourselves. Thank you
5 very much.

6 MR. WAGAGE: We will have to review GEH
7 response. We are awaiting for GEH to respond to RAI
8 6.2-140 on GDC 50 use. You saw some results today.
9 When we get the results, we will review that. We will
10 continue our MELCOR calculation for long term, and
11 confirm --

12 MEMBER BANERJEE: When will you bring in
13 rough terms this understanding of this from the staff,
14 and your communication with GE, to some sort of a
15 position where we can look at it more or less in its
16 final form?

17 MS. CUBBAGE: We'd be planning to come
18 back to the Committee with the final SER about a year
19 from now, maybe a little bit less than that. If there
20 was a need to get into a lot of detail between now and
21 then, we could schedule a separate Subcommittee
22 meeting, but the intent on most issues is to come back
23 with resolution at the final SER.

24 MEMBER BANERJEE: But to deal with some of
25 these subjects in a Subcommittee meeting would be -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are we talking about three months, two months, one
2 month, six months? What is the time scale?

3 MS. CUBBAGE: Not one month, probably
4 something more like six months, three to six months.

5 MEMBER BANERJEE: Oh.

6 MS. CUBBAGE: I think coming back in a
7 month, you wouldn't probably hear much more than
8 you're hearing now.

9 MR. WALLIS: Will you perhaps do some
10 confirmatory analysis?

11 MR. WAGAGE: This is regards of
12 confirmatory analyses. What you are seeing here is
13 that sensitivity to contain suppression pool bypass.
14 Remember that at three days, PCC pools refill, but
15 this calculation we did not consider that PCC pool
16 refill. That's why there is no change in gradient at
17 three days. If you use one square centimeter, this is
18 the pressure. That's the design value GEH used in its
19 calculation.

20 VICE CHAIRMAN ABDEL-KHALIK: And what is
21 the cause of the slope difference, rapid increase in
22 slope at four and a half days?

23 MR. WAGAGE: This time, rapid increase is
24 because of PCC pool refill, PCC pool boiling, because
25 of boiling in the PCC pool, pool water level goes down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and there is much less heat transfer.

2 CHAIRMAN CORRADINI: You're running out of
3 water?

4 MR. WAGAGE: As I said at the beginning,
5 this is not the way it's going to be operated. We
6 assumed for this calculation for simplicity, there was
7 no PCC refill. When PCC is refilled --

8 MEMBER BANERJEE: No refill of the PCC
9 pool you are saying.

10 MR. WAGAGE: In the design, PCC pools are
11 going to be refilled after 72 hours.

12 CHAIRMAN CORRADINI: Right.

13 MR. WAGAGE: There will be enough water
14 after 72 hours, but we did not assume that condition
15 in this calculation. That's why you see the -- there
16 is no change in gradient.

17 MEMBER BANERJEE: That's just boiling in
18 the PCC pool.

19 MR. WAGAGE: Yes. Water level coming
20 down. As you are showing GEH results, so that there
21 the pressure comes down right away, because that's one
22 reason. Other one is that main system --

23 MR. WALLIS: The results are so sensitive
24 to this very small leak.

25 MR. WAGAGE: Exactly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: How are you going to measure
2 it? How are you going to know what it is?

3 MR. WAGAGE: What we have this RAI on,
4 that's an important question.

5 CHAIRMAN CORRADINI: Well, let's just take
6 one line, the red line.

7 MR. WAGAGE: Okay.

8 CHAIRMAN CORRADINI: And then we'll stop
9 torturing you. We're going to find another meeting to
10 torture you on it. But at the red line, it looks like
11 it's coming to some steady state, and you get these
12 wiggles, and then there's a slope, and then there's
13 another slope. So when we have the little wiggles, is
14 that when we're starting to boil off? What's the
15 wiggles?

16 MR. WAGAGE: Wiggles? Okay. We have
17 Andre Drozd here.

18 CHAIRMAN CORRADINI: The wiggle explainer?

19 (Laughter.)

20 MR. DROZD: I'm Andre Drozd from
21 Containment. The design value for the PCC pool is
22 that at three days, the water level is going to go
23 down to the top of heat exchanger tubes, so that's
24 where you see how the two-phase level is dropping down
25 and down. And that's the artifact of calculation, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 water level is going up and down, and the area,
2 transfer area is slowly diminishing.

3 CHAIRMAN CORRADINI: Okay. And then after
4 the wiggles are done at 3.6 days.

5 MR. DROZD: Right. Just drying out. Just
6 drying out.

7 CHAIRMAN CORRADINI: Right. Thank you.
8 And that same sort of wiggling is just for seating to
9 earlier times as we bypass.

10 MEMBER BANERJEE: You're not going to get
11 off so easy. Go back to the previous slide, please,
12 for me. Now you didn't do anything like GE did, like
13 turning on these vent fans or anything to --

14 MR. WAGAGE: No, that came much later.

15 MEMBER BANERJEE: Okay.

16 CHAIRMAN CORRADINI: I think these MELCOR
17 calculations were done many months ago.

18 MR. DROZD: I mean, those results are not
19 submitted to us yet, and that --

20 MEMBER BANERJEE: Potentially, how -- if
21 this is happening due to bypass, and I can see the
22 mechanism you're talking about, I'm trying to think
23 physically what happens if you turn the fans on, and
24 you -- what does that do for you?

25 MR. WAGAGE: If you turn the fans on at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that time bypass really is not an issue, because by --
2 what that fan does, there is a T-connection from the
3 vent line. There is a T-connection. It takes suction
4 from PCC.

5 MEMBER BANERJEE: It just doesn't let it
6 go into the suppression pool. Right?

7 MR. WAGAGE: That's right. Now what
8 happens is that steam and water mixture -- because
9 there's suction here, there is a T-junction. There is
10 a fan operating. There's suction, and --

11 MEMBER BANERJEE: Just making a forced
12 convection --

13 MR. WAGAGE: That's right, forced
14 convection. And there is no pressure gradient now
15 because the non-condensables goes back to the drywell.
16 Again, it's recirculated. Stop this bypass completely
17 when this system starts, so it's not an issue, but we
18 have an issue before three days, before these systems
19 come in. Then we have question how are they going to
20 measure, how are they going to confirm that one
21 centimeter squared assumed in the analysis is --

22 MS. CUBBAGE: This was an early
23 calculation that was demonstrating, number one, the
24 sensitivity to bypass, thinking also that there was a
25 concern with the peak pressure that was calculated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And now GE is addressing it, and we need to review
2 that when it's submitted. I don't think we're going
3 to get much more out of this right now.

4 MR. WAGAGE: This is sensitivity to
5 bypass.

6 MEMBER BANERJEE: And, of course, it also
7 is sensitive to the submergence of the vent line.

8 MR. WAGAGE: Because that bypass is going
9 by that, too, so that gives the pressure gradient for
10 the bypass.

11 MR. UPTON: Excuse me. This is Hugh Upton
12 with GEH. I just want to put something in perspective
13 about this leak rate. If you take a look at, say
14 containment testing, Appendix J testing, if you have
15 a .4 percent weight percent volume per day requirement
16 on your Appendix J leak rate out of the containment,
17 and that's your ELSA bay, you test at say .75 times
18 ELSA bay. That actually is going to come out to, at
19 a 45 PSIG leak rate, about 3 SCFM. Okay? Now we're
20 looking at an acceptance criteria of .5 square
21 centimeters. That actually comes out to be about 10.7
22 SCFM, so we believe that we have a test that's capable
23 of, within the current technology, of measuring that
24 one square centimeter leak rate.

25 CHAIRMAN CORRADINI: Okay. So you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actually have gone to where I was about to ask, which
2 is if you really are looking at this as two attached
3 containments, what's the equivalent of the leak rate
4 between the drywell to the wetwell. You've got about
5 a .15 bar delta P.

6 MR. UPTON: Right. The test that we're
7 looking at using is actually pressurizing the drywell
8 to just above the top horizontal vent, 2.2 PSIG. And
9 that gives us an allowable leak rate into the
10 suppression pool of about 10.7 SCFM. And, so, we know
11 that based on the Appendix J instrumentation we can
12 absolutely measure that.

13 CHAIRMAN CORRADINI: Thank you.

14 MR. WAGAGE: This table compares ESBWR
15 bypass leakage to other BWRs. I have these wetwell
16 free gas space, because it's important for bypass,
17 because if the wetwell air space is larger, it can
18 accommodate more bypass, more steam coming in before
19 it pressurizes.

20 As you see here, that GEH used one square
21 centimeter, assume one square centimeter bypass for
22 analysis, compared to much larger values assumed by
23 other BWRs.

24 The reason that GEH has to use smaller
25 bypass leakage is that this bypass continues for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 long duration. Other BWRs, bypass is short term
2 issue, but in this case, it's a long term issue,
3 continues for a long time, that's why have to use one
4 centimeter square.

5 There is another important issue in this
6 bypass. Because bypass is assumed in the safety
7 analysis, we did that -- SRP guidance is that bypass
8 has to be confirmed by surveillance testing. It's in
9 tech specs. So far, the staff has accepted the lowest
10 bypass surveillance testing value of around 3 square
11 centimeters. There is SRP guidance to say that what
12 the surveillance criteria has to be one-tenth or 10
13 percent of the value assumed for the analysis.

14 Operating BWRs have satisfied that
15 requirement, that guidance. ABWR you're going to see
16 that the value assumed for the analysis is same as the
17 value assumed in the surveillance criteria. The
18 reason is that ABWR has safety-related suppression
19 pool sprays. If there is a need, then operator can
20 activate safety-related suppression pool gas,
21 suppression pool sprays. If they use suppression pool
22 sprays, then this ABWR can accommodate 50 square
23 centimeters. That mean that what is measured is one-
24 tenth or 10 percent of what ABWR can accommodate.

25 The ESBWR is different. When we see in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the DCD that GEH was proposing to measure two square
2 centimeters as the surveillance criteria, which was
3 not acceptable to the staff, because the reason for
4 the surveillance test is to confirm what was assumed
5 in the analysis was correct. But there is no point of
6 measuring higher than that value, and there is nothing
7 to confirm. MR. WALLIS: How does that work?

8 You want to be sure you've got one, you measure two?

9 MR. WAGAGE: That's for the proposed
10 value. To be consistent with all the other operating
11 reactors, what the SRP guidance, is that surveillance
12 criteria has to be 0.1.

13 CHAIRMAN CORRADINI: What is the AB -- I
14 understand column one and column two for the current
15 operating ones. What is the ABWR, it's five and five?
16 And that's acceptable to the staff?

17 MR. WAGAGE: Staff accepted that five and
18 five, based on this reason, because ABWR has safety-
19 related sprays in the wetwell. I mean, the
20 pressurizer operators can activate safety-related
21 sprays in the wetwell, and pressure comes down.

22 By analysis, showed that if ABWR used 50
23 square centimeter bypass and sprays, then you maintain
24 under design pressure.

25 CHAIRMAN CORRADINI: And that's why you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accepted it as measuring -- testing for five, versus
2 having a design that gives you five.

3 MR. WAGAGE: Yes, that was the reason
4 staff accepted five and five, but for all the other
5 operating reactors we have accepted 10 percent.

6 MR. WALLIS: Are you proposing to accept
7 two for the ESBWR?

8 CHAIRMAN CORRADINI: No. That's just what
9 he said.

10 MR. WAGAGE: GEH was proposing to the
11 staff, the staff made clear that --

12 MR. WALLIS: You want .1, don't you?

13 MR. WAGAGE: We want .1, and --

14 CHAIRMAN CORRADINI: Don't agree with
15 Professor Wallis. He sucked you in there.

16 (Laughter.)

17 CHAIRMAN CORRADINI: Let's just stick with
18 the five and five for the moment, and understand that.

19 MEMBER BANERJEE: Under discussion.

20 CHAIRMAN CORRADINI: Under discussion.

21 MR. SNODDERLY: Yes. This is Mike
22 Snodderly. I think the feedback to GE was that the
23 two and the one would be unacceptable. But I think as
24 they've said, and this is the first that we've
25 formally heard that, but if one were to pose one and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 .5, first of all, the expectation is that at least
2 what you're testing to would be less than what is in
3 the design basis. But the .1 is guidance in the SRP
4 section. I think you can see that right now you're
5 starting to get down to the physical limits, and then
6 number two. But we would probably be willing to give
7 some latitude to .1, knowing that this is an extremely
8 low leakage containment.

9 MR. WALLIS: Aren't you concerned about a
10 design which requires such a very small leakage in
11 order to work? Doesn't that give you some concern?

12 MR. UPTON: This is GE. Can I respond?

13 MR. SNODDERLY: Yes.

14 MR. UPTON: This is Hugh Upton with GEH.
15 This design has -- we've always known that this was a
16 key type leakage rate, bypass leakage rate, and so in
17 SBWR and ESBWR we've done a significant amount of work
18 to try and minimize all of the leakage paths across
19 the diaphragm floor to maintain a leakage rate at
20 lower than one square centimeter. The entire vacuum
21 breaker test and development program, which was done
22 on SBWR, was extremely successful. And we can go into
23 the great detail of what testing was actually done on
24 the vacuum breaker.

25 But let me say this, that of the three

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 vacuum breakers, what we tested, and this is tested
2 after blowing -- after 3,000 cycles thermally,
3 radiation, seismically aging the valve, blowing four
4 pounds of sandblasting grit into the valve that had
5 been coated with oil to make sure that the bearing
6 surfaces would stick. We tested the valve leak rate,
7 and it was less than .02 square centimeters. Okay?
8 That is after 3,000 cycles, so we have confidence that
9 the vacuum breaker itself is an extremely reliable
10 component.

11 As-built, the vacuum breaker leakage rate
12 was bubble tight .00002 square centimeters. In
13 addition to that, what we've done is we've committed
14 to having an isolation valve in series with the vacuum
15 breaker that will be bubble tight. So if there is
16 indication of a failure of the vacuum breaker, or
17 leakage of the vacuum breaker, based on logic, the
18 isolation valve will shut that vacuum breaker.

19 The design as it stands today is N minus
20 2. We can fail two vacuum breakers, and still
21 operate, and still have sufficient relief capacity, so
22 we've done what we've tried -- by design, we've tried
23 to make sure that that bypass leakage is achievable.

24 MR. WALLIS: You say fail, you mean they
25 fail to open, they fail to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: No, failed by bypass
2 leakage and then isolate.

3 MR. UPTON: Yes. Right.

4 CHAIRMAN CORRADINI: So let me ask, or
5 just let me put it in perspective. I guess the one
6 thing, Graham, that I was trying to do as a
7 calculation is that at one square centimeter, that's
8 about .75 percent per day leakage as if this were a
9 containment boundary, which is, as I understood, is in
10 the ballpark of what you require, anyway, in terms of
11 continue leak rate, of .5 percent per day? Isn't that
12 what I remember seeing in the, not the DCD, but in the
13 SER in terms of the limit?

14 MR. WAGAGE: .5 is the design leakage --

15 CHAIRMAN CORRADINI: Okay. Go ahead.

16 MR. WAGAGE: To put in perspective, ESBWR
17 assumes one square centimeter leakage, that during the
18 surveillance testing the acceptance criteria has to be
19 fraction of that, that we have not seen that proposal
20 yet.

21 MR. WALLIS: Are these vacuum breakers
22 just pieces of chopped up metallic insulation?

23 MR. UPTON: Again, this is GEH. Let me
24 address that.

25 CHAIRMAN CORRADINI: We're going to have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that at the end. There's an expert, I am told, in the
2 audience. Let's get through this, and then we'll get
3 to the vacuum breaker.

4 MEMBER SIEBER: There's also a drawing of
5 it, it's 6.2, and it's on page 221.

6 CHAIRMAN CORRADINI: Yes.

7 MEMBER SIEBER: Looks pretty reliable to
8 me.

9 MR. WALLIS: Did you test it?

10 MR. WAGAGE: You have seen this figure
11 from actually a GEH chart, this is up to three days,
12 GEH showed longer time, that the first period up to
13 three days, you have seen the same one in these
14 presentations.

15 Okay. Let's go back. I want to make one
16 point on that figure, that you see that drywell
17 pressure is higher than the wetwell pressure. This is
18 pressure difference in the drywell and wetwell
19 pressure, it is driving the bypass. Okay. Let's go
20 back, go to the next one.

21 We have an open item on GDC 38. GDC 38
22 requires containment heat removal system, system
23 safety function shall be rapidly reduce containment
24 pressure and temperature after loss of coolant
25 accident, and maintain at acceptably low levels.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 During the initial phase, just after the
2 blow-down steam is condensed in the wetwell, the
3 pressure comes down, but after that, pressure starts
4 rising, and pressure continue to rise. That mean that
5 although it's dropped the pressure initially, it did
6 not maintain at acceptably low level. It was going to
7 pass, the pressure was going to pass the design
8 pressure later on, unless more systems are created
9 after 72 hours.

10 For first 72 hours, this is something that
11 the feature of the PCC, PCC cannot remove significant
12 -- rapidly like active systems. Because of the
13 advantage of having these completely passive system,
14 that GDC 38 not satisfying, were not dropping off
15 within 72 hours. But after 72 hours, other systems can
16 be used, and pressure can be dropped. But as you saw
17 today from GE's results, that it's encouraging that
18 PCC gas recirculation system and other systems GE is
19 going to use, that GDC 38 will be addressed.

20 CHAIRMAN CORRADINI: So I think I
21 understand your explanation, but I'm still curious, so
22 you want them to put in the -- because I read the back
23 and forth between the licensee and the staff, to put
24 in an isolation valve to the PCCS.

25 MS. CUBBAGE: You know what, I think we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 got a little confused here, because Handry was
2 speaking to a different issue than what's behind him
3 there.

4 CHAIRMAN CORRADINI: Oh.

5 MS. CUBBAGE: I don't think we're on to
6 this issue yet. Right, Handry?

7 MR. WAGAGE: Oh, okay.

8 MEMBER BANERJEE: He's still talking about
9 GDC 38.

10 MS. CUBBAGE: Drywell gas recirculation,
11 yes.

12 MR. WAGAGE: Oh, that's coming next.

13 MS. CUBBAGE: All right. You want to move
14 on to this issue now, Handry, please?

15 CHAIRMAN CORRADINI: Yes, that would be
16 good. Let's move on to this issue.

17 MR. WAGAGE: Okay. Next one, we have an
18 open item on PCCS isolation. PCCS system is an
19 advanced system. It starts operating immediately
20 after LOCA. There are no valves to open, and there is
21 no need for electric power, no need for operator
22 action. It start right away. But the downside is
23 that PCCS is a penetration in the containment, as you
24 see here. There is one pipe penetrating to take --

25 CHAIRMAN CORRADINI: Now, if I could just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stop you. It's penetrating the containment, or it is
2 the containment?

3 MS. CUBBAGE: That's the issue.

4 CHAIRMAN CORRADINI: I guess I'm still
5 trying to understand that, because I read the back and
6 forth from the staff and the licensee, and somehow I
7 tend to fall with the left.

8 MEMBER MAYNARD: Several plants have a
9 similar deal where basically, a penetration, you have
10 a pipe that penetrates the containment, but that pipe
11 becomes the containment.

12 MEMBER BLEY: It would be nice to see a
13 detail of that connection. That's what you'd like,
14 Mike.

15 MR. WAGAGE: I'm coming to that.

16 CHAIRMAN CORRADINI: Okay. Sorry.

17 MR. WAGAGE: Right now --

18 CHAIRMAN CORRADINI: The way you gave the
19 preliminary discussion got me a little bit nervous.

20 MR. WAGAGE: Maybe have some patience.

21 CHAIRMAN CORRADINI: That's okay. Go
22 ahead. I'm sorry.

23 MR. WAGAGE: As you see, there are three
24 penetration in the physical containment boundary. We
25 ask the -- according to our GDC 56, that there are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 penetration, and penetration has to have isolation
2 valves. We asked GEH in an RAI.

3 MR. WALLIS: So you have to isolate the
4 inlet and the outlets.

5 PARTICIPANT: Which defeats the purpose,
6 doesn't it?

7 MR. WAGAGE: According to our GDC 56,
8 penetrations have to have inside and outside isolation
9 valves, that mean there are three penetrations, there
10 has to be six isolation valves. That is GDC 56. Then
11 GEH came up with an argument, although this is the
12 penetration in the physical boundary, that it is
13 closed system. And PCCS is designed to significantly
14 higher design pressure than the containment, and GE
15 came up with an idea that all this -- extend the
16 containment boundary, and include that as part of the
17 containment boundary.

18 MEMBER BANERJEE: It makes sense, because
19 if you close those isolation valves, you'd lose your
20 heat sink.

21 MR. WALLIS: If it's got a hole in it,
22 too.

23 MR. MARQUINO: This is Wayne Marquino of
24 GEH. I'd like to admit that in our initial submittal,
25 it was unclear whether this heat exchanger was part of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the containment, with some places we said it was
2 extension of the containment. Our intent always was
3 to apply the same structural codes that apply to the
4 primary containment to evaluations of the PCC heat
5 exchanger.

6 As one of the members pointed out, we have
7 containments like the MARK II, that have a pretty
8 complex structure, and the ducts that come off between
9 the drywell and wetwell, we feel this is analogous to
10 that.

11 There is an existing RAI on this, so that
12 was our latest response to the staff. And we've had
13 discussions with them since then, where they've asked
14 us to provide a risk-based evaluation of putting
15 isolation valves versus not -- isolation valves versus
16 no isolation valves. Our PRA group is in the process
17 of responding to that.

18 CHAIRMAN CORRADINI: So let me ask you
19 then, since you are taking this route to discuss it,
20 are these automatic isolation, or manual isolation?
21 What are these valves? If they --

22 MR. MARQUINO: Since we don't have valves

23 --

24 CHAIRMAN CORRADINI: All right. And I
25 apologize, I turned to you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: GEH --

2 CHAIRMAN CORRADINI: Are these automatic
3 isolation valves that concern you, or manual isolation
4 valves?

5 MR. WAGAGE: There are no isolation valves
6 at all right now in the design.

7 CHAIRMAN CORRADINI: Yes, I know that, but
8 in my mind, I mean I'll just say what I'm thinking,
9 and then you can get mad at me later. This is crazy.
10 Right? You don't want to put a valve right where you
11 have your only method of heat loss, heat sink, so
12 what's the staff thinking here?

13 MR. WAGAGE: The purpose of isolation
14 valve is --

15 CHAIRMAN CORRADINI: Sorry to say it so
16 bluntly, but --

17 MR. WAGAGE: The purpose of isolation
18 valve is to be able to isolate if there was failure in
19 the system, if there is a failure of the valves or
20 drop off, there will be -- if there's a failure in the
21 system, then --

22 VICE CHAIRMAN ABDEL-KHALIK: What kind of
23 signal would allow you to detect that and actuate
24 those valves?

25 MR. WAGAGE: The idea is that there are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 valves, if there is a need, then the system can be
2 isolated. But as GE --

3 VICE CHAIRMAN ABDEL-KHALIK: I'm sorry.
4 I don't think you answered my question. Let's say the
5 applicant complies, how would an operator detect the
6 need to actuate those valves?

7 MR. WAGAGE: Operator --

8 VICE CHAIRMAN ABDEL-KHALIK: Obviously,
9 those valves would be normally open to maintain this
10 heat sink function.

11 MR. WAGAGE: Yes.

12 VICE CHAIRMAN ABDEL-KHALIK: So how would
13 one go about detecting, ascertaining the need to close
14 those valves?

15 MR. WAGAGE: There has to be other
16 measurements, there is the need that --

17 VICE CHAIRMAN ABDEL-KHALIK: Sensors in
18 the pools?

19 MEMBER MAYNARD: Well, typically, you
20 probably have radiation monitors or other things in
21 the area. You'd have other indications that would say
22 you had some type of containment leakage during an
23 accident. I think what they're really trying to deal
24 with here is how do they show compliance, or how do
25 they justify compliance with a general design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 criteria, and does it need to -- and I do think that
2 there's other precedents already set out there for
3 addressing these types of issues. And I think we need
4 to be careful that we don't force somebody to do
5 something that is less safe, just to be --

6 MR. SNODDERLY: That's exactly the gray
7 issue that we're trying to deal with. If you look at
8 the ANS standard 45.2, it clearly says that -- the way
9 it defines a closed system outside containment, one
10 could interpret that this meets that definition, i.e.,
11 penetrations that are welded to containment, and
12 return fluid back to containment. So it meets the
13 definition of the standard that says you shall have at
14 least one isolation valve.

15 Now the normal configuration that people
16 are used to seeing is the pool is inside containment,
17 so you have at least one isolation valve outside
18 containment. This one is flipped around. Okay? So
19 one could interpret the standard that you should have
20 at least one isolation valve inside containment, but
21 it would be to the applicant to determine how it
22 should be shut.

23 If you're asking the question, then it
24 would be, I would assume, remote manual, but that
25 would be for them to decide. But, again, we have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 standard that clearly says a system, a closed system
2 outside containment that penetrates should have an --
3 if it returns fluid back to containment, should have
4 an isolation valve.

5 MR. WALLIS: Should have?

6 MR. SNODDERLY: Should have, should. But
7 we also are acknowledging -- so, for example,
8 isolation condensers have had -- do have these
9 isolation valves, and this design proposed I believe
10 also has isolation valves. Okay. But, as was said
11 before, you have high pressure fluids, here you don't,
12 so, again, it's a gray area, but we have a question.
13 We'd like to understand. Another thing that could
14 justify it would be looking at what's the likelihood
15 that you would have a failure of containment, and the
16 one I was postulating was in that pool region, say
17 someone were to drop a heavy load on the exchanger and
18 damage a tube, but then you could have certain
19 precautions that would prevent such a heavy load
20 during operation. But things like this that can
21 reduce that likelihood, to say -- so those are the
22 types of arguments that we're trying to develop and
23 justify.

24 CHAIRMAN CORRADINI: So let me try one on
25 you. So why, if this is containment, not a system

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 welded to containment, but containment, why can't it
2 be part of the normal integrated leak rate test, and
3 use that as the service inspection method to determine
4 if they're above their integrated leak rate on a
5 continuing or surveillance basis. They can then find
6 out where it is. But if it is containment, isn't that
7 the surveillance, or the periodic test that one would
8 use?

9 MR. SNODDERLY: Right. So, periodically,
10 they -- they don't have the diagram up there now, but
11 the one that they did have up for the PCCS, you can
12 see there's some temporary connections for doing
13 pressurizing the PCCS to verify.

14 Of course, the problem there is, if you do
15 your test, and you don't know how thick the -- and
16 let's say there was corrosion going on, you do a test.
17 It appears that it's pressurized, but you only have a
18 small amount of material left, so that's one. But,
19 again, the fact that you were doing that test every
20 couple of years, yes, would give you some assurance.

21 CHAIRMAN CORRADINI: That's an economic
22 issue. If they want to take the chance that they have
23 to shut down the machine and fix containment, I mean,
24 if it was a large dry, and I didn't make the leak
25 rate, I don't go back up to power until I find the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 leak, and fix the leak, and that's it.

2 MR. SNODDERLY: Right, but it would be a
3 303 concern.

4 MS. CUBBAGE: I guess on this one, I'd
5 like to just close by saying we've asked them to
6 justify their current design. We haven't told them
7 one way or the other that it's required.

8 CHAIRMAN CORRADINI: Okay. Thank you.

9 MR. SNODDERLY: It's an open item. We've
10 made you aware of it, and it's something that we have
11 to resolve.

12 CHAIRMAN CORRADINI: That's helpful.
13 Thank you so much.

14 MR. WALLIS: Well, is it up to you to
15 decide, or is it possible this --

16 MR. SNODDERLY: Well, as Otto said, we
17 have a GDC, and we have an ANS standard, so we're
18 going to have to reconcile that.

19 MR. WALLIS: I think the man on the street
20 might say it's not containment. It doesn't look like
21 containment. It's piping and stuff.

22 MR. SNODDERLY: Yes. And that's --

23 MR. WALLIS: It doesn't look like
24 containment at all.

25 CHAIRMAN CORRADINI: We're beyond this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one. Move on.

2 MR. WAGAGE: We have an open item on very
3 fine containment of concentration. ESBWR containment
4 is inerted by regulation, inerted mean that oxygen
5 concentration in the containment has to be less than
6 4 percent. 10 CFR 50-55(c)(2) for advance reactors,
7 state that these containers do not require inerted
8 containments to provide methods to control combustible
9 gas, because containment is inerted, there is no
10 possible combustion.

11 Containment has flammability control
12 system that is PARS, part of catalytic converters.
13 There are monitors for hydrogen and oxygen in the
14 containment. However, that oxygen monitoring, the
15 confirmation is not in the tech spec, it's in
16 availability controls manual. Once it's not in tech
17 spec, there is less regulatory control because the
18 assumption is that containment is inerted, it's less
19 than 4 percent oxygen in the containment, but there is
20 no verification unless it's in the tech spec. We have
21 an open item asking GEH to have verification of oxygen
22 concentration in the containment.

23 MR. WALLIS: This radiolytic generation
24 after an accident, surely radiolytic generation is
25 going on all the time while the reactor is operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at a higher rate, isn't it, or apparently the same
2 rate, or something. It's not -- and that is on the
3 control. There's not that much, is there? It seems
4 to be such a small amount compared with the volume of
5 the containment.

6 MR. WAGAGE: I think during that time that
7 for clean up system removes that --

8 MR. WALLIS: But it's not that much, is
9 it?

10 MR. WAGAGE: I don't know the number, how
11 much.

12 MR. WALLIS: If it's enough to cause a
13 fire in containment, then I don't see how they could
14 handle it during normal operation. It would be much
15 too much, wouldn't it?

16 MR. UPTON: This is Hugh Upton of GEH. We
17 have a separate system called the off-gas system that
18 deals with during normal operation --

19 MR. WALLIS: There's not that much gas, is
20 there? There's no huge flow which would really -- if
21 went into the containment, would enable a fire to
22 occur there.

23 MR. UPTON: I would have to take a look at
24 the design specification. I don't remember how much
25 gas actually is generated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MARQUINO: Well, the flow is mainly
2 condenser leakage, air that's leaking in from the
3 condenser is processed by the off-gas system, and
4 there is some hydrogen and oxygen generated by
5 radiolytic gas. I don't know that we can -- that
6 we've measured --

7 MR. WALLIS: But there have been
8 explosions in BWRs gathering this gas and not venting.
9 But it takes months to gather enough gas in a pipe
10 which isn't very big in order to make an explosion, so
11 there can't be very much of it being made. Why is
12 there suddenly a great concern with an accident that
13 you're going to make a lot more of it? It doesn't
14 make any sense, just by radiolysis.

15 MEMBER BANERJEE: TMI got it in a
16 different way. Metal water --

17 PARTICIPANT: That's different.

18 PARTICIPANT: It's a bigger generator.

19 (Off the record comments.)

20 MR. WAGAGE: During an accident, this adds
21 into other pressurization from bypass and not removing
22 heat from the containment. This adds on, it keeps on
23 going, that may be reason.

24 MR. WILLIAMS: Okay. We still have one
25 more presentation to go.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: During an outage, you open
2 up that containment, get a lot of air in there, and
3 then when you button it up and go back, you've got to
4 do something to verify you've got an inerted
5 containment.

6 MS. CUBBAGE: Yes, they do. The question
7 is whether it's in tech specs or not. It's just a
8 matter of a tech spec. This is not a big technical
9 issue.

10 MEMBER ARMIJO: Okay.

11 MR. WILLIAMS: I just wanted to make sure
12 we didn't mislead Dr. Bley in his question about
13 cleanliness. Right now, what the DCD says is that the
14 GDCS pool will have a stainless steel liner, will have
15 a screen, and will have a temporary strainer to
16 prevent debris getting into the system, but it would
17 be removed prior to start-up, and there would be no
18 strainer. But they have not committed to Reg Guide
19 182, Rev 3 for the GDCS pool. We have a question
20 concerning the -- meaning Reg Guide 182, Rev 3 for the
21 suppression pool, and meeting the bullets in 95-02,
22 but it's not clear that that -- how that applies to
23 the GDCS pool, because it is unique. So I just wanted
24 to make sure that that was clear, and perhaps GE can
25 respond to you about their plans concerning

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cleanliness for the GDCS pool. But right now in this
2 revision, there is no commitment for that in the GDCS,
3 except what I just laid out.

4 MR. WILLIAMS: Now Weidong Wang is going
5 to go over Chapter 6.3.

6 MEMBER BLEY: Let me raise a question,
7 Mike. Given what you just told me, how do you folks
8 convince yourself whether or not there might be a
9 problem with debris?

10 MR. SNODDERLY: Well, I think as Handry
11 said, there are some very key differences between this
12 design and the problem we're trying to solve, and have
13 solved for operating BWRs. Debris falls down or
14 transfers into the suppression pool. Here you have an
15 elevated release and a screen that prevents debris
16 from going in. And, also, there's -- we don't
17 anticipate as much maintenance or communication into
18 the GDCS pool where those sources would come from.
19 And it does have a stainless steel liner, so it's just
20 a different system.

21 Now, I do believe that in pursuing this
22 issue with the suppression pool, we will also want to
23 know about cleanliness programs. I just wanted to say
24 that we -- I think we gave you an impression that
25 there will be one. Right now in the DCD there is not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a formal commitment for the GDCS pool, but there are
2 some unique differences. But I do believe that it's -
3 - it's mainly gravitational settling. Right. The
4 high elevated release, there is a screen to prevent
5 the debris. And I think we also said that the
6 diameter was one inch. The diameter is an inch and a
7 half, and I think we're also -- so although a formal
8 calculation in accordance with Reg Guide 182, Rev 3,
9 it's not being performed to determine the amount of
10 debris, it's transport and how it would get into -- I
11 think there is a concern about downstream effects, and
12 I believe that Jim Gilmore in Chapter 4 has asked an
13 RAI concerning the filters for the fuel, and whether
14 that debris would be a problem or not, so we're going
15 to be pursuing that coordinating with Reactor Systems.

16 MR. WILLIAMS: You're up, Weidong.

17 MR. WANG: My name is Weidong Wang. I'm
18 going to present Chapter 6.3. This section is also
19 contributed by a team, George Thomas and Veronica
20 Wilson, and also from Offices of Research. I'm kind
21 of tired.

22 (Laughter.)

23 CHAIRMAN CORRADINI: That's okay. We have
24 a lot of time tonight. Don't worry.

25 MR. WANG: Basically, we will go over a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 little bit about the regulations, and also talk about
2 SER topic of interest. And, again, significant open
3 items, and answer questions.

4 So I'm not going to go into detail of
5 these federal regulations, and also our review
6 guidelines. This is a list for the LOCA.

7 Now for the ECCS system, this is a summary
8 of what components for the ECCS system, basically,
9 automatic depressurization system, which include SRVs
10 and the DPVs, and safety relief valve, isolation
11 condenser system, and also standby liquid control
12 systems all went discussion in the past ACRS meetings.
13 And gravity-driven cooling system is also part of the
14 ECCS. And for DPV, which Jerry already went over,
15 went through, and staff currently is reviewing a test
16 report for this DPV.

17 Number four, GDCS check valve, that was
18 changed from biased open to normal open. And the
19 check above design is an open item. Basically, staff
20 is concerned about what about more function, say
21 opposed to the not open, but it's open during the
22 LOCA, and that that might backflow through the check
23 valve.

24 And also for GDCS open items, ITAAC-
25 related, we would like to check the as-built nozzle

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 throat lengths to be verified against TRACG input,
2 because the --

3 MR. WALLIS: This is for critical flow, or
4 what is this?

5 MR. WANG: Yes, check for the critical
6 flow. And also for loss of -- flow loss coefficient
7 needed to be verified by test against the TRACG input.
8 Basically, we would like to make sure what as-built
9 the same as what the TRACG input.

10 Staff verified all RPV penetrations, and
11 accepted GE's eight break flow locations. In the DCDG
12 submitted four break locations for main steam line
13 break, gravity-driven line, cooling system line break,
14 bottom drain line and the feedwater. And they have an
15 extra, another four breaks, which is isolation --

16 MR. WALLIS: Is the bottom drain line the
17 only line that's below the core level?

18 MR. WANG: Yes.

19 MR. WALLIS: It's the only one, is it not?

20 MR. WANG: Yes. And one open item is
21 staff is asking GE to perform standby liquid coolant
22 steam line break, and GE has revised Rev 3 under Rev
23 4. I don't see where this break was analyzed, so this
24 is one open item. And for the single failure
25 selection, basically federal regulation applies, ECCS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 functions accomplished with a single failure. And the
2 staff found that GE basically considered all the
3 systems connected to RPV, and the staff verified GDCS
4 valve and ADS SLC and isolation condenser, they can
5 break, bottom drain line break, and the control rod
6 hydraulic control unit. And the final --

7 MR. WALLIS: But not a break of the PCCS
8 itself?

9 MR. WANG: Not break of the PCCS, they are
10 not --

11 CHAIRMAN CORRADINI: You're seeing PCCS or
12 isolation condenser?

13 MR. WALLIS: No, a LOCA followed by a PCCS
14 tube break.

15 MR. WANG: PCCS is a low pressure system,
16 and it's very --

17 (Off the record comments.)

18 MR. WALLIS: This is a conceivable
19 failure.

20 CHAIRMAN CORRADINI: It's in the PRA.

21 MS. WILSON: Hi, Dr. Wallis. This is
22 Veronica Wilson. The regulations only require a
23 single active failure, so we weren't allowed to break
24 that, but it would be an interesting simulation.

25 CHAIRMAN CORRADINI: That was a cast off.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Nicely done.

2 MR. WANG: Yes. Thank you.

3 CHAIRMAN CORRADINI: Nicely done.

4 MR. WANG: And the final selection of the
5 single failure is GDCS squib valve. Now one SRV or
6 one DPV single failure was selected. Other systems
7 are GE designed basically failure proof.

8 MR. WALLIS: So another failure is when
9 the isolation valve is closed by mistake. But now
10 you've put it in, you run the risk of having an
11 accident when it's closed. Someone left it closed for
12 maintenance or something.

13 MR. WANG: And there is, I believe, a
14 bypass valve, so once --

15 MR. WALLIS: There's another valve, yet
16 another valve.

17 MEMBER BANERJEE: That could be closed,
18 too.

19 MR. WANG: But we only consider one single
20 failure.

21 MR. WALLIS: When in doubt, put in another
22 valve.

23 MR. WANG: And the open items are
24 basically when vacuum breaker fails to close, and by
25 design from DCD, there's an isolation valve will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 used. And the staff is asking for the design of this
2 isolation valve, and also how this isolation valve --

3 MR. WALLIS: Now this vacuum breaker valve
4 opens and closes several times sometimes, so you're
5 going to have somebody open and close the isolation
6 valve, as well?

7 MR. WANG: That's what we have as a
8 question for GE to answer the design --

9 MR. WALLIS: I understand the vacuum
10 breaker opens on demand, and closes on demand.
11 Isolation valve you tend to just close it, and then
12 leave it. The operator isn't going to be able to know
13 when he should be opening and closing.

14 MEMBER BLEY: I think they said they can
15 live with two of them isolated.

16 MR. WALLIS: So that's what they do, they
17 just isolate it and leave it.

18 MEMBER BLEY: One would think so.

19 MR. WALLIS: I think that's what you have
20 to do, yes.

21 MR. UPTON: Yes, we're looking at that.
22 This is Hugh Upton with GEH. We can tolerate for a
23 period of time an absolute failed open vacuum breaker,
24 and when there's indication that you actually are --
25 you have a failed open vacuum breaker both from seat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 indication and the pressure response of the
2 containment, then we would isolate it. But it is N
3 minus 2, and we can live with one isolated.

4 MR. WALLIS: Do you know which one is
5 failed?

6 MR. UPTON: The valve itself is designed
7 with indication on the disk, we've got proximity
8 probes on the seats, so we know when the valve is
9 stuck open or off its seat. Okay? And then you'd
10 also have some indication on containment pressure
11 response. Those are equalizing --

12 MR. WALLIS: I think my question was what
13 will tell you which one is failed.

14 MR. UPTON: But containment pressure
15 response in addition with a disk off the valve seat
16 would give you indication that you've got a failed
17 vacuum breaker, because you've got -- yes, it would
18 tell you which one it was, so you've got four probes
19 on each one of the vacuum breakers.

20 CHAIRMAN CORRADINI: Let me just ask one
21 other thing, because these are -- well, we're going to
22 have -- well, maybe not ask now, because we're going
23 to have somebody talking about this in detail at the
24 end. Is that correct? Right? There is somebody,
25 because I wanted to ask a little bit more about your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 surveillance mechanism.

2 MR. WANG: Okay. Another item, I think I
3 just went through previous GDCS check valve failure.
4 Basically, we would like to see if that fails, and
5 what's the design of this check valve. And if fails,
6 what's the consequence.

7 CHAIRMAN CORRADINI: But there's an
8 upstream squib that has to open for discharge.

9 MR. WANG: Right.

10 CHAIRMAN CORRADINI: So your worry is
11 what?

12 MR. WANG: After the squib valve open, the
13 check valve didn't function as it is, what about it's
14 open also, and then flow will go back through the --
15 RPVs are pressurized.

16 MEMBER BANERJEE: Doesn't act as a check
17 valve.

18 MR. WALLIS: It gets stuck.

19 CHAIRMAN CORRADINI: Leakage once the
20 squib opens. Okay. Thank you.

21 VICE CHAIRMAN ABDEL-KHALIK: Have you
22 looked at possible failure loss of nitrogen in
23 combination --- as the single failure in combination
24 with a LOCA?

25 MR. WANG: Loss of nitrogen --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN ABDEL-KHALIK: So that the
2 water in the isolation condenser system would actually
3 end up inside the vessel, and the total inventory that
4 would be released into the containment would increase,
5 so that your total containment pressure would be
6 higher than the calculated value.

7 MR. WANG: So then what's --

8 MS. CUBBAGE: I think it's assumed that
9 the liquid in the isolation condenser does go into the
10 vessel.

11 VICE CHAIRMAN ABDEL-KHALIK: It does?

12 MS. CUBBAGE: Yes. That's part of the
13 inventory that's assumed in the calculation.

14 MR. WANG: TRACG was used for this LOCA
15 analysis by GEH, and this slide basically talk about
16 a few selected input parameters. For the bounding
17 calculation, the power is like 2 percent higher, plus
18 2 percent for this designed power, which is considered
19 consistent with SRP. And we look at the maximum
20 linear heat generation rate, and also we look at the
21 actual power shapes, which is not important for this
22 LOCA, since from the calculation we didn't really see
23 core uncover, so power won't -- cladding was not where
24 the heat up, so we would just use the one power shape.

25 MEMBER BANERJEE: You mean that there was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 no dry out anywhere in the core.

2 MR. WANG: No dry out is what the
3 calculation show.

4 VICE CHAIRMAN ABDEL-KHALIK: I would like
5 to just verify what Amy said. Does GE agree with what
6 Amy said, that in the event of a LOCA, that all the
7 inventory in the isolation condenser system will end
8 up inside the vessel, and eventually gets into
9 containment?

10 MR. MARQUINO: Yes, we agree.

11 VICE CHAIRMAN ABDEL-KHALIK: Thank you.

12 MR. WANG: And for the initial stored
13 energy, we have an open item, which we asked GE to
14 justify the use of the simple conductivity model they
15 used.

16 MEMBER ARMIJO: Is there any difference
17 between this model and previously used thermal
18 conductivity model?

19 MR. WANG: Previous model I believe they
20 used from the PRIMUS-II code, and that code was
21 approved by NRC. And later, GEH, they used a later
22 version of the TRACG, and they used the conductivity
23 models from Time Code 4, which was not approved by
24 NRC, so we asked --

25 MEMBER BANERJEE: Do you have a comment,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Veronica?

2 MR. JUNGEE: Yes, this is Nahim Jungee
3 from GEH --

4 MS. WILSON: This is Veronica Wilson.
5 It's correct in principle, but it was the JESTER M
6 code that's always been used with previous LOCA
7 analyses, and GE is using the PRIME III for the
8 thermal conductivity, so the staff just asked them to
9 justify that.

10 In addition, there was some mismatch of
11 the models, because they used the gap contents from
12 JESTER M, and that's a very coupled process, so the
13 staff was interested in finding out how GE justifies
14 the use of two different codes to calculate thermal
15 conductivity and then gap contents.

16 MR. JUNGEE: Let me respond to that. This
17 is Nahim Jungee again from GEH, and talking about the
18 thermal conductive model in PRIME and JESTER M, the
19 difference is we have modified the thermal
20 conductivity model to account for the expositive
21 index, which is reflected in the PRIME model. JESTER
22 model didn't have that expositive index in the thermal
23 conductivity model. That has been addressed in the
24 Part 21 evaluation, what are the consequences of not
25 having the expositive dependency. I think staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mentioned that. Going back to the gap contents issue,
2 we look at the impact of gap contents if you change
3 the thermal conductivity model, I think the impact is
4 very negligible, so that code, if you use that gap
5 contents from either code, should be -- the impact
6 should be similar, no impact, basically.

7 MEMBER ARMIJO: So, basically, the thermal
8 conductivity model has been --

9 MR. JUNGEE: Updated.

10 MEMBER ARMIJO: -- approved for burn-up
11 effects.

12 MR. JUNGEE: Yes.

13 MEMBER ARMIJO: That has not been reviewed
14 by the staff. Is that correct?

15 MS. WILSON: Currently under review.

16 MEMBER ARMIJO: Pardon?

17 MS. WILSON: You're correct, but it is
18 currently under review.

19 MR. WANG: The PRIME code has been
20 submitted to staff review.

21 MEMBER ARMIJO: Okay. Thank you.

22 MR. WANG: Okay. For the control rod
23 insertion, basically, it is factored into the decay
24 heat curve. This was selected into the assumptions.
25 Summary of this ECCS LOCA analysis, basically, you all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 see this, all calculations show that the core remains
2 covered with water. And from GE's submission, we saw
3 that the minimum water above the top of active fuel is
4 1.447 meter.

5 MR. WALLIS: Can somebody tell me in this
6 -- some of these LOCAs, there's a mention of the
7 spill-over hole. I don't know what a spill-over hole
8 is.

9 MR. WANG: Okay. I believe this is --

10 MR. WALLIS: Oh, I thought it was
11 something to do with the vessel.

12 PARTICIPANT: He needs the microphone,
13 Shawn.

14 MEMBER BANERJEE: Repeat what you said
15 with the mic.

16 MR. WALLIS: Well, he pointed to it, so
17 that did it. You can't do that with a mic.

18 MR. WANG: I'll use this. This one is the
19 spill-over hole. Basically, when you have a lower
20 kind of break, and the water eventually will fill,
21 reach that level, and --

22 MR. WALLIS: Oh, that explains it. Thank
23 you very much.

24 MEMBER BANERJEE: Now this seems very high
25 precision on the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(Laughter.)

1
2 CHAIRMAN CORRADINI: Let's just keep on
3 going. He's just trying to tease you. VICE CHAIRMAN
4 ABDEL-KHALIK: Based on the results that were
5 presented by GE, it looks like the smallest vertical
6 channel in their model was a 4 by 4 bundle, and there
7 were two of them. But does that give you enough
8 resolution to look at what happens in the hot channel,
9 in the hot bundle, excuse me?

10 MR. WANG: So you are talking about the
11 nodalization for the --

12 VICE CHAIRMAN ABDEL-KHALIK: Radial --

13 MR. WANG: Radial numbers?

14 VICE CHAIRMAN ABDEL-KHALIK: Yes.

15 MR. WANG: I believe, Veronica can correct
16 me, we have done some sensitivity studies, and we
17 noticed that basically from the sensitivity study with
18 different ring, or different nodalization, we found
19 it's acceptable.

20 MS. WILSON: I'm sorry. I wasn't entirely
21 sure. What was the question again?

22 VICE CHAIRMAN ABDEL-KHALIK: The question
23 pertains to the adequacy of the radial nodalization,
24 and whether the fact that the smallest radial channel
25 was a 4 by 4, essentially super channel. And the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 question is whether that gives you enough information
2 on the performance of the hot bundle.

3 MS. WILSON: Yes, Weidong is correct.
4 During the pre-application phase, they study this in
5 great detail, and I don't know if there's anybody in
6 the audience from that part of the review, but they
7 did look at the different nodalization schemes, and it
8 was actually -- they originally did not have the 4 by
9 4 smaller bundle, but after a few nodalization
10 studies, the staff actually found that to be the most
11 conservative way of measuring the minimum level.
12 Because they found if you just assume a bunch of hot
13 channels underneath like these larger rings that they
14 had put in, that you end up getting this kind of
15 drafting effect, and then it turns out to be actually
16 less conservative, so that's why they had to switch to
17 the smaller bundles.

18 VICE CHAIRMAN ABDEL-KHALIK: Is that
19 information documented somewhere?

20 MS. WILSON: Yes, it is. It's in NEDERC
21 33083P-A, and it's in the appendix to that document.

22 MS. CUBBAGE: I believe that was provided
23 to you all.

24 MS. WILSON: Yes. It was actually listed
25 in the RAI section, because the staff asked that RAI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 during that review, so there's a detailed RAI response
2 from GE discussion, and a kind of a back and forth
3 from the staff on what was done to find the minimum,
4 most conservative minimum --

5 VICE CHAIRMAN ABDEL-KHALIK: Thank you.

6 MR. WANG: Thank you for the confirmation,
7 Veronica. You see why I bring her here.

8 CHAIRMAN CORRADINI: You brought her, or
9 she agreed to come?

10 (Laughter.)

11 MR. DONOGHUE: I should have never let her
12 leave the branch, basically.

13 PARTICIPANT: Why did you?

14 (Laughter.)

15 MR. WANG: Okay. So let's come back to
16 this summary of this LOCA analysis results. GEH has
17 concluded most limiting breaks are main steam line
18 break, and the gravity-driven line break, and we have
19 an open item. From GE's II response, which they had
20 additional four LOCA analyses, and we found isolation
21 condenser return line break looks like the number is
22 smaller, and we are just asking them to clarify.

23 This is a summary of what GEH had obtained
24 the results. The left column basically is all breaks,
25 and EQL means equalization line break. I'm not going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to read the rest of them.

2 MS. CUBBAGE: And those are all above
3 vessel zero.

4 MR. WANG: And, also, in the middle is
5 like single failures, one DPV or one GDCS injection
6 line, or one SRV. And that open item we just
7 basically asked from this reading, we saw the
8 isolation condenser return line break looks like --

9 MR. WALLIS: When you give these areas,
10 are these double-ended for some of these breaks on
11 single and otherwise, depending on how they're
12 connected? There's the total area of the break, or
13 does it? It says break size. Is this the total area?

14 MR. WANG: It should be break area.

15 MR. WALLIS: Aren't some of them double,
16 and some single, depending on how they're connected to
17 things?

18 MR. WANG: I don't know if it's --

19 MR. MARQUINO: Dr. Cheung indicated it's
20 single area. We don't have things like a recirc loop,
21 where we break a pipe and we get flow from both
22 directions.

23 MR. WALLIS: But they're all single area.

24 MR. MARQUINO: Yes.

25 MR. WALLIS: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 PARTICIPANT: So I guess I don't
2 understand the logic of what concerns you about the
3 ICR. Can you explain again? I'm sorry.

4 MR. WANG: Okay. Basically, if you look
5 at this number, the GEH, that ICR with one GDSCS break
6 is nine point zero zero --

7 MR. WALLIS: Lowest.

8 MR. WANG: And this one --

9 MEMBER SIEBER: And top of active fuel is
10 how many meters?

11 MR. WANG: Top of active fuel --

12 MR. WALLIS: Around seven and a half.

13 MR. WANG: Seven and a half. And we
14 basically look at the table and compare with the other
15 break, and it was failures; we think that this one
16 should be considered as the most limiting. However,
17 if you look at a DPV, which DPV tube line break we
18 consider as a similar break as main steam line break,
19 so that one we were to put -- consider here, but
20 that's from this table.

21 CHAIRMAN CORRADINI: Thank you.

22 MR. WANG: Okay. The next one, please.
23 And the other significant open items, okay, this one
24 is, basically, it's a regulatory issue. GE has
25 demonstrated the core is keep covered during the whole

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- not covered -- always covered with water during the
2 break. And federal regulation requires either do
3 uncertainty analysis, or do a -- use Appendix K ECCS
4 variation model, and GE actually didn't really address
5 this tube.

6 MR. WALLIS: How can you use Appendix K
7 with this design?

8 MR. WANG: This, basically, is the federal
9 regulations. We would like them either to address by
10 uncertainty, or with the other method, but we don't
11 decide that here.

12 CHAIRMAN CORRADINI: So they have to
13 choose.

14 MR. WANG: They have to choose.

15 CHAIRMAN CORRADINI: And they haven't
16 chosen yet. Okay. Thank you.

17 MR. WANG: Or either they want to say
18 apply a waiver, and they have good justification.
19 Basically, saying that they --

20 MR. WALLIS: Well, they can't choose,
21 because you can't use Appendix K with this design, can
22 you? It doesn't make sense.

23 MEMBER BANERJEE: You can, but --

24 MR. WALLIS: You can?

25 CHAIRMAN CORRADINI: It's not very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicable, but you can try.

2 MEMBER BANERJEE: It's not very good.

3 MR. WANG: For the long-term cooling
4 calculation, GEH showed the core covered with water up
5 to 12 hours, and the staff is asking GEH to show the
6 results up to 72 hours.

7 CHAIRMAN CORRADINI: So it's that there's
8 no concern in the time available, they just haven't
9 run the calculation out? Is that your point?

10 MR. WANG: Not just the calculation.
11 Basically, they have yet to run the calculation, and
12 justify the results. For example, we have some
13 concern about from this II issued to GE, where we say
14 we don't -- staff do have concern about the non-
15 condensable.

16 CHAIRMAN CORRADINI: Non-condensable
17 where?

18 MR. WANG: Basically, hiding or as
19 transportation --

20 MEMBER BANERJEE: In the PCCS.

21 MR. WANG: For the PCCS.

22 CHAIRMAN CORRADINI: Oh, okay. All right.
23 But this is --

24 MEMBER BANERJEE: The whole thing is a
25 coupled calculation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Right. But this is
2 the emergency core cooling. How is the -- forget
3 about the containment making its design margin, but
4 taking that aside, how would the PCCS non-condensable
5 gas affect this?

6 MEMBER BANERJEE: Water came back to the
7 GDCS.

8 CHAIRMAN CORRADINI: But it's all gravity-
9 driven.

10 MR. WALLIS: It doesn't matter. There's
11 not much water held up in there.

12 CHAIRMAN CORRADINI: There's not much
13 water held up in the isolation condenser. It's all
14 sitting in that pool, though. That's what I'm --

15 MEMBER BANERJEE: And if the isolation
16 condenser didn't work, and didn't condense any water,
17 there would be no water coming back.

18 MR. WANG: We're talking about the PCCS.

19 MR. WALLIS: Where would the water go
20 then? It doesn't go anywhere.

21 CHAIRMAN CORRADINI: I know, but this is -

22 -

23 MS. CUBBAGE: In the long term you could
24 have a --

25 CHAIRMAN CORRADINI: This is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 quantitative question. Yes?

2 MS. CUBBAGE: Right. In the long term,
3 you could have a transfer of water into the
4 suppression pool, and not everything coming back
5 through the GDCS, and so there's a question of whether
6 that equalizing line is going to end up opening or
7 not. That's part of it.

8 CHAIRMAN CORRADINI: Okay. Right. So now
9 let me ask the next question. So you had audit
10 calculations with MELCOR and the containment, which we
11 think we would like to have a meeting and talk about
12 that, but in this case, what are you going to look at
13 to audit this? In other words, are you going to just
14 ask for them to show you another calculation, or are
15 you going to do something yourselves?

16 PARTICIPANT: TRACE.

17 CHAIRMAN CORRADINI: I didn't say that.
18 I'm asking --

19 MEMBER BANERJEE: But they use TRACG for
20 this long term cooling --

21 MR. WANG: For the long term cooling, GE
22 used TRACG, and staff planned to do complimentary
23 calculations.

24 MR. WALLIS: With what?

25 MR. WANG: With TRAC/TRACE.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: With TRACE.

2 MR. WANG: With TRACE.

3 MEMBER BANERJEE: With the non-
4 condensables and everything?

5 MR. WANG: Yes.

6 MR. CHEUNG: This is Chester Cheung from
7 GEH. Actually, we have response to the RAI 6.3-79
8 that address the long term cooling from time zero all
9 the way to 30 days. So we have to respond to that.

10 MEMBER BANERJEE: You have run that now?
11 You've run your calculations out?

12 MR. CHEUNG: No, we run the calculation
13 all the way to 72 hours, and based on the result from
14 the 72 hour, and then we project on how much, say the
15 steam condenses, the drywell wall, breaking down to
16 the drywell annulus and not coming back, we project
17 the loss rate, and then we project all the way to 30
18 days. We still have more than one meter covering the
19 core.

20 CHAIRMAN CORRADINI: But staff has yet to
21 review or look at it.

22 MS. CUBBAGE: I was just going to -- I
23 wasn't sure if you said you had submitted that, or you
24 were getting ready to.

25 MR. CHEUNG: I don't know the status of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that.

2 MS. CUBBAGE: Okay.

3 MR. CHEUNG: We have finished, and --

4 MEMBER BANERJEE: Finished the
5 calculations.

6 MR. CHEUNG: We finished writing the
7 response.

8 MEMBER BANERJEE: And when is the
9 confirmatory -- this is one of the main issues,
10 clearly, what happens to the non-condensables.

11 MR. WANG: We already had some preliminary
12 confirmatory calculations done by Office of Research -
13 - actually Joe, because he didn't really get a chance
14 to present, because staff is still under review the
15 results from NRO side, but basically, Office of
16 Research made a few calculations, and they will give
17 us I think in the next one or two months -- I think we
18 will have a better answer for that.

19 CHAIRMAN CORRADINI: Excellent. Okay.

20 MEMBER BANERJEE: You don't want to give
21 us a peep at the answer at the moment? You want to
22 evaluate them before --

23 MR. WANG: It's up to our manager. MR.
24 DONOGHUE: Not now, no. We want to make sure that we
25 understand what the results are, and that -- because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Research has performed them. They've handed them over
2 to us in preliminary form. When they are issued in
3 final, we'll be more than glad to send them to you.
4 And we'll be talking to them definitely when we come
5 back here.

6 MR. WANG: Other significant open items,
7 basically GEH performed a sensitivity study for GD,
8 gravity-driven line break, and they ran for this break
9 up to -- it says, 20 percent of the break. And staff
10 is asking what about say smaller than 20 percent.

11 MR. WALLIS: That's for the GDL based?

12 MR. WANG: GDL.

13 MR. WALLIS: And the next bullet says 80
14 percent size --

15 MR. WANG: That's -- the first --

16 MR. WALLIS: Which is the one where you go
17 down through 180, 60, 40, 20, still gets worse and
18 worse? Which one is that?

19 MR. WANG: That's GDL line break.

20 MS. WILSON: That's the main steam line.
21 For the GDL break, it was mostly just trying to cover
22 all of our bases, because they didn't analyze anything
23 smaller than 20, so it's mostly just --

24 MR. WALLIS: It's getting worse as you --

25 MS. WILSON: This one it does not. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 GDL one is not -- it's the main steam line that --

2 MR. WALLIS: I thought it was the main
3 steam line.

4 MS. WILSON: Yes. They had analyzed --

5 MR. WALLIS: I was wondering why he said
6 GDLB. It's the main steam line that's the problem.

7 MS. WILSON: There's two different RAIs
8 out right now. They've only -- they've performed a
9 spectrum on the GDLB and the main steam line breaks,
10 and so for the GDLB, this is more of a completeness
11 issue, where we're like --

12 MR. WALLIS: The main steam line break
13 gets worse and worse as it gets smaller --

14 MS. WILSON: Right. And that was another
15 -- so there are two separate RAIs. This is more for
16 completeness sake. The other one was more of a
17 concern.

18 MR. WALLIS: I expected to see it here.
19 That's why.

20 CHAIRMAN CORRADINI: Why is it main steam
21 line gets worse and worse the smaller and smaller it
22 is? I don't understand.

23 MR. WALLIS: But it does, apparently.

24 CHAIRMAN CORRADINI: But I don't
25 understand.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: You don't have to understand,
2 just look at the result.

3 CHAIRMAN CORRADINI: I'm sorry.

4 MR. WANG: I don't have an answer here.

5 MS. CUBBAGE: Is it because there's a
6 delay in the ADS, if it's a small --

7 MR. WALLIS: Shouldn't extrapolate it to
8 zero, anyway.

9 (Off the record comments.)

10 VICE CHAIRMAN ABDEL-KHALIK: What is the
11 size, the flow limiter on the steam line?

12 MR. WALLIS: We don't know yet.

13 PARTICIPANT: It's 16 inches, or something
14 like that.

15 MR. WANG: I don't know the number.

16 MR. MARQUINO: I don't know off the top of
17 my head. It is documented in the DCD, the break area
18 for the steam line break, and the flow limiter area.

19 VICE CHAIRMAN ABDEL-KHALIK: Well, yes.
20 Right here it's 1.058 square feet, which is much, much
21 less than the diameter of the --

22 MR. WALLIS: I read that the minimum
23 static head in the chimney keeps dropping as you go to
24 --

25 MR. MARQUINO: Definitely, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: All the way down to 10
2 percent, it keeps dropping. Is that right?

3 MR. MARQUINO: Can you explain? Can you
4 say that again, Graham? I didn't hear you.

5 MR. WALLIS: They did a sensitivity of the
6 main steam line break, 180, 60, 40, 20, 10, and the
7 minimum static head in the chimney kept dropping as
8 they decreased the break size. So the question is
9 what happens between 10 percent and zero?

10 MR. MARQUINO: We understand the concern.
11 There is some numerical noise in these results, and
12 we'll address the NRC's question about this, and go
13 down to running a zero square foot break, if
14 necessary.

15 (Laughter.)

16 (Simultaneous speech.)

17 VICE CHAIRMAN ABDEL-KHALIK: I hope you
18 use long concepts.

19 MEMBER BANERJEE: What's the physics?

20 MEMBER SHACK: I don't understand it.

21 MR. CHEUNG: This is Chester Cheung from
22 GEH. The basic thing is everything -- all the breaks,
23 all you count is what happened at a point of level
24 one, and how much inventory remaining in RPV. That's
25 the piece measurement, because the level one is 4

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meter above the top active fuel. Now, at that point,
2 ADS open, and pretty sure memory, SRV to PV open, look
3 like a large break -- everything fresh, and then go
4 through DPV, we call the suppression pool, then the
5 RPV lose inventory that way.

6 MR. WALLIS: So it doesn't matter how big
7 the break is, as long as ADS opens.

8 MR. CHEUNG: No, it doesn't matter how big
9 is it, but it matters in the sense that when the level
10 one trip, now 100 percent it trip at 500 seconds. If
11 smaller break, then the level one trip keep pushing
12 out.

13 CHAIRMAN CORRADINI: So you're losing
14 inventory. That's your point.

15 MR. CHEUNG: No, at the point where level
16 one, the inventory is about the same. But the decay
17 heat different. At the time, also the system pressure
18 is different, say 500 second to decay heat, and so and
19 so, 600 second to decay drop. The system pressure
20 drop because you have a break anyway, so the way the
21 fresh, or blow-down, or the DPV or SRV lose --

22 MR. WALLIS: It shouldn't matter very
23 much, once you open ADS everything is the same.

24 MR. CHEUNG: Everything is the same, but
25 the point is initiation point --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WALLIS: It shouldn't matter much at
2 all.

3 CHAIRMAN CORRADINI: So it's the delay
4 time.

5 MEMBER BANERJEE: I still don't understand
6 it.

7 MR. CHEUNG: Because at level one 500
8 second, the decay heat, the system pressure is
9 observed. At 600 second, the decay is lower, the
10 system pressure is lower. On these two case,
11 everything blow up, that means either lower decay
12 heat, lower system pressure, the inventory lost will
13 be less.

14 MR. WALLIS: Before all the things happen.

15 CHAIRMAN CORRADINI: The inventory loss
16 will be less.

17 MR. CHEUNG: And that means --

18 MEMBER BANERJEE: For a smaller break,
19 you're getting more --

20 MR. CHEUNG: Smaller break, that means the
21 level one trip would be further, further out.

22 MEMBER BANERJEE: But it's going to be at
23 the same level. Right?

24 MR. CHEUNG: No. And ADS timing is
25 different.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: That's right. That
2 we got.

3 MR. WALLIS: That's what this is.

4 CHAIRMAN CORRADINI: And so let's just say
5 it out loud. So if at 100 percent break it's at time
6 one, and at 50 it's time two, time two is longer than
7 time one.

8 MR. CHEUNG: Much longer.

9 CHAIRMAN CORRADINI: Therefore, what's
10 different, the amount of inventory left in the --

11 MR. CHEUNG: After the DPV open.

12 CHAIRMAN CORRADINI: Okay. All right. So
13 it's the inventory remaining. Okay.

14 MEMBER BANERJEE: What trips the ADS
15 system?

16 MR. CHEUNG: Level one. Four meter above
17 the top of the fuel.

18 CHAIRMAN CORRADINI: But you were going to
19 do it for smaller -- so eventually it turns around and
20 all is good. Right?

21 MR. CHEUNG: Yes.

22 CHAIRMAN CORRADINI: Okay.

23 MR. CHEUNG: And we have gauges.

24 MEMBER BANERJEE: Do you understand it?

25 MR. WALLIS: Yes. They tell you that it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 --

2 MR. WANG: Another open item is basically
3 one category showed GD air line break, 80 percent is
4 the most limiting using nominal, but for 100 percent
5 size break, the most limiting for the bounding
6 condition, and the staff is asking what's basically
7 the reason. And the next one is, basically, staff is
8 asking GEH to perform SLCS, standby liquid cooling
9 system line break long-term results, with a worst
10 single failure.

11 Conclusion. Basically, from the
12 calculation results, the results show that the core is
13 covered in all LOCA, and preliminary staff calculation
14 also confirmed GEH's analysis. And there are major
15 open items. This concludes my presentation.

16 MR. WALLIS: Are there any showstoppers?
17 Are there really serious open items, or are these just
18 tidying up the details, as we heard this morning?

19 MR. WANG: Basically, it's detail, but GE,
20 I don't know if you have a solution for this
21 uncertainty.

22 MS. CUBBAGE: But that's not a technical
23 issue.

24 MR. WANG: That's not technical.

25 MR. WALLIS: I thought they were going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just bound it, instead of doing uncertainty analysis.
2 They just bound it.

3 CHAIRMAN CORRADINI: It's in the mail.

4 MR. MARQUINO: Well, Professor Wallis,
5 you're basically right. When we submitted the
6 application methodology, we looked at the important
7 parameters, and we set a set of very important
8 parameters at limiting values, and we call that our
9 bounding analysis, and we still have a meter and a
10 half of water level. But we did not do a 95-95 Monte
11 Carlo analysis on PCT, because the PCT is down like
12 the initial temperature of the fuel, and the
13 acceptance criteria is 2200 degrees.

14 MR. WALLIS: I'm saying it's absurd to use
15 those rules.

16 MR. MARQUINO: So we will respond to the
17 staff's --

18 MR. WALLIS: I thought you were doing an
19 uncertainty analysis on the level.

20 CHAIRMAN CORRADINI: Yes, that's what they
21 told -- so, thank you very much.

22 MR. WANG: Thank you.

23 CHAIRMAN CORRADINI: So I'll turn to Amy
24 and Jim, so I understand that there is a --

25 MS. CUBBAGE: They actually have some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 slides, so why don't we let GE take the table, and
2 talk about vacuum breakers.

3 CHAIRMAN CORRADINI: So all you vacuum
4 breaker folks.

5 MR. UPTON: Let me make one correct. What
6 we'd like to do is not present slides, but I'm open
7 for any questions and clarifications.

8 MR. WALLIS: No pictures?

9 MR. UPTON: The picture --

10 CHAIRMAN CORRADINI: He got you there. He
11 got you.

12 (Laughter.)

13 MEMBER BANERJEE: We're really
14 disappointed.

15 MR. UPTON: Well, we can discuss -- it's
16 in the DCD, a rough sketch of what the vacuum breaker
17 looks like.

18 MR. WALLIS: No pictures and no data, it's
19 no good.

20 MR. UPTON: Oh, no.

21 (Laughter.)

22 MEMBER BLEY: When you -- earlier you said
23 you can live with a vacuum breaker stuck open for a
24 period of time. Can you tell us a little more about
25 the period of time, and how effective is your passive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cooling system under that --

2 MR. UPTON: What we've seen, and I think
3 we have an analysis that shows, say for a two square
4 centimeter leak, you have containment pressure and
5 temperature is increasing, the delta P between the
6 drywell and the wetwell is increasing at a steady
7 rate. That period of time, if and when we see that we
8 have zero DP between the drywell and the wetwell, and
9 we isolate one of the vacuum breakers, it just re-
10 establishes, it's basically another equilibrium state
11 within the containment. So we have -- and so the
12 change is within -- I mean, at 72 hours, that's when
13 we see containment pressure even with excess leakage,
14 so we think we've got time to operate, or even
15 manually isolate if we had to.

16 MR. WALLIS: Do these vacuum breakers have
17 some sort of seal material in them?

18 MR. UPTON: Yes. If you'd like, I can
19 walk you through what we have done on the vacuum
20 breaker.

21 CHAIRMAN CORRADINI: Yes. It's in Chapter
22 4, is it not?

23 MR. UPTON: It's in Chapter 6, isn't it?

24 MEMBER SIEBER: Six.

25 CHAIRMAN CORRADINI: Six, 228.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. UPTON: Right. It's in Chapter 6.

2 (Off the record comments.)

3 MR. UPTON: If I might, I might give you
4 some of the history. The vacuum breaker design itself
5 was developed during the SBWR program, which is the
6 precursor to the ESBWR program. There was an
7 extensive design and development program that went
8 into it.

9 CHAIRMAN CORRADINI: Page 250.

10 MEMBER SIEBER: About two-thirds of the
11 way down.

12 MR. UPTON: And, as a matter of fact, the
13 prototype testing on the valve --

14 MS. CUBBAGE: This is the sensitive
15 version, so I'd like to search right to it. If you
16 have a number, do you have a figure number?

17 CHAIRMAN CORRADINI: Page 250, 6.2-28.

18 MEMBER SIEBER: That's the figure number,
19 but the page is like 250 or something like that.

20 CHAIRMAN CORRADINI: The page is 250, yes.
21 One more time.

22 MS. CUBBAGE: It's thinking.

23 CHAIRMAN CORRADINI: There you go. There
24 it is. Okay.

25 PARTICIPANT: Somebody explain to us how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that thing works.

2 MR. UPTON: Right. Okay. Now, first of
3 all, let me state that what's not shown on this figure
4 are the exhaust screens, which are flanged. You see
5 the flange connections on the valves. I'll get into
6 that in a minute, but -- I could go up with a pointer.

7

8 MR. WALLIS: It's just a weight that jumps
9 up and down?

10 MR. UPTON: That's basically what it is.

11 MR. WALLIS: What's the point for?

12 MR. UPTON: Let me give you some
13 background. The vacuum breaker was developed
14 specifically for the SBWR program. Okay? And the
15 development was completed in like July of 1994. Okay?
16 It was docketed under the SBWR program in response to
17 an RAI. There was a complete test and development
18 program done.

19 Now, I'll walk you through. It's a very
20 simple passive device. First of all, what's not shown
21 on here, there will be a debris screen underneath the
22 vacuum breaker, where the screen itself is sized for
23 a minimum particle.

24 The unique feature about this vacuum
25 breaker basically is the fact that we've got two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seats. You've got a non-metallic seat, and you've got
2 a hard seat. Okay? So the non-metallic seat is an
3 elastomer seat, which gives you extremely tight --

4 MR. WALLIS: That's an O-ring-like thing
5 that goes around --

6 MR. UPTON: Yes. So the vacuum breaker,
7 as tested, is effectively bubble tight. It lists just
8 a disk. It has an anti-chatter ring here, basically,
9 it's an increased area that once it opens up at half
10 a PSID, will force the vacuum breaker up. But it
11 opens at half a PSID to relieve pressure between the
12 drywell and the wetwell, when you have a vacuum,
13 either during the GDCS quenching phase, or during --
14 if you decide to use drywell spray and create a
15 vacuum in that region.

16 MEMBER BANERJEE: So it's just that weight
17 which determines what --

18 MR. UPTON: That's correct. It's just the
19 weight, the weight of the disk, the weight of this
20 disk determines the valve set point. Now, when we
21 tested it, we tested -- a full-scale prototype was
22 built. It was tested in FIAT in Italy in a full-scale
23 test facility. We did -- we aged the valve, we did
24 thermal aging, we did dynamic aging, we tested for
25 seismic conditions, we radiation-aged it, radiation-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 aged the seal, then we did as-built testing on the
2 valve before we started. We did performance testing
3 on the valve, and then we did reliability testing on
4 the valve.

5 MR. WALLIS: How about those bearings?
6 What's in the bearings? Is this metal-on-metal?

7 MR. UPTON: I'd have to go back and look
8 at the specifics of what the bearing is.

9 MR. WALLIS: What you worry about is
10 bearings getting jammed up or something? It doesn't
11 take much to jam a bearing.

12 MR. UPTON: Right. And that's -- one of
13 the things we did was we looked at okay, what is the
14 expected debris into the valve over a 60-year life, so
15 what we did is ingest a lot of basically grit,
16 sandblasting grit.

17 MR. WALLIS: Which ought to go right
18 through the thing, but if grit gets in the bearing --

19 MR. UPTON: Well, what we did is we coated
20 the inside of the valve with oil so that it would
21 stick. And then after we ingested two pounds of
22 sandblasting grit, we cycled the valve for 3,000
23 times, and basically had no failure.

24 CHAIRMAN CORRADINI: What is the position
25 indicator for this valve?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. UPTON: What you have, you've got
2 proximity switches in the seat area here, which
3 determines where the seat is. There's four of them
4 located. You can operate with one failed, and that
5 will give you sufficient indication to determine -- in
6 the original design, they were sufficiently sensitive
7 enough that even if you had a particle on the seat,
8 you would determine how much area --

9 MEMBER BANERJEE: What principle does the
10 proximity sensor work from?

11 MR. UPTON: It's just the proximity of
12 metal, and it gives you a voltage output.

13 MEMBER BANERJEE: Capacity --

14 MR. UPTON: I think so.

15 MEMBER BLEY: Is the only thing that moves
16 that little round disk --

17 MR. UPTON: This disk here.

18 MEMBER BLEY: There's no guides for it.
19 It's just --

20 MR. UPTON: No, this is the guide here.
21 This is the guide here. There's a bearing here, and
22 there's a bearing here.

23 MR. WALLIS: The shaft moves up and down.

24 MR. UPTON: The shaft moves up and down.

25 MR. WALLIS: Grit might not hurt you. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mean, what hurts a bearing is very, very fine
2 particles or corrosion inside the bearing, usually
3 there's a small clearance in the bearing. I don't
4 know what you've got in there at all, but it doesn't
5 take much if you've got a tight clearance in a bearing
6 to prevent it from moving.

7 MEMBER BANERJEE: Depends on what bearing
8 they're using.

9 MR. WALLIS: Yes, I know.

10 MEMBER BANERJEE: What is it?

11 MR. UPTON: I'd have to go back and review
12 exactly what we're using in the bearing. I don't
13 recall. It's been a while.

14 CHAIRMAN CORRADINI: So now just one
15 thing. You said you tested this under the SBWR
16 program, so is the design in the ESBWR just more of
17 the same, or larger?

18 MR. UPTON: It's identical. It's an
19 identical valve.

20 CHAIRMAN CORRADINI: Same number, there's
21 four.

22 MR. UPTON: Same number, there's just --
23 no, just same number, same size valve. It's
24 identical. We had three on the ESBWR or on SBWR, and
25 we've got three on ESBWR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN ABDEL-KHALIK: You said the
2 original position indicator was very sensitive.

3 MR. UPTON: Yes.

4 VICE CHAIRMAN ABDEL-KHALIK: What is the
5 sensitivity of the current position indicator, and
6 what --

7 MR. UPTON: Well, after the testing, we
8 used proximity probes during the testing on SBWR.
9 Okay? There was some drift associated with those
10 proximity probes, so they recommended after the
11 testing that we use proximity switches, which are
12 basically the same thing, the same technology. It
13 just shows you whether the disk is in contact or not.
14 So we haven't actually -- in an actual production
15 valve, we may look at those sensors and say well,
16 maybe we can get more accurate proximity probes that
17 don't drift. We haven't gotten there yet.

18 VICE CHAIRMAN ABDEL-KHALIK: I mean, the
19 reason I'm asking is, can these things be not quite
20 closed, but would give you an indication that they are
21 closed?

22 MR. UPTON: That is not possible with the
23 proximity sensors themselves, because it's based on
24 the location of where the disk is, you have a voltage
25 output, and so you would have some --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: You've got some
2 calibration error.

3 MR. UPTON: That's true, there will be
4 calibration error.

5 MEMBER SIEBER: It may be open a little
6 bit. One of the things that's important is that that
7 valve is normally closed.

8 MR. UPTON: Right.

9 MEMBER SIEBER: And if you're worried
10 about debris, and the valve is normally closed, the
11 amount of debris accumulation is pretty small.

12 MR. UPTON: And the filter, the discharge
13 filters that we designed basically have a cover over
14 the top of the filter, and the discharge port is below
15 it, so any LOCA debris would not actually get into or
16 on to the seat. That's by design.

17 VICE CHAIRMAN ABDEL-KHALIK: How much of
18 a gap would give you a one centimeter square area?

19 MR. UPTON: The discharge holes on the
20 exhaust screen are .9 millimeters.

21 VICE CHAIRMAN ABDEL-KHALIK: No, no. How
22 much of the field gap on the seat?

23 MR. UPTON: On the hard seat, even if you
24 had a particle on the hard seat, the soft seat still
25 seals, so we did do testing for various particle sizes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at FIAT to determine at what size would fail it. And
2 I have the report here.

3 MEMBER BANERJEE: Could you give us the
4 diameter of the circle which the O-ring makes, we can
5 calculate it.

6 MS. CUBBAGE: I think you're answering a
7 different question than was asked. They want to know
8 how much --

9 VICE CHAIRMAN ABDEL-KHALIK: How much
10 would it have to rise to equal --

11 MEMBER BANERJEE: Just give us the
12 diameter.

13 MR. UPTON: Oh, oh, oh, oh. I don't have
14 that off the top of my head.

15 MEMBER BANERJEE: Give us the diameter.
16 How big is it?

17 MR. UPTON: Well, the diameter of the
18 valve is 24 inches. Okay?

19 MEMBER SIEBER: Manholes. A person --

20 MEMBER BANERJEE: Sixty centimeters.

21 MR. WALLIS: Sixty centimeters, yes.

22 MR. UPTON: Part of the --

23 (Off the record comments.)

24 MR. UPTON: As I said, the test report for
25 the vacuum breaker was docketed under the SBWR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 program, so it was in response to an RAI on the SBWR
2 program, and we have the docket number, and the MFN
3 letter that it was transmitted under. And as part of
4 that testing, we used -- we did look at particles on
5 the hard seat, and to see what the leakage rate would
6 be.

7 MEMBER SIEBER: No chance for it to rattle
8 or get --

9 MEMBER BANERJEE: One two-hundredth of a
10 centimeter.

11 MR. WALLIS: 10,000 over 200.

12 MS. CUBBAGE: Were there any other points
13 you wanted to make?

14 MR. UPTON: I guess the other point is
15 that what we're currently going to do is put in an
16 isolation valve with -- basically bubble tight
17 isolation valve, with a scotchlogarp operator nitrogen
18 supplied solenoid actuated. That's the current
19 reference configuration, so that not only do we have
20 a vacuum breaker that's extremely leak tight, but
21 you've got an isolation valve which is also extremely
22 leak tight, or bubble tight.

23 MR. WALLIS: So human error in there would

24 --

25 VICE CHAIRMAN ABDEL-KHALIK: It's 2 mils.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: If it's uniformly open.

2 CHAIRMAN CORRADINI: I guess I want to ask
3 one other thing about the proximity switch, or
4 proximity whatever they are. So are they all around
5 the whole circumference of the manhole, or are they in
6 precise positions?

7 MR. UPTON: There are four, basically one
8 in each quadrant.

9 MEMBER SIEBER: Ninety degrees apart.

10 MR. UPTON: Ninety degrees apart. Now
11 there's nothing that says we can't add additional
12 proximity probes. It was just that four was felt to
13 be sufficient to detect the seat not fully seated.

14 CHAIRMAN CORRADINI: And now let's talk
15 about bypass leakage, the opposite direction. That
16 would be the path the bypass leakage in the opposite
17 direction, through an unseated valve this way. Yes?

18 MR. UPTON: Right. Right.

19 CHAIRMAN CORRADINI: So what's the weight
20 of the piston or the cylindrical thingamabobber in the
21 middle?

22 MR. UPTON: You'd have to calculate it.
23 It lists at half a PSID. I don't recall exactly what
24 the weight is.

25 CHAIRMAN CORRADINI: I guess what I --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 maybe I should ask the question in a bit different
2 way. When you say it's tight, do you design it to
3 have a certain weight to cause it to essentially seal
4 on the hard seal? I don't understand the soft seal.
5 I understand the hard seal. How is it sealing on the
6 soft seal above it?

7 MR. UPTON: Not above it. In other words,
8 you've got a hard seat here, and then in addition to
9 that, you've got an elastomer seat.

10 CHAIRMAN CORRADINI: Oh, in the middle as
11 an O-ring.

12 MR. UPTON: Yes, as an O-ring.

13 CHAIRMAN CORRADINI: That's this little
14 black square?

15 MR. UPTON: Right.

16 CHAIRMAN CORRADINI: Okay. Thank you.

17 MR. UPTON: Right. Right. Right.

18 MEMBER BANERJEE: Why does it have to be -
19 -

20 MEMBER SIEBER: The weight of the disk is
21 determined by how much pressure you want to have --

22 MR. UPTON: There is a certain relief area
23 that's required, and I think it was 1.04 foot squared,
24 so that defined the size of the valve. We could have
25 done it by multiple valves.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: How many of these do you
2 have?

3 MR. UPTON: Three, we have three valves.
4 We only need one, so it's like an N minus 2 type
5 situation.

6 MEMBER MAYNARD: You really end up with
7 quite a bit of force trying to shut it. I mean, the
8 size of that valve, even fairly small differential
9 pressure is going to be a lot of force.

10 MEMBER SIEBER: That disk is probably 30
11 or 40 pounds, too. You have to have enough force to
12 lift it, and that's -- the weight of the disk
13 determines when it's going to trip.

14 MR. UPTON: Right.

15 CHAIRMAN CORRADINI: It's a manhole.

16 MR. UPTON: Right, that's what it is.

17 CHAIRMAN CORRADINI: It's a manhole.

18 MR. UPTON: And the reason we went this
19 way is it doesn't have the same problems that the
20 swing checks had. You don't have -- you've got all of
21 the force of gravity working on this plate, basically,
22 to seal it, and it's sealed uniformly.

23 MEMBER MAYNARD: Now when you want it
24 shut, it's got a lot of force shutting it. When you
25 want it open, it ends up --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. UPTON: A lot of force opening it.

2 MEMBER SIEBER: Right. And it goes to the
3 top.

4 MEMBER BLEY: How wide is the seating
5 surface?

6 MR. UPTON: I've got the detail example
7 drawing. It's about --

8 CHAIRMAN CORRADINI: It's probably an
9 inch.

10 MR. UPTON: Yes, it's an inch and a half,
11 an inch.

12 MEMBER BLEY: That's what it looks like.

13 MEMBER BANERJEE: It's a big valve.

14 MR. UPTON: It's a big valve.

15 VICE CHAIRMAN ABDEL-KHALIK: So how tight
16 is the clearance on the vertical rod that's providing
17 guidance for this valve?

18 MR. WALLIS: It's the bearing we're
19 talking about.

20 MR. UPTON: On the bearings?

21 VICE CHAIRMAN ABDEL-KHALIK: No, just --
22 how tight -- in other words, to answer the gravity
23 question, can this valve actually be partially seated
24 because it's crooked?

25 MR. UPTON: The tolerances on the bearings

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are pretty tight, so we maintain the configuration,
2 that is up and down. And I have to -- I don't have
3 the assembly drawing with me. We can get you those
4 numbers, because we have an assembly drawing that the
5 valve was built by, and the tolerances are -- I don't
6 want to guess. I'll get you the --

7 VICE CHAIRMAN ABDEL-KHALIK: Well, this
8 may sound like a lot of detail, but when you figure
9 out that it takes only 2 mils of a gap to give you one
10 square centimeter of a leakage area, then you start
11 worrying about things, how aligned is this valve,
12 whether or not -- if you've got so many of them, you
13 can actually add up to one centimeter square.

14 MR. UPTON: Yes, but the elastomer seal is
15 very forgiving, too. In other words, you've got not
16 only a hard seat, only if the hard seat didn't meet --
17 -- if I had a single seal, yes, I'd be concerned,
18 because then a particle on the hard seat would then,
19 indeed, give you leakage. But the elastomer seat is
20 very forgiving. And, as a matter of fact, what we've
21 seen is even if we have particles on the hard seat,
22 the elastomer seat seal is still within tolerance. I
23 mean, it's less than point zero -- well, it's
24 extremely leak tight. And, again, in the testing that
25 we did in Italy, we looked at that. And we looked at,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 okay, what is the leakage rate if we have something on
2 the seal?

3 (Simultaneous speech.)

4 MEMBER BLEY: Is there a test report?

5 MR. UPTON: Yes, there is a test -- and
6 that's what I was saying. On the SBWR docket in 1994,
7 the entire test report was supplied. As part of an
8 RAI response, we plan on also -- on ESBWR we will also
9 provide that.

10 MEMBER BANERJEE: Is there a program --
11 you know, these are basically polymers. Right? Your
12 elastomer.

13 MR. UPTON: Yes.

14 MEMBER BANERJEE: So they're going to age.

15 MR. UPTON: Yes, six years.

16 MEMBER BANERJEE: Yes. So the question is
17 how often do you change them out?

18 MR. UPTON: We change it out six years,
19 about.

20 MR. WALLIS: You check it out actually
21 every outage or something like that?

22 MR. UPTON: Yes. We will be -- the plan
23 is that every refueling outage, you will confirm the
24 leak tightness of the valve by local leak rate test.

25 CHAIRMAN CORRADINI: But you'll cover it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with a housing --

2 MR. UPTON: Basically, take off the
3 discharge ports, add flanges, and then pressurize over
4 the seat, and do a pressure decay to confirm that it's
5 not leaking.

6 CHAIRMAN CORRADINI: I'm sorry. One
7 question about -- so you said it's on the SBWR, but
8 this is not the design on the ABWR.

9 MR. UPTON: No, it is the design on the AB
10 ---- it's identical. They're identical.

11 CHAIRMAN CORRADINI: It is, on the ABWR?

12 MR. UPTON: Oh, no, I'm sorry. I'm sorry.
13 No, it's not the ABWR. On the ESBWR it is identical.

14 CHAIRMAN CORRADINI: Right. I understand.

15 MR. UPTON: Yes.

16 MEMBER MAYNARD: How often, if ever, will
17 these actually be exercised?

18 MR. UPTON: I think the calculation
19 predicts 37 times.

20 MS. CUBBAGE: Tested.

21 MEMBER MAYNARD: No, I mean tested. I'm
22 sorry, tested.

23 MR. UPTON: Oh, when we tested it, we
24 cycled it 3,000 times plus.

25 MEMBER MAYNARD: No, I'm talking about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 during normal -- my concern isn't debris getting in
2 there and stuff. It's a type of corrosion build up or
3 something that's sitting there over a long period of
4 time, and maybe 10, 15 years after this thing has been
5 put in service.

6 MEMBER BANERJEE: Well, they change it
7 every six years, anyway.

8 MR. UPTON: And we're talking about leak
9 rate testing it, and lifting it every outage.

10 MEMBER MAYNARD: Okay. Lifting at each
11 outage. Okay. The leak rate -- okay.

12 MEMBER BANERJEE: And changing out the O-
13 ring.

14 MEMBER MAYNARD: Now that's every six
15 years I think.

16 MEMBER SIEBER: How do you lift it?

17 CHAIRMAN CORRADINI: Carefully.

18 MR. UPTON: Yes, carefully.

19 MEMBER SIEBER: There's no handle any
20 place.

21 MR. UPTON: We haven't worked that out
22 yet, but the thinking is that you'll have something
23 that will grab onto the stem of the valve and just
24 lift it. Or you can come in through the top of the
25 valve here, and lift the stem.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: The only thing looks just a
2 little funny to me, the stem -- given this is a
3 manhole cover, the stem is real skinny.

4 MR. UPTON: Well, this may not be
5 representative of the actual valve.

6 MEMBER BLEY: I'm just thinking about some
7 kind of bending moments on there, when it -- does it
8 bang open?

9 MR. UPTON: We can provide the staff the
10 actual assembly drawing of the valve.

11 MS. CUBBAGE: Right. And we'll be getting
12 that test report, and we'll send it to you guys.
13 There's one more presentation, so if you want to get
14 to that, we probably ought to --

15 CHAIRMAN CORRADINI: Yes, we do.

16 MS. CUBBAGE: So we'll send it.

17 CHAIRMAN CORRADINI: Are we done torturing
18 Mr. Upton?

19 MR. UPTON: Is that it, all these
20 questions?

21 CHAIRMAN CORRADINI: So just to repeat
22 about the one thing you said, just all kidding aside.
23 So you're planning to take the test program and give
24 it back to the staff under the ESBWR --

25 MR. UPTON: Docket.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: -- docket.

2 MR. UPTON: Yes.

3 CHAIRMAN CORRADINI: Thank you.

4 MR. UPTON: That's true.

5 CHAIRMAN CORRADINI: Okay. And then we
6 could look that --

7 MEMBER BLEY: WE can look at anything we
8 want, but it's already filed on the SBWR docket.

9 MR. UPTON: Yes. In other words, we could
10 ---- I've got the docket number, the MFN letter that
11 it was transmitted under. You can get access to it --

12

13 CHAIRMAN CORRADINI: Pass that to Amy.

14 MEMBER BANERJEE: This was done in a steam

15 --

16 MR. UPTON: Yes.

17 MEMBER BANERJEE: Where, in Kachensa, or
18 where was it?

19 MR. UPTON: Fiat. Now the cycling test,
20 the reliability test was an air test. But the valve
21 performance test was done at full speed.

22 (Off the record comments.)

23 DR. WHITE: Are we ready?

24 CHAIRMAN CORRADINI: Go ahead.

25 DR. WHITE: Hi, I'm Dr. Frostie --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Oh, I'm sorry.

2 DR. WHITE: We're going to go into light
3 topics today, since we had so many wide ones over
4 there. I'm Dr. Frostie White, and I'm the lead
5 license engineer for the transient analysis, and we
6 have submitted a topical report on feedwater
7 maneuvering over the past month. It's under review
8 right now. We've had a couple of presentations with
9 th staff, and we thought it would be appropriate to
10 present this also to the ACRS.

11 Dr. Pradip Saha will be our presenter, and
12 go through how we looked at the analyses, and I will
13 caution, if we get into some topics related to the
14 actual feedwater controller, we may have to go into a
15 closed session, because we are under a patent review
16 right now for our feedwater control. Dr. Saha.

17 DR. SAHA: Okay. As Dr. White mentioned,
18 I'm Pradip Saha, and I work for GE Nuclear Energy.
19 I'm a principal engineer in the ESBWR engineering
20 team. And I know it's late, but I'm sure everybody is
21 awake. Right? You're all interested to hear this.

22 CHAIRMAN CORRADINI: We're all interested.

23 DR. SAHA: That's right. Professor
24 Wallis, and Sanjoy, and you, Mike. Anyway, so what I
25 will do, basically, I will just give you the concept

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and the overview of this feedwater temperature control
2 system, and the operating domain. We have developed
3 a new operating domain, because this morning we have
4 heard, and it is rightly, that for the operating BWR
5 reactors, we have two nice features. One is, of
6 course, the control rod movement, and another is the
7 cold flow changes. And in the ESBWR again this
8 morning, we heard - we saw, even though now, of
9 course, the natural circulation core quality is quite
10 good, but it is really just a function of power, so
11 there is no other method to change the reactor power
12 other than the control rod motion. So, basically, our
13 objective of this work is to develop a metric similar
14 to cold flow control in operating BWRs. But this is
15 additional to the control rod movement much like in
16 operating reactor. And this is desired for ESBWR
17 operational acceptability.

18 MEMBER ARMIJO: Is it GE's intent to make
19 this an integral part of the design certification?

20 DR. SAHA: Yes.

21 MEMBER ARMIJO: Okay.

22 DR. SAHA: Right. Okay. So we actually
23 assembled a team about a year ago, maybe a little bit
24 more than one year ago. We assembled a team, a multi-
25 disciplinary team of experts, and the experts were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from nuclear analysis area, balance of plant area,
2 implementation and control, mechanical design, safety
3 analysis, and reactor operation. And all these
4 experts, they had combined probably 200, maybe 300 man
5 years of experience in nuclear industry. And they're
6 all highly respected in their own field. And we
7 looked into -- this team, actually, looked into
8 various methods, and then finally, we decided on this
9 feedwater temperature control. And this slide shows
10 three bullets, and I'm more accustomed, and more at
11 ease standing up, and using my pointer. This is good.
12 This is all Spanish pointer that we used to use at NRC
13 in meetings 20 years ago.

14 Okay. So these are three bullets, is that
15 what we did, we reconfigured our feedwater heaters.
16 Actually, we did it such that we have now seven
17 feedwater heater. It's the high pressure. We
18 basically brought one from the low pressure feedwater
19 heater, but, of course, now this is a high pressure
20 feedwater heater. And we allow, when we want, to have
21 steam from the main steam bypass header, which is, of
22 course, high pressure, and high temperature, to
23 increase the final feedwater that is going into the
24 reactor vessel. Okay?

25 And this seven feedwater heater is sized

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 such that the feedwater temperature will increase at
2 the right condition by 66 degree Fahrenheit, so from
3 a nominal temperature, feedwater temperature of 420
4 degree Fahrenheit, it will go to 400 -- maximum of 486
5 degree Fahrenheit. And that lowers the reactor power,
6 if the reactor were at 100 percent power, lowered by
7 about 15 percent, or 85 percent rated power. Low
8 insertion of control rod, control rod pattern stays
9 the same. We just increase the feedwater temperature,
10 and the power goes down.

11 DR. WHITE: This makes more voids in the
12 core.

13 DR. SAHA: Yes, no. The reason is here,
14 Professor Wallis. What happens when we increase the
15 feedwater temperature, and our circulation water is,
16 of course, in the saturation, that drops the core
17 inlet temperature somewhat. Okay? Maybe by one-
18 fourth of whatever increase we are doing. It
19 increases the temperature, so that drops the volume
20 boundary, so more parts in the core, and, again, avoid
21 the activity feedback. That brings the power down.

22 MEMBER BANERJEE: Are there any stability
23 implications of this?

24 DR. SAHA: Well, we have done stability
25 analysis. I will come to that. Well, first of all,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this presentation is supposed to be just an overview.
2 I have only five slides. And as staff has mentioned
3 many times during the whole day, that there has been,
4 one, an EDO report is a Class I report, an EDO 3338.
5 This is a 400-page document, and it has got all the
6 stability, AOs, and infrequent event analysis, LOCA
7 analysis, everything.

8 VICE CHAIRMAN ABDEL-KHALIK: Now your
9 circulation ratio at full power is about 6.

10 DR. SAHA: I think one is to 4, because --

11
12 VICE CHAIRMAN ABDEL-KHALIK: How much?

13 DR. SAHA: One is to 4, about one is to 4.

14
15 VICE CHAIRMAN ABDEL-KHALIK: Four?

16 DR. SAHA: Four.

17 VICE CHAIRMAN ABDEL-KHALIK: About four.
18 So you mean the average quality at the top of the core
19 is 25 percent?

20 DR. SAHA: About 20, 25 percent, because -

21 -
22 VICE CHAIRMAN ABDEL-KHALIK: That is
23 inconsistent with what we heard --

24 DR. SAHA: Okay. Let me -- if we go back,
25 if we go to say feedwater flow or steam flow, and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 core flow rate, if I remember, there is a table in DCD
2 4.4-1, that has feedwater flow rate, steam flow rate,
3 2,000, a little bit more than 2,000 kg plus --

4 CHAIRMAN CORRADINI: 2400 is a steam flow
5 about 10,900 is your --

6 DR. SAHA: That's right. That's about one
7 is to 4. Right?

8 VICE CHAIRMAN ABDEL-KHALIK: Okay. So
9 what is your circulation ratio at 85 percent power at
10 this lower feedwater temperature?

11 DR. SAHA: Okay. Again, this -- the EDO
12 3338 has that table, again. And that shows that
13 number. I don't exactly remember the number, but the
14 number is there. It's not much different. Bigger
15 code, the circulation flow rate goes up a little bit,
16 goes down, because now we have a little bit higher
17 void fraction.

18 Anyway, so this is basically an opposite happens if we
19 defeat the feedwater temperature.

20 DR. ALAMGIR: This is Dr. Alamgir from
21 GEH. I did the evaluation of condition at high
22 temperature. It's about the same, four to one.

23 DR. SAHA: Thank you.

24 MEMBER ARMIJO: Just for clarification, by
25 this technique you can -- at any power level you can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 move plus, with a 15 percent range of that stated
2 power just by this changing the feedwater temperature?

3 DR. SAHA: No, this is from 100 percent,
4 it comes to 85 percent.

5 MEMBER ARMIJO: 85.

6 DR. SAHA: And I have --

7 MEMBER ARMIJO: But going up from low
8 power up.

9 DR. SAHA: Low power up?

10 MEMBER ARMIJO: If you're at 10 percent
11 power, and you want to go up to 30 percent.

12 DR. SAHA: Oh, okay. Now there, actually,
13 again, if you -- I mean, if I can wait for one or two
14 slides.

15 MEMBER ARMIJO: Okay, I'll wait.

16 DR. SAHA: This will be clearer. Things
17 will be clearer. Can we go to the next slide? Okay.
18 So this is a schematic. Again, this is from DCD, in
19 the DCD 10.1-1, I just took a part of it. The high
20 pressure feedwater heater part. Here you see this is
21 basically the feed pump, the normal feedwater flow
22 line is going like this, and there are two trains,
23 heater number 5, 6, and 7. And the 7, as I said
24 before, the steam comes from the main steam line. And
25 there are valves here and here. It is not necessarily

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that one wants to increase the feedwater temperature
2 all the time. It's kind of an option.

3 And, also, so feedwater temperature can
4 increase when we allow main steam line to come to the
5 7 heater. Also, you can see there is a bypass line
6 here, and this valve is, of course, normally closed.
7 But if somebody wants to, the operator or the utility
8 wants to reduce the feedwater temperature, they can
9 open this bypass valve, so some feedwater will go
10 unheated, and some other will go heated. And the
11 mixture, temperature here, final feedwater temperature
12 will be lower than the normal. So this is the way we
13 can go high, as well as low in the feedwater
14 temperature. Question?

15 MEMBER BANERJEE: The flow eventually is
16 calibrated for temperature changes?

17 DR. SAHA: Are you going into --

18 MEMBER BANERJEE: The measurement of the -

19 -

20 DR. SAHA: Feedwater flow?

21 MEMBER BANERJEE: Yes.

22 MR. MARQUINO: Yes, they are.

23 MEMBER BANERJEE: You calibrate them over
24 this?

25 MR. MARQUINO: Yes. We compensate for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 temperature density variations in the heat balance,
2 and the feedwater flow measurement. VICE CHAIRMAN
3 ABDEL-KHALIK: So at full power, there is no lead
4 steam going to feedwater heater number 7?

5 DR. SAHA: At the normal condition --

6 VICE CHAIRMAN ABDEL-KHALIK: Operation,
7 full power.

8 DR. SAHA: In the normal operation,
9 feedwater -- yes, okay. In normal operation, there is
10 no steam going into this feedwater heater. There may
11 be just a crack open valve or orifice just to keep
12 these heaters warm.

13 DR. WHITE: But that would be to reduce
14 your efficiency, presumably, because you're just
15 circulating stuff around that's doing nothing.

16 DR. SAHA: No. This -- just a little
17 steam will come, and the drain goes to this open
18 heater number 4.

19 MEMBER BANERJEE: Doing this, does it
20 affect your cycle efficiency?

21 CHAIRMAN CORRADINI: Not much.

22 DR. SAHA: No, no, no. Actually, the BOP
23 side, the balance of plant side, is designed such that
24 we have maximum thermal efficiency at operating point
25 of 100 percent power and 420 degrees.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Yes. I'm asking when
2 you do this --

3 MR. WALLIS: So when you maneuver, you
4 reduce it.

5 DR. SAHA: Yes, we reduce a little bit of
6 efficiency.

7 MEMBER SIEBER: Well, that happens in a
8 normal configuration, too.

9 MEMBER BANERJEE: Yes.

10 MEMBER SIEBER: Once you start to
11 throttle, the valves on the turbine lose some
12 efficiency. But I think you have to go the whole way
13 on this once you increase feedwater temperature.
14 That reduces the core power output, which reduces the
15 steam pressure, and since this is basically a constant
16 pressure device, you have to change the governor
17 valves to get the pressure back up. And so there's
18 more things that happen than just changing the
19 feedwater control.

20 DR. SAHA: That's right. Okay. Now, I
21 would like to explain this, take some time and explain
22 this figure, because it shows the similarity and the
23 difference between what we are all familiar with for
24 the forced circulation boiling water reactors. This
25 is the forced circulation side, and this is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 natural circulation, the ESBWR side. And here I have
2 got two maps, one is power flow map, this way. And
3 another is power feedwater temperature map this way.

4 MR. WALLIS: It would help if you put the
5 -- on the power flow map, you actually put different
6 feedwater temperatures. That one over there on the
7 right, upper right-hand --

8 DR. SAHA: Yes, what I'm saying --

9 MR. WALLIS: It would help if you put --
10 the upper right-hand one, which has one curve on it,
11 that's for one feedwater temperature. That one on the
12 right upper right.

13 DR. SAHA: Upper right?

14 MR. WALLIS: That's for one feedwater
15 temperature.

16 DR. SAHA: This is for one feedwater, yes.

17 MR. WALLIS: It would help if you had
18 curves of different feedwater temperature in that --

19 DR. SAHA: Good point. Good point. Okay.
20 What I wanted to say is this, that even for operating
21 reactors, we do have a natural circulation line that
22 was shown this morning, and then because of this cold
23 flow that we have this recirculation of the pump, we
24 have this operating zone. So there are two ways to
25 change reactor power; one is, of course, control rod,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 another is the core flow. And, originally, of course,
2 GE had this map, and then basically we analyzed
3 further, and we went to higher and higher power. And
4 NRC and ACRS have reviewed all this thing.

5 MEMBER BANERJEE: Total plant you have no
6 plants yet at.

7 DR. SAHA: Not yet at, but they are going
8 towards higher power.

9 MEMBER BANERJEE: Right.

10 DR. SAHA: Okay. So more electricity
11 generation. Okay. Now the lower figure, this column,
12 first column, shows the power feedwater temperature,
13 and this black line, solid line is the normal
14 feedwater temperature versus power. Because as you
15 increase power, of course, more extraction steam, so
16 feedwater temperature also increases.

17 Okay. Now here is this green region, is
18 the feedwater temperature reduction region, and in
19 several BWRs, operating BWRs, towards the end of cycle
20 to get to more power out of the core, feedwater
21 temperature has been reduced, maybe by passing
22 feedwater heater. And, again, GE and the utility
23 worked together, and NRC and ACRS have reviewed it,
24 and they have approved this, so we do have operational
25 experience of this region also, feedwater temperature

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reduction area.

2 Okay. Now let me focus on the right-hand
3 side. Here is the ESBWR, and, again, today many times
4 it was mentioned. It is basically practically in
5 line, and to answer Professor Wallis' question, yes,
6 if we change the feedwater temperature, and it does
7 move a little bit, but, again, we do not get a big
8 region. It is a very, very narrow band, but your
9 point is --

10 MR. WALLIS: But it changes the power a
11 lot, because you're on that vertical path.

12 DR. SAHA: Yes. Because 85 percent, this
13 point will come down somewhere here. But flow doesn't
14 change that much.

15 VICE CHAIRMAN ABDEL-KHALIK: If we go to
16 this lower right corner diagram --

17 DR. SAHA: Yes, this is what I'm coming
18 to.

19 VICE CHAIRMAN ABDEL-KHALIK: At the 85
20 percent power, 486 degrees F, Fahrenheit, if we were
21 to operate at this point, the natural circulation
22 driving head through the core, the difference with the
23 same chimney would be decreased. Correct?

24 DR. SAHA: Again?

25 VICE CHAIRMAN ABDEL-KHALIK: The driving

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pressure difference --

2 DR. SAHA: Can I have a blow up, the next
3 figure has the blow up.

4 VICE CHAIRMAN ABDEL-KHALIK: Right there.

5 DR. SAHA: Yes.

6 VICE CHAIRMAN ABDEL-KHALIK: Okay. DR.
7 SAHA: So let me explain first, this is the normal
8 power ascension line with no seven feedwater heater,
9 or no steam to the seven feedwater heater. Six
10 feedwater heaters are on line, and we are cooling
11 rods, and we are going this way. And suppose we are
12 here, and now we open the valve to the seven feedwater
13 heater, no change in the control rod pattern, the
14 power goes here.

15 VICE CHAIRMAN ABDEL-KHALIK: So let's look
16 at this dropped power, you've cut power down by 15
17 percent.

18 DR. SAHA: Correct.

19 VICE CHAIRMAN ABDEL-KHALIK: How much do
20 you cut the flow? How much of the flow decreased?

21 DR. SAHA: Recirc flow? Recirculation
22 flow?

23 VICE CHAIRMAN ABDEL-KHALIK: Right. DR.
24 SAHA: Very little, 2 or 3 percent.

25 VICE CHAIRMAN ABDEL-KHALIK: That's it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. SAHA: Yes. There is a table, 4.1-1
2 in NEDO 33338.

3 MR. WALLIS: Because if you'd shown it on
4 the other curve, it would be obvious --

5 MEMBER BANERJEE: It would have been
6 obvious.

7 MR. WALLIS: You've shown it in the other
8 picture, the curves are close together, and the flow
9 doesn't change much, although the power changes a lot.

10 VICE CHAIRMAN ABDEL-KHALIK: So from a
11 stability standpoint, the worst point is still hotter
12 than normal full power operating point.

13 DR. SAHA: Yes. I mean, this is from
14 stability point of view, this is worse than this. But
15 then this morning my colleague has shown you that even
16 for the worst, that regional oscillation, the decay
17 ratio is well below that acceptance criteria of .8.
18 Okay?

19 MR. WALLIS: So the only reason you want
20 to do this is so that you can maneuver without moving
21 the control rods so much.

22 DR. SAHA: Yes, this one. If I may
23 explain, so this is the normal ascension line. Okay?
24 This is where I have given this legend, that feedwater
25 temperature change only, and so this region here, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 can do both if you want. Okay? And this is typical.
2 Again, this is not hard and fast, and these are
3 naturally going through evolution. This is a typical
4 start up path. It could be that you come up up to a
5 point where you would like to say reduce power before
6 you maneuver the control rods. So you increase
7 feedwater temperature, you lower power, do your
8 maneuvering. Again, you go to another point, and
9 again you increase feedwater. You can come up to here
10 with your kind of best control rod pattern.

11 MR. WALLIS: The fuel or something, why
12 would you want to do that?

13 DR. SAHA: Yes. This is the operational
14 flexibility, and also easy on the fuel. So then once
15 you come here, then you just drop the temperature
16 again, basically close the valve to the seven
17 feedwater heater, and you come here.

18 VICE CHAIRMAN ABDEL-KHALIK: Normally,
19 during start up at low power, don't you bypass the
20 steam directly to the condenser?

21 DR. SAHA: Okay. Here what we're talking
22 about, what you were saying, said this morning, we
23 were talking about this type one oscillation, those
24 are at very low power, maybe only up to 2 percent
25 power. Here we are talking about all this thing we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would like to do, if necessary, at higher power, like
2 60 percent power and above.

3 MR. WALLIS: The turbine is not running.

4 DR. SAHA: The turbine is running. It is
5 generating electricity, yes. This is not a low power
6 situation. Low power would be way back --

7 MEMBER BANERJEE: What is the limit at
8 Point A? Is it fuel performance, or what limits you
9 to A?

10 DR. SAHA: There is no limit on Point A.
11 This is our normal --

12 MEMBER BANERJEE: Yes. I mean, why can't
13 -- if you extrapolate the line from Point C to A, to
14 the left-hand side.

15 DR. SAHA: Right.

16 MEMBER BANERJEE: And keep going up --

17 MR. WALLIS: You don't have a license to
18 do that.

19 MEMBER BANERJEE: It's called what? No,
20 I know.

21 PARTICIPANT: It's called an uprate, like
22 A Prime up there.

23 MEMBER BANERJEE: So it's a single power -
24 -

25 DR. SAHA: Just like operating reactors do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have --

2 MEMBER BANERJEE: It's the fuel, critical
3 power.

4 DR. SAHA: -- rod blocks, so here we just
5 show that, maybe 108 percent or something like that.

6 MEMBER BANERJEE: So A is limited by CPR.

7 MR. WALLIS: It's limited by your license
8 at the moment.

9 CHAIRMAN CORRADINI: Limited by your
10 license, and then if you want to argue that you can
11 make the MCPR, you can go up there. First you have to
12 build one before you go there.

13 MR. WALLIS: Why do you have to ask if you
14 can do this? You can obviously do it. But you have
15 to ask if you can do it, or you just do it?

16 CHAIRMAN CORRADINI: No, but there was --

17 MR. WALLIS: As long as you don't violate
18 any rule.

19 CHAIRMAN CORRADINI: Yes.

20 DR. SAHA: The question, of course, are
21 the safety - this is our -- and, as I said, this is
22 also -- we can also lower the temperature, so this is
23 now an operating domain.

24 CHAIRMAN CORRADINI: Somewhere in --

25 DR. SAHA: We did not have really an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operating domain.

2 CHAIRMAN CORRADINI: Somewhere in your
3 DCDs you made references a few times, and then in the
4 SER there are discussion about how this control was.
5 In fact, I was trying to understand what -- so this is
6 very helpful.

7 MS. CUBBAGE: No. This is new information
8 that came in this topical, will be officially
9 incorporated in DCD Rev 5.

10 CHAIRMAN CORRADINI: But I thought in
11 Chapter 4 there was some reference to feedwater
12 control.

13 MS. CUBBAGE: In our SE, we alluded to the
14 fact that this had been submitted, but we haven't
15 reviewed it yet.

16 CHAIRMAN CORRADINI: Okay.

17 MEMBER BLEY: The driving force for you to
18 figure this out is easier to control, or the rods are
19 easy enough to control. What was driving, why you
20 really want this --

21 DR. SAHA: As I said, driving thing was to
22 have another method of changing power.

23 MR. WALLIS: Why?

24 DR. SAHA: Why?

25 MR. WALLIS: What do you gain by doing it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. SAHA: As I said, yes, it is easier on
2 the fuel.

3 MR. WALLIS: It's easier on the fuel.

4 DR. SAHA: Easier on the fuel. Correct.

5 MEMBER ARMIJO: But you've got a very
6 resistant fuel, so unless you were thinking of going
7 to, let's say back to operational techniques to
8 prevent, let's say PCI failures, and reducing the cost
9 of your fuel, maybe it's cheaper to make it, what
10 other benefit is there?

11 DR. SAHA: We want to go to the zero fuel
12 failure as INPO's I think 2010 initiative, so that one
13 of the driving thing now for this.

14 MEMBER BLEY: Your recommendations would
15 be to use the feedwater control for minor changes and
16 maneuvering things to your license, to your customers.
17 Is that right?

18 DR. SAHA: Well --

19 MEMBER BLEY: Where they can.

20 DR. SAHA: Okay. At 100 percent power, if
21 they want to make some changes, slight changes, that
22 they can with the control rods. There's no problem.

23 MEMBER MAYNARD: I think there are some
24 potential safety benefits to this, too, besides just
25 being good for the fuel. It's good to have a way to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 make minor power changes without having to do rod
2 repositioning.

3 DR. SAHA: Right.

4 MEMBER MAYNARD: Not only for the fuel,
5 but also just for the core, any time you're
6 positioning control rods, now you're starting to move
7 flex around and things in there, and also, any time
8 you're having to reposition control rods, I believe
9 that this is less susceptible to human error than
10 control rod repositioning is. I'm not sure without
11 taking a better look at it, but I think there are some
12 potential safety reasons, in addition to just easier
13 on the fuel.

14 CHAIRMAN CORRADINI: It's not transparent.

15 MR. WALLIS: It's not transparent. You're
16 controlling with two hands, instead of with one, so it
17 may not be --

18 DR. SAHA: Let me clarify something. Oh,
19 you want to say something?

20 MR. MOEN: I'm Steve Moen. I worked with
21 the team that developed this. I think it was very
22 well stated over here that one of the big drivers for
23 this is to provide additional operating flexibility.
24 It gives the operators an extra knob that they can
25 turn to control the reactor.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The initial driver was to reduce the duty
2 on fuel, given that fuel still has -- experiences duty
3 failures on occasion. They're very, very low today,
4 but we wanted to reduce the possibility of that to the
5 absolute minimum. And what this does is it allows us
6 to bring the power down far enough, we can get out of
7 the region where we can have duty-related failures.

8 MR. MARQUINO: Steve, you may want to
9 clarify that's related to pattern exchange.

10 MEMBER SIEBER: It's big control rod
11 movements that give you PCI failures. This avoids
12 this. On the other hand, a commercial nuclear power
13 plant, when you start it up, at least I was in charge,
14 started up from the first day after fueling, and you
15 shut it down the day before you refuel the next time.
16 This would be okay, if we had nothing but nuclear
17 power plants, and some of the --

18 CHAIRMAN CORRADINI: I was going to say,
19 the thing that --

20 MEMBER SIEBER: They're the cheapest thing
21 out there, so they run them at 100 percent power all
22 the time, except when you have to do rod swaps.

23 DR. SAHA: Right.

24 MEMBER MAYNARD: There are times when you
25 have good stability issues, maybe totally unrelated to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 your plant, that you have to make a power reduction,
2 so the plants have restrictions on that. You may have
3 to come down to 90, 85 percent power, so --

4 MEMBER SIEBER: Or your transmission
5 system operator.

6 MR. UPTON: This is Hugh Upton, GEH. One
7 of the other considerations is that you have to do
8 control rod pattern change-outs during the cycle, so
9 this also allows you to do that without over-stressing
10 the fuel.

11 MEMBER SIEBER: Yes, you're still going to
12 put some stress on it. It's just not going to be as
13 much. You're moving the power around in the core.

14 MEMBER BANERJEE: You can also go to the
15 green region.

16 MR. WALLIS: Presumably, it's slightly
17 more unstable when you have -- you bring down your
18 boiling boundary?

19 DR. SAHA: Which one?

20 MR. WALLIS: Hotter feedwater is slightly
21 more unstable.

22 DR. SAHA: No, it is not.

23 MR. WALLIS: No?

24 DR. SAHA: Because if you see the
25 exuberant number versus sub-cooling number plain, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 see we already operate below that mean.

2 MR. WALLIS: You're below the mean.

3 DR. SAHA: Yes, we are below the mean. So
4 what happens --

5 CHAIRMAN CORRADINI: Even with a decrease
6 in the feedwater temperature?

7 DR. SAHA: Normally, we are already below
8 the mean. So what happens --

9 CHAIRMAN CORRADINI: If I want to stray
10 into the green region, I get towards the mean.

11 DR. SAHA: I heard, you were asking in the
12 red region, the hot region.

13 CHAIRMAN CORRADINI: He was talking about
14 green region.

15 PARTICIPANT: Must pick up now the other
16 feed heaters.

17 DR. SAHA: I didn't understand your
18 question.

19 MR. WALLIS: I was talking about the
20 effect on stability of going to Point C.

21 DR. SAHA: Yes, so that is the hot region.

22 MR. WALLIS: As opposed to A.

23 DR. SAHA: That's right. So he's talking
24 about hot region, so hot region, what is happening, we
25 are going below -- I mean, dropping the sub-cooling

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 number.

2 MR. WALLIS: Okay. Less sub-cooling,
3 which usually is bad.

4 DR. SAHA: You are already below the mean,
5 so we are more stable.

6 MR. WALLIS: Okay.

7 DR. SAHA: When we go to the green region,
8 the opposite happens. And we have analyzed that, and
9 our, again, maximum decay ratio value is well within
10 the acceptance criteria of .8.

11 VICE CHAIRMAN ABDEL-KHALIK: Now when you
12 change control rod patterns, let's say you're starting
13 at Point A, how would you go about doing that?

14 DR. SAHA: Okay. So what we do, we
15 basically first, we increase the feedwater
16 temperature, increase the feedwater temperature.

17 VICE CHAIRMAN ABDEL-KHALIK: Okay.

18 DR. SAHA: So we come down this way, right
19 here, say around 85 percent power, and then we do
20 whatever swapping we have to do. And then we go back
21 up again.

22 VICE CHAIRMAN ABDEL-KHALIK: But what
23 happens to power during that swap at Point C?

24 DR. SAHA: Well, here the power can, of
25 course, change a little bit when we are doing the

1 swapping. But once we go to the new pattern, new
2 control rod pattern, then we go up again here, by
3 throttling steam.

4 MR. WALLIS: So you think that having two
5 controls is easier --

6 DR. SAHA: Well, again, we have talked
7 naturally, regularly with our potential U.S.
8 customers.

9 MR. WALLIS: Actually, your procedures to
10 the operators might be more complicated.

11 DR. SAHA: Yes, let me answer that.

12 MEMBER SIEBER: That's true.

13 DR. SAHA: Let's me answer this. Yes, let
14 me answer this. We have talked regularly with our
15 potential U.S. customer, because they're a team from
16 that. And they would like to have the ESBWR as a base
17 load plant, so they would not like to use this feature
18 until the time of control rod exchange, which is maybe
19 once in a quarter. So they would like to operate
20 right here, as I think --

21 MR. WALLIS: As the fuel ages, they have
22 to move around a bit, don't they?

23 DR. SAHA: Yes.

24 MR. WALLIS: So they have to maneuver.

25 VICE CHAIRMAN ABDEL-KHALIK: If you did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 not have that flexibility, how would you do control
2 rod exchange?

3 DR. SAHA: Okay. That is -- see, again,
4 if he wants to add to it --

5 MEMBER MAYNARD: You put rods in further
6 than you need it, you swap them around, and then you
7 pull them back out.

8 PARTICIPANT: Right. Before it cools off
9 too much.

10 MR. MOEN: Steve Moen, GEH. With the fine
11 motion control rods, it gives us another knob that we
12 can move the control rods without impacting the fuel
13 too much. And there are some additional things that
14 are in the works to reduce the susceptibility of fuel
15 to fuel duty concerns. And, originally, we were
16 working with the SBWR at lower power levels, where we
17 weren't even approaching these thresholds where fuel
18 duty was a concern. But, fundamentally, control rod
19 motion is how the power was originally going to be
20 controlled. And, to a large extent, on day-to-day,
21 week-to-week operation, once an envelope is
22 established, I'll say the fuel duty envelope, the
23 plants will be able to move rods within that envelope
24 without impacting the fuel, or causing fuel duty
25 failures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Other questions?

2 MEMBER ARMIJO: What about the green
3 region, is that part of the domain that you're trying
4 to create?

5 DR. SAHA: Yes. We are creating this
6 entire domain so that, if necessary, we can even
7 operate here. But then, again, as I said, from
8 thermal efficiency point of view, A is definitely the
9 point that the plant would like to operate.

10 MEMBER ARMIJO: Okay. So the green is not
11 a more efficient regime.

12 DR. SAHA: No.

13 MEMBER BANERJEE: How much degradation is
14 there to go to that Point E there?

15 CHAIRMAN CORRADINI: Degradation of what?

16 DR. SAHA: Degradation in what?

17 MEMBER BANERJEE: Efficiency.

18 DR. SAHA: Yes. I cannot answer that.

19 MEMBER BANERJEE: So what is your thermal
20 efficiency at A?

21 DR. SAHA: At A, around --

22 MEMBER BANERJEE: Thirty-three percent?

23 DR. SAHA: -- 35 percent.

24 MEMBER BANERJEE: As high as 35?

25 DR. SAHA: You know, 4,500, say 15, 20

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 megawatt electric is what we are saying, but, again,
2 that number can change depending on the site
3 condition. So 15, 20 divided by 4,500 --

4 VICE CHAIRMAN ABDEL-KHALIK: Thirty-three
5 is what I -- so to get from Point A to Point E, you
6 cut down bleed steam to another heater.

7 DR. SAHA: No, we use the bypass. Can I
8 go back to that earlier line? No, we don't cut down
9 on all that. See, this line, there is no valves on
10 these lines, extraction lines, except for this line,
11 this is a special line. That has valve, but these do
12 not have any valve, so what we do to cool down the
13 feedwater temperature below normal, we, of course,
14 close the valves here. And then we open this valve,
15 which is a bypass valve. So this is the feedwater
16 that is coming, so some of it will go unheated. And
17 others will be heated by fifth and sixth heater.

18 VICE CHAIRMAN ABDEL-KHALIK: Oh, I see.

19 MR. WALLIS: So you're adding --

20 DR. SAHA: Here, the temperature will be
21 lower than --

22 CHAIRMAN CORRADINI: Bypass valve has
23 always been there? That's always been there in the
24 design?

25 DR. SAHA: Yes. What I understand, it was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 always there.

2 CHAIRMAN CORRADINI: I has an analyzed
3 accident path in case I have a feedwater cooling
4 event.

5 MEMBER ARMIJO: That was the question I
6 wanted to ask. If you're operating at Point C on your
7 domain, does that make a loss of feedwater heater
8 transient more severe on the --

9 DR. SAHA: I don't think so. We analyzed
10 those.

11 MEMBER ARMIJO: You have a bigger delta T.

12 DR. SAHA: When?

13 MR. MARQUINO: We did not change the
14 requirement that the BOP design doesn't impose more
15 than a 100 degree F delta T in the event of a failure.

16 MEMBER ARMIJO: Okay.

17 MR. MARQUINO: And we have analyzed the
18 loss of feedwater heater. Now the delta CPR is a
19 little bit worse at Point C with that same delta, but
20 we can accommodate it by adjusting the CPR operating
21 limit.

22 MEMBER BANERJEE: Come again?

23 MR. MARQUINO: If we have a higher delta,
24 we set a higher operating limit, and we avoid
25 transition boiling in that case, as well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Other questions?

2 Thank you.

3 DR. SAHA: Okay. My pleasure.

4 CHAIRMAN CORRADINI: So can I get comments
5 from the members about the two chapters today, because
6 I want to kind of summarize some stuff tonight. And
7 then we are going to look at accident analysis in
8 Chapter 15 and 21 tomorrow. Can I go around the
9 table, starting with Jack? Any issues that you want
10 me to make sure I don't forget?

11 MEMBER SIEBER: I didn't see either in my
12 -- doing my homework or reading today, any issues that
13 would gravely interfere with the progress issuing and
14 approving the DCD. There are a number of details that
15 need cleaning up, and I'm sure that the staff will
16 make sure that happens. The questions I had have been
17 answered.

18 CHAIRMAN CORRADINI: Tom.

19 MR. KRESS: Well, I agree with Jack. I
20 thought the staff was asking the right questions in
21 the SER and that's a good job. As far as particular
22 issues, personally, I hope the business of whether we
23 need isolation valves or not on the PCCS is resolved
24 to the way that we don't need them. I think that
25 increases the risk putting those on there. I don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know how you do that, because I can see staff's
2 problem with complying with the regulations.

3 I'm still not quite content with the
4 business of potential injection of nitrogen. I
5 suspect it's no longer a design basis, but it probably
6 ought to be part of the PRA, maybe. I, also, was
7 surprised at the amount of non-condensables we're
8 dealing with. I'm not sure yet why that's the case,
9 and I think we need to learn a little more about that.
10 And I also liked Sanjoy's question about whether
11 there's some coupling between the chimney and the core
12 that might induce either oscillations, or even fatigue
13 issues, thermal fatigues, so that's another one. And
14 Said's question about what sort of power gradients you
15 might get across a given chimney, I think we need to
16 know what that is, and see if it has any problems.
17 And I'm not sure I know enough about the detect and
18 suppress for regional oscillations, whether we've got
19 enough of the things that we can pick up regional
20 operations, to detect them and suppress them, so I'd
21 like to hear just a little more about what that system
22 is. So, basically, that's my issues.

23 CHAIRMAN CORRADINI: Otto.

24 MEMBER MAYNARD: I definitely agree with
25 Tom on the isolation valves. I think that's important

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to get resolved, and get resolved correctly. There
2 are mechanisms that even if it requires a waiver, or
3 exemption to the rules or regs, anyway, that would be
4 interesting to find out what the final outcome of that
5 is.

6 I think the staff is asking the right
7 questions. A number of the things that are of
8 interest to me are things that are not resolved yet,
9 but the staff is pursuing those, and I think that's
10 good.

11 There's a couple of things that, like the
12 vacuum breaker. There's not a lot of margin there as
13 far as on the size of the lift, but still, even if
14 it's three times more than what the acceptance
15 criteria is, you still have 40 hours or so before you
16 come close to exceeding something, so even though you
17 may not meet the 72 hours, there's still a lot of time
18 there, so I think probably all that can be balanced
19 out.

20 The debris and tube fouling I think is
21 still an important issue. And I think there's two
22 stages that we're going to address. I think, first of
23 all, the design has to be to minimize and keep it out
24 of there. I think when it comes to the COL stage, I
25 think that's going to be probably the key time to work

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with the licensee on exactly how -- what are they
2 going to do to make sure that the design criteria is
3 met. And that, also, what inspections. I still think
4 that over time some, I don't know, dust or whatever
5 may build up in the tube. There needs to be some type
6 of inspection to make sure that the heat exchangers
7 will still do their job. That's probably more at the
8 COL stage, than at this stage, but I do think that's
9 an important issue, too.

10 CHAIRMAN CORRADINI: Said.

11 VICE CHAIRMAN ABDEL-KHALIK: I guess I'm
12 concerned about the large number of open items. So
13 specific comments about Chapter 4 would be, I'd like
14 to see the analysis of this maximum heat up rate
15 during start up. I'd like to see the details of the
16 detect and suppress stability system. And if it is a
17 defense-in-depth feature, I'd like to know what the
18 operability requirements will be. I'd like to see the
19 details of the new full-scale GE 14E test results are.
20 And how those results sort of either support, or
21 refute the applicability of the JEXL correlation. I'd
22 like to see the details in support or otherwise, in
23 support of that one dimensionality of the flow within
24 the chimney cells given the large radial power
25 gradients in a super cell. I'd like to see the test

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 data on the flow induced vibrations, what the critical
2 locations are in the GE 14E bundle versus the GE 14.
3 I mean, there are some unsupported cantilevered length
4 for the parked length rod, which is a little longer
5 than what you have in the GE 14 bundle, and does that
6 change the location of -- the critical location from
7 a flow induced vibration standpoint.

8 For Chapter 6, I really would like to see
9 the details of the containment response calculations.
10 Some of the results just are counterintuitive. And,
11 particularly, the effect of the vent fans. And the
12 results with regard to the rate of the radiolytic
13 decomposition, how much gas is being produced by
14 radiolytic decomposition? The pressurizing
15 containment in the event of discharge of the
16 accumulator gas, this is something new, but if you do
17 a calculation, just the gas in those two accumulators
18 would increase the containment, the drywell pressure
19 by 11 PSI. And that's a significant change.

20 MS. CUBBAGE: I don't know if it came
21 across in the presentation, but there are -- the
22 shutoff valves are safety-related and automatically
23 actuated. GE can confirm that.

24 MR. MARQUINO: Right.

25 MR. KRESS: That would make it a PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 issue.

2 MS. CUBBAGE: Yes.

3 VICE CHAIRMAN ABDEL-KHALIK: So I guess
4 the point to be made is, there are a lot of detail
5 things that perhaps would be much more appropriate if
6 we generate a list of those detailed calculations, and
7 ask the thermal hydraulic subcommittee to just look at
8 that list of items, and see the details of the
9 calculations, rather than present them sort of in a
10 big picture presentation like we're seeing chapter-by-
11 chapter. Thank you.

12 CHAIRMAN CORRADINI: Bill.

13 MEMBER SHACK: I'll say if all these
14 questions are answered, I won't have any left. But I
15 think I would keep in perspective, one of the things
16 that I do like is that when you do these accidents,
17 you have so much margin under many of these accidents.
18 And as we go through all the unknowns here and the
19 details that we have left out, I don't think you want
20 to lose the picture that this actually is sort of an
21 interesting looking reactor, with ample margins in
22 many ways.

23 MEMBER ARMIJO: Yes. I think when you
24 don't have to talk about peak clad temperature during
25 a LOCA, that's a nice --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: How to apply Appendix K.

2 MEMBER ARMIJO: That's a significant
3 accomplishment, I think. Well, I don't want to. I
4 think they're doing the right thing. In the case of
5 the -- just on flow induced vibration experiments, I
6 think they're good to do. My expectation with a
7 shorter bundle, very low, much lower flow rates, that
8 there probably won't be a problem, but they could find
9 some surprises, and so doing the test is a good idea.

10 I'd like to learn more, hear more about
11 this issue of uniform strain versus ultimate strain.
12 To me, it's strange that we would be looking for a
13 uniform strain, applying that to a pellet clad
14 mechanical interaction problem, when really ultimate
15 strain adequately handles that, but I'll wait to see
16 some more on that.

17 I was happy to see finally that I
18 understand that GE does recommend hydrogen water
19 chemistry for the ESBWR, and that the design
20 certification will permit it without any amendment, so
21 that -- and the U.S. utilities who are the ESBWR are
22 going to use it. I don't believe that just material
23 selection, and materials fabrication controls alone
24 will protect these materials from IASEC, and even from
25 IGSEC. Even though they are better materials, I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the belt and suspender with a good environment, and
2 good materials, and good fabrication could potentially
3 make these a 60-year plant life materials. So I think
4 that's a good thing.

5 Control rod drive design, several
6 improvements have been made in the mechanical design
7 of the control rod drive. GEH is proposing to get the
8 control rod drop accident analysis removed. I think
9 there should be some sort of encouragement for
10 improving system designs so that -- but if you still
11 stick them with the analysis requirements, then
12 there's no incentive to improve the design, so I think
13 -- I'm hoping that the staff looks at that carefully,
14 and doesn't say yes, you improved the design, but
15 we're still going to make you do the same old stuff.
16 And I think that's all I have.

17 CHAIRMAN CORRADINI: Dennis.

18 MEMBER BLEY: Well, most of the things I
19 was concerned with have been mentioned, but I
20 personally -- and a couple of these things can wait
21 until the PRA, perhaps. But these things that can't
22 possibly happen are things that worry me a little.
23 And like the CRDMs, I want to understand those a
24 little better, and see what the PRA has to say about
25 it. The debris issue, kind of the same thing, but it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sounds like the staff is on track with chasing that.

2
3 I guess, I think I want to look at the GDC
4 56, and just the issue on the primary containment, and
5 maybe that's something we want to comment on
6 ourselves, it's important to understand real well.
7 And the other thing that can't possibly fail, that I
8 want to know more about, is these vacuum breakers.
9 And I think seeing the test report will help. In
10 addition, I want to see how it's handled in the PRA
11 later. It's probably fine for now, but at least when
12 we get to the PRA, I need to see what can't possibly
13 fail means. That's all.

14 MEMBER BANERJEE: I think that most of the
15 issues that are important have been mentioned. I
16 think, though, that what Said brought up was to make
17 a list of certain issues, which I think we'd like to
18 see more details about at a thermal hydraulic
19 subcommittee meeting. It would be useful, so we might
20 want to get together at some point and make a trial
21 list, and propose it, and see --

22 CHAIRMAN CORRADINI: Just to interject, I
23 think -- I was talking to Amy at a break. My thought
24 is that we could use this subcommittee, but
25 essentially stay with it so the full subcommittee can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hear about it, but get a meeting specifically on these
2 issues, because I think that if you add them up,
3 there'll be a few of these that all kind of come
4 within this construct of containment response, et
5 cetera.

6 MEMBER BANERJEE: Yes. The details,
7 particularly with regard to containment behavior,
8 that's a key thing here. And the coupling with --

9 CHAIRMAN CORRADINI: The core.

10 MEMBER BANERJEE: -- long-term cooling.

11 CHAIRMAN CORRADINI: Yes.

12 MEMBER BANERJEE: That needs to be
13 explored. And then there are side issues, like what
14 happens to debris, where does it go, does it foul,
15 what happens to the non-condensables. And that's also
16 related to what happens with these vacuum breakers,
17 what margins you have, do you have these fans, do you
18 really need them. So we need to see some details
19 here. This is very much an overview. C H A I R M A N
20 CORRADINI: Professor Wallis.

21 MR. WALLIS: Well, it's pretty well been
22 said. I'd like to reiterate what Tom said. I think
23 the staff did a very good job of asking these hundreds
24 of questions. And most of the questions are the kind
25 of questions that I think we would have asked.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Really, until we get the answers to some of these
2 questions, how does the GE 14E fuel behave when you do
3 these critical power tests, and what happens to the
4 high void fractions, and so on, we get those answers,
5 then we'll know better where we are. So there's a lot
6 that we're waiting for.

7 I agree that we should look at certain
8 things in more detail, actually look at the basic
9 analysis, maybe go back to a few topical reports. We
10 don't all need to do that, but one or two of us might
11 want to do that. Generally, we seem to be in good
12 shape. I'd really like to see some TRACE runs. That
13 hasn't been mentioned yet, but keeping promise that
14 TRACE is going to look at some of these key issues,
15 and I'd like to see how well they can do.

16 The thing that I felt most uncomfortable
17 about was the way the non-condensables get handled,
18 particularly after 72 hours. And I would hope that
19 it's a good enough reactor, you don't have to switch
20 on a lot of fans, and move around a huge amount of gas
21 in order to make it work after 72 hours. I don't
22 quite understand why that's necessary. That's the
23 issue that bothered me the most, was about this sudden
24 appearance of a lot of non-condensables, which I
25 thought had been sequestered in places where they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 didn't do any harm. I need to look at that some more.
2 But, generally, I think the staff has done a very good
3 job, and we need to see how GE responds to these open
4 items.

5 MEMBER BLEY: One last thing I forgot to
6 mention is, and maybe this is just something I need to
7 understand. I want to understand why the recombiner
8 issue is such a burden. What is it? I know we were
9 part of it, from what you said, but really understand
10 what all of the burden is, and why taking credit for
11 that is -- looks hard to do.

12 CHAIRMAN CORRADINI: I think Mike is not
13 here, so we have --

14 MS. CUBBAGE: He's right behind you.

15 CHAIRMAN CORRADINI: Can you give us some
16 thought?

17 MR. SNODDERLY: No. I thought, I just was
18 going --

19 (Laughter.)

20 MR. SNODDERLY: I think what can help us
21 in our review is -- because I think what we're asking
22 the Committee for right now is that the open items
23 that we've identified are correct. And if there's
24 something that we missed, let us know so that we can
25 determine if we need to, or how to proceed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now, how do we address GE has performed
2 their analyses, and they've explained how they
3 calculated those analyses. And then we showed that
4 we've done confirmatory analyses, that show that the
5 design pressure is correct. I think that there --
6 we're trying to address uncertainties, and we've seen
7 one place where there's uncertainty, is that there
8 could be a build-up of non-condensables in the PCCS.
9 There's a test program that shows that those non-
10 condensables would probably burp through, but there's
11 a chance that they could build up, and so we addressed
12 that by saying provide a mitigative feature, or
13 something that could do that. And they've done that
14 with this drywell gas mixing system. And I think that
15 it shows -- it provides greater margin. It has a
16 system that I can analyze better, and understand
17 better than a PARS system, that has, I believe, more
18 uncertainty, and provides greater margin. So I'm a
19 little -- I believe -- I don't want to let this
20 opportunity slip away while we're all here with the
21 people from GE, the Committee, so I want to really
22 make sure -- do we have a good enough understanding of
23 the non-condensables to make a regulatory decision?
24 I think so. And I think --

25 CHAIRMAN CORRADINI: You're asking us

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 today?

2 MR. SNODDERLY: Well, I'm trying to
3 determine where we go from here. To come back and to
4 say we have to have a better understanding of where
5 the non-condensables are, I think we've conservatively
6 bounded it. Right? The worst case is that the non-
7 condensables end up in the PCCS and affect its
8 performance.

9 MR. WALLIS: And you say you blow them out
10 with a fan? Is that the idea?

11 MR. SNODDERLY: Yes. And that --

12 mS. CUBBAGE: Recognize that the Committee
13 ---- we haven't seen those results yet. GE hasn't
14 provided them yet. We'll provide those results to you
15 as soon as they come in, and we'll talk about them
16 when we come back with the final SER, unless there's
17 some --

18 CHAIRMAN CORRADINI: So let me talk --
19 suggest a path forward, because I think in some sense
20 we covered a lot more of what I thought we'd be ending
21 up doing in 15 today because it's all related to
22 containment performance relative to ECCS, because we
23 didn't have core uncovering as one of the issues. But
24 a suggestion, I'll just go off with Said's point and
25 connect it with Sanjoy's, maybe the members want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 give me a list of things that apparently are details,
2 but then will drive a common theme. And we try to get
3 another day on what I'll call containment response,
4 and if I were to pick one topic that I definitely want
5 to start with, is that curve. That curve gets me a
6 little bit crazy.

7 MR. SNODDERLY: Which curve, Mike?

8 CHAIRMAN CORRADINI: I get very unsettled
9 when I turn on a fan at 72 hours to make things good
10 by 20 percent.

11 MS. CUBBAGE: I mean, the alternative is
12 you don't turn on the fan, and then the results were
13 questionable, and that's why the staff had questions.

14 CHAIRMAN CORRADINI: I understand that,
15 but I mean, just thinking out of the box, I'd rather
16 vent out of the wetwell through a HEPA filter than
17 turn on fans.

18 MEMBER BANERJEE: We're not doing a
19 brainstorm here.

20 CHAIRMAN CORRADINI: I understand.

21 MEMBER BANERJEE: Right now we really --

22 CHAIRMAN CORRADINI: But my point is, what
23 I would rather do is get together on a subcommittee
24 with a set of issues, and at least start off with, to
25 me, containment response as a starting point. But I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think there's other issues that you guys have brought
2 up relative to --

3 MEMBER BANERJEE: Stability needs to be
4 looked at.

5 CHAIRMAN CORRADINI: Well, I wrote it down
6 in terms of core chimney coupling, thermal hydraulic
7 coupling. But to get a series of these, and I'd like
8 to show them to the staff.

9 MS. CUBBAGE: Right.

10 CHAIRMAN CORRADINI: And see which ones
11 are at a point where you feel you can come back and
12 give us more detail, and which ones you're still
13 analyzing, waiting for GEH response.

14 MS. CUBBAGE: Absolutely. And I think --

15 CHAIRMAN CORRADINI: And then bundle them,
16 and then come back and have a subcommittee on that.

17 MR. WALLIS: I'd like to see the staff do
18 some independent analysis of these non-condensables so
19 that you really feel comfortable with that.

20 MR. SNODDERLY: And I think we can answer
21 that question now. We are. It's conservative.

22 MR. WALLIS: Happy with this four fan, and
23 six fan, and this mysterious huge amount you have to
24 pump around. That's okay?

25 MR. SNODDERLY: Yes, because the analyses

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 - the concern, Graham, the concern is the sensitivity
2 to the bypass leakage. That's what's unique here in
3 this design, and the absence of wetwell sprays. So
4 now bypass leakage is very important, and I think --
5 and what we tried to communicate to you today, is
6 that the confirmatory analyses show that that's where
7 the focus should be. And the non-condensable gases
8 are conservatively bounded, conservatively modeled in
9 the containment analysis, and the concern is their
10 effect on possibly degrading PCCS performance.

11 MR. WALLIS: You see these plants as
12 having to check their bypass leakage all the time with
13 some instrumentation and stuff to be sure that they
14 don't have more than a square centimeter?

15 MR. SNODDERLY: No more than what's done
16 now, which would be an as-found, and as-left during
17 the refueling outage.

18 MEMBER BANERJEE: So if the PCCS doesn't
19 work, there's other problems that occur, in terms of
20 getting water down to the GDCS system, long-term
21 cooling. It's all coupled. This is a very coupled
22 system, so you've got not just one thing to fix by
23 blowing -- if you can blow the non-condensables and
24 make sure the water goes back where it has to go,
25 that's fine. But we really need to take a close look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at this. I think what has happened is we've seen all
2 these results. Some people have done MELCOR, some
3 people have done TRACG, some people have done
4 something else. It all has to be put together and
5 brought to some order in our minds.

6 MR. SHUAIBI: Mike, if you don't mind, let
7 me suggest, I think the suggestion was that the
8 Committee was going to get together and come up with
9 a list of things that you're interested in seeing.
10 And maybe we could work through your staff, Gary
11 Hammer, and see what the best way to deal with those
12 items are. If it's getting you reports, we can do
13 that. If it's having another meeting, then that's
14 what needs to happen, and we can work on that.

15 CHAIRMAN CORRADINI: I think that might be
16 the most effective way, because some things you are
17 still analyzing, GEH is still doing calculations on.
18 Other things may be wrapped up in a way that with four
19 or five issues that seem disparate, all fit together
20 in some calculation with an audit calculation that we
21 could look at and kind of -- so it might occur in a
22 month, it might occur in two months. We're going to
23 have wait until other things you get, and look at.

24 MS. CUBBAGE: Right. And I can just tell
25 you from -- we can talk schedule later, but from a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 timing perspective, I think it would be a challenge to
2 come back before the end of March, just in light of
3 where the status of different issues and different
4 work load is.

5 CHAIRMAN CORRADINI: Thank you.

6 MEMBER MAYNARD: Something I think we need
7 to keep in mind here, because one of the things that
8 seemed to be confusing is the curve that shows then at
9 72 hours, all of a sudden we do something. And,
10 again, that's for regulatory purposes, and for the
11 analysis. In reality, that's not what's going to be
12 going on. They're not going to be setting there for
13 72 hours. I think we need to keep that in mind. We
14 may want somebody -- what we really expect to be going
15 on.

16 MEMBER BLEY: What's really going to
17 happen, analyze that.

18 MEMBER MAYNARD: I think we're getting a
19 little confused, and from a regulatory standpoint they
20 have to demonstrate that they can sit there basically
21 hands-off doing nothing for 72 hours. And if you do
22 that, yes, then at the end of 72 hours when you start
23 doing something, you have more of a need to do it than
24 if you've been doing it all along.

25 MEMBER BLEY: I think two things. I don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think any -- at least I didn't hear anybody on this
2 Committee say they really understood those curves of
3 what was happening in 72 hours, so that's one thing.
4 The other is something you just said, Mike, which kind
5 of -- I'm probably wrong on this, but I have to ask
6 the question. I would be more comfortable analyzing
7 the fan system and the recombiners, but chemical
8 engineers I've worked with probably would say just the
9 opposite. Do we have chemical engineers here looking
10 at that, or are we nukes, and EEs and MEs?

11 MEMBER BANERJEE: I'm a chemical engineer.

12 MEMBER BLEY: And you're not the one who
13 said you couldn't analyze the recombiners, or have as
14 much confidence --

15 MR. SNODDERLY: And I think, Dennis,
16 that's the last point I'll make, that part of what --
17 another challenge that we were looking at is,
18 something else isn't typical. We don't have a safety-
19 related active mixing system for the drywell. Okay?
20 So when you take that away, and then you say well,
21 we're going to look at four to six PARS, and say that
22 that's going to solve our non-condensable gas problem,
23 then it brings in something like chemical engineering
24 kind of problems about poisons, reliability, mixing,
25 and so the problem comes, what's the worst -- if I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 can't say for exactly where these non-condensables are
2 going to go, because I have a one node model. I'm
3 trying to bound this thing. What's the worst thing
4 that can happen? Well, I have a bounding amount of
5 non-condensables, and they end up in the PCCS. So I'm
6 going to say that if that happens, I can solve that
7 problem. That's why I think we're where we are today.

8 MR. KRESS: You think that's the simplest,
9 most direct.

10 MR. SNODDERLY: That's where -- making a
11 decision that I have to make --

12 MR. KRESS: You still have to say that
13 even if you had --

14 MR. SNODDERLY: Yes. Right. Because
15 otherwise they're going to come back, and have to
16 justify the mixing, and the absence of an --

17 MR. WALLIS: The whole design basis of the
18 PCCS is that the non-condensables don't end up in it.
19 It's been designed so they don't, so I'm still
20 concerned about --

21 MR. SNODDERLY: Well, if they don't, then
22 Steve is there, and it's removing heat.

23 MEMBER BANERJEE: All the experiments show
24 that they're clear, that there is a lot of evidence
25 which shows they're clear. So in a way, if that can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be pretty certain, then -- and we have to look at that
2 in a little bit more detail, I think. You may have
3 satisfied yourself, Mike, that there is sufficient
4 uncertainty that you want a backup system there.

5 MR. SNODDERLY: We haven't satisfied you,
6 and we need to do that. And as Mohammed said, let's
7 work out what GE can do to explain their analyses, and
8 what we can do to explain our confirmatory analyses.

9 VICE CHAIRMAN ABDEL-KHALIK: Just a point
10 of information, Mr. Chairman. Has GE transmitted the
11 results of their full-scale GE 14E testing to you?

12 MS. CUBBAGE: They have not. I heard
13 earlier end of --

14 VICE CHAIRMAN ABDEL-KHALIK: What is the
15 time line for that?

16 MS. CUBBAGE: -- March was probably a best
17 case.

18 MR. MOEN: Yes, end of March time frame.
19 Expect about the end of March.

20 CHAIRMAN CORRADINI: And the same for the
21 flow induced vibration test?

22 MR. MOEN: I'm not sure what the schedule
23 is for that. Steve Moen, GEH. I'm not sure what the
24 schedule is for the FIV testing. We're still working
25 that out with the staff, and, of course, internally.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: I don't think you're working
2 --- you may be waiting to inform us, but the schedule
3 is what you can deliver. Right?

4 CHAIRMAN CORRADINI: Okay.

5 MS. CUBBAGE: We're waiting for it.

6 CHAIRMAN CORRADINI: Any other comments by
7 the members? So at least one action I hear is that
8 I'm going to get from all of you individual comments,
9 such as Said I saw already has a list. And I'll
10 accumulate them, and with Gary work with Amy to see if
11 that's a way to start thinking how to bundle it to, if
12 you have -- if it's appropriate, and there's a point
13 where you want to come back, how we can do it to be
14 most efficient.

15 MS. CUBBAGE: Right. Because I think we
16 need to get through the rest of the chapters with the
17 SER with open items. Then we're going to be coming
18 with the final at the end. There will be a window in-
19 between where we can try to get some of these issues
20 in, so they don't just all get saved up to the end
21 when there's no time to resolve them.

22 MEMBER BANERJEE: My impression, though,
23 from Mike's talk, Mike here, Mike's exposition on the
24 mic - where is Mike? Is that he would like some sort
25 of clarity on this relatively soon. Is that what --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SNODDERLY: I didn't hear that.

2 MS. CUBBAGE: No. I think we've come to
3 an understanding that you need to hear more, so that
4 you get the same understanding level that the staff
5 has with the issue. And, also, we all need to see
6 these additional results that GEH is going to provide.

7 CHAIRMAN CORRADINI: Okay. Any other
8 comments? Well, it's past our normal -- so thank you.
9 We're recessed.

10 (Whereupon, the proceedings went off the
11 record at 7:14 p.m.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

CERTIFICATE


This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on
Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



Eric Hendrixson
Official Reporter
Neal R. Gross & Co., Inc.



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review

Chapter 21 of the Safety Evaluation Report
Testing and Computer Code Evaluation

January 16, 2008

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 21

Review Team for Chapter 21:

- Project Manager
 - Shawn Williams
- Lead and Supporting Reviewers
 - Ralph R. Landry
 - Veronica Wilson
 - Edward Throm
 - Shanlai Lu
 - Muhammad Razzaque
 - James Gilmer
 - Weidong Wang
 - Ben Parks
 - Peter Yarsky
 - Jose March-Leuba, Consultant – ORNL
 - Jay Spore – Consultant - ISL
 - Andre Drozd
 - Syed Haider
 - Allen Notafrancesco
 - Jack Tills - Consultant

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21

RAI Status Summary

- Original RAIs: 111
- RAIs Resolved: 77
- Open Items: 34



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review Chapter 21

Introduction Presented by
Ralph R. Landry
Senior Level Advisor
NRO/DSRA

January 17, 2008

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21

Outline of Presentation

- Applicable Regulations
- LOCA Open Items— W. Wang
- Transient Open Items – J. Gilmer
- Discussion Committee questions
 - Stability: Presented in Chapter 4
 - ATWS: Presented in Chapter 15

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 21

Summary of TRACG Review Activities

- Testing and Scaling accepted 2004
 - Summarized in Chapter 21 SER
- LOCA Applicability accepted 2004
 - 20 confirmatory items to be resolved at the certification stage
 - Addendum SER with Open Items provided to ACRS
- Stability Applicability accepted 2006
 - 7 confirmatory items to be resolved at the certification stage
 - Addendum SER with Open Items provided to ACRS
- ATWS Applicability under review
 - SER with open items provided to ACRS
- Transients (AOO/IE) Applicability under review
 - SER with open items provided to ACRS

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (LOCA)

Summary of Regulations and Other Review
Guidance

- 10 CFR 50.34/50.46
- SRP 6.3, "Emergency Core Cooling System"
- SRP Section 15.6.5 "Loss-of-coolant Accidents Resulting From Spectrum Of Postulated Piping Breaks within the Reactor Coolant Pressure Boundary"
- SRP Section 15.0.2 "Review of Transient and Accident Analysis Method"

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 21.6 (LOCA)

- TRACG applicability to ESBWR LOCA
 - GEH submitted LTR NEDC-33083P "TRACG Application for ESBWR" in 2002.
 - Staff reviewed and accepted the TRACG code for analyzing ESBWR LOCA with 20 confirmatory items to be resolved at the certification stage
 - GEH submitted documents to address these confirmatory items and staff produced "Addendum with Open Items to the Safety Evaluation of NEDC-33083P-A"

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (LOCA)

Confirmatory Items

- Item #1 – Phenomena Identification and Ranking Table (PIRT) for Long-Term Core Cooling
 - High elevation breaks MSLB and FWLB ranks:
 - GDCS capacity relative to RPV volume
 - PCCS capacity relative to decay heat
 - Low elevation breaks GDLB and BDLB ranks
 - Lower drywell volume versus elevation
 - Break flow and pressure drop through DPVs
 - Others are similar to MSLB and FWLB
 - Staff Evaluation
 - Long-term LOCA PIRT did not identify unreviewed phenomena
 - Staff accepts the PIRT

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (LOCA)

Confirmatory Items

- Item #4 - Update TRACG Model Description
 - GE submitted a list of the changes from TRACG02 to TRACG04
 - The following models improved the accuracy ESBWR LOCA analysis:
 - Entrainment model
 - Flow regime map
 - Fuel rod thermal conductivity
 - RAI 6.3-54 requests GEH to justify use of this model

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (LOCA)

Confirmatory Items

- Item #4 (continued) - Update TRACG Model Description
 - Staff concurs that following updated models have no impact on ESBWR LOCAs are:
 - 3-D neutron kinetics model
 - Quench front model
 - Hot rod model
 - Minimum film boiling temperature
 - Cladding perforation and oxidation models
 - Enhanced pump homologous curves
 - Improved Boron model

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (LOCA)

Confirmatory Items

- Item #12 - Address Power Transient Resulting from MSIV Closure
 - GEH stated that there is no significant power transient because of MSIV closure since the control rods are always inserted before the MSIVs close for all breaks.
 - Staff agrees with the GEH assessment and concurs that this is not an issue for the ESBWR LOCA.

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (LOCA)

Confirmatory Items

- Item #20 - Provide a list of changes to the ESBWR design since the review of NEDC-33083P-A
 - Changes affecting TRACG applicability
 - Core power: changed from 4000MW to 4500MW
 - RAI 21.6-75: confirm the applicability range of the GEH interfacial shear models.
 - ICS is now part of ECCS
 - Supplemental RAI 21.6-55: Staff requested additional information regarding the modeling of the IC, such as TRACG nodalization clarification and justification that the modeling of the IC heat removal capacity in the LOCA event is conservative

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 21.6 (LOCA)

Confirmatory Items

- Item #20 (continued) Provide a list of changes to the ESBWR design since the review of NEDC-33083P-A
 - Staff concurs that the following changes do not affect the TRACG applicability
 - Core shroud size and core lattice
 - Number of bundles and control rod drives
 - GDCCS pool and airspace location
 - PCCS units and capacity changed – diameter/pitch same as the tested
 - Pressure relief system - critical flow model is independent as the number of valves
 - FW control – assumed to be tripped in the beginning of the LOCA
 - Turbine bypass capacity
 - PCCS drain tanks removed – SBWR design and was accepted in the past

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (LOCA)

Confirmatory Items

- Item #10 The assumption of the loss of feedwater flow used by GEH is not conservative. (RAI 21.6-103)
- Item #11 Feedwater Heater Modeling
 - GEH added detailed modeling of the feedwater system currently under staff evaluation.
- Item #18 Uncertainty Analysis
 - (Discussed in Chapter 6.3)

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (LOCA)

Discussion/Committee Questions



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 21.6 (AOO's/IE's)

Presented by
NRO/DSRA/SRSB

January 17, 2008

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (AOO/IE)

Outline of Presentation

- Overview of TRACG Application to AOOs/IEs and regulatory requirements
- Open Items associated with the DCD review
- Review findings associated with the supporting topical reports

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (AOO/IE)

Summary of Regulations and other
Review Guidance

- SRP Section 15.0.2 (Review of Transient Accident and Analysis Methods)
- Regulatory Guide 1.203 (Transient and Accident Analysis Methods)
- NUREG/CR-5249 (CSAU for LOCA)

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (AOO/IE)

TRACG Application for AOO/IE

- Described in NEDE-33083P, Section 4,
and in RAI responses
- CSAU-Based Technical Evaluation
(14 steps)
- Staff Independent Calculations
 - TRACE/PARCS code package

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (AOO/IE)

Open Items

- Isolation Condenser Modeling
(RAI 21.6-55)
- PIRT Ranking of Parameters
(RAI 21.6-64)
- Lower Plenum Cold Water Mixing

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 21.6 (AOO/IE)


Discussion/Committee Questions

ESBWR - Overview DCD Chapter 4 - Reactor

Advisory Committee on Reactor Safeguards

Gerald Deaver
Russ Fawcett
Nayem Jahingir
Stephan Moen
Pradip Saha
John Sorensen
Jun Yang
January 16-17, 2008

GE Hitachi Nuclear Energy



Presentation Content

- Section 4.1 – Summary Description
- Section 4.2 – Fuel System Design
- Section 4.3 – Nuclear Design
- Section 4.4 – Thermal & Hydraulic Design
- Section 4.5 – Reactor Materials
- Section 4.6 – Functional Design of Reactivity Control System
- Summary

Section 4.1 – Summary Description


- Section 4.1 provides an overview description of the ESBWR reactor and provides a road map to the content of Chapter 4

Section 4.2 – Fuel System Design

- Section 4.2 Provides:
 - > Fuel Assembly and Control Rod Design Bases
 - > Fuel Assembly and Control Rod Description
 - > Fuel Assembly Design Evaluations
 - GSTRM analyses based on "worst case" or statistically bounding limits
 - Analysis operating conditions cover normal operation and postulated Anticipated Operational Occurrences (AOD)
 - > Control Rod Design Evaluations Demonstrate
 - Design meets stress, strain and cumulative fatigue criteria
 - Capability of insertion during all modes of plant operation
 - Mechanical compatibility with core and reactor internals
- The ESBWR Fuel System and Control Rod designs are similar to those utilized in currently operating BWRs with improvements based on BWR fleet operating experience


Section 4.2 – Fuel System Design

- Design Derived from GE14
 - > Proven Components
 - Exposures to 68000 MWD/MT
 - > Proven materials
 - > Fuel Design Basis and Testing Applies to ESBWR
- Differences
 - > Length reduced for dp
 - Increased fuel rod plenum
 - > PLR length reduced
 - > Spacer positions slightly altered



Section 4.2 – Fuel System Design

- The ESBWR Marathon control rod design is a derivative of the approved BWR/2 - /6 Marathon design
- Mechanical design margins are increased by design modification to accommodate B₄C swelling




Section 4.3 – Nuclear Design

- Section 4.3 Provides a description of:
 - > Nuclear Design Bases ...
 - Reactivity basis prevents uncontrolled positive reactivity excursion
 - Overpower bases for control of power distribution
 - > Nuclear Design Analytical Methods
 - Steady-State Nuclear Methods
 - Reactivity Coefficient Methods
 - Stability Methods
 - > Nuclear Design Evaluation
 - Negative reactivity feedback
 - Control requirements
 - Criticality during refueling
 - Power distribution
 - Stability




Section 4.3 – Nuclear Design

- 4500 MWth Rated Thermal Power
- 1132 Bundles
 - > RKM 240 Bundles
 - > ABWR 872 Bundles
- 269 Control Blades
- FMCRDs (Fine Motion Control Rod Drives)
 - > Fast Scram (good transient response)
 - > Redundant Insertion
 - > Reduced Fuel Duty (small notch size)
- Moderate Power Density (54.3 KW/L)
- N-Lattice (symmetric water gap)
 - > Same as ABWR
 - > Improvement in CSDM



Section 4.3 – Nuclear Design

- Power shapes consistent with fleet experience
- Standard control rod patterns




Section 4.4 – Thermal and Hydraulic Design

- Section 4.4 Provides Description of:
 - > Design Description
 - Natural Circulation reactor coolant system configuration
 - Power operating map (FW temperature control)
 - > Reactor Core Thermal & Hydraulic Design Bases
 - Assure adequate margin to specified acceptable fuel design limits during normal operation and AOO
 - > Reactor Core Thermal & Hydraulic Design Methods & Evaluations
 - Critical Power
 - Core Thermal-Hydraulics
- The ESBWR design is similar to operating BWRs except that recirculation pumps and associated piping are eliminated

Section 4.4 – Thermal and Hydraulic Design


Natural Circulation in ESBWR vs. BWR

Enhanced Natural Circulation




Section 4.4 – Thermal and Hydraulic Design

- As part of DCD review, a conservative set of GEXL14 correlation statistics was developed for GE14E fuel
- Full scale Critical Power and Pressure Drop test of GE14E was completed in November
- GEXL14 correlation statistics are confirmed conservative for GE14E



Section 4.6 - Functional Design of Reactivity Control System



Control Rod Drive System

Summary

- Chapter 4 Provides Description of the ESBWR Reactor, Including Design Bases, Design Features, Design Evaluation Methodology, Materials, and Performance Analyses.
- GEH is Working With the NRC Staff To Address Remaining Open Items





Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 4

January 16, 2008

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 4

Outline of Presentation

- Brief the Subcommittee on the staff's ongoing review of the ESBWR DCD application:
 - 4.2 "Fuel System Design"
 - 4.6 "Functional Design of Fine Motion Control Rod Drive System"
 - 4.3 "Nuclear Design"
 - 4.4 "Thermal Hydraulic Design"
 - 4D & 21.6 "Stability"
- Answer the Committee's questions

* 4.5 "Reactor Materials" Will not be part of today's presentation but technical reviewers are available to answer questions if required.

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4**

Review Team for Chapter 4

- Lead PM
 - Bruce Bavol
 - Amy Cabbage
- Lead Technical Reviewers
 - Paul Clifford
 - George Thomas
 - Dr. Peter Yarsky
 - James Gilmer
 - Dr. Weidong Wang
 - Dr. Jose March-Leuba, ORNL
 - Robert Davis
 - Nihar Ray

1/15/2008

3

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4**

Summary of Regulations and other Review
Guidance

- GDCs: 10, 11, 12, 13, 20, 25, 26, 27, 28

Guidance From:

- SRP Section 4.2
- SRP Section 4.3
- SRP Section 4.4
- SRP Section 4.6

1/15/2008

4

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4**

RAI Status Summary

- Original number of RAI's - 184
- Number of RAI's resolved - 150
- Number of Open Items - 34

1/15/2008

5



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 4.2
Fuel System Design

**Presented by
Paul Clifford
NRR/DSS**

January 16, 2008

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Fuel System Design**

ESBWR Fuel Design Criteria:

- Fuel assembly and fuel rod design requirements consistent with currently operating fuel designs.
- Control blade design requirements consistent with currently operating blade designs.

1/15/2008

7

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Fuel System Design**

Open Items with Fuel Design Criteria:

- Allowance for limited fuel centerline melting during Anticipated Operational Occurrences (AOOs).
- Fuel cladding strain capability.

1/15/2008

8

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Fuel System Design**

GE14E Fuel Assembly Design:

- Ongoing review of NEDC-33240P "GE14E Fuel Assembly Mechanical Design Report" and NEDC-33242P "GE 14 for ESBWR Fuel Rod Thermal-Mechanical Design Report".
 - FRAPCON-3 used to perform independent calculations to validate GE14E fuel rod design.
 - Audit of supporting GEH engineering calculations.
- Significant operating experience with nearly identical GE14 design.

1/15/2008

9

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Fuel System Design**

Open items with GE14E Fuel Assembly

- Awaiting flow-induced vibration test results.
- Fuel rod corrosion limits required.
- GSTRM Part 21 evaluation.
- Revision expected for each topical report.

1/15/2008

10

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Fuel System Design**

ESBWR Marathon Control Blade Design:

- Ongoing review of NEDE-33243P "ESBWR Marathon Control Rod Nuclear Design Report" and NEDE-33244P "ESBWR Marathon Control Rod Mechanical Design Report".
 - Audit of supporting GEH engineering calculations.
- Significant operating experience with nearly identical Marathon design.

1/15/2008

11

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Fuel System Design**

Open Items with Control Blade Design:

- B₄C swelling rate in question.
- Irradiated stainless steel properties in question.
- Operating experience identified potential design flaws.
- GEH has re-designed the ESBWR control blade design. Revision 01 for each topical report recently received.

1/15/2008

12

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Fuel System Design**

Summary:

- Multiple issues which have necessitated revisions to the ESBWR DCD and supporting topical reports.

1/15/2008

13

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Fuel System Design**

Discussion/Committee Questions

1/15/2008

14



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Fine Motion Control Rod Drive System (FMCRD) Design
Chapter 4.6

Presented by
George Thomas
NRO/DSRA/SRSB

January 16, 2008

ACRS Subcommittee Presentation ESBWR Design Certification Review FMCRD System Design

- FMCRD Design is similar to the ABWR Design approved in 1997
- Operating experience – In Japan, ABWRs have demonstrated the ability to build and operate the FMCRD system meeting the requirements of the safety analyses.
- Failure Modes and Effects Analysis (FMEA) performed for the ABWR is applied to the ESBWR

1/15/2008

16

DCD Open Items for FMRD System Design Section

- No issues with hardware
- Performance characteristics of the control rod drive system are explicitly credited in the Chapter 15 safety analyses. (RAIs 4.6-27 and 4.6-28)
- Control Rod Drop Accident analysis is an open item in Chapter 15 (RAI 4.6-23)

1/15/2008

17

ACRS Subcommittee Presentation ESBWR Design Certification Review FMCRD System Design

Discussion/Committee Questions

1/15/2008

18



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 4.3

Presented by
Dr. Peter Yarsky
NRO/DNRL/NGE1 and NRR/DSS/SNPB

January 16, 2008

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 4.3

SER Technical Topics of Interest

- NEDC-33179P "Gamma Thermometer System for LPRM Calibration and Power Shape Monitoring"
- NEDC-33239P "GE14 for ESBWR Nuclear Design Report"
- NEDC-33326P "GE14E for ESBWR Initial Core Nuclear Design Report"
- NEDO-33338 "ESBWR Feedwater Temperature Operating Domain Transient and Accident Analysis"

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4.3**

Significant Open Items

- In-core instrumentation (GDC 13)
 - Automated Fixed In-core Probes (AFIPs) to replace the Traversing In-core Probe (TIP) system in operating BWRs
- Neutronic Methods (GDC 10)
 - Applicability of historically determined methods uncertainties to the ESBWR

1/15/2008

21

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4.3**

Significant Open Items

- Plan for resolution:
 - Audit core monitoring software and methods
 - Apply appropriate conservatism where required to resolve methods related issues

1/15/2008

22

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4.3**

Initial Core

- Previously identified Chapter 4.3 COL Action Items are being addressed through initial core design topical reports (NEDC-33326P)
- Staff intends to resolve several of these items through RAIs for the new submittals

1/15/2008

23

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4.3**

Significant Design Changes and New Submittals

- Feedwater Temperature / Power Operating Domain (NEDO-33338P)
- Initial Core Nuclear Design (NEDC-33326P)

1/15/2008

24

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4.3**

Discussion/Committee Questions

1/15/2008

25



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 4.4 (Core Thermal and Hydraulic Design)

**Presented by
James Gilmer
NRO/DSRA/SRSB**

January 16, 2008

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4.4: Methods**

- Core Thermal and Hydraulic Design Methods
 - Proposed fuel is GE14E, a shortened version of the GE14 fuel currently used in the Operating Fleet
 - Core flow, pressure drop, and heat transfer analyses utilize TRACG methods
 - An OLMCPR penalty has been proposed to account for uncertainties (e.g. total core flow measurement, bundle power uncertainty)
 - Critical Power Correlation (GEXL14) based on approved method applied to Operating Fleet GE14 fuel
 - GEXL14 Correlation uncertainty based on ATLAS facility and STERN Laboratory test data of GE14 fuel for the full range of ESBWR conditions
 - GE14E specific tests conducted

1/15/2008

27

Significant Review Activities

- Critical Power Correlation, Uncertainty, and OLMCPR Development Topical Report (NEDC-33237P)
- Initial Core Transients Topical Report (NEDO-33337P)
- Feedwater Temperature Operating Domain Topical Report (NEDO-33338P)

1/15/2008

28

Current Open Items

- Critical Power testing for GE14E fuel
- High Void Fraction data
- CPR confirmatory studies with COBRAG
- Critical Power Uncertainty evaluation
- Determination of R-factor specific to GE14E fuel

1/15/2008

29

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 4.4: Methods

Summary:

- Staff finds the thermal-hydraulic methods described in DCD Rev. 3 acceptable for the ESBWR design
- GEXL Correlation uncertainty must be re-evaluated using the new GE14E test data.

1/15/2008

30

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4.4**

Discussion/Committee Questions

1/15/2008

31



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 4.D – Stability, and
Chapter 21.6 - TRACG Analysis Methods for ESBWR Stability

Presented by
Dr. Weidong Wang
Dr. Jose March-Leuba, ORNL
NRO/DNRL/NGE1 and NRO/DSRA/SRSB

January, 2008

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

Summary of Regulations and other Review

Guidance

- GDC 12 – Oscillations are either not possible or readily detected and suppressed
- GDC 10 – If oscillations develop, the Reactor Protection System prevents SAFDL violations
- Guidance from
 - SRP 15.9 “BWR Stability”
 - SRP 15.0.2 “Review of Transient and Accident Analysis Methods”

1/15/2008

33

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

SER Technical Topics of Interest

- The review of ESBWR stability has covered three general areas
 - Core stability
 - Channel, core-wide, and regional oscillations
 - Chimney stability
 - Density oscillations
 - Startup stability
 - Low pressure startup with nuclear heat
- All areas covered in the staff SER and presented to ACRS in 2006 during the TRACG review

1/15/2008

34

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

SER Technical Topics of Interest (Previously Issued)

- TRACG methods are documented in NEDE-33083PA, "TRACG Application for ESBWR," dated March 2005, which includes:
 - Large- and small-break LOCA
 - Containment analysis
 - AOO's
 - Stability (NEDE-33083PA Supplement 1)
 - ATWS (NEDE-33083PA Supplement 2)

1/15/2008

35

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

TRACG SER Technical Topics of Interest (cont)

- TRACG use was previously approved for ESBWR stability analysis with confirmatory items to be resolved at the certification stage.
 - Channel, core-wide, and regional decay ratio (DR) for steady-state operation
- TRACG not approved to calculate DRs during transients, but can be used for:
 - Demonstration of stability after AOOs
 - Demonstration of stability during startup, and determination of maximum startup heat up rate

1/15/2008

36

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

TRACG SER Technical Topics of Interest (cont)

- TRACG SER main stability conclusions:
 - TRACG is capable of predicting oscillatory behavior in reactor power and flow for ESBWR.
 - TRACG is capable of tracking a density wave.
 - TRACG's numerics will permit an oscillation to occur, and they will not cause it to occur.
 - TRACG stability procedure can calculate a decay ratio for steady state conditions
 - TRACG is able to predict oscillations during the startup trajectory for the early startup phases

1/15/2008

37

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

TRACG SER Technical Topics of Interest (cont)

- TRACG SER Conclusions are based on:
 - Review of TRACG physical models
 - Numerical-damping evaluation
 - Fine nodalization, including chimney
 - TRACG qualification, including
 - Natural circulation benchmarks (Dodewaard, CRIEPI-SIRIUS, PANDA)
 - Benchmarks of operating reactor stability events (Peach Bottom, Leibstadt, Forsmark, ...)
 - Confirmatory calculations
 - TRACG by the Staff, LAPUR

1/15/2008

38

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

Design Certification Topics of Interest

- TRACG results indicate that
 - ESBWR design is stable at nominal conditions
 - Regional instability mode is dominant
 - Decay ratio ~0.4 (CSAU)
 - Within acceptance criteria $DR < 0.8$
 - Chimney has small effect on stability.
 - No chimney flow oscillations predicted
 - Startup instabilities not expected at nominal heat up rate of 50 MW/hr

1/15/2008

39

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

SER Technical Topics of Interest (cont)

- GDC 12 is satisfied because instabilities are highly unlikely in ESBWR
 - Future ESBWR core loadings will guarantee GDC 12 compliance by calculation
- ESBWR provides defense in depth to comply with GDC 12 and 10 with a Detect and Suppress stability solution
 - DCD Rev 4 specifies the use of DSS/CD

1/15/2008

40

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

Significant Open Items

- TRACG input data issues
 - Physics data generation (cross section)
 - Dynamic gap conductance model
- Fuel-specific issues
 - GE14E for ESBWR (Chapter 4.2)
 - CPR (GEXL) correlation (Chapter 4.4)
- ATWS-Stability analysis not complete. RAIs issued
- Startup – constant Xenon assumption questioned

1/15/2008

41

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 4-D & 21.6 Stability**

Discussion/Committee Questions

1/15/2008


42

GEH Nuclear Energy

Chapter 4 GEH ESBWR Stability Evaluation

January 16, 2008

Dr. Jun Yang



Licensing Requirements

- General Design Criterion 10 (Reactor Design) requires that:
 - “specified acceptable fuel design limits are not exceeded during any condition of normal operation, including the effects of anticipated operational occurrences.”
- General Design Criterion 12 (Suppression of Reactor Power Oscillations) requires that:
 - “power oscillations which can result in conditions exceeding specified acceptable fuel design limits are not possible or can be reliably and readily detected and suppressed.”

ESBWR Stability Licensing Basis

- Based on TRACG stability analysis results, a high degree of confidence is established that oscillations will not occur by imposing conservative design criteria on the channel, core wide and regional decay ratios under all conditions of normal operation and anticipated transients.
- Further, the ESBWR will implement a Detect and Suppress Solution as a defense-in-depth system.

Types of Stability Analyses for ESBWR

- Coupled neutronic-thermal-hydraulic instabilities
 - Density-wave induced (Type 2)
 - Single-channel mode
 - In-phase Core-wide mode
 - Out-of-phase Regional mode
 - Condensation/Flashing induced (Type 1)
 - Flow oscillation during plant startup
- Xenon Transients


Limiting DR Results under Rated Condition

	Core-wide DR	Hot Channel DR	Regional DR
Acceptance Criteria	0.8	0.8	0.8
Equilibrium Core	0.41	0.25	0.53
Initial Core	0.28	0.16	0.43

- Additional analysis was conducted at small exposure increments through the cycle in order to make sure that the worst exposure level in terms of Stability is captured. It is determined that the limiting exposure is at the Peak Hot Excess (PHE) cycle point for both equilibrium core and initial core.

Preliminary Information under GEH Verification

Limiting Conditions for AOO Stability



DR Results for Limiting AOOs

	Regional DR
Acceptance Criteria	0.8
Equilibrium Core, LOFWH, (100% Power, 420F FW Temp)	0.66
Equilibrium Core, LOFW, (100% Power, 420F FW Temp)	0.58

- As the feedwater temperature drops during LOFWH, power increases gradually. SRI/SCRRI (Select Rod Insert/Selected Control Rod Run-In) is initiated automatically upon the detection of FW temperature reduction of 30°F or higher during AOOs and limits the power increase. Therefore, the stability during AOOs is assured by SRI/SCRRI and the scram protection.
- Adequate margin is maintained to the stability design criteria during AOOs.

Preliminary Information under GEH Verification

ESBWR Plant Startup Stability Summary

- TRACG calculates small flow oscillations when voiding begins in the separators
 - During this phase,
 - Core flow is single phase
 - No oscillations in neutron flux
 - Large thermal margins (CPR >20)
 - Stable void fraction established in separators and chimney
- Smooth ascension to rated pressure and power
- Startup flow oscillations pose no threat to any thermal limits

Conclusion

- TRACG04 is approved by NRC for licensing analysis of ESBWR stability margins during normal operation and anticipated transients
- Based on TRACG analysis, it is demonstrated that ESBWR meets the stability design criteria and compliance with GDC 10 and 12 is assured.

21.6 NEDE-33083P, SUPPLEMENT 1 SER Confirmatory Items

1, 2 & 3. Physics Parameters, Fuel design, Critical Power Correlation

- No change from Fuel Design & Physics uncertainty parameters from SER,
- Stability results are insensitive to CPR correlation

4. Stability during Anticipated Transient without Scram

GEH provided documentation that ESBWR is stable (No limit cycle oscillations) during ATWS


21.6 NEDE-33083P, SUPPLEMENT 1 SER Confirmatory Items (cont'd)

- Detect & Suppress Function – Defense in Depth**
ESBWR employs an LPRM based function which assures clad damage is avoided. Additional design detail on the DSS function is being provided.
- Startup Stability**
GEH provided documentation that ESBWR is stable during startup. Additional evaluations are in progress for power levels above the TS heat-up rates, and with peaking which conservatively bounds Xe transients.
- Gap Conductance**
GEH is employing the approved GESTR gap conductance model, and the PRIME pellet conductance model, which produces a conductance similar results to the GESTR pellet conductance.

ESBWR - Overview
DCD Chapter 6
Engineered Safety Features

Advisory Committee
on Reactor Safeguards

Jerry Deaver
Brian Frew
Chester Cheung
January 16-17, 2008



GE Hitachi Nuclear Energy

Presentation Content

- Section 6.1 – Engineered Safety Features Materials
- Section 6.6 – Preservice and Inservice Inspection and Testing of Class 2 and 3 Components and Piping
- Section 6.2 – Containment Systems
- Section 6.3 – Emergency Core Cooling Systems
- Summary

Section 6.1 – Engineered Safety Features Materials

- Section 6.1 Provides Description Of:
 - > Material Selection to Ensure That Material Interactions Do Not Occur That Can Potentially Impair Operation of Engineered Safety Features
 - > Material Selection (Metallic and Organic) to Withstand the Environmental Conditions Encountered During Normal Operation and Postulated Accidents
- The ESBWR Incorporates Materials Similar to Those Utilized in Past BWR Designs With Improvements Based on BWR Fleet Operating Experience.


Section 6.6 – Preservice and Inservice Inspection and Testing of Class 2 and 3 Components and Piping

- Section 6.6 Provides Description Of:
 - > Class 2 and 3 System Boundaries
 - > Accessibility Requirements To Facilitate Preservice and Inservice Inspection and Testing
 - > Examination Categories and Methods
 - > Inspection Intervals
 - > Evaluation of Examination Results
 - > System Pressure Tests
 - > Augmented Inservice Inspections
 - > Code Exemptions and Code Cases
 - > Plant Specific Program Information
 - > COL Information

Section 6.2 – Containment Systems


- Section 6.2 Provides Description Of:
 - > Containment Systems Functional Design Features
 - Pressure Suppression Containment System, Including Drywell (DW), Wetwell (WW), Passive Containment Cooling System (PCCS), Containment Isolation, and Supporting Systems
 - > Containment Systems Performance Analyses
 - Containment Pressure and Temperature Nominal and Bounding Analyses
 - Negative Pressure Evaluation
- The ESBWR Incorporates Pressure Suppression Containment System Similar to Those Utilized in Past BWR Designs With Passive Cooling and Improvements Based on BWR Fleet Operating Experience

Section 6.2 – Containment Systems



Containment System





Section 6.2 - Cont. Performance Analyses (continued)

Section 6.3 - Emergency Core Cooling Systems

Section 6.3 Provides Description Of:

- > Emergency Core Cooling Systems Functional Design Features
- Passive Gravity-Driven Cooling System Injection
- Passive Isolation Condenser System Injection
- Passive Standby Liquid Control System Injection
- Automatic Depressurization System Using Depressurization Valves
- > Emergency Core Cooling Systems Performance Analyses
- Reactor Pressure Vessel Level Analyses Verify No Core Uncovery
- Short-Term and Long-Term Core Cooling Analyses
- The ESBWR Incorporates Passive Emergency Core Cooling Systems Considering BWR Fleet Operating Experience Providing Significant Core Cooling Capability

Section 6.2 - Cont. Performance Analyses (continued)


- Conservative Models used to maximize the long-term containment pressure
- All non-condensable gases purged to wetwell (WW)
- No mixing allowed in suppression pool
- No mixing allowed in WW gas space
- Drywell to Wetwell bypass leakage area assumed
- Design basis: 1 cm² (A/V)kl
- Leakage rate to be assured by drywell to wetwell bypass leakage test
- MSL break produced maximum DW pressure (0-72 hrs) (18.9% margin)
- Nominal calculation: Max. DW Press.=354.8 kPa
- Bounding calculation: Max. DW Press.=384.6 kPa (9.3% margin)

Section 6.2 - Cont. Performance Analyses (continued)

Systems credited in performance analyses

Time after break	Systems credited	Containment responses
0 - 3 (days)	IC/FCC pool makeup; PCCS; ADS; GDCS; SLCs liquid inventory; Drywell gas recirculation fans; Passive Autocatalytic Recombiners (PARS); FAPCS/RWCU (Defense-in-Depth)	DW pressure reaches rapid reduction and continued control of DW pressure, well below design value
3 + (days)	IC/FCC pool makeup; PCCS; ADS; GDCS; SLCs liquid inventory; Drywell gas recirculation fans; Passive Autocatalytic Recombiners (PARS); FAPCS/RWCU (Defense-in-Depth)	DW pressure reaches rapid reduction and continued control of DW pressure, well below design value





Drywell gas recirculation fans take suction from FCC vent line, and discharge the non-condensable gases to GDCS gas space.



Section 6.2 - Containment Systems

Section 6.2 - Containment Performance Analyses

- Evaluation Model
 - > TRACG code application for ESBWR containment performance
 - had been reviewed and accepted by ACRS (2/2004)
 - > Additional studies were performed to address the SCR conformity items, design changes and nodalization changes
- Containment Systems Performance Analyses
 - > Containment Pressure and Temperature for Nominal and Bounding Analyses
 - > Negative Pressure Evaluation
- Representative spectrum of guillotine breaks
 - > Feedwater Line (FWL), GDCS Line (GDL), Bottom Drain Line (BDL)
 - > Main Steam Line (MSL)



Section 6.3 – ECCS Performance Analyses

- Evaluation Model
 - > TRACG code: application for ESBWR ECCS performance had been reviewed and accepted by ACRS (2/2004)
 - > Additional studies were performed to address the SER confirmatory items, design and nodalization changes
- ECCS Performance Analyses
 - > Same TRACG nodalization as that used for containment analyses
 - > Short-Term (0-2000 sec.) and Long-Term Core Cooling Analyses
 - > Reactor Pressure Vessel Level Analyses Verify No Core Uncovery and No Fuel Heatup

Section 6.3 – ECCS Performance Analyses (continued)

- Short-term (0-2000 sec) analyses
 - > Nominal calculations
 - Break spectrum: all 9 RPV penetrations analyzed with 3 single failures
 - Main Steam Line, Feedwater Line, GDCC Injection Line, and Bottom Drain Line (DCD Section 6.3)
 - DPV stub tube, SDC suction line, IC return line, GDCC equalization line (RAI 6.3-46)
 - SLCC injection line (RAI 6.3-65)
 - Minimum chimney static head = 8.90 m, or 1.5 m measured from the Top of Active Fuel (TAF)
 - Chimney static head increases shortly after GDCC injection
 - Limiting break locations (Main Steam Line and GDCC Injection Line) selected for bounding calculations
 - > Bounding calculations
 - Limiting case: GDCC Injection Line break with 1 injection valve failure
 - Minimum chimney static head = 8.61 m, or greater than 1 m measured from the Top of Active Fuel (TAF)



Section 6.3 – ECCS Performance Analyses (continued)

- Long-term (0-72 hrs) analyses
 - > Containment performance analyses performed for DCD 6.2 demonstrate chimney static head at greater than 8.5 m (1 m above TAF) for a period of 72 hrs
- Beyond 72 hrs evaluation (response to RAI 6.3-79)
 - > GDCS line and bottom drain line breaks evaluated (break elevation less than 13 m)
 - > Other breaks evaluated (break elevation greater than 13 m)
 - > RPV level remains at greater than 8.5 m (1 m above TAF) for a period of 30 days
- All long-term analyses demonstrate RPV level remains at least 1 m above TAF

Summary

- Chapter 6 Provides Description of ESBWR Engineered Safety Features, Including Materials, Inspection and Testing Requirements, Design Features, and Performance Analyses
- GEH Is Working With the NRC Staff To Address Remaining Open Items





Presentation to the ACRS Subcommittee

ESBWR Design Certification Review

Chapter 6 Engineered Safety Features

January 16, 2008

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 6

Review Team for Chapter 6:

- Project Manager
 - Shawn Williams
- Lead Technical Reviewers
 - 6.1.1: Robert Davis
 - 6.1.2: Yamir Diaz-Castillo
 - 6.2.1, 6.2.1.1.C, 6.2.1.2, 6.2.1.3: Harry Wagage
 - 6.2.2: Andrzej Drozd
 - 6.2.3: Edwin Forrest
 - 6.2.4, 6.2.5, 6.2.6: Raj Goel
 - 6.2.7: Nihar Ray
 - 6.3: George Thomas, Weidong Wang, Veronica Wilson
 - 6.4: Edwin Forrest
 - 6.5: Jay Lee
 - 6.6: Robert Davis

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6**

Outline of Presentation

- RAI Status
- Significant Open Issues SER 6.1/6.6
- Significant Open Issues SER 6.2
- Significant Open Issues SER 6.3
- Discussion/Committee Questions

*Chapter 6.4 was discussed at the November 15, 2007, ACRS SC Meeting

*Chapter 6.5 will be discussed with Chapter 15.4 on January 17, 2008

3

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6**

RAI Status Summary

- Original RAIs: 306
- RAIs resolved: 215
- Open Items: 91

4



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 6.1, "Engineered Safety Feature Materials"
Chapter 6.6, "Preservice and Inservice Inspection and
Testing of Class 2 and 3 components and Piping"

**Presented by
NRO/DE/CIB2**

January 16, 2008

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 6 – SER Section 6.1.1

Engineered Safety Feature (ESF) Materials

- ESF materials were found to comply with the requirements of ASME Code, Section III
- Fabrication of ESF components comply with the requirements of ASME Section III
- Materials and processing of stainless steels conform with the guidance in NUREG-0313, Rev. 2 and RG 1.44
- Cleaning and cleanliness controls conform with the guidance of RG 1.37

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6 – SER Section 6.1.1**

Open Items

- Isolation condenser material specifications, fabrication and processing of Alloy 600 tubing
- PCCS heat exchanger material specifications, fabrication and processing of 304L tubing

7

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6 – SER Section 6.6**

Preservice and Inservice Inspection of ASME Code
Class 2 and 3 Components

- With the exception of Open Items, PSI and ISI of Class 2 and 3 systems were found to comply with the requirements of 10 CFR 50.55a and ASME Code, Section XI
- Development of the preservice inspection (PSI) and inservice inspection (ISI) programs is the responsibility of the COL Holder
- All items within the Class 2 and 3 boundaries are designed to provide access for the examinations required by IWC-2500 and IWD-2500

8

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6 – SER Section 6.6**

Augmented Examinations

- Augmented ISI to protect against postulated piping failure between the containment isolation valves will be performed as described in SRP Section 6.6
- Augmented inspections as described in GL 89-08, to detect and monitor potential wall thinning of high-energy piping by erosion/corrosion will be implemented. Inspections will include all susceptible ASME Code Class 1, 2, 3, and non-code class piping

9

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6 – SER Section 6.6**

Open Items

- ISI of austenitic and dissimilar metal welds and proposed use of radiography
- Inspection of IC and PCCS heat exchangers

COL Action Items

- The COL applicant will provide a description of the PSI/ISI programs for Class 2 and 3 components and piping. The COL applicant will also provide a milestone for full program implementation.

10

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6 – SER Section 6.1 and 6.6**

Discussion/Committee Questions

11



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 6.2

**Presented by
NRO/DSRA/SBCV**

January 16, 2008

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
SER Section 6.2 Containment Systems**

<u>SER Section</u>	<u>Reviewer</u>
6.2.1 Containment Functional Design	Henry Wagage
6.2.2 Passive Containment Cooling System	Andrzej Drozd
6.2.4 Containment Isolation System	Raj Goel
6.2.5 Combustible Gas Control in Containment	Raj Goel

13

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 6.2.1 Containment Functional Design and
Section 6.2.2 Passive Containment Cooling System**

Design Features

- Drywell and wetwell
- Drywell to wetwell flow paths: vertical/horizontal vents, PCCS vents, SRV discharge lines, and vacuum breakers.

Significant Open Items

- Containment subcompartment analysis (RAI 6.2-23)
- Containment debris protection for ECCS strainers (RAI 6.2-6)
- Amount of unqualified coatings inside containment (RAI 6.1-16)
- Meeting GDC 50—Containment design basis (RAI 6.2-140)
- Drywell to wetwell bypass leakage (RAI 6.2-145)
- Meeting GDC 38—Containment heat removal (RAI 6.2-139)

14




Figure 1. A schematic of ESBWR containment (DCD Figure 6.2-15)




Figure 2. MELCOR predicted ESBWR drywell pressure: sensitivity to bypass leakage w/o PCC pool refill

Section 6.2.1 Containment Functional Design

Table 1. Drywell to Wetwell Bypass Leakage (A/\sqrt{K}) for Different BWRs

Type	Wetwell Free Gas Space Volume (ft ³)	Design Leakage		Surveillance Test Leakage Acceptance Criteria		Comment
		Value (cm ² (A/\sqrt{K}))	Reference	Value (cm ² (A/\sqrt{K}))	Reference	
Mark I (Dresden 2)	112,800	167	SR 3.6.1.1.2	3.3	SR 3.6.1.1.2	Test criterion is 2% of the design value.
Mark II (Susquehanna 1)	148,590	49.7	FSAR Table 6.2-25	4.97	SR 3.6.1.1.2	Test criterion is 10% of the design value.
Mark III (Grand Gulf 1)	1,400,000	836	UFSAR Section 6.2.1.1.5.7	83.6	SR 3.6.5.1.1	Test criterion is 10% of the design value.
ABWR	210,500	5	DCD Section 6.2.1.1.5.3	5	DCD Section 6.2.1.1.5.7	The bypass leakage w/ sprays is 50 cm ² (A/\sqrt{K}) (DCD Section 6.2.1.1.5.4).
ESBWR	191,800	1	DCD Section 6.2.1.1.5.1	2	DCD Section 6.2.1.1.5.4.3	Proposed test criterion is 200% of the assumed design value.

17

Section 6.2.1 Containment Functional Design




Figure 3. Main steam line break (bounding case) containment pressures (DCD Figure 6.2-14a1)

18

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 6.2.4 Containment Isolation System**

Design Features

- Permits the normal or post-accident passage of fluids through the containment boundary, while protecting against release of fission products to the environment

Significant Open Items

- Need to justify not including PCCS isolation valves as required by GDC 56 (RG 1.141, ANS-56.2/ANSI N271-1976) (RAI 6.2-102)

19

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Section 6.2.5 Combustible Gas Control in Containment**

Design Features

- Containment inerting system
- Flammability control system (PARs) (DCD Rev. 4)
- Containment atmosphere monitoring
- Containment structural integrity
- Post-accident radiolytic oxygen generation

Significant Open Items

- Need to add oxygen concentration verification to Technical Specifications (presently in availability controls manual) (RAI 16.2-110)

20

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6 – SER Section 6.2**

Discussion/Committee Questions

21



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 6.3

**Presented by
NRO/SRSB**

January 16, 2008

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Outline of Presentation

- Applicable Regulations
- SER Technical Topics of Interest
- Significant Open Items
- Discussion / Committee Questions

23

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Summary of Regulations and Other Review Guidance

- GDCs 35, 36, 37
- 10 CFR 50.46 and Appendix K to 10 CFR 50
- SRP Section 6.3, "Emergency Core Cooling System"
- SRP Section 15.6.5 "Loss-of-Coolant Accidents resulting from Spectrum of Postulated Piping Breaks Within the reactor Coolant Pressure Boundary"
- SRP Section 15.0.2 "Review of Transient and Accident Analysis Method"

24

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

ECCS

- Automatic Depressurization System (SRVs and DPVs)
- Safety Relief Valves (SRV)
 - (Discussed at previous ACRS Meeting)
- Isolation Condenser System (ICS)
 - (Discussed at previous ACRS Meeting)
- Standby Liquid Control System (SLCS)
 - (Discussed at previous ACRS Meeting)
- Gravity Driven Cooling System (GDCCS)

25

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

DPV

- Depressurization Valve (DPV)
 - Squib actuated valves were tested
 - The test report is under staff review

26

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

GDCS

- Check valve design was changed from biased open to normally open
- Check valve design is an open item (RAI 6.3-78)
- GDCS Open items (ITAAC related):
 - As-built nozzle throat length should be verified against TRACG input (RAI 14.3-307)
 - Flow loss coefficient needs to be verified by test against TRACG input. (RAI 14.3-189)

27

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Staff verified all RPV penetrations and accepts GEH's 8 break locations with evaluation of limiting single failures:

- (1) Main Steam Line (MSL)
- (2) Gravity Driven Cooling System Line (GDL)
- (3) Bottom Drain Line (BDL)
- (4) Feed Water Line (FWL)
- (5) Isolation Condenser System Return (ICR)
- (6) Depressurization Valve (DPV)
- (7) Equalizing Line (EQL)
- (8) Shut Down Cooling Line (SDC)

Open Item (RAI 6.3-65):

Staff requested GEH to perform SLC line break

28

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Single Failure Selection

- 10 CFR 50.46 requires ECCS function accomplished with a single failure
- Staff found that GE has considered all of the credible single failures in their analyses of design bases LOCA events
 - Staff evaluated failures with GDCS valve, ADS, SLCS, ICS, vacuum breaker, bottom drain line isolation, CRD hydraulic control unit
 - 1 GDCS valve, 1 SRV, or 1 DPV single failure was selected for LOCA analysis
- Single failure open items:
 - When vacuum breaker fails to close, an isolation valve will be used. (RAI 6.3-63)
 - GDCS check valve failure consequences (RAI 6.3-78)

29

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Evaluation Model Parameters and Assumptions

- Bounding calculation used rated power +2%
 - Consistent with SRP 15.6.5
- Maximum linear heat generation rate
 - Consistent with the design limits report
- Axial power shapes
 - Since no core uncover, less important
- Initial stored energy
 - RAI 6.3-54 asks GEH to justify using fuel thermal conductivity model
- Control rod insertion
 - Factored into the decay heat curve

30

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Summary of ECCS-LOCA Analyses

- All calculations show that core remains covered with water
 - 1.447m above top of active fuel
- Main steam line break and gravity driven line break are most limiting
 - lowest minimum chimney water level
 - bounding conditions are applied to these two cases
- Open item (RAI 6.4-46)
 - explain why isolation condenser return (ICR) line break is not listed as the most limiting

31

Minimum Chimney Static Head Level above Vessel Zero per Active Single Failure			
Parameter Break Size, m ² (ft ²)	1DPV m (ft)	1GDGS INJ m (ft)	1SRV m (ft)
Nominal Condition			
EQL 0.002026(0.02181)	9.47 (31.08)	9.26 (30.36)	9.37 (30.75)
DPV 0.08320 (0.8956)	8.97 (29.42)	9.21 (30.20)	9.22 (30.25)
SDC 0.06558 (0.7059)	9.52 (31.22)	9.16 (30.05)	9.47 (31.06)
ICR* 0.01824 (0.1963)	9.34 (30.65)	9.00 (29.54)	9.24 (30.32)
MSL 0.09832 (1.058)	8.90 (29.20)	9.15 (30.02)	9.00 (29.53)
FWL 0.07420 (0.7986)	9.34 (30.64)	9.48 (31.10)	9.48 (31.10)
GDL 0.004561 (0.04910)	9.34 (30.64)	9.08 (29.77)	9.24 (30.31)
BDL 0.004052 (0.04361)	9.46 (31.02)	9.30 (30.52)	9.45 (31.00)
Bounding Condition			
MSL 0.09832 (1.058)	9.31 (30.54)	9.37 (30.74)	9.49 (31.14)
GDL 0.004561 (0.04910)	8.94 (29.34)	8.61 (28.25)	8.81 (28.89)

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Significant Open Items

- RAI 6.3-81 requests that GEH demonstrate how the LOCA analyses comply with 10 CFR 50.46(a)(1) (i) or (ii).
 - 10CFR 50.46(a)(1)(i) states in part that “Comparisons to applicable experimental data must be made and uncertainties in the analysis method and inputs must be identified and assessed so that the uncertainty in the calculated results can be estimated”.
 - 50.46(a)(1)(ii) states: “Alternatively, an ECCS evaluation model may be developed in conformance with the required and acceptable features of appendix K ECCS Evaluation Models.”
- Long-term cooling calculations showed that the core remains covered up to 12 hours. Staff is requesting GEH to show the results up to 72 hours. (RAI 6.3-64)

33

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Significant Open Items

- In RAI 6.3-46 response, GE performed sensitivity study of GDLB. Staff requested clarification for why break sizes smaller than 20% are not limiting for GDLB Break
- For GDLB, staff asked why 80% size break is the most limiting using nominal conditions but 100% size break is the most limiting case using bounding conditions
- Supplemental RAI 6.3-65, staff requested GEH to evaluate SLCS line break long term results with the worst single failure

34

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Conclusions

- The analyses show that the core is covered in all LOCA cases
- Preliminary staff confirmatory analyses confirmed that GEH analyses are valid
- Major open items remain

35

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 6.3 Emergency Core Cooling Systems**

Discussion/Committee Questions

36