

5.6 Reporting Requirements

5.6.5 COLR (continued)

14. EMF-92-116(P)(A), "Generic Mechanical Design Criteria for PWR Fuel Designs," Siemens Power Corporation. (LCOs 3.1.6, 3.2.1, 3.2.2, & 3.2.4)
 15. EMF-2087(P)(A), "SEM/PWR-98: ECCS Evaluation Model for PWR LBLOCA Applications," Siemens Power Corporation. (LCOs 3.1.6, 3.2.1, & 3.2.2)
 16. ANF-87-150 Volume 2, "Palisades Modified Reactor Protection System Report: Analysis of Chapter 15 Events," Advanced Nuclear Fuels Corporation. [Approved for use in the Palisades design during the NRC review of license Amendment 118, November 15, 1988] (LCOs 3.1.6, 3.2.1, 3.2.2, & 3.4.1)
 17. EMF-1961(P)(A), Revision 0, Siemens Power Corporation, July 2000, "Statistical Setpoint/Transient Methodology for Combustion Engineering Type Reactors." (LCOs 3.1.6, 3.2.1, 3.2.2, 3.2.4, & 3.4.1)
 18. EMF-2328 (P)(A), Revision 0, Framatome ANP, Inc., March 2001, "PWR Small Break LOCA Evaluation Model, S-RELAP5 Based." (LCOs 3.1.6, 3.2.1, & 3.2.2)
 19. BAW-2489P, "Revised Fuel Assembly Growth Correlation for Palisades." (LCOs 3.1.6, 3.2.1, 3.2.2, & 3.2.4)
 20. EMF-2103 (P)(A), "Realistic Large Break LOCA Methodology for Pressurized Water Reactors." (LCOs 3.1.6, 3.2.1, & 3.2.2)
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems limits, nuclear limits such as shutdown margin, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any mid cycle revisions or supplements, shall be provided, upon issuance for each reload cycle, to the NRC.