

“ Niigata-Chuetsu-Oki Earthquake of
16 July 2007 and Kashiwazaki-Kariwa
NPP -FINDINGS AND LESSONS
LEARNED”

IAEA EXPERT TEAM

Presented by:

James J. Johnson, JJJ and Associates

IAEA REVIEW TEAM:

- JAMET, Philippe IAEA/NSNI/Director,
Team Leader
- GODOY, Antonio R. IAEA/NSNI/ESS,
Deputy Team Leader.
- GUNSELL, Lars SKI, Sweden
- GÜRPINAR, Aybars Consultant, Turkey
- JOHNSON, James J. James J. Johnson &
Associates, USA
- KOSTOV, Marin Risk Engineering Ltd,
Bulgaria

OBJECTIVES

- Conduct a fact finding mission
- Identify lessons learned for such event
- Discuss the performance of the nuclear power plant units under the earthquake, and fulfilment of the fundamental safety functions:
 - control of reactivity;
 - removal of heat from the core; and
 - confinement of radioactive materials

SCOPE OF THE MISSION

- Comparison of the seismic design basis of the plant with the observed ground motion.
- Observation of the damages as consequence of the earthquake of 16 July 2007.
- Operation management during and after the earthquake.

THE EARTHQUAKE


Main shock:

- Moment Magnitude: 6.6
- Epicentre: N37.5 , E138.6
- Time: 16 July 2007, 10:13(JST)
- Depth: 17 km
- Distance to KK NPP:
 - Epicentre: 16 km
 - Hypocentre: 23 km

DISTRIBUTION OF MAIN AND AFTERSHOCKS

2007年7月20日7時現在


震央分布図 (2007年7月16日以降、深さ40km以浅、 $M \geq 2.0$)



丸の大きさはマグニチュードの大きさを、色は震源の深さを表す。

地形データには国土地理院の数値地図50mメッシュ (標高) および日本海洋データセンターのJ-EGQ500を使用。

MAP OF KK NPP



OUTLINE OF KK NPP

| 設備の概要 | 沿革 | アクセス | 資料画像 |
|------------------|----|------|------|
| 柏崎刈羽原子力発電所 設備の概要 | | | |


| | | 1号機 | 2号機 | 3号機 | 4号機 | 5号機 | 6号機 | 7号機 | | |
|-------------------|---------------|--------------|---------|--------|--------|---------|---------------------|----------------|-----|--|
| プラント主要諸元 | 電気出力(万kW) | 110.0 | 110.0 | 110.0 | 110.0 | 110.0 | 135.6 | 135.6 | | |
| | 建設着工 | 1978/12 | 1983/10 | 1987/7 | 1988/2 | 1983/10 | 1991/9 | 1992/2 | | |
| | 営業運転開始 | 1985/9 | 1990/9 | 1993/8 | 1994/8 | 1990/4 | 1996/11 | 1997/7 | | |
| | 原子炉形式 | 沸騰水型軽水炉(BWR) | | | | | | | | |
| | 格納容器形式 | マークII | マークII改良 | | | | 鉄筋コンクリート製 (ABWR) | | | |
| | 国産化率(%) | 99 | | | | | | 89 | | |
| 原子炉 | 主契約者 | 東芝 | | | 日立 | | 東芝 日立 GE | 日立 東芝 GE | | |
| | 熱出力(万kW) | 329.3 | | | | | | 392.6 | | |
| | 燃料集合体数(本) | 764 | | | | | | 872 | | |
| | 燃料集合体全長(m) | 約4.47 | | | | | | | | |
| | 制御棒本数(本) | 185 | | | | | | 205 | | |
| | 圧力容器 | 内径(m) | 6.4 | | | | | | 7.1 | |
| | | 全高(m) | 23 | | | | | | 21 | |
| | | 全重量(t) | 750 | | | | | | 910 | |
| | 格納容器 | 全高(m) | 約48 | | | | | | 約36 | |
| | | 直径(m) | 26 | 29 | | | | | | |
| 圧力抑制室 プール水量(t) | | 3,300 | 4,000 | | | | 3,600 | | | |
| タービン | 回転数(rpm) | 1,500 | | | | | | | | |
| | 入口蒸気温度(℃) | 282 | | | | | | 284 | | |
| | 蒸気圧力(kg/cm2g) | 66.8 | | | | | | 68.2 | | |
| 燃料 | 種類 | 二酸化ウラン | | | | | | | | |
| | ウラン装荷量(t) | 132 | | | | | | 150 | | |
| | 燃料集合体(本) | 764 | | | | | | 872 | | |

Total output


8,212 MW

BWR : 5 units


ABWR : 2 units



マークII型



マークII改良型



ABWR型

※各型のイラストの大きさの比率は一致していません。

PLANT PERFORMANCE

- Approximate number of incidents itemized by TEPCO
 - Total 1275
 - Identified, translated addressed 68
 - Reportable 10

PLANT PERFORMANCE

- Design basis ground motion largely exceeded
- Satisfactory behaviour during and after the earthquake
- Safety functions preserved
 - very small releases observed
- Conservatism in the design compensate the uncertainties in the data/methods at the time of design

FREE-FIELD SURFACE ACCELERATIONS approx. 1 g PGA

Kashiwazaki-Kariwa Nuclear Power Plant (7 Units)

| Unit | Observed Maximum Acceleration Top of RB Basemat (-45m) | | | Design Values (S2) |
|------|---|-----|-----|-----------------------|
| | NS | EW | UD | NS/EW |
| 1 | 311 | 680 | 408 | 274 |
| 2 | 304 | 606 | 282 | 167 |
| 3 | 308 | 384 | 311 | 192 |
| 4 | 310 | 492 | 337 | 193 |
| 5 | 277 | 442 | 205 | 249 |
| 6 | 271 | 322 | 488 | 263 |
| 7 | 267 | 356 | 355 | 263 |

SEISMIC WAVE AND RESPONSE SPECTRUM (ACCELERATION)




図 2-1 10 層建物が基礎固定梁上の加速度時刻歴波形 (東西方向)




図 3-1 10 層建物が基礎固定梁上の加速度応答スペクトル (東西方向)




図 2-2 10 層建物が基礎固定梁上の加速度時刻歴波形 (東西方向)




図 3-2 10 層建物が基礎固定梁上の加速度応答スペクトル (東西方向)




図 2-3 10 層建物が基礎固定梁上の加速度時刻歴波形 (東西方向)




図 3-3 10 層建物が基礎固定梁上の加速度応答スペクトル (東西方向)




図 2-4 10 層建物が基礎固定梁上の加速度時刻歴波形 (東西方向)




図 3-4 10 層建物が基礎固定梁上の加速度応答スペクトル (東西方向)




図 2-5 10 層建物が基礎固定梁上の加速度時刻歴波形 (東西方向)




図 3-5 10 層建物が基礎固定梁上の加速度応答スペクトル (東西方向)




図 2-6 10 層建物が基礎固定梁上の加速度時刻歴波形 (東西方向)




図 3-6 10 層建物が基礎固定梁上の加速度応答スペクトル (東西方向)




図 2-7 10 層建物が基礎固定梁上の加速度時刻歴波形 (東西方向)




図 3-7 10 層建物が基礎固定梁上の加速度応答スペクトル (東西方向)

— Observation — Design (S_2)

On the Foundation of R/B

PLANT PERFORMANCE

- In-structure responses compared for a very limited sample
 - Forces
 - ISRS at one location in RB #3

PLANT PERFORMANCE

- No LOSP (2 of 4 transmission lines always available)
- Soil failures
 - Generally, non-safety consequences
 - Fire protection piping failure led to water and soil intrusion in RB 1
- Fire fighting capability -
 - Lost water sources
 - Delayed off-site fire brigade

PLANT PERFORMANCE

- Seismic systems interaction
 - Falling
 - Control room ceilings Units 6,7 and 3
 - “Temporary” platform in spent fuel pools
 - Flooding
 - Sloshing spent fuel pools (Video Unit 6)
 - Fire suppression piping (RB 1)
 - Condenser (rubber connection failure)

PLANT PERFORMANCE

- Anchorage failures (non-safety water tanks)
- Very small releases
 - Air due to operator air
 - Sloshed water leaked into non-control area - pumped into the sea

PLANT PERFORMANCE

- Correlated failure modes/common cause
 - Control room ceiling light fixtures
 - Ducts to stack
 - Spent fuel pool maintenance platforms

OPERATIONAL MANAGEMENT

- Defense in depth (normal operating plant without actuation of safety systems)
- Readiness for operation (testing of safety systems under way)
- Reporting to authority (could have been quicker?)

RESTART of PLANT

- Seismic hazard re-evaluation (including identification and characterization of capable/active faults)
- Detailed check of integrity and operability of all safety systems (under way)
- Re-evaluation of seismic safety in relation with the new hazard
- Potential interaction between large ground motions and accelerated ageing

RELATION WITH THE JAPANESE COUNTERPART

- Japanese Counterpart open and cooperative.
- All questions addressed promptly and documented
- Transparency to the international community

INTERNATIONAL ATOMIC ENERGY AGENCY



Thank you for your attention