

March 25, 2008

Mr. James A. Spina, Vice President
Calvert Cliffs Nuclear Power Plant, Inc.
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 –
REPORTING REQUIREMENTS OF THE MONTHLY OPERATING REPORT

Dear Mr. Spina:

Your staff recently contacted the Nuclear Regulatory Commission (NRC) regarding proposed changes to information provided to the Monthly Operating Report. Specifically, changes were proposed with regard to reporting the net electrical energy.

Generic Letter (GL) 97-02, "Revised Contents of the Monthly Operating Report," identified the parameters to be included in the Monthly Operating Report. Net electrical energy, which is used to calculate the unit capacity factor, is defined in Attachment 1 of the GL as the gross electrical output of the unit measured at the output terminals of the turbine-generator minus the normal station service loads during the gross hours of the reporting period, expressed in mega-watt hours. Negative quantities should not be used.

It is our understanding that Calvert Cliffs has the capability of measuring turbine generator output at a different location from that described in the GL. Calvert Cliffs would like to use an alternate location to eliminate the task of taking manual, hourly readings from the Control Room. Furthermore, your staff has informed us that the turbine generator output readings from this alternate location will remain representative of readings that you currently report.

The NRC staff has discussed your proposal with industry representatives that monitor and distribute information included in the Monthly Operating Report and we have no objections to your proposal.

Sincerely,

/RA/

Douglas V. Pickett, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

cc: See next page

March 25, 2008

Mr. James A. Spina, Vice President
Calvert Cliffs Nuclear Power Plant, Inc.
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 –
REPORTING REQUIREMENTS OF THE MONTHLY OPERATING REPORT

Dear Mr. Spina:

Your staff recently contacted the Nuclear Regulatory Commission (NRC) regarding proposed changes to information provided to the Monthly Operating Report. Specifically, changes were proposed with regard to reporting the net electrical energy.

Generic Letter (GL) 97-02, "Revised Contents of the Monthly Operating Report," identified the parameters to be included in the Monthly Operating Report. Net electrical energy, which is used to calculate the unit capacity factor, is defined in Attachment 1 of the GL as the gross electrical output of the unit measured at the output terminals of the turbine-generator minus the normal station service loads during the gross hours of the reporting period, expressed in mega-watt hours. Negative quantities should not be used.

It is our understanding that Calvert Cliffs has the capability of measuring turbine generator output at a different location from that described in the GL. Calvert Cliffs would like to use an alternate location to eliminate the task of taking manual, hourly readings from the Control Room. Furthermore, your staff has informed us that the turbine generator output readings from this alternate location will remain representative of readings that you currently report.

The NRC staff has discussed your proposal with industry representatives that monitor and distribute information included in the Monthly Operating Report and we have no objections to your proposal.

Sincerely,

/RA/

Douglas V. Pickett, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

cc: See next page

Distribution

PUBLIC	LPL1-1 r/f	RidsNrrDorlLp11-1
RidsNrrLASLittle	RidsNrrPMDPickett	RidsNrrDirslpab
DHickman		

ADAMS Accession No.

OFFICE	LPL1-1/PM	LPL1-1/LA	IPAB/BC	LPL1-1/BC
NAME	DPickett	SLittle	JAnderson	MKowal
DATE	02 /11/ 08	02 /06/ 08	02 /20/ 08	02 /25/ 08

OFFICIAL RECORD COPY

Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2

cc:

Mr. Michael J. Wallace, President
Constellation Energy Nuclear Group, LLC
750 East Pratt Street, 18th Floor
Baltimore, MD 21202

Mr. John M. Heffley, Senior Vice President
and Chief Nuclear Officer
Constellation Energy Nuclear Generation
Group
111 Market Place
Baltimore, MD 21202

President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, MD 20678

Mr. Carey Fleming, Esquire
Sr. Counsel - Nuclear Generation
Constellation Energy Nuclear Group, LLC
750 East Pratt Street, 17th floor
Baltimore, MD 21202

Mr. Jay S. Gaines
Director, Licensing
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 287
St. Leonard, MD 20685

Mr. R. I. McLean, Manager
Nuclear Programs
Power Plant Research Program
Maryland Department of Natural Resources
580 Taylor Avenue (B wing, 3rd floor)
Tawes State Office Building
Annapolis, MD 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Ms. Kristen A. Burger, Esquire
Maryland People's Counsel
6 St. Paul Centre
Suite 2102
Baltimore, MD 21202-1631

Ms. Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P.O. Box 33111
Baltimore, MD 21218

Mr. Roy Hickok
NRC Technical Training Center
5700 Brainerd Road
Chattanooga, TN 37411-4017

Mr. Louis S. Larragoite
Manager – Nuclear Licensing
Constellation Energy Nuclear Generation
Group
111 Market Place, 2nd Floor
Baltimore, MD 212