	Survey	Unit Release Ro	ecord		
Design #	EP-ROLB-111	Revision #	Original	Page 1	of 3
Survey Unit #(s)		R	OLB-111		
Description	 Embedded Pipe embedded pipe fa EP ROLB-111 Status Survey Pla Surveys in EP optimized to mea and EP 4-6 from Survey Instruction accordance with Work Execution document constitution acquisition of sur Instrument effities Instrument effities Instrument effities Instrument effities 	 Embedded Pipe (EP) Survey Unit ROLB-111 meets the definition of embedded pipe for Plum Brook Reactor Facility (PBRF). EP ROLB-111 is a Class 1, Group 4.2 survey unit as per the PBRF Final Status Survey Plan (FSSP) and Technical Basis Document (TBD)-06-004. Surveys in EP ROLB-111 were performed using a scintillation detector optimized to measure gamma energies representative of Co-60. Sample #EP 4- 3 and EP 4-6 from Survey Request (SR)-13 were referenced for this decision. Survey Instructions for this survey unit are incorporated into and performed in accordance with (IAW) the Babcock Services Incorporated (BSI)/LVS-002, Work Execution Package (WEP) 05-006. Survey instructions described in this document constitute "Special Methods" and the survey design used in the acquisition of survey measurements. Instrument efficiency determinations are developed in accordance with the BSI/LVS-002, WEP 05-006, these determinations are appropriate for the types of radiation involved and the media being surveyed. 			
	Approval Sign	atures	M		Date:
FSS/Characterization	Engineer	Del Run	lall	8-2	4-07
Technical Revie (FSS/Characterization	ewer Engineer)	Duboo	l	10-1	0-07
FSS/Characterization	Manager	7. g.ess / / /	Ĺ	10/10	107
					Form CS-09/1

Rev 0

1

FSS	Design	# EP ROLB-111	Revision # Original	Page 2 of 3			
Surve	ey Unit	: ROLB-111					
1.0	Histo	ory/Description					
	 Irvey Unit: ROLB-111 History/Description The subject pipe system is located in the elevator shaft of the -15 ft elevation of the Reactor Office and Laboratory Building (ROLB). The purpose of this system is to convey water from the various floor drain openings to the ROLB sump located on the sump room on the -15 foot elevation of the ROLB. EP ROLB-111 consists of approximately 27 feet of piping. The piping system is consists of 10" ID piping. Survey Design Information EP ROLB-111 was surveyed IAW Procedure #BSI/LVS-002. 100% of the piping was accessible for survey. The accessible pipe was surveyed by static measurement at one foot increments, for a total of 27 survey measurements. The total surface area for the piping system is approximately 65,669 cm² (6.6 m²) for the entire length of (27') of piping. 						
1.2 EP ROLB-111 consists of approximately 27 feet of piping. system is consists of 10" ID piping.							
2.0	Surv	Survey Design Information					
	2.1	EP ROLB-111 w	as surveyed IAW Procedure #BS	I/LVS-002.			
	2.2	100% of the pipin surveyed by static survey measurem	100% of the piping was accessible for survey. The accessible pipe was surveyed by static measurement at one foot increments, for a total of 27 survey measurements.				
	2.3	The total surface (6.6 m^2) for the e	The total surface area for the piping system is approximately 65,669 cm^2 (6.6 m ²) for the entire length of (27') of piping.				
3.0	Surve	ey Unit Measureme	nt Locations/Data				
	3.1	Pipe interior radio this release record	ological survey forms are provide d.	ed in Attachment 2 of			

- 4.0 Survey Unit Investigations/Results
 - 4.1 None
- 5.0 Data Assessment Results
 - 5.1 Data assessment results are provided in the EP/Buried Pipe (BP) Survey Report provided in Attachment 1.
 - 5.2 All measurement results are less than the Derived Concentration Guideline Level (DCGL) for radionuclide specific EP that corresponds to the 1 mrem/yr dose goal established in Table 3-3 of the FSSP.
 - 5.3 When implementing the Unity Rule, provided in Section 3.6.3 of the FSSP, and applying the Nuclide Fraction (NF), provided in TBD-06-004, the survey unit that is constituted by EP ROLB-111 passes FSS.
 - 5.4 Background was not subtracted from the survey measurements and the Elevated Measurement Comparison (EMC) was not employed for this survey unit.

FSS Design # EP ROLB-111	Revision # Original	Page 3 of 3
Survey Unit: ROLB-111		

- 5.5 Cs-137 is designated as the primary nuclide of concern for piping Group 4.2 per Technical Basis Document (TBD)-06-004. The survey measurements and dose assessment for ROLB 111 were calculated and appropriately scaled for Piping Group 4.2 based on the direct measurement of Co-60. TBD-06-004 and the supporting sample analysis from Survey Request 13 were not approved or published at the time the ROLB 111 survey measurements were acquired.
- 5.6 Statistical Summary Table

	10"
Statistical Parameter	Pipe
Total Number of Survey Measurements	27
Number of Measurements >MDC	27
Number of Measurements Above 50% of DCGL	0
Number of Measurements Above DCGL	0
Mean	0.1845
Median	0.1881
Standard Deviation	0.0866
Maximum	0.3077
Minimum	0.0595

- 6.0 Documentation of evaluations pertaining to compliance with the unrestricted use limit of 25 mrem/yr and dose contributions from Embedded Pipe and radionuclides contributing 10% in aggregate of the total dose for both structural scenarios and soils.
 - 6.1 A review of the survey results has shown that the dose contribution for EP ROLB-111 to be less than 1 mrem/yr. The dose contribution is estimated to be 0.185 mrem/yr based on the average of the actual gross counts.
- 7.0 Attachments

Attachment 1 – BSI EP/BP Survey Report Attachment 2 – Pipe Interior Radiological Survey Form Attachment 3 – DQA Worksheet Attachment 4 –Disc containing RR for EP ROLB-111 & Spreadsheet SECTION 7 ATTACHMENT 1 _____ PAGE(S) 1

1

Babcock	BSI EI	P/BP SURVEY REPORT			
Pipe ID	EP ROLB-111	Survey Location	ROLB -15 el.		
Survey Date	08-Mar-06	2350-1 #	203488		
Survey Time	08:00	Detector-Sled #	B577A / 108		
Pipe Size	10"	Detector Efficiency	0.0033		
DCGL (dpm/100cm2)	2.41E+05	Pipe Area Incorporated by Detector Efficiency (in cm2)	2432		
Pipe Area Incorporated by Survey Data (m ²)	6.6	Field BKG (cpm)	598.3		
Routine Survey	х	Field MDCR (cpm)	87.3		
QA Survey		Nominal MDC (dpm/100cm2)	879		
	5	Survey Measurement Results			
	Total Number of S	urvey Measurements	27		
	Number of Mea	asurements >MDC	27		
	Nominal MDC (dpm/100cm2) Survey Measurement Results Total Number of Survey Measurements Number of Measurements >MDC Number of Measurements Above 50% DCGL Number of Measurements Above DCGL Mean Median Standard Deviation				
	Number of Measurements >MDC Number of Measurements Above 50% DCGL Number of Measurements Above DCGL Mean Median				
	N	lean	0.1845		
	M	edian	0.1881		
	Standar	d Deviation	0.0866		
	Ma	ximum	0.3077		
	Mir	nimum	0.0595		
Survey Te	echnician(s)	ROSENHAGEN			
	0	Classification	4		
	Survey Uni	t Glassification	1		
	SP 13 Pediopuelid		4.2		
	Monour	ed Nuclide	EF 4-3		
	Area East		C0-00		
	Alea Facio	Eail ESS	NO		
	MDEM/VE	Contribution	Pass		
		Contribution	<1		
COMMENTS:	ACTIVITY VAI	LUES NOT BACKGROUND CORRECTED			
RP Engi	neer Date	Oal Ranhall	9-24-07		

EP ROLB-111 10" Pipe TBD 06-004 Group 4.2

Measurement #	gcpm	ncpm	Co-60 activity (total dpm)	Co-60 activity (dpm/100cm2)	Cs-137 activity (dpm/100cm2)	Eu-152 activity (dpm/100cm2)	Eu-154 activity (dpm/100cm2)	Nb-94 activity (dpm/100cm2)	Ag-108m activity (dpm/100cm2)	Unity
1	200	200	606,061	24,918	131,800	-	-	-	-	0.138
2	250	250	757,576	31,148	164,750	-	-	-	-	0.173
3	411	411	1,245,455	51,207	270,850	-	-	-	-	0.284
4	432	432	1,309,091	53,823	284,689	-	-	-	-	0.299
5	445	445	1,348,485	55,443	293,256	-	-	-	-	0.308
6	426	426	1,290,909	53,076	280,735	-	-	-	-	0.295
7	414	414	1,254,545	51,581	272,827	-	-	-	-	0.286
8	393	393	1,190,909	48,964	258,988	-	-	-	-	0.272
9	356	356	1,078,788	44,354	234,605	-	-	-	-	0.246
10	272	272	824,242	33,889	179,248	-	-	-	-	0.188
11	320	320	969,697	39,869	210,880	-	-	-	-	0.221
12	292	292	884,848	36,381	192,428	-	-	-	-	0.202
13	379	379	1,148,485	47,220	249,762	-	-	-	-	0.262
14	410	410	1,242,424	51,082	270,191	-	-	-	-	0.284
15	397	397	1,203,030	49,463	261,624	-	-	-	-	0.275
16	291	291	881,818	36,256	191,769	-	-	-	-	0.201
17	227	227	687,879	28,282	149,593	-	-	-	-	0.157
18	166	166	503,030	20,682	109,394	-	-	-	-	0.115
19	157	157	475,758	19,561	103,463	-	-	-	-	0.109
20	86	86	260,606	10,715	56,674	-	-	-	-	0.059
21	88	88	266,667	10,964	57,992	-	-	-	-	0.061
22	138	138	418,182	17,194	90,942	-	-	-	-	0.095
23	146	146	442,424	18,190	96,214	-	-	-	-	0.101
24	125	125	378,788	15,574	82,375	-	-	-	-	0.086
25	122	122	369,697	15,200	80,398	-	-	-	-	0.084
26	142	142	430,303	17,692	93,578	-	-	-	-	0.098
27	118	118	357,576	14,702	77,762	-	-	-	-	0.082
									MEAN	0.184
									MEDIAN	0.188
									STD DEV	0.087
									MAX	0.308
									MIN	0.059

SECTION 7 ATTACHMENT 2 _____ PAGE(S)

BSI/LVSPipeCrawler-002 Revision 4

		Pipe Interior I	Radiological Sur	rvey Form	,	
Date:	3-8-06	Time:	6800			
Pipe ID#: Building:	ROLB III ROLB	Pipe Diameter: Elevation:	10" -15	Access	Point Area: $-15 RocecevAroystem:RocB$	B SHAFT 11 Die Straff
Type of Su	rvey Investigatio	on Charact	erization	Final Surve	y Other	- 21014700
Gross		Co60	· .	Cs		
Detecto	r ID# / Sled ID#	G3 BICRON /B	5774 1 10	8		
Detector	Cal Date: _/7 -	Nov -05	Detector Cal I	Due Date:	17- Nov-06	
Instru	ment:	350-1	Instrument	ID #:	203488	
Instrument	Cal Date: <u>17-</u>	NOJ -05	Instrument Cal	Due Date:	17 - Nov -06	
From the D Backgroun	Daily Pipe Survey D Id Value <u>598-3</u>	etector Control For	rm for the Select	ed Detector		
MDC _{static} Efficiency MDC _{static} Is the MDC Comments	Factor for Pipe Dia 879 C _{static} acceptable? $\mp wi'7$	$\frac{dpm}{Yes} No$	3 (from c cm ² (if no, adjust s	letector efficient	iency determination) ne and recalculate MDCR _{static})
					Complet	で
					0	

Technician Signature

Pipe Interior Radiological Survey

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
1	(1	200	200	na	na
2	д	7	2.50	250	1	1
3	3		411	411		
4	4		432	432		· · · ·
5	5	/	44.5	445		
6 ·	à		426	426		
7	7	/	414	414		
8	8		393	39.3		
9	9		356	356		
10	10		272	272	4	

Package Page 1 of <u>3</u>



÷

Attachment 3, Page 1

BSI/LVSPipeCrawler-002

Revision 4

Pipe Interior Radiological Survey Form (Continuation Form)

Date:	3-8-04		1(- ROCA
Pipe ID#:	ROLB III	Pipe Diameter	r: <u>10</u>	Access	Point Area:	SELEVATOR SHAFT
Building:	ROLB	Elevation:	-15	S	ystem: Z	OLB (11
Position	Feet into Pipe	Count Time	Gross Counts	Gross	Net	$dpm/100cm^2$
#	from Opening	(min)		cpm	cpm	
11	//	1	320	320	Na	nja
12	12	1	292	292		
13	13	· .	379	379		
14	14		410	410		
15	15		397	391		
16	16		291	291		
17	17		227	227		
18 /	18		Kele	166		
19	19		1.57	157		
20	20		8 Le	84		
21	21		88	88		
22	22		138	138		
23	23		146	146		
24	24		125	125		
25	25		127	122		
26	26		142	142		
27	27		18	118		
ALQ.	nla.	NIA	nia	NA		
	1		1			
		·				
					,	
					J	
N/	V	V	V V	75	¥	V V

Package Page 2 of 3



Attachment 3, Page 2



3 frat

SECTION 7 ATTACHMENT 3 ____ PAGE(S)

			DQ	A Check S	heet			
	Design #	EP ROLB-111	Revision #	Original				
S	urvey Unit #			EP	ROLB-111			
			Prelimi	inary Data	Review`			
	Answers to	the following quest	ions should be Release Red	e fully doc cord	umented in the Survey Unit	Yes	No	N/A
1.	. Have surveys been performed in accordance with survey instructions in the Survey Design?							
2.	Is the instrume survey units, o	entation MDC for structu or below 0.5 DCGL _W for	ire static measur Class 3 survey u	ements belo inits?	w the $DCGL_W$ for Class 1 and 2			х
3.	Is the instrume	entation MDC for embed	ded/buried pipin	g static mea	surements below the DCGL _W ?	Х		
4.	Was the instru embedded/bui static measure	imentation MDC for stru ried piping scan measur ements or soil samples a	cture scan meas rements below th addressed in the	urements, s e DCGL _{W,} o survey desi	oil scan measurements, and r, if not, was the need for additional gn?			x
5.	Was the instru	mentation MDC for volu	umetric measure	ments and s	mear analysis < 10% DCGL _W ?			X
6.	Were the MDC used to perform	Cs and assumptions use m the survey?	ed to develop the	m appropria	te for the instruments and techniques	х		
7.	Were the surverse media being s	ey methods used to coll urveyed?	ect data proper f	or the types	of radiation involved and for the	X		
8.	8. Were "Special Methods" for data collection properly applied for the survey unit under review?							
9. Is the data set comprised of qualified measurement results collected in accordance with the survey design, which accurately reflects the radiological status of the facility?						x		
			Graph	nical Data	Review			
1.	Has a posting	plot been created?						X
2. Has a histogram (or other frequency plot) been created?								X
3. Have other graphical data tools been created to assist in analyzing the data?								X
			I	Data Analys	is			
1.	Are all sample	measurements below t	he DCGL _W (Clas	s 1 & 2), or	0.5 DCGL _W (Class 3)?	X		
2.	Is the mean of	the sample data < DCC	GLw?			X		
3.	If elevated are elevated area	as have been identified < DCGL _{EMC} (Class 1),	by scans and/or < DCGL _W (Class	sampling, is 2), or <0.5	the average activity in each DCGL _W (Class 3)?			X
4.	Is the result of	the Elevated Measuren	nents Test < 1.0	?				X
5.	Is the result of	the statistical test (S+ f	or Sign Test or V	V _r for WRS	Test) ≥ the critical value?			X
Cor	nments:					,		
F	SS/Characteriza	ation Engineer (print/sig	n) Dale	Rang	lall of Dal Martal	Date	9-2	9-07
F	SS/ Characteriz	ation Manager (print/sig	n) F	Case	Man	Date	10/1	6/07
							For CS-0	rm 09/2

SECTION 7 ATTACHMENT 4 1 DISC