

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

April 21, 1980

390/80-12-03

391/80-09-03

APR 24 11:50

①

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

Dear Mr. O'Reilly:


WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - TPIPE - USER FAILED TO CHECK
FREQUENCY ANALYSIS - NCR 80-15 - FINAL REPORT

The subject deficiency was reported to NRC-OIE Inspector R. W. Wright
on March 20, 1980, in accordance with 10 CFR 50.55(e). Enclosed is
our final report.

If you have any questions concerning this matter, please get in touch
with D. L. Lambert at FTS 854-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosure

cc: Mr. Victor Stello, Jr., Director (Enclosure)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

dupe
8004250380

ENCLOSURE

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2
TPIPE - USER FAILED TO CHECK FREQUENCY ANALYSIS
NCR CEB 80-15
10 CFR 50.55(e)
FINAL REPORT

Description of Deficiency

One function of the TPIPE computer program is to determine the frequency response of piping systems during a seismic event. The TPIPE program outputs information regarding the correctness of the calculation of the frequency analysis. Convergence information is calculated and printed out for each frequency that is analyzed. If, for a given frequency, the results do not converge to within specified limits, a message to this effect is printed and analysis continues. The generalized mass matrix is also printed out for review. The TVA personnel who utilized this program failed to check for the nonconvergence message and the correctness of the generalized mass matrix.

Safety Implications

Because the user failed to properly analyze the output, design information could have been issued for problems where the results of the frequency analysis were not correct.

Corrective Action

All analyses performed using TPIPE have been reviewed. There are no occurrences of erroneous design information resulting from this condition. Additionally, the program has been modified in order to assist the user in detecting a frequency analysis that does not converge. Any run that does not converge to within specific limits will stop after the frequency analysis. Also, the generalized mass matrix will be internally checked for accuracy.