

Participant A

Reactor Pressure Vessel

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr-1)	Mid Value (cal-yr-1)	5% UB (cal-yr-1)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
CRDM	1 (> 100)	Developed from service history	1.78E-05	5.34E-05	1.60E-04	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
	2 (> 1,500)		1.78E-05	5.34E-05	1.60E-04	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01
	3 (> 5,000)		1.78E-05	5.34E-05	1.60E-04	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01
	4 (> 25,000)		1.78E-05	5.34E-05	1.60E-04	3.60E-05	7.20E-04	1.40E-03	3.60E-05	7.20E-04	1.40E-03	3.60E-05	7.20E-04	1.40E-03
	5 (> 100,000)		1.78E-05	5.34E-05	1.60E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04
	6 (> 500,000)		1.78E-05	5.34E-05	1.60E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04
CRDM Connections	1 (> 100)	Developed from service history	1.76E-05	5.27E-05	1.58E-04	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
	2 (> 1,500)		1.76E-05	5.27E-05	1.58E-04	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01
	3 (> 5,000)		1.76E-05	5.27E-05	1.58E-04	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01
	4 (> 25,000)		1.76E-05	5.27E-05	1.58E-04	3.60E-05	7.20E-04	1.40E-03	3.60E-05	7.20E-04	1.40E-03	3.60E-05	7.20E-04	1.40E-03
	5 (> 100,000)		1.76E-05	5.27E-05	1.58E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04
	6 (> 500,000)		1.76E-05	5.27E-05	1.58E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04
Nozzles	1 (> 100)	Developed from service history	2.31E-07	6.94E-07	2.08E-06	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
	2 (> 1,500)		2.31E-07	6.94E-07	2.08E-06	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01
	3 (> 5,000)		2.31E-07	6.94E-07	2.08E-06	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01
	4 (> 25,000)		2.31E-07	6.94E-07	2.08E-06	1.50E-03	3.00E-02	5.85E-02	1.50E-03	3.00E-02	5.85E-02	1.50E-03	3.00E-02	5.85E-02
	5 (> 100,000)		2.31E-07	6.94E-07	2.08E-06	5.00E-04	1.00E-02	1.95E-02	5.00E-04	1.00E-02	1.95E-02	5.00E-04	1.00E-02	1.95E-02
	6 (> 500,000)		2.31E-07	6.94E-07	2.08E-06	1.50E-04	3.00E-03	5.85E-03	1.50E-04	3.00E-03	5.85E-03	1.50E-04	3.00E-03	5.85E-03
In-Core Instrumentation	1 (> 100)	Developed from service history	1.85E-06	5.55E-06	1.66E-05	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
	2 (> 1,500)		1.85E-06	5.55E-06	1.66E-05	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01
	3 (> 5,000)		1.85E-06	5.55E-06	1.66E-05	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01
	4 (> 25,000)		1.85E-06	5.55E-06	1.66E-05	3.60E-05	7.20E-04	1.40E-03	3.60E-05	7.20E-04	1.40E-03	3.60E-05	7.20E-04	1.40E-03
	5 (> 100,000)		1.85E-06	5.55E-06	1.66E-05	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04
	6 (> 500,000)		1.85E-06	5.55E-06	1.66E-05	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04	1.82E-05	3.63E-04	7.08E-04
Head Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Other penetrations	1 (> 100)	Developed from service history	2.54E-06	7.63E-06	2.29E-05	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
	2 (> 1,500)		2.54E-06	7.63E-06	2.29E-05	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01
	3 (> 5,000)		2.54E-06	7.63E-06	2.29E-05	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01
	4 (> 25,000)		2.54E-06	7.63E-06	2.29E-05	1.50E-03	3.00E-02	5.85E-02	1.50E-03	3.00E-02	5.85E-02	1.50E-03	3.00E-02	5.85E-02
	5 (> 100,000)		2.54E-06	7.63E-06	2.29E-05	5.00E-04	1.00E-02	1.95E-02	5.00E-04	1.00E-02	1.95E-02	5.00E-04	1.00E-02	1.95E-02
	6 (> 500,000)		2.54E-06	7.63E-06	2.29E-05	1.50E-04	3.00E-03	5.85E-03	1.50E-04	3.00E-03	5.85E-03	1.50E-04	3.00E-03	5.85E-03

Percent Contributions for Reactor Pressure Vessel

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)
1 (> 100)									
2 (> 1,500)									
3 (> 5,000)									
4 (> 25,000)									
5 (> 100,000)									
6 (> 500,000)									
	Total (input)	100	100	100	100	100	100	100	100

Pumps

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr-1)	Mid Value (cal-yr-1)	5% UB (cal-yr-1)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Bonnet Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Nozzle	1 (> 100)		2.31E-07	6.92E-07	2.08E-06	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	
	2 (> 1,500)		2.31E-07	6.92E-07	2.08E-06	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	5.85E-01	1.50E-02	3.00E-01	
	3 (> 5,000)		2.31E-07	6.92E-07	2.08E-06	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	1.95E-01	5.00E-03	1.00E-01	
	4 (> 25,000)		2.31E-07	6.92E-07	2.08E-06	1.50E-03	3.00E-02	5.85E-02	1.50E-03	3.00E-02	5.85E-02	1.50E-03	3.00E-02	
	5 (> 100,000)		2.31E-07	6.92E-07	2.08E-06	5.00E-04	1.00E-02	1.95E-02	5.00E-04	1.00E-02	1.95E-02	5.00E-04	1.00E-02	
	6 (> 500,000)		2.31E-07	6.92E-07	2.08E-06	1.50E-04	3.00E-03	5.85E-03	1.50E-04	3.00E-03	5.85E-03	1.50E-04	3.00E-03	
Flywheel	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Pumps

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)
1 (> 100)									
2 (> 1,500)									
3 (> 5,000)									
4 (> 25,000)									
5 (> 100,000)									
6 (> 500,000)									
	Total (input)	100	100	100	100	100	100	100	100

Valves

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr-1)	Mid Value (cal-yr-1)	5% UB (cal-yr-1)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)				</									

Participant G

Reactor Pressure Vessel

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)	PWR-1	5.13E-08	1.54E-07	4.62E-07	3.33E-02	1.00E-01	3.00E-01	2.00E-02	1.00E-01	5.00E-01	1.00E-02	1.00E-01	1.00E+00
	2 (> 1,500)		7.50E-09	2.25E-08	6.75E-08	3.33E-02	1.00E-01	3.00E-01	2.00E-02	1.00E-01	5.00E-01	1.00E-02	1.00E+00	
	3 (> 5,000)		1.67E-09	8.33E-09	4.17E-08	2.00E-02	1.00E-01	5.00E-01	1.00E-02	1.00E-01	1.00E+00	5.00E-03	1.00E+00	
	4 (> 25,000)		2.85E-10	2.85E-09	2.85E-08	1.00E-02	1.00E-01	1.00E+00	5.00E-03	1.00E-01	2.00E+00	3.33E-03	1.00E+00	
	5 (> 100,000)		8.53E-11	8.53E-10	8.53E-09	1.00E-02	1.00E-01	1.00E+00	5.00E-03	1.00E-01	2.00E+00	3.33E-03	1.00E+00	
	6 (> 500,000)		7.90E-12	1.58E-10	3.16E-09	5.00E-03	1.00E-01	2.00E+00	3.33E-03	1.00E-01	2.00E+00	3.33E-03	1.00E+00	
CRDM	1 (> 100)	PWR-1	5.13E-08	1.54E-07	4.62E-07	1.67E-01	5.00E-01	1.50E+00	1.00E-01	5.00E-01	2.50E+00	5.00E-02	5.00E-01	
	2 (> 1,500)		7.50E-09	2.25E-08	6.75E-08	1.67E-01	5.00E-01	1.50E+00	1.00E-01	5.00E-01	2.50E+00	5.00E-02	5.00E-01	
	3 (> 5,000)		1.67E-09	8.33E-09	4.17E-08	1.00E-01	5.00E-01	2.50E+00	5.00E-02	5.00E-01	2.50E+00	5.00E-02	5.00E-01	
	4 (> 25,000)		2.85E-10	2.85E-09	2.85E-08	5.00E-02	5.00E-01	5.00E+00	2.50E-02	5.00E-01	1.00E+01	1.67E-02	5.00E-01	
	5 (> 100,000)		8.53E-11	8.53E-10	8.53E-09	5.00E-02	5.00E-01	5.00E+00	2.50E-02	5.00E-01	1.00E+01	1.67E-02	5.00E-01	
	6 (> 500,000)		7.90E-12	1.58E-10	3.16E-09	2.50E-02	5.00E-01	1.00E+01	1.67E-02	5.00E-01	1.50E+01	1.00E-02	5.00E-01	
CRDM Connection	1 (> 100)	PWR-1	5.13E-08	1.54E-07	4.62E-07	3.33E-04	1.00E-03	3.00E-03	2.00E-04	1.00E-03	5.00E-03	1.00E-04	1.00E-03	
	2 (> 1,500)		7.50E-09	2.25E-08	6.75E-08	3.33E-04	1.00E-03	3.00E-03	2.00E-04	1.00E-03	5.00E-03	1.00E-04	1.00E-03	
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Nozzles	1 (> 100)	PWR-1	5.13E-08	1.54E-07	4.62E-07	1.67E-01	5.00E-01	1.50E+00	1.00E-01	5.00E-01	2.50E+00	5.00E-02	5.00E-01	
	2 (> 1,500)		7.50E-09	2.25E-08	6.75E-08	1.67E-01	5.00E-01	1.50E+00	1.00E-01	5.00E-01	2.50E+00	5.00E-02	5.00E-01	
	3 (> 5,000)		1.67E-09	8.33E-09	4.17E-08	1.00E-01	5.00E-01	2.50E+00	5.00E-02	5.00E-01	2.50E+00	5.00E-02	5.00E-01	
	4 (> 25,000)		2.85E-10	2.85E-09	2.85E-08	5.00E-02	5.00E-01	5.00E+00	2.50E-02	5.00E-01	1.00E+01	1.67E-02	5.00E-01	
	5 (> 100,000)		8.53E-11	8.53E-10	8.53E-09	5.00E-02	5.00E-01	5.00E+00	2.50E-02	5.00E-01	1.00E+01	1.67E-02	5.00E-01	
	6 (> 500,000)		7.90E-12	1.58E-10	3.16E-09	2.50E-02	5.00E-01	1.00E+01	1.67E-02	5.00E-01	1.50E+01	1.00E-02	5.00E-01	
In-Core Instrumentation	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Head Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Other penetrations	1 (> 100)	PWR-1	5.13E-08	1.54E-07	4.62E-07	3.33E-04	1.00E-03	3.00E-03	2.00E-04	1.00E-03	5.00E-03	1.00E-04	1.00E-03	
	2 (> 1,500)		7.50E-09	2.25E-08	6.75E-08	3.33E-04	1.00E-03	3.00E-03	2.00E-04	1.00E-03	5.00E-03	1.00E-04	1.00E-03	
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Reactor Pressure Vessel

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)
1 (> 100)				75	100	100	75	100	100	75	100	100
2 (> 1,500)				75	100	100	75	100	100	75	100	100
3 (> 5,000)				75	100	100	75	100	100	75	100	100
4 (> 25,000)				75	100	100	75	100	100	75	100	100
5 (> 100,000)				75	100	100	75	100	100	75	100	100
6 (> 500,000)				75	100	100	75	100	100	75	100	100

Pumps

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)	PWR-1	5.13E-08	1.54E-07	4.62E-07	1.67E-03	5.00E-03	1.50E-02	1.00E-03	5.00E-03	2.50E-02	5.00E-04	5.00E-03	
	2 (> 1,500)		7.50E-09	2.25E-08	6.75E-08	1.67E-03	5.00E-03	1.50E-02	1.00E-03	5.00E-03	2.50E-02	5.00E-04	5.00E-03	
	3 (> 5,000)		1.67E-09	8.33E-09	4.17E-08	1.00E-03	5.00E-03	2.50E-02	5.00E-04	5.00E-03	1.00E-01	1.67E-04	5.00E-03	
	4 (> 25,000)		2.85E-10	2.85E-09	2.85E-08	5.00E-04	5.00E-03	5.00E-02	2.50E-04	5.00E-03	1.00E-01	1.67E-04	5.00E-03	
	5 (> 100,000)		2.84E-10	8.53E-09	2.86E-08	5.00E-04	5.00E-03	5.00E-02	2.50E-04	5.00E-03	1.00E-01	1.67E-04	5.00E-03	
	6 (> 500,000)		5.27E-11	1.58E-10	4.74E-10	2.50E-04	5.00E-03	1.00E-01	1.67E-04	5.00E-03	1.50E-01	1.00E-04	5.00E-03	
Bonnet Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Nozzle	1 (> 100)	PWR-1	5.13E-08	1.54E-07	4.62E-07	1.67E-03	5.00E-03	1.50E-02	1.00E-03	5.00E-03	2.50E-02	5.00E-04	5.00E-03	
	2 (> 1,500)		7.50E-09	2.25E-08	6.75E-08	1.67E-03	5.00E-03	1.50E-02	1.00E-03	5.00E-03	2.50E-02	5.00E-04	5.00E-03	
	3 (> 5,000)		1.67E-09	8.33E-09	4.17E-08	1.00E-03	5.00E-03	2.50E-02	5.00E-04	5.00E-03	1.00E-01	1.67E-04	5.00E-03	
	4 (> 25,000)		2.85E-10	2.85E-09	2.85E-08	5.00E-04	5.00E-03	5.00E-02	2.50E-04	5.00E-03	1.00E-01	1.67E-04	5.00E-03	
	5 (> 100,000)		2.84E-10	8.53E-09	2.86E-08	5.00E-04	5.00E-03	5.00E-02	2.50E-04	5.00E-03	1.00E-01	1.67E-04	5.00E-03	
	6 (> 500,000)		5.27E-11	1.58E-10	4.74E-10	2.50E-04	5.00E-03	1.00E-01	1.67E-04	5.00E-03	1.50E-01	1.00E-04	5.00E-03	
Flywheel	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Pumps

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)
1 (> 100)				75	100	100	75	100	100	75	100	100
2 (> 1,500)				75	100	100	75	100	100	75	100	100
3 (> 5,000)				75	100	100	75	100	100	75	100	100
4 (> 25,000)				75	100	100	75	100	100	75	100	100
5 (> 100,000)				75	100	100	75	100	100	75	100	100
6 (> 500,000)				75	100	100	75	100	100	75	100	100

Valves

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)	PWR-1	3.03E-09	9.08E-09	2.72E-08	3.33E-02	1.00E-02	3.00E-02	2.00E-03	1.00E-02	5.00E-02	1.00E-03	1.00E-02	
	2 (> 1,500)		4.77E-10	1.43E-09	4.29E-09	3.33E-02	1.00E-01	3.00E-01	2.00E-02	1.00E-01	5.00E-01	1.00E-02	1.00E-01	
	3 (> 5,000)		1.67E-10	5.00E-10	1.50E-09	2.00E-02								

Participant H

Reactor Pressure Vessel

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)	Calculated from PWR piping contributions	5.62E-08	1.69E-07	5.06E-07	1.00E-05	1.00E-03	1.00E-01	4.96E-05	4.96E-03	4.96E-01	2.86E-05	2.86E-02	2.86E+01
	2 (> 1,500)		5.62E-08	1.69E-07	5.06E-07	1.00E-05	1.00E-03	1.00E-01	4.96E-05	4.96E-03	4.96E-01	2.86E-05	2.86E-02	2.86E+01
	3 (> 5,000)		5.62E-08	1.69E-07	5.06E-07	1.00E-05	1.00E-03	1.00E-01	4.96E-05	4.96E-03	4.96E-01	2.86E-05	2.86E-02	2.86E+01
	4 (> 25,000)		1.70E-08	5.09E-08	1.55E-07	1.00E-05	1.00E-03	1.00E-01	4.91E-05	4.91E-03	4.91E-01	2.48E-05	2.48E-02	2.48E+01
	5 (> 100,000)		1.79E-09	5.38E-09	1.61E-08	1.00E-05	1.00E-03	1.00E-01	3.52E-05	3.52E-03	3.52E-01	1.84E-05	1.84E-02	1.84E+01
	6 (> 500,000)		2.94E-10	8.81E-10	2.64E-09	1.00E-05	1.00E-03	1.00E-01	5.09E-05	5.09E-03	5.09E-01	3.50E-05	3.50E-02	3.50E+01
CRDM	1 (> 100)	Riccardella's CRDM estimates	2.50E-04	2.50E-04	2.50E-04	5.00E-01	1.00E+01	2.00E+02	5.00E-01	1.00E+01	2.00E+02	5.00E-01	1.00E+01	2.00E+02
	2 (> 1,500)		2.50E-04	2.50E-04	2.50E-04	5.00E-01	1.00E+01	2.00E+02	5.00E-01	1.00E+01	2.00E+02	5.00E-01	1.00E+01	2.00E+02
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
CRDM Connections	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Nozzles	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
In-Core Instrumentation	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Head Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Other penetrations	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Reactor Pressure Vessel

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)
1 (> 100)			Total (input)	100	100	100	100	100	100	100	100	100
2 (> 1,500)			Total (input)	100	100	100	100	100	100	100	100	100
3 (> 5,000)			Total (input)	100	100	100	100	100	100	100	100	100
4 (> 25,000)			Total (input)	100	100	100	100	100	100	100	100	100
5 (> 100,000)			Total (input)	100	100	100	100	100	100	100	100	100
6 (> 500,000)			Total (input)	100	100	100	100	100	100	100	100	100

Pumps

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Bonnet Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Nozzle	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Flywheel	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Pumps

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)
1 (> 100)			Total (input)	100	100	100	100	100	100	100	100	100
2 (> 1,500)			Total (input)	100	100	100	100	100	100	100	100	100
3 (> 5,000)			Total (input)	100	100	100	100	100	100	100	100	100
4 (> 25,000)			Total (input)	100	100	100	100	100	100	100	100	100
5 (> 100,000)			Total (input)	100	100	100	100	100	100	100	100	100
6 (> 500,000)			Total (input)	100	100	100	100	100	100	100	100	100

Valves

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Bonnet Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Bonnet	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Valves

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)
1 (> 100)			Total (input)	100	100	100	100	100	100	100	100	100
2 (> 1,500)			Total (input)	100	100	100	100	100	100	100	100	100
3 (> 5,000)			Total (input)	100	100	100	100	100	100	100	100	100
4 (> 25,000)			Total (input)	100	100	100	100	100	100	100	100	100
5 (> 100,000)			Total (input)	100	100	100	100	100	100	100	100	100
6 (> 500,000)			Total (input)	100	100	100	100	100	100	100	100	100

Pressurizer

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio				

Participant I

Reactor Pressure Vessel

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation				
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio		
Body	1 (> 100)															
	2 (> 1,500)															
	3 (> 5,000)															
	4 (> 25,000)															
	5 (> 100,000)															
	6 (> 500,000)															
CRDM	1 (> 100)	Cat 1: % cont.	1.67E-03	5.00E-03	1.50E-02	1.00E-02	1.00E-01	2.00E-01	1.00E-02	1.00E-01	2.00E-01	1.00E-02	1.00E-01	2.00E-01	1.00E-01	2.00E-01
	2 (> 1,500)	Cat 2: direct	1.67E-05	5.00E-05	1.50E-04	1.00E-01	5.00E-01	5.00E+00	8.00E-03	8.00E-02	4.00E-01	3.00E-02	3.00E-01	1.50E+00	1.50E+00	1.50E+00
	3 (> 5,000)	Cat 3: direct	1.67E-05	5.00E-05	1.50E-04	8.33E-02	5.00E-01	5.00E+00	6.00E-03	6.00E-02	3.00E-01	2.00E-02	2.00E-01	1.00E+00	1.00E+00	1.00E+00
	4 (> 25,000)	Cat 4: direct	1.67E-06	5.00E-06	1.50E-05	8.00E-02	4.00E-01	8.00E-01	2.00E-03	2.00E-02	1.00E-01	2.00E-02	2.00E-01	1.00E+00	1.00E+00	1.00E+00
	5 (> 100,000)															
	6 (> 500,000)															
CRDM Connections	1 (> 100)	Cat 1: % cont.	1.67E-03	5.00E-03	1.50E-02	1.00E-02	1.00E-01	2.00E-01	1.00E-02	1.00E-01	2.00E-01	1.00E-02	1.00E-01	2.00E-01	1.00E-01	2.00E-01
	2 (> 1,500)	Cat 2: % cont.	1.67E-05	5.00E-05	1.50E-04	1.00E-01	5.00E-01	5.00E+00	8.00E-03	8.00E-02	4.00E-01	3.00E-02	3.00E-01	1.50E+00	1.50E+00	1.50E+00
	3 (> 5,000)	Cat 3: % cont.	1.67E-05	5.00E-05	1.50E-04	8.33E-02	5.00E-01	5.00E+00	6.00E-03	6.00E-02	3.00E-01	2.00E-02	2.00E-01	1.00E+00	1.00E+00	1.00E+00
	4 (> 25,000)															
	5 (> 100,000)															
	6 (> 500,000)															
Nozzles	1 (> 100)															
	2 (> 1,500)															
	3 (> 5,000)															
	4 (> 25,000)															
	5 (> 100,000)															
	6 (> 500,000)															
In-Core Instrumentation	1 (> 100)															
	2 (> 1,500)															
	3 (> 5,000)															
	4 (> 25,000)															
	5 (> 100,000)															
	6 (> 500,000)															
Head Bolts	1 (> 100)															
	2 (> 1,500)															
	3 (> 5,000)															
	4 (> 25,000)															
	5 (> 100,000)															
	6 (> 500,000)															
Other penetrations	1 (> 100)															
	2 (> 1,500)															
	3 (> 5,000)															
	4 (> 25,000)															
	5 (> 100,000)															
	6 (> 500,000)															

Percent Contributions for Reactor Pressure Vessel

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)
1 (> 100)				100	100	100	100	100	100	100	100	100
2 (> 1,500)				100	100	100	100	100	100	100	100	100
3 (> 5,000)				100	100	100	100	100	100	100	100	100
4 (> 25,000)				100	100	100	100	100	100	100	100	100
5 (> 100,000)				100	100	100	100	100	100	100	100	100
6 (> 500,000)				100	100	100	100	100	100	100	100	100

Pumps

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)	Cat 5, 6: German upper bound	2.50E-10	5.00E-09	1.00E-07	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02
	2 (> 1,500)		2.50E-10	5.00E-09	1.00E-07	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02
	3 (> 5,000)		2.50E-10	5.00E-09	1.00E-07	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02
	4 (> 25,000)		2.50E-10	5.00E-09	1.00E-07	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02
	5 (> 100,000)		2.50E-10	5.00E-09	1.00E-07	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02
	6 (> 500,000)		4.00E-11	2.00E-09	1.00E-07	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02	3.89E-02	3.89E-02	5.56E-02
Bonnet Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Nozzle	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Flywheel	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Pumps

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)	5% LB (%)	Mid Value (%)	5% UB (%)
1 (> 100)				100	100	100	100	100	100	100	100	100
2 (> 1,500)				100	100	100	100	100	100	100	100	100
3 (> 5,000)				100	100	100	100	100	100	100	100	100
4 (> 25,000)				100	100	100	100	100	100	100	100	100
5 (> 100,000)				100	100	100	100	100	100	100	100	100
6 (> 500,000)				100	100	100	100	100	100	100	100	100

Valves

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			5% LB (cal-yr ⁻¹)	Mid Value (cal-yr ⁻¹)	5% UB (cal-yr ⁻¹)	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio	5% LB Ratio	Mid Value Ratio	5% UB Ratio
Body	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Bonnet Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Bonnet	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Valves

LOCA Category (gpm)	5% LB (%)	Mid Value (%)	5% UB (%)
---------------------	-----------	---------------	-----------

Participant J

Reactor Pressure Vessel

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			% LB (cal-yr-1)	Mid Value (cal-yr-1)	% UB (cal-yr-1)	% LB Ratio	Mid Value Ratio	% UB Ratio	% LB Ratio	Mid Value Ratio	% UB Ratio	% LB Ratio	Mid Value Ratio	% UB Ratio
Body	1 (> 100)	Participant developed his own base case numbers	2.13E-08	1.75E-07	2.14E-06	1.00E+00	1.00E+00	1.00E+00	2.00E+00	2.00E+00	2.00E+00	3.00E+00	3.00E+00	3.00E+00
	2 (> 1,500)		3.94E-10	2.43E-08	1.49E-06	1.00E+00	1.00E+00	1.00E+00	2.00E+00	2.00E+00	2.00E+00	3.00E+00	3.00E+00	3.00E+00
	3 (> 5,000)		2.74E-14	1.92E-12	1.92E-10	1.00E+00	1.00E+00	1.00E+00	2.03E+00	2.03E+00	2.03E+00	1.69E+01	1.69E+01	1.69E+01
	4 (> 25,000)		1.00E-16	7.76E-15	1.58E-12	1.00E+00	1.00E+00	1.00E+00	6.33E+00	6.33E+00	6.33E+00	2.07E+03	2.07E+03	2.07E+03
	5 (> 100,000)		1.00E-16	7.76E-15	1.58E-12	1.00E+00	1.00E+00	1.00E+00	6.33E+00	6.33E+00	6.33E+00	2.07E+03	2.07E+03	2.07E+03
	6 (> 500,000)		1.00E-16	7.76E-15	1.58E-12	1.00E+00	1.00E+00	1.00E+00	6.33E+00	6.33E+00	6.33E+00	2.07E+03	2.07E+03	2.07E+03
CRDM	1 (> 100)	Participant developed his own base case numbers	2.22E-07	4.62E-06	7.37E-05	1.00E+00	1.00E+00	1.00E+00	3.88E+01	3.88E+01	3.88E+01	1.74E+04	1.74E+04	1.74E+04
	2 (> 1,500)		1.09E-08	2.51E-07	1.75E-05	1.00E+00	1.00E+00	1.00E+00	5.47E+01	5.47E+01	5.47E+01	2.91E+04	2.91E+04	2.91E+04
	3 (> 5,000)		1.09E-08	8.52E-08	5.69E-06	1.00E+00	1.00E+00	1.00E+00	7.44E+01	7.44E+01	7.44E+01	4.36E+04	4.36E+04	4.36E+04
	4 (> 25,000)		1.09E-08	8.52E-08	2.50E-06	1.00E+00	1.00E+00	1.00E+00	7.44E+01	7.44E+01	7.44E+01	4.36E+04	4.36E+04	4.36E+04
	5 (> 100,000)													
	6 (> 500,000)													
CRDM Connections	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Nozzles	1 (> 100)	Participant developed his own base case numbers	4.58E-14	1.33E-12	7.46E-11	1.00E+00	1.00E+00	1.00E+00	6.48E+01	6.48E+01	6.48E+01	2.66E+04	2.66E+04	2.66E+04
	2 (> 1,500)		2.99E-15	7.13E-14	1.00E-11	1.00E+00	1.00E+00	1.00E+00	8.25E+01	8.25E+01	3.49E+04	3.49E+04	3.49E+04	
	3 (> 5,000)		2.03E-15	4.07E-14	1.17E-11	1.00E+00	1.00E+00	1.00E+00	8.57E+01	8.57E+01	3.64E+04	3.64E+04	3.64E+04	
	4 (> 25,000)		1.21E-16	2.42E-15	1.77E-12	1.00E+00	1.00E+00	1.00E+00	8.97E+01	8.97E+01	3.82E+04	3.82E+04	3.82E+04	
	5 (> 100,000)		1.21E-16	2.42E-15	1.77E-12	1.00E+00	1.00E+00	1.00E+00	8.97E+01	8.97E+01	3.82E+04	3.82E+04	3.82E+04	
	6 (> 500,000)		1.21E-16	2.42E-15	1.77E-12	1.00E+00	1.00E+00	1.00E+00	8.97E+01	8.97E+01	3.82E+04	3.82E+04	3.82E+04	
In-Core Instrumentation	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Head Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Other penetrations	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Reactor Pressure Vessel

LOCA Category (gpm)	% LB (%)	Mid Value (%)	% UB (%)	% LB (%)	Mid Value (%)	% UB (%)	% LB (%)	Mid Value (%)	% UB (%)
1 (> 100)		Total (input)	100	100	100	100	100	100	100
2 (> 1,500)		Total (input)	100	100	100	100	100	100	100
3 (> 5,000)		Total (input)	100	100	100	100	100	100	100
4 (> 25,000)		Total (input)	100	100	100	100	100	100	100
5 (> 100,000)		Total (input)	100	100	100	100	100	100	100
6 (> 500,000)		Total (input)	100	100	100	100	100	100	100

Pumps

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			% LB (cal-yr-1)	Mid Value (cal-yr-1)	% UB (cal-yr-1)	% LB Ratio	Mid Value Ratio	% UB Ratio	% LB Ratio	Mid Value Ratio	% UB Ratio	% LB Ratio	Mid Value Ratio	% UB Ratio
Body	1 (> 100)	Participant developed his own base case numbers												
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Bonnet Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Nozzle	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Flywheel	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Pumps

LOCA Category (gpm)	% LB (%)	Mid Value (%)	% UB (%)	% LB (%)	Mid Value (%)	% UB (%)	% LB (%)	Mid Value (%)	% UB (%)
1 (> 100)		Total (input)	100	100	100	100	100	100	100
2 (> 1,500)		Total (input)	100	100	100	100	100	100	100
3 (> 5,000)		Total (input)	100	100	100	100	100	100	100
4 (> 25,000)		Total (input)	100	100	100	100	100	100	100
5 (> 100,000)		Total (input)	100	100	100	100	100	100	100
6 (> 500,000)		Total (input)	100	100	100	100	100	100	100

Valves

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			% LB (cal-yr-1)	Mid Value (cal-yr-1)	% UB (cal-yr-1)	% LB Ratio	Mid Value Ratio	% UB Ratio	% LB Ratio	Mid Value Ratio	% UB Ratio	% LB Ratio	Mid Value Ratio	% UB Ratio
Body	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Bonnet Bolts	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													
Bonnet	1 (> 100)													
	2 (> 1,500)													
	3 (> 5,000)													
	4 (> 25,000)													
	5 (> 100,000)													
	6 (> 500,000)													

Percent Contributions for Valves

LOCA Category (gpm)	% LB (%)	Mid Value (%)	% UB (%)	% LB (%)	Mid Value (%)	% UB (%)	% LB (%)	Mid Value (%)	% UB (%)
1 (> 100)		Total (input)	100	100	100	100	100	100	100
2 (> 1,500)		Total (input)	100	100	100	100	100	100	100
3 (> 5,000)		Total (input)	100	100	100	100	100	100	100
4 (> 25,000)		Total (input)	100	100	100	100	100	100	100
5 (> 100,000)		Total (input)	100	100	100	100	100	100	100
6 (> 500,000)		Total (input)	100	100	100	100	100	100	100

Pressurizer

Component	LOCA Category (gpm)	Base Case	LOCA Frequency for System			25 Years of Plant Operation			40 Years of Plant Operation			60 Years of Plant Operation		
			% LB (cal-yr-1)	Mid Value (cal-yr-1)	% UB (cal-yr-1)	% LB Ratio	Mid Value Ratio	% UB Ratio	% LB Ratio					

