

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>M. Two or more low pressure ECCS injection/spray subsystems inoperable for reasons other than Condition C, D, or F.</p> <p><u>OR</u></p> <p>HPCI System and one or more ADS valves inoperable.</p>	M.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.5.1.1 Verify, for each low pressure ECCS injection/spray subsystem, the piping is filled with water from the pump discharge valve to the injection valve.</p>	31 days
<p>SR 3.5.1.2 Verify each ECCS injection/spray subsystem manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.</p>	31 days
<p>SR 3.5.1.3 Verify ADS pneumatic pressure is as follows for each required ADS pneumatic supply:</p> <ul style="list-style-type: none"> a. S/RV Accumulator Bank header pressure \geq 88.3 psig; and b. Alternate Nitrogen System pressure is \geq 410 psig. 	31 days