From: Lynnea Wilkins
To: MLARSON@entergy.com
Date: 2/27/2008 4:04:45 PM
Subject: **DRAFT** RAI for MD 7758 - Grand Gulf SRV relief reqest

Mike,

The draft RAIs for Relief Request VRR-GGNS-2007-2 (MD7757) are provided below.

Please let me know your convenient times and dates in the next week to schedule a conference call to ensure that the questions are clearly understood and to obtain the date of the responses to the RAIs.

Thanks

Relief Request VRR-GGNS-2007-2, MD7757

1. Verify [acknowledge that it is true] that Valves 1B21-F041K, 1B21-F041F, 1B21-F051F, 1B21-F051B, 1B21-F041D, 1B21-F047D were refurbished to a like-new condition prior to being placed in storage and later installed in October 2005. Verify that Valves 1B21-F047L, 1B21-F041G, 1B21-F047G, 1B21-F051C and 1B21-F047C were refurbished to a like-new condition prior to being placed in storage and later installed in March 2007.

2. Discuss if the controlled environment for the storage of Valves 1B21-F041K, 1B21-F041F, 1B21-F051F, 1B21-F051B, 1B21-F041D, 1B21-F047D, 1B21-F047L, 1B21-F041G, 1B21-F047G, 1B21-F051C and 1B21-F047C was equipped to prevent condensation and corrosion.

3. Please provide test results for Dikkers Model G-471 safety relief valves (SRVs) that were maintained in a controlled environment similar to the GGNS controlled environment for an extended period of time and setpoint tested prior to actual installation. As an alternative, discuss why the as-found set-pressure test results for Dikkers Model G-471 SRVs provided in a letter dated September 28, 2007 (Agencywide Documents Access and Management System Accession No. ML072740030) are be applicable to the GGNS SRVs.

Lynnea Wilkins
General Engineer, NSPDP
NRR/DORL/LPL4
301-415-1377

CC: Bhalchandra Vaidya

Mail Envelope Properties (47C5D06D.261 : 11 : 10422)

Subject: **DRAFT** RAI for MD 7758 - Grand Gulf SRV relief reqest
Creation Date 2/27/2008 4:04:45 PM
From: Lynnea Wilkins

Created By: LEW2@nrc.gov

Recipients
entergy.com
MLARSON (MLARSON@entergy.com)

nrc.gov
TWGWPO04.HQGWDO01
BKV CC (Bhalchandra Vaidya)

Post Office	**Route**
	entergy.com
TWGWPO04.HQGWDO01	nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	2631	2/27/2008 4:04:46 PM
TEXT.htm	1996	

Options
Expiration Date: None
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No
Security: Standard