

#9105090262 50-390
w/ltb. dtd. 4/30/91


-NOTICE-

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE INFORMATION & REPORTS MANAGEMENT BRANCH. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS & ARCHIVES SERVICES SECTION P1-22 WHITE FLINT. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

-NOTICE-

WATTS BAR NUCLEAR PLANT UNIT 1

TENNESSEE VALLEY AUTHORITY



SUPPLEMENTAL INFORMATION-
TVA'S COMPLIANCE TO 10 CFR50.49-
ENVIRONMENTAL QUALIFICATION OF
ELECTRIC EQUIPMENT
IMPORTANT TO SAFETY FOR
NUCLEAR POWER PLANTS

SUPPLEMENTAL INFORMATION
TVA'S COMPLIANCE TO 10CFR50.49 - ENVIRONMENTAL QUALIFICATION
OF ELECTRIC EQUIPMENT IMPORTANT TO SAFETY
FOR NUCLEAR POWER PLANTS
VOLUME 3

TABLE OF CONTENTS

BINDER NUMBER	REVISION	EQUIPMENT TYPE	VENDOR
WBNEQ-ITE-001	1	Strap-On RTD (Minco)	Westinghouse
WBNEQ-ITE-003	1	Resistance Temperature Detector (RCS Well-Mounted)	RdF
WBNEQ-ITE-004	2	Resistance Temperature Detector (Fast Response Well-Mounted)	RdF
WBNEQ-ITS-001	3	Temperature Switches	Fenwal
WBNEQ-ITS-002	4	Temperature Switches	Static-O-Ring
WBNEQ-IZS-001	4	EA 180 Series Limit Switches Manufactured after 7/30/80	Namco
WBNEQ-IZS-002	2	EA 180 Series Limit Switches Manufactured between 9/5/78 and 7/30/80	Namco
WBNEQ-IZS-003	3	EA 740 Limit Switches Manufactured after 10/01/81	Namco
WBNEQ-IZS-004	3	EA 740 Limit Switches Manufactured between 2/20/78 and 10/01/81	Namco
WBNEQ-IZS-005	0	EA 180 Limit Switches Manufactured after December 1986	Namco
WBNEQ-JBOX-001	4	Junction Boxes	Various

UNIT DEVICE ID NO.	MODEL NUMBER	LOCATION	ELEV(1)	RELEASE CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TE -068-0373 REAC LEVEL CAP TUBE TEMP COMP	-D 1-TE -068-0373 S8809	709*11" LC 71C62-54114-1			A A A A A	1000 1000 1000 1MO 1MO		L FW/C MS/C RH/C CV/C ACCURATE REACTOR VESSEL LEVEL INDICATION IS REQUIRED FOR ALL EVENTS AND REQUIRES TEMPERATURE COMPENSATION.
WBN-1-TE -068-0376 REAC LEVEL CAP TUBE TEMP COMP	-D 1-TE -068-0376 S8810	708* 2" LC 71C62-54114-1			A A A A A	1000 1000 1000 1MO 1MO		L FW/C MS/C RH/C CV/C ACCURATE REACTOR VESSEL LEVEL INDICATION IS REQUIRED FOR ALL EVENTS AND REQUIRES TEMPERATURE COMPENSATION.
WBN-1-TE -063-0377 REAC LEVEL CAP TUBE TEMP COMP	-D 1-TE -063-0377 S8809	714* 4" LC 71C62-54114-1			A A A A A	1000 1000 1000 1MO 1MO		L FW/C MS/C RH/C CV/C ACCURATE REACTOR VESSEL LEVEL INDICATION IS REQUIRED FOR ALL EVENTS AND REQUIRES TEMPERATURE COMPENSATION.
WBN-1-TE -068-0378 REAC LEVEL CAP TUBE TEMP COMP	-D 1-TE -068-0378 S8809	752*10" LC 71C62-54114-1			A A A A A	1000 1000 1000 1MO 1MO		L FW/C MS/C RH/C CV/C ACCURATE REACTOR VESSEL LEVEL INDICATION IS REQUIRED FOR ALL EVENTS AND REQUIRES TEMPERATURE COMPENSATION.
WBN-1-TE -068-0379 REAC LEVEL CAP TUBE TEMP COMP	-D 1-TE -068-0379 S8809	727* 8" LC 71C62-54114-1			A A A A A	1000 1000 1000 1MO 1MO		L FW/C MS/C RH/C CV/C ACCURATE REACTOR VESSEL LEVEL INDICATION IS REQUIRED FOR ALL EVENTS AND REQUIRES TEMPERATURE COMPENSATION.

PREPARER/DATE GJB 4/21/86
 CHECKED/DATE SRP 4/23/86
 R. J. 6/6/89
 1-16-89

PAGE A-1 RI

WATTS BAR NU CLAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQUIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZNITH	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
			ELEV(1)	SM/RAD CONISACT				
WBN-1-TE -068-0380 REAC LEVEL CAP TUBE TEMP COMP	-E 1-TE -068-0380 S8809	-E 220	713' 3" LC		A	100D	L	ACCURATE REACTOR VESSEL LEVEL
			71C62-54114-1		A	100D	FW/C	INDICATION IS REQUIRED FOR ALL
					A	100D	MS/C	EVENTS AND REQUIRES
					A	1MO	RH/C	TEMPERATURE COMPENSATION.
					A	1MO	CV/C	
WBN-1-TE -068-0383 REAC LEVEL CAP TUBE TEMP COMP	-E 1-TE -068-0383 S8810	-E 090	706' 10" LC		A	100D	L	ACCURATE REACTOR VESSEL LEVEL
			71C62-54114-1		A	100D	FW/C	INDICATION IS REQUIRED FOR ALL
					A	100D	MS/C	EVENTS AND REQUIRES
					A	100D	RH/C	TEMPERATURE COMPENSATION.
					A	100D	CV/C	
WBN-1-TE -068-0384 REAC LEVEL CAP TUBE TEMP COMP	-E 1-TE -068-0384 S8809	-E	71C62-54114-1		A	100D	L	ACCURATE REACTOR VESSEL LEVEL
					A	100D	FW/C	INDICATION IS REQUIRED FOR ALL
					A	100D	MS/C	EVENTS AND REQUIRES
					A	1MO	RH/C	TEMPERATURE COMPENSATION.
					A	1MO	CV/C	
WBN-1-TE -068-0385 REAC LEVEL CAP TUBE TEMP COMP	-E 1-TE -068-0385 S8809	-E 002	753' LC		A	100D	L	ACCURATE REACTOR VESSEL LEVEL
			71C62-54114-1		A	100D	FW/C	INDICATION IS REQUIRED FOR ALL
					A	100D	MS/C	EVENTS AND REQUIRES
					A	1MO	RH/C	TEMPERATURE COMPENSATION.
					A	1MO	CV/C	
WBN-1-TE -068-0386 REAC LEVEL CAP TUBE TEMP COMP	-E 1-TE -068-0386 S8809	-E 084	733' 9" LC		A	100D	L	ACCURATE REACTOR VESSEL LEVEL
			71C62-54114-1		A	100D	FW/C	INDICATION IS REQUIRED FOR ALL
					A	100D	MS/C	EVENTS AND REQUIRES
					A	1MO	RH/C	TEMPERATURE COMPENSATION.
					A	1MO	CV/C	

PREPARER/DATE GJB 4/21/86

CHECKED/DATE SRP 4/23/86

R J
 68m
 4/19/89
 HSR
 1-16-89

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	ALMTH	ELEV(1) CONTRACT	RH/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TE -068-0393 REAC LEVEL CAP TUBE TEMP COMP	-E 1-TE -068-0393 S8809	-E 218	707' 71062-54114-1	LC	A	100D	L	ACCURATE REACTOR VESSEL LEVEL INDICATION IS REQUIRED FOR ALL EVENTS AND REQUIRES TEMPERATURE COMPENSATION.
					A	100D	FW/C	
					A	1M0	MS/C	
					A	1M0	RH/C	
					A	1M0	CV/C	

PAGE A-3

RI

PREPARED/DATE: GJB 4/21/86
 CHECKED/DATE: SRP 4/23/86
 R-1
 6/8/89
 1-16-89

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R 1 R _____
BINDER TITLE MINCO RTD COMPUTED E. C. McKe DATE 12/19/88
CHECKED NOR DATE 12-27-88

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-1 for source of Category and Operating Time assignments.

BINDER NO. WBNEO-ITE-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 27
R 1 R _____
BINDER TITLE MINCO RTD COMPUTED GJB DATE 4/16/86 12/11/88
CHECKED SRP DATE 4/23/86 2/28/88
12-27-88

A. DOCUMENTATION

Equipment Description Resistance Temperature Detector (RTD)
Vendor/Manufacturer Minco Products, Inc.
Equipment Model No.(s) S8809
S8810

QUALIFICATION REPORTS

(1) Title/Number/Revision Equipment Qualifica- RIMS B45 850614 354
tion Test Report - Minco Surface Mounted
RTDs/WCAP-8687, Supp. 2-E42A, Rev. 1 DATE January 1985

OTHER (ANALYSIS, VENDOR DATA, ETC.) _____

(2) TVA Environmental Data Drawing 47E235-42 R2

(3) Category and Operating Times Calculation, System 68, R8
(WBNOSG4-017, B45 860722 218)

(4) Westinghouse Equipment Qualification Data Package,
EODP-ESE-42A R1 (B45 851030 356)

(5) Westinghouse Auditable Link Document for Unit 1, EQUAL-WAT,
Rev. 2, January, 1985, (B45 850321 352)

(6) Westinghouse Drawing 2654C65, Rev. 8

(7) Minco Products, Inc. Drawing S8809, sheets 1 and 2, Rev. C

(8) Minco Products, Inc. Drawing S8810, sheets 1 and 2, Rev. C

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

R1

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 2 OF 27
BINDER TITLE MINCO RTD COMPUTED DCB DATE 5/18/86 R R
CHECKED SRP/2K DATE 5/18/86

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified (Pending Satisfactory Resolution of Open Items)
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES _____

1) Section F - Conduit and Grounding Drawing 45W860-9 must be revised to show a connection that is qualified for submergence.

See open item sheets at the front of the binder for documentation of open items that apply to the other tabs in this binder.

COMMENTS/RECOMMENDATIONS _____

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 3 OF 27
 BINDER TITLE MINCO RTD COMPUTED YGB DATE 4/16/86 R R
 CHECKED CSA DATE 4/27/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- X Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS This equipment was bought under the scope of Change of Contract 128 on the WBN NSSS contract with Westinghouse, dated January 31, 1980 (QEB 800214 111 - TAB E6).

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 4 OF 27
R 1 R
BINDER TITLE MINCO RTD COMPUTED GJB DATE 5/23/86 EC/17
5/17/86
CHECKED SRP/DLK DATE 5/27/86 2/27
12-27-88

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Reference QR(1), pages 24 and 31-35 (TAB D) specifies the equipment tested. The Field Verification Data (TAB F) specifies what is installed at the plant. The Traceability Package (TAB E11) links the plant RTD serial numbers to the WBN NSSS contract and the Purchase Order No. The Westinghouse Audit-able Link Document, EQAL-WAT, Item ESE-42, p. 9 (TAB E9) links the Purchase Order number to the test report. Westinghouse letter WAT-D-6920 (B45 860328 600) - In Traceability Package - TAB E11) also links the test report in TAB D to the Watts Bar contract. R1

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 5 OF 27
 BINDER TITLE MINCO RTD COMPUTED BJB DATE 4/17/86 R R
 CHECKED SA DATE 4/27/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>RTD</u>	<u>SAME</u>	<u>QR(1), page 24</u>
(2) Manufacturer	<u>MINCO</u>	<u>SAME</u>	<u>QR(1), page 1</u>
(3) Model Number(s)	<u>S8809</u>	<u>SAME</u>	<u>QR (1), page 24</u>
	<u>S8810</u>	<u>SAME</u>	<u>QR(1), page 24</u>
(4) Serial Number(s)	<u>See TAB F</u>	<u>146</u>	<u>QR(1), p.24</u>
		<u>039</u>	<u>QR(1), p.24</u>
		<u>058</u>	<u>QR(1), p.24</u>
		<u>041</u>	<u>QR(1), p.24</u>
(5) Identify Component-Unique checksheet attached:	<u>NA</u>		

JUSTIFICATION/COMMENTS The model numbers have extra characters on the end which designates the size of the tube the RTD block fits. However, this does not affect qualification, as stated in the test report (QR(1)) conclusions on pages 20 and 21. Therefore, these additional characters will not be shown on the model numbers listed above.

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 6 OF 27
 R 1 R _____
 BINDER TITLE MINCO RTD COMPUTED GJB DATE 5/15/86 EEH
12/17/88
 _____ CHECKED SRP DATE 5/18/86 ZOR
12-27-88

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification. R1

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NONE</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NONE</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>See Comments Below</u>	<u>NA</u>	<u>NA</u>
Conduit Seals	<u>See Comments Below</u>	<u>NA</u>	<u>NA</u>
Connector Seals	<u>NONE</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>NONE</u>	<u>NA</u>	<u>NA</u>
Physical Configuration	<u>Install per Westing-house Drawing 2654C65 *</u>	<u>No</u>	<u>QR(1), p.7.</u>
Other	<u>NONE</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS The moisture intrusion problem exhibited in the test via the insulation resistance data taken (QR(1), p.35) prompted the issuance of SCR WBNNEB8506 (TAB E7) which requires the ethylene propylene lead wires of all these RTDs (not just the submerged devices) to be protected by a watertight connection. This connection is shown on TVA Drawing 45W860-9 (TAB E8). The configuration shown includes a Conax connector, which is qualified per binder WBNEQ-CSC-001, and Raychem splices, which are qualified per binder WBNEQ-SPLC-001. R1

*This drawing has not had any changes made, since the one called out in the test report, that affect qualification (TAB E12). R1

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 7 OF 27
 BINDER TITLE MINCO RTD COMPUTED DJB DATE 4/16/86 R R
 CHECKED CSL DATE 4/22/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>YES</u>	<u>QR(1), pp. 13 & 31-34</u>
(b) Baseline performance measurements taken	<u>YES</u>	<u>QR(1), pp.31-34</u>
(c) Equipment aged:		
Thermal	<u>YES</u>	<u>QR(1), p.17</u>
Radiation	<u>YES</u>	<u>QR(1), p.17</u>
Wear	<u>NA</u>	<u>NA</u>
(d) Vibration/seismic testing conducted	<u>YES</u>	<u>QR(1), p. 18, App. B & C</u>
(e) Design basis event (DBE) exposure	<u>YES</u>	<u>QR(1), p.19</u>
(f) Post-DBE exposure	<u>YES</u>	<u>QR(1), pp.12, 19 & 131-134</u>
(g) Final inspection and disassembly	<u>YES</u>	<u>QR(1), pp.19, 48 & 31-35</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? YES

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? YES
 (Reference QR(1), pp. 25-28).

JUSTIFICATION/COMMENTS (1)(c) - Wear - This type of aging is not applicable to an RTD because it is a passive device with no moving parts.

(1)(g) - Disassembly - As far as can be ascertained from the test report, no disassembly was performed as part of the final inspection, just a visual inspection, calibration and insulation resistance checks.

(3) Test equipment accuracies were not included, but are available for audit or inspection at Westinghouse.

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 8 OF 27

BINDER TITLE MINCO RTD COMPUTED DGB DATE 4/16/86 R R

CHECKED CAF DATE 4/20/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? YES (Reference QR(1), pp. 3,6,9,14 and 17).

JUSTIFICATION/COMMENTS NONE

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>YES</u>	<u>QR(1), pp. 6, 9,14 & 17</u>
Radiation exposure	<u>YES</u>	<u>QR(1), pp. 3,6, 7,9,15 & 17</u>
Vibration (non-seismic) aging	<u>NO</u>	<u>NA</u>
Operational (electrical/mechanical/process) stress aging	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Vibration Aging - The omission of this type of test is justified because: 1) No problems were encountered in the seismic test. 2) RTDs are passive devices with no moving or loose parts. 3) The surveillance and maintenance program is adequate to correct any problems that might arise from this aging effect such as loosened bolts and nuts.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference).

JUSTIFICATION/COMMENTS NUREG-0588 Category II requirements do not require that synergistic effects be addressed.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? YES (Reference QR(1), pp. 3,6,9,14 & 17).

JUSTIFICATION/COMMENTS NONE

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 9 OF 27

BINDER TITLE MINCO RTD COMPUTED WGS DATE 4/16/86 R R

CHECKED CS DATE 4/27/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? YES (Reference: QR(1), p. 9).

JUSTIFICATION/COMMENTS NONE

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? YES (Reference QR(1), p.3).

JUSTIFICATION/COMMENTS Also see Westinghouse letters TVA-85-176 and TVA-85-172 in TAB E1 and E2 respectively.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? YES (Reference QR(1), p. 9 and Westinghouse letter TVA-85-176 (B70 850925 006) - TAB E1.

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>120°F</u>	<u>250°F</u>	<u>120°F</u>
Time	<u>40 years</u>	<u>504h</u>	<u>21.8 years</u>

JUSTIFICATION/COMMENTS See TAB C1 for calculation extending the qualified life.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? YES (Reference QR(1), p. 9 and TAB C1).

JUSTIFICATION/COMMENTS NONE

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? YES (Reference Westinghouse letter TVA-85-172 (B70 850925 002)-TAB E2).

JUSTIFICATION/COMMENTS NONE

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 10 OF 27
 BINDER TITLE MINCO RTD COMPUTED gag DATE 4/16/86 R R
 CHECKED GA DATE 4/23/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? NA (Reference).

JUSTIFICATION/COMMENTS NONE

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? YES (Reference QR(1), p. 14).

JUSTIFICATION/COMMENTS NONE

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? YES (Reference QR(1), p.3).

JUSTIFICATION/COMMENTS NONE

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? NA (Reference).

JUSTIFICATION/COMMENTS This was not necessary, as a test was performed on the assembled device.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? YES
 (Reference QR(1), p. 3 and Westinghouse letter TVA-85-172 (B70 850925 002) - TAB E2).

JUSTIFICATION/COMMENTS NONE

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 11 OF 27
R 1 R
BINDER TITLE MINCO RTD COMPUTED GJB DATE 4/16/86 25/7
12/17/86
CHECKED SRP DATE 4/23/86 2/8/86
12-27-86

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: OR(1) p. 17 and Westinghouse letter TVA-85-172 (B70 850925 002)-TAB E2).

Plant normal ambient radiation dose (rd) 5.45×10^7 (21.8 yr. dose)

Test exposure dose (rd) 1.6×10^8

Test exposure dose rate (rd/hr) 2.18×10^6

Test exposure source type (e.g., Co-60 gamma) Co - 60 gamma

JUSTIFICATION/COMMENTS (1) Worst case 40 year normal dose is 1×10^8 rads. (2) Normal and Accident Doses were combined in the test.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* No (Reference: _____).

JUSTIFICATION/COMMENTS See Justification/Comments for H(2) on page 8 of this TAB.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? NA (Reference: _____).

JUSTIFICATION/COMMENTS NONE

*Qualification program refers to the test report and any supplemental documentation including TVA analyses in Tab C of the binder. | R1

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 12 OF 27
R 1 R _____
BINDER TITLE MINCO RTD COMPUTED GJB DATE 4/16/86 E.E. 117
12/15/86
CHECKED SRP DATE 4/23/86 Z/SK
12-27-86

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? NA (Reference: _____).

JUSTIFICATION/COMMENTS None

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? NA (Reference: _____).

JUSTIFICATION/COMMENTS None

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes (Reference: QR(1), p. 9).

Qualified life (Document in QMDS) 21.8 years

JUSTIFICATION/COMMENTS See TAB C1.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes (Reference: TAB C1).

JUSTIFICATION/COMMENTS No specific replacement intervals for any components of the RTD were specified in the qualification program. The instruction manual states that no periodic maintenance is required.

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 13 OF 27

BINDER TITLE MINCO RTD COMPUTED DGA DATE 4/16/86 R R

CHECKED SAR DATE 4/23/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Hypalon/Elongation/ Wire Jacket</u>	<u>NA</u>	<u>NA</u>	<u>1.13</u>	<u>Westinghouse letter TVA-85-172 (B70 850925 002) TAB E2</u>
(b) <u>Epoxy/Flexural Strength/ Potting Material</u>	<u>NA</u>	<u>NA</u>	<u>0.98</u>	<u>"</u>
(c) <u>EPR/Dielectric Strength/ Wire Insulation</u>	<u>NA</u>	<u>NA</u>	<u>0.90</u>	<u>"</u>
(d) _____	_____	_____	_____	_____
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS 1) Radiation values were not given in the test report because the equipment underwent radiation testing which was successfully completed. 2) See TAB C1 for Arrhenius Calculations.

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 14 OF 27

BINDER TITLE MINCO RTD COMPUTED gjb DATE 4/16/86 R R

CHECKED gjb DATE 4/27/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? YES (Reference QR(1), p.5).

Identify Acceptance Criteria: 1) Insulation resistance must be greater than 500,000 ohms to guarantee a functional accuracy of $\pm 1.0^{\circ}\text{F}$.

2) Repeatability of the calibration must be $\pm 0.2^{\circ}\text{F}$.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? YES (Reference QR(1), pp. 13, 14, & 135

-142).

Identify baseline and functional testing: 1) Calibration measurements before and after each test to verify repeatability. 2) Analog and digital recordings for verifying continuous operability during testing.

3) Insulation resistance measurements before, during and after HELB simulation to verify accuracy.

JUSTIFICATION/COMMENTS None

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? NA (Reference).

JUSTIFICATION/COMMENTS Insulation resistance measurements were taken periodically throughout the LOCA test, as documented on page 35 of the test report (TAB D). Measurement of the performance was by evaluation of the recorded RTD outputs (QR(1), pp. 131-142). Insulation resistance was selected to guarantee functional accuracy. Load is an irrelevant parameter for these RTDs.

12-27-88

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

(4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? NA (Reference: _____).

JUSTIFICATION/COMMENTS Baseline testing consisted of calibration checks at various temperatures (QR(1), pp. 31-34). Load is an irrelevant parameter for these RTDs. Baseline testing is considered acceptable based on the application.

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>NA</u>	<u>NA</u>
Load	<u>NA</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>See Open Item 2</u>	
Other(s)		

R1

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 16 OF 27

R 1 R

BINDER TITLE MINCO RTD COMPUTED GJB DATE 5/23/86

CHECKED SRP DATE 5/27/86

for
12-27-88

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>NA</u>	<u>NA</u>
Load	<u>NA</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>±5°F</u>	Westinghouse EQDP-ESE-42A R1 p. 14 (TAB E10)
Other(s)		

JUSTIFICATION/COMMENTS (1) See discussion in Section P on page 26 of this TAB on response time. (2) Applied voltage is 10VDC maximum across sensor resistance (TAB I - Note 5 on Minco drawings S8809 and S8810. (3) See Section M(5) Comments for a discussion on insulation resistance values and their relationship to accuracy. | R1

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>NA</u>	
Load	<u>NA</u>	
Frequency	<u>NA</u>	
Accuracy	<u>±1°F</u>	Westinghouse EQDP-ESE-42A, R1 p.14 (TAB E10)
Other(s)		

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 17 OF 27
 R 1 R
 BINDER TITLE MINCO RTD COMPUTED GJB DATE 4/16/86 5/2/87
12/11/86
 CHECKED SRP DATE 4/23/86 7/02
12-27-88

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-42, (Lower Containment) | R1

- | | |
|--|---------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>120</u> | (a) Temperature (°F) <u>130</u> |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>100</u> |
| (d) Radiation (rd) <u>5.45 x 10⁷*</u>
(21.8 yr dose) | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: The RTD is in direct contact with the capillary instrument lines of the reactor vessel level transmitters; however, these are static lines at ambient temperature. Therefore, there is no additional heat contribution from the process line over and above that of the ambient containment temperature.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Frequency = less than 1% of plant life; Duration - 8 hours maximum.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|---|-------------------------------------|
| (a) Temperature (°F) <u>327</u> | Accident type <u>HELB/LOCA</u> |
| (b) Pressure (psig) <u>11.2</u> | Accident type <u>LOCA</u> R1 |
| (c) Humidity (%) <u>100</u> | Accident type <u>HELB/LOCA</u> |
| (d) Radiation (rd) <u>4.7 x 10⁸ beta</u> | Accident type <u>LOCA</u> R1 |
| (e) Spray Type <u>2000 ppm Boron,</u> | Accident type <u>HELB/LOCA</u> R1 |
| <u>0.033 Molar NaOH pH 8.3 @ 25°C</u> | |
| <u>for 30 days at 0.92 gpm/ft²</u> | |

*Calculated from a worst case 40 yr. dose of 1×10^8 rads as shown on drawing 47E235-42. | R1

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 27
 R 1 R _____
 BINDER TITLE MINCO RTD COMPUTED GJB DATE 4/16/86 12/19/88
 _____ CHECKED SRP DATE 4/23/86 12-27-88

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): _____

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes

(Reference: 47E235-42, Note 46 _____). R1

- (7) Subject to submergence (Yes/No/NA)? Yes (Reference: TAB C). R1

Identify initiation time and duration of submergence: At the beginning of a LOCA and for 100 days thereafter.

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes

(Reference: WCAP-8687, supp. 2-E42A, pg. 3 _____).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: A beta

dose of 9×10^8 rads is equivalent to a gamma dose of 2×10^7 R1

rads. Since the actual plant beta dose is 4.7×10^8 rads, a

gamma equivalent of 2×10^7 rads can be conservatively assumed

in calculating the TID and that is reflected in the specified

dose given in Section L(1) on page 19 of this TAB.

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

_____	_____
_____	_____
_____	_____

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 19 OF 27
 R 1 R _____
 BINDER TITLE MINCO RTD COMPUTED GJB DATE 5/01/86 5/1/86
 _____ CHECKED SRP/DLK DATE 5/08/86 5/8/86
 _____ 12-27-88

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>13 days</u>	QR(1), App. D, p. 132
Temperature (°F)	<u>327</u>	<u>420</u>	QR(1), pp. 4,19 & 131-132
Pressure (psig)	<u>11.2</u>	<u>75</u>	QR(1), pp. 19 & 133-134 R1
Relative Humidity (%)	<u>100</u>	<u>100</u>	QR(1), p. 12
Chemical Spray*	<u>2000 Boron, pH 8.35, 0.033 Molar NaOH, 0.92 gpm/ft², 30 days 1.145 x 10⁸ gamma</u>	<u>2750ppm Boron pH 10.7, 24 hrs</u>	QR(1), p. 41 & TAB C R1
Radiation (rd)** (See K(5)comments)		<u>1.6 x 10⁸ gamma</u>	QR(1), p.17
Submergence	<u>Yes</u>	<u>No</u>	TAB C R1

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	TAB C R1
Pressure	<u>Yes</u>	QR(1), pp. 19 & 133-134
Relative Humidity	<u>Yes</u>	QR(1), p. 12
Chemical Spray	<u>Yes</u>	TAB C R1
Submergence	<u>Yes</u>	TAB C
JUSTIFICATION/COMMENTS	<u>None</u>	

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 20 OF 27

BINDER TITLE MINCO RTD COMPUTED YJB DATE 4/16/86 R R

CHECKED SP DATE 4/23/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>+93°F</u>	<u>YES</u>
Pressure: +10% but no more than 10 psig	<u>+63psig</u>	<u>YES</u>
Radiation: +10% of accident dose	<u>40%</u>	<u>YES</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>NA</u>	<u>NO</u>
Voltage: <u>+10%</u> of rated value	<u>NA</u>	<u>NA</u>
Frequency: <u>+5%</u> of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>2 dwells</u>	<u>YES</u>
Vibration: +10% added to acceleration	<u>QR(1), p.18, App B & C</u>	<u>YES</u>

JUSTIFICATION/COMMENTS: Time Margin - See the analysis in TAB C2 which demonstrates qualification for the 100 day operating time requirement.

BINDER NO. WBNEO-ITE-001 PLANT WBN UNIT(S) 1 SHEET 21 OF 27
R 1 R _____
BINDER TITLE MINCO RTD COMPUTED GJB DATE 4/16/86 12/11/88
CHECKED SRP DATE 4/23/86 12-27-88

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference: See Sheet B-1 for Category and Operating Times). | R1

JUSTIFICATION/COMMENTS These RTDs provide temperature compensation to the reactor vessel level indicators and must provide a continuous output during and after an accident to fulfill their Post-Accident Monitoring (PAM) function.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: QR(1), p. 19).

JUSTIFICATION/COMMENTS None

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (Yes/No/NA)? Yes
(Reference: QR(1), p. 19).

JUSTIFICATION/COMMENTS None

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (Yes/No/NA)? Yes (Reference: QR(1), p. 20 &

TAB C2).

JUSTIFICATION/COMMENTS None

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: QR(1), pp. 19-20, App. A).

JUSTIFICATION/COMMENTS The original test was conducted with the lead wires run outside the test chamber because the insulation on them appeared to be cracked from excessive handling. The qualification of these lead wires was proven in a separate test which is documented in Appendix A of the report.

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 22 OF 27
BINDER TITLE MINCO RTD COMPUTED DQB DATE 4/16/86 R R
CHECKED CS DATE 4/23/86

M. (5) (continued)

Insulation resistance during the HELB test is required to remain
greater than 500,000 ohms to guarantee a functional accuracy of
 $\pm 1.0^{\circ}\text{F}$ (QR(1),p.5). The insulation resistance measurements taken
during the HELB test for RTDs KK-1, KK-3, KK-4, and the dummy RTD
all had insulation resistance values of greater than 500,000 ohms
(QR(1),p.35). KK-2 exhibited unacceptable insulation resistance
due to a faulty sealing between the potting boot and the adapter
(QR(1),p.20). This is considered to be a random occurrence.
These anomalies together with their resolutions have been reviewed
and are considered to be adequately resolved. Therefore, the test
demonstrated qualification of these RTDs.

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 23 OF 27
BINDER TITLE MINCO RTD COMPUTED JGE DATE 4/16/86 R R
CHECKED CSF DATE 4/23/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? YES (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See QMDS (TAB G).

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 24 OF 27
 BINDER TITLE MINCO RTD COMPUTED YJB DATE 4/16/86 R R
 CHECKED CSF DATE 4/23/86

0. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|---|------------------|
| (1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)? | <u>YES</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified? | <u>NA</u> |
| (3) Choice of qualification methodology adequately justified? | <u>YES</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements identified? | <u>NA</u> |
| (b) Were specific features and failure modes and effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used together with appropriate justification for their use? | <u>NA</u> |
| (d) Were environmental parameters which affect equipment performance identified? | <u>NA</u> |
| (5) Adequate similarity between equipment and test specimen established? | <u>YES</u> |
| (6) Aging degradation evaluated adequately? | <u>YES</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>NA</u> |
| (b) Equipment aged to end of life condition prior to application of DBE conditions? | <u>YES</u> |
| (c) Absence of preaging in test/analysis justified? | <u>NA</u> |
| (d) Materials susceptible to thermal/radiation aging identified? | <u>YES</u> |

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 25 OF 27
 BINDER TITLE MINCO RTD COMPUTED BJB DATE 4/16/86 R R
 CHECKED CAF DATE 4/23/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>YES</u>
(7) Qualified life or replacement schedule established?	<u>YES</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>YES</u>
(a) Peak temperature adequate	<u>YES</u>
(b) Peak pressure adequate	<u>YES</u>
(c) Duration adequate	<u>YES</u>
(d) Required profile enveloped adequately	<u>YES</u>
(e) Steam exposure adequate	<u>YES</u>
(9) Criteria regarding test sequence satisfied?	<u>YES</u>
(10) Criteria regarding spray satisfied?	<u>YES</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>YES</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>YES</u>
(11) Criteria regarding submergence satisfied?	<u>YES</u>
(12) Criteria regarding radiation satisfied?	<u>YES</u>
(a) Was dose rate considered?	<u>YES</u>
(b) Was beta radiation considered?	<u>YES</u>
(13) Criteria regarding operability status/mode satisfied?	<u>YES</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>YES</u>

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 26 OF 27
 BINDER TITLE MINCO RTD COMPUTED YJB DATE 7/16/86 R R
 CHECKED CSA DATE 4/23/86

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>YES</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>YES</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>YES</u> |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>YES</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>YES</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>YES</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>YES</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>NA</u> |
| (19) Criteria regarding margins satisfied? | <u>YES</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>YES</u> |

P. DISCUSSION

Response Time - In Section 6.2 on page 14 of the test report, it states that "The RTD accuracy during testing was not verified against a reference standard thermometer because of differences in time response, mounting location, RTD construction and local temperature variations." In Section 6.3 on the same page, it states that the

BINDER NO. WBNEQ-ITE-001 PLANT WBN UNIT(S) 1 SHEET 27 OF 27
R 1 R _____
BINDER TITLE MINCO RTD COMPUTED GJB DATE 5/23/86 5/27/86
CHECKED SRP/DLK DATE 5/27/86 12-27-89

P. DISCUSSION (Continued)

accuracy is established by measuring the insulation resistance and that a value of at least 500,000 ohms guarantees a functional accuracy of $\pm 1^{\circ}\text{F}$. These measurements were taken and reported in Table 7 on page 35 of the test report. In spite of the fact that Westinghouse makes no claims to having measured accuracy of the RTDs during the test, Figures D2 (p. 132) and D12 (p. 142) in the test report (TAB D) show the temperature profiles recorded by the average of four Type K thermocouples monitoring the test chamber temperature (p. 16) and RTD test specimen KK-4 during DBA and post-DBA conditions. When these two profiles are compared, it can be seen that they do not match during the first hour or so of the test. This indicates a much slower response time for the RTDs as compared to the thermocouples. This is not considered to be a problem because these instrument's only safety function is to provide temperature compensation to a system (RVLIS) which is required for PAM. The temperature of the water, in the sensing lines these RTDs are measuring, also will not "see" the brief transients in temperature that occur, but will heat up gradually, which renders the response time concern insignificant. Westinghouse has also taken the position that time response testing has been done successfully on a sample model of this RTD via type testing per Section 2.9 on page 8 of EQDP-ESE-42A, TAB E10.

|R1

PRINT DATE: 01/11/89

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQUIS. NUMBER DESCRIPTION	UNIT DEVICE ID NO.	AZMIH MODEL NUMBER	LOCATION ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TE -068-0001 RCS LOOP 1 HOT LEG TEMP	-D 1-TE -068-0001	21205 -D 030	718° 6" LC 71C62-54114-1	A A A A A	100D 100D 100D 1MO 1MO		L MS FW CV/C RH/C MONITORS RCS LOOP 1 HOT LEG TEMP, PAM
WBN-1-TE -068-0018 RCS LOOP 1 COLD LEG TEMP	-D 1-TE -068-0018	21205 -D 057	718° 4" LC 71C62-54114-1	A A A A A	100D 100D 100D 1MO 1MO		L MS FW CV/C RH/C MONITORS RCS LOOP 1 COLD LEG TEMP PAM
WBN-1-TE -068-0024 RCS LOOP 2 HOT LEG TEMP	-D 1-TE -068-0024	21205 -D 153	718° LC 71C62-54114-1	A A A A A	100D 100D 100D 1MO 1MO		L MS FW CV/C RH/C MONITORS RCS LOOP 2 HOT LEG TEMP PAM
WBN-1-TE -068-0041 RCS LOOP 2 COLD LEG TEMP	-D 1-TE -068-0041	21205 -D 119	718° 6" LC 71C62-54114-1	A A A A A	100D 100D 100D 1MO 1MO		L MS FW CV/C RH/C MONITORS RCS LOOP 2 COLD LEG TEMP PAM
WBN-1-TE -068-0043 RCS LOOP 3 HOT LEG TEMP	-E 1-TE -068-0043	21205 -E 208	718° 5" LC 71C62-54114-1	A A A A A	100D 100D 100D 1MO 1MO		L MS FW CV/C RH/C MONITORS RCS LOOP 3 HOT LEG TEMP PAM

PAGE A-1

PREPARER/DATE HWL 9/11/86
 CHECKED/DATE WCG 9/12/86

R 1
 R
 R

ITC-003

PRINT DATE: 01/11/89

BINDER NO. : WBNEQ-ITE -003
 MANUFACTURER : RDF
 PAGE 2 OF 2

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EGIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZIMUTH	ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
MBN-1-TE -068-0060 -E RCS LOOP 3 COLD LEG TEMP	1-TE -068-0060 21205	-E	232	713' 6" LC 71C62-54114-1	A	100D	L	MONITORS RCS LOOP 3 COLD LEG TEMP PAM
					A	100D	HS	
					A	100D	FW	
					A	1MO	CV/C	
					A	1MO	RH/C	
MBN-1-TE -068-0065 -E RCS LOOP 4 HOT LEG TEMP	1-TE -068-0065 21205	-E	330	718' 6" LC 71C62-54114-1	A	100D	L	MONITORS RCS LOOP 4 HOT LEG TEMP PAM
					A	100D	HS	
					A	100D	FW	
					A	1MO	CV/C	
					A	1MO	RH/C	
MBN-1-TE -068-0083 -E RCS LOOP 4 COLD LEG TEMP	1-TE -068-0083 21205	-E	308	718' 6" LC 71C62-54114-1	A	100D	L	MONITORS RCS LOOP 4 COLD LEG TEMP PAM
					A	100D	HS	
					A	100D	FW	
					A	1MO	CV/C	
					A	1MO	RH/C	

PAGE A-2

R1

PREPARER/DATE HWL 9/11/86
 CHECKED/DATE WCG 9/12/86
 R-1
 WCG
 1-13-89
 R-
 R-
 2/12
 1-13-89

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R _____ R _____
BINDER TITLE INSTRUMENT COMPUTED /RI *all* DATE 1-12-87
TEMPERATURE ELEMENT CHECKED /RI *HR* DATE 1-12-89

TAB A

NOTES

1. Elevations shown are actual elevations for equipment located in the Reactor Building and floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See page B-1 for source of Category and Operating Times assignments.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 37
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 ^{WCG}
 12-29-88
 TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 ^{WCG}
 12-29-88

A. DOCUMENTATION

Equipment Description Resistance Temperature Detector
(RCS Well-Mounted)

Vendor/Manufacturer RdF

Equipment Model No.(s) 21205

QUALIFICATION REPORTS

(1) Title/Number/Revision Equipment Qualifi- RIMS B45 860512 365
cation Test Report WCAP-8687 Supp. 2-E06A
R3 DATE March, 1983

(2) Title/Number/Revision _____ RIMS _____
 _____ DATE _____

(3) Title/Number/Revision _____ RIMS _____
 _____ DATE _____

OTHER (ANALYSIS, VENDOR DATA, ETC.) _____

(1) The following documentation is required to support qualifica-
tion:

a) OE Calculation WBNOSG4-017 R8 Reactor Coolant System (68)
NUREG-0588 Category and Operating Times (B45 860722 218).

b) Deleted.

c) Justification for HELB/LOCA Chemical Spray Qualification
Deficiency.

d) Initiation Time and Duration of Submergence Including
Analysis Supporting Operation of Submerged RTDs.

e) Material Aging Calculation Reports WAC-104 DTD 5-20-86, and
WAC-195 DTD 9-3-86. Calculations Determine Qualified
Lifetimes and Post-DBE Qualified Lifetimes.

R1

R1

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 2 OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG
12-28-88
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 WCG
12-28-88

A. DOCUMENTATION - OTHER (ANALYSIS, VENDOR DATA, ETC.), (Continued)

f) Instrument Accuracy Calculations WBPE0688605005
(B43 860722 901).

g) Justification for Applied 10% Margin of Accident Radiation
Dose.

(2) In addition to qualification reports listed on Sheet 1, this
section, the following documentation required to support
qualification is included in TAB D - Qualification Documents.

a) Equipment Qualification Data Package WCAP-8587, EQDP-ESE-6
R5, DTD 3/83 (B45 860512 366).

(3) The following documentation required to support qualification is
included in TAB E - Miscellaneous Documents and Correspondence.

a) Design Specification 955322 R3, DTD 8/10/82 (B45 851210 351).

b) Design Specification 955270 R2, dated 6/4/84
(B45 850423 359).

c) Specification for Reactor Coolant RTD's Drawing No. WATS-
325-04210 R1, dated 10/5/84, page 1 (B45 850425 352).

d) Traceability of Installed RTD to Its Qualification Docu-
mentation (Secton includes Auditable Link Document EQAL-
WAT R3, dated March 1986, RIMS NO. B45 860521 351 and
Quality Release 74284).

e) Letter from Westinghouse to D. L. Kitchel dated 8-22-86
(B71 860826 003) - States that Cal-Note SEC-OSA-1242-CO
which provides justification for use of a max normal am-
bient temperature of 200°F is on file at Westinghouse.

f) Letter from Westinghouse to D. Wilson dated 3-27-86
(B71 860404 002) - States type, manufacturer and activation
energy of the epoxy used in RTD assembly. Also deontes
epoxy location in RTD assembly.

g) EN DES Calculations Maximum Containment Water Level Rise
(NEB 811125 267).

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 3 OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCP
12-28-88
TEMPERATURE ELEMENT CHECKED WCG DATE 9/12/86 WCP
12-29-88

A. DOCUMENTATION - OTHER (ANALYSIS, VENDOR DATA, ETC.), (Continued)

h) TVA Drawings

a) Conduit and Grounding Penetration Sealing and Fire Stop Details, DWG 45W883-3 R15.

b) Conduit and Grounding Floor EL 716.0 Details, Sheet 17, DWG 45W862-19 R22.

i) Traceability of Installed Thermowell.

(4) Westinghouse's Drawings 5365C29 R1, 271C315 R3 and 206C470 R5; |R1
All incorporated in TAB I.

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

R1

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 4 OF 37
BINDER TITLE INSTRUMENT COMPUTED Yes DATE 6-27-86 R R
TEMPERATURE ELEMENT CHECKED WBR DATE 7/3/86

B. CONCLUSION OF REVIEW (Check only one block)

- X Equipment Qualified (Pending Resolution of Open Items)
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES Refer to Sheet 5, this section, for open items and qualification deficiencies.

COMMENTS/RECOMMENDATIONS _____

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 5 OF 37
R R
BINDER TITLE INSTRUMENT COMPUTED KWL DATE 9-11-86
TEMPERATURE ELEMENT CHECKED WCP DATE 9-12-86

B. CONCLUSION OF REVIEW - Open Items and Qualification Deficiencies

(1) Relocation of junction boxes for 1-TE-68-1, -18, -24, -41, -43,
-60, and -83 above postulated flood level. Reference

SCR WBNEEB8559/ECN5993.

(2) Binder Open Item WBNEQP8621 R1, (B45 860717 851) which requires
review of Westinghouse's PAM Functional Requirements Document

(B45 860122 351) to determine its adequacy for use in

demonstrating qualification of the RCS wide range RTDs.

PAGE B-5

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 6 CF 37
BINDER TITLE INSTRUMENT COMPUTED KW DATE 5-28-86 R R
TEMPERATURE ELEMENT _____ CHECKED WPK DATE 6/12/86 _____

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

 X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

 Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS _____

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 344-1975 _____

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 7 OF 37
BINDER TITLE INSTRUMENT COMPUTED Howe DATE 5-28-86
TEMPERATURE ELEMENT _____ CHECKED WPK DATE 6/12/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The installed RTDs are identical to those tested. Refer to TAB E, Section 4, for traceability.

During HELB simulation tests, RTDs were subjected to chemical spray from start of test to 24 hours. Flow rate was not specified. RTDs are required to operate for 100 days following a LOCA or line breaks in either MS or FW lines. Refer to TAB C, Section 5, for acceptability.

RTDs are subject to submergence following a DBE. During HELB simulation tests, RTDs were not tested to demonstrate qualification for submergence. For analysis supporting operation of submerged RTDs, refer to TAB C, Section 6.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 8 OF 37

R 1 R

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 5/28/86 WCG

12-28-88

TEMPERATURE ELEMENT CHECKED WCG DATE 6/12/86 WCG

12-29-88

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Resistance Temperature Detector</u>	<u>Same</u>	<u>(1)</u>
(2) Manufacturer	<u>RdF</u>	<u>Same</u>	<u>(1)</u>
(3) Model Number(s)	<u>21205</u>	<u>21205</u>	<u>Tbl 1, p 20⁽¹⁾</u>
	<u>_____</u>	<u>_____</u>	<u>_____</u>
	<u>_____</u>	<u>_____</u>	<u>_____</u>
	<u>_____</u>	<u>_____</u>	<u>_____</u>
(4) Serial Number(s)	<u>417, 418,</u>	<u>103, 114,</u>	<u>Tbl 1, p 20⁽¹⁾</u>
	<u>419, 420,</u>	<u>115</u>	<u>_____</u>
	<u>421, 422,</u>	<u>_____</u>	<u>_____</u>
	<u>423, 424</u>	<u>_____</u>	<u>_____</u>
(5) Identify Component- Unique checksheet attached:	<u>_____</u>	<u>_____</u>	<u>_____</u>

JUSTIFICATION/COMMENTS

(1) Qualification Report WCAP-8687, Supp. 2-E06A [R1]

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 9 OF 37
 R 1 R
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCP
12-11-88
TEMPERATURE ELEMENT CHECKED WCG DATE 9/12/86 WCP
12-29-88

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u> </u>	<u> </u>
External Process Connections	<u>NA</u>	<u> </u>	<u> </u>
Electrical Connections	<u>NA (1)</u>	<u> </u>	<u> </u>
Conduit Seals	<u>Nuclear qualified splice (1)</u>	<u>Yes</u>	<u>G-38 (2)</u> R1
Connector Seals	<u>NA</u>	<u> </u>	<u> </u>
Orientation	<u>NA</u>	<u> </u>	<u> </u>
Physical Configuration	<u>NA</u>	<u> </u>	<u> </u>
Other	<u>(3)(4)</u>	<u>Yes</u>	<u>(5)</u>

JUSTIFICATION/COMMENTS

- (1) RTD cable assembly interfaces with a Conax seal and electrical connections are made within the Conax seal (Refer to TAB E, Section 8, TVA drawings 45W883-3, Detail F3 and 45W862-19, Detail F19). Environmental qualification of Conax seal is documented in EQ Binder WBNEQ-CSC-001. Environmental qualification of splice is documented in EQ Binder WBNEQ-SPLC-001. | R1
- (2) Qualification Report WCAP-8687, Supp 2-E06A, Para 7.1, pp 17 and 18. | R1
- (3) The RTD cable must be seismically supported to maintain seismic qualification. For seismic installation requirements, refer to TAB I, DWG 2650C31, Note 1. | R1

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 9A OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/27/86 WJP
12-13-88
TEMPERATURE ELEMENT CHECKED WBK DATE 7/3/86 WJP
12-29-88

JUSTIFICATION/COMMENTS (Continued)

- (4) Installation requirements are per Westinghouse drawings RCS Cold Leg RTD Installation Details (Well Type), drawing no. 5365C29 (Refer to TAB I, Section 1). RTD to be used with thermowell as specified on Westinghouse drawing Installation Details Thermowell with Boss, drawing no. 271C315 (Refer to TAB I, Section 2). | R1
- (5) Equipment Qualification Data Package EQDP-ESE-6, Paragraph 1.2, page 2. | R1

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 10 OF 37
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/27/86 WCL??
12-23-88
 TEMPERATURE ELEMENT _____ CHECKED WBK DATE 7/3/86 WDR
12-25-88

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6, 3.2 (Yes/No/NA)? (Note below.) Refer to Para 2.9, p 9 ⁽¹⁾

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>Para 2.9, p 9</u> ⁽¹⁾
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Appx C, pp 58, 59, 60</u> ⁽²⁾
(c) Equipment aged: ⁽⁴⁾		
Thermal	<u>Yes</u>	<u>Para 5.1, p 10</u> ⁽²⁾
Radiation	<u>Yes</u>	<u>Paras 5.3, 5.4 pp 10, 11</u> ⁽²⁾
Wear	<u>Yes</u>	<u>Para 3.2, p 5</u> ⁽²⁾
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Paras 5.5, 5.6 pp 11 thru 14</u> ⁽²⁾
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>Para 5.7, p 14</u> ⁽²⁾
(f) Post-DBE exposure	<u>Yes</u>	<u>Para 5.7, p 14</u> ⁽²⁾
(g) Final inspection and disassembly	<u>(3)</u>	<u>(3)</u>
(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)?	<u>Yes</u>	
(3) Have the test equipment, test equipment accuracies and calibration data been appropriately document (Yes/No/NA)?	<u>Yes</u>	⁽⁵⁾
(Reference: <u>Tbl II, pp 21 thru 24</u> ⁽²⁾).		

JUSTIFICATION/COMMENTS ⁽¹⁾ Equipment Qualification Data Package

EODP-ESE-6. | R1

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 11 OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/27/86 WCM
12-15-88
TEMPERATURE ELEMENT _____ CHECKED WBK DATE 7/3/86 WCM
12-29-88

G. TEST SEQUENCE - Justification/Comments (Continued)

- (2) Qualification Report WCAP-8687, Supp. 2-E06A. |R1
- (3) RTDs were subjected to final inspection (Refer to Equipment Qualification Data Package EQDP-ESE-6, Para 2.9, pp 9 & 10) and were subjected to post-qualification performance tests (Refer to Qualification Report WCAP-8687, Supp 2-E06A, Appx C). |R1
- (4) RTDs were subjected to thermal cycling (Refer to Qualification Report WCAP-8687, Supp 2-E06A, Para 5.2, p 10). |R1
- (5) Calibration Data and Test Equipment Accuracies are available for audit at Westinghouse.

H. AGING

(1) Was aging considered in the qualification program
 (Yes/No/NA)? Yes (Reference: Qualification Report
WCAP-8687, Supp 2-E06A, Para 3.1, p 3).

JUSTIFICATION/COMMENTS _____

(2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	Para 3.1.1, p 3 (1)
Radiation exposure	<u>Yes</u>	Para 3.1.3, 3.1.4, p 4 (1) Para 3.1.5,
Vibration (non-seismic) aging	<u>Yes</u>	p 4 (1)
Operational (electrical/mechanical/ process) stress aging	<u>Yes</u>	Para 3.1.2, p3 (1) Para 3.1.5, p4 (1)

JUSTIFICATION/COMMENTS Qualification Report WCAP-8687, Supp
2-E06A. | R1

(3) Were all known synergistic effects which are believed to have a
 significant effect on equipment performance considered in the
 aging program (Yes/No/NA)? NA (Reference: _____
 _____).

JUSTIFICATION/COMMENTS Based upon review of materials of
construction, no known synergistic effects apply to this equip-
ment.

(4) Thermal Aging:

(a) Was thermal aging considered in the qualification program
 (Yes/No/NA)? Yes (Reference: Qualification Report
WCAP, Supp 2-E06A, Para 3.1.1, p 3 and Para 5.1, p 10). | R1

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 13 OF 37
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/27/86 mlg
12-28-88
 TEMPERATURE ELEMENT _____ CHECKED WBK DATE 7/3/86 WBE
12-29-88

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687, Supp 2-E06A, Para 3.1.1, p 3). |R1

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for thermal aging identified in the qualification program (Yes/No/NA)? Yes (Reference: Equipment Qualification Data Package EODP-ESE-6, Para 1.9, p 4; Qualification Report WCAP-8687, Supp 2-E06A, Para 5.1, p 10). |R1

JUSTIFICATION/COMMENTS _____

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687, Supp 2-E06A, Para 5.1, p 10). |R1

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>200°F⁽¹⁾</u>	<u>400°F⁽²⁾</u>	<u>200°F⁽³⁾</u>
Time	<u>40 years</u>	<u>11 days</u>	<u>>40 years</u>

JUSTIFICATION/COMMENTS (1)(2)(3) Refer to Sheet 14, this tab.

- (e) Was the Arrhenius methodology used for accelerated aging (Yes/No/NA)? Yes (Reference: Equipment Qualification Data Package EODP-ESE-6, Para 1.9, p 4). |R1

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (Yes/No/NA)? No (Reference: (4) Refer to Sheet 14, this tab). |R1

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 14 OF 37

R 1 R

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG
12-29-88

TEMPERATURE ELEMENT CHECKED WCG DATE 9/12/86 WCG
12-29-88

H. AGING

(4) Thermal Aging (Continued)

- (d) ⁽¹⁾ The plant maximum normal for RTDs 1-TE-68-1, -18, -24, -41, -43, -60, -65, -83 is 200°F. Westinghouse has performed an analysis which shows that the air velocity and ambient temperature of the area in which the RTDs are located are sufficient to limit the temperature of the RTDs head to approximately 200°F. Analysis, Cal-Note SEC-OSA-1242-CO, is on file at Westinghouse - Refer to TAB E, Section 5.
- (2) Qualification Report WCAP-8687, Supp 2-E06A, Para 5.1, p 10. |R1
- (3) Material Aging Calculation WAC-104, Refer to TAB C, Section 7.
- (f) ⁽⁴⁾ The activation energy used is denoted in Para 3.1.1, p 3 of Qualification Report WCAP-8687, Supp 2-E06A. |R1
Also refer to TAB E, Sect 6 - Letter from Westinghouse to D. Wilson dated March 27, 1986 (B71 860404 002).

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 15 OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 5/28/86 WJZ
12-18-88
TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/12/86 WJZ
12-18-88

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? NA
(Reference: _____).

JUSTIFICATION/COMMENTS _____

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? Yes (Reference: Qualification Report

WCAP-8687, Supp 2-E06A, Para 3.2, p 5). | R1

JUSTIFICATION/COMMENTS _____

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: Qualification

Report WCAP-8687, Supp 2-E06A, Para 3.1.3, 3.1.4, p 4 and | R1

Para 5.3, 5.4, pp 10, 11).

JUSTIFICATION/COMMENTS _____

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? Yes
(Reference: Qualification Report WCAP-8687, Supp 2-E06A | R1

Para 3.1.1, p 3).

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? Yes
(Reference: See comments).

JUSTIFICATION/COMMENTS Design Specification 955270, Para | R1

6.2, p 6. Refer to TAB E, Sect 2; Qualification Report

WCAP-8687, Supp 2-E06A, Para 3.1.3, 3.1.4, p 4. | R1

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 37
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG
12-27-88
 TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 WCG
12-29-88

H. AGING (Continued)

(d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687, Supp 2-E06A, Para 5.3, pp 10, 11). | R1

Plant normal ambient radiation dose (rd) 8 x 10⁷

Tip of RTD 2.47 x 10⁸⁽¹⁾

Test exposure dose (rd) Cable 1.22 x 10⁸

Between 2 x 10⁶⁽²⁾

Test exposure dose rate (rd/hr) and 3 x 10⁶

Test exposure source type (e.g., Co-60 gamma) Co-60 Gamma (2)

JUSTIFICATION/COMMENTS (1) Qualification Report WCAP-8687, Supp 2-E06A, Para 5.3, pp 10, 11. (2) Design Specification 955270, Para 6.2, p 6 (refer to TAB E, Sect 2) | R1

(6) Vibration (non-seismic) Aging:

(a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* (yes/no/NA)? Yes (Reference Qualification Report WCAP-8687, Supp 2-E06A, Para 3.1.5, p 4 and Para 5.5, pp 11 thru 13). | R1

JUSTIFICATION/COMMENTS _____

(b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687, Supp 2-E06A, Para 3.1.5, p 4 and Para 5.5, pp 11 thru 13). | R1

JUSTIFICATION/COMMENTS _____

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in Tab C of the binder.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 17 OF 37

R 1 R

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 5/28/86 ^{WCJ}
₁₂₋₂₇₋₈₇

TEMPERATURE ELEMENT CHECKED WBK DATE 6/12/86 ^{WJL}
₁₂₋₂₉₋₈₇

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report

WCAP-8687, Supp. 2-E06A, Para 3.1.2, p 3, and Para 5.2, p 10 |R1

JUSTIFICATION/COMMENTS _____

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Qualification

Report WCAP-8687, Supp. 2-E06A, Para 3.1.2, p 3 |R1

JUSTIFICATION/COMMENTS _____

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes

(Reference: Qualification Report WCAP-8687, Supp 2-E06A, Para 3.1.1, p 3, and Para 5.1, p 10. Equipment Qualification

Data Package EODP-ESE-6, Para 1.9, p 4 |R1

Qualified life (Document in QMDS) > 40 years

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 18 OF 37

R 1 R

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 5/28/86 WCJ

12-28-88

TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/12/86 WJR

12-29-88

H. AGING (Continued)

(9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: See comments).

JUSTIFICATION/COMMENTS Qualified life of test specimen is 10
years (refer to Equipment Qualification Data Package EODP-ESE-
6, Tbl 1, p 18).

|R1

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

<u>Material/ Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Silicon Varnish (Cable Coating)</u>	<u>NA</u> (1)	<u>(1)</u>	<u>Not Specified</u> (2)	<u>Para 3.1.1, p 3</u> (3)
(b) <u>Epoxy (Potting Matl)</u>	<u>NA</u> (1)	<u>(1)</u>	<u>.98eV</u>	<u>Para 3.1.1, p 3</u> (3)
(c) _____	_____	_____	_____	_____
(d) _____	_____	_____	_____	_____
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS (1) Materials were irradiated to 1.22×10^8
rads gamma and 9.23×10^8 rads beta during radiation exposure test
(refer to Qualification Report WCAP-8687, Supp 2-E06A, Paras 5.3., |R1
5.4, pp 10, 11).

(2) The silicon varnish is only used as a manufacturing process to
prevent the fiberglass insulation of the cable from fraying during
manufacturing and is not required for operation of the RTD.

(3) Qualification Report WCAP-8687, Supp 2-E06A. |R1

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 20 OF 37

R 1 R _____

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 5/28/86 ^{WLS}
₁₂₋₂₈₋₈₈

TEMPERATURE ELEMENT CHECKED WBK DATE 6/12/86 ^{WLS}
₁₂₋₂₉₋₈₈

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (Yes/No/NA)? Yes

(Reference: Equipment Qualification Data Package EODP-ESE-6, Sect. 1.7, p 3; Qualification Report WCAP-8687, Supp 2-E06A, Para 3.2, p 5, and Para 6.3, p 16). R1

Identify Acceptance Criteria: ± 0.2°F repeatability, ±1.0°F drift allowance; insulation resistance > 1 Megohm.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (Yes/No/NA)? Yes

(Reference: Qualification Report WCAP-8687, Supp. 2-E06A, Para 3.2, p 5). R1

Identify baseline and functional testing: Refer to Sheet 21, this tab.

JUSTIFICATION/COMMENTS _____

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (Yes/No/NA)? NA

(Reference: Equipment Qualification Data Package EODP-ESE-6, Para 1.1, p 2). R1

JUSTIFICATION/COMMENTS For electric connections, refer to Sheet 21, this tab.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 21 OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 7/2/86 ^{WCJ}
₁₁₋₂₃₋₈₈
TEMPERATURE ELEMENT _____ CHECKED WBK DATE 7/3/86 ^{JDR}
₁₂₋₂₉₋₈₈

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

(2) Performance Characteristics (Continued)

Baseline Functional Tests (Operation - Normal Condition) are described in the Equipment Qualification Data Package EQDP-ESE-6, Para 2.9, p 9. For baseline functional test results and functional test (static calibration) results performed after each of the test phases, refer to Qualification Report WCAP-8687, Supp 2-E06A, Appx C, pp 57 thru 61. |R1

(3) During static calibration checks, the RTDs were excited by a constant current (approximately 1 mA; refer to Equipment Qualification Data Package EQDP-ESE-6, Para 1.1, p 2) applied to the two leads while the voltage drop was measured across the other two leads. A digital voltmeter was used to measure resistance. Refer to Qualification Report WCAP-8687, Supp 2-E06A, Para 4.2.1, p 7, and Fig. 4, p 32. During each of the test phases, the RTD outputs were monitored via Westinghouse 300 series amplifiers. The 0-10-Volt analog outputs of the amplifiers were monitored and recorded on a digital data logger. Refer to Qualification Report WCAP-8687, Supp 2-E06A, Para 3.2, p 5, and Paras 4.2.2, 4.2.3, 4.2.4, 4.2.5, and 4.2.6, pp 7 thru 9. |R1

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 22 OF 37
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 ^{WCG}
 _____ ₁₂₋₁₈₋₈₈
 TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 ¹²⁻²⁹⁻⁸⁸
 _____ _{HDP/RMM}

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? NA (Reference: Refer to J.(3), Sheet 21, this tab).

JUSTIFICATION/COMMENTS _____

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>R/I Converter with 1-milliamp current</u>	<u>(1)</u>
Load	<u>NA</u>	<u>(1)</u>
Frequency	<u>NA</u>	<u>(1)</u>
Accuracy	<u>± 26.2°F</u>	<u>TAB C. Section 8</u>
Other(s)	_____	_____
	_____	_____

JUSTIFICATION/COMMENTS (1) Equipment Qualification Data Package EODP-ESE-6, para. 1.1, p. 2.

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u> R1
Voltage	R/I Converter with 1-milliamp current	(1)(2)
Load	NA	(1)
Frequency	NA	(1)
Accuracy	$\pm 21^{\circ}\text{F}$ (3)	(4)
Other(s)		

JUSTIFICATION/COMMENTS (1) Equipment Qualification Data
 Package EODP-ESE-6, Para 1.1, p. 2. (2) Electric Control | R1
 Drawing 47W610-68-1, -2, -3, and -4. (3) Open Item pending
 resolution of SCR WBNEQP8621. (4) Instrument Accuracy Calcula-
tion WBPE0688605005, p. 36 (refer to TAB C, Section 8).

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u> R1
Voltage	R/I Converter with 1 - milliamp current	(1)
Load	NA	(1)
Frequency	NA	(1)
Accuracy	$\pm 26.2^{\circ}\text{F}$	(2)
Other(s)		

JUSTIFICATION/COMMENTS (1) Equipment Qualification Data Pack-
age EODP-ESE-6, Para 1.1, p. 2. | R1
 (2) Refer to Sheet 24 this tab.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 24 OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCP
12-28-88
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 WCP
12-29-88

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

(5)(b) Demonstrated Conditions

Accuracy - There are no changes in the RTD due to severe environments. The calibration accuracy is $\pm 0.2, F$ and the drift allowance is $\pm 1.0, F$ (refer to Equipment Qualification Data Package EQDP-ESE-6, Tbl 1, p 18, and to Qualification Report WCAP-8687, Supp 2-E06A, R1 Para. 7.2, p 18). For demonstrated loop accuracy of $\pm 26.2, F$, refer to Instrument Accuracy Calculations, TAB C, Section 8.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 25 OF 37

R 1 R _____

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG
12-28-88

TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 WCG
12-29-88

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-42 | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 120⁽¹⁾

(a) Temperature (°F) 130⁽¹⁾

(b) Pressure (psig) .3

(b) Pressure (psig) .3

(c) Humidity (%) 80

(c) Humidity (%) 100

(d) Radiation (rd) 8 x 10⁷

(d) Radiation (rd) NA

(3) Process Interfaces: NA; RTDs are installed in thermowells.

For effects of process temperatures, refer to Sheet 26, this
TAB.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Maximum abnormal temperature, pressure, and humidity could exist for up to eight hours per excursion and will occur less than 1% of plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 327⁽¹⁾ Accident type HELB

(b) Pressure (psig) 11.2 Accident type LOCA

(c) Humidity (%) 100 Accident type LOCA/HELB

4.7 x 10⁸ beta

(d) Radiation (rd) 4 x 10⁷ gamma Accident type LOCA

(e) Spray Type Boron⁽²⁾ Accident type LOCA/HELB

(1)(2) Refer to Sheet 26, this TAB.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 26 OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WJH
12-28-88
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 JOR
12-29-88

K. REQUIRED OPERATING ENVIRONMENT (Continued)

- (1) Due to effect of process temperatures, the temperature of the RTD head, during normal operation, will be approximately 200,F (refer to H(4)(d), Comment (1), Sheet 14, this TAB) and during DBE/Post-DBE environments, the RTD will be subjected to a conservative 50,C temperature rise above ambient (refer to Qualification Report WCAP-8687, Supp 2-EO6A, Para 5.1, p 10). |R1
- (2) Refer to Sheet 30, this TAB, for composition.

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Refer to Sheet 30, this TAB.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: Refer to Sheet 28, this TAB).

(7) Subject to submergence (Yes/No/NA)? Yes (Reference: Refer to Section 6, TAB C).

Identify initiation time and duration of submergence: Refer to Section 6, TAB C.

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: Environmental Drawing 47E235-42).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: Required Beta dose is enveloped by the tested Beta dose (para. 5.4, p. 11) therefore no analysis was required.

(9) Special environmental calculations (temp., rad., etc.)

Type	RIMS No.
_____	_____
_____	_____
_____	_____

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 28 OF 37

R 1 R

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG
12-29-88

TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 WCG
12-29-88

K. REQUIRED OPERATING ENVIRONMENT (Continued)

(6) Reference - Environmental drawing 47E235-42 (note 46). | R1
To prevent moisture intrusion into the RTD/cable assembly, the RTD
cable assembly interfaces with a Conax seal assembly. The RTD
cable leads are enclosed in a flexibel, pressure-tight hose. The
flexible, pressure-tight hose is helium leak tested to assure no
degradation under HELB/LOCA environmental conditions (refer to
Qualification Report WCAP-8687, Supp. 2-E06A, Para. 7.1, p 17). | R1
Therefore, the RTD/cable assembly is not subject to moisture in-
trusion and will function as required under design basis conditions.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 29 OF 37
 R R
 BINDER TITLE INSTRUMENT COMPUTED HCW DATE 9-11-86
 TEMPERATURE ELEMENT CHECKED WCN DATE 9-12-86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>15 days</u>	<u>Fig 7, p 35⁽¹⁾</u> <u>Fig 7, p 35⁽¹⁾</u>
Temperature (°F)	<u>327</u>	<u>420</u>	<u>Tbl 1, p 18⁽²⁾</u> <u>Fig 8.9, pp 36, 37⁽¹⁾</u>
Pressure (psig)	<u>11.2</u>	<u>75</u>	<u>Tbl 1, p 18⁽²⁾</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>Tbl 1, p 18⁽²⁾</u>
*Chemical Spray	<u>Sheet 30, this tab</u>	<u>Sheet 30, this tab</u>	<u>Para 3.1.7, pp 4, 5⁽¹⁾</u> <u>Tbl 1, p 18</u> <u>Paras 5.3, 5.4, pp 10, 11⁽¹⁾</u>
**Radiation (rd)	<u>1.2 x 10⁸ gamma</u> <u>4.7 x 10⁸ beta</u>	<u>(3)</u>	<u>Tbl 1, p 18⁽²⁾</u> <u>Refer to TAB C, Sect 6, for Analysis</u>
Submergence	<u>Yes</u>	<u>No</u>	<u>Analysis</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>Fig 7, p 35⁽¹⁾</u> <u>Tbl 1, p 18⁽²⁾</u>
Pressure	<u>Yes</u>	<u>Figs 8, 9 pp 36, 37⁽¹⁾</u> <u>Tbl 1, p 18⁽²⁾</u>
Relative Humidity	<u>Yes</u>	<u>Tbl 1, p 18⁽²⁾</u>
Chemical Spray	<u>Yes</u>	<u>Sheet 30, this tab</u> <u>Refer to TAB C, Sect 6, for Analysis</u>
Submergence	<u>No</u>	<u>Analysis</u>

JUSTIFICATION/COMMENTS Qualification for submergence has been
established by analysis.

(1)(2)(3) Refer to Sheet 30, this tab.

PAGE B-30

BINDER NO. WBNEO-ITE-003 PLANT WBN UNIT(S) 1 SHEET 30 OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 HW
12-28-88
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 HW
12-29-88

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
(Continued)

- (1) Qualification Report WCAP-8687, Supp 2-E06A.
- (2) Equipment Qualification Data Package EQDP-ESE-6.
- (3) RTD TIP - 2.47×10^8 rads gamma
Cable - 1.22×10^8 rads gamma
RTD and Cable - 9.23×10^8 rads beta
Chemical Spray

R1

Specified - The chemical spray composition is 0.19 Molar H_3BO_3 (2000 ppm Boron), 0.033 Molar NaOH resulting in a pH of 8.3 at 25°C. The flowrate is equal to 0.92 gal/min per square foot of containment cross section. Refer to Environmental Data Drawing 47E235-42, notes 5 and 22.

R1

Demonstrated - The chemical spray composition consisted of 2750 ppm Boron buffered with 0.9 percent dissolved NaOH to a pH of 10.7 at 25°C and was applied from the start of HELB simulation to 24 hours. The flowrate was not specified. Refer to TAB C, Section 5 for acceptability.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 31 OF 37
 R _____ R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 ²²⁹
 1-12-89
 TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/12/86 ²⁰²
 1-12-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	> 15°F	Yes
Pressure: +10% but no more than 10 psig	> 10%	Yes
Radiation: +10% of accident dose	> 10% ⁽⁴⁾	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	None	(1)
Voltage: ±10% of rated value	NA	
Frequency: ±5% of rated value	NA	
Environmental Transient: the initial transient and the peak temperature applied twice	(2)	Yes
Vibration: +10% added to acceleration	(3)	Yes

JUSTIFICATION/COMMENTS ⁽¹⁾ Refer to TAB C, Section 7 for plant specific margin.

⁽²⁾ Qualification Report WCAP-8687, Supp 2-E06A, Fig. 7, p 35.

⁽³⁾ Equipment Qualification Data Package EODP-ESE-6, Para. 2.10.3.3, p 11.

⁽⁴⁾ Refer to TAB C, Section 9 for justification.

R1

M. OPERABILITY TEST RESULTS

(1) Identify the safety function(s) of this equipment:
(Reference: Refer to TAB A)

_____)

JUSTIFICATION/COMMENTS _____

(2) Did the equipment perform its intended function during the simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: Qualification Report WCAP-8687, Supp 2-E06A, | R1

Para 3.2, p 5, Para 6.2, p 15, and Para 7.2, p 18)

JUSTIFICATION/COMMENTS _____

(3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (Yes/No/NA)? Yes
(Reference: Qualification Report WCAP-8687, Supp 2-E06A, | R1

Para 3.2, p 5, Para 6.2, p 15, and Para 7.2, p 18)

JUSTIFICATION/COMMENTS _____

(4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (Yes/No/NA)? Yes (Reference: Refer to TAB C,

Section 7)

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 33 OF 37
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 5/28/86 WC
12-15-88
TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/12/86 WOL
12-29-88

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: Qualification Report WCAP-8687, Supp. 2-E06A, | R1
Para 6.2, p 15, and Para 7.3, p 19).

JUSTIFICATION/COMMENTS

The qualification report denotes that during beta irradiation testing, an apparent transient effect on the amplified RTD output occurred.

Tests were performed to investigate the apparent response to beta radiation, and in none of the tests were the original effects repeated. Westinghouse concluded that the responses observed in the initial tests were the result of conditions unique to the qualification test set-up and not a response to conditions reflecting accident doses.

The above anomaly was properly addressed in the qualification report and the conclusion concurred with.

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 34 CF 37
BINDER TITLE INSTRUMENT COMPUTED 1624 DATE 5-28-86 R R
TEMPERATURE ELEMENT _____ CHECKED WPK DATE 6/12/86 _____

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 35 OF 37
 BINDER TITLE INSTRUMENT COMPUTED KWC DATE 5-28-86
 TEMPERATURE ELEMENT _____ CHECKED WBA DATE 6/12/86

0. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|---|------------------|
| (1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified? | <u>NA</u> |
| (3) Choice of qualification methodology adequately justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements identified? | <u>NA</u> |
| (b) Were specific features and failure modes and effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used together with appropriate justification for their use? | <u>NA</u> |
| (d) Were environmental parameters which affect equipment performance identified? | <u>NA</u> |
| (5) Adequate similarity between equipment and test specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u> |
| (b) Equipment aged to end of life condition prior to application of DBE conditions? | <u>Yes</u> |
| (c) Absence of preaging in test/analysis justified? | <u>NA</u> |
| (d) Materials susceptible to thermal/radiation aging identified? | <u>Yes</u> |

0. SUMMARY OF REVIEW (Continued)

Yes/No/NA

- (e) Normally operating state of device (e.g., normally energized) considered? Yes
- (7) Qualified life or replacement schedule established? Yes
- (8) Criteria regarding temperature/pressure exposure satisfied? Yes
 - (a) Peak temperature adequate Yes
 - (b) Peak pressure adequate Yes
 - (c) Duration adequate Yes
 - (d) Required profile enveloped adequately Yes
 - (e) Steam exposure adequate Yes
- (9) Criteria regarding test sequence satisfied? Yes
- (10) Criteria regarding spray satisfied? Yes
 - (a) Was the spray testing done while under the extremes of pressure and temperature? Yes
 - (b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant? No; Refer to TAB C, Sect 5 for Acceptability
- (11) Criteria regarding submergence satisfied? Yes
- (12) Criteria regarding radiation satisfied? Yes
 - (a) Was dose rate considered? Yes
 - (b) Was beta radiation considered? Yes
- (13) Criteria regarding operability status/mode satisfied? Yes
- (14) Criteria regarding test failures or anomalies satisfied? Yes

BINDER NO. WBNEQ-ITE-003 PLANT WBN UNIT(S) 1 SHEET 37 OF 37
 BINDER TITLE INSTRUMENT COMPUTED WMC DATE 6-27-86 R R
 TEMPERATURE ELEMENT _____ CHECKED WJK DATE 7/7/86

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|---|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | No pending resolution of <u>open item</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

PRINT DATE: 06/28/90

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

MANUFACTURER PAGE 1 OF 1

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TE -068-0319 RCS PRZR LIQUID TEMP	-F	1-TE	-068-0319		734' 9" LC 71C62-54114-1		A A A A	100D 100D 100D 1MO 1MO	L MS FW RH/C CV/C	MONITORS RCS PRZR LIQUID TEMP PAM
WBN-1-TE -068-0324 RCS PRZR VAPOR TEMP	-G	1-TE	-068-0324		777' 6" UC 71C62-54114-1		A A A A	100D 100D 100D 1MO 1MO	L MS FW RH/C CV/C	MONITORS RCS PRZR VAPOR TEMP - PAM
WBN-1-TE -074-0014 RHR PUMP A-A DISCH PUMP	-G	1-TE	-074-0014		713' A12 71C62-54114-1		A C C C C	100D N/A N/A N/A N/A	L AF AB RH/A CV/A	REQUIRED FOR POST ACCIDENT MONITORING OF CONTAINMENT SUMP 1R2 TEMPERATURE -PAM
WBN-1-TE -074-0025 RHR PUMP B-B OUTLET TEMP	-F	1-TE	-074-0025		713' A11 71C62-54114-1		A C C C C	100D N/A N/A N/A N/A	L AF AB RH/A CV/A	REQUIRED FOR POST ACCIDENT MONITORING OF CONTAINMENT SUMP TEMPERATURE -PAM

PAGE A-1 R2

PREPARER/DATE HWL 9/11/86 R 1
 CHECKED/DATE WCG 9/18/86 R 2
 WCG 7/13/89
 HDR 7/13/89
 ATW 7/14/90

20-711

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1

BINDER TITLE INSTRUMENT COMPUTED /R1 WCP DATE 1-12-89 R R

TEMPERATURE ELEMENT CHECKED /R1 JDR DATE 1-12-89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-1 for source of Category and Operating Time assignments.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 43
 R 1 R 2
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WGG CRH
 12/20/88 7/12/90
TEMPERATURE ELEMENT CHECKED WGG DATE 9/17/86 HDR GJM
 1/4/89 7/16/90

A. DOCUMENTATION

Equipment Description Resistance Temperature Detector
(Fast Response Well Mounted)
 Vendor/Manufacturer RdF
 Equipment Model No.(s) 21232-2 and 3

QUALIFICATION REPORTS

(1) Title/Number/Revision Equipment Qualifica- RIMS B45 851203 357
tion Test Report WCAP-8687, Supp. 2-E07A,
Revision 3 DATE March, 1983

OTHER (ANALYSIS, VENDOR DATA, ETC.) (1) The following documenta-
tion is required to support qualification:

- a) OE Calculation WBNOSG4-017 R11, Reactor Coolant System (68)
NUREG 0588 Category and Operating Times (B18 900612 252). R2
- b) OE Calculation WBNOSG4-020 R8, Residual Heat Removal System
(74) NUREG 0588 Category and Operating Times (B18 900309 232).
- c) Environmental Drawing 47E235-50 R1
- d) Environmental Drawing 47E235-42 R2
- e) Environmental Drawing 47E235-41 R1
- f) WBN Normal and Accident Process Temperatures for the RHR Pump
Discharge (TAB C, Page C-22). R2
- g) Justification for HELB/LOCA Chemical Spray Qualification
Deficiency (TAB C, Page C-24). R2

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 2 OF 43
R 1 R 2
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG CSH
12/20/88 7/12/90
TEMPERATURE ELEMENT CHECKED WCG DATE 9/17/86 HDR QPM
1/4/89 7/16/90

OTHER (ANALYSIS, VENDOR DATA, ETC) (Continued)

h) Material Aging Calculation Reports WAC-103 Dtd 5-20-86,
WAC-191 Dtd 9-3-86 (Both Applicable to 1-TE-68-319, -324) and
WAC-58 Dtd 4-8-86 (Applicable to 1-TE-74-14, -25). Calcula-
tions determine qualified lifetimes and post-DBE qualified
lifetimes.

i) OE Calculation WBNOSG4-075, NUREG-0588 Loop Accuracy for
TE-68-319 and TE-68-324. (B45 860812 219)

j) DNE Calculation WBPEVAR9004014, Required/Demonstrated Accuracy
Calculation for Reg. Guide 1.97 Cat. 2 Loops with Transmitter
and/or Sensor in a Harsh Environment (B26 900609 400)
(TE-74-14 and -25).

R2

2. In addition to qualification reports listed on Sheet 1, this sec-
tion, the following documentation required to support qualification
is included in TAB D - Qualification Documents.

a) Equipment Qualification Data Package WCAP-8587, EODP-ESE-7,
Rev. 5, Dtd 3/83 (B45 851203 356).

3. The following documentation required to support qualification is
included in TAB E - Miscellaneous Documents and Correspondence.

a) Equipment Specification 953297 Rev. 1 Dtd 3-11-83 (NEB 830629
354).

b) Specifications for Resistance Temperature Detectors with Wells,
Spec Sheet No. 4.39 (Applicable to 1-TE-68-319, -324).

c) Specifications for Resistance Temperature Detectors with Wells,
Spec Sheet No. 6.39 (Applicable to 1-TE-74-14, -25).

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 3 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 ~~12/8/88~~
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 ~~10/1-4-89~~

OTHER (ANALYSIS, VENDOR DATA, ETC) (Continued)

3. d) Traceability of Installed RTD to it's Qualification Document-
ation (Section includes Auditable Link Document EOAL-WAT, Rev.
3, Dtd March 1986, RIMS Accesssion No. B45 860521 351, Quality
Releases N-58820 Rev. 0, and Applicable Certificate of
Compliances).
- e) Letter from Westinghouse to D. W. Wilson Dtd 3.-20-86 (B71
860403 004) states Qualified Radiation Exposure limits of
 1.22×10^8 rads (on cable), applicable to Model 21205 RTD, are
acceptable limits for use on Model 21232 RTD's.
- f) Letter from J. A. Raulston to Westinghouse Dtd 1-13-86 (B45
860113 103) acknowledging receipt of Data Package WCAP-8587,
EODP-ESE-7, Rev 5 and Qualification Report WCAP-8687, Supp. 2-
E07A, Rev. 3.
- g) Letter from Westinghouse to D. Wilson Dtd 3-27-86 (B71 860404
002) states type, manufacture and activation energy of the
epoxy used in RTD assembly. Also, states epoxy location in
RTD assembly.
- h) Letter from Westinghouse to D. L. Kitchel Dtd 5-15-86 (B71
860516 004) states Cal-Note SEC-OSA-1242-CO, on file at West-
house, may be used for pressurizer RTDs 1-TE-68-319, -324 when
calculating qualified life.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 3A OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCS
12-17-88
TEMPERATURE ELEMENT CHECKED WCG DATE 9/17/86 HWL
1-4-89

OTHER (ANALYSIS, VENDOR DATA, ETC) (Continued)

3. i) Conduit and Grounding Penetration Sealing and Fire Stop Details,

TVA Drawing 45W883-3 R15.

Conduit and Grounding Floor EL 716.0. Details Sheet 9. TVA

Drawing 45N862-11 R32. Conduit and Grounding EL 713.0. Col

A5-All. U-W Floor Plan. TVA Drawing 45N824-4 R26.

j) Traceability of installed thermowells.

4. Westinghouse Drawings 2657C49 R3 and 21232 R5; Rdf Drawings 52475

and 52476; all incorporated in TAB I.

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

R1

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 4 OF 43
R 2 R
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/25/86 CAF
7/12/90
TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/25/86 AFM
7/16/90

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified (Pending Resolution of Open Items)
- Equipment Satisfied All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES _____

1. Instrument Accuracy Calculations are required for System 68

R2

RTDs.

COMMENT/RECOMMENDATIONS _____

WBNEQ-ITE-004

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-6 was deleted per revision 2.

WBEP-0033Q

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 6 OF 43

BINDER TITLE INSTRUMENT COMPUTED WJK DATE 6-10-86 R R

TEMPERATURE ELEMENT _____ CHECKED WJK DATE 6-11-86 _____

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

 X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

 Components are Qualified to the Criteria of NUREG-058 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS _____

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 344-1975 _____

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 7 OF 43
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 ¹²⁻¹¹⁻⁸⁶
TEMPERATURE ELEMENT CHECKED WCG DATE 6/11/86 ¹⁻⁴⁻⁸⁹

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The RTDs tested were RdF Models 21232-1 and 21232-3. The Model 21232-2 was not tested. It differs from those tested only in length. The test units were selected because their longer length better represented the design in vibration and seismic tests. All three models are otherwise of identical design. Refer to Qualification Report WCAP-8687, Suppl 2-E07A, page 2, paragraph 2.1, and to TAB E, Section 4 for Traceability of RTDs to their Qualification Documentation. During HELB simulation tests, the RTD/Cable Assemblies were subjected to chemical spray from start of test to 24 hours (Refer to Qualification Report WCAP-8687, Supp. 2-E07A, paragraph 3.1.7, page 5). Flow rate was not denoted. RTDs 1-TE-68-319 and -324 are required to operate for 100 days following a LOCA. Refer to TAB C, Section 3 for acceptability.

R1

R1

R1

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 8 OF 43
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 ^{HWL}
 12-14-88
TEMPERATURE ELEMENT CHECKED WCG DATE 9/17/86 ^{WCG}
 1-4-89

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Resistance Temperature Detector</u>	<u>Same</u>	<u>(1)</u>
(2) Manufacturer	<u>RdF</u>	<u>Same</u>	<u>(1)</u>
(3) Model Number(s)	<u>(2)</u>	<u>21232-1</u>	<u>Table 1 (1)</u> <u>page 19</u>
		<u>21232-3</u>	
(4) Serial Number(s)	<u>(2)</u>	<u>100, 101,</u>	<u>Table 1 (1)</u> <u>page 19</u>
		<u>102, 103</u>	
(5) Identify Component- Unique checksheet attached:	<u>NA</u>		

JUSTIFICATION/COMMENTS (1) Qualification Report WCAP-8687,
Supp. 2-E07A

R1

(2)	<u>Component</u>	<u>Model No.</u>	<u>Serial No.</u>
	<u>1-TE-68-319</u>	<u>21232-2</u>	<u>109</u>
	<u>1-TE-68-324</u>	<u>21232-2</u>	<u>108</u>
	<u>1-TE-74-14</u>	<u>21232-3</u>	<u>164</u>
	<u>1-TE-74-25</u>	<u>21232-3</u>	<u>163</u>

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 9 OF 43
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 ^{W.C.P.}
 _____ ₁₂₋₁₅₋₈₇
TEMPERATURE ELEMENT CHECKED WCG DATE 9/17/86 ^{W.C.P.}
 _____ ₁₋₄₋₈₉

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>_____</u>	<u>_____</u>
External Process Connections	<u>NA</u>	<u>_____</u>	<u>_____</u>
Electrical Connections	<u>Nuclear qualified splice and (1)</u>	<u>Yes</u>	<u>G-38</u> R1
Conduit Seals	<u>(1)</u>	<u>Yes</u>	<u>(2)</u>
Connector Seals	<u>NA</u>	<u>_____</u>	<u>_____</u>
Orientation	<u>NA</u>	<u>_____</u>	<u>_____</u>
Physical Configuration	<u>NA</u>	<u>_____</u>	<u>_____</u>
Other	<u>(3) (4)</u>	<u>_____</u>	<u>_____</u>

JUSTIFICATION/COMMENTS (1) RTD Cable Assembly interfaces with a Conax seal and electrical connections are made within the Conax Seal (Refer to TAB E Section 9 TVA Drawing 45W883-3, Detail F3). Environmental qualification of Conax seal is documented in EQ Binder WBNEQ-CSC-001. | R1

(2) Qualification Report WCAP-8687, Supp. 2-E07A, para. 7.1, pages 16 and 17. | R1

JUSTIFICATIONS/COMMENTS continued on Sheet 9A.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 9a OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG
1-17-89
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 WCG
1-4-89

(3) The RTD cable must be seismically supported to maintain seismic qualification. For seismic installation requirements, refer to TAB I, Drawing 2657C49, Note 1.

R1

(4) Installation Requirements are per Westinghouse drawing RCS Fast Response RTD Installation Details Drawing No. 2657C49 (refer to TAB I, Section 1). RTD to be used with thermowell as specified on Westinghouse drawing Reactor Coolant Fast Response RTD Drawing No. 21232 (refer to TAB I, Section 2).

R1

R1

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (Yes/No/NA)? (Note below.)

	<u>Yes/No/NA</u>	<u>Reference</u>
		para. 2.9,
		(1)
(a) Equipment inspected for damage	<u>Yes</u>	pg 9
(b) Baseline performance measurements taken	<u>Yes</u>	para. 2.9, pg. 9, (1) App C. pg 56 (2)
(c) Equipment aged: (4)		para. 5.1,
Thermal	<u>Yes</u>	(2) pg 10
Radiation	<u>Yes</u>	(2) pg 10
Wear	<u>Yes</u>	(2) pg 5
(d) Vibration/seismic testing conducted	<u>Yes</u>	para. 5.4, pg 11 (2) para. 5.5, pg 12 (2)
(e) Design basis event (DBE) exposure	<u>Yes</u>	para. 5.6, (2) pg 13
(f) Post-DBE exposure	<u>Yes</u>	para. 5.6, (2) pg 13
(g) Final inspection and disassembly	(3)	(3)

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately document (Yes/No/NA)? Yes
(Reference: Table 2, pp 20-23 (2)).

JUSTIFICATION/COMMENTS (1) Equipment Qualification Data Package

(2) EQDP-ESE-7 Qualification Report WCAP-8687, Supp. 2-E07A |R1

(3) RTDs were subjected to final inspection (refer to Equipment Qualification Data Package EQDP-ESE-7 page 10 paragraph 2.9). |R1

PAGE B-12 R1

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 11 OF 43

R 1 R _____

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 WEC
12-23-88

TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/11/86 WEC
1-4-89

JUSTIFICATION/COMMENTS (Continued)....

and were subjected to post Qualification Performance Tests

(Refer to Qualification Report WCAP-8687, Supp. 2-E07A Appx C). | R1

(4) RTDs were subjected to thermal cycling (Refer to

Qualification Report WCAP-8687 Supp. 2-E07A page 10 | R1

paragraph 5.2).

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 12 OF 43
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/19/86 WC
 10-28-86
 TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/19/86 WC
 1-4-89

H. AGING

- (1) Was aging considered in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687 Supp. 2-EQ7A, paragraph 3.1, page 3). |R1

JUSTIFICATION/COMMENTS _____

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	para, 3.1.1, pg 3 (1)
Radiation exposure	<u>Yes</u>	para. 3.1.3, 3.1.4, pg 4 (1) para. 3.1.5,
Vibration (non-seismic) aging	<u>Yes</u>	pg 4 (1)
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	para. 3.1.2, pg 3 (1) Para 3.1.5, pg 4 (1)
JUSTIFICATION/COMMENTS	(1)	<u>Qualification Report WCAP-8687, Supp. 2-EQ7A</u>

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (Yes/No/NA)? NA (Reference: _____).

JUSTIFICATION/COMMENTS Based upon review of materials of construction, no known synergistic effects apply to this equipment.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687 Supp. 2-EQ7A paragraph 3.1.1., page 3 and paragraph 5.1, page 10). |R1

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 13 OF 43
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG
 10-15-87
 TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 WCG
 1-4-89

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687 Supp. 2-E07A, paragraph 3.1.1, page 3). |R1

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for thermal aging identified in the qualification program (Yes/No/NA)? Yes (Reference: Equipment Qualification Data Package EQDP-ESE-7, paragraph 1.9, page 4; Qualification Report WCAP-8687 Supp. 2-E07A, paragraph 5.1, page 10). |R1

JUSTIFICATION/COMMENTS _____

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687 Supp. 2-E07A, paragraph 5.1, page 10). |R1

Parameter	Plant	Maximum Normal	Test	Equivalent
Temperature	<u>200°F</u> (1)	<u>104°F</u> (2)	<u>400°F</u> (3)	<u>200°F</u> (4)
Time	<u>40 Years</u>		<u>11 days</u>	<u>> 40 Years</u>

JUSTIFICATION/COMMENTS (1) (2) (3) (4) Refer to Sheet 14, this TAB.

- (e) Was the Arrhenius methodology used for accelerated aging (Yes/No/NA)? Yes (Reference: Equipment Qualification Data Package EQDP-ESE-7, paragraph 1.9, page 4). |R1

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (Yes/No/NA)? No (Reference: (5) Refer to Sheet 14, this TAB). |R1

JUSTIFICATION/COMMENTS _____

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG CJH12/20/88 7/12/90TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 HDR AFM1/4/89 7/16/90

H(4) Aging (Continued)

- (1) The plant maximum normal temperature for RTDs 1-TE-68-319, -324 is 200°F. Qualification Report WCAP-8687, Supp 2-E07A, page 10, paragraph 5.1 denotes a 50° temperature rise due to the effects of the Reactor Coolant System temperature, was used in determining Qualified Life. Westinghouse has performed an analysis (Cal-note SEC-OSA-1242-GO- on file at Westinghouse) that demonstrates that the air velocity and the ambient temperature of the area are sufficient to limit the temperature of the RTD's head to 200°F. R2
- (2) Temperature rise due to process temperatures for RTDs 1-TE-74-14, -25 is considered negligible. The normal process temperature is 137°F (Refer to TAB C, Sect 1) and the air velocity and ambient temperature are considered sufficient to limit the temperature of the RTDs head to the plant's maximum normal of 104°F.
- (3) Qualification Report WCAP-8687, Supp. 2-E07A, paragraph 5.1, page 10.
- (4) Refer to TAB C, Sect. 3-Calculations WAC-103 and WAC-58 for plant specific Qualified Life.
- (5) The activation energy used is denoted in paragraph 3.1.1, page 3 of Qualification Report WCAP-8687, Supp. E07A. Also, Refer to TAB E, Sect 7 - Letter from Westinghouse to D. Wilson Dtd March 27, 1986 (B71 860404 002).

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 15 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 WBJ
12-11-88
TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/11/86 WBJ
1-4-89

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? NA
(Reference: _____).

JUSTIFICATION/COMMENTS _____

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687 Supp. 2-E07A, paragraph 3.2, page 5). | R1

JUSTIFICATION/COMMENTS _____

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687 Supp. 2-E07A, paragraph 3.1.3, 3.1.4, page 4 and paragraph 5.3, page 10). | R1

JUSTIFICATION/COMMENTS _____

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687, Supp. 2-E07A, para. 3.1.1, p 3). | R1

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? Yes
(Reference: See Comments).

JUSTIFICATION/COMMENTS Design Specification 9532978 Rev 1, paragraph 12.3.2, page 17, Refer to TAB E, Sect. 1; Qualification Report WCAP-8687, Supp. 2-E07A, paragraph 3.1.3, 3.1.4, page 4. | R1

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 16 OF 43
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 WCL?
1-28-88
TEMPERATURE ELEMENT CHECKED WBK DATE 6/11/86 WCL
1-4-89

H. AGING (Continued)

(d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: See

Comments _____

Plant normal ambient radiation dose (rd) 2×10^7 (1) 4.3×10^5 (2)

1×10^6 (2A) |R1
Tip of RTD 1.56×10^8 (3)

Test exposure dose (rd) Cable 1.22×10^8 (4)

Test exposure dose rate (rd/hr) Between 2×10^6 and
 2.5×10^6 (5)

Test exposure source type (e.g., Co-60 gamma) CO-60 gamma (6)

JUSTIFICATION/COMMENTS (1) (2) (3) (4) (5) (6) Refer to Sheet 17 this TAB.

(6) Vibration (non-seismic) Aging:

(a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* (yes/no/NA)?
 (Reference: Qualification Report WCAP-8687 Supp. 2-E07A para. 3.1.5, pg. 4 & para. 5.4, pg 11). |R1

JUSTIFICATION/COMMENTS _____

(b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes
 (Reference: Qualification Report WCAP-8687 Supp. 2-E07A para. 3.1.5 pg. 4 and para. 5.4 pg. 11). |R1

JUSTIFICATION/COMMENTS _____

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the binder.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 17 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 12/15/78
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/88 1-4-89

H(5)(d) Aging - Justification/Comments

- (1) Applies to 1-TE-68-319. | R1
- (2) Applies to 1-TE-74-14, -25. (2A) Applies to 1-TE-68-324. | R1
- (3) Qualification Report WCAP-8687, Supp. 2-E07A paragraph 5.3 page 10 and 11.
- (4) Refer to TAB E, Sect. 5, letter from Westinghouse to D. W. Wilson Dtd. 3-20-86 (B71 860403 004) - states qualified radiation exposure limits of 1.22×10^8 rads (on cable) applicable to Model 21205 RTDs, are acceptable limits for use on Model 21232 RTDs (Qualification of Model 21205 RTDs is documented in EQ Binder WBNEQ-ITE-004).
- (5) Per telecon between J. Capone of Westinghouse and H. Luton of TVA on 6-2-86.
- (6) Qualification Report WCAP-8687, Supp. 2-E07A, para. 4.2.3, page 8. | R1

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 18 OF 43
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 HWL
12/15/88
 TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/11/88 HWL
1-4-89

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687 Supp. 2-E07A, para. 3.1.2, page 3, para. 3.1.5, page 4, para. 5.2, page 10, and para. 5.4, page 11). |R1

JUSTIFICATION/COMMENTS _____

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687 Supp. 2-E07A, para. 3.1.2, page 3, and para. 3.1.5, page 4). |R1

JUSTIFICATION/COMMENTS _____

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Report WCAP-8687 Supp. 2-E07A, para. 3.1.1, pg. 3 & para. 5.1, pg. 10; Equipment Qualification Data Package EQDP-ESE-7, para. 1.9, pg. 4). |R1

Qualified life (Document in QMDS) > 40 YRS

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 19 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 WLB
1225-18
TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/11/88 WLB
1-4-89

H. AGING (Continued)

(9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: See comments)

_____.

JUSTIFICATION/COMMENTS Qualified life of test specimen was
20 years @ normal ambient temperature of 50°C (Refer to
Equipment Qualification Data Package EQDP-ESE-7, page 17, | R1
Table 1).

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
Silicon Varnish	(1)		Not	(2) para.3.1.1
(a) <u>(Cable Coating)</u>	<u>NA</u>	<u>(1)</u>	<u>Specified</u>	<u>pg. 3</u> (3) <u>para.3.1.1</u>
(b) <u>Epoxy (Potting Matl)</u>	<u>NA</u>	<u>(1)</u>	<u>.93eV</u>	<u>pg. 3</u> (3)
(c) _____	_____	_____	_____	_____
(d) _____	_____	_____	_____	_____
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS (1) Cable assembly is qualified to 1.22×10^8
rads. Refer to Sheet 17, Comment (4), this TAB for Justification.

(2) The silicon varnish is only used as a manufacturing process to
prevent the fiber glass insulation of the cable from frying during
manufacturing and is not required for operation of RTD.

(3) Qualification Report WCAP-8687, Supp. 2-E07A, para. 3.1.1.,
pg. 3.

(4) Epoxy as part of RTD assembly is qualified to 1.56×10^8 rads. R2
Refer to Qualification Report WCAP-8687, Supp. 2-E07A, para. 5.3,
page 11. Also refer to TAB E, sect. 7, for epoxy location.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 21 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 12-2-88
TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/11/86 1-4-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (Yes/No/NA)? Yes
(Reference: Equipment Qualification Data Package EODP-ESE-7, Sect. 1.7, pg. 3; Qualification Report WCAP-8687 Supp. 2-E07A, para. 3.2, pg. 5). | R1

Identify Acceptance Criteria: $\pm 0.2^{\circ}\text{F}$ Repeatability, $\pm 1.0^{\circ}\text{F}$ drift allowance; insulation resistance > 1 megohm.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (Yes/No/NA)? Yes
(Reference: Qualification Report WCAP-8687, Supp. 2-E07A, para. 3.2, page 5). | R1

Identify baseline and functional testing: Refer to Sheet 22 this TAB.

JUSTIFICATION/COMMENTS _____

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (Yes/No/NA)? NA
(Reference: Equipment Qualification Data Package EODP-ESE-7, para. 1.1, pg. 2). | R1

JUSTIFICATION/COMMENTS For electrical connections, refer to Sheet 22 this TAB.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 22 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 HWL
16-6-86
TEMPERATURE ELEMENT CHECKED WBK DATE 6/11/86 WBK
1-4-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (CONTINUED)

- J.(2) Baseline Functional Tests (Operation - Normal Condition) are described in the Equipment Qualification Data Package EODP-ESE-7, page 9, para. 2.9. For Baseline Functional Tests results and for Functional Tests (Static Calibration) results performed after each of the test phases refer to Qualification Report WCAP-8687 Supp. 2-E07A, Appx. C, pp. 57 through 60. R1
- J.(3) During static calibration checks, the RTD(s) were excited by a constant current (approx. 1 mA, refer to Equipment Qualification Data Package EODP-ESE-7, page 2, para. 1.1) applied to two leads while the voltage drop was measured across the other two leads. A digital voltmeter was used to measure resistance. Refer to Qualification Report WCAP-8687 Supp. 2-E07A, page 6, para. 4.2.1 and page 31, Figure 4. During each of test phases, the RTD outputs were monitored via Westinghouse 7300 Series amplifiers. The 0-10 volt analog outputs of the amplifiers were monitored and recorded on a digital data logger. Refer to Qualification Report WCAP-8687 Supp. 2-E07A, page 5, para. 3.2 and pages 7 through 9, para(s), 4.2.2, 4.2.3, 4.2.4, and 4.2.5. R1

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 23 OF 43
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCL?
12/88
 TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 WCL
1-4-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? NA (Reference: Refer to J.(3) Sheet this TAB. _____).

JUSTIFICATION/COMMENTS _____

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>R/I Converter with 1 milliamp current</u>	<u>(1)</u>
Load	<u>NA</u>	<u>(1)</u>
Frequence	<u>NA</u>	<u>(1)</u>
Accuracy	<u>(2)</u>	<u>(2)</u>
Other(s)	_____	_____
	_____	_____

JUSTIFICATION/COMMENTS (1) Equipment Qualification Data Package EQDP-ESE-7, para. 1.1, page 2. (2) Refer to Sheet 25, this TAB.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 24 OF 43
 R 1 R 2
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG CAH
 12/20/88 7/12/90
 TEMPERATURE ELEMENT CHECKED WCG DATE 9/17/86 HDR ATM
 1/4/89 7/16/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

<u>(b) Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	R/I Converter with 1 milliamp current	(1)(2)
Load	NA	(1)
Frequency	NA	(1)
Accuracy	(3)	(3)
Other(s)		

JUSTIFICATION/COMMENTS (1) Equipment Qualification Data Pack-
age EODP-ESE-7, para 1.1, p. 2. (2) Electrical Control Dia-
gram Dwg. 47W6, 10-68-5, -74, -1. (3) The demonstrated LOOP
accuracy of $\pm 24.2^{\circ}\text{F}$ for RTDs 1-TE-68-319, -324 and $\pm 10.85^{\circ}\text{F}$ R2
for RTDs 1-TE-74-14, -25 is acceptable for the required
accuracy (refer to TAB C, Page C-47). (SEE OPEN ITEM No. 1 R2
FOR RTDs 1-TE-68-319, -324).

<u>(c) Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	R/I Converter with 1 milliamp current	(1)
Load	NA	(1)
Frequency	NA	(1)
Accuracy	(2)	(1)
Other(s)		

JUSTIFICATION/COMMENTS (1) Equipment Qualification Data
Package EODP-ESE-7, para. 1.1, page 2. (2) Refer to Sheet 25,
this TAB.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 25 OF 43
R 1 R 2
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WCG CAH
12/20/88 7/12/90
TEMPERATURE ELEMENT CHECKED WCG DATE 9/17/86 HDR AFM
1/4/89 7/16/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(c) Accuracy - There are no changes in the RTD due to severe environments. The calibration accuracy is $\pm 0.2^{\circ}\text{F}$ and the drift allowance is $\pm 1.0^{\circ}\text{F}$ (Refer to Equipment Qualification Data Package EODP-ESE-7, Table 1, page 17). Additional allowances of $\pm 2.0^{\circ}\text{F}$ for environmental effects and $\pm 0.2^{\circ}\text{F}$ for sensor drift to be included in Westinghouse's Safety Analyses (Refer to Qualification Report WCAP-8687 Supp. 2-E07A, page 18). For demonstrated loop accuracy refer to Instrument Accuracy Calculations Summary
TAB C, Page C-47.

R2

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 26 OF 43
 R 1 R _____
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 swt
11/10/88
 TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 WCG
1-4-89

K. 1 REQUIRED OPERATING ENVIRONMENT 1-TE-68-319

R1

Reference Environmental Drawing No. 47E235-42

- | | |
|--|--|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>120</u> ⁽¹⁾ | (a) Temperature (°F) <u>130</u> ⁽¹⁾ |
| (b) Pressure (psig) <u>.3</u> | (b) Pressure (psig) <u>.3</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>100</u> |
| (d) Radiation (rd) <u>2x10⁷</u> | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: NA, RTDs are installed in thermowells.
For effects of process temperatures, refer to Sheet 27,
comment 1, this tab.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Maximum abnormal temperature, pressure and
humidity could exist for up to eight hours per excursion and
will occur less than 1% of plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|---|--------------------------------|
| (a) Temperature (°F) <u>327</u> ⁽¹⁾ | Accident type <u>HELB</u> |
| (b) Pressure (psig) <u>11.2</u> | Accident type <u>LOCA</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| | <u>4.7x10⁸ beta</u> |
| (d) Radiation (rd) <u>4x10⁷</u> <u>gamma</u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>Boron</u> ⁽²⁾ | Accident type <u>LOCA</u> |

(1)(2) Refer to Sheet 27, this TAB.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 26A OF 43
 BINDER TITLE INSTRUMENT COMPUTED /R1 WCR DATE 1-12-87 R _____ R _____
 TEMPERATURE ELEMENT _____ CHECKED /R1 WCR DATE 1-12-87

K. 2 REQUIRED OPERATING ENVIRONMENT 1-TE-68-324

Reference Environmental Drawing No. 47E235-41

- | | |
|--|--|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>110</u> ⁽¹⁾ | (a) Temperature (°F) <u>120</u> ⁽¹⁾ |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>1x10⁶</u> | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: NA. RTDs are installed in thermowells.
For effects of process temperatures, refer to Sheet 27,
comment 1, this TAB.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Maximum abnormal temperature, pressure and humidity could exist for up to eight hours per excursion and will occur less than 1% of plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | | |
|--|---------------|--------------------------------|
| (a) Temperature (°F) <u>161</u> ⁽¹⁾ | Accident type | <u>HELB</u> |
| (b) Pressure (psig) <u>11.2</u> | Accident type | <u>LOCA</u> |
| (c) Humidity (%) <u>100</u> | Accident Type | <u>LOCA/HELB</u> |
| | | <u>4.7x10⁸ Beta</u> |
| (d) Radiation (rd) <u>3.8x10⁷</u> | Accident type | <u>LOCA</u> |
| | | <u>Gamma</u> |
| (e) Spray Type <u>Boron</u> ⁽²⁾ | Accident type | <u>LOCA</u> |

(1)(2) Refer to Sheet 27, this TAB.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 27 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 12-28-88
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 1-4-89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

(1) Qualification Report WCAP-8687 Supp 2-E07A, para. 5.1, |R1
p. 10 denotes a 50°C temperature rise, due to the effects of
the Reactor Coolant System temperature, was used in determining
qualified life. Westinghouse has performed an analysis
(Cal-note SEC-OSA-1242-C0- on file at Westinghouse) that
demonstrates that the air velocity and the ambient temperature
of the area are sufficient to limit the temperature of the
RTD's head to 200°F.

(2) Refer to Sheet 33, this TAB, for Composition.

K. 3 REQUIRED OPERATING ENVIRONMENT 1-TE-74-14, -25

Reference Environmental Drawing No. 47E235-50 | R1

- | | |
|--|--|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> ⁽¹⁾ | (a) Temperature (°F) <u>110</u> ⁽¹⁾ |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>4.3x10⁵</u> | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: NA, RTDs are installed in thermowells.
For effects of process temperatures, refer to Sheet 14,
comment 2, this TAB.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Maximum abnormal temperature and humidity could exist for up to eight hours per excursion and will occur less than 1% of plant life.

- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|--|---------------------------|
| (a) Temperature (°F) <u>NA</u> | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>NA</u> | Accident type <u>LOCA</u> |
| (c) Humidity (%) <u>NA</u> | Accident Type <u>LOCA</u> |
| (d) Radiation (rd) <u>1x10⁷</u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

(1) Refer to Sheet 17, Comment 2, this TAB.

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Refer to Sheet 33 this TAB for spray composition and pH.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: Refer to

HOR
PHM
3-17-89
h
3-17-89

Sheet 30 this TAB.)

(7) Subject to submergence (Yes/No/NA)? Yes (Reference: Refer to Sheet 30 this TAB.)

R1

Identify initiation time and duration of submergence: _____

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes
 (Reference: Environmental data drawing 47E235-50).

R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA -

Refer to Sheet 30 this TAB.

(9) Special environmental calculations (temp., rad., etc.)

Type	RIMS No.
_____	_____
_____	_____
_____	_____

R1

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 30 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 ^{.WCG}
_{12-23 88}
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 ^{WCG}
₁₋₄₋₈₉

K. REQUIRED OPERATING ENVIRONMENT (Continued)

K. (6) Reference - Environmental Data Drawings 47E235-42
(Note 46) and -50 (Note 48).

R1

K. (7) Reference - RTDs 1-TE-68-319, -324 are located above
surge flood level of 722'. RTDs 1-TE-74-14, -25 are located
1'1" below the RHR HELB flood level (the only event causing
flooding on elevation 713, room A12 per environmental drawing
47E235-50). The RTD's are not required to function for this
event per OE calculation WBNOSG4-020 - Category and Operating
Times (see Section A, this TAB).

R1

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
1-TE-68-319, 324

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>15 days</u>	Tab C, Sect. 3 ⁽¹⁾ Fig. 7, pg. 34 R1
Temperature (°F)	<u>327</u>	<u>420</u>	Fig. 7, pg. 34 ⁽¹⁾ Table 1, pg. 17
Pressure (psig)	<u>11.2</u>	<u>75</u>	Fig 9, pg. 36 ⁽¹⁾ Table 1, pg. 17 ⁽²⁾
Relative Humidity (%)	<u>100</u>	<u>100</u>	Table 1, pg. 17 ⁽²⁾
Chemical Spray*	Sheet 33 <u>this TAB</u>	Sheet 33 <u>this TAB</u>	Para. 3.1.7, pg. 5 ⁽¹⁾ Table 1, pg. 17 ⁽²⁾
Radiation (rd)**	<u>6x10⁷ gamma</u> <u>4.7x10⁸ beta (3)</u>		Table 1, pg. 17 ⁽²⁾ Para. 5.3, pg. 11 ⁽¹⁾
Submergence	<u>NA</u>		

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	Fig. 7, pg. 34 ⁽¹⁾ Table 1, pg. 17 ⁽²⁾
Pressure	<u>Yes</u>	Fig. 9, pg. 36 ⁽¹⁾ Table 1, pg. 17 ⁽²⁾
Relative Humidity	<u>Yes</u>	Table 1, pg. 17 ⁽²⁾
Chemical Spray	<u>No</u>	Sheet 33 this TAB
Submergence	<u>NA</u>	

(1)(2)(3) Refer to Sheet 32, this TAB.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 32 OF 43
 R 1 R 2
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 WCG CAH
 12/20/88 7/12/90
 TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/12/86 HDR ASM
 1/4/89 7/16/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (1) Qualification Report WCAP-8687, Supp. 2-E07A.
- (2) Equipment Qualification Data Package EQDP-ESE-7.
- (3) a) RTD TIP - 1.56×10^8 rads gamma.

b) Cable - 8.64×10^6 rads gamma. However, the cable is identical in design and makeup to the RdF Model 21205 cable. Therefore, qualified radiation exposure limits of 1.22×10^8 rads gamma are acceptable limits (Refer to TAB E, Section 5, letter from Westinghouse to D. W. Wilson, Dtd. 3-20-86. RIMS No. B71 860403 004). Qualification of the Model 21205 RTD/Cable Assembly is documented in EQ Binder WBNEQ-ITE-003.

c) No actual Beta irradiation was performed. However, the ^{CAH 7/12/90} cable is identical in design and makeup to the RdF Model 21205 RTD cable (Refer to TAB E, Sect. 5, letter to D. W. Wilson Dtd. 3-20-86, RIMS No. B71 860403 004). The RTD probe contains no aging sensitive materials ^{R2} (materials consist of stainless steel, platinum wire and magnesium oxide). Therefore, the qualified radiation exposure limits of 9.13×10^8 rads beta for the RdF ^{R2} Model 21205 RTD/Cable Assembly as documented in EQ Binder WBNEQ-ITE-003, are acceptable limits for the RdF Model 21232 RTD/Cable Assembly.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 33 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 ^{401??}
₁₂₋₁₄₋₈₇
TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 ^{1/02}
₁₋₄₋₈₉

L.(1) SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS -
COMPARISON OF WORST-CASE PROFILES AND MARGIN ASSESSMENT

Chemical Spray

Specified - The chemical spray composition is 0.19 molar H_3BO_3 (2000ppm Boron), 0.003 molar NaOH resulting in a pH of 8.3 at 25°C. The flow rate is equal to 0.92 gal/min per square foot of containment cross section. Refer to Environmental Data Drawings 47E235-41 and -42, Notes 5 and 22 (Both Drawings).

R1

Demonstrated - The chemical spray composition consisted of 2750ppm Boron buffered with 0.9 percent dissolved NaOH to a pH of 10.7 at 25°C and was applied from the start of HELB simulation to 24 hours. The flow rate was not specified. Refer to TAB C, Section 2 for acceptability.

R1

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	>15°F	Yes
Pressure: +10% but no more than 10 psig	>10%	Yes
Radiation: +10% of accident dose	>10%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	No	(3)
Voltage: ±10% of rated value	NA	_____
Frequency: ±5% of rated value	NA	_____
Environmental Transient: the initial transient and the peak temperature applied twice	Yes (1)	Yes
Vibration: +10% added to acceleration	(2)	Yes

JUSTIFICATION/COMMENTS (1) Qualification Report WCAP-8687.

Supp. 2-EQ7A, Figure 7, page 34. (2) Equipment Qualification

Data Package EODP-ESE-7, paragraph 2.10.3.3, page 11.

(3) Refer to TAB C, Section 3 Material Aging Calculation

Report WAC-191 for plant specific applied margin.

R1

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
1-TE-74-14, -25

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>15 days</u>	Tab C, Sect. 3 Fig. 7, pg. 34 ⁽¹⁾ R1
Temperature (°F)	<u>110</u>	<u>420</u>	Fig. 7, pg. 34 ⁽¹⁾ Table 1, pg. 17
Pressure (psig)	<u>0</u>	<u>75</u>	Fig 9, pg. 36 ⁽¹⁾ Table 1, pg. 17 ⁽²⁾
Relative Humidity (%)	<u>90</u>	<u>100</u>	Table 1, pg. 17 ⁽²⁾
Chemical Spray*	<u>NA</u>	_____	Para. 5.3, pg. 11 ⁽²⁾ Table 1, pg. 17 ⁽²⁾
Radiation (rd)**	<u>1.043x10⁷ gamma</u>	<u>(3)</u>	Para. 5.3, pg. 11 ⁽¹⁾ Table 1, pg. 17 ⁽²⁾
Submergence	<u>NA</u>	_____	_____

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	Fig. 7, pg. 34 ⁽¹⁾ Table 1, pg. 17 ⁽²⁾
Pressure	<u>Yes</u>	Fig. 9, pg. 36 ⁽¹⁾ Table 1, pg. 17 ⁽²⁾
Relative Humidity	<u>Yes</u>	Table 1, pg. 17 ⁽²⁾
Chemical Spray	<u>NA</u>	_____
Submergence	<u>NA</u>	_____

(1)(2)(3) Refer to Sheet 36 this TAB.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 36 OF 43
R 1 R _____
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 WC
1-1-86
TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/11/86 WOK
1-4-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
(Continued)

- (1) Qualification Report WCAP-8687, Supp. 2-E07A.
- (2) Equipment Qualification Data Package EQDP-ESE-7.
- (3) a) RTD TIP - 1.56×10^8 rads gamma.

R1

b) Cable - 8.64×10^6 rads gamma. However, the cable is identical in design and makeup to the RdF Model 21205 cable. Therefore, qualified radiation exposure limits of 1.22×10^8 rads gamma are acceptable limits (Refer to TAB E, Section 5, letter from Westinghouse to D. W. Wilson, Dtd. 3-20-86. RIMS No. B71 860403 004). Qualification of the Model 21205 RTD/Cable Assembly is documented in EQ Binder WBNEQ-ITE-003.

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 37 OF 43
 R 1 R
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 9/11/86 WJ?
12-288
 TEMPERATURE ELEMENT _____ CHECKED WCG DATE 9/17/86 WJ?
1-4-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	>15°F	Yes
Pressure: +10% but more than 10 psig	>10%	Yes
Radiation: +10% of accident dose	>10%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	No	(3)
Voltage: ±10% of rated value	NA	
Frequency: ±5% of rated value	NA	
Environmental Transient: the initial transient and the peak temperature applied twice	Yes (1)	Yes
Vibration: +10% added to acceleration	(2)	Yes

JUSTIFICATION/COMMENTS (1) Qualification Report WCAP-8687,
 Supp. 2-EO7A, Figure 7, page 34. (2) Equipment Qualification
Data Package EODP-ESE-7, paragraph 2.10.3.3, page 11.
 (3) Refer to TAB C, Section 3 Material Aging Calculation
Report WAC-191 for plant specific applied margin.

R1

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 38 OF 43
R 1 R
BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 WJ
12-15-88
TEMPERATURE ELEMENT CHECKED WMR DATE 6/11/86 WJ
1-4-89

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference: Refer to TAB A).

JUSTIFICATION/COMMENTS _____

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: Qualification Report WCAP-8687 Supp. 2-E07A, | R1
para. 6.2, pg. 14, and para. 7.2, pp. 17, 18).

JUSTIFICATION/COMMENTS _____

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (Yes/No/NA)? Yes
(Reference: Qualification Report WCAP-8687, Supp. 2-E07A, | R1
para. 6.2, pg. 14, and para 7.2, pp. 17, 18).

JUSTIFICATION/COMMENTS _____

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (Yes/No/NA)? Yes (Reference: Refer to TAB C, Section 3). | R1

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 39 OF 43

R 1 R

BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 ⁴⁰⁰⁷
₁₁₋₂₃₋₈₆

TEMPERATURE ELEMENT CHECKED WBK DATE 6/11/86 ⁷⁶⁹²
₁₋₉₋₈₉

M. OPERABILITY TEST RESULTS (Continued)

(5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? NA

(Reference: _____)

JUSTIFICATION/COMMENTS No anomalies were noted in Qualification Report WCAP-8687 Supp. 2-E07A or Equipment Qualification Data Package EODP-ESE-7.

RI

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 40 OF 43
R R
BINDER TITLE INSTRUMENT COMPUTED K.L.C. DATE 6-10-86
TEMPERATURE ELEMENT CHECKED WLR DATE 6-11-86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 41 OF 43
 BINDER TITLE INSTRUMENT COMPUTED HWC DATE 6-10-86 R R
 TEMPERATURE ELEMENT _____ CHECKED WJR DATE 6-11-86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>NA</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>NA</u>
(b) Were specific features and failure modes and effects analyzed?	<u>NA</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>NA</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 42 OF 43
 BINDER TITLE INSTRUMENT COMPUTED HWL DATE 6/10/86 ^{HWL} R 1 R 12-28-88
 TEMPERATURE ELEMENT _____ CHECKED WBK DATE 6/11/86 ^{HWL} R 1-4-89

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	No-Refer to TAB C, Sect. 2, for ac- ceptability
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

R1

BINDER NO. WBNEQ-ITE-004 PLANT WBN UNIT(S) 1 SHEET 43 OF 43
 BINDER TITLE INSTRUMENT COMPUTED KCWL DATE 6-10-86
 TEMPERATURE ELEMENT _____ CHECKED WJK DATE 6-11-86

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>Yes</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1

BINDER TITLE: FENWAL COMPUTED BDM DATE 5-15-86 R R

CHECKED ANZ DATE 5/15/86

TAB A - IDENTIFICATION OF EQUIPMENT COMPRISING THE EQUIPMENT TYPE

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZIMUTH ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TS -001-0017A -A TEMP SWITCH STM FLOW TO AFPT	1-TS -001-0017A -A 17323-0	692° 75K13-086422	A05	A	5MIN	AF	DETECT AFPT ROOM HIGH TEMP TO INITIATE STEAM SUP ISLN. SWITCH CANNOT FAIL SO AS TO INDICATE AFPT ROOM HIGH TEMP AND INITIATE STEAM SUPPLY ISLN
WBN-1-TS -001-0017B -A TEMP SWITCH STM FLOW TO AFPT	1-TS -001-0017B -A 17323-0	692° 75K13-086422	A06	A	5MN	AF	DETECT AFPT ROOM HIGH TEMP TO INITIATE STEAM SUP ISLN. SWITCH CANNOT FAIL SO AS TO INDICATE AFPT ROOM HIGH TEMP AND INITIATE STEAM SUPPLY ISLN
WBN-1-TS -001-0018A -B TEMP SWITCH STM FLOW TO AFPT	1-TS -001-0018A -B 17323-0	692° 75K13-086422	A06	A	5MN	AF	DETECT AFPT ROOM HIGH TEMP TO INITIATE STEAM SUP ISLN. SWITCH CANNOT FAIL SO AS TO INDICATE AFPT ROOM HIGH TEMP AND INITIATE STEAM SUPPLY ISLN
WBN-1-TS -001-0018B -B TEMP SWITCH STM FLOW TO AFPT	1-TS -001-0018B -B 17323-0	692° 75K13-086422	A05	A	5MN	AF	DETECT AFPT ROOM HIGH TEMP TO INITIATE STEAM SUP ISLN. SWITCH CANNOT FAIL SO AS TO INDICATE AFPT ROOM HIGH TEMP AND INITIATE STEAM SUPPLY ISLN
WBN-3-TS -012-0091A -A TEMP SW - AUX BLDG STEAM LINE RUPTURE	3-TS -012-0091A -A 12923-7	729° 34KK5-334197	A05	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.

PAGE A-2 RI

PREPARED/DATE BDM 8/11/86
 CHECKED/DATE AWL 8/16/86
 R-1
 8/21/89
 1-21-87

PRINT DATE: 01/11/89

BINDER NO. : W6NEQ-ITS -00
 MANUFACTURER : FENWAL
 PAGE 2 OF 4

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZMIH ELEV(1) RM/BLD CONTRACT	CAI (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-0-TS -012-0091B -B TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0091B -B 18023-7	729 ⁰ A06 84KK3-334197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-0-TS -012-0092A -A TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0092A -A 18023-7	692 ⁰ A14 84KK3-334197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-0-TS -012-0092B -B TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0092B -B 18023-7	692 ⁰ A14 84KK3-234197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-0-TS -012-0093A -A TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0093A -A 18023-7	713 ⁰ A01 84KK3-334197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-0-TS -012-0093B -B TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0093B -B 18023-7	713 ⁰ A01 84KK3-334197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.

PAGE A-3 RI

PREPARER/DATE _____ BDM 8/11/86
 CHECKED/DATE _____ AWL 8/16/86
 R-1
 8 E M
 1/21/89
 2/02
 2-21-89

PRINT DATE: 01/11/99

BINDER NO. : WBNEQ-ITS -0
MANUFACTURER : FENWAL
PAGE 3 OF 4

W A T T S 3 4 R N U C L E A R P L A N T
T A G A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	ADMID CONTRACT	ELEV(1) CONTRACT	GM/RAD	CAI	OPER TIME	EVENT	SAFETY FUNCTION
WBN-3-TS -012-0095A -A TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0095A -A 18023-7		692'	AG1 84KK3-934197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-3-TS -012-0095B -B TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0095B -B 18023-7		692'	AG1 84KK3-934197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-0-TS -012-0096A -A TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0096A -A 18023-7		692'	A01 84KK3-334197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-3-TS -012-0096B -B TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0096B -B 18023-7		692'	A01 84KK3-334197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-3-TS -012-0098A -A TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0098A -A 18023-7		692'	A01 84KK3-334197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.

PAGE A-4 RI

PREPARER/DATE	BDM	8/11/86	R ¹ _{88m}	R	R
CHECKED/DATE	AWL	8/16/86	2/21/89		
			2-21-89		

PRINT DATE: 01/11/89

BINDER NO. : W6NEQ-ITS -0
MANUFACTURER : FENWAL
PAGE 4 OF 4

W A T T S S A R N U C L E A R P L A N T
T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQUIS. NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
		ALMITH	ELEV(1) RM/RAD CONTRACT				
WBN-D-TS -012-0098B -B TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0098B -B 15023-7	692°	A01 S4KK3-334197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-D-TS -012-0099A -A TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0099A -A 18023-7	692°	A14 S4KK3-834197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.
WBN-D-TS -012-0099B -B TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0099B -B 18023-7	692°	A14 S4KK3-834197	A	1MN	AB	DETECT AUX BLDG STEAM LINE RUPTURE AND INITIATE ISLN OF TURBINE BLDG STEAM FLOW TO AUX BLDG.

PAGE A-5 RI

PREPARED/DATE BDM 8/11/86
 CHECKED/DATE AWL 8/16/86
 R 1
 R
 R
 8/11/86
 2-21-87

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET _____ OF _____
R _____ R _____
BINDER TITLE FENWAL COMPUTED RI Est DATE 2/21/89
CHECKED RI Hor DATE 2-21-89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-2 for source of Category and Operating Time assignments.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86
CHECKED AWL DATE 5/15/86

TAB B

Contents:

EQ Checksheets

PAGE B-1

EQP058.21

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B1 OF 40
R 1 R 3
BINDER TITLE FENWAL COMPUTED BDM DATE 9-15-86 EEM EB 127
2/21/89 1/31/90
CHECKED AWL DATE 9-18-86 HDR ARM
2/21/89 2/7/90

A. DOCUMENTATION

Equipment Description Temperature Switches
Vendor/Manufacturer Fenwal
Equipment Model No.(s) 17323-0
18023-7

QUALIFICATION REPORTS

(1) Title/Number/Revision Wyle Nuclear Equip- RIMS EEB 830803516
ment Qualification, Temperature Switches/
17509-1/RO DATE May 16, 1983

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (2) Material Aging Calculation (WAC-10).
- (3) System "1" Category and Operating Times (WBNOSG4-004 R10, B45 861017 218).
- (4) System "12" Category and Operating Times (WBNOSG4-006 R4, B45 851031 226).
- (5) QIR NEB86072, "Location Specific Dose Analysis for 0-TS-12-91 A & B" (B45 860613 263).
- (6) WBPE0018604016 RO System "1" Instrument Accuracy Calculation (B43 860519 901).
- (7) 0-TS-12-91A Instrument Accuracy Calculation (B43 860117 903).
- (8) System "1" Set-point Evaluation (B44 860401 008).
- (9) WBNOSG4-050 R1 System "12" Set-point Evaluation (B45 860530 219).
- (10) Environmental Data Drawing 47E235-39, R4 and DCA-P-02351-06-0 and -07-0 per DCN P-02351-A (B26 881210 801)
- (11) Environmental Data Drawing 47E235-40, R3 and DCA-P-022351-08-0 and -09-0 per DCN P-02351-A (B26 881210 801).

R3

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B1A OF 40
R 2 R 3
BINDER TITLE FENWAL COMPUTED BDM DATE 8-18-86 EEM EEM
10/17/89 11:30/90
CHECKED AWL DATE 8-25-86 WCG AWM
10/18/89 217/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (12) Environmental Data Drawing 47E235-52, R1.
- (13) Environmental Data Drawing 47E235-62, R1.
- (14) Environmental Data Drawing 47E235-68, R1.
- (15) Environmental Data Drawing 47E235-69, R2 and DCA-P-02351-23-0
per DCN P-02351-A (B26 881210 801). | R3
- (16) Environmental Data Drawing 47E235-54, R2.
- (17) Environmental Data Drawing 47E235-63, R2 and DCA-P-02351-19-0
per DCN P-02351-A (B26 881210 801). | R3
- (18) Environmental Data Drawing 47E235-64, R2 and DCA-P-02351-20-0
per DCN P-02351-A (B26 881210 801). | R3
- (19) QIR NEB86203, "Re-Analysis of Location Specific Calculations"
(B45 861007 258).
- (20) EQIR WBN EQC 89007 (Attachment 2) "Calibration Cards
For System 12 Temperature Switches" (T48 890928 918).
- (21) EQIR WBN EQC 89013 "Explanation of 1D number variations
for system 12 temperature switches." (T48 891122 984) | R3

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B2 OF 40
R 3 R
BINDER TITLE FENWAL COMPUTED BDM DATE 9-15-86 LEE
1/30/90
CHECKED AWL DATE 9-18-86 AWM
2/7/90

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified (Pending Acceptable Resolution
of Open Items)
- Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES:

- (1) Deleted.
- (2) Deleted
- (3) Required accuracy for System 1 switches based on preliminary
information. Audit Finding Deficiency number 86-21-D01
identifies concern with required accuracy calculations and
system 12 demonstrated accuracy calculation.

|R3

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B3 OF 40
R 1 R _____
BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 ESM
2/21/89
CHECKED AWL DATE 5-15-86 H/S
2-21-89

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS M/N 17323-0 devices were original installation and subject to NUREG 0588, Cat. II. M/N 18023-7 was a later procurement and subject to NUREG 0588, Cat. I. All Fenwal M/Ns were qualified by test in accordance with 10CFR50.49 and NUREG 0588, Cat. I.

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

Reference Report Section XIII (1.2)

- IEEE 323-1974 and 344-1975

- NUREG 0588, Category I

- Reg Guides 1.89 and 1.100

- 10CFR50 Appendix B

- ANSI N45.2

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B4 OF 40
 R 1 R _____
 BINDER TITLE FENWAL COMPUTED BDM DATE 8-9-86 EEW
2/21/87
 _____ CHECKED AWL DATE 8-16-86 HSZ
2-21-87

D. QUALIFICATION METHODOLOGY (Check only one block)

- X Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- _____ Test of Similar Items with Supporting Analysis
- _____ Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- _____ Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The Wyle EQ Test Report No. 17509-1 (TAB D) | R1
was conducted specifically for TVA BFN, and SON; however, due to
similar environment (temperature, pressure, radiation), similar
application and test of identical model numbers--the test report is
also applicable to WBN. Testing was performed on identical types
of temperature switches (Model No. 18023-7 and 17323-0) installed
at WBN.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B5 OF 40

BINDER TITLE FENWAL COMPUTED BDM DATE 8-9-86 R R

CHECKED ANL DATE 8/14/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Temp Switch</u>	<u>Same</u>	<u>See 1 below</u>
(2) Manufacturer	<u>Fenwal</u>	<u>Same</u>	<u>See 1 below</u>
(3) Model Number(s)	<u>17323-0</u>	<u>Same</u>	<u>See 1 below</u>
	<u>18023-7</u>	<u>Same</u>	<u>See 1 below</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(4) Serial Number(s)	<u>NA</u>	<u>NA</u>	<u>NA</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(5) Identify Component- Unique checksheet attached:	<u>NA</u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS

- 1. Tab D, PAGE XII, and Tab F (Field Verification).
- _____

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B6 OF 40
 BINDER TITLE FENWAL COMPUTED BOM DATE 7-11-86 R R
 CHECKED ASL DATE 8/16/86

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>None</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>None</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>**Connections should be per qualified plant procedures and covered with Raychem tubing.</u>	<u>*</u>	<u>Section I, pgs I-2, I-3, (2.2.1 & 2.2.4) Sect. XIII, (Fig 26)</u>
Conduit Seals	<u>**</u>	<u>*</u>	<u>Section I, pgs I-2, I-3, (2.2.2 & 2.2.4), Sect. XIII (Fig 26)</u>
Connector Seals	<u>***Raychem heat-shrink tubing on terminations</u>	<u>*</u>	<u>Sect. I, pg I-2, I-3, (2.2.2 & 2.2.4), Sect. XIII (Fig. 26)</u>
Orientation	<u>None</u>	<u>NA</u>	<u>NA</u>
Physical Configuration	<u>None</u>	<u>NA</u>	<u>NA</u>
Other	<u>None</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS

*Requirements entered in QMDS (See Tab G).
**M/N 18023-7 does not require conduit seals; however, continuous conduit (flex or rigid) is required from the switch to the junction box.
***Refer to Binder No. WBNEQ-SPLC-001 regarding qualification of the Raychem heat-shrink tubing.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B7 OF 40
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-24-86
 CHECKED AVL DATE 5-20-86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	Tab D Sect. I, pg I-1, (2.1)
(b) Baseline performance	<u>Yes</u>	Tab D Sect. I, pgs I-3 thru I-7 (2.3 thru 2.4, 3.0 results)
(c) Equipment aged:		
Thermal	<u>Yes</u>	Tab D Sect. IV, pgs IV-1 thru IV-5
Radiation	<u>*NA</u>	Tab D Sect. II (1.1)
Wear	<u>Yes</u>	Sect. VI, pgs VI-1 thru VI-4
(d) Vibration/seismic testing conducted	<u>Yes</u>	Tab D Sect. VIII, pgs VIII-1 thru VIII-5
(e) Design basis event (DBE) exposure	<u>Yes</u>	Tab D Section X, pgs X-1 thru X-5
(f) Post-DBE exposure	<u>Yes</u>	Tab D Section X pgs X2 thru X-4
(g) Final inspection and disassembly	<u>Yes</u>	Tab D Section XII

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes (Reference Tab D page xii).

JUSTIFICATION/COMMENTS Refer also to Tab D pages i, ii.

*See page B12, Section H5-C.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B8 OF 40
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-5-86 R R
 CHECKED ANZ DATE 5/15/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference Tab D Section IV, VI).

JUSTIFICATION/COMMENTS _____

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Tab D Section IV</u>
Radiation exposure	<u>* NA</u>	<u>Tab D Section II (1.1)</u>
Vibration (non-seismic) aging	<u>** No</u>	<u>NA</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>Tab D Section IV</u>

JUSTIFICATION/COMMENTS * See page B12, Section H5-C.

** See page B9.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? No (Reference Section XIII (3.4)).

JUSTIFICATION/COMMENTS Long-term effects from temperature, cycling, seismic and humidity were considered in the testing; however, radiation exposure was not performed in the test program due to low TID (see page B12, Section H-5C).

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference Tab D Section IV).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B9 OF 40
BINDER TITLE FENWAL COMPUTED BAm DATE 5-15-86 R R
CHECKED AVL DATE 5/15/86

**Non-seismic vibration is not an EQ consideration for these devices.
These devices are rigidly wall mounted. Also, the seismic testing
(Tab D Section VIII, Section IX) adequately demonstrates the
mechanical structural integrity of these devices.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B10 OF 40
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 R R
 CHECKED AWR DATE 5/15/86

H. AGING

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: Tab D Section XIII, Table I).

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Tab D Section XIII (3.4)).

JUSTIFICATION/COMMENTS _____

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Tab D Sect. XIII(3.4), Sect. IV).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
	<u>(.99)104°F +</u>		
<u>Temperature</u>	<u>(.01)110°F=104.06°F</u>	<u>*</u>	<u>*</u>
<u>Time</u>	<u>40 years</u>	<u>*</u>	<u>*</u>

JUSTIFICATION/COMMENTS *See Sheet B11.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Tab D Sect. XIII(3.4), Sect. IV).

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference Tab D Section XIII, Table I).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B11 OF 40
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86
 CHECKED ARL DATE 5/15/86

M/N 17323-0

Case I

<u>Parameter</u>	* <u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature (°F)	<u>104.06</u>	<u>172.4</u>	<u>104.06</u>
Time	<u>40 years</u>	<u>213.2 hrs</u>	<u>21.30 yrs</u>

Case II

<u>Parameter</u>	* <u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature (°F)	<u>104.06</u>	<u>172.4</u>	<u>104.06</u>
Time	<u>40 years</u>	<u>406 hrs</u>	<u>40.56 yrs</u>

Case I - Applications where switch is required to actuate on both
increasing and decreasing temperatures.

Case II - Applications where switch is required to actuate on
increasing temperature only. (Reference Tab C, Thermal Aging
Analysis).

*Plant max normal includes 1% of 40 year plant life at max abnormal
temperature.

M/N 18023-7

<u>Parameter</u>	* <u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature (°F)	<u>104.06</u>	<u>172.4</u>	<u>104.06</u>
Time	<u>40 years</u>	<u>102 hrs</u>	<u>10.19 yrs</u>

Reference-Tab C, Thermal Aging Analysis

*Plant max normal includes 1% of 40 year plant life at max abnormal
temperature.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B12 OF 40

BINDER TITLE FENWAL COMPUTED BDM DATE 6-24-86 R R

CHECKED RJK DATE 6/25/86

H. AGING (Continued)

(g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? NA (Reference).

(h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference Tab D Section IV).

JUSTIFICATION/COMMENTS Operation during thermal aging not
a factor for this type of equipment.

(5) Radiation Aging Exposure:

(a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference Tab D Section II(1.1)).

JUSTIFICATION/COMMENTS These devices were exempted from
radiation exposure in testing. See comment below.

(b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes (Reference Tab D Section XIII, Table I).

JUSTIFICATION/COMMENTS

(c) Was the basis for excluding radiation aging exposure identified in the qualification program (yes/no/NA)? No (Reference Tab D Section II(1.1), Section XIII, Table I).

JUSTIFICATION/COMMENTS Worst case radiation exposure for
both M/N 17323-0 and 18023-7 is less than 5×10^4 rad (TID).
For this equipment a dose of approximately 5×10^4 rad, gamma
is considered negligible based on the equipment's design,
materials used, and other test data. In the qualification
test, identical devices with respect to materials and funct-
ional design, but having different model numbers were
successfully qualified for doses in excess of 1×10^7 rad,
gamma (Tab D sheets iii, iv and Section II(1.1)).

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B13 OF 40
 R 1 R _____
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 EEW
2/21/89
 CHECKED AWL DATE 5-15-86 AWL
2-21-89

H. AGING (Continued)

(d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? NA (Reference: NA).

Plant normal ambient radiation dose (rd) NA

Test exposure dose (rd) NA

Test exposure dose rate (rd/hr) NA

Test exposure source type (e.g., Co-60 gamma) NA

JUSTIFICATION/COMMENTS *See page B12 Section H(5)

(6) Vibration (non-seismic) Aging:

(a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ No (Reference: NA).

JUSTIFICATION/COMMENTS **See comment on Section H(2) page B9. Non-seismic Aging.

(b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? NA (Reference: NA).

JUSTIFICATION/COMMENTS _____

(7) Operational Stress Aging:

(a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: TAB D Section VI, Section XIII (3.4.4)).

JUSTIFICATION/COMMENTS _____

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B14 OF 40
 R 1 R _____
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 EEA
2/21/89
 CHECKED AWL DATE 5-15-86 WCR
2-21-89

H. AGING (Continued)

(b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, Section VI).

JUSTIFICATION/COMMENTS These devices are cycled only during routine testing; not during normal operation.

(8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, page iii, Section IV).

Qualified life (Document in QMDS) See sheets B15

JUSTIFICATION/COMMENTS _____

(9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, page iii, Section IV).

JUSTIFICATION/COMMENTS _____

|R1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET _____ OF _____
R _____ R _____
BINDER TITLE FENWAL COMPUTED IRI 88M DATE 2/21/89
CHECKED IRI HSR DATE 2-21-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-17 was deleted per revision 1 .

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B16 OF 40

BINDER TITLE FENWAL COMPUTED Bdm DATE 5-20-86 R R

CHECKED AYL DATE 5/20/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis) (M.N.'s 17323-0, 18023-7)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>TAGT/Wire Insulation</u>	<u>1.7 x 10⁴</u>	<u>*</u>	<u>1.69</u>	<u>*</u>
(b) <u>Teflon/Insulation</u>	<u>1.7 x 10⁴</u>	<u>*</u>	<u>1.69</u>	<u>*</u>
(c) <u>Glass/Insulation</u>	<u>5 x 10⁸</u>	<u>*</u>	<u>NAS</u>	<u>*</u>
(d) _____	_____	_____	_____	_____
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS *Tab D, Section XIII, Table I; and Section XIII,

(3.4.2).

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B17 OF 40
BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 R R
CHECKED AKL DATE 5-15-86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Tab D Section X(1.1)).

Identify Acceptance Criteria: Specimens shall switch on increasing temperature and remain switched as long as accident temperature remains above setpoint (i.e., operability and switching temperature only).

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Tab D Section X(2.4)).

Identify baseline and functional testing: Specimens electrically loaded as described in references and monitored before, during, and after testing to judge equipment performance.

JUSTIFICATION/COMMENTS _____

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Tab D Section X(2.4)).

JUSTIFICATION/COMMENTS See (2) above.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B18 OF 40
 R 1 R _____
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 EE'm
2-21-89
 CHECKED AWL DATE 5-15-86 YDR
2-21-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS.
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: TAB D, Section I-2.3.4).

JUSTIFICATION/COMMENTS The applied load used by Wyle for baseline testing includes a 10% margin for voltage.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>120 VAC</u>	<u>45 W760-1-2</u> <u>45 N 600-12</u>
Load	<u>N/A</u>	<u>45W760-1-2</u>
Frequency	<u>60 Hz</u>	<u>45N600-12</u>
Accuracy	<u>17323-0 ± 11.6°F</u> <u>18023-7 ± 10.7°F</u>	<u>Instrument Accuracy Calc</u> <u>TAB C</u>
Other(s)		

R1

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B19 OF 40

R 1 R 2

BINDER TITLE FENWAL COMPUTED BDM DATE 9-19-86 EEM 66m

2/21/89 10/17/89

CHECKED AWL DATE 9-19-86 HDR WCS

2/21/89 10/17/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

(b) Parameter	Specific Accident Conditions	Reference
Voltage	<u>120 ±2.4 VAC</u>	<u>TAB E, 120 VAC Vital Instr Pwr</u>
Load	<u>N/A</u>	
Frequency	<u>60 ± 0.6 Hz</u>	<u>TAB E, 120 VAC Vital Instr Pwr</u>
*Accuracy	<u>MN.17323-0 ±11.5°F</u> <u>MN.18023-7 ±11°F</u>	<u>Instrument Accuracy Calc (TAB C)</u> R2
Other(s)	<u>N/A</u>	

JUSTIFICATION/COMMENTS Variations in voltage, load and frequency are accounted for in the design process and will not vary from the continuous operating characteristics outlined in the 120 VAC Vital Instrument Power Design Criteria (TAB C).

(c) Parameter	Demonstrated Conditions	Reference
Voltage	<u>132 VAC</u>	<u>TAB D Sect. X (2.4)</u>
Load	<u>1.61 Amps</u>	<u>TAB D Sect. X (2.4)</u>
Frequency	<u>N/A</u>	
*Accuracy	<u>MN.17323-0 ±11.6°F</u> <u>MN.18023-7 ±10.72°F</u>	<u>Instrument Accuracy Calc (TAB C)</u> R2
Other(s)		

JUSTIFICATION/COMMENTS *See open item 3, Sheet B2. | R2

K. REQUIRED OPERATING ENVIRONMENT (Model No. 17323-0)

Reference Environmental Drawing No. 47E235-68, -69 (692' Rm A06) R3
and DCA-P-02351-23-0

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>1.8x10³ gamma</u> | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal max conditions could exist up to eight hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|--|--------------------------------|
| (a) Temperature (°F) <u>212/110</u> | Accident type <u>AF</u> |
| (b) Pressure (psig) <u>0.06</u> | Accident type <u>AF</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>Less than 1x10 gamma</u> | Accident type <u>LOCA/HELB</u> |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

K. REQUIRED OPERATING ENVIRONMENT (Model No. 17323-0)(692' Rm A06) -
 (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): None

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: _____)

*See comment Page B22).

R1

- (7) Subject to submergence (Yes/No/NA)? No (Reference: See page B30/A).

Identify initiation time and duration of submergence: NA

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? NA
 (Reference: Environmental Data Drawing 47E235-68).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

R1

- (9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
_____	_____
_____	_____
_____	_____

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B22 OF 40
R 1 R _____
BINDER TITLE FENWAL COMPUTED BDM DATE 8-14-86 EBM
JP/1/89
CHECKED AWL DATE 8-16-86 HDK
2-21-89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

JUSTIFICATION/COMMENTS

*The Environmental Data Drawing 47E235-68, Note 49 requires additional conduit sealing; however, Fenwal model numbers located in this room (692' Rm A06) are 17323-0 which have vendor supplied seals (see TAB F) on lead wires and adjustment knob. |R1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B23 OF 40
R 1 R 3
BINDER TITLE FENWAL COMPUTED BDM DATE 7-2-86 EEM EEM
2/21/89 1/30/90
CHECKED AWL DATE 7-2-86 HDR AWM
2/21/89 2/7/90

K. REQUIRED OPERATING ENVIRONMENT (Model No. 18023-7)

Reference Environmental Drawing No. 47E235-39, (729' Rm A06) | R3
and DCA-P-02351-06-0, -07-0

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>1.8x10³ gamma</u> | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal maximum conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | | |
|----------------------|---------------------------------|-------------------------|
| (a) Temperature (°F) | <u>116°F (@ 1 min)</u> | Accident type <u>AB</u> |
| (a) Temperature (°F) | <u>125°F (PK)</u> | Accident type <u>AB</u> |
| (b) Pressure (psig) | <u>0.15</u> | Accident type <u>AB</u> |
| (c) Humidity (%) | <u>100</u> | Accident type <u>AB</u> |
| (d) Radiation (rd) | <u>1.3x10⁴ gamma</u> | Accident type <u>AB</u> |
| (e) Spray Type | <u>NA</u> | Accident type <u>NA</u> |

**See Section A, Reference 5, Sheet B1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B24 OF 40
 R 1 R _____
 BINDER TITLE FENWAL COMPUTED BDM DATE 8-14-86 EM
3/21/87
 CHECKED AWL DATE 8-16-86 HCR
2-21-84

K. REQUIRED OPERATING ENVIRONMENT (Model No. 18023-7)(729' Rm A06) -
 (Continued)

Comments (duration/peak/profile/spray composition and pH,
 margin, etc.): None

(6) Is the equipment subject to moisture or liquid intrusion which
 can affect the performance of the equipment under design basis
 accident conditions (Yes/No/NA)? No (Reference: Drawing
47E235-39 does not require conduit sealing analysis).

R1

(7) Subject to submergence (Yes/No/NA)? No (Reference: See
page B30/A).

Identify initiation time and duration of submergence: NA

R1

(8) Is the equipment subject to a beta radiation contribution to
 the total accident dose (Yes/No/NA)? NA
 (Reference: Drawing 47E235-39).

If yes, identify the fraction of the unattenuated free field
 beta dose to be added to the total dose and justify: _____

(9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

_____	_____
_____	_____
_____	_____

R1

K. REQUIRED OPERATING ENVIRONMENT (Model No. 18023-7)

Reference Environmental Drawing No. 47E235-40, (692' Rm A14) R3
and DCA-P-02351-08-0, -09-0

- | | |
|-----------------------------------|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |

- | | |
|--|------------------------------|
| (d) Radiation (rd) <u>3.5x10⁴
gamma</u> | (d) Radiation (rd) <u>NA</u> |
|--|------------------------------|

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal maximum conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|--|-------------------------|
| (a) Temperature (°F) <u>143</u> | Accident type <u>AB</u> |
| (b) Pressure (psig) <u>0.15</u> | Accident type <u>AB</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>AB</u> |
| (d) Radiation (rd) <u>Less than
1x10 gamma</u> | Accident type <u>L</u> |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B26 OF 40
 R 1 R _____
 BINDER TITLE FENWAL COMPUTED BDM DATE 8-14-86 6:00 PM
3/31/89
 CHECKED AWL DATE 8-16-86 7:00
2-21-89

K. REQUIRED OPERATING ENVIRONMENT (Model No. 18023-7)(692' Rm A14) -
 (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): None

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: _____)

Drawing 47E235-40 does not require conduit sealing analysis . | R1

- (7) Subject to submergence (Yes/No/NA)? No (Reference: See page B30/A) .

Identify initiation time and duration of submergence: NA

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? NA (Reference: 47E235-40) .

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

_____	_____
_____	_____
_____	_____

| R1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B27 OF 40
 R 1 R _____
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 6 8 87
2/21/89
 CHECKED AWL DATE 5-15-86 7/22
2-21-89

K. REQUIRED OPERATING ENVIRONMENT (Model No. 18023-7)

Reference Environmental Drawing No. 47E235-52, -54, (713' Rm A01) | R1

- | | |
|---|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| | <u>4x10⁴</u> |
| | <u>gamma</u> |
| (d) Radiation (rd) <u>(zone D)</u> | (d) Radiation (rd) <u>NA</u> R1 |
| (3) Process Interfaces: <u>None</u> | |
| (4) State anticipated occurrence frequency and duration of abnormal conditions: <u>Abnormal maximum conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life.</u> | |
| (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile): | |
| (a) Temperature (°F) <u>128</u> | Accident type <u>AB</u> |
| (b) Pressure (psig) <u>0.03</u> | Accident type <u>AB</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>AB</u> |
| (d) Radiation (rd) <u>Less₄ than 1x10 gamma</u> | Accident type <u>L</u> R1 |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

| R1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B28 OF 40
 R 1 R
 BINDER TITLE FENWAL COMPUTED BDM DATE 8-14-86 EEM
3/31/89
 CHECKED AWL DATE 8-16-86 HAW
2-21-87

K. REQUIRED OPERATING ENVIRONMENT (Model No. 18023-7)(713' Rm A01) -
 (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): None

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: _____)

Drawing 47E235-52 does not require conduit sealing analysis. |R1

- (7) Subject to submergence (Yes/No/NA)? No (Reference: See page B30/A).

Identify initiation time and duration of submergence: NA

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? NA

(Reference: 47E235-52). |R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

- (9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
_____	_____
_____	_____
_____	_____

R1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B29 OF 40
R 1 R 3
BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 EEM EEM
2/21/89 11 30 76
CHECKED AWL DATE 5-15-86 HDR AWM
2/21/89 2/7/90

K. REQUIRED OPERATING ENVIRONMENT (Model No. 18023-7)

Reference Environmental Drawing No. 47E235-62, -63, -64 | R3
(692' Rm A01) and DCA-P-02351-
-19-0, -20-0

- | | |
|---|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>3.2x10⁴
gamma
(zone C)</u> | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal maximum conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|--|-------------------------|
| (a) Temperature (°F) <u>153</u> | Accident type <u>AB</u> |
| (b) Pressure (psig) <u>0.03</u> | Accident type <u>AB</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>AB</u> |
| (d) Radiation (rd) <u>Less than
1x10 gamma</u> | Accident type <u>L</u> |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

K. REQUIRED OPERATING ENVIRONMENT (Model No. 18023-7)(692' Rm A01) -
(Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): None

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: Drawing 47E235-62 does not require conduit sealing analysis).

R1

(7) Subject to submergence (Yes/No/NA)? No (Reference: See page B30/A).

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? NA (Reference: 47E235-62).

R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

(9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

_____	_____
_____	_____
_____	_____

R1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B30/A OF 40
 R 1 R _____
 BINDER TITLE FENWAL COMPUTED BDM DATE 8-18-86 EEA
2/21/87
 _____ CHECKED AWL DATE 8-25-86 AWA
1-21-87

SUBMERGENCE EVALUATION

Component (As listed TAB A)	ACTUAL ELEVATION (From TAB F)	FLOOR ELEV/RM #/ REQUIRED ACCIDENT (From TAB A)	MAX FLOOD ELEV (From 47E235- Series Drawings)	R1
1-TS-1-17A-A	*695'-9"	692'/A06/L,AF	692'-2"	
1-TS-1-17B-A	*695'-9"	692'/A06/L,AF	692'-2"	
1-TS-1-18A-B	*695'-9"	692'/A06/L,AF	692'-2"	
1-TS-1-18B-B	*695'-9"	692'/A06/L,AF	692'-2"	
0-TS-12-91A-A	735'-9"	729'/A06/AB	NA	
0-TS-12-91B-B	735'-9"	729'/A06/AB	NA	
0-TS-12-92A-A	724'-0"	692'/A14/AB	692'-1"	
0-TS-12-92B-B	724'-0"	692'/A14/AB	692'-1"	
0-TS-12-93A-A	715'-7"	713'/A01/AB	713'-1"	
0-TS-12-93B-B	715'-10"	713'/A01/AB	713'-1"	
0-TS-12-95A-A	705'-2"	692'/A01/AB	692'-1"	
0-TS-12-95B-B	698'-9"	692'/A01/AB	692'-1"	R1
0-TS-12-96A-A	707'-0"	692'/A01/AB	692'-1"	
0-TS-12-96B-B	706'-1"	692'/A01/AB	692'-1"	
0-TS-12-98A-A	701'-4"	692'/A01/AB	692'-1"	
0-TS-12-98B-B	700'-11"	692'/A01/AB	692'-1"	
0-TS-12-99A-A	721'-6"	692'/A14/AB	692'-1"	
0-TS-12-99B-B	724'-0"	692'/A14/AB	692'-1"	

All temperature switches are located at least 2 feet above respective floor elevations. From Auxiliary Building Environmental Data Drawings, R1 flood levels for AB or AF HELBs do not exceed 1 foot; therefore, no switches are subject to submergence.

*Elevation measured to bottom of J.B. switches have the "flange" type mounting (see TAB H. 1.10.K) and are mounted on J.B. above low-point of J.B.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B31 OF 40
 BINDER TITLE FENWAL COMPUTED BAM DATE 5-20-86 R R
 CHECKED ATZ DATE 5/20/86

L. SUMMARY COMPARISON OF TEST OCNDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters: (M/N 17323-0)

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time (See pg 32)	<u>100 days</u>	<u>24 hours</u>	<u>Tab D pg iii, X Sect. X (3.0)</u>
Temperature (°F)	<u>212°F</u>	<u>323°F</u>	<u>Tab D Sect. X (Fig X-1, pg X-3)</u>
Pressure (psig)	<u>0.06</u>	<u>7.9</u>	<u>Tab D Sect. X (Fig X-2)</u>
Relative Humidity (%)	<u>100%</u>	<u>100%</u>	<u>Tab D, Sect. XIII (3.10.3, pg 39)</u>
*Chemical Spray	<u>NA</u>	<u>NA</u>	<u>NA</u>
**Radiation (rd)	<u>1.18 x 10⁴ gamma</u>	<u>NA</u>	<u>See pg B12 (H5-C) Tab D Sect. II(1.1)</u>
Submergence	<u>No</u>	<u>No</u>	<u>See page B30/A</u>

*Includes spray concentration, flowrate, density, duration, and pH.
 **Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelops Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes (See sheet B32)</u>	<u>Tab D Sect. X (3.0) Tab D Sect. X Figs. X-3, X-4</u>
Pressure	<u>Yes (See sheet B32)</u>	<u>Tab D Sect. X (3.0) Figs. X-3, X-4</u>
Relative Humidity	<u>Yes</u>	<u>Tab D, Sect. XIII (3.10.3, pg 39)</u>
Chemical Spray	<u>NA</u>	<u>NA</u>
Submergence	<u>NA</u>	<u>NA</u>

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B32 OF 40
R 1 R _____
BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 EE 17
2/21/89
CHECKED AWL DATE 5-15-86 AWL
2-21-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
(Continued)

JUSTIFICATION/COMMENTS

*The 24 hour duration test profile envelops the accident profile for the AF HELB specified in the category and operating time calculation for System 1 which is the only DBE which results in a harsh environment. The 100-day post-DBE operability requirement is from a category B/LOCA requirement for these devices (M/N 17323-0). However, the environmental conditions resulting from a LOCA are essentially mild. (See K(5) page B20). The 100-day post-LOCA operability requirement is accounted for due to the demonstrated qualified life being 40.56 years (see TAB C, page C-2, Section H(8), but only a 40-year qualified life is specified on the QMDSs. | R1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B33 OF 40
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86
 CHECKED AVR DATE 5-15-86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS M/N 17323-0
 (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>+111°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>+7.84 psig</u>	<u>Yes</u>
* Radiation: +10% of accident dose	<u>NA</u>	<u>NA</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>10%</u>	<u>Yes</u>
Voltage: +10% of rated value	<u>10%</u>	<u>Yes</u>
Frequency: +5% of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>Margin of 111°F</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS: *See Page B12.

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters: (M/N 18023-7)

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>1 minute</u>	<u>100 days</u>	<u>Tab D Sect. X (3.0)</u>
Temperature (°F)	<u>153°F</u>	<u>323°F</u>	<u>Tab D Sect. X (Fig X-1, pg X-3)</u>
Pressure (psig)	<u>0.15</u>	<u>7.9</u>	<u>Tab D Sect. X (Fig X-2)</u>
Relative Humidity (%)	<u>100%</u>	<u>100%</u>	<u>Tab D, Sect. XIII (3.10.3, pg 39)</u>
*Chemical Spray	<u>NA</u>	<u>NA</u>	<u>NA</u>
Radiation (rd)	<u>Less than 5 x 10⁴ Gamma</u>	<u>NA</u>	<u>Tab D Sect. II(1.1)</u>
Submergence	<u>No</u>	<u>No</u>	<u>See pg B30/A</u>

*Includes spray concentration, flowrate, density, duration, and pH.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>Tab D Sect. X (3.0) Sect. X Figs. Tab D X-3, X-4</u>
Pressure	<u>Yes</u>	<u>Sect. X (3.0) Sect. X Figs. Tab D X-3, X-4</u>
Relative Humidity	<u>Yes</u>	<u>Tab D, Sect XIII (3.10.3, pg 39)</u>
Chemical Spray	<u>NA</u>	<u>NA</u>
Submergence	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B35 OF 40
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 R R
 CHECKED AWL DATE 5/16/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (M/N 18023-7)
 (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>+170°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>+7.75 psig</u>	<u>Yes</u>
* Radiation: +10% of accident dose	<u>NA</u>	<u>NA</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>10%</u>	<u>Yes</u>
Voltage: +10% of rated value	<u>10%</u>	<u>Yes</u>
Frequency: +5% of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>Margin of 170°F</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS: * See Page B12

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B36 OF 40
R 1 R _____
BINDER TITLE FENWAL COMPUTED BDM DATE 5-15-86 ECM
2/21/89
CHECKED AWL DATE 5-16-86 HDL
2-21-89

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference: See page B-2 for category and operating time assignments). R1

JUSTIFICATION/COMMENTS _____

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: TAB D, Section X (3.0))

JUSTIFICATION/COMMENTS _____

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (Yes/No/NA)? Yes (Reference: TAB D, Sections X (3.0), XI)

JUSTIFICATION/COMMENTS _____

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (Yes/No/NA)? Yes (Reference: TAB D, page X, Section X (3.0))

JUSTIFICATION/COMMENTS _____

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: TAB D, Page iv-xi)

JUSTIFICATION/COMMENTS *See page B36/A.

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B36/A OF 40
R 1 R _____
BINDER TITLE FENWAL COMPUTED BDM DATE 5-20-86 SEM
1/21/87
CHECKED AWL DATE 5-20-86 HR
2-21-87

M. OPERABILITY TEST RESULTS (Continued)

JUSTIFICATION/COMMENTS

*There were 23 anomalies which occurred during testing. Of the 23, 10 anomalies (#'s 3, 4, 6, 8/A, 16, 17, 20, 21, 22/A, 23) involved specimens 7-9 and 13-15 (M.N.'s 17323-0, and 18023-7, respectively.) The anomalies are summarized on pages iv-xi of the Wyle report. Anomaly resolutions were reviewed and concurred with. Resolution of anomaly 22/A will be evaluated upon receipt of the revised demonstrated and required accuracy calculations (see open item 3, sheet B1).

|R1

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B38 OF 40
 BINDER TITLE FENWAL COMPUTED BDM DATE 5-9-86 R R
 _____ CHECKED AKL DATE 8/16/86 _____

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>NA</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>NA</u>
(b) Were specific features and failure modes and effects analyzed?	<u>NA</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>NA</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B39 OF 40
 BINDER TITLE FENWAL COMPUTED BPM DATE 6-24-86
 CHECKED Abel DATE 6/25/86

U. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>NA</u>
(b) Was beta radiation considered?	<u>NA</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-ITS-001 PLANT WBN UNIT(S) 1 SHEET B40 OF 40
 R 1 R 2
 BINDER TITLE FENWAL COMPUTED BDM DATE 9-3-86 EEM 88m
 2/21/89 12/17/89
 CHECKED AWL DATE 9-3-86 HDR AWCJ
 2/21/89 12/18/89

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>**</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

**See open item 3, sheet B2. |R2

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
COMPUTED BDM DATE 5-22-86
BINDER TITLE STATIC-0-RING CHECKED AWR DATE 6/3/86
TEMPERATURE SWITCHES

TAB A - Identification of equipment comprising the equipment type

EQP136.51

200-517

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-0-TS -012-0094A -A TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0094A -A 201TAB123JJTTX7		692' 85KLC-837662	A29	A	1MN	AB DETECT STEAM LINE BREAK AND ISOLATE FLOW FROM THE TURBINE BLDG TO AUX BLDG.
WBN-0-TS -012-0094B -B TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0094B -B 201TAB123JJTTX7		692' 86PLB-376059	A29	A	1MIN	AB DETECT STEAM LINE BREAK AND ISOLATE FLOW FROM THE TURBINE BLDG TO AUX BLDG.
WBN-0-TS -012-0097A -A TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0097A -A 201TAB123JJTTX7		692' 85KLC-837662	A30	A	1MIN	AB DETECT STEAM LINE BREAK AND ISOLATE FLOW FROM THE TURBINE BLDG TO AUX BLDG.
WBN-0-TS -012-0097B -B TEMP SW - AUX BLDG STEAM LINE RUPTURE	0-TS -012-0097B -B 201TAB123JJTTX7		692' 85KLC-837662	A30	A	1MIN	AB DETECT STEAM LINE BREAK AND ISOLATE FLOW FROM THE TURBINE BLDG TO AUX BLDG.
WBN-0-TS -030-0192A -A SFP & THERM BARRIER BSTR PUMP COOLER FAN	0-TS -030-0192A -A 201TAB125JJTTX6		737' 84K2-835754	A01	A	100D 1MO 1MO 1MO 1MO	L RH/A CV/A AF AB IF ASSOCIATED HS IN AUTO, TEMP SWITCH REQUIRED TO START ROOM COOLER FAN ON HIGH TEMP.

R4

PAGE A-2

R4

PREPARER/DATE BDM
 CHECKED/DATE AWL

R 1 WCG 4-4-89
 R 3 WCG 10-12-89
 R 4 WCG 6-15-90
 KBN HDR 4-28-89
 HDR 10-18-89
 CSH 6/27/90

W A T T S 2 A R N U C L E A R P L A N T
 T A S 4 - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACI				
WBN-3-TS -030-0192B -A SFP & THERM BARRIER BSTR PUMP COOLER FAN	0-TS -030-0192B -A 201TA9125JJTTX6	737'	A01	A	100D	L	IF ASSOCIATED HS IN STANDBY, RH/A TEMP SWITCH IS REQUIRED TO CV/A CLOSE ON ROOM HIGH TEMP. AF AB
				A	1M0	RH/A	
				A	1M0	CV/A	
				A	1M0	AF	
WBN-3-TS -030-0193A -B SFP & THERM BARRIER BSTR PUMP COOLER FAN	0-TS -030-0193A -B 201TA9125JJTTX6	737'	A01	A	100D	L	IF ASSOCIATED HS IN AUTO, TEMP RH/A SWITCH REQUIRED TO START CV/A ROOM COOLER FAN ON HIGH TEMP. AF AB
				A	1M0	RH/A	
				A	1M0	CV/A	
				A	1M0	AF	
WBN-3-TS -030-0193B -B SFP & THERM BARRIER BSTR PUMP COOLER FAN	0-TS -030-0193B -B 201TA9125JJTTX6	737'	A01	A	100D	L	IF ASSOCIATED HS IN STANDBY, T REQD TO CLOSE ON ROOM HIGH TEM
				A	1M0	RH/A	
				A	1M0	CV/A	
				A	1M0	AF	
WBN-1-TS -030-0194A -A PENETRATION ROOM COOLER FAN	1-TS -030-0194A -A 201TA9125JJTTX6	737'	A05	A	100D	L	IF ASSOCIATED HS IN AUTO, TEMP RH/A SWITCH REQD TO START ROOM CV/A COOLER FAN ON HIGH TEMP. AF AB
				A	1M0	RH/A	
				A	1M0	CV/A	
				A	1M0	AF	
WBN-2-TS -030-0194A -A PENETRATION ROOM COOLER FAN	2-TS -030-0194A -A 201TA9125JJTTX6	737'	A09	A	100D	L	REQ'D FOR AUTO START OF UNIT 2 ROOM COOLER WHICH SERVES ABGTS TRAIN B.
				A	1M0		
				A	1M0		
				A	1M0		

PAGE A-3

PREPARED/DATE BDM 8/12/86
 CHECKED/DATE AWL 8/16/86
 4-4-89
 8/23/89

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNII DEVICE ID NO.	AZMIH	ELEV(1)	SM/RAD	CONTRACT	CAI	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION	MODEL NUMBER					(2)			
WBN-1-TS -030-0194B -A 1-TS -030-0194B -A PENETRATION ROOM COOLER FAN	201TAB125JJTTX6		737'	A05	85KJ2-336755	A	1000	L	IF ASSOCIATED HS IN STANDBY, RH/A TEMP SWITCH IS REQUIRED TO CV/A CLOSE ON ROOM HIGH TEMP.
						A	1MO		
						A	1MO		
						A	1MO		AF
						A	1MO		AB
WBN-2-TS -030-0194B -A 2-TS -030-0194B -A PENETRATION ROOM COOLER FAN	201TA9125JJTTX5		737'	A09	85KJ2-336755	A	1000	L	REQ'D FOR AUTO START OF UNIT 2 ROOM COOLER WHICH SERVES ABGTS TRAIN B.
WBN-1-TS -030-0195A -B 1-TS -030-0195A -B PENETRATION ROOM COOLER FAN	201TAB125JJTTX6		737'	A05	83XJ9-333871	A	1000	L	IF ASSOCIATED HS IN AUTO, TEMP SWITCH REQD TO START ROOM COOLER FAN ON HIGH TEMP.
						A	1MO		
						A	1MO		
						A	1MO		AF
						A	1MO		AB
WBN-2-TS -030-0195A -B 2-TS -030-0195A -B PENETRATION ROOM COOLER FAN	201TA3125JJTTX5		737'	A09	83XJ9-833871	A	1000	L	REQ'D FOR AUTO START OF UNIT 2 ROOM COOLER WHICH SERVES ABGTS TRAIN B.
WBN-1-TS -030-0195B -B 1-TS -030-0195B -B PENETRATION ROOM COOLER FAN	201TA9125JJTTX6		737'	A05	85KJ2-336755	A	1000	L	IF ASSOCIATED HS IN STANDBY, RH/A TEMP SWITCH IS REQUIRED TO CV/A CLOSE ON ROOM HIGH TEMP.
						A	1MO		
						A	1MO		
						A	1MO		AF
						A	1MO		AB

PAGE 4-4
R1

PREPARER/DATE BDM 8/12/86
 CHECKED/DATE AWL 8/16/86
 R 1
 WBS
 4-4-89
 KBL
 4/20/89

PRINT DATE: 02/02/89

BINDER NO. : W8NEQ-ITS -002
 MANUFACTURER : SOR
 PAGE 4 OF 6

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER		UNIT DEVICE ID NO.		AZMIH		ELEV(1)		RM/PAD	CAI	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION		MODEL NUMBER		CONTRACT		CONTRACT			(2)			
W8N-2-TS	-030-0195B	-B	2-TS	-030-0195B	-B	737'	A09	A09	A	1000	L	REQ'D FOR AUTO START OF UNIT 2 ROOM COOLER WHICH SERVES ABGTS TRAIN B.
PENETRATION ROOM COOLER FAN		201TAB125JJTTX6		85KJ2-836755								
W8N-1-TS	-030-0196A	-A	1-TS	-030-0196A	-A	713'	A06	A06	A	1000	L	IF ASSOCIATED HS IN AUTO, TS REQUIRED TO START ROOM COOLER FAN ON HI TEMP.
PENETRATION ROOM COOLER FAN		201TAB125JJTTX6		85XJ9-333871					A	1MO	RH/A	
									A	1MO	CV/A	
									A	1MO	AF	
									A	1MO	AB	
W8N-1-TS	-030-0196B	-A	1-TS	-030-0196B	-A	713'	A06	A06	A	1000	L	IF ASSOCIATED HS IN STANDBY, TEMP SWITCH IS REQUIRED TO CLOSE ON ROOM HIGH TEMP.
PENETRATION ROOM COOLER FAN		201TAB125JJTTX6		85KJ9-836755					A	1MO	RH/A	
									A	1MO	CV/A	
									A	1MO	AF	
									A	1MO	AB	
W8N-1-TS	-030-0197A	-B	1-TS	-030-0197A	-B	713'	A06	A06	A	1000	L	IF ASSOCIATED HS IN AUTO, TEMP SWITCH REQUIRED TO START ROOM COOLER FAN ON HIGH TEMP.
PENETRATION ROOM COOLER FAN		201TAB125JJTTX6		83XJ9-333871					A	1MO	RH/A	
									A	1MO	CV/A	
									A	1MO	AF	
									A	1MO	AB	
W8N-1-TS	-030-0197B	-B	1-TS	-030-0197B	-B	713'	A06	A06	A	1000	L	IF ASSOCIATED HS IN STANDBY, TEMP SWITCH IS REQUIRED TO CLOSE ON ROOM HIGH TEMP.
PENETRATION ROOM COOLER FAN		201TAB125JJTTX6		85KJ2-836755					A	1MO	RH/A	
									A	1MO	CV/A	
									A	1MO	AF	
									A	1MO	AB	

PAGE A-5

PREPARER/DATE BDM 8/12/86
 CHECKED/DATE AWL 8/26/86
 R1
 WCS?
 4-4-89
 KBL
 4/2/89

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMIH	ELEV(1) CONTRACT	RH/PAQ	CAI OPER TIME (2)	EVENT	SAFETY FUNCTION
MBN-2-TS -030-0200A EGTS COOLER FAN	-A 2-TS -030-0200A 201TAB125JJTTX6	-A	757' 85KJ2-836755	A16	A 1000	L	EGTS HVAC REQUIRED FOR UNIT 1 LOCA MITIGATION.
MBN-1-TS -030-0201A PIPE CHASE COOLERS FAN	-A 1-TS -030-0201A SEE OPEN ITEM 1	-A	692'	A08	A 1000 A 1MO A 1MO A 1MO A 1MO	L RH/A CV/A AF AB	L: ABI OR ESF SIGNAL WILL AUTO START FANS. RH, CV, AF, AB: AUTO START COOLING FANS ON PIPE CHASE HIGH TEMP.
MBN-1-TS -030-0201B PIPE CHASE COOLERS FAN	-A 1-TS -030-0201B 201TAB125JJTTX6	-A	692' 86PLB-367310	A08	A 1000 A 1MO A 1MO A 1MO A 1MO	L RH/A CV/A AF AB	IF ASSOCIATED HS IN STANDBY-TS REQD TO CLOSE ON ROOM HIGH TEM
MBN-1-TS -030-0202A PIPE CHASE COOLERS FAN	-B 1-TS -030-0202A SEE OPEN ITEM 1	-B	692'	A08	A 1000 A 1MO A 1MO A 1MO A 1MO	L RH/A CV/A AF AB	L: ABI OR ESF SIGNAL WILL AUTO START FANS. RH, CV, AF, AB: AUTO-START COOLING FANSON PIPE CHASE HIGH TEMP.
MBN-1-TS -030-0202B PIPE CHASE COOLERS FAN	-B 1-TS -030-0202B 201TAB125JJTTX6	-B	692' 85KJ2-836755	A08	A 1000 A 1MO A 1MO A 1MO A 1MO	L RH/A CV/A AF AB	IF ASSOCIATED HS IN STANDBY-TS REQD TO CLOSE ON ROOM HIGH TEM

PAGE A-6

R1

PREPARED/DATE: BDM 5/30/86
 CHECKED/DATE: AWL 6/8/86
 R 1
 R
 R

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZIMUTH	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
			ELEV(1)	RH/RAD CONTRACT				
WBN-2-TS -030-0207A EGTS COOLER FAN	-B 2-TS -030-0207A 201TA5125JJTTX5		757'	A15 35KJ2-336755	A	1000	L	EGTS HVAC REQ'D FOR UNIT 1 LOC MITIGATION.
WBN-1-TS -074-0043 RHR RETURN LINE BREAK DETECTION	-A 1-TS -074-0043 SEE OPEN ITEM 1		713'	A29	A	15 MIN 30 MIN	RH/A CV/A	MUST PROVIDE SIGNAL TO INITIATE MANUAL ISOLATION DURING A LINE BREAK
WBN-1-TS -074-0044 RHR RETURN LINE BREAK DETECTION	-A 1-TS -074-0044 SEE OPEN ITEM 1		713'	A28	A	15 MIN 30 MIN	RH/A CV/A	MUST PROVIDE SIGNAL TO INITIATE MANUAL ISOLATION DURING A LINE BREAK
WBN-1-TS -074-0045 RHR RETURN LINE BREAK DETECTION	-B 1-TS -074-0045 SEE OPEN ITEM 1		713'	A23	A	15 MIN 30 MIN	RH/A CV/A	MUST PROVIDE SIGNAL TO INITIATE MANUAL ISOLATION DURING A LINE BREAK
WBN-1-TS -074-0046 RHR RETURN LINE BREAK DETECTION	-B 1-TS -074-0046 SEE OPEN ITEM 1		713'	A28	A	15 MIN 30 MIN	RH/A CV/A	MUST PROVIDE SIGNAL TO INITIATE MANUAL ISOLATION DURING A LINE BREAK

PAGE A-7
R1

PREPARER/DATE BDM 5/30/86
 CHECKED/DATE AWL 6/03/86
 R 1
 4-4-84
 R
 R
 4/23/89

BINDER NO. WBNEO-ITS-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R _____ R _____
BINDER TITLE STATIC-O-RING COMPUTED /R1 WLP DATE 4-4-89
TEMPERATURE SWITCHES CHECKED /R1 KAN DATE 4/23/89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-1 for source of Category and Operating Time assignments.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 5-22-86 R R
TEMPERATURE SWITCHES CHECKED ASL DATE 6/3/86

TAB B - Checklist for evaluation of environmental qualification
including summary and conclusion

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 60

BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6/24/81 R R

TEMPERATURE SWITCHES CHECKED [Signature] DATE 6/25/81

A. DOCUMENTATION

Equipment Description Temperature Switches

Vendor/Manufacturer Static O-Ring

Equipment Model No. (s) 201TA-B125-JJTTX6

201TA-B123-JJTTX7

QUALIFICATION REPORTS

(1) Title/Number/Revision See below RIMS

DATE

(2) Title/Number/Revision RIMS

DATE

(3) Title/Number/Revision RIMS

DATE

OTHER (ANALYSIS, VENDOR DATA, ETC.)

(1) AETC "Generic Qualification of Class 1E Electrical Equipment Used

for Nuclear Power Generating Stations", Report No. 17344-82N-D,

Rev. 1, Date 2-28-83, (RIMS: EEB 840612 500 and B70 851009 101).

(2) AETC "Qualification Testing and Analysis of Class 1E Electrical

Equipment in Accordance with IEEE Standard 323-1974" Addendum I to

17344-82N-D, Report No. 18441-83N, Rev. 1, Date 8-17-83, RIMS:

B70 851009 102.

(3) AETC "Generic Qualification of Class 1E Electrical Equipment Used

for Nuclear Power Generating Stations", Report No. 17344-82N-C, Rev.

3, Date 2-27-85, (RIMS: B70 851009 103 and B70 851009 101).

BINDER NO. WBNEO-ITS-002 PLANT WBN UNIT(S) 1 SHEET 2 OF 60
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/09/86 R 4 R _____
TEMPERATURE SWITCHES CHECKED AWL DATE 8/26/86 AWL
 _____ 6/18-90
 _____ 6/27/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (4) AETC "Qualification Testing of Class 1E Electrical Equipment in Accordance with IEEE Standard 323-1974", Report No. 18577-83N, Rev. 1, Dated 7-18-83, RIMS: B43 851223 510.
- (5) AETC "Qualification Testing of Class 1E Electrical Equipment in Accordance with IEEE Standard 323-1974", Report No. 18878-84N-2, Rev. 1, Date 8-30-84, RIMS: EEB 850122 301.
- (6) Aux. Boiler Category and Operating Times WBNOSG4-006 Rev. 4 (B45 851031 226).
- (7) Containment HVAC Category and Operating Times WBNOSG4-008 Rev. 15 (B26 900309 231).
- (8) RHR Category and Operating Times WBNOSG4-020 Rev. 8 (B26 900309 232). R4
2 7/9/90 7/10/90
- (9) Unit 2 Components Required for Unit 1 Operation Category and Operating Times WBNOSG4-040 Rev. 7 (B26 900327 203).
- (10) Calculation WBNTSR-014 R0 (B26 890725-551).
- (11) DCA-P02351-17-0
- (12) NTS "Report of Test for SLB Testing of SOR Model 127A-B4-NX-CLA-JJX6 Pressure Switch" Report No. 21510-86N, Revision 0, dated January 14, 1986. R4
- (13) Deleted
- (14) Material Aging Calculation (WAC-92).
- (15) System 30 Demonstrated Accuracies (B43 851029 926).
- (16) System 12 Demonstrated Accuracies (B43 851121 915).
- (17) HVAC and RHR Demonstrated Accuracies (see Open Item No. 1).
- (18) HVAC Set-point Evaluation (B45 860317 236).
- (19) Aux. Boiler Set-point Evaluation (B45 860530 219) (see Open Item No. 2)
- (20) HVAC and RHR Set-point Evaluation (see Open Item No. 1)

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 2A OF 60
R 1 R _____
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/19/86 WCS
4-4-89
TEMPERATURE SWITCHES CHECKED AWL DATE 8/26/86 AW
8/22/87

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (21) SCR WBNEQP8603/R1 (B71 860509 007).
- (22) 100 Day LOCA Dose in EGTS WBNNAL3-031 Rev. 1 (B45 880826 235). | R1
- (23) NCRs 6224/R0 and 6774/R0.
- (24) Deleted | R1
- (25) SOR Letter Addressing Qualified Life (EEB 840802 004).
- (26) SOR Confirmation Letter (B71 860521 100).
- (27) Environmental Data Drawing 47E235-85 Rev. 1.
- (28) Environmental Data Drawing 47E235-86 Rev. 1.
- (29) Environmental Data Drawing 47E235-46 Rev. 1.
- (30) Environmental Data Drawing 47E235-47 Rev. 2.
- (31) Environmental Data Drawing 47E235-48 Rev. 3.
- (32) Environmental Data Drawing 47E235-49 Rev. 2. | R1
- (33) Environmental Data Drawing 47E235-56 Rev. 1.
- (34) Environmental Data Drawing 47E235-57 Rev. 2.
- (35) Environmental Data Drawing 47E235-59 Rev. 2.
- (36) Environmental Data Drawing 47E235-60 Rev. 1.
- (37) Environmental Data Drawing 47E235-78 Rev. 3.
- (38) Environmental Data Drawing 47E235-61 Rev. 1.
- (39) SOR Confirmation Letter Addressing Switch Orientation
B71 860610 100

Note: All references in this section are to AETC Test Report 17344-82N-C unless otherwise stated.

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references. | R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 3 OF 60

R 3 R

BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/27/86 WCR

10-17-89

TEMPERATURE SWITCHES CHECKED AWL DATE 8/27/86 AWL

10-17-89

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES _____

(1) SCRWBNEQP8603 must be implemented and closed.

(2) Set-point evaluation outstanding for system 12 switches. The demonstrated accuracy and set-point evaluations must be revised for system 30 temperature switches.

(3) Deleted

(4) Deleted

|R3

(5) Deleted

COMMENTS/RECOMMENDATIONS None

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 4 OF 60

R 1 R

BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 5/22/86 ⁴⁻⁴⁻⁸⁷

TEMPERATURE SWITCHES CHECKED AWL DATE 6/03/86 ^{KEJ}
_{4/29/87}

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

_____ Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN) | R1

JUSTIFICATION/COMMENTS _____

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 323-1974 _____

IEEE 344-1975 _____

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 5 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 5-31-86 R R
TEMPERATURE SWITCHES CHECKED AKL DATE 6/3/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- X Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The Certificates of Conformance (see TAB C, Section 16) for these temperature switches list the first four reports in Section A as applicable to show generic qualification. Report 17344-82N-C is mainly used as a basis for qualification of these switches. The fifth report, 18878-84N-2, is used to obtain an activation energy for silicone rubber and for thermal aging data on silicone rubber.

Qualification of the temperature switches is accomplished by considering separately the two basic subassemblies of the device. The temperature switch is composed of the switch (electrical) and the sensor (mechanical).

Examination of catalog information (TAB E) shows that the switch sub-assembly is identical to that tested in 17344-82N-C with two exceptions - the material used in the secondary diaphragms and the attachment at the pressure port.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 6 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 5-31-86 R R
TEMPERATURE SWITCHES CHECKED AWR DATE 6/3/86

JUSTIFICATION/COMMENTS (Continued)

The secondary diaphragms of the plant equipment have grey silicone rubber (see TAB C, Section #22 on index); the tested switch has fluorinated silicone on dacron polyester cloth. Several factors allow the assumption that the silicone rubber is as good as or better than the fluorinated silicone on dacron polyester cloth for this application.

These are:

1) The fluorinated silicone and silicone rubber are both members of the silicone family of materials. The activation energy, which is an indication of thermal stability, is higher for silicone rubber (1.59eV - see 18878-84N-2, Section 3.0) than it is for fluorinated silicone (1.2eV - see 17344-82N-C, Appendix D) or for dacron polyester cloth (1.18eV - see 17344-82N-C, Appendix D). Therefore, the silicone rubber is less susceptible to the long-term effects of time and temperature.

2) Silicone rubber has been thermally aged for 131 hours at 280°F (see 18878-84N-2, Appendix E). This represents a life of 725 years at the normal and abnormal service temperatures (see calculation WAC-92 in TAB C). Therefore, silicone rubber is not sensitive to thermal aging at these temperatures.

3) Silicone rubber has been subjected to 325°F (peak) in an HELB

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 7 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 5-31-86 R R
TEMPERATURE SWITCHES CHECKED ANL DATE 6/3/86

JUSTIFICATION/COMMENTS (Continued)

simulation (See 18878-84N-2, Section 7.5.2). This temperature very
adequately envelops the maximum accident temperature (219°F) for
the areas in which these switches are located. Therefore, silicone
rubber is not sensitive to accident temperatures for this application.

4) Radiation testing has been done on the silicone rubber to a dose of
 3.3×10^7 rads (see 18441-83N, Section 5.1.B). Therefore, silicone
rubber is not significantly affected by radiation doses of least
 3.3×10^7 rads.

In conclusion, the silicone rubber can perform as well as or better than
the fluorinated silicone in the plant applications.

The attachment at the pressure port of a pressure switch is a pressure
port fitting; in a temperature switch it is a temperature bulb (see
Sales Manuals in TAB E). In this binder, the temperature bulb is
considered as a separate subassembly in the qualification of the
temperature switch.

Therefore, the testing performed on the pressure switch in 17344-82N-C
is representative of the environment in which the switch subassemblies
are located in the plant providing that radiation exposure for a 40-
year life plus DBE accident is limited to 3.3×10^7 rads.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 8 OF 60
BINDER TITLE STATIC O-RING COMPUTED B.D.M. DATE 5-31-76 R R
TEMPERATURE SWITCHES CHECKED AWL DATE 4/3/86

JUSTIFICATION/COMMENTS (Continued)

The sensor subassembly is a purely mechanical device consisting of a T316 stainless steel tube filled with Dupont "Freon-12" charge material (see 18441-83N, pg 5-6). Being such, this device is not required to be qualified to IEEE 323-1974. It will, however, be evaluated to demonstrate that it would not be affected by the accident environments to which it could be exposed.

The stainless steel is not sensitive to the temperature and radiation levels being considered in this binder.

"Freon-12" is not susceptible to thermal aging at the temperatures being considered as evidenced by the thermal decomposition data in 18441-83N, Appendix E. It shows a decomposition rate of 1% per year at temperatures greater than 900°F. Irradiation testing performed on the temperature switch in 18441-83N, Section 5.1.B, shows that "Freon-12" is not significantly affected by doses to at least 3.3×10^7 rads.

Therefore, based on the data presented above and on sound engineering rationale, the mechanical temperature bulb assembly could withstand the harsh environments under consideration in this binder.

PAGE B-10

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 9 OF 60
 R 1 R _____
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/04/86 WCS
4-4-84
TEMPERATURE SWITCHES CHECKED AWL DATE 6/04/86 KAJ
4/23/89

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Temperature Switch</u>	<u>See (1) below</u>	
(2) Manufacturer	<u>Static O-Ring</u>	<u>Static O-Ring</u>	<u>Sect. 3.0 pg 3-1</u>
(3) Model Number(s)	<u>201TA-B125-JJTX6</u>	<u>12TA-B4-NX-C1A-JJTX6</u>	<u>Add. I, Sect. 3.0 pg 3-2</u>
	<u>201TA-B123-JJTX7</u>	<u>201TA-B125 -JJ</u>	<u>Add. I, Sect. 3.0 pg 3-1</u>
		<u>(See (2) below)</u>	
(4) Serial Number(s)	<u>See Sheet 10</u>	<u>82-6-384</u> <u>83-4-3530</u>	<u>Sect. 3.0 pg 3-1</u> R1 <u>18441-83N, Sect. 3.0 pg 3-2</u>
(5) Identify Component- Unique checksheet attached:	<u>None</u>		

JUSTIFICATION/COMMENTS

- (1) The temperature switch is qualified using tests of pressure switches (17344-82N-C and 18878-84N-2) and a test of a temperature switch (18441-83N).
- (2) The differences between the plant model and the models tested are in the last section of the model numbers (i.e. -JJTX6 versus -JJ and 125 versus 123)(See page 11).

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 10 OF 60
R 1 R 3
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/12/86 WCG WCP
4/4/89 10-17-89
TEMPERATURE SWITCHES CHECKED AWL DATE 8/25/86 KBN HOK
4/28/89 10-17-89

1. From TAB B, Section E(4):

<u>EIN</u>	<u>Serial Numbers</u>	<u>PO Number</u>
0-TS-12-94A	85-7-4260	85K1C-837662
0-TS-12-94B	86-10-2389R	86PLB-376059
0-TS-12-97A	85-7-4262	85K1C-837662
0-TS-12-97B	85-7-4263	85K1C-837662
0-TS-30-192A	84-9-3733	84KN2-835754
0-TS-30-192B	85-3-3457	85KJ2-836755
0-TS-30-193A	84-9-3734	84KN2-835754
0-TS-30-193B	85-3-3452	85KJ2-836755
1-TS-30-194A	84-2-249	83XJ9-833871
1-TS-30-194B	85-3-3439	85KJ2-836755
1-TS-30-195A	84-2-250	83XJ9-833871
1-TS-30-195B	85-3-3440	85KJ2-836755
1-TS-30-196A	84-2-252	83XJ9-833871
1-TS-30-196B	85-3-3437	85KJ2-836755
1-TS-30-197A	84-2-254	83XJ9-833871
1-TS-30-197B	85-3-3438	85KJ2-836755
1-TS-30-201A	*	*
1-TS-30-201B	85-12-269	86PLB-367310
1-TS-30-202A	*	*
1-TS-30-202B	85-3-3444	85KJ2-836755
2-TS-30-194A	84-2-248	83XJ9-833871
2-TS-30-194B	85-3-3449	85KJ2-836755
2-TS-30-195A	84-2-251	83XJ9-833871
2-TS-30-195B	85-3-3450	85KJ2-836755
2-TS-30-200A	85-3-3451	85KJ2-836755
2-TS-30-207A	85-3-3458	85KJ2-836755
1-TS-74-43	*	*
1-TS-74-44	*	*
1-TS-74-45	*	*
1-TS-74-46	*	*

R3

* See Open Item No. 1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 11 OF 60
BINDER TITLE STATIC O-RING COMPUTED BBM DATE 5-31-86 R R
TEMPERATURE SWITCHES CHECKED AWR DATE 6/3/86

JUSTIFICATION/COMMENTS (Continued)

2. From TAB B, Section E(3): (Continued)

TT = 316 stainless steel tag permanently attached to the housing
(reference TAB E).

X6 = Designates the required documentation for a nuclear qualified
switch (reference SOR letter in TAB C).

X7 = Designates nuclear qualified switch and also indicates it has
a smaller temperature bulb.

123 = Contains a special spring size which results in a quicker
response time and a narrower range (40-150°F).

125 = Contains standard spring and has a range of 40-225°F.

Reference: TAB C, SOR Confirmation letter; TAB E, Vendor
Drawings and Sales manual.

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>See (1) below</u>	<u>Yes</u>	<u>Sect. 7.8.1 pages 7-19</u>
External Process Connections	<u>None</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>See (4) on page 13</u>	<u>NA</u>	<u>NA</u>
Conduit Seals	<u>See (2) below</u>	<u>No</u>	<u>Sect. 7.10.4 pages 7-37</u>
Connector Seals	<u>See (4) on page 13</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>See (3) page 13</u>	<u>Yes</u>	<u>Sect. 7.10.4 pages 7-37</u>
Physical Configuration	<u>None</u>	<u>NA</u>	<u>NA</u>
Other	<u>See (4) and (5), page 13</u>	<u>Yes</u>	<u>See (4) and (5)</u>

JUSTIFICATION/COMMENTS

- (1) 3 Standard grade 1/4" U-bolts; this requirement is also stated in SOR's general instructions for qualified switches - SOR document No. 8215-439R1 (reference TAB H, page 1).
- (2) The Environmental Drawings identify areas with high potential for condensate formation and specifies conduit sealing requirements (see Section K(6) of TAB B). Additionally, conduit seals are required by the test report; however, since SOR provides seals as an integral part of their qualified

R4

BINDER NO. WBNEQ-IIS-002 PLANT WBN UNIT(S) 1 SHEET 13 OF 60
R 1 R _____
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 5/22/86 WCS
4-4-89
TEMPERATURE SWITCHES CHECKED AWL DATE 6/03/86 KBA
4/22/89

From TAB B, Section F: (Continued)

switches, a conduit seal requirement is not necessary for the plant equipment.

- (3) Test report 17344-82N-C mounted the unit with the pressure port vertical axis parallel to earth. The general instruction sheet sent with the switches, however, states that the switches should be mounted with the pressure port vertical axis oriented downward. The purpose of testing the switch in the horizontal position was to show that the switch is not position sensitive. (Reference TAB C).
- (4) The test report does not identify a requirement for the interface to field wiring; however, connections should be per qualified plant procedures and sealed with Raychem heat-shrink tubing. Refer to Binder WBNEQ-SPLC-001 regarding qualification of the Raychem splice.
- (5) Test report 17344-82N-C tested a pressure switch with a plugged housing which resulted in severe setpoint shifts due to pressure buildup in the housing at high temperatures (LOCA testing). Report 18577-83N is a LOCA test of a second switch with the housing vented. In this test the setpoint shift was acceptable. For plant applications, housing venting requirements are dependent upon local temperature extremes. Venting is required for components located in environments with maximum accident temperatures greater than their abnormal temperatures. (See TAB G, QMDS).

|R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 14 OF 60
 BINDER TITLE STATIC O-RING COMPUTED Dom DATE 5/31/86 R R
 TEMPERATURE SWITCHES CHECKED AWL DATE 6/3/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference (1)</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>Sect. 2.0</u> <u>page 2-1</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Sect. 2.0</u> <u>page 2-1</u>
(c) Equipment aged:		<u>Sect. 2.0</u>
Thermal	<u>Yes</u>	<u>page 2-1</u> <u>See (2)</u>
Radiation	<u>Yes</u>	<u>below</u> <u>Sect. 2.0</u>
Wear	<u>Yes</u>	<u>page 2-1</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Sect. 2.0</u> <u>page 2-2</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>Sect. 2.0</u> <u>page 2-2</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>Sect. 2.0</u> <u>page 2-2</u>
(g) Final inspection and disassembly	<u>NO</u>	<u>**See</u> <u>page 14A</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes (Reference *See page 14A).

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes (Reference See (3) below).

JUSTIFICATION/COMMENTS (1)References refer to AETC Test Report
17344-82N-C unless otherwise stated. (2)18441-83N, Section 5.1.B,
page 5-2 and Section 2.0 of 17344-82N-C, page 2-2.
(3)Appendix E of 17344-82N-C and Appendix F of Addendum I to 17344-
82N-D.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 14A OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 5-31-86 R R
TEMPERATURE SWITCHES CHECKED ANR DATE 6/3/86

*During the accelerated aging, SOR replaced the "N6" switch housing with a "TA" type (See 17344-82N, Section 7.2.3, page 7-42). The epoxy lead wire seal, with cover gasket and silicone thread sealant also were replaced; however, a supplemental thermal aging was conducted to compensate. The remainder of the test sequence was completed with the same device.

**Final disassembly and inspection of the test device was not performed; however, a post-accident visual inspection was performed.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 15 OF 60
 BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6-24-86 R R
 TEMPERATURE SWITCHES CHECKED ATK DATE 4/24/88

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS Sections 7.2, page 7-6; 7.3, page 7-13; 7.5, page 7-16; 7.8.5, page 7-25; and 5.1.B 18441-83N, page 5-2.

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Sect. 7.2 page 7-6</u>
Radiation exposure	<u>Yes</u>	<u>See (1) below</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Sect. 7.8.5 page 7-25</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>Sect. 7.3 page 7-13</u>

JUSTIFICATION/COMMENTS (1) Section 7.5, page 7-16 and Section 5.1.B of 18441-83N.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS No synergistic effects are known for the material contained within this device in its specific configuration (O-Ring). Any unknown synergistic effects will be compensated for by the large margin in testing (Section 7.7, pages 7-17 and 18).

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference Section 7.2, page 7-6).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 16 OF 60
 BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6-24-86 R R
 TEMPERATURE SWITCHES CHECKED AKR DATE 6/24/86

H. (4) Thermal Aging: (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: See Comments).

JUSTIFICATION/COMMENTS 17344-82N-C, Appendix D, 18878-84N-2, Section 3.0, and 18441-83N, Appendix E.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS Appendix F, Section 9.1, page 41.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Section 7.2.3, page 7-11).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature (°F)	<u>*111.06</u>	<u>302</u>	<u>111</u>
Time	<u>40 Years</u>	<u>100 Hrs</u>	<u>1004.75 Years</u>

JUSTIFICATION/COMMENTS *Plant maximum normal includes 1% of 40-year plant life at maximum abnormal temperature.

See TAB C for equivalent life calculation.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Section 5.2, page 5-2).

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS 17344-82N-C, Appendix D, 18878-84N-2, Section 3.0, and 18441-83N, Appendix E. (See page 17 for further discussion).

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 17 OF 60
BINDER TITLE STATIC 0-RING COMPUTED BDM DATE 6-13-86 R R
TEMPERATURE SWITCHES CHECKED AW/Leis DATE 6-13-86

H. (4) Thermal Aging, Section (f): (Continued)

However, the actual Arrhenius calculations are found in Section 7.3, pages 7-9 and 7-11. Originally, the weak-link material in the switches was thought to be nitrile rubber with an activation energy of 1.04eV. Thus, an aging time of 277.7 hours was determined (Section 7.2.1, page 7-9). Subsequent to the aging process, data was provided to show that nitrile rubber was not present in the switch. Thus, based on data in Appendix D, the actual weak-link material was a dacron polyester cloth with an activation energy of 1.18eV. Prior to irradiation, SOR replaced the N6 housing with a TA housing which involved replacement of some previously aged components (Section 7.2.3, page 7-11). Therefore, a supplemental thermal aging was done to retain the aged status of the test unit. The plant devices, however, do not have dacron polyester cloth. Instead, they have grey silicone rubber (see TAB C, Section 22) which has an activation energy of 1.59 eV (18878-84N-2, Section 3.0). That then makes the weak-link material for the switch to be the Emmerson and Cummings 2651 Epoxy Potting Compound with an activation energy of 1.24 eV. The Arrhenius calculations for the supplemental aging are found in 17344-82N-C, pages 7-11 and 7-13 and calculate the qualified life for switches with the dacron polyester cloth. The qualified life for the plant devices is determined by calculations found in TAB C, Section 9.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 18 OF 60
STATIC 0-RING R R
BINDER TITLE TEMPERATURE SWITCHES COMPUTED BDM DATE 6-13-86
CHECKED aw/ls DATE 6-13-86

H. (4) Thermal Aging: (Continued)

- (g) If a regression line were used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS None

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference Section 7.2.2, page 7-10).

JUSTIFICATION/COMMENTS Only contact resistance measurements were taken during thermal aging.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference Section 7.5, page 7-16).

JUSTIFICATION/COMMENTS See (1) page 19.

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? No (Reference Section 7.7, page 7-17 and 18441-83N, Section 5.1.B).

JUSTIFICATION/COMMENTS See (2) page 19.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? No (Reference See Comments).

JUSTIFICATION/COMMENTS See (2) page 19.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 19 OF 60
BINDER TITLE STATIC O-RING COMPUTED BLM DATE 5-22-86 R R
TEMPERATURE SWITCHES CHECKED AWR DATE 6/3/86

(1) From TAB B, Section H(5)(a): (Continued)

Radiation withstand capability of the switch part of the device is
proven in Section 7.5 of 17344-82N-C, where the device is exposed to
 2.2×10^8 rads and then successfully completes the seismic and LOCA
portions of the test. However, withstand capability of the grey
silicone rubber in the secondary diaphragm and of the temperature-
sensing bulb is proven in Addendum I of 17344-82N-D, where it is
irradiated to 3.3×10^7 rads.

(2) From TAB B, Sections H(5)(b) and H(5)(c): (Continued)

A generic level of irradiation was administered in both reports.
The 2.2×10^8 rads dose was generic for inside containment (see
Section 7.5 of 17344-82N-C) and the 3.3×10^7 rads dose was generic
for outside containment (see Section 5.5 of 17344-82N-D, page 5-6).

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 20 OF 60
R 1 R
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/13/86 ^{WES}
₄₋₄₋₈₆
TEMPERATURE SWITCHES CHECKED AWL/RNB DATE 6/13/86 ^{KBA}
_{4/20/89}

H. AGING (Continued)

(5) (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: See Comments).

Plant normal ambient radiation dose (rd)	<u>7.5 x 10⁶ rads(737'P.C.)</u>	R1
Test exposure dose (rd)	<u>*2.2x10⁸ rads/3.3x10⁷ rads</u>	
Test exposure dose rate (rd/hr)	<u>*2.36x10⁶ rads/hr</u>	
	<u>*2.2x10⁵ rads/hr</u>	
Test exposure source type (e.g., Co-60 gamma)	<u>*Cobalt-60 Gamma</u>	
JUSTIFICATION/COMMENTS <u>*Section 7.5 of 17344-82N-C, Addendum I of 17344-82N-D.</u>		

(6) Vibration (non-seismic) Aging:

(a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ Yes (Reference: Section 7.8.5, page 7-25).

JUSTIFICATION/COMMENTS None

(b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Section 7.8.5, page 7-25).

JUSTIFICATION/COMMENTS None

(7) Operational Stress Aging:

(a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: Section 7.3, page 7-13).

JUSTIFICATION/COMMENTS None

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 21 OF 60
R 1 R _____
BINDER TITLE STATIC-O-RING COMPUTED BDM _____ DATE 6/03/86 WJS
4-4-89
TEMPERATURE SWITCHES CHECKED AWL _____ DATE 6/03/86 KW
4/23/89

H. AGING (Continued)

(7) (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: _____
Section 7.3, page 7-13 _____).

JUSTIFICATION/COMMENTS None

(8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: Section 7.2.3, pages 7-11 and 7-13 _____).

Qualified life (Document in QMDS) 40 years

JUSTIFICATION/COMMENTS See note (1) on page 22.

(9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? No
(Reference: See Comments _____).

|R1

JUSTIFICATION/COMMENTS The qualification program does not define any replacement intervals for the switch or any of its components. SOR, however, does require replacement of the cover gasket whenever the cover is removed. (See TAB H - SOR General Instructions 8215-475, Rev. 2, and TAB I - SOR Dimensional Drawing 8215-602, Rev. 1.)

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 22 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 9-3-86 R R
TEMPERATURE SWITCHES CHECKED ANR DATE 9/3/86

From TAB B, Section H(8):

- (1) The service temperature of 160°F used in Section 7.2.3 is higher than e maximum normal/abnormal temperatures seen by the switches in their varus locations. The qualified life calculation is based on the worst case "maximum normal temperature" of 111°F and the "maximum abnormal temperature" of 117°F (see TAB C for calculation). Reference TAB B Section (K) for maximum normal and abnormal temperatures, for respective locations.

PAGE B-25

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 23 OF 60
 BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6-13-86 R R
 TEMPERATURE SWITCHES CHECKED awt/als DATE 6-13-86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Viton E60C or Fluorel 2174</u>	<u>Not Given</u>	<u> </u>	<u>1.32eV</u>	<u>See (1) below</u>
(b) <u>Nomex Paper</u>	<u>Not Given</u>	<u> </u>	<u>1.60eV</u>	<u>See (1) below</u>
(c) <u>Silicone Rubber</u>	<u>Not Given</u>	<u> </u>	<u>1.59eV</u>	<u>See (1) below</u>
(d) <u>Ethylene Propylene Rubber Emerson & Cummings 2651</u>	<u>Not Given</u>	<u> </u>	<u>1.28eV</u>	<u>See (1) below</u>
(e) <u>Epoxy Potting Compound Belden No. 32418, Silicone Rubber</u>	<u>Not Given</u>	<u> </u>	<u>1.24eV</u>	<u>See (1) below</u>
(f) <u>Glass Braid Impregnated Rodgers No. 640</u>	<u>Not Given</u>	<u> </u>	<u>1.51eV</u>	<u>See (1) below</u>
(g) <u>Glass Filled Phenolic</u>	<u>Not Given</u>	<u> </u>	<u>1.75eV</u>	<u>See (1) below</u>
(h) <u>Grey Silicone Rubber</u>	<u>Not Given</u>	<u> </u>	<u>1.59eV</u>	<u>See (1) below</u>
(i) <u>Kapton Polyimide</u>	<u>Not Given</u>	<u> </u>	<u>1.41eV</u>	<u>below</u>

JUSTIFICATION/COMMENTS

- (1) The materials for the temperature switch were taken from the comparison list in Addendum I of 17344-82N-D. Activation energies for all materials except grey silicone rubber were taken from 17344-82N-C, Appendix D. The activation energy for grey silicone rubber was taken from Section 3.0 of 18878-84N-2 (TAB D).
- (2) Material function can be found in 18878-84N-2, Section 3.0 (TAB D).
- (3) A literature search has determined that the only material subject to synergistic effects is ethylene propylene rubber used in the O-Ring.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 23A OF 60
R R
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6-13-86
TEMPERATURE SWITCHES CHECKED awz/pwb DATE 6-13-86

I. MATERIALS ANALYSIS (Continued)

The onset of synergistic effects occurs at relatively high dose levels
compared to normal service conditions and therefore is not a
significant aging concern. Figure 2 of NUREG/CR-2157 shows a
relationship between dose rate and dose for an EPR material. Up to
about 10 to 20 Mrad there is an insignificant difference in observed
property degradation due to the dose rate effect, especially in view
of the normal variation in properties experienced by EPRs over this
same range. Low service doses should minimize the impact of potential
synergisms with respect to aging for this equipment.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 24 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6-3-86 R R
TEMPERATURE SWITCHES CHECKED AWK DATE 6/3/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference See page 25).

Identify Acceptance Criteria: See page 25.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference See page 25).

Identify baseline and functional testing: See page 25.

JUSTIFICATION/COMMENTS None

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Section 7.10.5, page 7-42).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 25 OF 60
BINDER TITLE STATIC O-RING COMPUTED BOM DATE 5-22-86 R R
TEMPERATURE SWITCHES CHECKED AMR DATE 6/3/86

From TAB B, Sections J(1) and (2):
(Reference 17344-82N-C, Appendix F, Sections 7.0 and 16.0)

1. Dielectric Withstand Voltage

Baseline Criteria: less than 2mA leakage at 1240 VAC

rms applied for 1 minute

Post-LOCA Criteria: Same

2. Insulation Resistance

Baseline Criteria: Greater than 100 M at 500 VDC applied for 1 minute

Post-LOCA Criteria: Greater than or equal to 1 M at 500 VDC applied

for 1 minute

3. Contact Resistance

Baseline Criteria: 200 M less than at 1 amp

Post-LOCA Criteria: Same

4. Overpressure Test

Baseline Criteria: No pressure loss at 200 psig

Post-LOCA Criteria: Same

5. Operability

Baseline Criteria: Must operate within the adjustable range

Post-LOCA Criteria: Must actuate on increasing and decreasing

pressure at rated voltage and current. Setpoint

repeatability was not required due to the

temperature-influenced shift on the setpoint.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 26 OF 60

R 1 R _____

BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/24/86 ⁴⁻¹²⁻⁸⁹

TEMPERATURE SWITCHES CHECKED AWL DATE 6/24/86 ^{4/23/87}

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____)

See below _____).

JUSTIFICATION/COMMENTS Only the applied load during DBE was identified - 120 VAC at 5A (Section 7.10.5, page 7.42).

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
<u>Voltage</u>	<u>120 VAC</u>	<u>(1)</u>
<u>Load</u>	<u>NA</u>	_____
<u>Frequency</u>	<u>60 ± 0.6 Hz</u>	<u>(1)</u>
<u>Accuracy</u>	<u>NA</u>	_____
<u>Other(s)</u>	_____	_____
<u>NA</u>	_____	_____

JUSTIFICATION/COMMENTS ⁽¹⁾ Variations in voltage, load, and frequency are accounted for in the design process and will not vary from the continuous operating characteristics outlined in section 8.3.1 of Watts Bar Final Safety Analysis Report.

R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 27 OF 60
 R 1 R
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/13/86 4-12-89
TEMPERATURE SWITCHES CHECKED AWL/RNB DATE 6/13/86 4-12-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) Parameter	Specific Accident Conditions	Reference	R1
Voltage	<u>120 ± 2.4 VAC</u>	<u>(1)</u>	R1
Load	<u>NA</u>		
Frequency	<u>60 ± 0.6 Hz</u>	<u>(1)</u>	R1
** Accuracy	<u>201TA-B125-JJTTx6 * ±8.19°F</u> <u>201TA-B125-JJTTx7 ± 8.00°F</u>	<u>TAB C, B45860317236</u> <u>TAB C, B45860530219</u>	
Other(s)	<u>NA</u>		

(1)
 JUSTIFICATION/COMMENTS Variations in voltage, load, and frequency are accounted for in the design process and will not vary from the continuous operating characteristics outlined in section 8.3.1 of Watts Bar Final Safety Analysis Report (FSAR) R1

(c) Parameter	Demonstrated Conditions	Reference	R1
Voltage	<u>120 VAC</u>	<u>Sect. 7.10.5</u> <u>page 7-42</u>	
Load	<u>5A</u>	<u>Sect. 7.10.5</u> <u>page 7-42</u>	
Frequency	<u>NA</u>		
** Accuracy	<u>201TA-B125-JJTTx6 *</u> <u>201TA-B123-JJTTx7 ± 7.07°F</u>	<u>* TAB C</u> <u>TAB C,</u> <u>B43 851121 915</u>	
Other(s)			

JUSTIFICATION/COMMENTS _____

* See Open Item No. 2. R1

** The demonstrated accuracy and the set-point evaluation calculations for components under SCR 8603 are outstanding (See Open Item No. 1). R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 28 OF 60
R 1 R _____
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/03/86 awc
4-4-89
TEMPERATURE SWITCHES CHECKED AWL/RNB DATE 6/03/86 KBU
5/21/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-85, -86 (692' Rm A29) | R1

- (1) Normal Max (2) Abnormal Max
- (a) Temperature (°F) 111 (a) Temperature (°F) 117
(b) Pressure (psig) ATM(-) (b) Pressure (psig) ATM(-)
(c) Humidity (%) 63 (c) Humidity (%) 70
(d) Radiation (rd) 1.7x10⁶ gamma (d) Radiation (rd) NA | R1
- (3) Process Interfaces: None
-
-
- (4) State anticipated occurrence frequency and duration of abnormal conditions: These conditions could exist for up to 8 hours per excursion and will occur less than 1% of plant life.
-
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- (a) Temperature (°F) 219 Accident type AB
(b) Pressure (psig) 0.20 Accident type AB
(c) Humidity (%) 100 Accident type AB
(d) Radiation (rd) Less than 1x10 gamma Accident type L | R1
(e) Spray Type NA Accident type NA

| R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 29 OF 60
 R 1 R
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/20/86 WES
4-4-89
TEMPERATURE SWITCHES CHECKED AWL DATE 8/25/86 KLN
4/23/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Accident temperature and pressure will decrease linearly to the normal maximum values at the end of 24 hours.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: See Environmental Data Drawing 47E235-85).

(7) Subject to submergence (Yes/No/NA)? No (Reference: See pages B-51 and B-52). | R1

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No* (Reference: Environmental Data Drawing 47E235-85). | R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA

* Location is outside the reactor building, therefore, no beta contribution.

(9) Special environmental calculations (temp., rad., etc.) | R1

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Section A</u>	<u>See TAB B, Section A</u>
_____	_____
_____	_____

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 30 OF 60
R 1 R
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/03/86 WCP
4-4-89
TEMPERATURE SWITCHES CHECKED AWL DATE 6/03/86 KEA
4/22/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-85, -86 (692' Rm A30) | R1

- (1) Normal Max (2) Abnormal Max
- (a) Temperature (°F) 111 (a) Temperature (°F) 117
- (b) Pressure (psig) ATM(-) (b) Pressure (psig) ATM(-)
- (c) Humidity (%) 63 (c) Humidity (%) 70
- (d) Radiation (rd) 2.0x10⁶ gamma (d) Radiation (rd) NA | R1
- (3) Process Interfaces: None
-
-
-
- (4) State anticipated occurrence frequency and duration of abnormal conditions: These conditions could exist for up to 8 hours per excursion and will occur less than 1% of plant life.
-
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- (a) Temperature (°F) 219 Accident type AB
- (b) Pressure (psig) 0.20 Accident type AB
- (c) Humidity (%) 100 Accident type AB
- (d) Radiation (rd) Less₄ than 1x10⁶ gamma Accident type L | R1
- (e) Spray Type: NA Accident type NA

| R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 31 OF 60
R 1 R _____
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/19/86 WCS
4-4-89
TEMPERATURE SWITCHES CHECKED AWL DATE 8/26/86 AWL
4/22/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Accident temperature and pressure will decrease linearly to the normal maximum value at the end of 24 hours.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: See Environmental Data Drawing 37E235-85). | R1

(7) Subject to submergence (Yes/No/NA)? No (Reference: See pages B-51 and B-52). | R1

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No* (Reference: Environmental Data Drawing 47E235-85). | R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA

* Location is outside the reactor building, therefore, no beta contribution.

(9) Special environmental calculations (temp., rad., etc.) | R1

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Section A</u>	<u>See TAB B, Section A</u>
_____	_____
_____	_____

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 32 OF 60

R 1 R

BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/05/86 WCP

4/4/87

TEMPERATURE SWITCHES CHECKED AWL DATE 6/05/86 KLP

4/2/87

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-46, -47 (737' Rm A01) |R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104

(a) Temperature (°F) 110

(b) Pressure (psig) ATM(-)

(b) Pressure (psig) ATM(-)

(c) Humidity (%) 80

(c) Humidity (%) 90

(d) Radiation (rd) 1.8x10³

(d) Radiation (rd) NA |R1

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: These conditions could exist for up to 8 hours per excursion and will occur less than 1% of plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 128 Accident type RH

(b) Pressure (psig) 0.03 Accident type AF/AB

(c) Humidity (%) 100 Accident type RH/CV/AB/AF

(d) Radiation (rd) Less than 1x10⁴ gamma Accident type LOCA/HELB |R1

(e) Spray Type NA Accident type NA

|R1

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Accident temperature and pressure will decrease linearly to the normal maximum values at the end of 24 hours.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: See Environmental Data Drawing 47E235-46).

(7) Subject to submergence (Yes/No/NA)? No (Reference: See pages B-51 and B-52). | R1

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No* (Reference: Environmental Data Drawing 47E235-46).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA | R1

* Location is outside the reactor building, therefore no beta contribution.

(9) Special environmental calculations (temp., rad., etc.) | R1

<u>Type</u>	<u>RIMS No.</u>	
<u>See TAB B, Section A</u>	<u>See TAB B, Section A</u>	R1
_____	_____	
_____	_____	

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 34 OF 60
R 1 R 2
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/05/86 WCG WCG
04/04/89 7-26-89
TEMPERATURE SWITCHES CHECKED AWL DATE 6/05/86 KBN KBN
04/28/89 8/2/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-48, -49 (737' Rm A05)

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>8.8x10⁵ gamma</u> | (d) Radiation (rd) <u>NA</u> } R1 |
- (3) Process Interfaces: None
-
-
-
- (4) State anticipated occurrence frequency and duration of abnormal conditions: These conditions could exist for up to 8 hours per excursion and will occur less than 1% of plant life.
-
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|---|-------------------------------------|
| (a) Temperature (°F) <u>195</u> | Accident type <u>RH/A</u> |
| (b) Pressure (psig) <u>0.03</u> | Accident type <u>RH/A</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>RH/CV/AB/AF</u> |
| (d) Radiation (rd) <u>6.21 x 10⁵ *</u> | Accident type <u>LOCA/HELB</u> } R2 |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

*Worst case value for this area obtained from Calculation
WBNTSR-014.

R2

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 35 OF 60
 R 1 R
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/19/86 ^{WEP}
₄₋₄₋₈₉
TEMPERATURE SWITCHES CHECKED AWL DATE 8/26/86 ^{WEP}
_{4/22/89}

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Accident temperature and pressure will decrease linearly to the normal maximum at the end of 24 hours.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: See Environmental Data Drawing 47E235-48, note 47). | R1

(7) Subject to submergence (Yes/No/NA)? No (Reference: See pages B-51 and B-52). | R1

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No* (Reference: Environmental Data Drawing 47E235-48). | R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA

* Location is outside the reactor building, therefore no beta contribution.

(9) Special environmental calculations (temp., rad., etc.) | R1

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Section A</u>	<u>See TAB B, Section A</u>
_____	_____
_____	_____

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 36 OF 60
 R 1 R 2
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/03/86 WCG WCF
04/04/89 7-31-87
TEMPERATURE SWITCHES CHECKED AWL DATE 6/03/86 KBN ALF
04/28/89 8/2/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-56, -57 (713' Rm A06)

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>2.2x10⁶ gamma</u> | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: These conditions could exist for up to 8 hours per excursion and will occur less than 1% of plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | | |
|--|----------------------------------|----|
| (a) Temperature (°F) <u>199*</u> | Accident type <u>RH</u> | R2 |
| (b) Pressure (psig) <u>0.03</u> | Accident type <u>AB</u> | |
| (c) Humidity (%) <u>100</u> | Accident type <u>RH/CV/AB/AF</u> | |
| (d) Radiation (rd) <u>2 x 10⁶</u> | Accident type <u>LOCA/HELB</u> | |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> | |

*Value obtained from DCA-P02351-17-0 | R2

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 37 OF 60
 R 1 R _____
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/19/86 we
4-4-89
TEMPERATURE SWITCHES CHECKED AWL DATE 8/26/86 dk
9/2/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Accident temperature and pressure will decrease linearly to the normal maximum values at the end of 24 hours.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: See Environmental Data Drawing 47E235-56, note 47). R1

(7) Subject to submergence (Yes/No/NA)? No (Reference: See pages B-51 and B-52). R1

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No* (Reference: Environmental Data Drawing 47E235-56). R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA

* Location is outside the reactor building, therefore no beta contribution.

(9) Special environmental calculations (temp., rad., etc.) R1

Type

RIMS No.

See TAB B. Section A

See TAB B. Section A R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 38 OF 60
 R 1 R 2
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/03/86 WCG WCG
 04/04/89 7-31-89
TEMPERATURE SWITCHES CHECKED AWL DATE 6/03/86 KBN KBN
 04/28/89 5/2/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-60, -59 (692' Rm A08)

- (1) Normal Max (2) Abnormal Max
- (a) Temperature (°F) 104 (a) Temperature (°F) 110
- (b) Pressure (psig) ATM(-) (b) Pressure (psig) ATM(-)
- (c) Humidity (%) 80 (c) Humidity (%) 90
- (d) Radiation (rd) 7.5x10⁶ gamma (d) Radiation (rd) NA
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: These conditions could exist for up to 8 hours per excursion and will occur less than 1% of plant life.
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- (a) Temperature (°F) 210* Accident type RH | R2
- (b) Pressure (psig) 0.03 Accident type RH/AB
- (c) Humidity (%) 100 Accident type RH/CV/AB/AF
- (d) Radiation (rd) 5x10⁶ gamma Accident type LOCA/HELB
- (e) Spray Type NA Accident type NA

*Value obtained from DCA-P02351-17-0

| R2

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 39 OF 60
 R 1 R _____
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/19/86 4-4-89
TEMPERATURE SWITCHES CHECKED AWL DATE 8/25/86 4/25/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Accident temperature and pressure will decrease linearly to the normal maximum values at the end of 24 hours.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: See Environmental Data Drawing 47E235-60, note 47). | R1

(7) Subject to submergence (Yes/No/NA)? No (Reference: See pages B-51 and B-52). | R1

Identify initiation time and duration of submergence: NA

* See Open Item No. 1 for 1-TS-30-201A and -202A | R1

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No* (Reference: Environmental Data Drawing 47E235-60). | R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA

* Location is outside the reactor building, therefore no beta contribution.

(9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Section A</u>	<u>See TAB B, Section A</u>
_____	_____
_____	_____

BINDER NO. WBNEO-ITS-002 PLANT WBN UNIT(S) 1 SHEET 40 OF 60
 R 1 R 2
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/03/86 WCG WCG
04/12/89 7-26-89
TEMPERATURE SWITCHES CHECKED AWL DATE 6/03/86 KBN RF
04/28/89 8/2/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-48 (737' Rm A09)

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>8.8×10^5 gamma</u> | (d) Radiation (rd) <u>NA</u> R1 |
- (3) Process Interfaces: None
-
- (4) State anticipated occurrence frequency and duration of abnormal conditions: These conditions could exist for up to 8 hours per excursion and will occur less than 1% of plant life.
-
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|---|-------------------------------------|
| (a) Temperature (°F) <u>110</u> | Accident type <u>L</u> |
| (b) Pressure (psig) <u>NA</u> | Accident type <u>L</u> |
| (c) Humidity (%) <u>NA</u> | Accident type <u>L</u> |
| (d) Radiation (rd) <u>1.18×10^6 *</u> | Accident type <u>LOCA/HELB</u> R2 |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

*Value obtained from Calculation WBNTSR-014. | R2

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Accident temperature and pressure will decrease linearly to the normal maximum values at the end of 24 hours.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: See Environmental Data Drawing 47E235-48, note 47).

(7) Subject to submergence (Yes/No/NA)? No (Reference: See pages B-51 and B-52 and Open Item No. 3).

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No* (Reference: Environmental Data Drawing 47E235-48).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA

* Location is outside of the reactor building, therefore no beta contribution.

(9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B, Section A

See TAB B, Section A

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 42 OF 60
R 1 R _____
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/12/86 WJZ
4-4-84
TEMPERATURE SWITCHES CHECKED AWL DATE 8/16/86 KEN
4/2/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-78 (757' Rm A16) | R1

- (1) Normal Max (2) Abnormal Max
- (a) Temperature (°F) 104 (a) Temperature (°F) 110
- (b) Pressure (psig) ATM (b) Pressure (psig) ATM
- (c) Humidity (%) 80 (c) Humidity (%) 90
- (d) Radiation (rd) 1.8x10³ gamma (d) Radiation (rd) NA | R1
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: These conditions could exist for up to 8 hours per excursion and will occur less than 1% of plant life.
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- (a) Temperature (°F) 110 Accident type LOCA
- (b) Pressure (psig) NA Accident type LOCA
- (c) Humidity (%) NA Accident type LOCA
- * (d) Radiation (rd) 1.8x10⁶ gamma Accident type LOCA/HELB | R1
- (e) Spray Type NA Accident type NA

Additional References

* LOCA Doses EGTS Rm. WBNNAL3-031 | R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 43 OF 60
 R 1 R _____
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/01/86 WCS
4/2/89
TEMPERATURE SWITCHES CHECKED AWL DATE 8/25/86 KBR
4/2/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Accident temperature and pressure will decrease linearly to the normal maximum values at the end of 24 hours.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: See Environmental Data Drawing 47E235-78).

(7) Subject to submergence (Yes/No/NA)? No (Reference: See pages B-51 and B-52 and Open Item No. 1). | R1

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No (Reference: Environmental Data Drawing 47E235-78).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA | R1

Location is outside the reactor building, therefore no beta contribution.

(9) Special environmental calculations (temp., rad., etc.) | R1

Type

RIMS No.

See TAB B. Section A

See TAB B. Section A | R1

_____ | R1

BINDER NO. WBNEQ-IIS-002 PLANT WBN UNIT(S) 1 SHEET 44 OF 60
R 1 R
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/03/86 *wca*
4-4-84
TEMPERATURE SWITCHES CHECKED AWL DATE 6/04/86 *KSA*
4/27/87

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-59, -61, (713' A28) | R1

- | | |
|---|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>Atm(-)</u> | (b) Pressure (psig) <u>Atm(-)</u> |
| (c) Humidity (%) <u>80</u>
<u>7.5x10⁶</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>gamma</u> | (d) Radiation (rd) <u>NA</u> R1 |
- (3) Process Interfaces: None
-
-
-
- (4) State anticipated occurrence frequency and duration of abnormal conditions: These conditions could exist for up to 8 hours per excursion and will occur less than 1% of plant life.
-
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|--|--------------------------------|
| (a) Temperature (°F) <u>210</u> | Accident type <u>RH</u> |
| (b) Pressure (psig) <u>0.03</u> | Accident type <u>RH</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>RH/CV</u> |
| (d) Radiation (rd) <u>5x10⁶ gamma</u> | Accident type <u>LOCA</u> R1 |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

| R1

4/23/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Accident temperature and pressure will decrease linearly to the normal maximum values at the end of 24 hours.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: See Environmental Data drawing 47E235-61, note 47). |R1

(7) Subject to submergence (Yes/No/NA)? No* (Reference: See pages B-51 and B-52 and Environmental Data Drawing 47E235-61, Table 1.). |R1

Identify initiation time and duration of submergence: NA
*See Open Item No. 1 for system 74 switches

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No* (Reference: Drawing 47E235-61). |R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

*Equipment located outside the reactor building, therefore no beta contribution.

(9) Special environmental calculations (temp., rad., etc.) |R1

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Section A</u>	<u>See TAB B, Section A</u>

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 46 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6/3/86 R R
TEMPERATURE SWITCHES CHECKED AWR DATE 6/3/86

K.(6) GENERAL:

Justification for Eliminating Consideration of Moisture Intrusion into SOR Temperature Switches

In 17344-82N-C, where moisture intrusion through the seal was noted, the LOCA test conditions included 100% relative humidity, a 120 psig atmosphere, and a 6200 ppm Boron spray. During an accident, the equipment would be exposed to 100% humidity at less than 0.1 psig (no caustic spray); therefore, there would be no driving force for moisture intrusion.

Also, the LOCA/HELB test of 18577-83N was run with the same model switch using the same types of materials at 100% humidity but without caustic spray and only a 48 psig atmosphere and moisture intrusion was not observed. (Insulation resistance at post-HELB test was in excess of 1 Giga. ohm. SOR provides a conduit seal on these switches; therefore, based on the above, moisture intrusion need not be considered.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 47 OF 60
 R 1 R
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/20/86 *WES*
4-4-87
TEMPERATURE SWITCHES CHECKED AWL DATE 8/25/86 *AWL*
4/22/87

K.(7) GENERAL SUBMERGENCE EVALUATION

<u>Component</u> <u>(TAB A)</u>	<u>Actual</u> <u>Elevation</u> <u>(TAB F)</u>	<u>Floor Elevation/</u> <u>Rm#/Required Accident</u> <u>(TAB A)</u>	<u>Worst Case</u> <u>Accident/Flood</u> <u>Level (Environmental</u> <u>Data Drawings)</u>	<u>R1</u>
0-TS-12-94A	708'	692'/A29/AB	692'-2"	
0-TS-12-94B	708'-0"	692'/A29/AB	692'-2"	
0-TS-12-97A	705'-7 1/2"	692'/A30/AB	692'-2"	
0-TS-12-97B	704'-6 1/2"	692'/A30/AB	692'-2"	
0-TS-30-192A	741'-6"	737'/A01/L,RH,CV,AF,AB	NA	
0-TS-30-192B	741'6"	737'/A01/L,RH,CV,AF,AB	NA	
0-TS-30-193A	741'5 1/2"	737'/A01/L,RH,CV,AF,AB	NA	
0-TS-30-193B	742'-1"	737'/A01/L,RH,CV,AF,AB	NA	
1-TS-30-194A	739'-11"	737'/A05/L,RH,CV,AF,AB	NA	
1-TS-30-194B	739'-0"	737'/A05/L,RH,CV,AF,AB	NA	
1-TS-30-195A	740'-3"	737'/A05/L,RH,CV,AF,AB	NA	
1-TS-30-195B	740'-4"	737'/A05/L,RH,CV,AF,AB	NA	
1-TS-30-196A	715'-5 1/2"	713'/A06/L,RH,CV,AF,AB	713'1"	
1-TS-30-196B	714'-10"	713'/A06/L,RH,CV,AF,AB	713'1"	
1-TS-30-197A	714'-2 1/2"	713'/A06/L,RH,CV,AF,AB	713'1"	
1-TS-30-197B	714'-2 1/2"	713'/A06/L,RH,CV,AF,AB	713'1"	
1-TS-30-201A	*	692'/A08/L,RH,CV,AF,AB	692'2"	
1-TS-30-201B	696'-3 1/2"	692'/A08/L,RH,CV,AF,AB	692'2"	
1-TS-30-202A	*	692'/A08/L,RH,CV,AF,AB	692'2"	
1-TS-30-202B	696'-3 1/4"	692'/A08/L,RH,CV,AF,AB	692'2"	
2-TS-30-194A	746'-1"	737'/A09/L	NA	
2-TS-30-194B	739'-8"	737'/A09/L	NA	
2-TS-30-195A	743'-0"	737'/A09/L	NA	
2-TS-30-195B	739'-7 1/2"	737'/A09/L	NA	
2-TS-30-200A	760'-11"	737'/A16/L	NA	
2-TS-30-207A	758'-9 1/2"	737'/A16/L	NA	
1-TS-74-43	*	713'/A28/RH,CV	713'-3"	
1-TS-74-44	*	713'/A28/RH,CV	713'-3"	
1-TS-74-45	*	713'/A28/RH,CV	713'-3"	
1-TS-74-46	*	713'/A28/RH,CV	713'-3"	

*See Open Item No. 1

|R1

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 48 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6-3-86 R R
TEMPERATURE SWITCHES CHECKED AKR DATE 6/3/86

K.(7) GENERAL:

All temperature switches are located greater than 1.0' above respect-
ive floor elevations. The flood levels do not exceed 3" above floor
elevations; therefore, the temperature switches are not subject to
submergence.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 49 OF 60
 R 1 R 2
 BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 6/13/86 WCG WCG
 04/04/89 7-26-89
TEMPERATURE SWITCHES CHECKED AWL/RNB DATE 6/13/86 KBN WCF
 04/28/89 5/2/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100</u>	<u>30</u> (1)	<u>Fig 14, page 7-41</u>
Temperature (°F)	<u>219</u>	<u>430</u>	<u>Fig 14, page 7-41</u>
Pressure (psig)	<u>Atm</u>	<u>120 psig</u>	<u>Fig 14, page 7-41</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>Sect. 7.10.3 page 7-36</u>
Chemical Spray*	<u>NA</u>	<u>NA</u>	<u>NA</u>
Radiation (rd)**	<u>1.25x10⁷ gamma</u>	<u>3.3x10⁷ gamma</u>	<u>See page 20(1)</u> R2
Submergence	<u>NA</u>	<u>NA</u>	<u>NA</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

| R2

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>Fig 14 page 7-41</u>
Pressure	<u>Yes</u>	<u>Fig 14 page 7-41</u>
Relative Humidity	<u>Yes</u>	<u>Sect. 7.10.3 page 7-36</u>
Chemical Spray	<u>NA</u>	<u>NA</u>
Submergence	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS (1) The 30-day DBE simulation translates into more than the 100 days required operating time. See post-DBE life calculation in TAB C.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 50 OF 60
R 1 R
BINDER TITLE STATIC-O-RING COMPUTED BDM DATE 8/09/86 WST
4-4-84
TEMPERATURE SWITCHES CHECKED AWL DATE 8/16/86 KBN
4/23/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
(Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	>15°F	Yes <u>RI</u>
Pressure: +10% but no more than 10 psig	+120 psig	Yes
Radiation: +10% of accident dose	>> 10%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	+ 376%	See (1) below
Voltage: ±10% of rated value	See page 51 (2)	Yes
Frequency: ±5% of rated value	NA	NA
Environmental Transient: the initial transient and the peak temperature applied twice	2 Transients	Yes
Vibration: +10% added to acceleration	NA	NA

JUSTIFICATION/COMMENTS (1) Yes; this figure reflects the margin between the equivalent post-DBE life calculated in TAB C, page 3, and the required post-DBE life.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 51 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 5-22-86 R R
TEMPERATURE SWITCHES CHECKED AMR DATE 6/3/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

From TAB B, Section L(3):

(2) Per 17344-82N-C, Appendix F, page 22 and Section 7.1.1, page 7-1,
the switch has been tested with the application of a higher than rated
voltage (1240 VAC rms for 1 minute) to demonstrate that the switch can
operate safely at rated voltage and withstand momentary surges due to
switching. A large margin is also provided by plant application since
the plant circuit is 120 VAC (Vital Instr. Power Calculation, reference
TAB E), and the maximum rated value of the switch is 250 VAC (reference
TAB I). During DBE testing 120 VAC @ 5amps was applied (sect. 7.10.5,
page 7-42) which falls within $\pm 10\%$ of normal plant voltage.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 52 OF 60
BINDER TITLE STATIC O-RING COMPUTED BLM DATE 6-4-86 R R
TEMPERATURE SWITCHES CHECKED ANL DATE 6/4/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference See TAB A).

JUSTIFICATION/COMMENTS _____

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes (Reference See pages 55 and 56).

JUSTIFICATION/COMMENTS _____

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes (Reference See pages 55 and 56).

JUSTIFICATION/COMMENTS _____

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference See Section 8.3 and Table 5, and post-DBE calculation in TAB C).

JUSTIFICATION/COMMENTS _____

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Reference See below).

JUSTIFICATION/COMMENTS See Section 7.11, page 7-42 and Section 8.3, page 8-2 and pages 53 and 54 for justification.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 53 OF 60
BINDER TITLE STATIC O-RING COMPUTED B.D.m DATE 6-4-86 R R
TEMPERATURE SWITCHES CHECKED AWL DATE 6/4/86

M. OPERABILITY TEST RESULTS

(5) Test Anomalies

1. Due to functional anomalies noted for other test units being simultaneously tested with the SOR test unit, Magnetrol decided to interrupt the LOCA/MSLB simulation test to investigate. The specified test chamber step-down to 259°F/20 psig was continued to room ambient. Test restart was initiated after a 25.5 hour downtime. Calrod-induced heating, in lieu of additional steam injection, was utilized to retain the 259°F/20 psig plateau. A 25.5 hour period was added to the end of the test. The SOR test unit was operated without anomaly both immediately prior to the test chamber cooldown and immediately subsequent to re-achieving the 259°F/20 psig plateau.
2. Visual inspection of the test unit after post-LOCA/MSLB simulation testing revealed that the switch lead wires, external to the sealed electrical port, were brittle and cracked. This, however, did not affect the function of the unit as shown by the results of functional tests run during the simulation in Table 5, page 7-43; therefore, this anomaly is not significant.
3. The insulation resistance of the test unit decreased significantly (see Table 5, page 7-43) due to moisture/condensate penetration of the switch housing. Despite this, the test unit did function; therefore, this anomaly is not significant.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 54 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6-4-86 R R
TEMPERATURE SWITCHES CHECKED AKL DATE 6/4/86

Test Anomalies (Continued)

4. As shown in Table 5, page 7-43, the test unit failed the post-LOCA
functional tests. The test unit, however, did operate through the test
which meets the requirements specified in the Category and Operating
Times for these temperature switches. This anomaly, therefore, is not
significant (reference sections 7.11 and 8.3).

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 55 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 2-4-86 R R
TEMPERATURE SWITCHES CHECKED ANR DATE 6/2/86

From TAB B, Section M(2) and M(3):

The switch in 17344-82N-C was exposed to a simulated LOCA/MSLB. In the test setup, however, the switch housing was not vented. As a result, the high temperatures in the simulation caused a pressure buildup within the sealed housing and therefore a shift in the setpoint of the switch.

This effect was noted in Table 5, page 7-43 of 17344-82N-C. In order to demonstrate the ability of the Model 12TA-B4 switch to perform its intended function, a second switch was tested in a simulated design basis accident (reference 18577-83N, TAB D). This second switch, S/N 82-6-1267R, was built using various previously aged parts from switches in test reports 17344-82N-C, 17344-82N-D and Addendum I of 17344-82N-D (reference SOR letter TAB E, page 8). This was necessary to place the tested unit in an end-of-life condition. The resulting test unit was a model 12TA-B4 switch with identical materials as were in the switch tested in 17344-82N-C. All materials were in an end-of-life condition at least equal to those in 17344-82N-C before the simulated LOCA test.

As shown in Figure 2, page 4-4 of 18577-83N, the second switch was vented to the atmosphere during the simulation. Table 1, page 4-7 of the same report shows the results of baseline and functional tests performed during the simulation. The setpoints for the switch ranged from 2.85 psig to 3.20 psig increasing and from 2.75 psig to 2.98 psig decreasing.

PAGE B-59

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 56 OF 60
BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6-4-86 WSP R 4 R
TEMPERATURE SWITCHES CHECKED AWL DATE 6-4-86 CRJ R
7-10-90 7/10/90

From TAB B, Section M(2) and M(3):

The tested unit successfully performed its intended safety function.

Since the temperature switch is a pressure switch with a temperature-sensing bulb attached at the pressure port, evidence that the pressure switch can perform its intended safety function is also evidence that the temperature switch will perform its intended safety function.

For the justification for venting to the room atmosphere for the SOR switches see TAB C, p. C-103

R4

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 57 OF 60

BINDER TITLE STATIC O-RING COMPUTED BDM DATE 5-22-86 R R

TEMPERATURE SWITCHES CHECKED AKR DATE 4/3/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See TAB G.

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 58 OF 60
 BINDER TITLE STATIC O-RING COMPUTED BDM DATE 5-22-86 R R
 TEMPERATURE SWITCHES CHECKED FAUR DATE 6/3/86

0. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|---|------------------|
| (1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified? | <u>NA</u> |
| (3) Choice of qualification methodology adequately justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements identified? | <u>Yes</u> |
| (b) Were specific features and failure modes and effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used together with appropriate justification for their use? | <u>Yes</u> |
| (d) Were environmental parameters which affect equipment performance identified? | <u>Yes</u> |
| (5) Adequate similarity between equipment and test specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u> |
| (b) Equipment aged to end of life condition prior to application of DBE conditions? | <u>Yes</u> |
| (c) Absence of preaging in test/analysis justified? | <u>NA</u> |
| (d) Materials susceptible to thermal/radiation aging identified? | <u>Yes</u> |

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 59 OF 60
 BINDER TITLE STATIC O-RING COMPUTED BDM DATE 5-22-86 R R
 TEMPERATURE SWITCHES CHECKED ANR DATE 6/3/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>NA</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>NA</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-ITS-002 PLANT WBN UNIT(S) 1 SHEET 60 OF 60
 BINDER TITLE STATIC O-RING COMPUTED BDM DATE 6-5-86 R R
 TEMPERATURE SWITCHES CHECKED AMK DATE 6/5/86

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>*</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>No</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

*See Open Items pages 1 and 2

PRINT DATE: 11/07/90

BINDER NO. : WBNEQ-IZS -001
 MANUFACTURER : NAMCO
 PAGE 1 OF 21

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-ZS -001-0005A SG1 MS HDR PWR RELIEF CNTL VALVE POS SW	-A	1-ZS -001-0005A EA180-11302		729'	A01	A	100D	FW/V MS/V	MUST PROVIDE PORV POSITION INDICATION POSITION INDICATION IS A PAM B1 VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
WBN-1-ZS -001-0005B SG1 MS HDR PWR RELIEF CNTL VALVE POS SW	-A	1-ZS -001-0005B EA180-11302		729'	A01	A	100D	FW/V MS/V	MUST PROVIDE PORV POSITION INDICATION POSITION INDICATION IS A PAM B1 VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
WBN-1-ZS -001-0012A SG2 MS HDR PRESS RELIEF CNTL VLV POS SW	-B	1-ZS -001-0012A EA180-12302		729'	A02	A	100D	FW/V MS/V	MUST PROVIDE PORV POSITION INDICATION POSITION INDICATION IS A PAM B1 VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
WBN-1-ZS -001-0012B SG2 MS HDR PRESS RELIEF CNTL VLV POS SW	-B	1-ZS -001-0012B EA180-11302		729'	A20	A	100D	FW/V MS/V	MUST PROVIDE PORV POSITION INDICATION POSITION INDICATION IS A PAM B1 VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
WBN-1-ZS -001-0023A SG3 MS HDR PRESS RELIEF CNTL VLV POS SW	-A	1-ZS -001-0023A EA180-12302		729'	A02	A	100D	FW/V MS/V	MUST PROVIDE PORV POSITION INDICATION POSITION INDICATION IS A PAM B1 VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.

PAGE A-1/R4

PREPARER/DATE D.R. Scotrino 8/22/86 R 4 R R
 CHECKED/DATE R.N. Bell 8/22/86 11/8/90 JDH 11/8/90

PRINT DATE: 11/07/90

BINDER NO. : WBNEQ-IZS -0
 MANUFACTURER : NAMCO
 PAGE 2 OF 21

W A T T S B A R N U C L E A R P L A N T
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-1-ZS -001-0023B -A SG3 MS HDR PRESS RELIEF CNTL VLV POS SW	1-ZS -001-0023B -A EA180-11302		729'	A02	A A	100D 100D	FW/V MS/V MUST PROVIDE PORV POSITION INDICATION POSITION INDICATION IS A PAM B1 VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
WBN-1-ZS -001-0030A -B SG4 MS HDR PRESS RELIEF CNTL VLV POS SW	1-ZS -001-0030A -B EA180-11302		729'	A01	A A	100D 100A	FW/V MS/V MUST PROVIDE PORV POSITION INDICATION POSITION INDICATION IS A PAM B1 VARIABLE AND MUST BE MONITORED FOR THE DURATION OF THE EVENT.
WBN-1-ZS -001-0030B -B SG4 MS HDR PRESS RELIEF CNTL VLV POS SW	1-ZS -001-0030B -B EA180-11302		729'	A01	A A	100D 100D	FW/V MS/V MUST PROVIDE PORV POSITION INDICATION POSITION INDICATION IS A PAM B1 VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
WBN-1-ZS -030-0002A -A PURGE AIR SUP FAN A ISLN VALVE POS SW	1-FCV -030-0002/ZS1 -A EA180-11302		737'	A05	A/B	5MN/100D	L MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
WBN-1-ZS -030-0002B -A PURGE AIR SUP FAN A ISLN VALVE POS SW	1-FCV -030-0002/ZS2 -A EA180-12302		737'	A05	A/B	5MN/100D	L MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL

PAGE A-2 R1

PREPARER/DATE D.R. Scantrive 8/22/86 R 4 R R
11/8/90
 CHECKED/DATE R.N. Bell 8/22/86 JDH
11/8/90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
✓ WBN-1-ZS -030-0005A -A 1-FCV -030-0005/ZS1 -A PURGE AIR SUPPLY FAN B ISLN VALVE POS SW EA180-11302			737'	A05	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
✓ WBN-1-ZS -030-0005B -A 1-FCV -030-0005/ZS2 -A PURGE AIR SUPPLY FANB ISLN VALVE POS SW EA180-12302			737'	A05	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
✓ WBN-1-ZS -030-0007A -A 1-ZS -030-0007/1 -A 288 UPPER COMPT PURGE ISLN VALVE POS SW EA180-12302			795' 8"	ANN	A 100D A 100D A 100D A 1MO A 1MO	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0007B -A 1-ZS -030-0007/2 -A 288 UPPER COMPT PURGE ISLN VALVE POS SW EA180-11302			795' 8"	ANN	A 100D A 100D A 100D A 1MO A 1MO	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0009A -B 1-ZS -030-0009/1 -B 263 UPPER COMPT PURGE ISLN VALVE POS SW EA180-12302			800' 1"	ANN	A 100D A 100D A 100D A 1MO A 1MO	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.

R3

PREPARER/DATE D.R. SCOTTRINO 8/22/86 KBN
 CHECKED/DATE L.N. BELL 8/22/86 6/8/90
 R 3 R R

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1) CONTRACT	RM/RAD				
✓ WBN-1-ZS -030-0009B -B 1-ZS -030-0009/2 -B 263 UPPER COMPT PURGE ISLN VALVE POS SW EA180-11302			800'	1" ANN	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0012A -A 1-FCV -030-0012/ZS1 -A 360 ANNULUS PURGE VALVE POS SW EA180-12302			794'	9" ANN	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
✓ WBN-1-ZS -030-0012B -A 1-FCV -030-0012/ZS2 -A 260 ANNULUS PURGE VALVE POS SW EA180-11302			795'	3" ANN	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
✓ WBN-1-ZS -030-0013A -A 1-ZS -030-0013/1 -A INTERIM ABSCE ISLN VALVE POS SW EA180-11302			713'	A06	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
✓ WBN-1-ZS -030-0013B -A 1-ZS -030-0013/2 -A INTERIM ABSCE ISLN VALVE POS SW EA180-12302			713'	A06	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL

R3

PREPARER/DATE D.R. SCOTTEINO 8/22/86 KBN R 3 R _____ R _____
 CHECKED/DATE R.N. BEK 8/22/86 6/8/90 _____
6/8/90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1) CONTRACT	RM/RAD				
✓ WBN-1-ZS -030-0014A -A 1-ZS -030-0014/1 -A 303 LOWER COMPT PURGE ISLN VALVE POS SW EA180-12302			739'	2"	ANN	A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0014B -A 1-ZS -030-0014/2 -A 303 LOWER COMPT PURGE ISLN VALVE POS SW EA180-11302			739'	3"	ANN	A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0016A -B 1-FCV -030-0016/ZS1 -B 240 LOWER COMPT PURGE ISLN VALVE POS SW EA180-12302			733'	8"	ANN	A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0016B -B 1-FCV -030-0016/ZS2 -B 240 LOWER COMPT PURGE ISLN VALVE POS SW EA180-11302			733'	8"	ANN	A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0018A -B 1-ZS -030-0018/1 -B INTERIM ABSCE ISLN VALVE POS SW EA180-11302			713'		A06	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL

R3

PREPARER/DATE D.R. SCOTTRINO 8/22/86 R3 R R
 CHECKED/DATE R.N. BELL 8/22/86 REN/6/90 CAF 6/8/90

PR: 05/30/90

BINDER NO. : WBNEQ-IZS
 MANUFACTURER : NAMCO
 PAGE 6 OF 21

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
✓ WBN-1-ZS -030-0018B -B 1-ZS -030-0018/2 -B INTERIM ABSCE ISLN VALVE POS SW	EA180-12302		713'	A06	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
✓ WBN-1-ZS -030-0019A -B 1-ZS -030-0019/1 -B 058 INCORE INST RM PURGE ISLN VALVE POS SW	EA180-12302		730' 4"	ANN	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0019B -B 1-ZS -030-0019/2 -B 057 INCORE INST RM PURGE ISLN VALVE POS SW	EA180-11302		730' 4"	ANN	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0028A -A 1-ZS -030-0028/1 -A INTERIM ABSCE ISLN VALVE POS SW	EA180-12302		737'	A05	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
✓ WBN-1-ZS -030-0028B -A 1-ZS -030-0028/2 -A INTERIM ABSCE ISLN VALVE POS SW	EA180-11302		737'	A05	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL

R3

PREPARER/DATE D.R. SCONTRINO 8/22/86 R 3 R R
 CHECKED/DATE R.N. BELL 8/22/86 6/8/90 _____

PAGE A-6 R3

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
✓ WBN-1-ZS -030-0029A -B 1-ZS INTERIM ABSCE ISLN VALVE POS SW	-030-0029/1 -B EA180-12302		737'	A05	A/B	5MN/100D	L MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
✓ WBN-1-ZS -030-0029B -B 1-ZS INTERIM ABSCE ISLN VALVE POS SW	-030-0029/2 -B EA180-11302		737'	A05	A/B	5MN/100D	L MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
✓ WBN-1-ZS -030-0037A -B 1-FCV LOWER COMPT PURGE CNTL VALVE POS SW	-030-0037/ZS1 -B 280 EA180-12302		719' 7"	ANN	A	100D 100D 100D 1MO 1MO	L MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0037B -B 1-FCV LOWER COMPT PURGE CNTL VALVE POS SW	-030-0037/ZS2 -B 280 EA180-11302		719' 1"	ANN	A	100D 100D 100D 1MO 1MO	L MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0051A -A 1-ZS UPPER CNTMT EXH ISLN VALVE POS SW	-030-0051/1 -A 290 EA180-12302		745' 11"	ANN	A	100D 100D 100D 1MO 1MO	L MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.

R3

PREPARER/DATE D.R. SCONTEINO 8/22/86 R3 R R
 CHECKED/DATE R.N. BELL 8/22/86 REN 4/8/90 CAH 6/8/90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION	
			AZMITH	ELEV(1) CONTRACT					RM/RAD
✓ WBN-1-ZS -030-0051B UPPER CNTMT EXH ISLN VALVE POS SW	-A	1-ZS -030-0051/2 EA180-11302	-A	290	745'11"	ANN	A 100D A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0053A UPPER CNTMT EXH ISLN VALVE POS SW	-B	1-ZS -030-0053/1 EA180-11302	-B	252	748'	ANN	A 100D A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT. R3
✓ WBN-1-ZS -030-0053B UPPER CNTMT EXH ISLN VALVE POS SW	-B	1-ZS -030-0053/2 EA180-12302	-B	252	748'	ANN	A 100D A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0054A ANNULUS EXH ISLN VALVE POS SW	-A	1-FCV -030-0054/ZS1 EA180-12302	-A	039	729' 2"	ANN	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
✓ WBN-1-ZS -030-0054B ANNULUS EXH ISLN VALVE POS SW	-A	1-FCV -030-0054/ZS2 EA180-11302	-A	039	729' 2"	ANN	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL

PREPARER/DATE D.R. SCOTTRING 8/22/86 8/26/90 R 3 R R
 CHECKED/DATE R.N. BELL 8/22/86 6/8/90 CAF R R R

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
✓ WBN-1-ZS -030-0057A -B 1-ZS -030-0057/1 -B 035 LOWER CNTMT EXH ISLN VALVE POS SW EA180-11302			731' 10"	ANN	A 100D A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0057B -B 1-ZS -030-0057/2 -B 035 LOWER CNTMT EXH ISLN VALVE POS SW EA180-12302			731' 4"	ANN	A 100D A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0059A -A 1-ZS -030-0059/1 -A 115 INCORE INSTR RM EXH ISLN VALVE POS SW EA180-12302			740' 9"	ANN	A 100D A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0059B -A 1-ZS -030-0059/2 -A 115 INCORE INSTR RM EXH ISLN VALVE POS SW EA180-11302			741'	ANN	A 100D A 100D A 100D A 1MO A 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
✓ WBN-1-ZS -030-0060A -A 1-ZS -030-0060/1 -A INTERIM ABSCE ISLN VALVE POS SW EA180-11302			757'	A16	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL

R3

PREPARER/DATE D.R. SCOTRINO 8/22/86 R3 R___ R___
 CHECKED/DATE R.N. BELL 8/22/86 CRJ R___ R___
6/8/90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
✓ WBN-1-ZS -030-0060B -A INTERIM ABSCE ISLN VALVE POS SW	1-ZS -030-0060/2 -A EA180-12302		757'	A16	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
✓ WBN-1-ZS -030-0061A -A PURGE AIR EXH UNIT A SUCT VALVE POS SW	1-FCV -030-0061/ZS1 -A EA180-11302		713'	A06	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
✓ WBN-1-ZS -030-0061B -A PURGE AIR EXH UNIT A SUCT VALVE POS SW	1-FCV -030-0061/ZS2 -A EA180-12302		713'	A06	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
✓ WBN-1-ZS -030-0062A -A PURGE AIR EXH UNIT B SUCT VALVE POS SW	1-FCV -030-0062/ZS1 -A EA180-11302		713'	A06	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
✓ WBN-1-ZS -030-0062B -A PURGE AIR EXH UNIT B SUCT VALVE POS SW	1-FCV -030-0062/ZS2 -A EA180-12302		713'	A06	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL

PREPARER/DATE D.P. SCOTRINO 8/22/86 IDH R 2 R _____ R _____
 CHECKED/DATE R.N. BELL 8/22/86 WCB R _____ R _____
 12/12/89
 12/13/89

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-ZS -030-0069A -B INTERIM ABSCE ISLN VALVE POS SW	1-ZS -030-0069/1 -B EA180-11302		757'	A16	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
WBN-1-ZS -030-0069B -B INTERIM ABSCE ISLN VALVE POS SW	1-ZS -030-0069/2 -B EA180-12302		757'	A16	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
WBN-1-ZS -030-0296A -A INTERIM ISLN DAMPER CDWE POS SWITCH	1-FCO -030-0296/ZS1 -A		(*)		A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
WBN-1-ZS -030-0296B -A INTERIM ISLN DAMPER CDWE POS SWITCH	1-FCO -030-0296/ZS2 -A		(*)		A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
WBN-1-ZS -030-0297A -B INTERIM ISLN DAMPER CDWE POS SWITCH	1-FCO -030-0297/ZS1 -B		(*)		A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL

PREPARER/DATE D.R. SCOTTRINO 8/22/86 R 2 R___ R___
 CHECKED/DATE R.N. BELL 8/22/86 JDH ___ ___
12/22/89 ___ ___
12/13/89 ___ ___

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-1-ZS -030-0297B -B INTERIM ISLN DAMPER CDWE POS SWITCH	1-FCO -030-0297/ZS2 -B		(*)		A/B 5MN/100D L		MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
WBN-1-ZS -030-0298A -B INTERIM ISLN DAMPER CDWE POS SWITCH	1-FCO -030-0298/ZS1 -B		(*)		A/B 5MN/100D L		MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
WBN-1-ZS -030-0298B -B INTERIM ISLN DAMPER CDWE POS SWITCH	1-FCO -030-0298/ZS2 -B		(*)		A/B 5MN/100D L		MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
WBN-1-ZS -030-0299A -A INTERIM ISLN DAMPER CDWE POS SWITCH	1-FCO -030-0299/ZS1 -A		(*)		A/B 5MN/100D L		MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL
WBN-1-ZS -030-0299B -A INTERIM ISLN DAMPER CDWE POS SWITCH	1-FCO -030-0299/ZS2 -A		(*)		A/B 5MN/100D L		MUST OPERATE AND NOT FAIL UPON AUX BLDG ISOLATION SIGNAL

PREPARER/DATE DR. SCOTRINO 9/22/86 R 2 R R
 CHECKED/DATE R.N. BELL 9/22/86 JDH
WCP
12/12/89
12/13/89

W A T T S B A R N U C L E A R P L A N T
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1) CONTRACT	RM/RAD				
✓ WBN-1-ZS -032-0080A -A 1-FCV -032-0080/ZS1 -A 290 RB UNIT 1 TRAIN A ISLN VALVE POS SW	EA180-11302		717' 5"	ANN	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL.
					A	100D	MS/C	PERFORMS A PAM TYPE B FUNCTION
					A	100D	FW/C	& MUST BE MONITORED TO ENSURE
					A	1MO	RH/C	CNTMT INTEGRITY IS MAINTAINED.
					A	1MO	CV/C	
✓ WBN-1-ZS -032-0080B -A 1-FCV -032-0080/ZS2 -A 293 RB UNIT 1 TRAIN A ISLN VALVE POS SW	EA180-11302		717'10"	ANN	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL.
					A	100D	MS/C	PERFORMS A PAM TYPE B FUNCTION
					A	100D	FW/C	& MUST BE MONITORED TO ENSURE
					A	1MO	RH/C	CNTMT INTEGRITY IS MAINTAINED.
					A	1MO	CV/C	
✓ WBN-1-ZS -032-0102A -B 1-FCV -032-0102/ZS1 -B 277 RB UNIT 1 TRAIN B ISLN VALVE POS SW	EA180-11302		728' 4"	ANN	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL.
					A	100D	MS/C	PERFORMS A PAM TYPE B FUNCTION
					A	100D	FW/C	& MUST BE MONITORED TO ENSURE
					A	1MO	RH/C	CNTMT INTEGRITY IS MAINTAINED.
					A	1MO	CV/C	
✓ WBN-1-ZS -032-0102B -B 1-FCV -032-0102/ZS2 -B 278 RB UNIT 1 TRAIN B ISLN VALVE POS SW	EA180-11302		728' 2"	ANN	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL.
					A	100D	MS/C	PERFORMS A PAM TYPE B FUNCTION
					A	100D	FW/C	& MUST BE MONITORED TO ENSURE
					A	1MO	RH/C	CNTMT INTEGRITY IS MAINTAINED.
					A	1MO	CV/C	
✓ WBN-1-ZS -032-0110A -A 1-FCV -032-0110/ZS1 -A 290 RB UI NON ESNTL ISLN VALVE POS SWITCH	EA180-11302		718' 7"	ANN	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL.
					A	100D	MS/C	PERFORMS A PAM TYPE B FUNCTION
					A	100D	FW/C	& MUST BE MONITORED TO ENSURE
					A	1MO	RH/C	CNTMT INTEGRITY IS MAINTAINED.
					A	1MO	CV/C	

PREPARER/DATE D.R. SCONTRINO 9/22/86 JOH R 2 R _____ R _____
 CHECKED/DATE R.N. BELL 9/22/86 WCP R _____ R _____

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION			CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT	RM/RAD				
✓ WBN-1-ZS -032-0110B -A 1-FCV -032-0110/ZS2 -A 295 RB U1 NON ESNTL ISLN VALVE POS SWITCH EA180-11302		719' 7"	ANN	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL.	
				A	100D	MS/C	PERFORMS A PAM TYPE B FUNCTION & MUST BE MONITORED TO ENSURE CNTMT INTEGRITY IS MAINTAINED.	
				A	100D	FW/C		
				A	1MO	RH/C		
				A	1MO	CV/C		
✓ WBN-1-ZS -062-0069A -A 1-FCV -062-0069/ZS1 -A 131 RC LOOP 3 LETDOWN FLOW POS SW EA180-11302		725' 7"	LC	A/B	1HR/1MO	CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL	
✓ WBN-1-ZS -062-0069B -A 1-FCV -062-0069/ZS2 -A 131 RC LOOP 3 LETDOWN FLOW POS SW EA180-11302		725' 7"	LC	A/B	1HR/1MO	CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL	
✓ WBN-1-ZS -062-0070A -A 1-FCV -062-0070/ZS1 -A 133 RC LOOP 3 LETDOWN FLOW POS SW EA180-12302		719' 11"	AC2	A/B	1HR/1MO	CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL	
✓ WBN-1-ZS -062-0070B -A 1-FCV -062-0070/ZS2 -A 133 RC LOOP 3 LETDOWN FLOW POS SW EA180-12302		719' 8"	AC2	A/B	1HR/1MO	CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL	

PREPARER/DATE D.R. SCOTTRINO 8/22/86 R 2 R R
 CHECKED/DATE R.N. BELL 8/22/86 JDH
12/12/89
WCP
12/13/89

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION			CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION	
		AZMITH	ELEV(1)	RM/RAD					
WBN-1-ZS -062-0077A -B LTDN LINE ISLN VLV FLOW CONTROL POS SW	1-FCV -062-0077/ZS1 -B				(*)	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
						A	1MO	RH/A	
						A	1MO	CV/A	
						A	1MO	AF	
WBN-1-ZS -062-0077B -B LTDN LINE ISLN VLV FLOW CONTROL POS SW	1-FCV -062-0077/ZS2 -B				(*)	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
						A	1MO	RH/A	
						A	1MO	CV/A	
						A	1MO	AF	
WBN-1-ZS -063-0003 -A SIS PMP RECIRC TO RWST VLV ZONE SWITCH	1-ZS -063-0003 -A				(*)	A/B	1WK/100D	L	MUST OPERATE AND NOT FAIL UPON SIS RECIRC SIGNAL
WBN-1-ZS -063-0004 -B SIS PMP RECIRC TO RWST VLV ZONE SWITCH	1-ZS -063-0004 -B				(*)	A/B	1WK/100D	L	MUST OPERATE AND NOT FAIL UPON SIS RECIRC SIGNAL
WBN-1-ZS -063-0023A -B SIS ACCUM FILL LINE ISLN VLV POS SWITCH	1-FCV -063-0023/ZS1 -B				(*)	A	100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. THIS LIMIT SWITCH IS A PAM VARIABLE AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT.
						A	1MO	RH/A	
						A	1MO	AB	
						A	1MO	CV/A	

R3

R3

PREPARER/DATE D.R. SCOTTRING 8/22/86 ^{R 3} 6/8/90 R _____ R _____
 CHECKED/DATE R.N. BELL 8/22/86 CSH 6/8/90 R _____ R _____

PAGE A-15 R3

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION					
		AZMITH	ELEV(1) CONTRACT					RM/RAD	(2)			
WBN-1-ZS -063-0023B -B SIS ACCUM FILL LINE ISLN VLV POS SWITCH	1-FCV -063-0023/ZS2 -B				100D	L	MUST OPERATE AND NOT FAIL UPON					
								(*)	A	1MO	RH/A	CNTMT ISOLATION SIGNAL. THIS
									A	1MO	AB	LIMIT SWITCH IS A PAM VARIABLE
									A	1MO	AF/A	AND MUST BE MONITORED FOR THE
							DURATION OF EACH EVENT.					
WBN-1-ZS -063-0064A -A SIS ACCUM TANK N2 HDR INLET VLV POS SW	1-FCV -063-0064/ZS1 -A				100D	L	MUST OPERATE AND NOT FAIL UPON					
								(*)	A	1MO	RH/A	CNTMT ISOLATION SIGNAL. THIS
									A	1MO	AB	LIMIT SWITCH IS A PAM VARIABLE
									A	1MO	AF/A	AND MUST BE MONITORED FOR THE
							DURATION OF EACH EVENT.					
WBN-1-ZS -063-0064B -A SIS ACCUM TANK N2 HDR INLET VLV POS SW	1-FCV -063-0064/ZS2 -A				100D	L	MUST OPERATE AND NOT FAIL UPON					
								(*)	A	1MO	RH/A	CNTMT ISOLATION SIGNAL. THIS
									A	1MO	AB	LIMIT SWITCH IS A PAM VARIABLE
									A	1MO	AF/A	AND MUST BE MONITORED FOR THE
							DURATION OF EACH EVENT.					
WBN-1-ZS -063-0084A -B SIS CHECK VLV LEAK TEST ISLN VLV POS SW	1-FCV -063-0084/ZS1 -B				100D	L	MUST OPERATE AND NOT FAIL UPON					
								(*)	A	1MO	RH/A	CNTMT ISOLATION SIGNAL. THIS
									A	1MO	AB	LIMIT SWITCH IS A PAM VARIABLE
									A	1MO	AF/A	AND MUST BE MONITORED FOR THE
							DURATION OF EACH EVENT.					
WBN-1-ZS -063-0084B -B SIS CHECK VLV LEAK TEST ISLN VLV POS SW	1-FCV -063-0084/ZS2 -B				100D	L	MUST OPERATE AND NOT FAIL UPON					
								(*)	A	1MO	RH/A	CNTMT ISOLATION SIGNAL. THIS
									A	1MO	AB	LIMIT SWITCH IS A PAM VARIABLE
									A	1MO	AF/A	AND MUST BE MONITORED FOR THE
							DURATION OF EACH EVENT.					

R3

PREPARER/DATE D.R. SCOTTRINO 8/22/86 KEN 6/8/90 R 3 R R
 CHECKED/DATE R.N. BELL 8/22/86 CAF 6/8/90 R R

PRINT DATE: 11/07/90

BINDER NO. : WBNEQ-IZS -001
MANUFACTURER : NAMCO
PAGE 17 OF 21

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION			CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1)	RM/RAD				
WBN-1-ZS -063-0175 -B SIS PMP 1B-B DISCH RWST SHTOFF POS SW	1-ZS -063-0175 -B	(*)			A/B	1HK/100D	L	MUST OPERATE AND NOT FAIL UPON SIS RECIRC SIGNAL
WBN-2-ZS -065-0005A -A CNTMT ANN VAC FANS ISLN DMPR VLV POS SW	2-FCO -065-0005/ZS1 -A	(*)			A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
WBN-2-ZS -065-0005B -A CNTMT ANN VAC FANS ISLN DMPR VLV POS SW	2-FCO -065-0005/ZS2 -A	(*)			A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
WBN-1-ZS -065-0052A -A CNTMT ANN VAC FANS ISLN VALVE POS SW	1-FCV -065-0052/ZS1 -A EA180-11302	757'		A16	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON SI SIGNAL
WBN-1-ZS -065-0052B -A CNTMT ANN VAC FANS ISLN VALVE POS SW	1-FCV -065-0052/ZS2 -A EA180-12302	757'		A16	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON SI SIGNAL

PAGE A -17R4

PREPARER/DATE D.R. Scantrino 9/22/86

CHECKED/DATE R.N. Bell 9/22/86

R <u>4</u>	R	R
<u>11/8/90</u>		
<u>JDN</u>		
<u>11/8/90</u>		

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-1-ZS -065-0053A -B CNTMT ANN VAC FANS ISLN VALVE POS SW	1-FCV -065-0053/ZS1 -B EA180-11302		757'	A16	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON SI SIGNAL
WBN-1-ZS -065-0053B -B CNTMT ANN VAC FANS ISLN VALVE POS SW	1-FCV -065-0053/ZS2 -B EA180-12302		757'	A16	A/B 5MN/100D	L	MUST OPERATE AND NOT FAIL UPON SI SIGNAL
WBN-1-ZS -068-0305A -A RCS FCV WDS N2 MAN TO PRT POS SWITCH	1-ZS -068-0305A -A	(*)			A 100D A IMO A IMO A IMO A IMO	L AF AB RH/A CV/A	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL POSITION INDICATION IS A PAM VARIABLE AND MUST BE MONITORED FOR DURATION OF EACH EVENT.
WBN-1-ZS -068-0305B -A RCS FCV WDS N2 MAN TO PRT POS SWITCH	1-ZS -068-0305B -A	(*)			A 100D A IMO A IMO A IMO A IMO	L AF AB RH/A CV/A	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL POSITION INDICATION IS A PAM VARIABLE AND MUST BE MONITORED FOR DURATION OF EACH EVENT.
WBN-1-ZS -070-0085A -B EXCESS LETDOWN HTX OUTLET VALVE POS SW	1-ZS -070-0085A -B EA180-11302		713'	A28	A 100D A IMO A IMO A IMO A IMO	L CV/A RH/A AF/A AB/A	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. PERFORMS A PAM TYPE B FUNCTION & MUST BE MONITORED TO ENSURE CNTMT INTEGRITY IS MAINTAINED.

PAGE A-182A

PREPARER/DATE D.R. Scotrino 9/22/86

CHECKED/DATE R.N. Bell 9/22/86

R 4 R R
RBN
11/8/90
JOH
11/8/90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u> <u>(2)</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-ZS -070-0085B -B EXCESS LETDOWN HTX OUTLET VALVE POS SW	1-ZS -070-0085B -B EA180-12302		713'	A28	A A A A A	100D 1MO 1MO 1MO 1MO	L CV/A RH/A AF/A AB/A	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL. PERFORMS A PAM TYPE B FUNCTION & MUST BE MONITORED TO ENSURE CNTMT INTEGRITY IS MAINTAINED.
WBN-1-ZS -072-0040 -A RHR SPRAY HDR A ISLN VLV STEM POS SWITCH	1-ZS -072-0040 -A		(*)		A/B	1WK/100D	L	MUST NOT FAIL IN A MANNER THAT WOULD ADVERSELY IMPACT THE OPERATION OF THE ASSOCIATED FCV.
WBN-1-ZS -072-0041 -B RHR SPRAY HDR B ISLN VLV STEM POS SWITCH	1-ZS -072-0041 -B		(*)		A/B	1WK/100D	L	MUST NOT FAIL IN A MANNER THAT WOULD ADVERSELY IMPACT THE OPERATION OF THE ASSOCIATED FCV.
WBN-1-ZS -077-0019A -A RCDT TO VENT HDR FCV POS SWITCH	1-ZS -077-0019A -A		(*)		A A A A A	100D 1MO 1MO 1MO 1MO	L AF AB RH/A CV/A	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL POSITION INDICATION IS A PAM VARIABLE AND MUST BE MONITORED FOR DURATION OF EACH EVENT.
WBN-1-ZS -077-0019B -A RCDT TO VENT HDR FCV POS SWITCH	1-ZS -077-0019B -A		(*)		A A A A A	100D 1MO 1MO 1MO 1MO	L AF AB RH/A CV/A	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL POSITION INDICATION IS A PAM VARIABLE AND MUST BE MONITORED FOR DURATION OF EVENT.

PAGE A -19 RA

PREPARER/DATE D.R. Scontrino 9/22/86 R 4 R R
 CHECKED/DATE R.N. Bell 9/22/86 Ken 11/8/90 _____
JDW 11/8/90 _____

W A T T S B A R N U C L E A R P L A N T
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u> <u>CONTRACT</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>RM/RAD</u>	<u>CAT</u> <u>(2)</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-ZS -077-0020A RCDT N2 SUPPLY FCV POS SWITCH	-A 1-ZS -077-0020A	-A	(*)	A A A A A	100D 1MO 1MO 1MO 1MO	L AF AB RH/A CV/A	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL POSITION INDICATION IS A PAM VARIABLE AND MUST BE MONITORED FOR DURATION OF EACH EVENT.
WBN-1-ZS -077-0020B RCDT N2 SUPPLY FCV POS SWITCH	-A 1-ZS -077-0020B	-A	(*)	A A A A A	100D 1MO 1MO 1MO 1MO	L AF AB RH/A CV/A	MUST OPERATE AND FAIL UPON CNTMT ISOLATION SIGNAL POSITION INDICATION IS A PAM VARIABLE AND MUST BE MONITORED FOR DURATION OF EACH EVENT.
WBN-1-ZS -081-0012A PW-RCS PRESS RELF TKRCP STANPIPES POS SW	-A 1-FCV -081-0012/ZS1	-A	(*)	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
WBN-1-ZS -081-0012B PW-RCS PRESS RELF TKRCP STANPIPES POS SW	-A 1-FCV -081-0012/ZS2	-A	(*)	A/B	5MN/100D	L	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
WBN-1-ZS -090-0107 CNTMT BLDG LWR COMPT MON ISLN VLV POS SW	-A 1-FCV -090-0107/ZS EA180-11302	-A 294	740'10" ANN	A/B A/B A/B A/B A/B	5MN/100D 5MN/100D 5MN/100D 15MN/1MO 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL

PAGE A-20R4

PREPARER/DATE D.R. Scontrino 9/22/86
 CHECKED/DATE R.N. Bell 9/22/86

R 4 R R
 KBN 11/8/90
SDH
11/8/90

W A T T S B A R N U C L E A R P L A N T
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-1-ZS -090-0111 -A 1-FCV -090-0111/ZS -A 293 CNTMT BLDG LWR COMPT MON ISLN VLV POS SW EA180-12302			740' 10"	ANN	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
WBN-1-ZS -090-0113 -A 1-FCV -090-0113/ZS -A 290 CNTMT BLDG UP COMPT MON ISLN VLV POS SW EA180-11302			740' 9"	ANN	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL
WBN-1-ZS -090-0117 -A 1-FCV -090-0117/ZS -A 290 CNTMT BLDG UP COMPT MON ISLN VLV POS SW EA180-12302			740' 5"	ANN	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE AND NOT FAIL UPON CNTMT ISOLATION SIGNAL

PAGE A - 21/24

PREPARER/DATE D.R. Scantcino 9/22/86 ^{R 4} 11/8/90 R _____ R _____
 CHECKED/DATE R.N. Bell 9/22/86 ^{KBN} 11/8/90 _____

WBNEQ-IZS-001

THIS PAGE INTENTIONALLY LEFT BLANK

Pages A-22 R1 thru A-27 R1 were deleted per revision 2.

WBEP-0158Q

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R _____ R _____
BINDER TITLE EA 180 Series COMPUTED |R1 JDA DATE 6-9-89
Limit Switches Manufactured
After 7/30/80 CHECKED |R1 JDA DATE 6/9/89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F. Elevations shown as (*) are covered by SCR WBNEEB 8578 and are documented as Open Item No. 2 of this binder.
2. See Page B-1A for source of Category and Operating Time assignments.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 37
R 1 R 4
BINDER TITLE EA 180 Series COMPUTED DRS DATE 6/25/86 JDH KBJ
Limit Switches Manufactured 5/25/89 11/6/90
After 7/30/80 CHECKED RNB DATE 6/27/86 HDR JDM
6/9/89 11/7/90

A. DOCUMENTATION (See Note)

Equipment Description Limit Switch
Vendor/Manufacturer NAMCO
Equipment Model No.(s) See TAB A

QUALIFICATION REPORTS (See Note)

- (1) Title/Number/Revision Qualification of EA RIMS B70 851021 100
180 Series Limit Switches Namco Report
No. OTR 105, Rev. 4 (TAB D) DATE 1/9/84
- (2) Title/Number/Revision Qualification of EA RIMS B26 890516 926
180 Series Limit Switches NAMCO Report
No. OTR 155, Rev. 0 (TAB D) DATE 10/5/87
- (3) Title/Number/Revision _____ RIMS _____
DATE _____

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (4) Deleted per revision 4. |R4
- (5) Material Aging and Accident Degradation Equivalency |R4
Calculation - WAC-427 (B44 901011 802) (TAB C-4)
- (6) Vendor telecon: TVA (L.P. Woodley) and Namco
(John R. Bendokaitis) on 10/3/85 - See TAB E(1)
- (7) Vendor telecon: TVA (L.P. Woodley) and Namco
(John R. Bendokaitis) on 10/22/85 - See TAB E(2)
- (8) Vendor telecon: TVA (L.P. Woodley) and Namco
(John R. Bendokaitis) on 11/4/85 - See TAB E(3)
- (9) TI-RPS-32 R2 (B45 860407 237), Shield Design Review and
Equipment Qualification Study

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (10) WBNNAL3-022 RO (B45 860314 239), Pipe Chase and Pipe Shaft 100 Day Total Integrated Dose
- (11) WBNTSR-051 RO (B26 891129 202), Reduction of Beta Dose by Sheet Metal
- (12) TVA Environmental Drawing 47E235-42 R2, DCA P-04104-02-1, -03-0, -05-0, and DCA S-09715-02-0, -03-0, -04-0, -05-0, -13-0, -14-0, -15-0 R4
- (13) TVA Environmental Drawing 47E235-44 R1
- (14) TVA Environmental Drawing 47E235-48 R3
- (15) TVA Environmental Drawing 47E235-56 R1
- (16) TVA Environmental Drawing 47E235-61 R1
- (17) TVA Environmental Drawing 47E235-76 R3
- (18) TVA Environmental Drawing 47E235-78 R3

Category and Operating Times

RIMS NO.

- (19) System 1 (WBNOSG4-004 R11) B18 900612 253
- (20) System 30 (WBNOSG4-008 R16) B26 900717 201 R4
- (21) System 32 (WBNOSG4-010 R4) B26 891205 200
- (22) System 62 (WBNOSG4-013 R16) B18 901011 501
- (23) System 63 (WBNOSG4-014 R12) B26 900713 212 R4
- (24) System 65 (WBNOSG4-015 R10) B26 900309 226
- (25) System 68 (WBNOSG4-017 R11) B18 900612 252
- (26) System 70 (WBNOSG4-018 R14) B26 900614 204 R4
- (27) System 72 (WBNOSG4-019 R9) B26 900717 002
- (28) System 77 (WBNOSG4-021 R5) B18 900612 251
- (29) System 81 (WBNOSG4-023 R3) B45 851127 219
- (30) System 90 (WBNOSG4-026 R7) B45 870227 426
- (31) U2 for U1 (WBNOSG4-040 R8) B26 900626 224 R4
- (32) WBNNAL3-031 R1 (B45 880826 235), EGTS Room 100 Day LOCA dose
- (33) WBNTSR-018 RO (B26 891106 203), Dose Grid around the EGTS filter train.
- (34) QIR MNMWBN90032 RO (B26 900226 251) R4
- (35) QIR MNMWBN90057 RO (B26 900515 250)

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 2 OF 37
R 3 R 4
BINDER TITLE EA 180 Series COMPUTED DRS DATE 9/16/86 KBN KBN
Limit Switches Manufactured 6/14/90 11/6/90
After 7/30/80 CHECKED RNB DATE 9/16/86 CDH JDN
6/14/90 11/7/90

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES Equipment is qualified pending resolution of open item noted in the open items list.

1. SCR WBNEEB8578 R5 - Change out unqualified switches
2. DCN P-06660-A, M-07533-A, M-07890-A, M-08055-A, M-08061-A - | R4
Add conduit seals

COMMENTS/RECOMMENDATIONS The required operating environments, normal and accident, have been reviewed for each switch location identified in TAB A. All switches are qualified to the worst case combination of these environmental parameters. This includes consideration of peak levels and profiles.

Approximately 60 standard and short travel switches are being changed out per ECN 6613 (Unit 1) and ECN 6614 (Unit 2 for Unit 1 operation). The documentation for the short travel switches is presently referenced in the binder even though they are not yet included in the binder.

BINDER NO WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 3 OF 37

BINDER TITLE EA180 SERIES LIMIT COMPUTED DMS DATE 6/13/80 R R

SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RNB DATE 6/27/80

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

 X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE-323-1974)

 Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE-323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS None

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE Std 323-1974

IEEE Std 344-1975

IEEE Std 382-1972 (Pressurized Water Reactor Portion Only)

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 4 OF 37
BINDER TITLE EA180 SERIES LIMIT COMPUTED DMS DATE 6/13/86 R R
SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RWB DATE 6/27/86

D. QUALIFICATION METHODOLOGY

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS This test provides generic group qualifi-
cation for Model EA180 Series limit switches. The Model EA180-11302
selected for test purposes is identical to some of the equipment
qualified by this binder. TAB C(5) contains a similarity evalua-
tion which addresses the remainder of the equipment.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 5 OF 37
 BINDER TITLE EA180 SERIES LIMIT COMPUTED DMS DATE 6/13/86 R R
 SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED R/S DATE 6/27/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Limit Switch</u>	<u>Limit Switch</u>	<u>TAB D, pp. 3-1,3-6</u>
(2) Manufacturer	<u>Namco</u>	<u>Namco</u>	<u>TAB D, pp. 3-1,3-6</u>
(3) Model Number(s)	<u>See TAB A</u>	<u>EA180-11302</u>	<u>TAB D, pp. 3-1,3-6</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(4) Serial Number(s)	<u>See Comment</u>	<u>See Comment</u>	<u>TAB D, p. 3-10</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(5) Identify Component-Unique checksheet attached:	<u>NA</u>		

JUSTIFICATION/COMMENTS These limit switches do not have serial numbers but are provided with date codes per the manufacturer's date code system described in TAB D, page 3-10 of the test report. Field Verification (TAB F) has determined that all limit switches covered in TAB A have date codes after July 30, 1980, and are therefore covered by QTR 105. See TAB C(5) for similarity evaluation.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 6 OF 37
R 1 R 4
BINDER TITLE EA 180 Series COMPUTED DRS DATE 6/26/86 JDH KBN
Limit Switches Manufactured 5/17/89 11/6/90
After 7/30/80 CHECKED RNB DATE 6/27/86 HDR JDH
6/9/89 11/7/90

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Conduit Seals	<u>See Comment (1)</u>	<u>Yes</u>	<u>TAB D, p 4-2</u>
Connector Seals	<u>NA</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>None</u>	<u>NA</u>	<u>NA</u>
Physical Configuration	<u>None</u>	<u>NA</u>	<u>NA</u>
Other	<u>See Comments (2)</u>	<u>Yes</u>	<u>NA</u>

JUSTIFICATION/COMMENTS

(1) For installation instruction refer to EA 189-90008, TAB D, page 4-2 of OTR 105. The conduit entrance must be sealed in such a way as to maintain the switch integrity under required service condition (see OMDS (TAB G) for conduit seal requirements).

(2) Although, it was not considered part of the qualification test, an operating lever is required for proper operation of the switch. The lever and roller should be of metallic construction. Nylon rollers are not acceptable and are controlled through TVA's maintenance program (See TAB G).

R4

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 7 OF 32
 BINDER TITLE EAL80 SERIES LIMIT COMPUTED DAS DATE 6/13/86 R R
 SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RNB DATE 6/27/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>TAB D, p. 10-6</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>TAB D, p. 10-6</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>TAB D, p. 10-6</u>
Radiation	<u>Yes</u>	<u>TAB D, p. 10-7</u>
Wear	<u>Yes</u>	<u>TAB D, p. 10-6</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>TAB D, p. 10-7</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>TAB D, p. 10-8</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>TAB D, p. 10-9</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>TAB D, p. 6-2</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes - See Comment (2)

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? No - See Comment (1) (Reference TAB D, page 10-61).

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 8 OF 37
 BINDER TITLE EA180 SERIES LIMIT COMPUTED DPS DATE 7/8/86 R R
 SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RMB DATE 7/9/86

JUSTIFICATION/COMMENTS (1) Test equipment and calibration dates were recorded; however, test equipment accuracies were not documented in the test report. (2) The recorded seismic test in TAB D, App. B p. 10-20 (QTR 105) is from a different Model EA180 switch; however, full fragility testing was performed on the switch used throughout the test sequence (Ref TAB D, p. 10-7).

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference TAB D, page 10-6).

JUSTIFICATION/COMMENTS None

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>TAB D, p. 10-6</u>
Radiation exposure	<u>Yes</u>	<u>TAB D, p. 10-7</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>TAB D, p. 10-7</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>TAB D, p. 10-6</u>

JUSTIFICATION/COMMENTS None

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? Yes (Reference See TAB C(18)).

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 9 OF 37
R 1 R
BINDER TITLE EA 180 Series COMPUTED DRS DATE 6/13/86 JDH
Limit Switches Manufactured 6-9-89
After 7/30/80 CHECKED RNB DATE 6/27/86 JBR
6/9/89

H. AGING (Continued)

JUSTIFICATION/COMMENTS See TAB C 18 |R1

(4) Thermal Aging:

(a) Was thermal aging considered in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, page 10-6).

(b) Were the materials susceptible to thermal aging degradation identified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, page 4-7).

JUSTIFICATION/COMMENTS None

(c) Was the basis for thermal aging identified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, page 4-6, 4-7).

JUSTIFICATION/COMMENTS None

(d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, page 4-6, 4-7).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>54.4°C (55°C)</u>	<u>120°</u>	<u>55°C</u>
Time	<u>40 Years</u>	<u>432.5 hrs</u>	<u>5 Years</u>

JUSTIFICATION/COMMENTS The qualified life can be extended to 40 years through periodic refurbishment as defined in EA189-90051 TAB D, (Page 4-3).

(e) Was the Arrhenius methodolgy used for accelerated aging (Yes/No/NA)? Yes (Reference: TAB D, page 4-7).

JUSTIFICATION/COMMENTS None

(f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (Yes/No/NA)? Yes (Reference: TAB D, pp 4-8, 4-9).

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 100F 37

BINDER TITLE EA180 SERIES LIMIT COMPUTED DLS DATE 6/13/86 R R

SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED DMS DATE 6/27/86

H. AGING (Continued)

JUSTIFICATION/COMMENTS None

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS None

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference TAB D, pp. 11-13, 11-14).

JUSTIFICATION/COMMENTS Performance testing conducted before and after aging test adequately provided a basis for aging degradation evaluation

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference TAB D, p. 10-7).

JUSTIFICATION/COMMENTS None

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS Assembled test specimen irradiated to 204 megarads.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes (Reference TAB D, p. 5-3).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 11 OF 37
 R 1 R _____
 BINDER TITLE EA 180 Series COMPUTED DRS DATE 6/13/86 JOH
Limit Switches Manufactured 5/17/89
After 7/30/80 CHECKED RNB DATE 6/27/86 HR
6/9/89

H. AGING (Continued)

(d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: TAB D, pp. 11-21, 10-7).

Plant normal ambient radiation dose (rd) 2×10^7 (worst case)
 Test exposure dose (rd) 204×10^6
 Test exposure dose rate (rd/hr) 0.91×10^6
 Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS None

(6) Vibration (non-seismic) Aging:

(a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program? Yes (Reference: TAB D, p. 10-7) |R1

JUSTIFICATION/COMMENTS Plant induced vibration simulation 1×10^6 cycles @100Hz at 0.75 g's per QTR 105 TAB D, p. 4-4, Section 4.5.5.

(b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, p. 5-3, Section 5.4).

JUSTIFICATION/COMMENTS None

(7) Operational Stress Aging:

(a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, p. 10-6).

JUSTIFICATION/COMMENTS None

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. |R1

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 12 OF 37
R 1 R _____
BINDER TITLE EA 180 Series COMPUTED DRS DATE 6/13/86 JDH
Limit Switches Manufactured 5/17/89
After 7/30/80 CHECKED RNB DATE 6/27/86 AKC
4/89

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? No (Reference: NA _____).

JUSTIFICATION/COMMENTS See Section P for additional discussion.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes - See next sheet for discussion.
(Reference: TAB D. pp 4-6 through 4-12 _____).

Qualified life (Document in QMDS) 40 years*

JUSTIFICATION/COMMENTS *Through periodic refurbishment as defined in EA 189-90051 (TAB D, p 4-3).

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: TAB D, pp 4-3.1, 4-3.2 _____).

|R1

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 13 OF 37
 BINDER TITLE EA180 SERIES LIMIT COMPUTED DMS DATE 6/13/86 R R
 SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RNB DATE 6/27/86

QUALIFIED LIFE (H8)

The qualified life for all equipment covered by this binder is 40 years through periodic refurbishment. The refurbishment schedule was determined by NAMCO's use of a very conservative 0.8eV activation energy. Figure 8 on page 4-12 of the test report (TAB D) shows the qualified life based on a 0.8eV activation energy for the various ambient temperatures. The scheduled maintenance service times in TAB D, page 4-3.1 and 4-3.2 (EA 189-90051) comes directly from this Arrhenius curve and are shown below:

<u>Max. Normal Ambient</u>	<u>Service Time</u>
104°F	20.6 years
110°F	15 years
120°F	9 years
130°F	5.5 years

The QMDS section found in TAB G, will document the limit switches which require refurbishment and the appropriate schedule.

BINDER NO. _____ PLANT _____ UNIT(S) _____ SHEET _____ OF _____
 EAL80 SERIES LIMIT R _____ R _____
 BINDER TITLE _____ COMPUTED MS DATE 6/13/80
 SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RWB DATE 6/27/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Ethylene/O-Ring Propylene/Shaft Seal</u>	<u>NA</u>	<u>NA</u>	<u>0.8eV See Comment</u>	<u>TAB D, p.4-9</u>
(b) <u>Silicone Rubber/Gasket</u>	<u>NA</u>	<u>NA</u>	<u>1.14eV See Comment</u>	<u>TAB D, p.4-9</u>
(c) <u>Grease/Lubricant</u>	<u>NA</u>	<u>NA</u>	<u>Unknown See Comment</u>	<u>TAB D, p.4-8</u>
(d) <u>Asbestos Filled Phenolic/ Contact Carrier and Block</u>	<u>NA</u>	<u>NA</u>	<u>(.99eV) 0.96eV See Comment</u>	<u>TAB D, p.4-8</u>
(e) <u>Aromatic Ether Based Oil/ Lubricant</u>	<u>NA</u>	<u>NA</u>	<u>Unknown See Comment</u>	<u>TAB D, p.4-8</u>

JUSTIFICATION/COMMENTS Namco has assumed an activation energy of 0.8eV for the elastomer portions of the limit switch. Based on 0.8eV, the qualified life of the EAL80 Series limit switch (mfg after 7/80) is 5.3 years at 55°C. The qualified life can be extended to 40 years through periodic refurbishment as defined by EAL89-90051 (TAB D, p. 4-3). The 0.8eV assumed activation energy for Ethylene Propylene is considered to be conservative based on a review of the Digital Data Base, other test reports, & EPRI NP-1558 (See TAB C(8)). Martin Marietta indicates an activation energy of 1.14 for silicones (TAB D, p. 4-9) that have been tested for 432.5 hours at 120°C. Therefore, these gaskets are capable of

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 15 OF 37
 BINDER TITLE EAL80 SERIES LIMIT COMPUTED D/les DATE 6/25/86 R R
 SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED R/B DATE 6/27/86

I. MATERIALS ANALYSIS (Continued)

withstanding both the required normal and abnormal conditions over the life of the plant. An activation energy for the lubricant was not required since greases are designed for high temperature applications and are typically rated for temperatures of at least 250°F (TAB D, p. 4-7). The qualified life of the lubricants will be controlled through maintenance procedures. In QTR 105 Namco has assigned an activation energy of 0.96eV to Asbestos-filled Phenolic (thermoset plastic). Based on an ambient temperature of 55°C and the test performed in QTR 105, the resultant life of the phenolic would be as follows:

(Arrhenius EQ.)
$$t_1 = t_2 \exp \left[\frac{\phi}{K} \left(\frac{1}{T_1} - \frac{1}{T_2} \right) \right]$$

Where t_1 = Life

t_2 = Test Time = 432.5 hours

ϕ = Activation energy = 0.96eV

k = Boltzmann's Constant = 8.617×10^{-5}

T_1 = Ambient Temp = 55°C = 328°K

T_2 = Test Temp = 120°C = 393°K

$t_1 = 13.58 \text{ years @ } 55^\circ\text{C}$

More recent IEEE-323-74 testing of this material, as documented in QTR 140 (See 11/4/85 telecon in TAB E(3)), demonstrated 1049 hours @ 120°C at an assigned activation energy of 0.99eV (See materials analysis in TAB C(17)). Using the above Arrhenius equation, the equivalent life would be 39 years @55°C. Therefore, the 20-year replacement schedule recommended by Namco (See maintenance instruction in TAB H) for switches exposed to temperatures greater than 50°C is reasonable and conservative.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 15a OF 37

R _____ R _____

BINDER TITLE EA 180 Series COMPUTED R1 JDA DATE 5/25/89

Limit Switches Manufactured

After 7/30/80

CHECKED R1 JDR DATE 6/9/89

I. MATERIALS ANALYSIS (Continued)

JUSTIFICATION/COMMENTS

Qualification Report QTR 155 supports the change of contact block/ carrier material from Asbestos-filled Phenolic to glass-filled Phenolic for the contact block and Poly (Amide-Imide) for the carrier. This test report provides a comprehensive comparison of the physical properties between the old and new material and concludes that both new materials (RX865 glass-filled Phenolic and Torlon 4203L Poly) either meet or exceed the capabilities of the old Asbestos-filled Phenolic material (RX490). We agree with this conclusion and find replacement parts made from these materials and new switches containing these materials acceptable for use. All switches and replacement parts shipped after November, 1986 will be made from these materials.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 16 OF 37
BINDER TITLE EAL80 SERIES LIMIT COMPUTED JRS DATE 6/26/80 R R
SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RNB DATE 6/27/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference TAB D, p 11-27).

Identify Acceptance Criteria: See TAB D, Section 7.0, page 11-27.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference TAB D, p 11-15, Sect 6.2).

Identify baseline and functional testing: See TAB D, p 11-16, Sect 6.2.1 and p 11-17, Sect 6.2.2.

JUSTIFICATION/COMMENTS None

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference TAB D, p 10-50).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 17 OF 37

R 1 R _____

BINDER TITLE EA 180 Series COMPUTED DRS DATE 6/25/86 JDH

Limit Switches Manufactured 5/25/89

After 7/30/80 CHECKED RNB DATE 6/27/86 JDR

6/4/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____
TAB D, pp 5-1 through 5-3).

JUSTIFICATION/COMMENTS None

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>NA</u>	<u>NA</u>
Load	<u>NA</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		
Insulation Resistance		
Minimum	<u>NA</u>	<u>NA</u>
Closed Contact open less than 2 milli-sec during seismic test	<u>NA</u>	<u>NA</u>

R1

JUSTIFICATION/COMMENTS See Comment J(5)(c)

(b) Parameter	Specific Accident Conditions	Reference
Voltage	<u>See Comment</u>	<u>NA</u>
Load	<u>See Comment</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		
Insulation Resistance		
Minimum	<u>See Comment</u>	<u>NA</u>
Closed Contact open less than 2 milli-sec during seismic test	<u>See Comment</u>	<u>NA</u>

R1

JUSTIFICATION/COMMENTS See Comment J(5)(c)

R1

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 37
 R 1 R _____
 BINDER TITLE EA 180 Series COMPUTED DRS DATE 6/27/86 JDH
Limit Switches Manufactured 5/25/89
After 7/30/80 CHECKED RNB DATE 6/27/86 JDK
6/9/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>	(R1)
Voltage	<u>125V AC/DC</u>	<u>TAB D, p 3-4</u>	
Load	<u>0.5 amp/100VDC</u> <u>0.086 amp/100VDC</u>	<u>TAB D, pp 10-43, 7-1, Section 7.1</u>	
Frequency	<u>NA</u>	<u>NA</u>	
Accuracy	<u>NA</u>	<u>NA</u>	
<u>Other(s)</u> Insulation Resistance	<u>≥ 5 M OHM</u>	<u>TAB D, pp 10-41, 10-45, 10-50</u>	
Contact Opening	<u>< 2 milli-sec</u>	<u>TAB D, p 7-1, Section 7.1</u>	

JUSTIFICATION/COMMENTS The typical application of these limit switches is in control circuits, for example solenoid valves. These circuits operate at 120VAC or 125VDC with current ratings of approximately 0.3 to 1.3 amps. This is well within the UL and nameplate ratings of 20 amps @ 125VAC and 5 amps @ 125VDC. The demonstrated load of 0.5 amps @ 100VDC for mechanical aging and 0.086 amps @ 100VDC for all other performance tests is considered adequate for the following reasons: (1) Low voltage and currents may not break down the film/oxide and therefore provide little contact surface renewal.

R1

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 18a OF 37

R 1 R

BINDER TITLE EA 180 Series COMPUTED R1 JDH DATE 5/17/89

Limit Switches Manufactured
After 7/30/80 CHECKED R1 JDR DATE 6/9/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

JUSTIFICATION/COMMENTS (CONTINUED)

- (2) When switches are operated at rated voltage and currents, the contact surfaces tend to be self-cleaning and/or the potential of the circuit is sufficient to break down films or oxides that might form on the contact faces. While there are no plant specific requirements with regard to contact bounce and insulation resistance minimum, the values demonstrated are considered adequate. At 5M ohms, there would be a slight leakage current of approximately 0.025 milliamps for a typical 125V circuit. This small leakage current should not provide enough amperage to cause any adverse circuit operation.
- (3) Since TVA's standard design practices prevent circuits from exceeding the UL ratings of contacts, the 100VDC and 0.086 amp load used for testing is conservative and adequate considering items (1) and (2) above.

WBNEQ-IZS-001

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-19 R1 was deleted per revision 2.
WBEP-0158Q

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 20 OF 37
 R 1 R
 BINDER TITLE EA 180 Series COMPUTED DRS DATE 6/25/86 JDH
Limit Switches Manufactured 5/17/89
After 7/30/80 CHECKED RNB DATE 6/27/86 JHR
6/9/89

K.2 REQUIRED OPERATING ENVIRONMENT Room 737.0-A5

Reference Environmental Drawing No. 47E235-48 |R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104 (a) Temperature (°F) 110

(b) Pressure (psig) ATM(-) (b) Pressure (psig) ATM(-)

(c) Humidity (%) 80 (c) Humidity (%) 90

(d) Radiation (rd) 8.8×10^5 (d) Radiation (rd) NA |R1

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. (Effect on qualified life is negligible. See generic position in Binder No. WBNEQ-GEN-001).

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 110 Accident type LOCA

(b) Pressure (psig) NA Accident type NA

(c) Humidity (%) NA Accident type NA

(d) Radiation (rd) 1.2×10^8 Accident type LOCA |R1

(e) Spray Type NA Accident type NA

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 21 OF 37
R 1 R _____
BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 JDA
Limit Switches Manufactured 5/17/87
After 7/30/80 CHECKED RNB DATE 8/14/86 JOR
6/9/87

K.3 REQUIRED OPERATING ENVIRONMENT Room 713.0-A6

Reference Environmental Drawing No. 47E235-56 |R1

- (1) Normal Max (2) Abnormal Max
- | | |
|--|-----------------------------------|
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>2.2x10⁶</u> | (d) Radiation (rd) <u>NA</u> R1 |
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. (Effect on qualified life is negligible. See generic position in Binder No. WBNEQ-GEN-001).
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|--|-------------------------------|
| (a) Temperature (°F) <u>110</u> | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>NA</u> | Accident type <u>NA</u> |
| (c) Humidity (%) <u>NA</u> | Accident type <u>NA</u> |
| (d) Radiation (rd) <u>2 x 10⁶</u> | Accident type <u>LOCA</u> R1 |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 22 OF 37
 R 1 R
 BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 JDH
Limit Switches Manufactured 6-9-89
After 7/30/80 CHECKED RNB DATE 8/14/86 JHK
6/9/89

K.4 REQUIRED OPERATING ENVIRONMENT Room 713.0-A28

Reference Environmental Drawing No. 47E235-61 |R1

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>7.5x10⁶</u> | (d) Radiation (rd) <u>NA</u> R1 |

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. (Effect on qualified life is negligible. See generic position in Binder No. WBNEQ-GEN-001).

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|---|-------------------------------|
| (a) Temperature (°F) <u>110</u> | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>NA</u> | Accident type <u>NA</u> |
| (c) Humidity (%) <u>NA</u> | Accident type <u>NA</u> |
| (d) Radiation (rd) <u>5 x 10⁶*</u> | Accident type <u>LOCA</u> R1 |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

* Worst case per WBNNAL3-022 (OE Calculation). See TAB C(13). |R1

WBNEQ-IZS-001

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-23 R1 was deleted per revision 2.

WBEP-0158Q

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 24 OF 37
R 1 R 2
BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 JDH
Limit Switches Manufactured 5/17/89 JDH
After 7/30/80 CHECKED RNB DATE 8/14/86 HDR wes
6/9/89 12/14/89

K.6 REQUIRED OPERATING ENVIRONMENT Room 757.0-A16

Reference Environmental Drawing No. 47E235-78

- | | |
|--|---------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM</u> | (b) Pressure (psig) <u>ATM</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>1.8x10³</u> | (d) Radiation (rd) <u>NA</u> |
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Maximum and minimum abnormal temperatures could exist for up to eight hours per excursion and will occur less than 1% of the plant life. Maximum abnormal temperatures could exist for up to 10 hours "per month during" 4 months of the year because of the EGTS units being operated for testing and maintenance.
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|---|--------------------------------|
| (a) Temperature (°F) <u>110</u> | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>NA</u> | Accident type <u>NA</u> |
| (c) Humidity (%) <u>NA</u> | Accident type <u>NA</u> |
| (d) Radiation (rd) <u>< 1.7 x 10⁷ *</u> | Accident type <u>LOCA</u> R2 |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

* See TAB C (2)

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 25 OF 37
R 1 R
BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/15/86 JDM
Limit Switches Manufactured 5/17/89
After 7/30/80 CHECKED RNB DATE 8/15/86 HOK
6/9/89

K.7 REQUIRED OPERATING ENVIRONMENT ANN

Reference Environmental Drawing No. 47E235-44 |R1

- (1) Normal Max (2) Abnormal Max
- (a) Temperature (°F) 110 (a) Temperature (°F) 120
- (b) Pressure (psig) ATM(-) (b) Pressure (psig) ATM(-)
- (c) Humidity (%) 80 (c) Humidity (%) 90
- (d) Radiation (rd) 1 x 10⁶ (d) Radiation (rd) NA |R1
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. (Effect on qualified life is negligible. See generic position in Binder No. WBNEQ-GEN-001).
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- (a) Temperature (°F) 133.7 Accident type LOCA |R1
- (b) Pressure (psig) ATM(-) Accident type LOCA
- (c) Humidity (%) 61 Accident type LOCA |R1
- (d) Radiation (rd) 1.2x10⁷ gamma
6x10⁶ beta Accident type LOCA |R1
- (e) Spray Type NA Accident type NA

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 26 OF 37
 R 1 R
 BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 JDH
Limit Switches Manufactured 5/17/89
After 7/30/80 CHECKED RNB DATE 8/14/86 ZDR
6/4/89

K.8 REQUIRED OPERATING ENVIRONMENT L-Lower Containment

Reference Environmental Drawing No. 47E235-42 | R1

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>120</u> | (a) Temperature (°F) <u>130</u> |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>100</u> |
| (d) Radiation (rd) <u>2x10⁷</u> | (d) Radiation (rd) <u>NA</u> R1 |
| (3) Process Interfaces: <u>None</u> | |

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.
(Effect on qualified life is negligible. See generic position in binder WBNEQ-GEN-001).

- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|--|--------------------------------|
| (a) Temperature (°F) <u>327</u> | Accident type <u>LOCA/HELB</u> |
| (b) Pressure (psig) <u>11.2</u> | Accident type <u>LOCA/HELB</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| | <u>4.7x10⁸ beta</u> |
| (d) Radiation (rd) <u>4x10⁷ gamma</u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>*</u> | Accident type <u>LOCA/HELB</u> |

* 0.19 molar H₃BO₃ (2000 PPM Boron), 0.033 molar NaOH resulting in a pH of 8.3 at 25°C. Spray duration is 30 days, at a flow rate equal to 0.92 GPM per square foot of containment cross section.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 27 OF 37
 R 14 R 2
 BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 LBA
Limit Switches Manufactured 11/6/90
After 7/30/80 CHECKED RNB DATE 8/14/86 JDH
11/7/90

K.9 REQUIRED OPERATING ENVIRONMENT North and South Valve Rooms

Reference Environmental Drawing No. 47E235-76

- | | |
|---|---------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>130</u> | (a) Temperature (°F) <u>140</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM</u> |
| (c) Humidity (%) <u>50%</u> | (c) Humidity (%) <u>100%</u> |
| (d) Radiation (rd) <u>1.8x10³ North</u>
<u>1.8x10³ South</u> | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal temperature conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life. The abnormal humidity of 10% will occur simultaneously with abnormal maximum temperature of 140°F. The humidity conditions could exist for up to 8 hours and will return to the normal maximum of 50%. (Effect on qualified life is negligible. See generic position in binder WBNEQ-GEN-001).

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | | |
|---|---------------------------|----|
| * (a) Temperature (°F) <u>*453</u> | Accident type <u>MSLB</u> | R4 |
| (b) Pressure (psig) <u>8.77 North</u>
<u>10.78 South</u> | Accident type <u>FW</u> | |
| (c) Humidity (%) <u>100%</u> | Accident type <u>FW</u> | |
| (d) Radiation (rd) <u>< 1 x 10⁴</u> | Accident type <u>LOCA</u> | |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> | |

* - Per QIR MNMWB90032 R0

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): For a cross-reference of equipment to environmental drawing see TAB G.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: See TAB G for the limit switches requiring conduit seals). R4

(7) Subject to submergence (Yes/No/NA)? No* (Reference: TAB C (10)).

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: Environmental Drawing 47E235-42).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

See Section P(3) this TAB.

(9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Section A</u>	_____
_____	_____
_____	_____

* All devices located in the valve vault rooms have been verified to be above the maximum possible flood levels.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 29 OF 37
R 1 R 4
BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 JDH KBN
Limit Switches Manufactured 6/9/89 11/6/90
After 7/30/80 CHECKED RNB DATE 8/14/86 HDR JDH
6/9/89 11/7/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u> ***453(MSLB)	<u>30 days</u>	<u>TAB C(4)</u> R4
Temperature (°F)	<u>327</u>	<u>391</u>	<u>TAB D, p 10-14</u>
Pressure (psig)	<u>12.0</u>	<u>119</u>	<u>TAB D, p 10-14</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>TAB D,</u> <u>pp 10-9, 10-51</u>
Chemical Spray*	<u>TAB C(3)</u>	<u>TAB C(3)</u>	<u>TAB D,</u> <u>pp 10-9, 10-51</u>
	<u>4.7x10⁸ beta</u>		<u>beta-see P(3)</u>
Radiation (rd)**	<u>6x10⁷ gamma</u>	<u>2.04x10⁸ gamma</u>	<u>TAB D, p 10-5</u>
Submergence	<u>NA</u>	<u>NA</u>	<u>NA</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

***See TAB C(4)

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>TAB C</u>
Pressure	<u>Yes</u>	<u>See L(1)</u>
Relative Humidity	<u>Yes</u>	<u>See L(1)</u>
Chemical Spray	<u>Yes</u>	<u>TAB C</u>
Submergence	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS See TAB C(4) for comparison of test profiles and WBN accident profile and demonstration of 100 days operability (accident degradation equivalency calculation). R4

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 30 OF 37
 R 4 R _____
 BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 KBN
Limit Switches Manufactured 11/6/90
After 7/30/80 CHECKED RNB DATE 8/14/86 JOH
11/7/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins Per IEEE-323(74)</u>	<u>Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>+64</u> <u>+892%</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>(107 psig)</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>10%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>TAB C(4)</u>	<u>Tab C(4) R4</u>
Voltage: ± 10% of rated value	<u>NA</u>	<u>NA</u>
Frequency: ± 5% of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>2 Dwells</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>317% - See</u> <u>Comments</u>	<u>Yes</u>

JUSTIFICATION/COMMENTS: Per TVA standard specification SS-E18.12.10, Seismic Requirements for Category I Electrical and I&C Equipment, these limit switches should be tested to 3 g's horizontal and 2 g's vertical. Since Namco verified in App. C of their report (TAB D, pp 10-35 through 10-39) that cross-coupling was not significant, the single axis test performed in each of the 3 axis to 9.52 g's was more than adequate.

The applied margin to the maximum accident temperatures is acceptable since the initial transient and the peak temperature were applied twice. Reference: NUREG-0588, Revision 1, Part II, Comment No. 73, pages II-38 and II-39, and IEEE 323-1983, pages 18 and 19.

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference See TAB A).

JUSTIFICATION/COMMENTS None

- (2) Did the equipment performs its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes -

See comment (Reference TAB D, p. 7-1, Section 7.1).

JUSTIFICATION/COMMENTS One failure to transfer was recorded.

Namco believes this may have been aggravated by the test

set-up. See TAB D, page 7-1, Section 7.2.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)?
Yes (Reference TAB D, p. 10-10).

JUSTIFICATION/COMMENTS None

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference See TAB C(4)).

JUSTIFICATION/COMMENTS See TAB C(4) for additional comments.

R4

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes
(Reference TAB C(6)).

JUSTIFICATION/COMMENTS See TAB C(6) for additional comments.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 32 OF 37
BINDER TITLE EAI 80 SERIES LIMIT COMPUTED Yes DATE 8/14/80 R R
SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RAB DATE 8/14/80

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS SEE QMDS- TAB G

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 33 OF 37
 BINDER TITLE EAL80 SERIES LIMIT COMPUTED DPG DATE 8/14/86 R R
 SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RNB DATE 3/14/86

0. SUMMARY OF REVIEW

- | | |
|--|---|
| (1) Documented evidence of qualification adequate
(Have all assumptions, mathematical models, and
all extrapolations of test data used in an
analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary)
taken to the specified qualification level
adequately justified? | <u>NA</u> |
| (3) Choice of qualification methodology adequately
justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements
identified? | <u>NA</u> |
| (b) Were specific features and failure modes and
effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used
together with appropriate justification for
their use? | <u>NA</u> |
| (d) Were environmental parameters which affect
equipment performance identified? | <u>NA</u> |
| (5) Adequate similarity between equipment and test
specimen established? | <u>YES</u> |
| (6) Aging degradation evaluated adequately? | <u>YES</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>YES</u> |
| (b) Equipment aged to end of life condition prior to
application of DBE conditions? | <u>YES</u> |
| (c) Absence of preaging in test/analysis justified? | <u>NA</u> |
| (d) Materials susceptible to thermal/radiation
aging identified? | <u>YES-Section I
& TAB C(8)</u> |

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 34 OF 37
 BINDER TITLE EAL 80 SERIES LIMIT COMPUTED DPZ DATE 8/14/80 R R
 SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RNB DATE 8/14/80

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	See Section P(2) <u>YES</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u> <u>See TAB C(3)</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEO-IZS-001 PLANT WBN UNIT(S) 1 SHEET 35 OF 37
R 4 R _____
BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 KAN
Limit Switches Manufactured 11/6/90
After 7/30/80 CHECKED RNB DATE 8/14/86 JDH
11/7/90

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>NA</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes-See TAB C(4)</u> R4
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes-See TAB C(18)</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION 1. AGING - SECTION H(7)(b) - This device was subject to 100,200 actuation cycles during mechanical aging testing. This is equivalent to an average of 208 actuations per month or approximately 7 actuations per day over the 40 year life of the plant. This is judged to be in excess of the full open/close actuation cycles the associated valves will be required to operate for normal plant (cont. on next page)

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 36 OF 37
R 1 R _____
BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 JOH
Limit Switches Manufactured 6/9/89
After 7/30/80 CHECKED RNB DATE 8/14/86 JHR
6/9/89

P. DISCUSSION (Continued)

operation, surveillance, and maintenance. Therefore, the mechanical aging performed is adequate to demonstrate qualification over the 40 year life of the plant.

2. 0(6)(e) - This device operates intermittently at relatively low voltages and currents which will not result in significant heat rise.

5. 0(12)(b) Beta dose is not required to be considered since this device is housed in a sealed metal enclosure which will prevent the passage of beta radiation through it and the entrance of beta - emitting particles into it.

3. Per TVA Drawing 47E235-42 (Lower Compartment), the unattenuated free field post-LOCA beta radiation dose contribution for inside primary containment is 4.7×10^8 rads. The limit switch internals will not, however, be subject to the unattenuated free field beta dose. The switch housing assembly consists of three rectangular parts; the Bronwite alloy housing body (a corrosion resistant bronze casting alloy) and top and bottom stainless steel covers which are tightly bolted together. The minimum thickness is 1/8". Silicone rubber gaskets 0.060" thick are compressed between the housing and top and bottom covers at 20-inch pounds, creating a completely sealed unit that is water, oil, dust, and pressure tight, meeting NEMA type 1, 4, and 13 requirements. Also, all limit switches inside primary containment include a qualified seal. Therefore, all beta radiation sources will be external to the housing and subject to dose attenuation due to the housing. The beta dose to the switch internals will essentially be attenuated completely by a factor of 0.009 due to the minimum metal thickness (reference TVA Calculation No. GENNAL3-002, TAB C, Section 19). The gap created by the gasket is sufficiently small to allow only a negligible fraction of the unattenuated 4-pi geometry free field dose to penetrate. However, as a conservatism to account for the gap (without taking credit for attenuation due to the silicone gasket), 10% of the unattenuated free field dose is added to the dose attenuated by the metal housing. Therefore, the 100-day beta dose to the switch internals is conservatively estimated to be: 10% unattenuated contribution = $0.10 (4.7 \times 10^8) = 4.7 \times 10^7$, 100% attenuated contribution = $0.009 (4.7 \times 10^8) = 4.23 \times 10^6$. Total = 5.12×10^7 rads beta.

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 37 OF 37
R 1 R _____
BINDER TITLE EA 180 Series COMPUTED DRS DATE 8/14/86 JDA
Limit Switches Manufactured 6-9-89
After 7/30/80 CHECKED RNB DATE 8/14/86 HR
6/9/89

P. DISCUSSION (Continued)

Additionally, the silicone gaskets themselves are not a concern. They receive significant geometric shielding due to being tightly compressed between the metal housing parts. Based on the switch geometry, the outer gasket material will be exposed to only a fraction of the unattenuated 4-pi geometry free field beta radiation dose. This unattenuated dose would be further reduced due to the angle of incidence into the narrow gap and attenuation due to the outer gasket material resulting in minimal dose to the innermost gasket material. The gasket width is approximately equal to the housing thickness (1/8 inch). Also, Target Rock Corp. has conducted tests on a similar silicone rubber gasket used in a similar application (reference EQ Binder WBNEQ-SOL-001, Section D, page D-29) and found that after exposure to 185 megarads of gamma radiation,

BINDER NO. WBNEQ-IZS-001 PLANT WBN UNIT(S) 1 SHEET 37A OF 37
BINDER TITLE EAL80 SERIES LIMIT COMPUTED JMS DATE 8/14/80 R R
SWITCHES MANUFACTURED AFTER 7/30/80 CHECKED RMB DATE 8/14/86

P. DISCUSSION (Continued)

embrittlement had occurred in the excess gasket material extending
beyond the mated parts. The gasket material actually trapped between
the mated parts was still flexible. Likewise, in our application,
the gaskets would not be a concern even should they become brittle
due to their being tightly sandwiched between the housing and housing
covers in a static application; especially considering that the outer
part of the gasket (least important) would exhibit the more significant
degradation. The limit switches also contain EPDM O-rings used for
screw gaskets and the operating shaft seal. These O-rings are enclosed
by the metal screws and shaft housing which shields them from the
effects of beta radiation.

In conclusion: The total combined beta and gamma radiation dose will
equal 9.12×10^7 rads TID (5.12×10^7 beta + 4.0×10^7 gamma) for
accident conditions. The accident radiation plus the large lower
compartment 40-year dose of 2.0×10^7 rads equals a total radiation
dose of 1.1×10^8 rads TID. These switches were tested to 2.04×10^8
rads which envelops our plant requirements. Therefore, they are
qualified for our worst case gamma and beta radiation dose.

PAGE B-38

BINDER NO. <u>WBNEQ-IZS-002</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>1</u> OF <u>1</u>
BINDER TITLE <u>EA180 SERIES LIMIT</u>		COMPUTED <u>R1/JWH</u>	DATE <u>9/28/89</u>
LIMIT SWITCHES MANUFACTURED BETWEEN <u>5/78 and 7/20/80</u>		CHECKED <u>R1/WCG</u>	DATE <u>9/28/89</u>
			<u>WCG</u> <u>7/23/90</u>
			<u>JDK</u> <u>7/23/90</u>

IZS-002

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building.
2. See Page B-1 for source of Category and Operating Time assignments.
3. A phase "A" containment isolation will cause the associated FCV to close. The limit switches must then open and remain open preventing solenoid reenergization and valve opening upon phase "A" containment isolation reset. This limit switch position indication is a PAM B1 variable and must be monitored to verify that containment isolation integrity is maintained for the duration of each event.

R2

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-IZS -002
 MANUFACTURER : NAMCO
 PAGE 1 OF 8

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-1-ZS -061-0097A -B 1-FCV -061-0097/ZS1 -B 300 INLET ISLN VALVE REACTOR BLDG POS SW	EA180-15302		772' 10" UC 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	VLV POS IND IS A PAM B1 VARIB AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -061-0097B -B 1-FCV -061-0097/ZS2 -B 300 INLET ISLN VALVE REACTOR BLDG POS SW	EA180-15302		772' 5" UC 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	VLV POS IND IS A PAM B1 VARIB AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -061-0122A -B 1-FCV -061-0122/ZS1 -B 300 OUTLET ISLN VALVE REACTOR BLDG POS SW	EA180-15302		776' 2" UC 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	VLV POS IND IS A PAM B1 VARIB AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -061-0122B -B 1-FCV -061-0122/ZS2 -B 300 OUTLET ISLN VALVE REACTOR BLDG POS SW	EA180-15302		775' 9" UC 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	VLV POS IND IS A PAM B1 VARIB AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -061-0192A -B 1-FCV -061-0192/ZS1 -B 294 GLYCOL SUP ISLN VALVE POS SW	EA180-15302		807' 7" UC 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	VLV POS IND IS A PAM B1 VARIB AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT TO VERIFY CONTAINMENT INTEGRITY.

PAGE A-2 R2

PREPARER/DATE D.R.S. 9/8/86 R 1 JWH R 2 WCG R ---
 CHECKED/DATE N.A.P. 9/18/86 9-28-89 5-23-90
WCG JOK
9-28-89 7/23/90

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-IZS -002
 MANUFACTURER : NAMCO
 PAGE 2 OF 8

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) RM/RAD CONTRACT				
WBN-1-ZS -061-0192B -B GLYCOL SUP ISLN VALVE POS SW	1-FCV -061-0192/ZS2 -B 294 EA180-15302		807' 1" UC 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	VLV POS IND IS A PAM B1 VARIB AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -061-0194A -B GLYCOL RETURN ISLN VALVE POS SW	1-FCV -061-0194/ZS1 -B 300 EA180-15302		810' 3" UC 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	VLV POS IND IS A PAM B1 VARIB AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -061-0194B -B GLYCOL RETURN ISLN VALVE POS SW	1-FCV -061-0194/ZS2 -B 300 EA180-15302		809' 9" UC 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	VLV POS IND IS A PAM B1 VARIB AND MUST BE MONITORED FOR THE DURATION OF EACH EVENT TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -062-0072A -A REGEN HTX LETDOWN ISOLATION VLV	1-FCV -062-0072A/ZS1 -A 047 EA180-31302		704' 6" RW	A A A A A	5MIN 5MIN 5MIN 15MIN 1HR	L MS/C FW/C RH/C CV/C	LS POS IND IS A PAM B1 AND D2 VARIABLE AND MUST BE MONITORED TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -062-0072B -A REGEN HTX LETDOWN ISOLATION VLV	1-FCV -062-0072B/ZS2 -A 047 EA180-31302		704' 3" RW	A A A A A	5MIN 5MIN 5MIN 15MIN 1HR	L MS/C FW/C RH/C CV/C	LS POS IND IS A PAM B1 AND D2 VARIABLE AND MUST BE MONITORED TO VERIFY CONTAINMENT INTEGRITY.

PAGE A - 3 R2

PREPARER/DATE D.R.S. 9/8/86 R 1 JWH R 2 WCB R _____
 9-28-89 7-23-90
 CHECKED/DATE N.A.P. 9/8/86 WCG JDH
 9-28-89 7/23/90

PRINT DATE: 07/07/90

BINDER NO.: WBNEQ-IZS -002
 MANUFACTURER: NAMCO
 PAGE 3 OF 8

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-ZS -062-0073A -A REGEN HTX LETDOWN ISOLATION VLV	1-FCV -062-0073A/ZS1 -A 047 EA180-31302		704' 8"	RW	A A A A	5MIN 5MIN 15MIN 1HR	L MS/C FW/C RH/C CV/C	LS POS IND IS A PAM B1 AND D2 VARIABLE AND MUST BE MONITORED TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -062-0073B -A REGEN HTX LETDOWN ISOLATION VLV	1-FCV -062-0073B/ZS2 -A 047 EA180-11302		704' 3"	RW	A A A A	5MIN 5MIN 15MIN 1HR	L MS/C FW/C RH/C CV/C	LS POS IND IS A PAM B1 AND D2 VARIABLE AND MUST BE MONITORED TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -062-0074A -A REGEN HTX LETDOWN ISOLATION VLV	1-FCV -062-0074A/ZS1 -A 050 EA180-11302		704' 6"	RW	A A A A	5MIN 5MIN 15MIN 1HR	L MS/C FW/C RH/C CV/C	LS POS IND IS A PAM B1 AND D2 VARIABLE AND MUST BE MONITORED TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -062-0074B -A REGEN HTX LETDOWN ISOLATION VLV	1-FCV -062-0074B/ZS2 -A 050 EA180-31302		704' 4"	RW	A A A A	5MIN 5MIN 15MIN 1HR	L MS/C FW/C RH/C CV/C	LS POS IND IS A PAM B1 AND D2 VARIABLE AND MUST BE MONITORED TO VERIFY CONTAINMENT INTEGRITY.
WBN-1-ZS -063-0071A -A SIS CHECK VALVE LEAKTEST ISLN POS SW	1-FCV -063-0071/ZS1 -A 290 EA180-31302		721' 5"	AC4	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	PHASE A CNTMT ISO CAUSES ASSOC FCV TO CLOSE. LS OPENS & REMAINS OPEN PREVENTING SOL REENERGIZATION & VLV OPENING ON PHASE A CNTMT ISO RESET.

PAGE A-4 R2

PREPARER/DATE D.R.S. 9/8/86 R 1 R 2 R
 CHECKED/DATE N.A.P. 9/8/86 JWH WCG
 9-28-89 7-23-90 7-23-90 7/23/90

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-IZS -002
 MANUFACTURER : NAMCO
 PAGE 4 OF 8

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) RM/RAD				
WBN-1-ZS -063-0071B -A 1-FCV -063-0071/ZS2 -A 290 SIS CHECK VALVE LEAKTEST ISLN POS SW	EA180-31302		721' 6" AC4	79K3-824495-1	A	100D	L PHASE A CNTMT ISO CAUSES ASSOC MS/C FCV TO CLOSE. LS OPENS & FW/C REMAINS OPEN PREVENTING SOL RH/C REENERGIZATION & VLV OPENING CV/C ON PHASE A CNTMT ISO RESET.
					A	100D	
					A	100D	
					A	1MO	
					A	1MO	
WBN-1-ZS -063-0072A -A 1-FCV -063-0072/ZS1 -A CNTMT SUMP TO RHR PUMP A-A VLV LIMIT SW	EA180-12302		685' A07'	79K3-824495-1	A	100D	L PROVIDE INTERLOCK TO ALLOW RHR RH/A SPRAY HDR VLVS TO BE MANUALLY AB OPENED. MUST RETAIN POS FOR AF 30D MUST NOT FAIL SUCH THAT CV/A RHR SPRAY HDR CAN'T BE OPENED.
					A	1MO	
					A	1MO	
					A	1MO	
					A	1MO	
WBN-1-ZS -063-0072B -A 1-FCV -063-0072/ZS2 -A CNTMT SUMP TO RHR PUMP A-A VLV LIMIT SW	EA180-12301		685' A07'		A	100D	L PROVIDE INTERLOCK TO ALLOW RHR RH/A SPRAY HDR VLVS TO BE MANUALLY AB OPENED. MUST RETAIN POS FOR AF 30D. MUST NOT FAIL SUCH THAT CV/A RHR SPRAY HDR CAN'T BE OPENED.
					A	1MO	
					A	1MO	
					A	1MO	
					A	1MO	
WBN-1-ZS -063-0073A -B 1-FCV -063-0073/ZS1 -B CNTMT SUMP TO RHR PUMP B-B VLV LIMIT SW	EA180-12302		685' A07'	79K3-824495-1	A	100D	L PROVIDE INTERLOCK TO ALLOW RHR RH/A SPRAY HDR VLVS TO BE MANUALLY AB OPENED. MUST RETAIN POS FOR AF 30D. MUST NOT FAIL SUCH THAT CV/A RHR SPRAY HDR CAN'T BE OPENED.
					A	1MO	
					A	1MO	
					A	1MO	
					A	1MO	
WBN-1-ZS -063-0073B -B 1-FCV -063-0073/ZS2 -B CNTMT SUMP TO RHR PUMP B-B VLV LIMIT SW	EA180-12302		685' A07'	79K3-824495-1	A	100D	L PROVIDE INTERLOCK TO ALLOW RHR RH/A SPRAY HDR TO BE MANUALLY AB OPENED. MUST RETAIN POS FOR AF 30D. MUST NOT FAIL SUCH THAT CV/A RHR SPRAY HDR CAN'T BE OPENED.
					A	1MO	
					A	1MO	
					A	1MO	
					A	1MO	

PAGE A-5 R2

PREPARER/DATE D.R.S. 9/8/86 R 1 JWH R 2 WCP R ---
 9-28-89 7-23-93
 CHECKED/DATE N.A.P. 9/8/86 WCG IDH
 9-28-89 7/23/90

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-IZS -002
 MANUFACTURER : NAMCO
 PAGE 5 OF 8

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>RM/RAD</u> <u>CONTRACT</u>	<u>CAT</u> <u>(2)</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-ZS -068-0308A -B RCS FLOW CNTL VALVE WDS GA TO PRT POS SW	1-FCV -068-0308/ZS1 -B 317 EA180-11302		724° 4" AC4 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	SEE NOTE 3.
WBN-1-ZS -068-0308B -B RCS FLOW CNTL VALVE WDS GA TO PRT POS SW	1-FCV -068-0308/ZS2 -B 317 EA180-11302		723° AC4 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	SEE NOTE 3.
WBN-1-ZS -072-0044 -A CNTMT SMP TO HDR A FCV STEM SW	1-ZS -072-0044 -A EA180-12302		685° A07'	A/B B B B B	1WK/100D 30D 30D 30D 30D	L RH/A CV/A AF AB	LS PROVIDES INTERLOCKS WHICH PREVENT THE OPENING OF THE FCV LS MUST NOT FAIL IN ORDER TO PREVENT INADVERTENT DRAINING OF THE RWST TO CNMT SUMP.
WBN-1-ZS -072-0045 -B CNTMT SMP TO HDR B FCV STEM SW	1-ZS -072-0045 -B EA180-12302		685° A07' 79K3-824495-1	A/B B B B B	1WK/100D 30D 30D 30D 30D	L RH/A CV/A AF AB	LS PROVIDES INTERLOCKS WHICH PREVENT THE OPENING OF THE FCV LS MUST NOT FAIL IN ORDER TO PREVENT INADVERTENT DRAINING OF THE RWST TO CNMT SUMP.
WBN-1-ZS -077-0009A -B RCDT PUMP DISCH FLOW CNTL VLV LIMIT SW	1-FCV -077-0009/ZS1 -B 280 EA180-15302		724° 1" AC4 79K3-824495-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	SEE NOTE 3.

PAGE A-6 R2

PREPARER/DATE D.R.S. 9/8/86 R 1 R 2 R
 CHECKED/DATE N.A.P. 9/8/86 JWH WCG
 9-28-89 7/23/90
 WCG JOH
 9-28-89 7/23/90

PRINT DATE: 07/07/90

BINDER NO.: WBNEQ-IZS -002
 MANUFACTURER: NAMCO
 PAGE 6 OF 8

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION	
			ELEV(1)	RM/RAD					
WBN-1-ZS -077-0009B -B RCDT PUMP DISCH FLOW CNTL VLV LIMIT SW	1-FCV -077-0009/ZS2 -B 280 EA180-15302		723' 8"	AC4	79K3-824495-1	A	100D	L	SEE NOTE 3.
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
						A	1MO	CV/C	
WBN-1-ZS -077-0016A -B RCDT TO GAS ANALYZER FLOW CNTL VLV LS	1-FCV -077-0016/ZS1 -B 285 EA180-15302		718' 8"	AC4	79K3-824495-1	A	100D	L	SEE NOTE 3.
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
						A	1MO	CV/C	
WBN-1-ZS -077-0016B -B RCDT TO GAS ANALYZER FLOW CNTL VLV LS	1-FCV -077-0016/ZS2 -B 285 EA180-15302		718' 3"	AC4	79K3-824495-1	A	100D	L	SEE NOTE 3.
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
						A	1MO	CV/C	
WBN-1-ZS -077-0018A -B RCDT TO VENT HDR FLOW CNTL VLV LIMIT SW	1-FCV -077-0018/ZS1 -B 280 EA180-15302		723' 9"	AC4	79K3-824495-1	A	100D	L	SEE NOTE 3.
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
						A	1MO	CV/C	
WBN-1-ZS -077-0018B -B RCDT TO VENT HDR FLOW CNTL VLV LIMIT SW	1-FCV -077-0018/ZS2 -B 280 EA180-15302		723' 4"	AC4	79K3-824495-1	A	100D	L	SEE NOTE 3.
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
						A	1MO	CV/C	

PAGE A-7 R2

PREPARER/DATE D.R.S. 9/8/86 JWH WCG
 9-28-89 7-23-90
 CHECKED/DATE N.A.P. 9/8/86 JWH JWH
 9-28-89 7/23/90

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-IZS -002
 MANUFACTURER : NAMCO
 PAGE 7 OF 8

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1) CONTRACT	RM/RAD				
WBN-1-ZS -090-0108 -B 1-FCV -090-0108/ZS -B 296 CNTMT BLDG LWR COMPT MON ISLN VLV POS SW EA180-14302			736'	1"	AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	CNTMT VENT ISO SIG WILL CAUSE ASSOC FCV TO CLOSE. THE LS MUST OPEN & REMAIN OPEN PREVENTING SOL REENERGIZATION & VLV OPENING ON SIGNAL RESET.
WBN-1-ZS -090-0109 -B 1-FCV -090-0109/ZS -B 297 CNTMT BLDG LWR COMPT MON ISLN VLV POS SW EA180-14302			736'	10"	AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	CNTMT VENT ISO SIG WILL CAUSE ASSOC FCV TO CLOSE. THE LS MUST OPEN & REMAIN OPEN PREVENTING SOL REENERGIZATION & VLV OPENING ON SIGNAL RESET.
WBN-1-ZS -090-0110 -B 1-FCV -090-0110/ZS -B 295 CNTMT BLDG LWR COMPT MON ISLN VLV POS SW EA180-14302			737'	3"	AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	CNTMT VENT ISO SIG WILL CAUSE ASSOC FCV TO CLOSE. THE LS MUST OPEN & REMAIN OPEN PREVENTING SOL REENERGIZATION & VLV OPENING ON SIGNAL RESET.
WBN-1-ZS -090-0114 -B 1-FCV -090-0114/ZS -B 296 CNTMT BLDG UP COMPT MON ISLN VLV POS SW EA180-14302			736'	4"	AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	CNTMT VENT ISO SIG WILL CAUSE ASSOC FCV TO CLOSE. THE LS MUST OPEN & REMAIN OPEN PREVENTING SOL REENERGIZATION & VLV OPENING ON SIGNAL RESET.
WBN-1-ZS -090-0115 -B 1-FCV -090-0115/ZS -B 296 CNTMT BLDG UP COMPT MON ISLN VLV POS SW EA180-14302			736'	3"	AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	CNTMT VENT ISO SIG WILL CAUSE ASSOC FCV TO CLOSE. THE LS MUST OPEN & REMAIN OPEN PREVENTING SOL REENERGIZATION & VLV OPENING ON SIGNAL RESET.

PAGE A-8 R2

PREPARER/DATE D.R.S. 9/8/86 R 1 JWH R 2 WCG R ---
 9-28-89 7-23-89
 CHECKED/DATE N.A.P. 9/8/86 WCG JWH
 9-28-89 7/23/89

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-IZS -002
MANUFACTURER : NAMCO
PAGE 8 OF 8

W A T T S B A R N U C L E A R P L A N T
T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO.	-----LOCATION-----		CAT	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1)				
WBN-1-ZS -090-0116 CNTMT BLDG UP COMPT MON ISLN VLV POS SW	-B 1-FCV -090-0116/ZS EA180-14302	-B 291	736'11"	AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	CNTMT VENT ISO SIG WILL CAUSE ASSOC FCV TO CLOSE. THE LS MUST OPEN & REMAIN OPEN PREVENTING SOL REENERGIZATION & VLV OPENING ON SIGNAL RESET.

PAGE A-9 R2

PREPARER/DATE	<u>D.R.S.</u>	<u>9/8/86</u>	R <u>1</u>	R <u>2</u>	R _____
CHECKED/DATE	<u>N.A.P.</u>	<u>9/8/86</u>	<u>JWH</u> 9-28-89	<u>WCP</u> 7-23-90	_____
			<u>WCG</u> 9-28-89	<u>JOH</u> 7/23/90	_____

BINDER NO. <u>WBNEQ-IZS-002</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>1</u> OF <u>32</u>
		R <u>1</u>	R <u>2</u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>DRS</u>	DATE <u>5/22/86</u>	<u>JWH</u> <u>wcp</u>
<u>LIMIT SWITCHES MANUFACTURED</u>			<u>9/28/89</u> <u>7-23-90</u>
<u>BETWEEN 9/5/78 AND 7/30/80</u>	CHECKED <u>NAP</u>	DATE <u>5/23/86</u>	<u>WCG</u> <u>JDH</u>
			<u>9/28/89</u> <u>7/23/90</u>

A. DOCUMENTATION

Equipment Description Limit Switch

Vendor/Manufacturer NAMCO

Equipment Model No.(s) See Tab A

QUALIFICATION REPORTS

- (1) Title/Number/Revision Qualification of RIMS NEB 820318 202
NAMCO controls Limit Switch Model EA 180
to IEEE Standards 344 ('75), 323 ('74)
and 382 ('72)
Revision 1 DATE 9/5/78

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- WBNOSG4-012 R5 (B18 900531 252) Category & Operating Times-System 61
WBNOSG4-013 R12 (B26 900327 200) Category & Operating Times-System 62
WBNOSG4-014 R11 (B26 900309 227) Category & Operating Times-System 63
WBNOSG4-017 R11 (B18 900612 252) Category & Operating Times-System 68
WBNOSG4-019 R8 (B26 900628 201) Category & Operating Times-System 72
WBNOSG4-021 R5 (B18 900612 251) Category & Operating Times-System 77
WBNOSG4-026 R7 (B45 870227 426) Category & Operating Times-System 90
Vendor Telecon: TVA (L. P. Woodley) and NAMCO (J. R. Bendokaitis)
on 10/22/85 - See TAB E (3)
Watts Bar Environmental Drawing 47E235-41 R1
Watts Bar Environmental Drawing 47E235-42 R2
Watts Bar Environmental Drawing 47E235-77 R1
Material Aging Calculation WAC-293 (B44 900410 805)
Reduction of Beta Dose by Sheet Steel WBNTSR-051 R0 (B26 891129 202)

R2

R2

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 2 OF 32
R 1 R _____
BINDER TITLE EA 180 SERIES COMPUTED DRS _____ DATE 9/8/86 *WCS*
LIMIT SWITCHES MANUFACTURED _____
BETWEEN 9/5/78 AND 7/30/80 CHECKED- NAP DATE 9/8/86 *WCS*
9-25-89

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

Equipment is qualified pending resolution of open items identified in the front of the binder. 1. SCR WBNEEB8578 R3 - Gasket replacement

| R1

COMMENTS/RECOMMENDATIONS

The required operating environments, normal and accident, have been reviewed for each switch location identified in TAB A. All switches are qualified to the worst case combination of these environmental parameters. This includes consideration of peak levels and profiles.

BINDER NO. WBNEQ-1ZS-002 PLANT WBN UNIT(S) 1 SHEET 3 OF 32

BINDER TITLE EA180 SERIES LIMIT COMPUTED DRS DATE 5/22/82 R R
SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80 CHECKED Wap DATE 5/23/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

 Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

 X Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS Purchase contract is dated 1978 (see Tab E(2)).

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET
IEEE 323-1971

BINDER TITLE EA180 SERIES LIMIT SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80 COMPUTED DAS DATE 5/22/86 R R
CHECKED nap DATE 5/23/86

D. QUALIFICATION METHODOLOGY

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS This test provides generic group qualification for EA180 series limit switches. Model EA180-11302 was selected for test purposes and is identical to models of the same number at Watts Bar. Other models of the EA180 series have been qualified with supporting supplementary testing and similarity discussions. See Tab C(1) for similarity evaluation.

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? Yes - See Comment Section D.

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Limit Switch</u>	<u>Limit Switch</u>	<u>TAB D, Page D-6</u>
(2) Manufacturer	<u>NAMCO</u>	<u>NAMCO</u>	<u>TAB D, Page D-6</u>
(3) Model Number(s)	<u>See TAB A</u>	<u>EA 180-11302</u>	<u>TAB D, Page D-6</u>
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
(4) Serial Number(s)	<u>See Comment</u>	<u>See Comment</u>	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
(5) Identify Component Unique checksheet attached:	<u>N/A</u>		

RI

JUSTIFICATION/COMMENTS

These limit switches do not have serial numbers but are provided with date codes per the manufacturer's date code system described on EA 189-90051, page 1 of 3 (TAB H). These date codes are documented on field verification sheets found in TAB F. All limit switches in this binder have date codes between 9/5/78 and 7/30/80. Contract Certification of Compliance for these switches, found in TAB E(1), documents qualification to the test report found in TAB D.

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>None</u>	<u>No</u>	<u>None</u>
External Process Connections	<u>None</u>	<u>No</u>	<u>None</u>
Electrical Connections	<u>None</u>	<u>No</u>	<u>None</u>
Conduit Seals	<u>Required</u>	<u>Yes</u>	<u>TAB D, Page D-7</u>
Connector Seals	<u>None</u>	<u>No</u>	<u>None</u>
Orientation	<u>None</u>	<u>No</u>	<u>None</u>
Physical Configuration	<u>None</u>	<u>No</u>	<u>None</u>
Other	<u>See Comments</u>	<u>See Comments</u>	<u>None</u>

RI

JUSTIFICATION/COMMENTS

Although it was not considered part of the qualification test, an operating lever is required for proper operation of the switch. The lever and roller should be of metal construction. Nylon rollers are not acceptable and are controlled through TVA's maintenance program (see TAB G).

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (Yes/No/NA)? (Note below.)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>TAB D, Page D-7</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>TAB D, Page D-7</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>TAB D, Page D-7</u>
Radiation	<u>Yes</u>	<u>TAB D, Page D-8</u>
Wear	<u>Yes</u>	<u>TAB D, Page D-7</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>TAB D, Page D-8</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>TAB D, Page D-12</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>TAB D, Page D-13</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>TAB D, Page D-41</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)? Yes - See Comment (2)

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately document (Yes/No/NA)? No - See Comment (1)
(Reference: TAB D, Appendix E).

JUSTIFICATION/COMMENTS (1) Test equipment and calibration dates were recorded; however, test equipment accuracies were not documented in the test report. (2) The test report recorded seismic test data (TAB D, Appendix B) for a different EA 180 switch. However, the switch

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 8 OF 32

R 1 R

BINDER TITLE EA 180 SERIES COMPUTED DRS DATE 5-22-86 *Jul 1986*

LIMIT SWITCHES MANUFACTURED

BETWEEN 9/5/78 AND 7/30/80 CHECKED NAP DATE 5-23-86 *WLD 9-28-89*

G. TEST SEQUENCE (continued)

used throughout the test sequence was seismically conditioned by subjecting it to all vibrations contained in the seismic test (TAB D, pages D-11 and D-12).

| R1

H. AGING

- (1) Was aging considered in the qualification program (Yes/No/NA)?
Yes (Reference: TAB D, pages D-7 & D-8).

| RI

JUSTIFICATION/COMMENTS None

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>TAB D, Page D-7</u>
Radiation exposure	<u>Yes</u>	<u>TAB D, Page D-8</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>TAB D, Page D-35</u>
Operational (electrical/mechanical/ process) stress aging	<u>Yes</u>	<u>TAB D, Page D-7</u>

| RI

JUSTIFICATION/COMMENTS None

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (Yes/No/NA)? N/A (Reference: See Comment).

JUSTIFICATION/COMMENTS No known synergistic effects.

- (4) Thermal Aging:

- a) Was thermal aging considered in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, page D-7).

| RI

JUSTIFICATION/COMMENTS None

BINDER NO. <u>WBNEQ-IZS-002</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>10</u> OF <u>32</u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>DRS</u>	DATE <u>5-22-86</u>	R <u>1</u> R _____
<u>LIMIT SWITCHES MANUFACTURED</u>			<i>WCS</i>
<u>BETWEEN 9/5/78 AND 7/30/80</u>	CHECKED <u>NAP</u>	DATE <u>5-23-86</u>	<i>WCS</i> <i>9-18-89</i>

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (Yes/No/NA)? Yes
(Reference: N/A).

JUSTIFICATION/COMMENTS See Material Analysis in TAB C(5).

- (c) Was the basis for thermal aging identified in the qualification program (Yes/No/NA)? Yes Reference TAB D Page D-7 footnote "+"). | RI

JUSTIFICATION/COMMENTS See Material Analysis in TAB C(5).

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, Page D-7, footnote "+"). | RI

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>104°F/110°F/120°F</u>	<u>N/A</u>	<u>104°F/ 110°F/120°F 20.6/</u>
Time	<u>40 Years</u>	<u>N/A</u>	<u>12.9/8.2 yrs</u>

JUSTIFICATION/COMMENTS *Qualified life established by Materials Analysis in TAB C(5).

- (e) Was the Arrhenius methodology used for accelerated aging (Yes/No/NA)? Yes (Reference: N/A).

JUSTIFICATION/COMMENTS See Materials Analysis in TAB C(5).

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (Yes/No/NA)? Yes (Reference: N/A).

JUSTIFICATION/COMMENTS See Materials Analysis in TAB C(5).

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 11 OF 32
R 1 R _____
BINDER TITLE EA 180 SERIES COMPUTED DRS _____ DATE 5-22-86 CHW
LIMIT SWITCHES MANUFACTURED 7/9/81
BETWEEN 9/5/78 AND 7/30/80 CHECKED NAP DATE 5-23-86 WCS
9-28-89

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? N/A (Reference: N/A).

JUSTIFICATION/COMMENTS None

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? N/A (Reference: N/A).

JUSTIFICATION/COMMENTS Qualified life determined by Materials Analysis rather than accelerated aging test on assembled device.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, Page D-8). | R1

JUSTIFICATION/COMMENTS None

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? No (Reference: N/A).

JUSTIFICATION/COMMENTS Assembled test specimen irradiated to 204 megarads.

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? No (Reference: N/A).

JUSTIFICATION/COMMENTS 204 megarads exposed the switch to a greater radiation dose than expected for the service life of the switch plus accident conditions and margins.

BINDER NO. <u>WBNEQ-IZS-002</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>12</u> OF <u>32</u>
		R <u>1</u>	R _____
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>DRS</u>	DATE <u>5-22-86</u>	<u>9/28/86</u>
<u>LIMIT SWITCHES MANUFACTURED</u>			
<u>BETWEEN 9/5/78 AND 7/30/80</u>		CHECKED <u>NAP</u>	DATE <u>5-23-86</u> <u>WCP</u> <u>9-28-89</u>

H. AGING (Continued)

(d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: TAB D, Page D-18). | R1

Plant normal ambient radiation dose (rd) 2 x 10⁷

Test exposure dose (rd) 2.04 x 10⁸

Test exposure dose rate (rd/hr) .7 x 10⁶

Test exposure source type (e.g., Co-60 gamma) Co-60 Gamma

JUSTIFICATION/COMMENTS None

(6) Vibration (non-seismic) Aging:

(a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program? Yes (Reference: TAB D, Page D-35). | R1

JUSTIFICATION/COMMENTS None

(b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? No (Reference: N/A).

JUSTIFICATION/COMMENTS See TAB C(2)

1. Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 13 OF 32
R 1 R _____
BINDER TITLE EA 180 SERIES COMPUTED DRS DATE 5-22-86 WCS
LIMIT SWITCHES MANUFACTURED
BETWEEN 9/5/78 AND 7/30/80 CHECKED NAP DATE 5-23-86 WCS
9-28-89

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, Pages D-50 & D-51). | R1

JUSTIFICATION/COMMENTS None

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D, Pages D-7 & D-8). | R1

JUSTIFICATION/COMMENTS See Section P(1) for additional discussion.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes. See next sheet for discussion. (Reference: N/A).

Qualified life (Document in QMDS) 40 years*

JUSTIFICATION/COMMENTS *Through periodic refurbishment as defined in EA 189-90051 (TAB H).

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? No (Reference: N/A).

Replacement Intervals (Document in QMDS) See QMDS TAB G.

JUSTIFICATION/COMMENTS None

BINDER TITLE EA180 SERIES LIMIT SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80 COMPUTED DJS DATE 5/22/82 R R
 CHECKED rap DATE 5/23/82

QUALIFIED LIFE H(8) The qualified life for all equipment covered by this binder is 40 years through periodic refurbishment. For further discussion on material analysis and Arrhenius methodology, refer to material analysis discussion found in Tab C(5).
The scheduled maintenance service times shown below comes directly from this Arrhenius curve.

<u>Max Normal Ambient</u>	<u>Service Time</u>
104°F	20.6 yrs.
110°F	12.9 yrs.
120°F	8.2 yrs.

The QMDS section found in Tab G will document the limit switches which require refurbishment and the appropriate schedule.

BINDER TITLE EA180 SERIES LIMIT COMPUTED DPS DATE 5/22/86 R — R —
 SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80 CHECKED REP DATE 5/23/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Ethylene Propylene/ O-Ring Shaft Seal</u>	<u>NA</u>	<u>NA</u>	<u>0.8eV</u>	<u>TAB C(5)</u>
(b) <u>Silicone rubber/Gasket</u>	<u>NA</u>	<u>NA</u>	<u>1.14eV</u>	<u>TAB C(5)</u>
(c) <u>Synthetic hydrocarbon grease with fluorocarbon/ lubricant</u>	<u>NA</u>	<u>NA</u>	<u>Unknown</u>	<u>TAB C(5)</u>
(d) <u>Aromatic ether based oil/ lubricant</u>	<u>NA</u>	<u>NA</u>	<u>Unknown</u>	<u>TAB C(5)</u>
(e) <u>Glass filled polyester (thermoset plastic)/ contact block contact carrier</u>	<u>NA</u>	<u>NA</u>	<u>Unknown</u>	<u>TAB C(5)</u>

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 16 OF 32
R 1 R _____
BINDER TITLE EA 180 SERIES COMPUTED DRS _____ DATE 5-29-86 WCS
9/28/86
LIMIT SWITCHES MANUFACTURED
BETWEEN 9/5/78 AND 7/30/80 CHECKED NAP DATE 5-29-86 WCS
9-28-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (Yes/No/NA)? No (Reference: N/A).

Identify Acceptance Criteria: See Section P(3).

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (Yes/No/NA)? No (Reference: N/A).

Identify baseline and functional testing: See Section P(3).

JUSTIFICATION/COMMENTS None

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (Yes/No/NA)? Yes (Reference: TAB D, Page D-43).

JUSTIFICATION/COMMENTS None

| R1

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: See Comment).

JUSTIFICATION/COMMENTS See Comment J(5)(b)

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>See Comment</u>	<u>N/A</u>
Load	<u>See Comment</u>	<u>N/A</u>
Frequency	<u>N/A</u>	<u>N/A</u>
Accuracy	<u>N/A</u>	<u>N/A</u>
Other(s)		
<u>Insulation Resis. minimum</u>	<u>See Comment</u>	<u>N/A</u>
<u>Closed contact open less than 2 mili-sec during seismic test</u>	<u>See Comment</u>	<u>N/A</u>

JUSTIFICATION/COMMENTS See Comment J(5)(b)

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>See Comment</u>	<u>N/A</u>
Load	<u>See Comment</u>	<u>N/A</u>
Frequency	<u>N/A</u>	<u>N/A</u>
Accuracy	<u>N/A</u>	<u>N/A</u>
Other(s)		
<u>Insulation Resis. minimum</u>	<u>See Comment</u>	<u>N/A</u>
<u>Closed contact open less than 2 mili-sec during seismic test</u>	<u>See Comment</u>	<u>N/A</u>

JUSTIFICATION/COMMENTS

Just / Comment
← See comment
J5C

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>R</u>
Voltage	<u>125V AC/DC</u>	<u>TAB D, Page D-22</u>
Load	<u>0.5 amp/100VDC</u> <u>0.086 amp/100VDC</u>	<u>TAB D, Page D-38</u> <u>TAB D, Page D-43</u>
Frequency	<u>N/A</u>	<u>N/A</u>
Accuracy	<u>N/A</u>	<u>N/A</u>
Other(s)		
<u>Constant Resistance</u>	<u>50,000 ohms</u>	<u>TAB D, Page D-13</u>
<u>Contact Opening</u>	<u>2 mili-sec</u>	<u>TAB D, Page D-28</u>

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 18a OF 32

R 1 R

BINDER TITLE EA 180 SERIES COMPUTED DRS DATE 5-31-86 *APV*

LIMIT SWITCHES MANUFACTURED

BETWEEN 9/5/78 AND 7/30/80 CHECKED NAP DATE 6-2-86 *wco*

9-28-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(c) (Continued)

JUSTIFICATION/COMMENTS

The typical application of these limit switches is in control circuits. for example, solenoid valves. These circuits



REVISE PER BELOW:

- 1. THE TYPICAL APPLICATION OF THESE LIMIT SWITCHES IS IN THE CONTROL CIRCUIT OF, FOR EXAMPLE, SOLENOID OPERATED VALVES*

L

g

the

and

currents, the contact surfaces tend to be self-cleaning and/or the potential of the circuit is sufficient to break down films or oxides that might form on the contact faces.

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 19 OF 32
BINDER TITLE EAI 80 SERIES LIMIT COMPUTED DMS DATE 5/31/86 R. R.
SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80 CHECKED Wap DATE 6/2/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

JUSTIFICATION/COMMENTS (Continued)

(3) Since standard design practices should prevent circuits from exceeding the UL ratings of contacts, the 100 VDC and 0.086 amp load used for testing is conservative and adequate considering items (1) and (2) above.

While there are no plant specific requirements with regard to contact bounce and insulation resistance minimum, the values demonstrated are considered adequate. At 50,000 ohms, there would be a slight leakage current of approximately 2.5 milliamps for a typical 125V circuit. This small leakage current should not provide enough amperage to cause any adverse circuit operation.

K.1 REQUIRED OPERATING ENVIRONMENT - UPPER COMPARTMENT

Reference Environmental Drawing No. 47E235-41

- | | |
|--|---------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>110</u> | (a) Temperature (°F) <u>120</u> |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>1 x 10⁶</u> | (d) Radiation (rd) <u>N/A</u> |

(3) Process Interfaces: None.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. (Effect on qualified life is negligible. See generic position in binder WBNEQ-GEN-001.)

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|--|--------------------------------|
| (a) Temperature (°F) <u>161</u> | Accident type <u>LOCA/HELB</u> |
| (b) Pressure (psig) <u>11.2</u> | Accident type <u>LOCA/HELB</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>4.7 x 10⁸</u> Beta
<u>3.8 x 10⁷</u> Gamma | Accident type <u>LOCA</u> |
| (e) Spray Type <u>*</u> | Accident type <u>LOCA/HELB</u> |

*0.1844 Molar H₃BO₃ (2000 PPM Boron), 0.033 Molar NaOH resulting in a PH of 8.35 at 25°C. Spray duration is up to 30 days at a flow rate equal to 0.92 GPM per square foot of containment cross section.

K.2 REQUIRED OPERATING ENVIRONMENT - LOWER COMPARTMENT

Reference Environmental Drawing No. 47E235-42

| R1

- | | |
|--|---------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>120</u> | (a) Temperature (°F) <u>130</u> |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>100</u> |
| (d) Radiation (rd) <u>2 x 10⁷</u> | (d) Radiation (rd) <u>N/A</u> |

| R1

(3) Process Interfaces: None.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. (Effect on qualified life is negligible. See generic position in binder WBNEQ-GEN-001.)

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|--|--------------------------------|
| (a) Temperature (°F) <u>327</u> | Accident type <u>HELB</u> |
| (b) Pressure (psig) <u>11.2</u> | Accident type <u>LOCA/HELB</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>4.7 x 10⁸ Beta</u>
<u>4 x 10⁷ Gamma</u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>*</u> | Accident type <u>LOCA/HELB</u> |

| R1

| R1

*0.1844 Molar H₃BO₃ (2000 PPM Boron), 0.033 Molar NaOH resulting in a PH of 8.35 at 25°C. Spray duration is up to 30 days at a flow rate equal to 0.92 GPM per square foot of containment cross section.

| R1

BINDER NO. <u>WBNEQ-IZS-002</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>22</u> OF <u>32</u>
		R <u>1</u>	R _____
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED DRS _____	DATE <u>5-22-86</u>	<u>WCP</u> <u>10/28/89</u>
<u>LIMIT SWITCHES MANUFACTURED</u>			
<u>BETWEEN 9/5/78 AND 7/30/80</u>		CHECKED <u>NAP</u>	DATE <u>5-23-86</u> <u>WCP</u> <u>9-28-89</u>

K.3 REQUIRED OPERATING ENVIRONMENT: RHR Valve Rooms

Reference Environmental Drawing No. 47E235-77

|R1

- | | |
|--|---------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM</u> | (b) Pressure (psig) <u>ATM</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>1.8 x 10⁶</u> | (d) Radiation (rd) <u>NA</u> |

|R1

(3) Process Interfaces: None.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. (Effect on qualified life is negligible. See generic position in binder WBNEQ-GEN-001.)

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|--|---------------------------|
| (a) Temperature (°F) <u>190</u> | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>NA</u> | Accident type <u>NA</u> |
| (c) Humidity (%) <u>90</u> | Accident type <u>LOCA</u> |
| (d) Radiation (rd) <u>1 x 10⁷</u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

|R1

|R1

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): For a cross-reference of equipment to environmental drawing, see Tab G

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: Tab C(8)).

(7) Subject to submergence (Yes/No/NA)? No (Reference: see Section P(2)).

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: _____).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: 5.12×10^7 rads, See TAB B, Section P, Page B-32.

(9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>None</u>	_____
_____	_____
_____	_____

RI

L SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>30 days</u>	<u>Tab C(6)</u>
Temperature (°F)	<u>327</u>	<u>349</u>	<u>TAB D, p D-45</u>
Pressure (psig)	<u>11.2</u>	<u>83</u>	<u>TAB D, p D-45</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>TAB D, p D-45</u>
Chemical Spray*	<u>Tab C(3)</u> <u>6 x 10⁷</u>	<u>Tab C(3)</u> <u>2.04 x 10⁸</u>	<u>TAB D, p D-45</u>
Radiation (rd)**	<u>Gamma</u>	<u>Gamma</u>	<u>TAB D, p D-39</u>
Submergence	<u>NA</u>	<u>NA</u>	<u>TAB B, Sec. P(2)</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>TAB C(9)</u>
Pressure	<u>Yes</u>	<u>See L(1)</u>
Relative Humidity	<u>Yes</u>	<u>See L(1)</u>
Chemical Spray	<u>Yes</u>	<u>TAB C(3)</u>
Submergence	<u>NA</u>	<u>TAB B, Sect. P(2)</u>

JUSTIFICATION/COMMENTS None

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>+22</u> <u>+591%</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>+71PSIG</u> <u>+240%</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>+1.4 x 10⁸</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>Tab C(6)</u>	<u>Yes</u>
Voltage: ±10% of rated value	<u>NA</u>	<u>NA</u>
Frequency: ±5% of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>2 Dwells</u> <u>+217% See</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>Comment</u>	<u>Yes</u>

JUSTIFICATION/COMMENTS: Per TVA Standard Specification - SS-E18. 12.01 - Seismic Requirements for Category I Electrical and I&C Equipment, these limit switches should be tested to 3 g's horizontal and 2 g's vertical. Since NAMCO verified in their test report (TAB D, Page D-11) that cross-coupling was not significant, the single axis test performed in each of the 3 axis to 9.52 g's was more than adequate. | R1

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference: See Tab A).

JUSTIFICATION/COMMENTS None

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: TAB D, Page D-50).

JUSTIFICATION/COMMENTS None

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (Yes/No/NA)? Yes
(Reference: TAB D, Page D-50).

JUSTIFICATION/COMMENTS None

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (Yes/No/NA)? Yes
Yes (Reference: See Tab C(6)).

JUSTIFICATION/COMMENTS See Tab C(6)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: Tab C(4)).

JUSTIFICATION/COMMENTS See Tab C(4)

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 27 OF 32

BINDER TITLE EA180 SERIES LIMIT SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80

COMPUTED DS DATE 5/22/82 R R
CHECKED Nap DATE 5/23/82

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQP Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See QMDS - Tab G

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 28 OF 32
 BINDER TITLE EA180 SERIES LIMIT COMPUTED DBS DATE 5/27/86 R R
 SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80 CHECKED nap DATE 5/27/86

0. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|---|---------------------------------------|
| (1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified? | <u>NA</u> |
| (3) Choice of qualification methodology adequately justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements identified? | <u>NA</u> |
| (b) Were specific features and failure modes and effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used together with appropriate justification for their use? | <u>Yes-TAB C(5)</u> |
| (d) Were environmental parameters which affect equipment performance identified? | <u>NA</u> |
| (5) Adequate similarity between equipment and test specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes-Tab C(6)</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u>
<u>NA-See</u> |
| (b) Equipment aged to end of life condition prior to application of DBE conditions? | <u>Section P(6)</u> |
| (c) Absence of preaging in test/analysis justified? | <u>Yes-See</u>
<u>Section P(6)</u> |
| (d) Materials susceptible to thermal/radiation aging identified? | <u>Yes-Tab C(5)</u> |

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes-See Sect.P(4)</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes-See TAB C(3)</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes-See Sect.P(5)</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 30 OF 32

BINDER TITLE EA180 SERIES LIMIT SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80 COMPUTED DK DATE 5/24/80 R R
CHECKED nap DATE 7/23/80

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|--------------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes-See Sect.P(3)</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>NA</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes-TAB C(6)</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>NA</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

1. H(7)(b) This device was subject to 100,000 actuation cycles during mechanical aging testing. This is equivalent to an average of 208 actuations per month or approximately 7 actuations per day over the 40-year life of the plant. This is judged to be in excess of the full open/close actuation cycles the associated valves will be required to

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 31 OF 32
R 1 R _____
BINDER TITLE EA 180 SERIES COMPUTED DRS DATE 5-29-86 WCO
LIMIT SWITCHES MANUFACTURED
BETWEEN 9/5/78 AND 7/30/80 CHECKED NAP DATE 5-29-86 WCO
9-28-89

P. DISCUSSION

operate for normal plant operation, surveillance, and maintenance. Therefore, the mechanical aging performed is adequate to demonstrate qualification over the 40-year life of the plant.

2. K(7) All equipment listed in Tab A has been evaluated for possible submergence due to flooding as defined by environmental drawings 47E235-42, 47E235-41 and 47E235-77 for Lower and Upper Containment and RHR Valve Rooms. No equipment will be submerged and required to operate. | R1

3. J(1)&(2) Acceptance criteria - As discussed on TAB D, Pages D-13 and D-14 of the test report, the following performance results were observed. | R1

1. Open contact resistance remained greater than 50 Kohms during all test phases.
2. During seismic testing, the trip point varied by .107" or less for all units seismically.
3. The closed current remained within two milliamps of the specified load.

While the test report does not cite limiting values for performance characteristics, the performance observed as noted above is judged acceptable. This judgment by the evaluator is based on acceptance criteria documented in QTR No. 105, for NAMCO EA180's manufactured after 7/30/80. This report and acceptance criteria can be found in binder WBNEQ-IZS-001.

4. O(6)(e) This device operates intermittently at relatively low voltages and currents which will not result in significant heat rise.

BINDER NO. <u>WBNEQ-IZS-002</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>32</u> OF <u>32</u>
			R <u>1</u> R <u>2</u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>DRS</u>	DATE <u>9-8-86</u>	<u>JWH</u> <u>wcj</u>
<u>LIMIT SWITCHES MANUFACTURED</u>			<u>9/28/89</u> <u>7-23-90</u>
<u>BETWEEN 9/5/78 AND 7/30/80</u>	CHECKED <u>NAP</u>	DATE <u>9-8-86</u>	<u>WGG</u> <u>JDH</u>
			<u>9/28/89</u> <u>7/23/90</u>

R2

P. DISCUSSION (Continued)

5. Per Watts Bar Environmental Drawing 47E235-41 and 47E235-42, the unattenuated free field post-LOCA beta radiation dose contribution for inside primary containment is 4.7×10^8 rads. The limit switch internals will not, however, be subject to the unattenuated free field beta dose. The switch housing assembly consists of three rectangular parts; the Bronwite alloy housing body (a corrosion resistant bronze casting alloy) and top and bottom stainless steel covers which are tightly bolted together. The minimum thickness is 1/8". Silicone rubber gaskets 0.060" thick are compressed between the housing and top and bottom covers at 20-inch pounds, creating a completely sealed unit that is water, oil, dust, and pressure tight, meeting NEMA type 1, 4, and 13 requirements. Also, all limit switches inside primary containment include a qualified seal. Therefore, all beta radiation sources will be external to the housing and subject to dose attenuation due to the housing. The beta dose to the switch internals will essentially be attenuated completely by a factor of 0.009 due to the minimum metal thickness (reference TVA Calculation No. WBNTSR-051 (TAB C, Section 14). The gap created by the gasket is sufficiently small to allow only a negligible fraction of the unattenuated 4-pi geometry free field dose to penetrate. However, as a conservatism to account for the gap (without taking credit for attenuation due to the silicone gasket), 10% of the unattenuated free field dose is added to the dose attenuated by the metal housing.

R2

BINDER NO. <u>WBNEQ-1ZS-002</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>32AOF 32</u>
			R <u>1</u> R <u>2</u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>DRS</u>	DATE <u>5-29-86</u>	<u>JWH</u> <u>wc</u>
<u>LIMIT SWITCHES MANUFACTURED</u>			<u>9/28/89</u> <u>7-23-90</u>
<u>BETWEEN 9/5/78 AND 7/30/80</u>	CHECKED <u>NAP</u>	DATE <u>5-29-86</u>	<u>WCG</u> <u>JDK</u>
			<u>9/28/89</u> <u>7/23/90</u>

R2

P. DISCUSSION (Continued)

Therefore, the 100-day beta dose to the switch internals is conservatively estimated to be 10% unattenuated contribution + 0.10 (4.7×10^8) = 4.7×10^7 , 100% attenuated contribution = 0.009 (4.7×10^8) = 4.23×10^6 . Total = 5.12×10^7 rads beta.

Additionally, the silicone gaskets themselves are not a concern. They receive significant geometric shielding due to being tightly compressed between the metal housing parts. Based on the switch geometry, the outer gasket material will be exposed to only a fraction of the unattenuated 4-pi geometry free field beta radiation dose. This unattenuated dose would be further reduced due to the angle of incidence into the narrow gap and attenuation due to the outer gasket material resulting in minimal dose to the innermost gasket material. The gasket width is approximately equal to the housing thickness (1/8 inch). Also, Target Rock Corp. has conducted tests on a similar silicone rubber gasket used in a similar application (reference EQ Binder WBNEQ-SOL-001, Section D, and found that after exposure to 185 megarads of gamma radiation, embrittlement had occurred in the excess gasket material extending beyond the mated parts. The gasket material actually trapped between the mated parts was still flexible. Likewise, in our application, the gaskets would not be a concern even should they become brittle due to their being tightly sandwiched between the housing and housing covers in a static application; especially considering that the outer part of the gasket (least important would exhibit the more significant

BINDER NO. WBNEQ-IZS-002 PLANT WBN UNIT(S) 1 SHEET 32B OF 32
BINDER TITLE EA180 SERIES LIMIT COMPUTED DLL DATE 7/23/80 R R
SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80 CHECKED nap DATE 7/23/80

P. DISCUSSION (Continued)

degradation. The limit switches also contain EPDM O-rings used for
screw gaskets and the operating shaft seal. These O-rings are enclosed
by the metal screws and shaft housing which shields them from the
effects of beta radiation.

In conclusion: The total combined beta and gamma radiation dose will
equal 9.12×10^7 rads TID (5.12×10^7 beta + 4.0×10^7 gamma) for
accident conditions. The accident radiation plus the large lower
compartment 40-year dose of 2.0×10^7 rads equals a total radiation
dose of 1.1×10^8 rads TID. These switches were tested to 2.04×10^8
rads which envelops our plant requirements. Therefore, they are
qualified for our worst case gamma and beta radiation dose.

6. 0(6)(b)&(c) This equipment is being qualified to NUREG-0588,
Category II and therefore does not have to be aged to an end-of-life
condition prior to DBE testing. The qualified life was determined
by evaluating the potential for significant thermal aging degradation
of the nonmetallic materials of construction (See TAB C(5)).

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
EA740 LIMIT COMPUTED WCG DATE 4-15/86 JDH
10/1/81 10/15/90 R 3 R
WBK DATE 6/19/86 CAH
10/18/90

TAB A

Identification of equipment comprising the equipment type

The following notes apply to all pages of this TAB A

1. Elevations shown are actual elevations for equipment located in the Reactor Building and floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-4 for source of Category and Operating Time assignments.
3. A containment vent isolation signal will cause the associated FCVs to close. The limit and zone switches must then open preventing solenoid reenergization and valve opening. The switches must remain open to prevent valve position changes after containment vent isolation reset. The limit switch position indication is a PAM B and D2 variable and must be monitored for the duration of each event to verify that containment integrity is maintained.
4. A phase "A" containment isolation signal will cause the associated FCVs to close. The limit switches must then open and remain open preventing solenoid reenergization and valve opening upon Phase "A" containment isolation reset. The limit switch position indication is a PAM B1 and D2 variable and must be monitored for the duration of each event to verify that containment integrity is maintained.
5. A Phase "A" containment isolation signal will cause the associated FCVs to close. The limit switches must then open and remain open preventing solenoid reenergization and valve opening upon Phase "A" containment isolation reset. The limit switch position indication is a PAM B1 variable and must be monitored for the duration of each event to verify that containment integrity is maintained.

IZS-003

PRINT DATE: 09/25/90

BINDER NO. : WBNEQ-IZS -003
 MANUFACTURER : NAMCO
 PAGE 1 OF 2

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) RM/RAD CONTRACT				
WBN-1-ZS -030-0058A -B 1-ZS -030-0058/1 -B 116 INCORE INSTR RM EXHAUST POS SWITCH	EA74020000		739' IIR 83KJ1-832128	A	100D	L	SEE NOTE 3
				A	100D	MS/C	
				A	100D	FW/C	
				A	1MO	RH/C	
				A	1MO	CV/C	
WBN-1-ZS -030-0058B -B 1-ZS -030-0058/2 -B 117 INCORE INSTR RM EXHAUST POS SWITCH	EA74020001		738' 5" IIR 83KJ1-832128	A	100D	L	SEE NOTE 3
				A	100D	MS/C	
				A	100D	FW/C	
				A	1MO	RH/C	
				A	1MO	CV/C	
WBN-1-ZS -031-0326B -A 1-FCV -031-0326/ZS2 -A 106 INCORE INSTR RM CHILLER B CWR ISO VL LS	EA74020100		745' 10" ANN	A	100D	L	SEE NOTE 4
				A	100D	MS/C	
				A	100D	FW/C	
				A	1MO	RH/C	
				A	1MO	CV/C	
WBN-1-ZS -077-0127A -B 1-ZS -077-0127A -B 290 REACTOR BLDG SUMP DISCH FLOW CNTL VLV LS	EA74020120		720' 9" AC4 84KJ5-836242	A	100D	L	SEE NOTE 5.
				A	100D	MS/C	
				A	100D	FW/C	
				A	1MO	RH/C	
				A	1MO	CV/C	
WBN-1-ZS -077-0127B -B 1-ZS -077-0127B -B 290 REACTOR BLDG SUMP DISCH FLOW CNTL VLV LS	EA74020120		720' 9" AC4 84KJ5-836242	A	100D	L	SEE NOTE 5.
				A	100D	MS/C	
				A	100D	FW/C	
				A	1MO	RH/C	
				A	1MO	CV/C	

R3

PAGE A-2 R3

PREPARER/DATE WCG 8/26/86
 CHECKED/DATE WBK 8/26/86

R 3 R ___ R ___
JOH ___ ___
10/15/90 ___ ___
CR ___ ___
10/14/90 ___ ___

PRINT DATE: 09/25/90

BINDER NO. : WBNEQ-IZS -003
MANUFACTURER : NAMCO
PAGE 2 OF 2

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-1-ZS -077-0128A -A REACTOR BLDG SUMP DISCH FCV LIMIT SW	1-ZS -077-0128A -A			A	100D	L	SEE NOTE 5.
				A	1MO	RH/A	
				A	1MO	CV/A	
				A	1MO	AF	
WBN-1-ZS -077-0128B -A REACTOR BLDG SUMP DISCH FCV LIMIT SW	1-ZS -077-0128B -A			A	100D	L	SEE NOTE 5.
				A	1MO	RH/A	
				A	1MO	CV/A	
				A	1MO	AF	
				A	1MO	AB	

R3

PAGE A-3 R3

PREPARER/DATE WCG 9/9/86
CHECKED/DATE WBK/DLK 9/9/86

R <u>3</u>	R <u> </u>	R <u> </u>
<u>JDA</u>	<u> </u>	<u> </u>
<u>11/15/90</u>	<u> </u>	<u> </u>
<u>12/18/90</u>	<u> </u>	<u> </u>

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE EA740 LIMIT SWITCHES COMPUTED WCP DATE 4-15-86 R R
MANUFACTURED AFTER OCTOBER 1, 1981 CHECKED WBK DATE 6/13/86

TAB B - Checklist for evaluation of environmental qualification
including summary and conclusion

PAGE B-1

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE EA740 LIMIT SWITCHES COMPUTED WCS DATE 4-15-86 R R
MANUFACTURED AFTER OCTOBER 1, 1981 CHECKED WJK DATE 6/17/86

TAB B - CHECKLIST
-Contents-

- A) Documentation
- B) Conclusion of Review
- C) Qualification Criteria
- D) Qualification Methodology
- E) Equipment Description
- F) Installation Interfaces
- G) Test Sequence
- H) Aging
- I) Material Analysis
- J) Equipment Electrical Characteristics
- K) Required Operating Environment
- L) Summary Comparison of Test Conditions to Specified Conditions
- M) Operability Test Results
- N) Maintenance and Surveillance
- O) Summary of Review
- P) Discussion

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 32
 R 2 R
 BINDER TITLE EA740 LIMIT COMPUTED WGG DATE 6/13/86 ^{JDM/}_{OTR} 4/15/90
 SWITCHES MANUFACTURED AFTER 10/1/81 CHECKED WBK DATE 6/13/86 ^{KBN/}_{WBK} 6-15-90

A. DOCUMENTATION (SEE NOTE) | R2

Equipment Description Limit Switch
 Vendor/Manufacturer Namco
 Equipment Model No.(s) See TAB A

QUALIFICATION REPORTS (SEE NOTE) | R2

- (1) Title/Number/Revision Qualification of RIMS B71 860325 100
EA740
Series Limit Switches/QTR111/Revision 1 DATE 1/09/84
- (2) Title/Number/Revision Supplement 02 to OTR RIMS B70 870121 003
111 Qualification by Similarity Presentation
to Support the Change of Contact Block/ DATE 12/16/86
Carrier Material | R2
- (3) Title/Number/Revision General Qualification RIMS B37 900214 800
of Series EA-740 Switches for use in Nuclear Power Plant
Class IE Applications in Compliance with DATE _____
IEEE Standards 323-74, 382-72, and 344-75, QTR 140, Revision 0

OTHER (ANALYSIS, VENDOR DATA, ETC.) _____

Note: Unless specified otherwise, all references made herein are to the above report (1).

BINDER NO. WBNEQ-1ZS-003 PLANT WBN UNIT(S) 1 SHEET 1a OF 32
 R 3 R _____
 BINDER TITLE EA740 LIMIT COMPUTED WGG DATE 8/19/86 JDH
 SWITCHES MANUFACTURED AFTER _____ 10/15/90

 10/1/81 _____ CHECKED WBK DATE 8/19/86 CBH
 _____ 10/18/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

1. EPDM Activation Energy Analysis
2. Material Aging Calculation Report, WAC-405
3. Similarity Analysis
4. OE Calculation WBNTSR-051 R0 (B26 891129 202), Reduction of Beta Dose by Sheet Steel.
5. TVA Environmental Drawing No. 47E235-42 R2 and DCA P-04104-02-0, -03-0, -02-1, -05-0, and S-09715-02, -03, -04, -05, -13, -14, -15 R3
6. TVA Environmental Drawing No. 47E235-44 R1
7. TVA Environmental Drawing No. 47E235-45 R1 and DCA P-04104-06-0, and S-09715-06, -07, -08, -09, -19 R3
8. Category and Operating Times Calculation, System 30, WBNOSG4-008 R16 (R26 900717 201)
9. Category and Operating Times Calculation, System 31, WBNOSG4-009 R7 (B26 900309 233)
10. Category and Operating Times Calculation, System 77, WBNOSG4-021 R5 (B18 900612 251) R3

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly, should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 2 OF 32
 R 1 R
 BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 9/9/86 RJA
5/5/89
 SWITCHES MANUFACTURED AFTER 10/1/81 CHECKED WBK/DLK DATE 9/9/86 JDH
5/5/89

B. CONCLUSION OF REVIEW (Check only one block)

- X Equipment Qualified (Pending acceptable resolution of open items)
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES _____

1. Limit switches WBN-1-ZS-077-0128A-A and -0128B-A are to be R1
replaced by SCR WBNEEB8578 R5. See Open Item No. 1.
See open item sheets in front of binder for more details.

COMMENTS/RECOMMENDATIONS The required operating environments,
Normal and Accident, have been reviewed for each switch location
identified in TAB A. All switches are qualified to the worst case
combination of these environmental parameters. This includes con-
sideration of peak levels and profiles.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 3 OF 32

BINDER TITLE EA740 LIMIT SWITCHES COMPUTED wcp DATE 4-15-86 R R

MANUFACTURED AFTER 10/1/81 CHECKED [Signature] DATE 4/13/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

 Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS None

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE STD. 323-1974

IEEE STD. 344-1975

IEEE STD. 382-1972 (Pressurized water reactor portion only)

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 4 OF 32

BINDER TITLE EA740 LIMIT SWITCHES COMPUTED wcj DATE 4-15-86 R R

MANUFACTURED AFTER 10/1/81 CHECKED WJK DATE 6/13/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 5 OF 32

BINDER TITLE: EA740 LIMIT SWITCHES COMPUTED WCR DATE 6/27/86 R R

MANUFACTURED AFTER 10/1/81 CHECKED WCR DATE 6/27/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? Yes, See TAB C, Sect. 15.

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Limit Switch</u>	<u>Limit Switch</u>	<u>pp. 3-4, 10-24, 10-55</u>
(2) Manufacturer	<u>NAMCO</u>	<u>NAMCO</u>	<u>pp. 3-4, 10-24, 10-55</u>
(3) Model Number(s)	<u>EA74020000</u>	<u>EA74020000</u>	<u>pp. 3-4, 10-24, 10-55</u>
	<u>EA74020001</u>	<u>EA74020100</u>	<u> </u>
	<u>EA74020100</u>	<u> </u>	<u> </u>
	<u>EA74020120</u>	<u> </u>	<u> </u>
(4) Serial Number(s)	<u>See Comments</u>	<u>See Comments</u>	<u>See Comments</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(5) Identify Component- Unique checksheet attached:	<u>NA</u>	<u> </u>	<u> </u>
	<u>NA</u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS These limit switches do not have serial numbers, but are provided with date codes per the manufacturer's date code system described on p. 3-35 of the Test Report. Field Verification (TAB F) has verified that all limit switches covered in TAB A have data codes after November 1980 and are, therefore, covered by QTR 111 (TAB "D").

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 6 OF 32
R 1 R 2
BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/13/86 RHM JDH/WBK/1/86
SWITCHES MANUFACTURED AFTER 10/1/81 CHECKED WBK DATE 6/13/86 JDH KBN/2/86
5/5/89 5/5/89 6-15-90

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Conduit Seals	<u>See TAB C, Sect. 1</u>	<u>Yes</u>	<u>p. 4-4.1 Sect. 4</u>
Connector Seals	<u>NA</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>NA</u>	<u>NA</u>	<u>NA</u>
Physical Configuration	<u>NA</u>	<u>NA</u>	<u>NA</u>
Other	<u>See Comments</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS For installation instructions refer to EA74990004 on page 4-4.1 of OTR 111. For Verification of Conduit seals see TAB F. Mounting and connection requirements are also addressed on page 11-11, Section 4.2.

Although, it was not considered part of the Qualification Test, an operating lever is required for proper operation of the switch. The lever and roller should be of metallic construction. Nylon rollers are not acceptable and are controlled through TVA's Maintenance Program (see TAB G).

| R2
| R2

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (Yes/No/NA)? (Note below.)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>p. 10-56, Sect. 10</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>p. 10-82</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>p. 10-82</u>
Radiation	<u>Yes</u>	<u>p. 10-84</u>
Wear	<u>Yes</u>	<u>p. 10-83</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>p.10-85</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>pp. 10-89, through 10-95</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>pp. 10-89, 10-93 through 10-98</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>pp.6-3, & 10-99</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)? Yes

(3) Have the test equipment, test equipment accuracies, and calibration data been appropriately document (Yes/No/NA)? Yes (1)(Reference: See Comment (2)).

JUSTIFICATION/COMMENTS (1) Test equipment and calibration dates were recorded; however, test equipment accuracies were not documented in the test report. (2) See pages ^{10 82K/14/90} 20-104 through 10-106 for calibration data. Test equipment is periodically calibrated traceable to NBS (see page 13-6).

R2

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 8 OF 32

BINDER TITLE EA740 LIMIT SWITCHES COMPUTED WCS DATE 6/13/86 R R

MANUFACTURED AFTER 10/1/81 CHECKED WPK DATE 6/19/86

H. AGING

(1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference P. 10-82 through 10-83).

JUSTIFICATION/COMMENTS None

(2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>P. 10-82</u>
Radiation exposure	<u>Yes</u>	<u>P. 10-84</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>P. 10-58</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>P. 10-83</u>

JUSTIFICATION/COMMENTS None

(3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? Yes (Reference See TAB C, Section 17).

JUSTIFICATION/COMMENTS None

(4) Thermal Aging:

(a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference TAB "D", Section 10, P. 10-82).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 9 OF 32
 BINDER TITLE EA740 LIMIT SWITCHES COMPUTED WCAJ DATE 8/24/86 R R
 MANUFACTURED AFTER 10/1/81 CHECKED WJK DATE 8/20/86

H. AGING

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
 (Reference: See TAB "D", pp. 4-9 through 4-12 and 4-17).

JUSTIFICATION/COMMENTS None

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference TAB "D", Sect. 11, p. 11-19).

JUSTIFICATION/COMMENTS None

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference TAB "D", Sect. 4, p 4-9).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>120°F</u>	<u>248°F</u>	<u>120°F</u>
Time	<u>40 years</u>	<u>408 hrs</u>	<u>7.8 years</u>

JUSTIFICATION/COMMENTS Qualified life is 40 years through periodic maintenance and replacement of the elastomeric components as specified in TAB G.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference TAB "D", Sect. 4.8 pp. 4-9 & 4-10).

JUSTIFICATION/COMMENTS None

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes
 (Reference TAB "D", Sect. 4.8, pp. 4-9 through 4-14).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 10 OF 32
BINDER TITLE EA740 LIMIT SWITCHES COMPUTED wcr DATE 6/13/86 R R
MANUFACTURED AFTER 10/1/81 CHECKED WPK DATE 4/13/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS Regression line not used.

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference TAB "D", Sect.10, p.10-58).

JUSTIFICATION/COMMENTS None

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference Refer to TAB "D", Sect. 10 P. 10-84).

JUSTIFICATION/COMMENTS None

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes (Reference P. 4-15).

JUSTIFICATION/COMMENTS Assembled test specimen irradiated to 204 Mrads.

- (c) Was the basis for excluding radiation aging exposure identified in the qualification program (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS Test included irradiation.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 11 OF 32
R 1 R _____
BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/13/86 RBM
SWITCHES MANUFACTURED AFTER _____ 5/5/89
10/1/81 CHECKED WBK DATE 6/13/86 JDH
5/5/89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: TAB D, Section 10, page 10-84).

Plant normal ambient radiation dose (rd) 2×10^7 (worst case)

Test exposure dose (rd) 2.04×10^8

Test exposure dose rate (rd/hr) 9.1×10^5 (average)

Test exposure source type (e.g., Co-60 gamma) Cobalt 60 gamma

JUSTIFICATION/COMMENTS None

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* Yes (Reference: TAB D, page 10-58).

JUSTIFICATION/COMMENTS Plant induced vibration simulation 1×10^6 cycles at 100Hz at 0.75g's per TAB D, page 10-58.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: page 11-23).

JUSTIFICATION/COMMENTS None

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 12 OF 32
R 1 R _____
BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 4/15/86 RJM
SWITCHES MANUFACTURED AFTER 10/1/81 CHECKED WBK DATE 6/13/86 JDH
5/5/89

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: TAB "D", Section 10, page 10-83).

JUSTIFICATION/COMMENTS None

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? NA (Reference: NA).

JUSTIFICATION/COMMENTS See TAB C, Section 11 for

Additional Discussion

R1

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes (Reference: See TAB "G").

Qualified life (Document in QMDS) 40* YRS

JUSTIFICATION/COMMENTS * Through periodic Refurbishment as defined in EA74920011 (p. 4-4.4); Refer also to TAB "C", Section 5.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 13 OF 32

BINDER TITLE EA740 LIMIT SWITCHES COMPUTED wca DATE 6/27/86 R R

MANUFACTURED AFTER 10/1/81 CHECKED WJK DATE 6/27/86

(9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes
(Reference See pp. 4-4.3 and 4-4.4).

Replacement Intervals (Document in QMDS) See TAB "G"

JUSTIFICATION/COMMENTS None

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

	Radiation		Activation	
<u>Material/Property/Function</u>	<u>Threshold</u>	<u>Reference</u>	<u>Energy</u>	<u>Reference</u>
(a) <u>Silicone rubber/top & Bottom cover gasket EPDM/O-ring (lever shaft)</u>	<u>NA</u>	<u>NA</u>	<u>1.14eV</u>	<u>See 4-12 & comment (3)</u>
(b) <u>O-ring (cover screws)</u>	<u>NA</u>	<u>NA</u>	<u>0.94eV</u>	<u>comment (2)</u>
(c) <u>Synthetic Polyphenyl based grease/lubricant</u>	<u>NA</u>	<u>NA</u>	<u>Unknown</u>	<u>see comment(1) P.4-10</u>
(d) <u>Thermoset plastic asbestos or glass-filled phenolic/contact block Contact Carrier</u>	<u>NA</u>	<u>NA</u>	<u>0.827</u>	<u>See comment (4)</u>
(e) <u>Polyphenyl Ether based oil/lubricant</u>	<u>NA</u>	<u>NA</u>	<u>Unknown</u>	<u>See comment(1) See comment (1)</u>

R2

JUSTIFICATION/COMMENTS

1. The qualified life of the lubricant is controlled by the maintenance procedure (reference page 4-11). (Scheduled maintenance requirements documented in TAB G required periodic lubrication.) An activation energy for the lubricant was not required since greases are designed for high temperature applications (the synthetic grease has a rating of 500°F [260°C] Page 4-10).
2. Namco has assumed an activation energy number of 0.8eV for the elastomeric portions of the limit switch. As explained in TAB C, TVA considers this overly conservative and will use 0.94eV. The activation energy of EPDM is a conservative value based on data in TAB C, Section ⁴ ~~7~~. ^{OK 6/14/90}
3. Silicone rubber activation energy is based on reference No. 7, page 4-14 of QTR 111 (TAB D).

BINDER NO. <u>WBNEQ-1ZS-003</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>15</u> OF <u>32</u>
			R <u>1</u> R <u>2</u>
BINDER TITLE <u>EA740 LIMIT</u>	COMPUTED <u>WGG</u>	DATE <u>6/19/86</u>	RHM <u>JDH/RLK</u>
SWITCHES MANUFACTURED AFTER <u>10/1/81</u>	CHECKED <u>WBK</u>	DATE <u>6/19/86</u>	5/5/89 <u>6/15/90</u>
			RBN/RLK <u>6-15-90</u>

JUSTIFICATION/COMMENTS

4. Namco test report QTR 111 documents the qualification of EA740 limit switches whose contact block and carrier material is asbestos-filled phenolic (RX490). However, in December 1986, the contact block material was changed to glass-filled phenolic (RX865) and the contact carrier material was changed to poly amide-imide (Torlon 4203L). This binder addresses both types of switches.

Subsequently, an in-depth analysis was performed in Supplement 02 to QTR 111 (TAB D) comparing the properties of RX490 to RX865 and Torlon 4203L. As a result of this analysis, a different activation energy has been derived for the RX490 contact block (QTR 111 assigned an activation energy of 0.96eV to RX490). Activation energies of 0.834eV, 0.836eV, and 0.99eV were derived for the RX490, RX865, and Torlon 4203L materials, respectively (see Section 3.2.1 of Supplement 02). The data used to derive these values are in Appendix E (RX865) and Appendix F (RX490 and Torlon 4203L) of Supplement 02 to QTR 111. The derivation of 0.836eV for the RX865 utilized only two of the four data points given in Appendix E (869 hours at 230°C and 5775 hours at 185°C). Using all four data points, TVA has derived an activation energy of 0.827eV for the RX865 (see calculation WAC-405 in TAB C). Because of the similarity between RX490 and RX865, 0.827eV will also be used as the activation energy for RX490.

R2

QTR 111 aged the switches for 408 hours at 120°C. TVA considers this aging insufficient. In Namco test report QTR 140, an EA740 limit switch with a RX490 contact block was aged for 1049 hours at 120°C (see excerpts in TAB D) with no adverse effects. Because of its similarity to RX490, the RX865 contact block would also be able to withstand this aging. Therefore, the qualified life of the contact blocks on the switches in this binder was based on the aging parameters in QTR 140.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 32

BINDER TITLE EA740 LIMIT SWITCHES COMPUTED WCR DATE 6/13/86 R R

MANUFACTURED AFTER 10/1/81 CHECKED [Signature] DATE 6/13/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

(1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference TAB D; Section 11, P. 11-27).

Identify Acceptance Criteria: See Section 11, P. 11-27.

(2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference TAB D; Section 11, PP. 11-16 and 11-27).

Identify baseline and functional testing: Voltage-100VDC, current-0.086A, Insulation Resistance-50K ohms minimum, contacts must transfer during each switch operation, closed circuit shall not open for more than 2 milli-seconds during seismic testing.

JUSTIFICATION/COMMENTS None

(3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Section 10, p. 10-90).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 17 OF 32
 R 1 R 2
 BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/27/86 RHM JDH/ozk
 SWITCHES MANUFACTURED AFTER 10/1/81 CHECKED WBK DATE 6/29/86 JDH 5/5/89 1/15/90
 5/5/89 6-15-90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: TAB D, Section 5.6, pp 5-8 thru 5.9).

JUSTIFICATION/COMMENTS None

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>125V DC</u>	<u>NA</u>
Load	<u>5 amps</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		

JUSTIFICATION/COMMENTS See J(5)(b) comments, pages B-20A and B-21.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 17a OF 32
 R 3 R
 BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/27/86 JDH
 SWITCHES MANUFACTURED AFTER 10/1/81 CHECKED WBK DATE 6/29/86 CJB
10/18/90
10/18/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(5)(b) Parameter	Specific Accident Conditions	Reference
Voltage	<u>125V DC</u>	<u>NA</u>
Load	<u>5 amps</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		

JUSTIFICATION/COMMENTS

1. The typical application of these limit switches is in the control circuits of, for example, solenoid operated valves. The UL and nameplate ratings of the switches being bought (20 amps @ 125V AC and 5 amps at 125V DC) envelop the required loads of the switches under normal and accident conditions. R3
2. The demonstrated load of 0.5 amps @ 100V DC is considered adequate for the following reasons:
 - a. Low voltage and currents may not break down the film/oxide; therefore, provide little contact surface renewal.
 - b. When switches are operated at rated voltage and current, the contact surfaces tend to be self-cleaning and/or the potential of the circuit is sufficient to break down films or oxides that might form on the contact faces.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 18 OF 32
R 2 R
BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/27/86 ^{JDM/CLK}
SWITCHES MANUFACTURED AFTER _{11/2/90}
10/1/81 CHECKED WBK DATE 6/29/86 ^{KBN/CLK}
₆₋₁₅₋₉₀

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

(5)(b)(2) JUSTIFICATION/COMMENTS (Continued)

- c. Since TVA's standard design practices prevent circuits from exceeding the UL ratings of contacts, the 100V DC and 0.086 amp load used for testing is conservative and adequate considering items a and b above.
3. At the demonstrated insulation resistance value of 50 Megohms, there would be a slight leakage current of approximately 2.5 milliamps for a typical 125V circuit. This small leakage current should not provide enough amperage to cause any adverse circuit operation. R2
4. While there are no plant-specific requirements with regard to contact bounce/circuit opening, it was demonstrated that none occurred during seismic and vibration testing of the limit switch.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 19 OF 32
 R 1 R 2
 BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/27/86 RHM JDH/BK
 SWITCHES MANUFACTURED AFTER 10/1/81 5/5/89 6/15/90
 CHECKED WBK DATE 6/27/86 JDH KBN/JDH
 5/5/89 6-15-90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(5)(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>100V DC</u>	<u>TAB D, p. 5-9</u>
Load	<u>0.5 amps</u>	<u>TAB D, p. 5-9</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		
Minimum Insulation Resistance	<u>50 megohms</u>	<u>pp. 10-82 thru 10-85 and 10-90</u>
Closed Contact Open <2ms during seismic tests	<u><2ms</u>	<u>p. 5-11, sect. 5.10, p. 10-86 (chart)</u>

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 20 OF 32
 R 1 R _____
 BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/27/86 EdM
5/5/89
 SWITCHES MANUFACTURED AFTER _____
10/1/81 CHECKED WBK DATE 6/27/86 JDH
5/5/89

K.1 REQUIRED OPERATING ENVIRONMENT - Lower Compartment

Reference Environmental Drawing No. 47E235-42 | R1

- (1) Normal Max (2) Abnormal Max
- (a) Temperature (°F) 120 (a) Temperature (°F) 130
- (b) Pressure (psig) 0.3 (b) Pressure (psig) 0.3
- (c) Humidity (%) 80 (c) Humidity (%) 100
- (d) Radiation (rd) 2 x 10⁷ (d) Radiation (rd) NA | R1
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist up to eight hours per excursion and will occur less than 1% of the plant life (effect on qualified life is negligible - see generic position in Binder No. WBNEQ-GEN-001).
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- (a) Temperature (°F) 327 Accident type LOCA/HELB
- (b) Pressure (psig) 11.2 Accident type LOCA/HELB | R1
- (c) Humidity (%) 100 Accident type LOCA/HELB
- (d) Radiation (rd) 4.7x10⁸ Beta
4x10⁷ Gamma Accident type LOCA | R1
- (e) Spray Type * Accident type LOCA/HELB

* 0.19 molar H₃BO₃ (2000 ppm Boron), 0.033 molar NaOH resulting in a pH of 8.3 at 25°C. The duration of the containment spray is 30 days, at a flow rate equal to 9500 gal/min. or 0.92 gpm per square foot of containment cross section. | R1

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 21 OF 32
 R 1 R
 BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 8/19/86 RJM
5/5/89
 SWITCHES MANUFACTURED AFTER 10/1/81 CHECKED WBK DATE 8/19/86 JDH
5/5/89

K.2 REQUIRED OPERATING ENVIRONMENT - Annulus

Reference Environmental Drawing No. 47E235-44 | R1

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>110</u> | (a) Temperature (°F) <u>120</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>1.0x10⁶</u> | (d) Radiation (rd) <u>NA</u> R1 |
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist up to eight hours per excursion and will occur less than 1% of the plant life (effect on qualified life is negligible - see generic position in Binder No. WBNEQ-GEN-001).
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|--|-------------------------------------|
| (a) Temperature (°F) <u>133.7</u> | Accident type <u>LOCA/HELB</u> R1 |
| (b) Pressure (psig) <u>ATM(-)</u> | Accident type <u>NA</u> |
| (c) Humidity (%) <u>61</u> | Accident type <u>LOCA/HELB</u> R1 |
| * (d) Radiation (rd) <u>1.2 x 10⁷</u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

* This dose includes a beta contribution of 6×10^5 rads. See environmental drawing 47E235-44, Note 37. | R1

BINDER NO. WBNEO-IZS-003 PLANT WBN UNIT(S) 1 SHEET 22 OF 32
 R 1 R 2
 BINDER TITLE EA740 LIMIT COMPUTED WGG DATE 6/13/86 RHM JDM/BJK
 SWITCHES MANUFACTURED AFTER 10/1/81 CHECKED WBK DATE 6/13/86 JDH 5/5/89 2/15/90
 DATE 6/13/86 JDH 5/5/89 6-15-90

K.3 REQUIRED OPERATING ENVIRONMENT - IIR

Reference Environmental Drawing No. 47E235-45

- | | |
|--|---------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>75</u> | (a) Temperature (°F) <u>120</u> |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>60</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>3.5x10⁵</u> | (d) Radiation (rd) <u>NA</u> |
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist up to eight hours per excursion and will occur less than 1% of the plant life (effect on qualified life is negligible - see generic position in Binder No. WBNEO-GEN-001).
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|---|--------------------------------|
| (a) Temperature (°F) <u>327</u> | Accident type <u>LOCA/HELB</u> |
| (b) Pressure (psig) <u>11.2</u> | Accident type <u>LOCA/HELB</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>4.7x10⁷ Gamma</u>
<u>Beta</u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>*</u> | Accident type <u>LOCA/HELB</u> |

*0.19 molar H₃BO₃ (2,000 ppm Boron), 0.033 molar NaOH resulting in a pH of 8.3 at 25°C. The duration of the containment spray is 30 days, at a flow rate equal to 9,500 gallons per minute or 0.92 gpm per square foot of containment cross section.

R2

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): For a cross-reference of equipment to environmental drawing. See TAB G.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: _____). |R3
See TAB G

(7) Subject to submergence (Yes/No/NA)? No (Reference: _____). |R3
See * note below

Identify initiation time and duration of submergence: _____
See * note below.

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes
 (Reference: TAB C, Section 9).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____
See TAB C, Section 9

(9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Section A</u>	_____
_____	_____
_____	_____

* All switches inside containment have been verified to be outside the crane wall and, therefore, are not submerged by the transient flood level of 722' inside the crane wall.

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>32 days*** (test time)</u>	<u>TAB C, Section 8</u>
Temperature (°F)	<u>327°F</u>	<u>350</u>	<u>p. 10-92</u>
Pressure (psig)	<u>11.2</u>	<u>76</u>	<u>p. 10-92</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>p. 10-57</u>
Chemical Spray*	<u>See TAB C Sect. 6</u>	<u>See TAB C Sect. 6</u>	<u>p. 4-7. p. 10-101 pp. 10-91 thru 93</u>
Radiation (rd)**	<u>6x10⁷gamma 5.12x10⁷beta ****</u>	<u>2.04 x 10⁸ gamma</u>	<u>p. 10-84</u>
Submergence	<u>NA</u>	<u>NA</u>	<u>NA-See TAB B, Page B-26</u> R3

*Includes spray concentration, flow rate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

****See TAB C, Section 9.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>See L(1)</u>
Pressure	<u>Yes</u>	<u>See L(1)</u>
Relative Humidity	<u>Yes</u>	<u>See L(1)</u>
Chemical Spray	<u>Yes</u>	<u>See L(1)</u>
Submergence	<u>NA</u>	<u>NA-See TAB B, Page B-26</u> R3

JUSTIFICATION/COMMENTS *** For comparison of test profile
to WBN accident profile see TAB C, Section 8.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 25 OF 32
 R 1 R _____
 BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/19/86 RJM
5/5/89
 SWITCHES MANUFACTURED AFTER _____
10/1/81 CHECKED WBK DATE 6/19/86 JDH
5/5/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>	
Temperature: +15 degrees F	+ 23°F	Yes	
Pressure: +10% but no more than 10 psig	> 10%	Yes	R1
Radiation: +10% of accident dose	> 10%	Yes-See TAB C, Section 9	R1
Time: +10% (or 1 hour + operating time per NUREG-0588)	10% See TAB C Section 8	Yes	
Voltage: ±10% of rated value	NA	NA	R1
Frequency: ±5% of rated value	NA	NA	
Environmental Transient: the initial transient and the peak temperature applied twice	2 Dwells	Yes	
Vibration: +10% added to acceleration	See Comments	Yes	

JUSTIFICATION/COMMENTS Per TVA Standard Specification SS-E18.

12.01 - "Seismic Requirements for Category I Electrical and I & C Equipment." These limit switches should be tested to 3 g's Horizontal and 2 g's Vertical. Since NAMCO verified in Appendix A of their report (p. 10-71) that cross coupling was not significant, the single axis test performed in each of the 3 axis to 10 g's was more than adequate.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 26 OF 32
BINDER TITLE EA740 LIMIT SWITCHES COMPUTED WCP DATE 6/27/86 R R
MANUFACTURED AFTER 10/1/81 CHECKED WPK DATE 6/27/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference See Tab A).

JUSTIFICATION/COMMENTS None

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference p. 7-3).

JUSTIFICATION/COMMENTS A 2.5 millisecond contact opening during seismic conditioning was considered a random occurrence (see p. 5-11)

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference p.7-3).

JUSTIFICATION/COMMENTS None

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference Tab C, Section 8).

JUSTIFICATION/COMMENTS The qualified life can be extended to 40 years through refurbishment as defined in EQ749-20011.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 27 OF 2

BINDER TITLE: EA740 LIMIT SWITCHES COMPUTED wcj DATE 6/27/86 R R

MANUFACTURED AFTER 10/1/81 CHECKED wmj DATE 6/27/86

M. OPERABILITY TEST RESULTS

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes
(Reference Tab D, Sect. 10, p. 10-63 and Sect. 5, p. 5-11).

JUSTIFICATION/COMMENTS The 2.5 ms contact opening occurred at
10 g's which is well above our 3 g test requirement. All other
tests (Ref. 5-11, Sect. 5.10) showed no failures.

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 28 OF 32

BINDER TITLE EA740 LIMIT SWITCHES COMPUTED wcjr DATE 4-15-86 R R

MANUFACTURED AFTER 10/1/81 CHECKED [Signature] DATE 6/19/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See Tab G

[Lined area for justification/comments]

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 29 OF 32
 BINDER TITLE EA740 LIMIT SWITCHES COMPUTED WCP DATE 4-15-86 R R
 MANUFACTURED AFTER 10/1/81 CHECKED WPK DATE 6/19/86

0. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (1) Documented evidence of qualification adequate
(Have all assumptions, mathematical models, and
all extrapolations of test data used in an
analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary)
taken to the specified qualification level
adequately justified? | <u>NA</u> |
| (3) Choice of qualification methodology adequately
justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements
identified? | <u>NA</u> |
| (b) Were specific features and failure modes and
effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used
together with appropriate justification for
their use? | <u>NA</u> |
| (d) Were environmental parameters which affect
equipment performance identified? | <u>NA</u> |
| (5) Adequate similarity between equipment and test
specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u> |
| (b) Equipment aged to end of life condition prior to
application of DBE conditions? | <u>Yes</u> |
| (c) Absence of preaging in test/analysis justified? | <u>NA</u> |
| (d) Materials susceptible to thermal/radiation
aging identified? | <u>Yes</u> |

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 30 OF 32
 R 1 R _____
 BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/13/86 RJM
5/5/89
 SWITCHES MANUFACTURED AFTER _____
10/1/81 CHECKED WBK DATE 6/19/86 JDH
5/5/89

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	Yes- See TAB C R1 <u>Sect. 10</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	Yes-See TAB C <u>Sect. 6</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	Yes- See TAB C R1 <u>Sect. 9</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	• <u>Yes</u>

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 31 OF 32
 R 1 R
 BINDER TITLE EA740 LIMIT COMPUTED WCG DATE 6/19/86 RJH
5/5/89
 SWITCHES MANUFACTURED AFTER 10/1/81 CHECKED WBK DATE 6/19/86 JDH
5/5/89

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|----------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>NA</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes-See TAB C</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

BINDER NO. WBNEQ-IZS-003 PLANT WBN UNIT(S) 1 SHEET 32 OF 32
R _____ R _____
BINDER TITLE EA740 LIMIT COMPUTED /R/ Rohn DATE 5-5-89
SWITCHES MANUFACTURED AFTER _____
10/1/81 CHECKED /R/ JDH DATE 5-5-89

THIS PAGE INTENTIONALLY LEFT BLANK

Pages B-35 thru B-36 were deleted per revision 1 .

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1

BINDER TITLE EA740 Limit Switches COMPUTED wcp DATE 5/22/86

Manufactured between February 20, 1978 and October 1, 1981 CHECKED rap DATE 6/27/86

100-527

TAB A - Identification of equipment comprising the equipment type

BINDER NO. WBNEO-IZS-004 PLANT WBN UNIT(S) 1 SHEET 1a OF 1
R 2 R
BINDER TITLE NAMCO EA740 LIMIT COMPUTED /R1CAG DATE 2-22-89 WCP
SWITCHES MANUFACTURED BETWEEN 6-6-90
FEB. 20, 1978 AND OCT. 1, 1981 CHECKED /R1JDH DATE 2-22-89 CAH
6/8/90

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-2A for source of Category and Operating Time assignments.
3. For 1-ZS-30-0056-A Model No. Discrepancy, See TAB C, Page C-135.
4. The safety function of this limit switch is as follows:

To open preventing solenoid reenergization and valve opening, it must remain open to prevent valve position changes after containment vent isolation reset. It must also provide position indication for PAM.

R2

PRINT DATE: 06/05/90

BINDER NO. : WBNEQ-IZS -004
 MANUFACTURER : NAMCO
 PAGE 1 OF 7

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-1-ZS -030-0008A -B 1-ZS -030-0008/1 -B 289 UPPER COMPT PURGE ISLN VALVE POS SW	EA74050001	797° 2"	UC 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
				A	100D	MS/C	PREVENTING SOL REENERGIZATION
				A	100D	FW/C	AND VLV OPENING UPON CNTMNT
				A	1MO	RH/C	VENT ISOL RESET. PROVIDE POS
				A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -030-0008B -B 1-ZS -030-0008/2 -B 289 UPPER COMPT PURGE ISLN VALVE POS SW	EA74050000	797° 2"	UC 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
				A	100D	MS/C	PREVENTING SOL REENERGIZATION
				A	100D	FW/C	AND VLV OPENING UPON CNTMNT
				A	1MO	RH/C	VENT ISOL RESET. PROVIDE POS
				A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -030-0010A -A 1-ZS -030-0010/1 -A 270 UPPER COMPT PURGE ISLN VALVE POS SW	EA74050000	790°	UC 79K3-824495-1	A	100D	L	SEE NOTE 4.
				A	100D	MS/C	
				A	100D	FW/C	
				A	1MO	RH/C	
				A	1MO	CV/C	
WBN-1-ZS -030-0010B -A 1-ZS -030-0010/2 -A 270 UPPER COMPT PURGE ISLN VALVE POS SW	EA74050000	790°	UC 79K3-824495-1	A	100D	L	SEE NOTE 4.
				A	100D	MS/C	
				A	100D	FW/C	
				A	1MO	RH/C	
				A	1MO	CV/C	
WBN-1-ZS -030-0015A -B 1-ZS -030-0015/1 -B 299 LOWER COMPT PURGE ISLN VALVE POS SW	EA74050000	737° 1"	AC4 79K3-824495-1	A	100D	L	SEE NOTE 4.
				A	100D	MS/C	
				A	100D	FW/C	
				A	1MO	RH/C	
				A	1MO	CV/C	

PAGE A-2

PREPARER/DATE WCG 9/10/86 R 1 WCG R 2 WCG R ---
 CHECKED/DATE NAP 9/10/86 R 1 JDH R 2 JDH R ---
 2-23-89 6-8-90
 2-23-89 6/8/90

PRINT DATE: 06/05/90

BINDER NO. : WBNEQ-IZS -004
 MANUFACTURER : NAMCO
 PAGE 2 OF 7

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-ZS -030-0015B -B 1-ZS -030-0015/2 -B 299 LOWER COMPT PURGE ISLN VALVE POS SW	EA74050000		736' 7"	AC4	A	100D	L	SEE NOTE 4.
					A	100D	MS/C	
					A	100D	FW/C	
					A	1MO	RH/C	
					A	1MO	CV/C	
WBN-1-ZS -030-0017A -A 1-FCV -030-0017/ZS1 -A 239 LOWER COMPT PURGE ISLN VALVE LIMIT SW	EA74050000		738' 1"	AC3	A	100D	L	SEE NOTE 4.
					A	100D	MS/C	
					A	100D	FW/C	
					A	1MO	RH/C	
					A	1MO	CV/C	
WBN-1-ZS -030-0017B -A 1-FCV -030-0017/ZS2 -A 239 LOWER COMPT PURGE ISLN VALVE LIMIT SW	EA74050000		737' 6"	AC3	A	100D	L	SEE NOTE 4.
					A	100D	MS/C	
					A	100D	FW/C	
					A	1MO	RH/C	
					A	1MO	CV/C	
WBN-1-ZS -030-0020A -A 1-ZS -030-0020/1 -A 059 IIR PURGE ISLN VALVE POS SWITCH	EA74050000		727' 8"	IIR	A	100D	L	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON CNTMNT VENT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
					A	100D	MS/C	
					A	100D	FW/C	
					A	1MO	RH/C	
					A	1MO	CV/C	
WBN-1-ZS -030-0020B -A 1-ZS -030-0020/2 -A 059 IIR PURGE ISLN VALVE POS SWITCH	EA74050000		727' 2"	IIR	A	100D	L	TO OPEN PREVENTING SOL REENERGIZATION AND VALVE OPENING UPON CNTMNT VENT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
					A	100D	MS/C	
					A	100D	FW/C	
					A	1MO	RH/C	
					A	1MO	CV/C	

PAGE A-3

PREPARER/DATE	WCG	9/10/86	R 1	R 2	R
CHECKED/DATE	NAP	9/10/86	CAG	WCG	
			2-23-89	6-8-90	
			JDH	CSB	
			2-23-89	6/8/90	

R2

PRINT DATE: 06/05/90

BINDER NO. : WBNEQ-IZS -004
 MANUFACTURER : NAMCO
 PAGE 3 OF 7

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1) CONTRACT	RM/RAD				
WBN-1-ZS -030-0040A -A 1-FCV -030-0040/ZS1 -A 284 LOWER COMPT PURGE CONT VALVE POS SW EA74050000			721' 11"	AC4 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON CNTMNT
					A	1MO	RH/C	VENT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -030-0040B -A 1-FCV -030-0040/ZS2 -A 290 LOWER COMPT PURGE CONT VALVE POS SW EA74050000			721' 8"	AC4 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON CNTMNT
					A	1MO	RH/C	VENT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -030-0050A -B 1-ZS -030-0050/1 -B 295 UPPER CNTMT EXH ISLN VALVE POS SW EA74050000			746' 4"	AC4 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON CNTMNT
					A	1MO	RH/C	VENT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -030-0050B -B 1-ZS -030-0050/2 -B 295 UPPER CNTMT EXH ISLN VALVE POS SW EA74050000			746' 4"	AC4 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON CNTMNT
					A	1MO	RH/C	VENT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -030-0052A -A 1-ZS -030-0052/1 -A 247 UPPER CNTMT EXH ISLN VALVE POS SW EA74050000			754' 3"	UC 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON CNTMNT
					A	1MO	RH/C	VENT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.

PAGE A - 4

PREPARER/DATE	WCG	9/10/86	R 1	R 2	R
CHECKED/DATE	NAP	9/10/86	CAG	WCG	
			2-23-89	6-8-90	
			JDH	CAG	
			2-23-89	6/8/90	

R2

PRINT DATE: 06/05/90

BINDER NO. : WBNEQ-IZS -004
 MANUFACTURER : NAMCO
 PAGE 4 OF 7

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-ZS -030-0052A -A 1-ZS -030-0052/2 -A 247 UPPER CNTMT EXH ISLN VALVE POS SW	EA74050000		754' 3"	UC 79K3-824495-1	A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON CNTMNT VENT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
WBN-1-ZS -030-0056A -A 1-ZS -030-0056/1 -A 034 LOWER CNTMT EXH ISLN VALVE POS SW	EA74050000		737' 9"	AC1 79K3-824495-1	A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON CNTMNT VENT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
WBN-1-ZS -030-0056B -A 1-ZS -030-0056/2 -A 034 LOWER CNTMT EXH ISLN VALVE POS SW	EA74050000 (3)		737' 9"	AC1 79K3-824495-1	A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON CNTMNT VENT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
WBN-1-ZS -031-0305A -B 1-FCV -031-0305/ZS1 -B 062 IIR CHILLER A CHR ISLN VALVE LIMIT SW	EA74020100		736' 3"	ANN 79K3-824495-1	A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON PHASE A CNTMNT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
WBN-1-ZS -031-0305B -B 1-FCV -031-0305/ZS2 -B 060 IIR CHILLER A CHR ISLN VALVE LIMIT SW	EA74020100		736'	ANN 79K3-824495-1	A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VALVE OPENING UPON PHASE A CNTMNT ISOL RESET. PROVIDE POS INDICATION FOR PAM.

PAGE A-5

PREPARER/DATE	WCG	9/10/86	R 1	R 2	R
CHECKED/DATE	NAP	9/10/86	CAG	WCD	
			2-23-89	6-8-90	
			JDH	CAV	
			2-23-89	6/8/90	

R2

PRINT DATE: 06/05/90

BINDER NO. : WBNEQ-IZS -004
 MANUFACTURER : NAMCO
 PAGE 5 OF 7

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-ZS -031-0306A -A 1-FCV -031-0306/ZS1 -A 061 IIR CHILLER A CHR ISLN VALVE LIMIT SW EA74020100			737' 11"	IIR	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON PHASE A
					A	1MO	RH/C	CNTMNT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -031-0306B -A 1-FCV -031-0306/ZS2 -A 061 IIR CHILLER A CHR ISLN VALVE LIMIT SW EA74020100			737' 5"	IIR	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON PHASE A
					A	1MO	RH/C	CNTMNT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -031-0308A -A 1-FCV -031-0308/ZS1 -A 061 IIR CHILLER A CMS ISLN VALVE LIMIT SW EA74020100			739' 2"	IIR	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON PHASE A
					A	1MO	RH/C	CNTMNT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -031-0308B -A 1-FCV -031-0308/ZS2 -A 061 IIR CHILLER A CMS ISLN VALVE LIMIT SW EA74020100			739' 2"	IIR	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON PHASE A
					A	1MO	RH/C	CNTMNT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.
WBN-1-ZS -031-0309A -B 1-FCV -031-0309/ZS1 -B 062 IIR CHILLER A CMS ISLN VALVE LIMIT SW EA74020100			738' 4"	ANN	A	100D	L	TO OPEN AND REMAIN OPEN
					A	100D	MS/C	PREVENTING SOL REENERGIZATION
					A	100D	FW/C	AND VLV OPENING UPON PHASE A
					A	1MO	RH/C	CNTMNT ISOL RESET. PROVIDE POS
					A	1MO	CV/C	INDICATION FOR PAM.

PREPARER/DATE WCG 9/10/86 R 1 CAG R 2 WCD R ---
 CHECKED/DATE NAP 9/10/86 2-23-89 6-8-90
JDH CAR
2-23-89 6/8/90

PAGE A-6
 R2

PRINT DATE: 06/05/90

BINDER NO. : WBNEQ-IZS -004
 MANUFACTURER : NAMCO
 PAGE 6 OF 7

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-ZS -031-0309B -B 1-FCV -031-0309/ZS2 -B 062 IIR CHILLER A CWS ISLN VALVE LIMIT SW	EA74020100		738' 1" ANN 79K3-824495-1		A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON PHASE A CNTMNT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
WBN-1-ZS -031-0326A -A 1-FCV -031-0326/ZS1 -A 105 IIR CHILLER B CWR ISLN VALVE LIMIT SW	EA74020100		733' 9" ANN 79K3-824495-1		A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON PHASE A CNTMNT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
WBN-1-ZS -031-0327A -B 1-FCV -031-0327/ZS1 -B 103 IIR CHILLER B CWR ISLN VALVE LIMIT SW	EA74020100		734' 1" IIR 79K3-824495-1		A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON PHASE A CNTMNT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
WBN-1-ZS -031-0327B -B 1-FCV -031-0327/ZS2 -B 103 IIR CHILLER B CWR ISLN VALVE LIMIT SW	EA74020100		733' 3" IIR 79K3-824495-1		A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON PHASE A CNTMNT ISOL RESET. PROVIDE POS INDICATION FOR PAM.
WBN-1-ZS -031-0329A -B 1-FCV -031-0329/ZS1 -B 103 IIR CHILLER B CWR ISLN VALVE LIMIT SW	EA74020100		733' 5" IIR 79K3-824495-1		A A A A	100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	TO OPEN AND REMAIN OPEN PREVENTING SOL REENERGIZATION AND VLV OPENING UPON PHASE A CNTMNT ISOL RESET. PROVIDE POS INDICATION FOR PAM.

PAGE A-7

R2

PREPARER/DATE WCG 9/10/86 R 1 R 2 R
 CHECKED/DATE NAP 9/10/86 CAG WCD
2-27-89 6-8-89
JDH CSH
2-23-89 6/8/90

PRINT DATE: 06/05/90

BINDER NO. : WBNEQ-IZS -004
MANUFACTURER : NAMCO
PAGE 7 OF 7

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-1-ZS -031-0329B -B 1-FCV -031-0329/ZS2 -B 103 IIR CHILLER B CHR ISLN VALVE LIMIT SW EA74020100			732' 5" IIR 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
				A	100D	MS/C	PREVENTING SOL REENERGIZATION
				A	100D	FW/C	AND VLV OPENING UPON PHASE A
				A	1MO	RH/C	CNTMNT ISOL RESET. PROVIDE POS
WBN-1-ZS -031-0330A -A 1-FCV -031-0330/ZS1 -A 109 IIR CHILLER B CMS ISLN VALVE LIMIT SW EA74020100			734' 5" ANN 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
				A	100D	MS/C	PREVENTING SOL REENERGIZATION
				A	100D	FW/C	AND VLV OPENING UPON PHASE A
				A	1MO	RH/C	CNTMNT ISOL RESET. PROVIDE POS
WBN-1-ZS -031-0330B -A 1-FCV -031-0330/ZS2 -A 110 IIR CHILLER B CHR ISLN VALVE LIMIT SW EA74020100			733' 9" ANN 79K3-824495-1	A	100D	L	TO OPEN AND REMAIN OPEN
				A	100D	MS/C	PREVENTING SOL REENERGIZATION
				A	100D	FW/C	AND VLV OPENING UPON PHASE A
				A	1MO	RH/C	CNTMNT ISOL RESET. PROVIDE POS
				A	1MO	CV/C	INDICATION FOR PAM.

PAGE A-8

PREPARER/DATE WCG 9/10/86 R 1 R 2 R
 CHECKED/DATE NAP 9/10/86 CAG WCG
 2-23-89 JDH 6-8-90
 2-23-89 CAH 6/8/90

R2

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1

BINDER TITLE EA740 Limit Switches COMPUTED wcj DATE 5-22-86 R R

Manufactured between February 20, 1978 and October 1, 1981 CHECKED map DATE 6/27/86

TAB B - Checklist for evaluation of environmental qualification
including summary and conclusion

BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 CAG JDH

SWITCHES MANUFACTURED BETWEEN 2/22/89 10/15/90

FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH CST
2/22/89 10/16/90

A. DOCUMENTATION (See Note)

Equipment Description Limit Switch

Vendor/Manufacturer NAMCO

Equipment Model No.(s) EA740-20100

EA740-50000

EA740-50001

QUALIFICATION REPORTS (See Note)

*(1) Title/Number/Revision Qualification of RIMS B70 851017 104
NAMCO Controls Limit Switch Model EA-740 to
IEEE Standards 344 ('75), 323 ('74), and
382 ('72) DATE 2/20/78

(2) Title/Number/Revision Test Plan 8/31/77 RIMS B70 851031 007
Qualification of Series EA-180 and EA-740
Switches for Class IE use in Nuclear Power
Plants in Compliance with IEEE Standard
382-1972 DATE 8/31/77

(3) Title/Number/Revision Supplement 02 to QTR RIMS B70 870121 003
111 - Qualification by Similarity
Presentation to Support the Change of
Contact Block/Carrier Material DATE 12/16/86

(4) NAMCO Report No. QTR 140, Dated 4/19/84. (Selected Parts)
(C-82 thru C-92)

(5) NAMCO Report No. QTR 155, Dated 10/5/87. (Selected Parts)
(D-161 thru D-165)

(6) NAMCO Report No. QTR 107, Dated 4/6/82. (Selected Parts)
(C-81A thru C-81D)

(7) NAMCO Report No. QTR 111, Dated 10/1/81. (Selected Parts)
(C-75 thru C-78)

OTHER (ANALYSIS, VENDOR DATA, ETC.)

(8) TVA Environmental Drawing 47E235-41 R1, DCA P-04104-01-0, and
S-09715-10,-11,-12

(9) TVA Environmental Drawing 47E235-42 R2, DCA P-04104-02-0,
-03-0,-02-1,-05-0, and S-09715-02,-03,-04,-05,-13,-14,-15

(10) TVA Environmental Drawing 47E235-44 R1

R3

R3 JDH
10/15/90

R3

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (11) TVA Environmental Drawing 47E235-45 R1, DCA P-04104-06-0, and S-09715-06,-07,-08,-09,-19
- (12) WBNTSR-051 R0 (B26 891129 202), Reduction of Beta Dose by Sheet Steel
- (13) WBNOSG4-008 R16 (B26 900717 201) System 30 Category and Operating Times Calculation
- (14) WBNOSG4-009 R7 (B26 900309 233) System 31 Category and Operating Times Calculation
- (15) WBN-EEB-MS-TI06-0017 (B26 900202 410) 120V AC Vital Instrument Power Voltage Profile

R3

*Unless specified otherwise, all references made herein are to this report.

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 2 OF 28
 R 1 R 3
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 CAG JDH
 SWITCHES MANUFACTURED BETWEEN 2/22/89 9/25/90
FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH CSH
2/22/89 10/16/90

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES _____

- 1. Unqualified lever arms _____ | R3
- 2. Unqualified gaskets _____ | R3

COMMENTS/RECOMMENDATIONS The required operating environments, normal and accident, have been reviewed for each switch location identified in TAB A. All switches are qualified to the worst case combination of these environmental parameters. This includes consideration of peak levels and profiles.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 3 OF 28

BINDER TITLE NAMCO EA740 LIMIT COMPUTED wcr DATE 5-22-86
SWITCHES MANUFACTURED BETWEEN _____ R _____ R _____
FEBRUARY 20, 1978 AND OCTOBER 1, 1981 CHECKED nup DATE 6/27/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

_____ Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

X Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS The date codes on the limit switches (TAB F) indicate that all switches were manufactured in the year of 1979.

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET
IEEE Standard 323-1971

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 4 OF 28
BINDER TITLE NAMCO EA740 LIMIT SWITCHES MANUFACTURED BETWEEN FEBRUARY 20, 1978 AND OCTOBER 1, 1981 COMPUTED wcjr DATE 6/25/86 R R
CHECKED nap DATE 6/27/86

D. QUALIFICATION METHODOLOGY

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS This test provides generic group qualification for EA-740 series limit switches. Model EA-740-20000 was selected for test purposes and is identical to models of the same number at Watts Bar. Other models of the EA-740 series have been qualified with supporting supplementary testing and similarity discussions. See TAB C, Section 3 for similarity evaluation.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 5 OF 28
 R 1 R _____
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 *JDH*
 SWITCHES MANUFACTURED BETWEEN FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 *JDH*
 2-22-89

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Limit Switch</u>	<u>Limit Switch</u>	<u>TAB D-1, Page D-5</u>
(2) Manufacturer	<u>NAMCO</u>	<u>NAMCO</u>	<u>TAB D-1, Page D-5</u>
(3) Model Number(s)	<u>EA-74020100</u>	<u>EA-74020000</u>	<u>Page D-5</u>
	<u>EA-74050000</u>	_____	_____
	<u>EA-74050001</u>	_____	_____
	_____	_____	_____
(4) Serial Number(s)	<u>See comments</u>	<u>See comments</u>	<u>See comments</u>
	_____	_____	_____
(5) Identify Component- Unique checksheet attached:	<u>NA</u>	<u>NA</u>	<u>NA</u>

R1

JUSTIFICATION/COMMENTS NAMCO Limit Switches do not have serial numbers but date codes stamped on the conduit entrance of the switch. These are documented in TAB F (Date Code System described in TAB E, Section 1). Field Verification (TAB F) has confirmed that all limit switches covered in TAB A have a date code of Feb, 1979. Similarity of the different model numbers is discussed in TAB C, Section 3. Contract Certification of Compliance for these switches found in TAB E, Section 1: Documents Qualification to the test reports found in TAB D.

R1

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 6 OF 28
 R 1 R
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 2-22-89
 SWITCHES MANUFACTURED BETWEEN
 FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JOK
2-22-89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Conduit Seals	<u>Required</u>	<u>Yes</u>	<u>TAB D, p D-10</u> R1
Connector Seals	<u>NA</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>None</u>	<u>NA</u>	<u>NA</u>
Physical Configuration	<u>None</u>	<u>NA</u>	<u>NA</u>
Other	<u>See comments (1) and (2)</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS (1) For installation instructions refer to EA749 90002 (TAB H, Section 1). Mounting and connection requirements are also addressed in TAB D - TEST PLAN page 1, Section (2). Wire passage through switch conduit entrance must be sealed in such a way as to maintain switch integrity under required service conditions. All switches inside containment must have a qualified Conax seal (Ref. to generic binder WBNEQ-CSC-001).

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 6a OF 28 | R1
R 1 R
BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 5/22/86 JDH
2-22-89
SWITCHES MANUFACTURED BETWEEN
FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH
2-22-89

F. INSTALLATION INTERFACES (continued)

JUSTIFICATION/COMMENTS (Continued)

(2) Although it was not considered part of the qualification test,
an operating lever is required for proper operation of the switch.
The lever and roller shall be of metal construction. Nylon | R1
rollers are not acceptable and are controlled through TVA's
Maintenance Program (see TAB G).

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 7 OF 28
 R 1 R _____
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 JAH
 SWITCHES MANUFACTURED BETWEEN _____
2-22-89
 FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JAH
2-22-89

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (Yes/No/NA)? (Note below.)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>TAB D-1, p D-6</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>TAB D-1, p D-6</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>TAB D-1, p D-6</u>
Radiation	<u>Yes</u>	<u>TAB D-1, p D-7</u>
Wear	<u>Yes</u>	<u>TAB D-1, p D-6</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>TAB D-1, p D-7</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>TAB D-1, p D-10</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>TAB D-1, p D-11</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>TAB D-1, p D-38</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)? Yes
See Comment (2).

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately document (Yes/No/NA)? No
See Comment (1) (Reference TAB D-1, Appendix E, page 1).

JUSTIFICATION/COMMENTS (1) Test equipment and calibration dates were recorded; however, test equipment accuracies were not documented in the test report. (2) The test switch was not used in the seismic qualification, however, it was seismically conditioned by subjecting it to all vibrations contained in the seismic tests (Ref. TAB D-1, pages D-8 and D-10)

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 8 OF 28
 R 1 R _____
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 2-22-89
 SWITCHES MANUFACTURED BETWEEN _____
 FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH
2-22-89

H. AGING

(1) Was aging considered in the qualification program
 (Yes/No/NA)? Yes (Reference: TAB D-1 pages D-6 and D-7 | R1
 _____).

JUSTIFICATION/COMMENTS None

(2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>TAB D-1 Pages D-6 and D-34</u>
Radiation exposure	<u>Yes</u>	<u>TAB D-1 Pages D-7 and D-36</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>TAB D-1 Page D-32</u>
Operational (electrical/mechanical/ process) stress aging	<u>Yes</u>	<u>TAB D-1 Pages D-6 and D-35</u>

R1

JUSTIFICATION/COMMENTS None

(3) Were all known synergistic effects which are believed to have a
 significant effect on equipment performance considered in the
 aging program (Yes/No/NA)? Yes (Reference: _____
See TAB C. Section 16 _____).

JUSTIFICATION/COMMENTS None

(4) Thermal Aging:

(a) Was thermal aging considered in the qualification program
 (Yes/No/NA)? Yes (Reference: TAB D-1, page D-6 | R1
 _____).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 9 OF 28
 R 1 R _____
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/26/86 2-22-84
 SWITCHES MANUFACTURED BETWEEN _____
 FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH
 2-22-89

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (Yes/No/NA)? Yes (Reference: TAB E, Section 2).

JUSTIFICATION/COMMENTS See also Materials Analysis in TAB C, Section 6.

- (c) Was the basis for thermal aging identified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D-1, Page D-6, footnote "+"). | R1

JUSTIFICATION/COMMENTS See Materials Analysis in TAB C, Section 6.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D-1, page D-6, footnote "+"). | R1

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
<u>Temperature</u>	<u>75°F/110°F/120°F</u>	<u>NA</u>	<u>75°F/110°F/120°F</u>
<u>Time</u>	<u>40 yrs</u>	<u>NA</u>	<u>40/14.2/8.6 yrs.</u>

JUSTIFICATION/COMMENTS Qualified life established by Materials Analysis in TAB C, Section 6.

- (e) Was the Arrhenius methodology used for accelerated aging (Yes/No/NA)? Yes (Reference: NA).

JUSTIFICATION/COMMENTS See Materials Analysis in TAB C, Section 6.

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (Yes/No/NA)? Yes (Reference: NA).

JUSTIFICATION/COMMENTS See Materials Analysis in TAB C, Section 6.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 10 OF 28
R 1 R _____
BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 2-22-89
SWITCHES MANUFACTURED BETWEEN _____
FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDK
2-22-89

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? NA
(Reference: NA).

JUSTIFICATION/COMMENTS Regression line not used.

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? NA (Reference: NA).

JUSTIFICATION/COMMENTS Qualified life determined by
Material Analysis rather than accelerated aging test on
the assembled device.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: TAB D-1, pages
D-7 and D-36). R1

JUSTIFICATION/COMMENTS None

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? No
(Reference: NA).

JUSTIFICATION/COMMENTS Assembled test specimen
irradiated to 204 megarads.

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? NA
(Reference: NA).

JUSTIFICATION/COMMENTS 204 Megarads exposed the switch
to a greater radiation dose than expected for the service
life of the switch plus accident conditions and margins.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 11 OF 28

R 1 R

BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 WJH

SWITCHES MANUFACTURED BETWEEN FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH

2-22-89

H. AGING (Continued)

(d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: _____)

TAB D-1, p D-36 _____). |R1

Plant normal ambient radiation dose (rd) 2 x 10⁷

Test exposure dose (rd) 2.04 x 10⁸

Test exposure dose rate (rd/hr) 1.2 x 10⁶

Test exposure source type (e.g., Co-60 gamma) Co-60 Gamma

JUSTIFICATION/COMMENTS None

(6) Vibration (non-seismic) Aging:

(a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* Yes (Reference: _____)

TAB D-1, page D-32 _____). |R1

JUSTIFICATION/COMMENTS None

(b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes

(Reference: TAB D-1, page D-32 _____). |R1

JUSTIFICATION/COMMENTS See TAB C, Section 7

(7) Operational Stress Aging:

(a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: TAB D-1, pages

D-47 and D-48 _____). |R1

JUSTIFICATION/COMMENTS Wear cycling - 100,000 cycles.

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. |R1

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 12 OF 28
R 1 R _____
BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 2-22-89
SWITCHES MANUFACTURED BETWEEN _____
FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 TDH
2-22-89

H. AGING (Continued)

- (7) (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D-1 page D-6).

R1

JUSTIFICATION/COMMENTS See Section P(1) for additional discussion

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes-See TAB B, pg 16 (Reference: NA).

R1

Qualified life (Document in QMDS) 40 years

JUSTIFICATION/COMMENTS See TAB C - Material Analysis for qualified life.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? No - See TAB B, page 16 for discussion (Reference: NA).

R1

Replacement Intervals (Document in QMDS) See QMDS - TAB G.

JUSTIFICATION/COMMENTS None

WBNEQ-IZS-004

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-15 was deleted per revision 1.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 13a OF 28

R 1 R _____

BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 5/22/86 Adel

SWITCHES MANUFACTURED BETWEEN FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDK

2-22-89

H. AGING (Continued)

Qualified Life - H(8)

The qualified life for all equipment covered by this binder is 40
years through periodic refurbishment. For further discussion on
Materials Analysis and Arrhenius Methodology, refer to material
analysis discussion found in TAB C, Section 6. The scheduled
maintenance service times shown below come directly from this
Arrhenius curve.

<u>Max Normal Ambient</u>	<u>Service Time</u>
<u>75°F</u>	<u>> 40 yrs.</u>
<u>110°F</u>	<u>14.2 yrs.</u>
<u>120°F</u>	<u>8.6 yrs.</u>

...

The OMDS Section found in TAB G will document the limit switches
which require refurbishment and the appropriate schedule.

BINDER NO. WBNEO-IZS-004 PLANT WBN UNIT(S) 1 SHEET 14 OF 28
 R. 1 R. 2
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/26/86 CAG WCG
 SWITCHES MANUFACTURED BETWEEN 2/22/89 6-6-90
 FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH CAH
2/22/89 6/8/90

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

<u>Material/Property/Function</u> <u>Top/Bottom</u>	<u>Radiation</u> <u>Threshold</u>	<u>Reference</u>	<u>Activation</u> <u>Energy</u>	<u>Reference</u>
(a) <u>*Silicone Rubber/Gaskets</u>	<u>NA</u>	<u>NA</u>	<u>1.14 eV</u>	<u>TAB C,</u> <u>Section 6</u>
(b) <u>EPDM/O-Rings</u>	<u>NA</u>	<u>NA</u>	<u>0.94 eV</u>	<u>TAB C,</u> <u>Section 6</u>
(c) <u>*Contact Block</u> <u>Glass Filled Polyester/</u>	<u>NA</u>	<u>NA</u>	<u>0.50 eV</u>	<u>TAB C,</u> <u>Section 6</u>
(d) <u>Asbestos Filled</u> <u>Phenolic/Contact Carrier</u>	<u>NA</u>	<u>NA</u>	<u>0.99 eV</u>	<u>TAB C,</u> <u>Section 6</u>
(e) <u>Lubricant</u>	<u>NA</u>	<u>NA</u>	<u>Not</u> <u>Required</u>	<u>TAB C,</u> <u>Section 6</u>

JUSTIFICATION/COMMENTS See TAB C, Section 6 for further analysis.

*NOTE: See Page E-14 for change history of materials thru January 9,
1984. Also see Page C-74A for current contact block and
carrier material.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 15 OF 28
R 1 R _____
BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 2-22-89
SWITCHES MANUFACTURED BETWEEN _____
FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 2-22-89 JON

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS.

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (Yes/No/NA)? Yes
(Reference: TAB D-2, page D-60)

Identify Acceptance Criteria: See page B-19

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (Yes/No/NA)? Yes
(Reference: TAB D-1, page D-6 and pages D-35, D-36, D-37, D-39 and D-40)

Identify baseline and functional testing: See page B-19

JUSTIFICATION/COMMENTS None

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (Yes/No/NA)? Yes
(Reference: TAB D-1, pages D-39 and D-40)

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 16 OF 28

BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCS DATE 6/25/86 R R

SWITCHES MANUFACTURED BETWEEN FEBRUARY 20, 1978 AND OCTOBER 1, 1981 CHECKED rap DATE 6/27/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

Item J(1) - (1) Failure of one or more contact pairs to test as open when the unit is in such a condition that said contacts would normally be open.

(2) Failure of one or more contact pairs to test as closed when the unit is in such a condition that said contacts would normally be closed. (3) Shorting of any contact to the unit housing. (4) Shorting of any two contacts which are not of the same pair. (5) The opening of a closed contact for more than two milliseconds during seismic testing.

Item J(2) - (1) Before: o open and closed circuit performance measured and recorded.

o meggar and conductivity (amps) during WEAR TEST (0.086A@100VDC).

o meggar and conductivity (amps) during radiation test and seismic test (86mA@100VDC).

(2) During: o meggar and conductivity during LOCA Test (.086A@100VDC).

(3) After: o meggar and conductivity (0.086A@100VDC).

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 17 OF 28
 R 1 R _____
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 5/22/86 WCG
 SWITCHES MANUFACTURED BETWEEN FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDA
 2-22-89 2-22-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____)
See J(5) comments page B-22) | R1

JUSTIFICATION/COMMENTS None

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>See Comments</u>	<u>NA</u>
Load	<u>See Comments</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		
_____	_____	_____
_____	_____	_____

JUSTIFICATION/COMMENTS See J(5) Comments page B-22

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS - (Continued)

(b) Parameter	Specific Accident Conditions	Reference
Voltage	<u>See Comments</u>	<u>NA</u>
Load	<u>See Comments</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)	_____	_____

JUSTIFICATION/COMMENTS See J(5) Comments page B-22

(c) Parameter	Demonstrated Conditions	Reference
Voltage	<u>125V AC/DC</u>	<u>TAB D-1, p D-6</u> <u>TAB I, p I-3</u>
Load	<u>100VDC/86MA, 100VAC/500MA</u>	<u>TAB D-1, p D-6</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		
Open Contact Resistance	<u>40,000 OHMS</u>	<u>TAB D-1, p D-40</u>
Closed Contact Open < 2ms	<u>< 2ms</u>	<u>TAB D-1, p D-26</u>

JUSTIFICATION/COMMENTS The typical application of these limit switches is in the control circuits of, for example, solenoid operated valves. These circuits operate at 120VAC or 125VDC with current ratings of approximately 0.3 to 1.3 amps. This is well within the UL and nameplate ratings of 20 amps at 125VAC and 5 amps at 125VDC.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 19 OF 28 | R1
R 1 R _____
BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/20/86 BJJ
SWITCHES MANUFACTURED BETWEEN FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH
2-22-89 2-22-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS -
(Continued)

J(5) - JUSTIFICATION/COMMENTS (Continued)

The demonstrated load of 0.5 amps @ 100VDC for mechanical aging and
0.086 amps @100VDC for all other performance tests is considered
adequate for the following reasons:

- (1) Low voltages and currents may not break down the films/oxides
and therefore provide little contact surface renewal.
- (2) When switches are operated at rated voltages and currents, the
contact surfaces tend to be self-cleaning and/or the potential
of the circuit is sufficient to break down films or oxides that
might form on the contact faces.
- (3) Since TVA's standard design practices prevent circuits from
exceeding the UL ratings of the contacts, the 100VDC and 0.086
amp load used for testing is conservative and adequate
considering items (1) and (2) above.

While there are no plant specific requirements with regard to
contact bounce and open contract resistance minimums, the values
demonstrated are considered adequate. At 40,000 ohms, there would
be a slight leakage current of approximately 3.1 milliamps for a
typical 125V circuit. This small leakage current should not
provide enough amperage to cause any adverse circuit operations.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 20 OF 28
 R 1 R _____
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 LDH
 SWITCHES MANUFACTURED BETWEEN 2-22-89
 FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH
2-22-89

K.1 REQUIRED OPERATING ENVIRONMENT - UPPER COMPARTMENT

Reference Environmental Drawing No. 47E235-41 | R1

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>110</u> | (a) Temperature (°F) <u>120</u> |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>1 x 10⁶</u> | (d) Radiation (rd) <u>NA</u> R1 |
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist up to eight hours per excursion and will occur less than 1 percent of the plant life (effect on qualified life is negligible - (See generic position in Binder No. WBNEQ-GEN-001).
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|--|-------------------------------------|
| (a) Temperature (°F) <u>161</u> | Accident type <u>LOCA/HELB</u> R1 |
| (b) Pressure (psig) <u>10.9</u> | Accident type <u>LOCA/HELB</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>4.7x10⁸ beta</u>
<u>3.8x10⁷ gamma</u> | Accident type <u>LOCA</u> R1 |
| (e) Spray Type <u>*</u> | Accident type <u>LOCA/HELB</u> |

*0.19 molar H₃BO₃ (2000 ppm Boron), 0.033 molar NaOH, resulting in a pH of 8.3 at 25°C. The duration of the containment spray is 30 days, at a flow rate equal to 9500 gal/min. or 0.92 gpm per square foot of containment. | R1

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 20a OF 28 |R1
 R 1 R
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 WJH
 SWITCHES MANUFACTURED BETWEEN FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH
2-22-89
2-22-89

K.2 REQUIRED OPERATING ENVIRONMENT - LOWER COMPARTMENT

Reference Environmental Drawing No. 47E235-42 |R1

- | | |
|--|----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>120</u> | (a) Temperature (°F) <u>130</u> |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>100</u> |
| (d) Radiation (rd) <u>2×10^7</u> | (d) Radiation (rd) <u>NA</u> R1 |
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist up to eight hours per excursion and will occur less than 1 percent of the plant life (effect on qualified life is negligible - (See generic position in Binder No. WBNEQ-GEN-001).
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|---|--------------------------------|
| (a) Temperature (°F) <u>327</u> | Accident type <u>LOCA/HELB</u> |
| (b) Pressure (psig) <u>10.9</u> | Accident type <u>LOCA/HELB</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>4.7×10^8 beta</u> | Accident type <u>LOCA</u> R1 |
| (e) Spray Type <u>*</u> | Accident type <u>LOCA/HELB</u> |

*0.19 molar H₃BO₃ (2000 ppm Boron), 0.033 molar NaOH resulting in a pH of 8.3 at 25°C. The duration of the containment spray is 30 days, at a flow rate equal to 9500 gal/min. or 0.92 gpm per square foot of containment. |R1

K.3 REQUIRED OPERATING ENVIRONMENT - ANNULUS

Reference Environmental Drawing No. 47E235-44

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>110</u> | (a) Temperature (°F) <u>120</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>1x10⁶</u> | (d) Radiation (rd) <u>NA</u> |

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist up to eight hours per excursion and will occur less than 1 percent of the plant life (effect on qualified life is negligible - (See generic position in Binder No. WBNEQ-GEN-001).

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | | |
|---|--------------------------------|----|
| (a) Temperature (°F) <u>133.7</u> | Accident type <u>LOCA/HELB</u> | R3 |
| (b) Pressure (psig) <u>ATM(-)</u> | Accident type <u>NA</u> | |
| (c) Humidity (%) <u>61</u> | Accident type <u>LOCA/HELB</u> | R3 |
| (d) Radiation (rd) <u>*1.2x10⁷</u> | Accident type <u>LOCA</u> | |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> | |

*Includes beta dose of 6×10^5 rads.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 20c OF 28 | R1
 R 1 R
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 WCG
 SWITCHES MANUFACTURED BETWEEN FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JWH
2-22-84
2-22-89

K.4 REQUIRED OPERATING ENVIRONMENT - IIR

Reference Environmental Drawing No. 47E235-45 | R1

- (1) Normal Max (2) Abnormal Max.
- | | |
|--|-----------------------------------|
| (a) Temperature (°F) <u>75</u> | (a) Temperature (°F) <u>120</u> |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>60</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>3.5×10^5</u> | (d) Radiation (rd) <u>NA</u> R1 |
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist up to eight hours per excursion and will occur less than 1 percent of the plant life (effect on qualified life is negligible - (See generic position in Binder No. WBNEQ-GEN-001).
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|--|-------------------------------------|
| (a) Temperature (°F) <u>327</u> | Accident type <u>LOCA/HELB</u> |
| (b) Pressure (psig) <u>10.9</u> | Accident type <u>LOCA/HELB</u> R1 |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>4.7×10^8 beta</u>
<u>1×10^7 gamma</u> | Accident type <u>LOCA</u> R1 |
| (e) Spray Type <u>*</u> | Accident type <u>LOCA/HELB</u> |

*0.19 molar H₃BO₃ (2000 ppm Boron), 0.033 molar NaOH resulting in a pH of 8.3 at 25°C. The duration of the containment spray is 30 days, at a flow rate equal to 9500 gal/min. or 0.92 gpm per square foot of containment.

K. REQUIRED OPERATING ENVIRONMENT (Continued) | R3

Comments (duration/peak/profile/spray composition and pH, margin, etc.): None

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: _____)

See Tab G | R3

(7) Subject to submergence (Yes/No/NA)? No (Reference: _____)
TAB C, Section 1).

Identify initiation time and duration of submergence: NA

(8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes
 (Reference: See Section P, 2.0 (12)(b), page B-35, B-36,

B-37 and B-38 | R3

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

See Section P, 2.0 (12)(b), page B-35, B-36 & B-37 and B-38 | R3

(9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Section A</u>	_____
_____	_____
_____	_____

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>30 days+</u>	TAB D-1, p D-11 & P D-41 thru D-46
Temperature (°F)	<u>327</u>	<u>356</u>	TAB D-1, p D-42
Pressure (psig)	<u>12.3</u>	<u>83 ***</u>	TAB D-1, p D-41 thru D-46
Relative Humidity (%)	<u>100</u> See TAB C, p C-71 & C-72	<u>100</u> See TAB C, p C-71 & C-72	TAB D-1, p D-41 thru D-46 See TAB C, p C-71 & C-72
Chemical Spray*			
Radiation (rd)**	<u>5.12x10⁷beta</u> <u>6x10⁷gamma</u>	<u>8</u> <u>2.04x10 gamma</u>	TAB D-1, p D-15 TAB C, p C-3
Submergence	<u>NA</u>	<u>NA</u>	

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type. (Reference also p. B-36 of this TAB.) |R2

***7 PSI subtracted from peak pressure of 90 psig due to test instrument miscalibration (Appendix E).

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	TAB C, Section 2
Pressure	<u>Yes</u>	See L(1)
Relative Humidity	<u>Yes</u>	See L(1)
Chemical Spray	<u>Yes</u>	TAB C, pages C-71 & C-72
Submergence	<u>NA</u>	TAB C, page C-3

JUSTIFICATION/COMMENTS +Justification for long term operability (30 days vs. 100 days) is given in TAB C, Section 2.

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
(Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	+29, F +574%	Yes
Pressure: +10% but no more than 10 psig	70.7 psig 155% 7	Yes
Radiation: +10% of accident dose	9.3 x10	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	TAB C, Section 2	Yes
Voltage: ±10% of rated value	NA	NA
Frequency: ± 5% of rated value	NA	NA
Environmental Transient: the initial transient and the peak temperature applied twice	2 Dwells	Yes
Vibration: +10% added to acceleration	217% See Comment	Yes

R2

JUSTIFICATION/COMMENTS Per TVA Standard Specification
SS-E18-12.01 - Seismic Requirements for Category I Electrical and I&C Equipment - these limit switches should be tested to 3 g's horizontal and 2 g's vertical. Since NAMCO verified in their test report (page 5) that cross-coupling was not significant, the single axis test performed in each of the 3 axes to 9.52 g's was more than adequate.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 23 OF 28

R 1 R

BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 JDK

SWITCHES MANUFACTURED BETWEEN FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDK

2-22-89

M. OPERABILITY TEST RESULTS

(1) Identify the safety function(s) of this equipment:
(Reference: See TAB A)
_____).

JUSTIFICATION/COMMENTS None

(2) Did the equipment perform its intended function during the simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: TAB D-1, pages D-39 and D-40) | R1
_____).

JUSTIFICATION/COMMENTS None

(3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (Yes/No/NA)? Yes (Reference: TAB D-1, pages D-39 and D-40) | R1
_____).

JUSTIFICATION/COMMENTS None

(4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (Yes/No/NA)? Yes (Reference: See TAB C, Section 2)
_____).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 23a OF 28
R _____ R _____
BINDER TITLE NAMCO EA740 LIMIT COMPUTED /RI ~~0/4~~ DATE 2-22-84
SWITCHES MANUFACTURED BETWEEN
FEB. 20, 1978 AND OCT. 1, 1981 CHECKED /RI JDH DATE 2-22-89

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: See TAB C, Pages C-100 and C-101)

JUSTIFICATION/COMMENTS See TAB C, Pages C-100 and C-101

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 24 OF 28

BINDER TITLE NAMCO EA740 LIMIT COMPUTED wes DATE 5-22-86 R R
SWITCHES MANUFACTURED BETWEEN FEBRUARY 20, 1978 AND OCTOBER 1, 1981 CHECKED map DATE 6/27/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See QMDS - TAB G.

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 25 OF 28
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WAP DATE 6/25/86
 SWITCHES MANUFACTURED BETWEEN _____ DATE _____
FEBRUARY 20, 1978 AND OCTOBER 1, 1981 CHECKED WAP DATE 6/27/86

O. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|--|---|
| (1) Documented evidence of qualification adequate
(Have all assumptions, mathematical models, and
all extrapolations of test data used in an
analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary)
taken to the specified qualification level
adequately justified? | <u>NA</u> |
| (3) Choice of qualification methodology adequately
justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements
identified? | <u>NA</u> |
| (b) Were specific features and failure modes and
effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used
together with appropriate justification for
their use? | <u>Yes</u>
<u>TAB C,</u>
<u>Section 6</u>
<u>Yes-See</u> |
| (d) Were environmental parameters which affect
equipment performance identified? | <u>TAB C,</u>
<u>Section 6</u> |
| (5) Adequate similarity between equipment and test
specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u>
<u>TAB C,</u>
<u>Section 6</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u>
<u>NA-See</u> |
| (b) Equipment aged to end of life condition prior to
application of DBE conditions? | <u>Section P(4)</u> |
| (c) Absence of preaging in test/analysis justified? | <u>Yes-See</u>
<u>Section P(4)</u> |
| (d) Materials susceptible to thermal/radiation
aging identified? | <u>Yes-See TAB C,</u>
<u>Section 6</u> |

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 26 OF 28
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCS DATE 5-22-86
 SWITCHES MANUFACTURED BETWEEN FEBRUARY 20, 1978 AND OCTOBER 1, 1981 CHECKED map DATE 6/27/86

0. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|---|---------------------------------|
| (e) Normally operating state of device (e.g., normally energized) considered? | <u>Yes-See Section P(3)</u> |
| (7) Qualified life or replacement schedule established? | <u>Yes</u> |
| (8) Criteria regarding temperature/pressure exposure satisfied? | <u>Yes</u> |
| (a) Peak temperature adequate | <u>Yes</u> |
| (b) Peak pressure adequate | <u>Yes</u> |
| (c) Duration adequate | <u>Yes</u> |
| (d) Required profile enveloped adequately | <u>Yes</u> |
| (e) Steam exposure adequate | <u>Yes</u> |
| (9) Criteria regarding test sequence satisfied? | <u>Yes</u> |
| (10) Criteria regarding spray satisfied? | <u>Yes</u> |
| (a) Was the spray testing done while under the extremes of pressure and temperature? | <u>Yes</u> |
| (b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant? | <u>Yes-See TAB C, Section 5</u> |
| (11) Criteria regarding submergence satisfied? | <u>NA</u> |
| (12) Criteria regarding radiation satisfied? | <u>Yes</u> |
| (a) Was dose rate considered? | <u>Yes</u> |
| (b) Was beta radiation considered? | <u>Yes-See Section P(2)</u> |
| (13) Criteria regarding operability status/mode satisfied? | <u>Yes</u> |
| (14) Criteria regarding test failures or anomalies satisfied? | <u>Yes</u> |

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 27 OF 28
 BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/26/86 R R
~~SWITCHES MANUFACTURED BETWEEN~~ CHECKED nap DATE 6/27/86
FEBRUARY 20, 1978 AND OCTOBER 1, 1981

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|-------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>NA</u> |
| | <u>Yes-See</u> |
| | <u>TAB C,</u> |
| | <u>Section 2</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| | <u>Yes-See</u> |
| | <u>TAB C,</u> |
| | <u>Section 16</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified. | <u>Yes</u> |

P. DISCUSSION

1. Aging - Section H(7)(b)

This device was subjected to 100,000 actuation cycles
during mechanical aging testing. This is equivalent
to an average of 208 actuations per month or approximately
7 actuations per day over the 40 year life of the plant.
This is judged to be in excess of the full open/close
actuation cycles the associated valves will be required

PAGE B.34

P. DISCUSSION (continued)

_____ to operate for normal plant operation. _____ |R2

_____ surveillance, and maintenance. Therefore the mechanical
_____ aging performed is adequate to demonstrate qualification
_____ over the forty year life of the plant. _____ |R2

2.0(12)(B)-Per TVA Drawings 47E235-41,42,44 and 45, the attenuated
_____ free field post-LOCA beta radiation dose contribution for
_____ inside primary containment is 4.7×10^8 rads. The limit
_____ switch internals will not, however, be subject to the
_____ unattenuated free field beta dose. The switch housing
_____ assembly consists of three rectangular parts; the
_____ Brownite alloy housing body (a corrosion resistant
_____ bronze casting alloy) and top and bottom stainless steel
_____ covers which are tightly bolted to the body. The minimum
_____ thickness is 1/8". Silicone rubber gaskets 0.030" thick
_____ are compressed between the housing and top and bottom
_____ covers at 20-inch pounds, creating a completely sealed
_____ unit that is water, oil, dust, and pressure tight,
_____ meeting NEMA type 1, 4, and 13 requirements. Also, all
_____ limit switches inside primary containment include a
_____ qualified seal. Therefore, all beta radiation sources

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 28a OF 28
R 1 R 2
BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/25/86 CAG WCP
SWITCHES MANUFACTURED BETWEEN 2-22-89 6-6-90
FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH CAH
2-22-89 6/8/90

P. DISCUSSION

will be external to the housing and subject to dose
attenuation due to the housing. The beta dose to the
switch internals will essentially be attenuated
completely by a factor of 0.009 due to the minimum metal
thickness (reference TVA Calculation No. WBNTSR-051 |R2
TAB C, Section 15 - which is conservative for the bronze
alloy housing). The gap created by the gasket is
sufficiently small to allow only a negligible fraction
of the unattenuated 4-pi geometry free field dose to
penetrate. However, as a conservatism to account for
the gap (without taking credit for attenuation due to
the silicone gasket), 10% of the unattenuated free field
dose is added to the dose attenuated by the metal
housing. Therefore, the 100-day beta dose to the switch
internals is conservatively estimated to be: 10%
attenuated contribution = $0.10 (4.7 \times 10^8) = 4.7 \times 10^7$
100% attenuated contribution = $0.009 (4.7 \times 10^8) =$
 4.23×10^6 . Total = 5.12×10^7 rads beta. Additionally,
the silicone gaskets themselves are not a concern. They
receive significant geometric shielding due to being
tightly compressed between the metal housing parts.
Based on the switch geometry, the outer gasket material

BINDER NO. WBNEQ-IZS-004 PLANT WBN UNIT(S) 1 SHEET 28b OF 28 | R1
R 1 R
BINDER TITLE NAMCO EA740 LIMIT COMPUTED WCG DATE 6/26/86 JDH
SWITCHES MANUFACTURED BETWEEN FEB. 20, 1978 AND OCT. 1, 1981 CHECKED NAP DATE 6/27/86 JDH
2-22-89

P. DISCUSSION (Continued)

_____ will be exposed to only a fraction of the unattenuated
_____ 4-pi geometry free field beta radiation dose. This
_____ unattenuated dose would be further reduced due to the
_____ angle of incidence into the narrow gap and attenuation
_____ due to the outer gasket material resulting in minimal
_____ dose to the innermost gasket material. The gasket width
_____ is approximately equal to the housing thickness
_____ (1/8 inch). Also, Target Rock Corp. has conducted tests
_____ on a similar silicone rubber gasket used in a similar
_____ application (reference EQ Binder WBNEQ-SOL-001, Section
_____ D, Page D-29) and found that after exposure to 185
_____ megarads of gamma radiation, embrittlement had occurred
_____ in the excess gasket material extending beyond the mated
_____ parts. The gasket material actually trapped between the
_____ mated parts was still flexible. Likewise, in our
_____ application, the gaskets would not be a concern even
_____ should they become brittle due to their being tightly
_____ sandwiched between the housing and housing covers in a
_____ static application; especially considering that the
_____ outer part of the gasket (least important) would exhibit
_____ the more significant degradation.

_____ The limit switches also contain EPDM O-rings used for

P. DISCUSSION

screw gaskets and the operating shaft seal. These
0-rings are enclosed by the metal screws and shaft
housing which shields them from the effects of beta
radiation. In conclusion: The total combined Beta and
Gamma radiation dose will equal 9.12×10^7 rads TID
(5.12×10^7 Beta + 4.0×10^7 Gamma) for accident condi-
tions. The accident radiation plus the large lower
compartment 40-year dose of 2.0×10^7 rads equal a total
radiation dose of 1.11×10^8 rads TID. These switches | R2
were tested to 2.04×10^8 rads which envelops our plant
requirements. Therefore, they are qualified for our | R2
worst case Gamma and Beta radiation dose.

3. 0(6)(e)-This device operates intermittently at relatively low
voltages and currents which will not result in a signifi-
cant heat rise.

4. 0(6)(b)&(c)-This equipment is being qualified to NUREG-0588,
Category II and therefore does not have to be aged
to an end-of-life condition prior to DBE testing.
The qualified life was determined by evaluating the
potential for significant thermal aging degradation
of the non-metallic materials of construction (See
TAB C, Section 6).

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
<u> </u>	<u> </u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>
TITLE <u>EA 180 SERIES</u>		CHECKED <u>WCP</u>	DATE <u>4/20/90</u>
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986			

TAB A

NOTES

1. No TAB A is provided because the equipment is not installed. TAB A will be added as a binder revision after notification via EQIR that the equipment has been installed.
2. See Page B-²~~Y~~ for source of Category and Operating Time assignments.
2 JOK 4/16/90 WCP 4/20/90

IZS-005

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/20/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>wcj</u>	DATE <u>4/20/90</u>	

A. DOCUMENTATION (See note at the end of this section)

Equipment Description Limit Switch

Vendor/Manufacturer NAMCO Controls

Equipment Model No.(s) See TAB A

QUALIFICATION REPORTS

- *1. Title/Number/Revision Generic Qualification of RIMS B26 900320 902
EA180 Series Limit Switches/NAMCO Controls Test Report No. QTR155/Revision 0 DATE Oct. 5, 1987
- 2. Title/Number/Revision Test Plan for the Generic RIMS B74 890818 501
Qualification of Series EA180 and EA740 Switches/
NAMCO Controls Test Plan No. QTP215/Revision 2 DATE Feb. 18, 1987

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- 3. TVA Environmental Drawing 47E235-41 R1 and DCA P-04104-01-0
- 4. TVA Environmental Drawing 47E235-42 R2 and DCA P-04104-02-0, -03-0, -02-1, -05-0
- 5. TVA Environmental Drawing 47E235-44 R1
- 6. TVA Environmental Drawing 47E235-45 R1 and DCA P-04104-06-0
- 7. TVA Environmental Drawing 47E235-76 R3
- 8. TVA Environmental Drawing 47E235-77 R1
- 9. TVA Environmental Drawing 47E235-78 R3
- 10. WBNTSR-051 R0 (B26 891129 202), Reduction of Beta Dose by Sheet Steel.
- 11. WBNNAL3-031 R1 (B45 880826 235), EGTS Room 100 Day LOCA Dose.
- 12. WBNTSR-018 R0 (B26 891106 203), Dose Grid Around the EGTS Filter Train.
- 13. WBNTSR-016 R0 (B26 890703 552), Location Specific Radiation Doses to Limit Switches in EGTS Room A16 Elevation 757.

*All references herein are to NAMCO Report QTR 155 unless otherwise stated.

BINDER NO. WBNEQ-IZS-005 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE EA 180 SERIES COMPUTED JDH DATE 4/16/90
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986 CHECKED WCJ DATE 4/20/90

OTHER (ANALYSIS, VENDOR DATA, ETC.)

<u>CATEGORY AND OPERATING TIMES</u>	<u>RIMS NUMBER</u>
14. System 3 (WBNOSG4-005 R10)	B26 900314 202
15. System 30 (WBNOSG4-008 R15)	B26 900309 231
16. System 31 (WBNOSG4-009 R7)	B26 900309 233
17. System 62 (WBNOSG4-013 R12)	B26 900327 200
18. System 63 (WBNOSG4-014 R11)	B26 900309 227
19. System 65 (WBNOSG4-015 R10)	B26 900309 226
20. Material Aging Calculation-WAC- 258 ³⁹² ^{JDH} ^{4/16/90}	B44 900403 801 ^{JDH} ^{4/16/90}

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCP</u>	DATE <u>4/20/90</u>	

B. CONCLUSION OF REVIEW (Check only one block)

- X Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

COMMENTS/RECOMMENDATIONS

*JDH
5/3/90
WCP
5/13/90* THE DCNS REFERENCED IN THE REVISION LOG WERE REVIEWED TO DETERMINE
LIMIT SWITCH ID, CATEGORY AND OPERATING TIMES, LOCATION, AND ELEVATION.

BINDER NO. WBNEQ-IZS-005 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE EA 180 SERIES COMPUTED JDH DATE 4/6/90
LIMIT SWITCHES MANUFACTURED
AFTER DECEMBER 1986 CHECKED WCJ DATE 4/20/90

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following
(Indicate Which Criteria is Applicable):

 X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588
Category I (IEEE 323-1974).

 Components are Qualified to the Criteria of NUREG-0588 Category II

JUSTIFICATION/COMMENTS

None

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE Standard 323-1974

IEEE Standard 344-1975

IEEE Standard 382-1972 (Pressurized Water Reactor portion only)

BINDER NO.	WBNEQ-IZS-005	PLANT	WBN	UNIT(S)	1	SHEET	OF
						R	R
BINDER TITLE	EA 180 SERIES	COMPUTED	JDH	DATE	4/6/90		
LIMIT SWITCHES MANUFACTURED							
AFTER DECEMBER 1986		CHECKED	WCA	DATE	4/20/90		

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS

This test provides generic group qualification for Model EA180 Series limit switches. The Model EA180-11302 selected for test purposes is identical to some of the equipment qualified by this binder. TAB C.2 contains a similarity evaluation which addresses the remainder of the equipment.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u> R <u> </u>	
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCS</u>	DATE <u>4/20/90</u>	

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
1. Equipment Type	<u>Limit Switches</u>	<u>Limit Switch</u>	TAB D <u>p. 3-1</u>
2. Manufacturer	<u>NAMCO Controls</u>	<u>NAMCO Controls</u>	TAB D <u>p. 3-1</u>
3. Model number(s)	<u>See TAB A</u>	<u>EA180-11302</u>	TAB D <u>p. 3-7</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
4. Serial Number(s)	<u>See Comment</u>	<u>3179/383</u>	TAB D <u>p 3-9,3-10</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
5. Identify Component- Unique checksheet attached:	<u>NA</u>		

JUSTIFICATION/COMMENTS

These limit switches do not have serial numbers but are provided with date codes per the manufacturer's date code system described on page 10-12 of the test report. (See TAB D.)

BINDER NO. WBNEQ-IZS-005 PLANT WBN UNIT(S) 1 SHEET OF
 R R
 BINDER TITLE EA 180 SERIES COMPUTED JDH DATE 4/6/90
 LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986 CHECKED WCSJ DATE 4/20/90

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (yes/no/NA)? (note below). If yes, enter requirement in QMDS; If No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	See Comment (1)	Yes	TAB D p. 5-16 4/24/90 JDH WCSJ 4/25/90
External Process Connections	<u>NA</u>	<u>No</u>	<u>NA</u>
Electrical Connections	<u>NA</u>	<u>No</u>	<u>NA</u>
Conduit Seals	<u>See Comment (2)</u>	<u>Yes</u>	<u>TAB D p. 4-5, 4-6</u>
Connector Seals	<u>NA</u>	<u>No</u>	<u>NA</u>
Orientation	<u>NA</u>	<u>No</u>	<u>NA</u>
Physical Configuration	<u>NA</u>	<u>No</u>	<u>NA</u>
Other	<u>See Comment (3)</u>	<u>Yes</u>	<u>TAB D p. 4-6</u>

JUSTIFICATION/COMMENTS

- 4/24/90 JDH ~~(1) For standard side mounting, use two 5/16 18 bolts. For long or wide mounting use four 1/4 20 bolts. All bolts must be grade 2 (minimum). Torque to 80-85 inch pounds (minimum).~~
- WCSJ 4/25/90 (2) For installation instructions refer to EA189 90008 on page 11-9 of QTR155. The conduit entrance must be sealed in such a way as to maintain the switch integrity under required service conditions (see TAB G).
- (3) Although it was not considered part of the qualification test, an operating lever is required for proper operation of the switch. The lever and roller shall be of metallic construction. Nylon rollers are not acceptable and are controlled through TVA's maintenance program (see TAB G).

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCJ</u>	DATE <u>4/20/90</u>	

G. TEST SEQUENCE

1. Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
a. Equipment inspected for damage	<u>Yes</u>	TAB D <u>pp. 3-5, 8-6</u>
b. Baseline performance measurements taken	<u>Yes</u>	TAB D <u>p. 8-12</u>
c. Equipment aged:		TAB D
Thermal	<u>Yes</u>	<u>pp. 6-2, 8-17</u>
Radiation	<u>Yes</u>	TAB D <u>pp. 6-1, 8-31</u>
Wear	<u>Yes</u>	TAB D <u>6-1, 8-25</u>
d. Vibration/seismic testing conducted	<u>Yes</u>	TAB D <u>p. 8-41</u>
e. Design basis event (DBE) exposure	<u>Yes</u>	TAB D <u>p. 8-50</u>
f. Post-DBE exposure	<u>Yes</u>	TAB D <u>p. 8-50</u>
g. Final inspection and disassembly	<u>Yes</u>	TAB D <u>p. 8-64</u>

3. Was the same piece of equipment used throughout the test sequence described in item 1 above (yes/no/NA)? Yes

4. Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes, See Comment
(Reference QTR155, Sect. 8 & p. 15-8).

JUSTIFICATION/COMMENTS

The test equipment documentation is provided on the "Instrumentation Equipment Sheets" located throughout Section 8 of QTR155.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCS</u>	DATE <u>4/20/90</u>	

H. AGING

1. Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference TAB D, p. 6-1).

JUSTIFICATION/COMMENTS

None

2. Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	TAB D <u>p. 6-2</u>
Radiation exposure	<u>Yes</u>	TAB D <u>p. 6-1</u>
Vibration (non-seismic) aging	<u>Yes</u>	TAB D <u>p. 6-1</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	TAB D <u>p. 6-1</u>

JUSTIFICATION/COMMENTS

None

3. Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference TAB D, p. 7-4).

JUSTIFICATION/COMMENTS

No known synergistic effects.

4. Thermal Aging:

- a. Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference TAB D, p. 6-2, 8-17).

JUSTIFICATION/COMMENTS

None

H. AGING (Continued)

- b. Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference TAB D, p. 6-7).

JUSTIFICATION/COMMENTS

None

- c. Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference TAB D, p. 6-4).

JUSTIFICATION/COMMENTS

None

- d. Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)?
Yes (Reference TAB D, p. 6-12).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>130°F (54.4°C)</u>	<u>248°F</u>	<u>130°F (54.4°C)</u>
Time	<u>40 years</u>	<u>837 hrs</u>	<u>10.8 years</u>

JUSTIFICATION/COMMENTS

The qualified life of all switches can be extended to 40 years through periodic refurbishment (See TAB G for refurbishment schedules).

- e. Was the Arrhenius methodology used for accelerated aging (yes/no/NA)?
Yes (Reference TAB D, p. 6-2).

JUSTIFICATION/COMMENTS

None

- f. If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference TAB D, pp. 6-7, 6-8).

JUSTIFICATION/COMMENTS

None

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCJ</u>	DATE <u>4/24/90</u>	

H. AGING (Continued)

g. If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS

None

h. Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference TAB D, p. 8-17).

JUSTIFICATION/COMMENTS

None

5. Radiation Aging Exposure:

a. Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference TAB D, p. 8-31).

JUSTIFICATION/COMMENTS

None

b. Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes (Reference TAB D, p. 6-7).

JUSTIFICATION/COMMENTS

Assembled test specimen irradiated to 220 Megarads.

c. Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes (Reference TAB D, p. 5-7).

JUSTIFICATION/COMMENTS

None

BINDER NO. WBNEQ-IZS-005 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE EA 180 SERIES COMPUTED JDH DATE 4/16/90
LIMIT SWITCHES MANUFACTURED
AFTER DECEMBER 1986 CHECKED WCS DATE 4/20/90

H. AGING (Continued)

- d. Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference TAB D, pp. 8-33, 8-34).

Plant normal ambient radiation dose (rd) 2.0 x 10⁷ (worst case)
Test exposure dose (rd) 2.2 x 10⁸
Test exposure dose rate (rd/hr) 7.73 x 10⁵
Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS

None

6. Vibration (non-seismic) Aging:

- a. Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (1)? Yes (Reference TAB D, pp. 8-41, 8-42).

JUSTIFICATION/COMMENTS

Plant induced vibration simulation 1 x 10⁶ cycles @ 100 Hz and 0.75 g's per QTR155, pp. 8-41 and 8-42.

- b. Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference TAB D, pp. 5-9).

JUSTIFICATION/COMMENTS

None

7. Operational Stress Aging:

- a. Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference TAB D, pp 5-13 and 35 B-25).

JUSTIFICATION/COMMENTS

None

- (1) Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the binder.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
			R <u> </u> R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED			
AFTER DECEMBER 1986	CHECKED <u>WCSJ</u>	DATE <u>4/20/90</u>	

H. AGING (Continued)

- b. Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes
 (Reference TAB D, p. 8-3).

JUSTIFICATION/COMMENTS

See section P.1 for additional discussion.

8. Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes, See TAB C.4.
 (Reference TAB D, p. 6-1).

Qualified life (Document in QMDS): 40 years*

JUSTIFICATION/COMMENTS

*Through periodic refurbishment as defined in TAB G.

9. Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes
 (Reference TAB D, p. 6-11, 11-14).

JUSTIFICATION/COMMENTS

None

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDA</u>	DATE <u>4/6/90</u>	R <u> </u> R <u> </u>
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCS</u>	DATE <u>4/20/90</u>	

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
Synthetic Hydrocarbon				TAB D
a. <u>Grease/Lubricant</u>	<u>NA</u>	<u>NA</u>	<u>1.19 eV</u>	<u>p. 6-7</u>
b. <u>Silicone Rubber/Gaskets</u>	<u>NA</u>	<u>NA</u>	<u>1.14eV, See Comment</u>	<u>TAB D p. 6-7</u>
c. <u>EPDM/O-Rings</u>	<u>NA</u>	<u>NA</u>	<u>.94eV, See Comment</u>	<u>TAB D p. 6-7</u>
<u>Glass-filled Phenolic RX865</u>			<u>.827eV, See</u>	<u>TAB D</u>
d. <u>Contact Carrier and Block</u>	<u>NA</u>	<u>NA</u>	<u>Comment</u>	<u>p. 6-7</u>
e. <u>RTV/Thread Sealant</u>	<u>NA</u>	<u>NA</u>	<u>.63eV, See Comment</u>	<u>TAB D p. 6-7</u>

JUSTIFICATION/COMMENTS

See the Materials Analysis discussion in TAB C.4 for justification of activation energies shown for listed materials.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCR</u>	DATE <u>4/20/90</u>	

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

1. Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference QTP215, p. 7-1).

Identify Acceptance Criteria: QTP215, p. 7-1

2. Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference QTP215, p. 7-1).

Identify baseline and functional testing: QTP215, p. 7-1

JUSTIFICATION/COMMENTS

None

3. Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference TAB D, p. 7-7).

JUSTIFICATION/COMMENTS

None

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	R <u> </u> R <u> </u>
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCS</u>	DATE <u>4/20/90</u>	

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

4. Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference TAB D, p. 5-5, 5-6).

JUSTIFICATION/COMMENTS

None

5. Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

<u>a. Parameter</u>	<u>Plant Normal Condition</u>	<u>Reference</u>
Voltage	<u>125 VDC (1)</u>	<u>Contract (See TAB E)</u>
Load	<u>5 Amps (1)</u>	<u>Contract (See TAB E)</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
<u>Other(s)</u>		
	<u>NA</u>	<u>NA</u>
	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS

See comment (1) at end of section.

BINDER NO. WBNEQ-IZS-005 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE EA 180 SERIES COMPUTED JDH DATE 4/6/90
LIMIT SWITCHES MANUFACTURED
AFTER DECEMBER 1986 CHECKED WCA DATE 4/20/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

5. (Continued)

5. b. <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference Contract</u>
Voltage	<u>125 VDC</u> (1)	<u>(See TAB E)</u>
Load	<u>5 Amps</u> (1)	<u>(See TAB E)</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		
<u> </u>	<u>NA</u>	<u>NA</u>
<u> </u>	<u>NA</u>	<u> </u>

JUSTIFICATION/COMMENTS

See comment (1) at end of section.

BINDER NO. WBNEQ-IZS-005 PLANT WBN UNIT(S) 1 SHEET OF
 R R
 BINDER TITLE EA 180 SERIES COMPUTED JDH DATE 4/6/90
 LIMIT SWITCHES MANUFACTURED
 AFTER DECEMBER 1986 CHECKED WCT DATE 4/20/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

5. (Continued)

<u>c. Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	125 VDC (2)	TAB D p. 5-6
Load	0.5A (2)	TAB D p. 5-6
Frequency	NA	NA
Accuracy	NA	NA
Other(s)		
Insulation Resistance (Minimum)	280 Megohms (3)	TAB D p. 7-3
Circuit Opening/ Contact Bounce (During Seismic/ Vibration Test)	See Comment (4)	TAB D p. 7-2

JUSTIFICATION/COMMENTS

- (1) The typical application of these limit switches is in control circuits. for example solenoid valves. The U.L. and nameplate
 id 5
 s under
↑ RAISE PER DRAW.
- (2) 1. THE TYPICAL APPLICATION OF THESE LIMIT SWITCHES IS IN THE CONTROL CIRCUITS OF, FOR EXAMPLE, SOLENOID OPERATED VALVES
 1/oxide
 and therefore, provide little contact surface renewal.
- (b) When switches are operated at rated voltage and current, the contact surfaces tend to be self-cleaning and/or the potential of the circuit is sufficient to break down films or oxides that might form on the contact faces.

BINDER NO.	WBNEQ-IZS-005	PLANT	WBN	UNIT(S)	1	SHEET	OF
						R	R
BINDER TITLE	EA 180 SERIES	COMPUTED	JDH	DATE	4/6/90		
LIMIT SWITCHES MANUFACTURED							
AFTER DECEMBER 1986		CHECKED	WCS	DATE	4/20/90		

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

5. (Continued)

- (c) Since TVA's standard design practices prevent circuits from exceeding the U.L. ratings of contacts, the 100VDC and 0.086 Amp load used for testing is conservative and adequate considering items a and b above.
- (3) At the demonstrated insulation resistance value of 280 Megohms, there would be a slight leakage current of approximately 0.446 microamps for a typical 125V circuit. This small leakage current should not provide enough amperage to cause any adverse circuit operation.
- (4) While there are no plant specific requirements with regard to contact bounce/circuit opening, it was demonstrated that none occurred during seismic and vibration testing of the limit switch.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/16/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>wcjr</u>	DATE <u>4/20/90</u>	

K.1 REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-41 (Upper Compartment)

- | | |
|---|--------------------------------|
| 1. Normal Max | 2. Abnormal Max |
| a. Temperature (°F) <u>110</u> | a. Temperature (°F) <u>120</u> |
| b. Pressure (psig) <u>0.3</u> | b. Pressure (psig) <u>0.3</u> |
| c. Humidity (%) <u>80</u> | c. Humidity (%) <u>90</u> |
| d. Radiation (rd) <u>1 x 10⁶</u> | d. Radiation (rd) <u>NA</u> |

3. Process Interfaces: None

4. State anticipated occurrence frequency and duration of abnormal conditions:

Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. ~~(Effect on qualified life is negligible.~~ (See generic position in Binder No. WBNEQ-GEN-001).

*4/24/90
JDH
wcjr
4/18/90*

5. Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|---|--------------------------------|
| a. Temperature (°F) <u>161</u> | Accident type <u>LOCA/HELB</u> |
| b. Pressure (psig) <u>11.2</u> | Accident type <u>LOCA/HELB</u> |
| c. Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| d. Radiation (rd) <u>3.8 x 10⁷ gamma</u> | Accident type <u>LOCA</u> |
| e. Spray Type <u>**</u> | Accident type <u>LOCA/HELB</u> |

* Refer to TAB C.6 for justification regarding acceptability of beta radiation.

** 0.19 molar H₃BO₃ (2000 PPM Boron), 0.033 molar NaOH resulting in a pH of 8.3 at 25°C. Spray duration is 30 days, at a flow rate equal to 0.92 GPM per square foot of containment cross section.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/16/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCD</u>	DATE <u>4/20/90</u>	

K.2 REQUIRED OPERATING ENVIRONMENT (Continued)

Reference Environmental Drawing No. 47E235-42 (Lower Compartment)

- | | |
|---|--------------------------------|
| 1. Normal Max | 2. Abnormal Max |
| a. Temperature (°F) <u>120</u> | a. Temperature (°F) <u>130</u> |
| b. Pressure (psig) <u>0.3</u> | b. Pressure (psig) <u>0.3</u> |
| c. Humidity (%) <u>80</u> | c. Humidity (%) <u>100</u> |
| d. Radiation (rd) <u>2x10⁷</u> | d. Radiation (rd) <u>NA</u> |

3. Process Interfaces: None.

4. State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. ~~(Effect on qualified life is negligible.~~ (See generic position in Binder No. WBNEQ-GEN-001.)

4/24/90
JDH
WCD
4/25/90

5. Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|--|--------------------------------|
| a. Temperature (°F) <u>327</u> | Accident Type <u>LOCA/HELB</u> |
| b. Pressure (psig) <u>11.2</u> | Accident Type <u>LOCA/HELB</u> |
| c. Humidity (%) <u>100</u> | Accident Type <u>LOCA/HELB</u> |
| d. Radiation (rd) <u>4 x 10⁷gamma</u> | Accident Type <u>LOCA</u> |
| e. Spray Type <u>**</u> | Accident Type <u>LOCA/HELB</u> |

* Refer to TAB C.6 for justification regarding acceptability of beta radiation.

** 0.19 molar H₃BO₃ (2000 PPM Boron), 0.033 molar NaOH resulting in a pH of 8.3 at 25°C. Spray duration is 30 days, at a flow rate equal to 0.92 GPM per square foot of containment cross section.

BINDER NO. WBNEQ-IZS-005 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE EA 180 SERIES COMPUTED JDA DATE 4/16/90
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986 CHECKED WCV DATE 4/20/90

K.3 REQUIRED OPERATING ENVIRONMENT (Continued)

Reference Environmental Drawing No. 47E235-44 (Annulus)

- | | |
|---|----------------------------------|
| 1. Normal Max | 2. Abnormal Max |
| a. Temperature (°F) <u>110</u> | a. Temperature (°F) <u>120</u> |
| b. Pressure (psig) <u>ATM(-)</u> | b. Pressure (psig) <u>ATM(-)</u> |
| c. Humidity (%) <u>80</u> | c. Humidity (%) <u>90</u> |
| d. Radiation (rd) <u>1x10⁶</u> | d. Radiation (rd) <u>NA</u> |

3. Process Interfaces: None.

4. State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1% of the plant life. ~~(Effect on qualified life is negligible. (See generic position in Binder No. WBNEQ-GEN-001.)~~

4/24/90
JDA
WCV
4/25/90

5. Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|---|--------------------------------|
| a. Temperature (°F) <u>133.7</u> | Accident Type <u>LOCA/HELB</u> |
| b. Pressure (psig) <u>ATM(-)</u> | Accident Type <u>LOCA/HELB</u> |
| c. Humidity (%) <u>61</u> | Accident Type <u>LOCA/HELB</u> |
| d. Radiation (rd) <u>* 1.2 x 10⁷ gamma</u>
6 x 10⁵ beta | Accident Type <u>LOCA</u> |
| e. Spray Type <u>NA</u> | Accident Type <u>NA</u> |

JDA
5/3/90

JDA 5/3/90

* THIS DOSE INCLUDES A BETA CONTRIBUTION OF 6x10⁵ RADS.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/16/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCT</u>	DATE <u>4/20/90</u>	

K.4 REQUIRED OPERATING ENVIRONMENT (Continued)

Reference Environmental Drawing No.: 47E235-45 (Instrument Room)

- | | |
|---|--------------------------------|
| 1. Normal Max | 2. Abnormal Max |
| a. Temperature (°F) <u>75</u> | a. Temperature (°F) <u>120</u> |
| b. Pressure (psig) <u>0.3</u> | b. Pressure (psig) <u>0.3</u> |
| c. Humidity (%) <u>60</u> | c. Humidity (%) <u>90</u> |
| d. Radiation (rd) <u>3.5x10⁵</u> | d. Radiation (rd) <u>NA</u> |

3. Process Interfaces: None

4. State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1 percent of the plant life. ~~(Effect on qualified life is negligible.~~ (See generic position in binder No. WBNEQ-GEN-001).

*WCT
4/25/90
JDH*

5. Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|--|--------------------------------|
| a. Temperature (°F) <u>327</u> | Accident type <u>LOCA/HELB</u> |
| b. Pressure (psig) <u>11.2</u> | Accident type <u>LOCA/HELB</u> |
| c. Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| d. Radiation (rd) <u>1.0 x 10⁷gamma</u> | Accident type <u>LOCA</u> |
| e. Spray Type <u>**</u> | Accident type <u>LOCA</u> |

* Refer to TAB C.6 for justification regarding acceptability of beta radiation.

** 0.19 molar H₃BO₃ (2000 PPM Boron); 0.033 molar NaOH resulting in a pH of 8.3 at 25°C. Spray duration is 30 days, at a flow rate equal to 0.92 GPM per square foot of containment cross section.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/16/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCA</u>	DATE <u>4/20/90</u>	

K.5 REQUIRED OPERATING ENVIRONMENT (Continued)

Reference Environmental Drawing No.: 47E235-76 (North and South Valve Rooms)

- | | |
|---|--------------------------------|
| 1. Normal Max | 2. Abnormal Max |
| a. Temperature (°F) <u>130</u> | a. Temperature (°F) <u>140</u> |
| b. Pressure (psig) <u>ATM(-)</u> | b. Pressure (psig) <u>ATM</u> |
| c. Humidity (%) <u>50</u> | c. Humidity (%) <u>100</u> |
| d. Radiation (rd) <u>1.8x10³</u> | d. Radiation (rd) <u>NA</u> |

3. Process Interfaces: None

4. State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1 percent of the plant life. ~~(Effect on qualified life is negligible.)~~ (See generic position in binder No. WBNEQ-GEN-001).

*4/24/90
JDH
WCA
4/25/90*

5. Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | | |
|---------------------|---|---------------------------|
| a. Temperature (°F) | <u>325 north</u>
<u>323 south</u> | Accident type <u>FW</u> |
| b. Pressure (psig) | <u>8.77 north</u>
<u>10.78 south</u> | Accident type <u>FW</u> |
| c. Humidity (%) | <u>100</u> | Accident type <u>FW</u> |
| d. Radiation (rd) | <u><1 x 10⁴</u> | Accident type <u>LOCA</u> |
| e. Spray Type | <u>NA</u> | Accident type <u>NA</u> |

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCSZ</u>	DATE <u>4/20/90</u>	

K.6 REQUIRED OPERATING ENVIRONMENT: (Continued)

Reference Environmental Drawing No.: 47E235-77 (RHR Valve Rooms)

- | | |
|---|--------------------------------|
| 1. Normal Max | 2. Abnormal Max |
| a. Temperature (°F) <u>104</u> | a. Temperature (°F) <u>110</u> |
| b. Pressure (psig) <u>ATM</u> | b. Pressure (psig) <u>ATM</u> |
| c. Humidity (%) <u>80</u> | c. Humidity (%) <u>90</u> |
| d. Radiation (rd) <u>1.8x10⁶</u> | d. Radiation (rd) <u>NA</u> |

3. Process Interfaces: None

4. State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to eight hours per excursion and will occur less than 1 percent of the plant life. ~~(Effect on qualified life is negligible.)~~ (See generic position in binder No. WBNEQ-GEN-001).

4/24/90
JDH
WCSZ
4/25/90

5. Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | |
|---|---------------------------|
| a. Temperature (°F) <u>190</u> | Accident type <u>LOCA</u> |
| b. Pressure (psig) <u>ATM</u> | Accident type <u>LOCA</u> |
| c. Humidity (%) <u>90</u> | Accident type <u>LOCA</u> |
| d. Radiation (rd) <u>1 x 10⁷</u> | Accident type <u>LOCA</u> |
| e. Spray Type <u>NA</u> | Accident type <u>NA</u> |

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/16/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCT</u>	DATE <u>4/20/90</u>	

K.7 REQUIRED OPERATING ENVIRONMENT (Continued)

Reference Environmental Drawing No.: 47E235-78 (EGTS Room)

- | | |
|---|--------------------------------|
| 1. Normal Max | 2. Abnormal Max |
| a. Temperature (°F) <u>104</u> | a. Temperature (°F) <u>110</u> |
| b. Pressure (psig) <u>ATM</u> | b. Pressure (psig) <u>ATM</u> |
| c. Humidity (%) <u>80</u> | c. Humidity (%) <u>90</u> |
| d. Radiation (rd) <u>1.8x10³</u> | d. Radiation (rd) <u>NA</u> |
3. Process Interfaces: None
4. State anticipated occurrence frequency and duration of abnormal conditions: Maximum and minimum abnormal temperatures could exist for up to eight hours per excursion and will occur less than 1 percent of the plant life. Maximum abnormal temperatures could exist for up to 10 hours "per month during" 4 months of the year because of the EGTS units being operated for testing and maintenance.
5. Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|---|---------------------------|
| a. Temperature (°F) <u>110</u> | Accident type <u>LOCA</u> |
| b. Pressure (psig) <u>NA</u> | Accident type <u>NA</u> |
| c. Humidity (%) <u>NA</u> | Accident type <u>NA</u> |
| d. Radiation (rd) <u>1.06 x 10⁷*</u> | Accident type <u>LOCA</u> |
| e. Spray Type <u>NA</u> | Accident type <u>NA</u> |

*Worst case per WBNTSR-016 calculation.

BINDER NO. WBNEQ-IZS-005 PLANT WBN UNIT(S) 1 SHEET OF
 R R
 BINDER TITLE EA 180 SERIES COMPUTED JDN DATE 4/20/90
 LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986 CHECKED WCS DATE 4/20/90

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

For a cross-reference of equipment to environmental drawing, see TAB G.

6. Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? Yes (Reference TAB G, 47E235-41, -42, -45, and -76).

7. Subject to submergence (yes/no/NA)? No (Reference SECTION P(3) 5/13/90 WCS 5/13/90).

Identify initiation time and duration of submergence:

8. Is the equipment subject to a beta radiation contribution to the total accident dose (yes/no/NA)? Yes (Reference 47E235-41, -42, -45.)

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: See TAB C-6.

9. Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Section A</u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

1. Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>30 days</u>	<u>TAB D, p. 8-53</u>
Temperature (°F)	<u>327</u>	<u>342***</u>	<u>TAB D, p. 8-54</u>
Pressure (psig)	<u>11.2</u>	<u>76.4</u>	<u>TAB D, p. 7-6</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>TAB D, p. 7-6</u>
* Chemical Spray	<u>TAB C.1 1.11x10⁸gamma</u>	<u>TAB C.1 2.2x10⁸</u>	<u>p. 7-7 TAB D,</u>
** Radiation (rd)	<u>plus beta</u>	<u>gamma</u>	<u>p. 7-6</u>
Submergence	<u>NA</u>	<u>NA</u>	<u>NA</u>

* Includes spray concentration, flowrate, density, duration, and pH.

** Enter 40-year integrated normal dose plus integrated accident dose and specify type. Refer to TAB C.6 for beta dose contribution.

*** See TAB B, Section P.2

2. Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>See L(1)</u>
Pressure	<u>Yes</u>	<u>See L(1)</u>
Relative Humidity	<u>Yes</u>	<u>See L(1)</u>
Chemical Spray	<u>Yes</u>	<u>TAB C-1</u>
Submergence	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS

See TAB C-3 for demonstration of 100 day operability (Accident Degradation Equivalency Calculation).

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCT</u>	DATE <u>4/24/90</u>	

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

3. Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for: (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>15°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>10%</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>10%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>TAB C-3</u>	<u>TAB C-3</u>
Voltage: ±10% of rated value	<u>NA</u>	<u>NA</u>
Frequency: ±5% of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>2 Dwells</u>	<u>Yes</u>
Vibration: ±10% added to acceleration	<u>10%</u> <u>See Comments</u>	<u>Yes</u>

JUSTIFICATION/COMMENTS

Per TVA Standard Specification SS-E18.12.01, Seismic Requirements for Category I Electrical and I&C Equipment, these limit switches should be tested to 3 g's horizontal and 2 g's vertical. Since NAMCO verified in their report (TAB D, p. 5-9 and 5-10) that cross coupling was not significant, the single axis test performed in each of the 3 axes to 10 g's was more than adequate.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
			R <u> </u> R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCS</u>	DATE <u>4/20/90</u>	

M. OPERABILITY TEST RESULTS

1. Identify the safety function(s) of this equipment:
(Reference See TAB A).

JUSTIFICATION/COMMENTS

None

2. Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference TAB D, p. 7-1).

JUSTIFICATION/COMMENTS

None

3. Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes (Reference TAB D, p. 7-1).

JUSTIFICATION/COMMENTS

None

4. Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes
(Reference TAB D, p. 7-7).

JUSTIFICATION/COMMENTS

See TAB C.3 for discussion

5. Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Reference TAB D, p. 8-52).

JUSTIFICATION/COMMENTS

None

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
			R <u> </u> R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCY</u>	DATE <u>4/20/90</u>	

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)?
Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS

See QMDS-TAB G

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCJ</u>	DATE <u>4/20/90</u>	

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
1. Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
2. Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>NA</u>
3. Choice of qualification methodology adequately justified?	<u>Yes</u>
4. If analysis was performed, complete the following:	
a. Were equipment performance requirements identified?	<u>NA</u>
b. Were specific features and failure modes and effects analyzed?	<u>NA</u>
c. Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u>
d. Were environmental parameters which affect equipment performance identified?	<u>NA</u>
5. Adequate similarity between equipment and test specimen established?	<u>Yes</u>
6. Aging degradation evaluated adequately?	<u>Yes</u>
a. Mechanical and/or cycle aging addressed?	<u>Yes</u>
b. Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
c. Absence of preaging in test/analysis justified?	<u>NA</u>
d. Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
		R <u> </u>	R <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/16/90</u>	
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCP</u>	DATE <u>4/20/90</u>	

- | 0. <u>SUMMARY OF REVIEW (Continued)</u> | <u>Yes/No/NA</u> |
|--|------------------|
| e. Normally operating state of device
(e.g., normally energized) considered? | <u>Yes</u> |
| 7. Qualified life or replacement schedule established? | <u>Yes</u> |
| 8. Criteria regarding temperature/pressure exposure
satisfied? | <u>Yes</u> |
| a. Peak temperature adequate | <u>Yes</u> |
| b. Peak pressure adequate | <u>Yes</u> |
| c. Duration adequate | <u>Yes</u> |
| d. Required profile enveloped adequately | <u>Yes</u> |
| e. Steam exposure adequate | <u>Yes</u> |
| 9. Criteria regarding test sequence satisfied? | <u>Yes</u> |
| 10. Criteria regarding spray satisfied? | <u>Yes</u> |
| a. Was the spray testing done while under the
extremes of pressure and temperature? | <u>Yes</u> |
| b. Does the spray concentration, flow rate, density,
duration, and pH used in tests meet or exceed
those to be used for the plant? | <u>Yes</u> |
| 11. Criteria regarding submergence satisfied? | <u>Yes</u> |
| 12. Criteria regarding radiation satisfied? | <u>Yes</u> |
| a. Was dose rate considered? | <u>Yes</u> |
| b. Was beta radiation considered? | <u>Yes</u> |
| 13. Criteria regarding operability status/mode satisfied? | <u>Yes</u> |
| 14. Criteria regarding test failures or anomalies
satisfied? | <u>Yes</u> |

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/6/90</u>	R <u> </u> R <u> </u>
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCT</u>	DATE <u>4/20/90</u>	

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
15. Criteria regarding functional testing satisfied?	<u>Yes</u>
a. Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
b. Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
c. Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
16. Criteria regarding instrument accuracy satisfied?	<u>NA</u>
17. Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
a. Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
b. If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA</u>
18. Criteria regarding synergistic effects satisfied?	<u>Yes</u>
19. Criteria regarding margins satisfied?	<u>Yes</u>
20. Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

- (1) AGING - Section H.7.b - This device was subject to 100,300 actuation cycles during mechanical aging testing. This is equivalent to an average of 209 actuations per month or approximately 7 actuations per day over the 40 year life of the plant. This is judged to be in excess of the full open/close actuation cycles the associated valves will be required to operate for normal plant operation, maintenance, and surveillance. Therefore, the mechanical aging performed is adequate to demonstrate qualification over the 40 year life of the plant.

BINDER NO. <u>WBNEQ-IZS-005</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u> </u> OF <u> </u>
BINDER TITLE <u>EA 180 SERIES</u>	COMPUTED <u>JDH</u>	DATE <u>4/16/90</u>	R <u> </u> R <u> </u>
LIMIT SWITCHES MANUFACTURED AFTER DECEMBER 1986	CHECKED <u>WCS</u>	DATE <u>4/20/90</u>	

P. DISCUSSION (Continued)

(2) SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS -
 Section L.1 - QTR 155 states that the peak temperature in the test chamber was 361°F (p. 7-6). Two thermocouples were used to measure temperatures during the test. The 361°F was measured by the thermocouple, TC-13, that was closest to the steam inlet (p. 8-61). For qualification purposes, this binder has used the more conservative temperatures measured by thermocouple TC-06.

*JDH
5/31/90
WCS
5/31/90*

(3) REQUIRED OPERATING ENVIRONMENT - SECTION K.6 - SEE PAGES G-2 THRU G-6 .
 FOR LIST OF LIMIT SWITCHES WHICH REQUIRE CONDUIT SEALS DUE TO
 MOISTURE INTRUSION.

TAB A COMPLILATION METHODOLOGY

1. The Watts Bar Environmental Qualification binder WBNEQ-JBOX-001 equipment list (TAB A) was compiled by utilizing the DNE calculation WBPEVAR 8601003 as a baseline reference document. This calculation listed all of the Class 1E junction boxes and local instrumentation panels in the harsh environment. All end devices (devices whose circuits terminate in the junction box) were listed for each JB. A crosscheck of the end devices in each JB was made to the category and operating times calculations and, if any device was determined to be category A or B for any event, the JB was entered into the binder TAB A.

This process was performed for each revision and QIR to the WBPEVAR 8601003 calculation to ensure a comprehensive assessment of all Class 1E harsh environment JB's.

WBPEVAR 8601003 R4 dated 5/26/88 is superceded by the Environmental Qualification (EQ) Binders.

2. Elevations shown are actual elevations for equipment located in the reactor building and floor elevations for equipment located outside the reactor building. Actual elevations for all equipment are documented in TAB F.
3. Junction Box number 1-JB-292-3870 contains a MOS varistor. For discussion of this, see TAB C, page C-4.

R4

JBOX-001

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -276-L182A LOC PNL JUNCTION BOX	-D	1-JB -276-L182A BY PNL MFR	-D 183	721' 6"	FN2	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -276-L182B LOC PNL JUNCTION BOX	-D	1-JB -276-L182B BY PNL MFR	-D 181	721' 6"	FN2	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -276-L183A LOC PNL JUNCTION BOX	-E	1-JB -276-L183A BY PNL MFR	-E 005	721' 6"	FN1	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -276-L183B LOC PNL JUNCTION BOX	-E	1-JB -276-L183B BY PNL MFR	-E 002	721' 6"	FN1	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -276-L183C LOC PNL JUNCTION BOX	-B	1-JB -276-L183C BY PNL MFR	-B 359	721' 6"	FN1	B	100D	ALL	COMPONENT PROTECTION

PAGE A-2

R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG 9-20-89	WCP 2-22-90	
		WCG 9-25-89	WCF 2-13-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT</u>	<u>DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u> <u>(2)</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-JB -276-L196 LOC PNL JUNCTION BOX	-D	1-JB -276-L196 BY PNL MFR	-D	713'	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -276-L197 LOC PNL JUNCTION BOX	-E	1-JB -276-L197 BY PNL MFR	-E	713'	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -276-L216 LOC PNL JUNCTION BOX	-A	1-JB -276-L216 BY PNL MFR	-A	713'	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -276-L217 LOC PNL JUNCTION BOX	-A	1-JB -276-L217 BY PNL MFR	-A	737'	A05	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0004 JUNCTION BOX	-A	1-JB -292-0004 JXA	-A	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION

PAGE A-3

R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R
 CHECKED/DATE ETD 9-10-86 CAG WCG
 9-20-89 2-22-90
 WCG ETD
 9-25-89 2-23-90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		RM/RAD	CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
				ELEV(1)	CONTRACT					
WBN-2-JB -292-0006 JUNCTION BOX	-B	2-JB -292-0006	JXA	-B	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-0228 JUNCTION BOX	-A	0-JB -292-0228	JQE	-A	729' VARIOUS	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-0229 JUNCTION BOX	-B	0-JB -292-0229	JQE	-B	729' VARIOUS	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0358 JUNCTION BOX	-B	1-JB -292-0358	JXA	-B	692' VARIOUS	A12	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0359 JUNCTION BOX	-B	1-JB -292-0359	JXA	-B	692' VARIOUS	A13	B	100D	ALL	COMPONENT PROTECTION

PAGE A-4

R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG	WCM	
		9-20-89	2-02-90	
		WCG	RY	
		9-25-89	2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE	ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-0530 JUNCTION BOX	-B	1-JB	-292-0530	-B JVF	729' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0540 JUNCTION BOX	-A	1-JB	-292-0540	-A JVE	729' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0567 JUNCTION BOX	-A	1-JB	-292-0567	-A JFD	676' VARIOUS	A16	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0569 JUNCTION BOX	-B	1-JB	-292-0569	-B JFD	676' VARIOUS	A16	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0593 JUNCTION BOX	-A	1-JB	-292-0593	-A JQE	737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION

PAGE A-5

R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R
 CHECKED/DATE ETD 9-10-86 CAG WCP
 9-20-89 2-22-90
 WCG AT
 9-25-89 2-23-90

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
WBN-1-JB -292-0748 JUNCTION BOX	-B	1-JB -292-0748	JXA		713'	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0772 JUNCTION BOX	-B	1-JB -292-0772	JFD		676'	A16	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0773 JUNCTION BOX	-A	1-JB -292-0773	JXA		676'	A16	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0846 JUNCTION BOX	-B	1-JB -292-0846	JVC		692'	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-0847 JUNCTION BOX	-A	1-JB -292-0847	JVC		692'	A06	B	100D	ALL	COMPONENT PROTECTION

PAGE A-6

R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R _____
 CHECKED/DATE ETD 9-10-86 CAG WCG _____
 9-20-89 2-22-90
 WCG WCG _____
 9-25-89 2-23-90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-1005 JUNCTION BOX	-A	1-JB -292-1005 JXA	-A	737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1006 JUNCTION BOX	-B	1-JB -292-1006 JXA	-B	737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB -292-1008 JUNCTION BOX	-B	2-JB -292-1008 JXA	-B	737' VARIOUS	A09	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-1163 JUNCTION BOX	-B	0-JB -292-1163 JSE	-B	757' VARIOUS	A16	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-1164 JUNCTION BOX	-A	0-JB -292-1164 JSE	-A	757' VARIOUS	A16	B	100D	ALL	COMPONENT PROTECTION

PAGE A-7
R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG 9-20-89	WGP 9-22-89	
		WCG 9-25-89	HY 2.23.90	

PRINT DATE: 02/02/90

BINDER NO. : WBNEQ-JBOX-001
MANUFACTURER : VARIOUS
PAGE 7 OF 51

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION		RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMITH	ELEV(1)					

WBN-1-JB JUNCTION BOX	-A	1-JB -292-1189	JYJ	-A	692' VARIOUS	A09	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB -292-1190	JYJ	-B	692' VARIOUS	A10	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-A	1-JB -292-1195	JYJ	-A	692' VARIOUS	A13	B	100D	ALL	COMPONENT PROTECTION

R4

PAGE A-8

PREPARER/DATE	<u>JLH 9-8-86</u>	<u>R 2</u>	<u>R 3</u>	<u>R 4</u>
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u>	<u>WCG</u>	<u>WCP</u>
		<u>9-20-89</u>	<u>2-22-90</u>	<u>9-19-90</u>
		<u>WCG</u>	<u>RCF</u>	<u>CSB</u>
		<u>9-25-89</u>	<u>2-23-90</u>	<u>9/20/90</u>

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION			CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMITH	ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-1196 JUNCTION BOX	-B	1-JB -292-1196	JYJ	-B	692' VARIOUS	A12	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1231 JUNCTION BOX	-A	1-JB -292-1231	JQD	-A	713' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1232 JUNCTION BOX	-B	1-JB -292-1232	JQD	-B	713' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1235 JUNCTION BOX	-A	1-JB -292-1235	JXA	-A	713' VARIOUS	A13	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1246 JUNCTION BOX	-A	1-JB -292-1246	JXB	-A	713' VARIOUS	A13	B	100D	ALL	COMPONENT PROTECTION

PAGE A-9

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R _____
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u> 9-20-89	<u>WCG</u> 2-22-90	_____
		<u>WCG</u> 9-25-89	<u>RT</u> 2.23.90	_____

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-1352 JUNCTION BOX	-A	1-JB -292-1352	-A JXD	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1353 JUNCTION BOX	-A	1-JB -292-1353	-A JXA	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1354 JUNCTION BOX	-B	1-JB -292-1354	-B JXD	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1355 JUNCTION BOX	-B	1-JB -292-1355	-B JXA	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1356 JUNCTION BOX	-A	1-JB -292-1356	-A JXA	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION

PAGE A-10
R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R _____
 CHECKED/DATE ETD 9-10-86 CAG WCG _____
9-20-89 2-20-90 _____
WCG WCG _____
9-25-89 1-23-90 _____

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

FOIS NUMBER DESCRIPTION	UNIT DEVICE ID NO.		AZMITH	LOCATION		RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
	MODEL NUMBER			ELEV(1) CONTRACT						
WBN-1-JB -292-1357 JUNCTION BOX	-A	1-JB -292-1357	-A	JXA	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1358 JUNCTION BOX	-B	1-JB -292-1358	-B	JXD	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1367 JUNCTION BOX	-A	1-JB -292-1367	-A	JQG	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1368 JUNCTION BOX	-B	1-JB -292-1368	-B	JQH	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1369 JUNCTION BOX	-A	1-JB -292-1369	-A	JQG	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION

PAGE A-11

R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R
 CHECKED/DATE ETD 9-10-86 CAG WCG
9-20-89 2-20-90
WCG WY
9-25-89 2-23-90

PRINT DATE: 02/02/90

BINDER NO. : WBNEQ-JBOX-001
MANUFACTURER : VARIOUS
PAGE 11 OF 51

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE	ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME (2)	EVENT	SAFETY FUNCTION
					ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB JUNCTION BOX	-A	1-JB	-292-1370	JQE -A	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-1371	JQE -B	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-S	1-JB	-292-1391	JVC -S	692' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION

R4

PAGE A-12

R4

PREPARER/DATE JLH 9-8-86 R 2 R 3 R 4
CHECKED/DATE ETD 9-10-86
CAG WCG WCP
9-20-89 2-22-90 7-19-90
WCG RCE CSH
9-25-89 9-23-90 9/26/90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION			CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMITH	ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-1421 JUNCTION BOX	-A	1-JB -292-1421	JXA	-A	713' VARIOUS	A12	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1422 JUNCTION BOX	-B	1-JB -292-1422	JXA	-B	713' VARIOUS	A11	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1425 JUNCTION BOX	-A	1-JB -292-1425	JXA	-A	713' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1426 JUNCTION BOX	-B	1-JB -292-1426	JXA	-B	713' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1446 JUNCTION BOX	-B	1-JB -292-1446	JXA	-B	713' VARIOUS	A06	B	100D	ALL	COMPONENT PROTECTION

PAGE A-13

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	<u>R 2</u>	<u>R 3</u>	<u>R</u>
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG 9-20-89</u>	<u>WCG 2-22-90</u>	
		<u>WCG 9-25-89</u>	<u>WCG 2-23-90</u>	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT</u>	<u>DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u> <u>(2)</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-JB -292-1447 JUNCTION BOX	-A	1-JB -292-1447 JXA	-A	713' VARIOUS	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB -292-1448 JUNCTION BOX	-B	2-JB -292-1448 JXA	-B	713' VARIOUS	A19	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB -292-1449 JUNCTION BOX	-A	2-JB -292-1449 JXA	-A	713' VARIOUS	A19	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1502 JUNCTION BOX	-A	1-JB -292-1502 JXA	-A	713' VARIOUS	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB -292-1503 JUNCTION BOX	-A	2-JB -292-1503 JXA	-A	713' VARIOUS	A19	B	100D	ALL	COMPONENT PROTECTION

PAGE A-14

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u> 9-20-89	<u>WCP</u> 2-22-90	
		<u>WCG</u> 9-25-89	<u>RT</u> 1-25-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION			CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMITH	ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB JUNCTION BOX	-B	1-JB -292-1504	JXA	-B	713' VARIOUS	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB JUNCTION BOX	-B	2-JB -292-1505	JXA	-B	713' VARIOUS	A19	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-A	1-JB -292-1506	JXA	-A	713' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB -292-1507	JXA	-B	713' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB JUNCTION BOX	-A	2-JB -292-1508	JXA	-A	713' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION

PAGE A-15

R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG 9-20-89	WCP 2-22-90	
		WCG 9-25-89	WCF 7-23-90	

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT</u>	<u>DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-2-JB -292-1509 JUNCTION BOX	-B	2-JB -292-1509 JXA	-B	713' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1512 JUNCTION BOX	-A	1-JB -292-1512 JVE	-A	729' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1514 JUNCTION BOX	-A	1-JB -292-1514 JVE	-A	729' VARIOUS	A02	B	100D	ALL	COMPONENT PROTECTION ←
WBN-1-JB -292-1516 JUNCTION BOX	-B	1-JB -292-1516 JVE	-B	729' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1518 JUNCTION BOX	-B	1-JB -292-1518 JVC	-B	729' VARIOUS	A02	B	100D	ALL	COMPONENT PROTECTION

-1514-A
 Located in NSVR

PAGE A - 16 R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG 9-20-89	WCG 2-28-90	
		WCG 9-25-89	AT 2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-1543 JUNCTION BOX	-A	1-JB -292-1543	-A JFD	692' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1544 JUNCTION BOX	-B	1-JB -292-1544	-B JFD	692' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-1547 JUNCTION BOX	-A	0-JB -292-1547	-A JXA	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-1548 JUNCTION BOX	-B	0-JB -292-1548	-B JXA	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1549 JUNCTION BOX	-A	1-JB -292-1549	-A JXA	737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION

PAGE 4-17

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R _____
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u> 9-20-89	<u>WGP</u> 2-22-90	_____
		<u>WCG</u> 9-25-89	<u>RT</u> 2.23.90	_____

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE	ID NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION	
					ELEV(1)	RM/RAD					
			MODEL NUMBER			CONTRACT	(2)				
WBN-2-JB JUNCTION BOX	-A	2-JB	-292-1550 JXA	-A	737'	VARIOUS	A09	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-1551 JXA	-B	737'	VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB JUNCTION BOX	-B	2-JB	-292-1552 JXA	-B	737'	VARIOUS	A09	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB JUNCTION BOX	-A	2-JB	-292-1553 JFD	-A	692'	VARIOUS	A25	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB JUNCTION BOX	-B	2-JB	-292-1554 JFD	-B	692'	VARIOUS	A25	B	100D	ALL	COMPONENT PROTECTION

PAGE A - 18

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R _____
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u> 9-20-89	<u>WCP</u> 2-22-90	_____
		<u>WCG</u> 9-25-89	<u>RT</u> 1.23.90	_____

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID	NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
			MODEL NUMBER			CONTRACT	(2)			
WBN-2-JB JUNCTION BOX	-A	2-JB	-292-1555 JYJ	-A	692' VARIOUS	A25	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB JUNCTION BOX	-B	2-JB	-292-1556 JYJ	-B	692' VARIOUS	A25	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-A	1-JB	-292-1564 JXA	-A	692' VARIOUS	A08	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-1565 JXA	-B	692' VARIOUS	A08	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-1566 JXA	-B	692' VARIOUS	A08	B	100D	ALL	COMPONENT PROTECTION

PAGE A-19

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R <u> </u>
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG 9-20-89</u>	<u>WGP 2-02-90</u>	<u> </u>
		<u>WCG 9-25-89</u>	<u>HT 7-25-90</u>	<u> </u>

PRINT DATE: 02/02/90

BINDER NO. : WBNEQ-JBOX-001
 MANUFACTURER : VARIOUS
 PAGE 19 OF 51

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				MODEL NUMBER	ELEV(1) CONTRACT				
WBN-1-JB JUNCTION BOX	-A	1-JB -292-1567	JXA	-A	692' VARIOUS	A08	B	100D	ALL COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-A	1-JB -292-1598	JXA	-A	713' VARIOUS	A28	B	100D	ALL COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB -292-1599	JXA	-B	713' VARIOUS	A28	B	100D	ALL COMPONENT PROTECTION

R4

PAGE A-20

R4

PREPARER/DATE	<u>JLH 9-8-86</u>	R 2	R 3	R 4
CHECKED/DATE	<u>ETD 9-10-86</u>	CAG 9-20-89	WCG 2-22-90	WCP 9-19-89
		WCG 9-25-89	RCF 2-23-90	CRJ 9/26/90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE	ID NO.	AZMITH	LOCATION		CAT	OPER	TIME	EVENT	SAFETY	FUNCTION
					MODEL NUMBER	ELEV(1) CONTRACT						
WBN-1-JB -292-1933 JUNCTION BOX	-S	1-JB	-292-1933	-S	692' VARIOUS	A01	B	100D	ALL	COMPONENT	PROTECTION	
WBN-0-JB -292-1942 JUNCTION BOX	-A	0-JB	-292-1942	-A	757' VARIOUS	A16	B	100D	ALL	COMPONENT	PROTECTION	
WBN-0-JB -292-1943 JUNCTION BOX	-B	0-JB	-292-1943	-B	757' VARIOUS	A16	B	100D	ALL	COMPONENT	PROTECTION	
WBN-1-JB -292-1964 JUNCTION BOX	-B	1-JB	-292-1964	-B	737' VARIOUS	A01	B	100D	ALL	COMPONENT	PROTECTION	
WBN-1-JB -292-1966 JUNCTION BOX	-A	1-JB	-292-1966	-A	737' VARIOUS	A01	B	100D	ALL	COMPONENT	PROTECTION	

PAGE A - 21

R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG 9-20-89	WCA 2-20-90	
		WCG 9-25-89	RT 7-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-1968 JUNCTION BOX	-A	1-JB -292-1968	-A JWH	737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1970 JUNCTION BOX	-B	1-JB -292-1970	-B JWH	737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1972 JUNCTION BOX	-B	1-JB -292-1972	-B JWH	729' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1974 JUNCTION BOX	-A	1-JB -292-1974	-A JWH	729' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1985 JUNCTION BOX	-A	1-JB -292-1985	-A JVC	729' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION

PAGE A - 22
R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-8-86	CAG 9-22-87	WCP 2-22-90	
		WCG 9-25-84	MT 1.23.90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				MODEL NUMBER	ELEV(1) CONTRACT				
WBN-1-JB -292-1986 JUNCTION BOX	-B	1-JB -292-1986	-B	JVC	729' VARIOUS	A01	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1987 JUNCTION BOX	-B	1-JB -292-1987	-B	JVE	729' VARIOUS	A02	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-1988 JUNCTION BOX	-A	1-JB -292-1988	-A	JVE	729' VARIOUS	A02	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2007 JUNCTION BOX	-B	1-JB -292-2007	-B	JYJ	692' VARIOUS	A07	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2008 JUNCTION BOX	-A	1-JB -292-2008	-A	JYJ	692' VARIOUS	A07	B 100D	ALL	COMPONENT PROTECTION

PAGE A - 23

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	<u>R 2</u>	<u>R 3</u>	<u>R</u>
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u>	<u>WCP</u>	
		<u>9-25-89</u>	<u>2-22-90</u>	
		<u>WCG</u>	<u>WJ</u>	
		<u>9-25-89</u>	<u>2-25-90</u>	

PRINT DATE: 02/02/90

BINDER NO. : WBNEQ-JBOX-001
MANUFACTURER : VARIOUS
PAGE 23 OF 51

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	NO.	MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION	
					AZMITH	ELEV(1) CONTRACT					
WBN-1-JB -292-2012 JUNCTION BOX	-B	1-JB	-292-2012	JXD	-B	713' VARIOUS	A13	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2013 JUNCTION BOX	-A	1-JB	-292-2013	JXD	-A	713' VARIOUS	A13	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2034 JUNCTION BOX	-A	1-JB	-292-2034	JQD	-A	713' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-2035 JUNCTION BOX	-B	0-JB	-292-2035	JQD	-B	713' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION

R4

PAGE A-24

R4

PREPARER/DATE	<u>JLH 9-8-86</u>	<u>R2</u>	<u>R3</u>	<u>R4</u>
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG 9-20-89</u>	<u>WCG 2-22-90</u>	<u>WCP 9-19-89</u>
		<u>WCG 9-25-89</u>	<u>RCF 2-23-90</u>	<u>CRF 9/26/90</u>

PRINT DATE: 02/02/90

BINDER NO. : WBNEQ-JBOX-001
MANUFACTURER : VARIOUS
PAGE 24 OF 51

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION	
					ELEV(1)	RM/RAD					
				MODEL NUMBER	CONTRACT	(2)					
WBN-1-JB JUNCTION BOX	-A	1-JB	-292-2063	JXA	-A	692' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-2064	JXA	-B	692' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-A	1-JB	-292-2065	JFE	-A	692' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-2066	JFE	-B	692' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION

R4

PAGE A-25

PREPARER/DATE	<u>JLH 9-8-86</u>	R 2	R 3	R 4
CHECKED/DATE	<u>ETD 9-10-86</u>	CAG 9-20-89	WCG 2-22-90	WCP 9-19-90
		WCG 9-25-89	RCF 2-23-90	CAF 9/26/90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				MODEL NUMBER	ELEV(1) CONTRACT				
WBN-1-JB -292-2071 JUNCTION BOX	-A	1-JB -292-2071	-A	JXA	737' VARIOUS	A01	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2122 JUNCTION BOX	-A	1-JB -292-2122	-A	JQE	713' VARIOUS	A06	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2140 JUNCTION BOX	-A	1-JB -292-2140	-A	JVC	729' VARIOUS	A01	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2141 JUNCTION BOX	-B	1-JB -292-2141	-B	JVC	729' VARIOUS	A01	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2202 JUNCTION BOX	-A	1-JB -292-2202	-A	JXB	737' VARIOUS	A05	B 100D	ALL	COMPONENT PROTECTION

PAGE A-26

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R _____
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u>	<u>WCP</u>	_____
		<u>9-20-89</u>	<u>2-22-90</u>	_____
		<u>WCG</u>	<u>WTF</u>	_____
		<u>9-25-89</u>	<u>2.23.90</u>	_____

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-2204 JUNCTION BOX	-A	1-JB -292-2204 JXD	-A	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2205 JUNCTION BOX	-A	1-JB -292-2205 JXD	-A	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2206 JUNCTION BOX	-A	1-JB -292-2206 JXD	-A	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2207 JUNCTION BOX	-A	1-JB -292-2207 JQD	-A	692' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2208 JUNCTION BOX	-B	1-JB -292-2208 JXD	-B	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION

PAGE A-27 R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R <u> </u>
CHECKED/DATE	<u>ETD 9-10-86</u>	CAG	WCR	
		9-20-89	2-20-90	
		WCG	RT	
		9-25-89	1-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE	ID NO.	AZMITH	LOCATION		CAT	OPER	TIME	EVENT	SAFETY	FUNCTION
					MODEL NUMBER	ELEV(1) CONTRACT						
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-2209	-B	JXB	737' VARIOUS	A05	B	100D	ALL	COMPONENT	PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-2211	-B	JQD	692' VARIOUS	A07	B	100D	ALL	COMPONENT	PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-2212	-B	JXD	737' VARIOUS	A01	B	100D	ALL	COMPONENT	PROTECTION
WBN-1-JB JUNCTION BOX	-S	1-JB	-292-2234	-S	JVE	692' VARIOUS	A01	B	100D	ALL	COMPONENT	PROTECTION
WBN-1-JB JUNCTION BOX	-S	1-JB	-292-2236	-S	JXD	692' VARIOUS	A01	B	100D	ALL	COMPONENT	PROTECTION

PAGE
A
-28

R3

PREPARER/DATE	JLH	9-8-86	R 2	R 3	R
CHECKED/DATE	ETD	9-10-86	CAG	WCG	
			9-25-89	2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH		LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			MODEL NUMBER		ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-2238 JUNCTION BOX	-S	1-JB -292-2238	-S	JVC	692'	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2240 JUNCTION BOX	-A	1-JB -292-2240	-A	JVA	692'	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2242 JUNCTION BOX	-S	1-JB -292-2242	-S	JVB	692'	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2244 JUNCTION BOX	-A	1-JB -292-2244	-A	JVA	692'	A06	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2248 JUNCTION BOX	-B	1-JB -292-2248	-B	JVA	692'	A06	B	100D	ALL	COMPONENT PROTECTION

PAGE
A-29

R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG	WCG	
		9-25-89	2-22-90	
		WCG	RT	
		9-25-89	2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-2249 JUNCTION BOX	-B	1-JB -292-2249	JVA	-B	692' VARIOUS	A06	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2252 JUNCTION BOX	-A	1-JB -292-2252	JXA	-A	757' VARIOUS	A16	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2257 JUNCTION BOX	-A	1-JB -292-2257	JQE	-A	713' VARIOUS	A06	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2260 JUNCTION BOX	-B	1-JB -292-2260	JQE	-B	713' VARIOUS	A06	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2262 JUNCTION BOX	-B	1-JB -292-2262	JXA	-B	757' VARIOUS	A16	B 100D	ALL	COMPONENT PROTECTION

PAGE A-30

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R 2	R 3	R
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u>	<u>WCG</u>	
		<u>9-25-89</u>	<u>2-22-90</u>	
		<u>WCG</u>	<u>WCG</u>	
		<u>9-25-89</u>	<u>2-23-90</u>	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -292-2265 JUNCTION BOX	-B	1-JB -292-2265	-B JXD	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2386 JUNCTION BOX	-B	1-JB -292-2386	-B JXA	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2387 JUNCTION BOX	-A	1-JB -292-2387	-A JXA	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-2388 JUNCTION BOX	-A	1-JB -292-2388	-A JXA	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB -292-2389 JUNCTION BOX	-A	2-JB -292-2389	-A JWB	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION

PAGE A-31

R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG WCP	4-20-89 2-22-90	
		WCG	WCF	
		4-25-89	2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE	ID NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
			MODEL NUMBER		CONTRACT	(2)				
WBN-2-JB JUNCTION BOX	-B	2-JB	-292-2390	-B	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
			JWB							
WBN-2-JB JUNCTION BOX	-A	2-JB	-292-2391	-A	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
			JWB							
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-2503	-B	676' VARIOUS	A08	B	100D	ALL	COMPONENT PROTECTION
			JFG							
WBN-1-JB JUNCTION BOX	-A	1-JB	-292-2504	-A	676' VARIOUS	A09	B	100D	ALL	COMPONENT PROTECTION
			JFG							
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-2507	-B	676' VARIOUS	A10	B	100D	ALL	COMPONENT PROTECTION
			JFG							

PAGE A-32
 R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG	WCP	
		9-20-89	2-22-90	
		WCG	RT	
		9-25-89	2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
WBN-1-JB JUNCTION BOX	-A	1-JB -292-2508	JQE	-A	676'	A11	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB JUNCTION BOX	-B	2-JB -292-2761	JXA	-B	757'	A16	B	100D	ALL	COMPONENT PROTECTION
WBN-2-JB JUNCTION BOX	-A	2-JB -292-2762	JXA	-A	757'	A16	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB JUNCTION BOX	-A	0-JB -292-2765	JQE	-A	692'	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB JUNCTION BOX	-B	0-JB -292-2766	JQE	-B	692'	A01	B	100D	ALL	COMPONENT PROTECTION

PAGE
A - 33

R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG WCA	9-20-89 2-22-90	
		WCG RT	9-25-89 2.23.90	

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID	NO.	AZMITH		LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				MODEL NUMBER	NUMBER	ELEV(1) CONTRACT	RM/RAD				
WBN-0-JB -292-2856 JUNCTION BOX	-A	0-JB	-292-2856	-A		737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-2894 JUNCTION BOX	-B	0-JB	-292-2894	-B		737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-3032 JUNCTION BOX	-B	1-JB	-292-3032	-B		713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-3033 JUNCTION BOX	-A	1-JB	-292-3033	-A		713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-3208 JUNCTION BOX	-A	1-JB	-292-3208	-A		692' VARIOUS	A07	B	100D	ALL	COMPONENT PROTECTION

PAGE A-34 R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R
 CHECKED/DATE ETD 9-10-86 CAG wcp
 WCG
 9-25-89 2.23.90

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT</u>	<u>DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u> <u>(2)</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-0-JB -292-3213 JUNCTION BOX	-B	0-JB -292-3213 JXA	-B	692' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-3214 JUNCTION BOX	-B	1-JB -292-3214 JXA	-B	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-3215 JUNCTION BOX	-A	0-JB -292-3215 JXA	-A	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-3341 JUNCTION BOX	-B	0-JB -292-3341 JXA	-B	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-0-JB -292-3342 JUNCTION BOX	-A	0-JB -292-3342 JXA	-A	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION

PAGE A - 35 R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R
 CHECKED/DATE ETD 9-10-86 CAG wcd
9-20-89 2-22-90
WCG
9-25-89 7.23.90

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH	MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION	
					ELEV(1)	RM/RAD					
WBN-1-JB -292-3422 JUNCTION BOX	-A	1-JB -292-3422		JQQ	-A	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-3423 JUNCTION BOX	-B	1-JB -292-3423		JQQ	-B	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-3424 JUNCTION BOX	-A	1-JB -292-3424		JVB	-A	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-3425 JUNCTION BOX	-A	1-JB -292-3425		JVB	-A	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-3426 JUNCTION BOX	-B	1-JB -292-3426		JVB	-B	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION

PAGE A-36
R3

PREPARER/DATE	JLH 9-8-86	R2	R3	R
CHECKED/DATE	ETD 9-10-86	CAG 9-20-84	WCP 2-27-90	
		WCG 9-25-84	WCA 2-23-90	

PRINT DATE: 02/02/90

BINDER NO. : WBNEQ-JBOX-001
 MANUFACTURER : VARIOUS
 PAGE 36 OF 51

H A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION		
				MODEL NUMBER	ELEV(1) CONTRACT					RM/RAD	
WBN-1-JB -292-3427 JUNCTION BOX	-B	1-JB -292-3427		JVB	-B	713' VARIOUS	A28	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-3870 JUNCTION BOX	-A	1-JB -292-3870		JWH	-A	737' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-4011 JUNCTION BOX	-A	1-JB -292-4011		JXA	-A	729' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-4013 JUNCTION BOX	-A	1-JB -292-4013		JXA	-A	737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -292-4015 JUNCTION BOX	-B	1-JB -292-4015		JXA	-B	737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION

R4

PAGE A -37

R4

PREPARER/DATE	<u>JLH 9-8-86</u>	R 2	R 3	R 4
CHECKED/DATE	<u>ETD 9-10-86</u>	CAG 9-20-89	WCG 2-22-90	WCF 9-19-90
		WCG 9-25-89	RCF 2-23-90	WCF 9/26/90

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

<u>EQIS NUMBER</u>	<u>UNIT</u>	<u>DEVICE ID NO.</u>	<u>NO.</u>	<u>AZMITH</u>	<u>LOCATION</u>	<u>ELEV(1)</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
<u>DESCRIPTION</u>		<u>MODEL NUMBER</u>			<u>CONTRACT</u>			<u>(2)</u>			
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-4026	-B		737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION
			JVE								
WBN-1-JB JUNCTION BOX	-A	1-JB	-292-4027	-A		737' VARIOUS	A05	B	100D	ALL	COMPONENT PROTECTION
			JVE								
WBN-1-JB JUNCTION BOX	-A	1-JB	-292-4166	-A		729' VARIOUS	A04	B	100D	ALL	COMPONENT PROTECTION
			JVE								
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-4167	-B		729' VARIOUS	A04	B	100D	ALL	COMPONENT PROTECTION
			JVE								
WBN-1-JB JUNCTION BOX	-B	1-JB	-292-4261	-B		713' VARIOUS	A01	B	100D	ALL	COMPONENT PROTECTION
			JXA								

PAGE A-38 R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG	WCP	
		9-20-89	122-90	
		WCG	RT	
		9-25-89	1.23.90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				MODEL NUMBER	ELEV(1) CONTRACT				
WBN-1-JB JUNCTION BOX	-A	1-JB -292-4275	-A	JQO	737' VARIOUS	A01	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-A	1-JB -292-4984	-A	JQB	757' VARIOUS	A16	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB -292-4985	-B	JQB	757' VARIOUS	A16	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB -293-0159	-B	JVC	804' 7" VARIOUS	UC	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB -293-0368	-B	JVC	806' VARIOUS	UC	B 100D	ALL	COMPONENT PROTECTION

PAGE A-39 R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R _____
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u>	<u>WCP</u>	_____
		<u>9-20-87</u>	<u>WCP</u>	_____
		<u>9-25-89</u>	<u>WCP</u>	_____
			<u>2-23-90</u>	_____

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION			CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMITH	ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -293-0369 JUNCTION BOX	-A	1-JB -293-0369	JVC	-A 0	706' 7" VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-0394 JUNCTION BOX	-A	1-JB -293-0394	JVD	-A 045	706' VARIOUS	RW	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-0542 JUNCTION BOX	-A	1-JB -293-0542	JVB	-A 234	736' 4" VARIOUS	AC3	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-0544 JUNCTION BOX	-A	1-JB -293-0544	JVC	-A 248	754' VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-0546 JUNCTION BOX	-B	1-JB -293-0546	JXA	-B 300	724' 5" VARIOUS	ANN	B	100D	ALL	COMPONENT PROTECTION

PAGE A-40

R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R <u> </u>
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u>	<u>WCP</u>	<u> </u>
		<u>9-20-89</u>	<u>2-22-90</u>	<u> </u>
		<u>WCG</u>	<u>BT</u>	<u> </u>
		<u>9-25-89</u>	<u>2-23-90</u>	<u> </u>

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION			CAT	OPER TIME	EVENT	SAFETY FUNCTION	
				AZMITH	ELEV(1)	RM/RAD					
					CONTRACT	(2)					
WBN-1-JB JUNCTION BOX	-B	1-JB -293-0548	JQE	-B	248	753'10" VARIOUS	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-A	1-JB -293-0550	JQB	-A	287	792' VARIOUS	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-A	1-JB -293-0553	JSE	-A	294	744' 6" VARIOUS	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-A	1-JB -293-0574	JVB	-A	013	734' 9" VARIOUS	FN1	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-B	1-JB -293-0578	JVB	-B	349	730' 5" VARIOUS	FN1	B	100D	ALL	COMPONENT PROTECTION

PAGE A-41

RS

PREPARER/DATE	<u>JLH 9-8-86</u>	<u>R 2</u>	<u>R 3</u>	<u>R</u>
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u>	<u>WCF</u>	
		<u>9-20-89</u>	<u>WCF</u>	
		<u>9-25-89</u>	<u>1.23.90</u>	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
WBN-1-JB JUNCTION BOX	-B	1-JB -293-0596	JVC	-B 346	706' 7"	LC	B	100D	ALL	COMPONENT PROTECTION
					VARIOUS					
WBN-1-JB JUNCTION BOX	-A	1-JB -293-0656	JVC	-A 132	731' 7"	AC2	B	100D	ALL	COMPONENT PROTECTION
					VARIOUS					
WBN-1-JB JUNCTION BOX	-A	1-JB -293-0691	JVB	-A 213	706'	RW	B	100D	ALL	COMPONENT PROTECTION
					VARIOUS					
WBN-1-JB JUNCTION BOX	-B	1-JB -293-0724	JQE	-B 059	748' 6"	ANN	B	100D	ALL	COMPONENT PROTECTION
					VARIOUS					
WBN-1-JB JUNCTION BOX	-A	1-JB -293-0745	JVC	-A 199	805' 8"	UC	B	100D	ALL	COMPONENT PROTECTION
					VARIOUS					

R 2 R 3 R
 PREPARER/DATE JLH 9-8-86 CAG wca
 CHECKED/DATE ETD 9-10-86 9-20-89 WY
 WCG WY
 9-25-89 1-23-90

PAGE A-42 R3

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION			CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMITH	ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB JUNCTION BOX	-B	1-JB -293-0760	JVC	-B 115	731' 4" VARIOUS	IIR	B 100D	ALL	COMPONENT PROTECTION	
WBN-1-JB JUNCTION BOX	-A	1-JB -293-0762	JQE	-A 105	751' 6" VARIOUS	ANN	B 100D	ALL	COMPONENT PROTECTION	
WBN-1-JB JUNCTION BOX	-A	1-JB -293-0764	JVC	-A 060	740' 2" VARIOUS	IIR	B 100D	ALL	COMPONENT PROTECTION	
WBN-1-JB JUNCTION BOX	-B	1-JB -293-0766	JVJ	-B 291	745' VARIOUS	AC4	B 100D	ALL	COMPONENT PROTECTION	
WBN-1-JB JUNCTION BOX	-A	1-JB -293-0768	JQG	-A 297	731' 4" VARIOUS	ANN	B 100D	ALL	COMPONENT PROTECTION	

PAGE A-43 R3

PREPARER/DATE	<u>JLH 9-8-86</u>	R <u>2</u>	R <u>3</u>	R <u> </u>
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG</u>	<u>WCG</u>	<u> </u>
		<u>9-20-89</u>	<u>WCG</u>	<u> </u>
		<u>9-25-89</u>	<u>WCG</u>	<u> </u>

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -293-0775 JUNCTION BOX	-A	1-JB -293-0775	JVB	-A 035	720' 4" VARIOUS	AC1	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-0788 JUNCTION BOX	-A	1-JB -293-0788	JQG	-A 287	727' 9" VARIOUS	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-0792 JUNCTION BOX	-B	1-JB -293-0792	JVD	-B 285	722' VARIOUS	AC4	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-0795 JUNCTION BOX	-A	1-JB -293-0795	JXA	-A 283	728' 10" VARIOUS	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1034 JUNCTION BOX	-A	1-JB -293-1034	JQD	-A 006	835' 9" VARIOUS	ANN	B	100D	ALL	COMPONENT PROTECTION

PAGE A-44 R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG	WCG	
		9-20-89	2-27-90	
		WCG	RT	
		9-25-89	2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
WBN-1-JB -293-1036 JUNCTION BOX	-B	1-JB -293-1036	JQD	-B 357	835' 9"	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1255 JUNCTION BOX	-A	1-JB -293-1255	JQE	-A 028	727' 10"	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1277 JUNCTION BOX	-A	1-JB -293-1277	JXA	-A 311	804' 10"	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1283 JUNCTION BOX	-B	1-JB -293-1283	JXA	-B 317	804' 10"	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1285 JUNCTION BOX	-B	1-JB -293-1285	JXA	-B 319	804' 10"	ANN	B	100D	ALL	COMPONENT PROTECTION

PAGE A-45 R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG 9-20-89	WCG 2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT</u>	<u>DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u> <u>CONTRACT</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-JB -293-1287 JUNCTION BOX	-A	1-JB -293-1287 JXA	-A 313	804'10" VARIOUS	ANN	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1576 JUNCTION BOX	-A	1-JB -293-1576 JVC	-A 100	787' VARIOUS	PRS	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1736 JUNCTION BOX	-B	1-JB -293-1736 JVB	-B 304	738' 6" VARIOUS	AC4	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1738 JUNCTION BOX	-B	1-JB -293-1738 JVC	-B 285	720' VARIOUS	AC4	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1750 JUNCTION BOX	-A	1-JB -293-1750 JVC	-A 308	724'10" VARIOUS	AC4	B	100D	ALL	COMPONENT PROTECTION

PAGE A-46

R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R
 CHECKED/DATE ETD 9-10-86 CAG wcs
 9-20-89 227
 WCG
 9-25-89 227

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION		RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	CONTRACT					
WBN-1-JB -293-1758 JUNCTION BOX	-B	1-JB -293-1758	-B	280	719'10"	AC4	B	100D	ALL	COMPONENT PROTECTION	
		FIELD			VARIOUS						
WBN-1-JB -293-1764 JUNCTION BOX	-B	1-JB -293-1764	-B	285	719'11"	AC4	B	100D	ALL	COMPONENT PROTECTION	
		JVC			VARIOUS						
WBN-1-JB -293-1883 JUNCTION BOX	-B	1-JB -293-1883	-B	165	727'11"	ANN	B	100D	ALL	COMPONENT PROTECTION	
		JXA			VARIOUS						
WBN-1-JB -293-1885 JUNCTION BOX	-A	1-JB -293-1885	-A	191	727'11"	ANN	B	100D	ALL	COMPONENT PROTECTION	
		JXA			VARIOUS						
WBN-1-JB -293-1887 JUNCTION BOX	-A	1-JB -293-1887	-A	007	725' 3"	ANN	B	100D	ALL	COMPONENT PROTECTION	
		JXA			VARIOUS						

PAGE A-47
R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R
 CHECKED/DATE ETD 9-10-86 CAG wca
 9-20-89 WCG
 9-25-89
 2-20-90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-JB -293-1889 JUNCTION BOX	-B	1-JB -293-1889 JXA	-B 350	728' 2" VARIOUS	ANN'	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-1921 JUNCTION BOX	-A	1-JB -293-1921 JVB	-A 297	718' 1" VARIOUS	AC4	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-2649 JUNCTION BOX	-A	1-JB -293-2649 JVC	-A	805' 7" VARIOUS	UC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-3193 JUNCTION BOX	-B	1-JB -293-3193 JVD	-B	784' 10" VARIOUS	UC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-3201 JUNCTION BOX	-B	1-JB -293-3201 JVB	-B 288	720' 3" VARIOUS	AC4	B	100D	ALL	COMPONENT PROTECTION

PAGE A-48 R3

PREPARER/DATE	<u>JLH 9-8-86</u>	<u>R 2</u>	<u>R 3</u>	<u>R</u>
CHECKED/DATE	<u>ETD 9-10-86</u>	<u>CAG 9-20-89</u>	<u>WCG 11/10</u>	
		<u>WCG 9-25-89</u>	<u>WCG 2-23-90</u>	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				MODEL NUMBER	ELEV(1) CONTRACT				
WBN-1-JB -293-3203 JUNCTION BOX	-A	1-JB -293-3203	-A	235	721' 2" VARIOUS	AC3	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-3317 JUNCTION BOX	-B	1-JB -293-3317	-B	280	732' 11" VARIOUS	AC4	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4326 JUNCTION BOX	-D	1-JB -293-4326	-D	030	720' 5" VARIOUS	LC	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4328 JUNCTION BOX	-D	1-JB -293-4328	-D	050	721' 11" VARIOUS	LC	B 100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4330 JUNCTION BOX	-E	1-JB -293-4330	-E	150	721' VARIOUS	LC	B 100D	ALL	COMPONENT PROTECTION

PAGE A-49 R3

PREPARER/DATE JLH 9-8-86 R 2 R 3 R
 CHECKED/DATE ETD 9-10-86
CAG 9-20-89 WCG WCG
9-25-89 22390

W A T T S B A R N U C L E A R P L A N T
 T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT</u>	<u>DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-JB -293-4332 JUNCTION BOX	-E	1-JB -293-4332 JVB	-E 135	721' 3" VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4334 JUNCTION BOX	-F	1-JB -293-4334 JVB	-F 224	723' 7" VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4336 JUNCTION BOX	-F	1-JB -293-4336 JVB	-F 229	720' 8" VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4338 JUNCTION BOX	-G	1-JB -293-4338 JVB	-G 333	720' 9" VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4340 JUNCTION BOX	-G	1-JB -293-4340 JVB	-G 315	717' 1" VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION

PAGE A-50
R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG 9-20-89	WCG 1-22-90	
		WCG 9-25-89	WCG 2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
WBN-1-JB -293-4342 JUNCTION BOX	-D	1-JB -293-4342	JVA	-D 030	720' 10"	LC VARIOUS	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4344 JUNCTION BOX	-D	1-JB -293-4344	JVA	-D 068	719' 7"	LC VARIOUS	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4346 JUNCTION BOX	-D	1-JB -293-4346	JVA	-D 148	720' 4"	LC VARIOUS	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4348 JUNCTION BOX	-D	1-JB -293-4348	JVA	-D 117	719' 4"	LC VARIOUS	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB -293-4350 JUNCTION BOX	-E	1-JB -293-4350	JVA	-E 185	716' 9"	LC VARIOUS	B	100D	ALL	COMPONENT PROTECTION

PAGE A-51
R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG	WCG	
		9-20-89	2-23-90	
		WCG	ETD	
		9-25-89	2-23-90	

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION	
					ELEV(1)	RM/RAD					
WBN-1-JB JUNCTION BOX	-E	1-JB	-293-4352 JVA	-E	240	716' 4" VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-E	1-JB	-293-4354 JVA	-E	340	720' 9" VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION
WBN-1-JB JUNCTION BOX	-E	1-JB	-293-4356 JVA	-E	300	716' 4" VARIOUS	LC	B	100D	ALL	COMPONENT PROTECTION

PAGE A-52

R3

PREPARER/DATE	JLH 9-8-86	R 2	R 3	R
CHECKED/DATE	ETD 9-10-86	CAG	WCP	
		9-20-89	2-22-90	
		WCG	BT	
		9-25-89	2-23-90	

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B1 OF B11
R 1 R _____
BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 9/10/86 PLH
4-27-89
CHECKED ETD DATE 9/15/86 PLH
4-27-89

A. DOCUMENTATION

Equipment Description Junction Boxes
Vendor/Manufacturer Various*
Equipment Model No.(s) See Binder TAB E for a list of mark
numbers used at WBN

QUALIFICATION REPORTS

- (1) Title/Number/Revision Wyle Test Report RIMS B43 860514 501
No. 17733-1, RB, "Nuclear Environmental
Qualification Test Program On Terminal
Blocks & Cables for TVA" DATE 3/19/86
- (2) Title/Number/Revision Calc WBPEVAR8601003, RIMS B26 880527 030
R4 Watts Bar Plant Class 1E Junction Boxes
and local instrument panel list
(Harsh Environment) DATE 5/26/88

R1

OTHER (ANALYSIS, VENDOR DATA, ETC.)

*Comment - The Junction Boxes were purchased on various contracts. They are static, passive devices which only serve to provide a mounting location and a certain degree of protection for other components and devices, therefore contractual documentation is not included.

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B1a OF B11
R 1 R
BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 9/10/86 EAH
7-25-89
CHECKED ETD DATE 9/15/86 JW
4-27-89

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

R1

3. Memorandum, M. L. Rayfield to P. D. Metcalf, August 21, 1986; Watts Bar Nuclear Plant - Engineering Report (ER) for Significant Condition Report (SCR) WBNEQP 8632 (RIMS No. B26 860821 005).
4. Environmental Dwg 47E235-41 R1, -42 R2 & -76 R3.

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

R1

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B2 OF B11
R 1 R 3
BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 6/13/86 CAG WCT
4/11/89 2/22/90
CHECKED ETD DATE 6/13/86 JAW RT
4/26/89 2-23-90

B. CONCLUSION OF REVIEW (Check only one block)

- X Equipment Qualified *
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES * The conclusion of equipment qualified is conditional depending upon resolution of the technical issues listed (see front of binder).

<u>Open Item No.</u>	<u>Punchlist Item No.</u>	
<u>1</u>	<u>JBOX-001-009</u>	
<u>2</u>	<u>JBOX-001-002</u>	
<u>3</u>	<u>JBOX-001-003</u>	
<u>4</u>	<u>JBOX-001-004</u>	
<u>6</u>	<u>JBOX-001-001</u>	<u>IR3</u>
<u>9</u>	<u>JBOX-001-007</u>	
<u>10</u>	<u>JBOX-001-008</u>	
<u>11</u>	<u>JBOX-001-016</u> <u>WCT</u> <u>2/22/90</u>	<u>IR3</u>

COMMENTS/RECOMMENDATIONS The size and type of Junction Boxes used is determined by electrical design requirements. Any junction box manufactured to applicable industry standards (NEMA, UL, ANSI) will meet the WBN Normal/Accident environment. Junction boxes used as pull boxes or splice boxes are not included in TAB A.

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R 1 R
BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 9/15/86
CHECKED ETD DATE 9/15/86
4-26-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-4 was deleted per revision 1 .

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B3 OF B11
 BINDER TITLE JUNCTION BOXES COMPUTED JH DATE 9/10/86 R R
 CHECKED E.T.D. DATE 9.11.86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS Criteria and requirements as set forth in 10CFR50.49 and 10CFR50 App. A have been met through the box manufacturer's adherence to recognized industry standards and this binder's utilization of qualification methods as outlined in IEEE 323-1974.

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

NEMA STD 250

ANSI/UL 50

JIC EMP-1/EGP-1-1967

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B4 OF B11
BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 5/15/86 R R
CHECKED ETD DATE 5/15/86

D. QUALIFICATION METHODOLOGY (Check only one block)

 Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

 Test of Similar Items with Supporting Analysis

X Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

 Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS IEEE 323-1974 states that: "Qualification
May Be Accomplished in Several Ways: Type Testing, Operating
Experience, or Analysis." The method used for qualifying junction
boxes at WBN relies heavily on analysis with some supporting type
test data from qualification testing of other equipment housed in
junction boxes during testing. See WYLE Laboratories Test Report
17733-1 in TAB D, portions of which support the analysis presented
in TAB C. TAB C presents a quantitative analysis (where pertinent)
in addition to a qualitative analysis of the junction boxes which
affirms that the performance/functional requirements of the junction
boxes (based on applicable industry standards - NEMA 250, ANSI/UL 50,
etc.) are met when the boxes are subjected to the WBN normal/acci-
dent service conditions and accident environments. Full considera-
tion of the time dependent effects of environmental influences was
taken in establishing the qualified life of the WBN junction boxes.

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B5 OF B11

R 1 R

BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 5/15/86 ^{4/11-84}

CHECKED ETD DATE 5/15/86 ⁴⁻²⁶⁻⁸⁹

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? _____ | R1

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Junction Boxes (Various Types and Sizes)</u>	<u>NEMA 12 Junction Box (12½"x10"x8")</u>	<u>17733-1 Section X Para 3.2.1</u>
(2) Manufacturer	<u>Various</u>	<u>Various</u>	_____
(3) Model Number(s)	<u>See TAB E</u>	<u>N/A</u>	<u>N/A</u>
	_____	_____	_____
	_____	_____	_____
(4) Serial Number(s)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	_____	_____	_____
	_____	_____	_____
(5) Identify Component- Unique checksheet attached:	<u>N/A</u>		

JUSTIFICATION/COMMENTS The basic structure and function of junction boxes are similar regardless of variations in size and NEMA types/features. The type box used in the WYLE Laboratories Test is representative of those boxes used at WBN.

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B6 OF B11
 BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 5/15/86 R R
 CHECKED ETD DATE 5/15/86

F. INSTALLATION INTERFACES

Does the qualification program address all relevant interfaces of the equipment so that the installed design and configuration is similar or identical to the test configuration (yes/no/NA)? (note below)

<u>Interface</u>	<u>Identify Interface Requirement</u>	<u>Acceptable? (Yes/No/NA)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>N/A</u>	<u> </u>	<u> </u>
External Process Connections	<u>N/A</u>	<u> </u>	<u> </u>
Electrical Connections	<u>N/A</u>	<u> </u>	<u> </u>
Conduit Seals	<u>N/A</u>	<u> </u>	<u> </u>
Connector Seals	<u>N/A</u>	<u> </u>	<u> </u>
Orientation	<u>N/A</u>	<u> </u>	<u> </u>
Physical Configuration	<u>N/A</u>	<u> </u>	<u> </u>
Other	<u>Internal Components See Comments</u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS Mounting of internal components is addressed in the qualification of terminal blocks, handswitches, etc. Where placement orientation, etc. is important to qualification, it is addressed for those particular components being qualified.

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B7 OF B11

BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 5/15/86 R R

CHECKED ETA DATE 5/15/86

Sections G through M are omitted as not being applicable to this
equipment.

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B9 OF B11

BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 5/15/86 R R

CHECKED [Signature] DATE 5/15/86

0. SUMMARY OF REVIEW

Yes/No/NA

- (1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)? Yes
- (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified? N/A
- (3) Choice of qualification methodology adequately justified? Yes
- (4) If analysis was performed, complete the following:
- (a) Were equipment performance requirements identified? Yes
- (b) Were specific features and failure modes and effects analyzed? N/A
- (c) Were assumptions and mathematical models used together with appropriate justification for their use? N/A
- (d) Were environmental parameters which affect equipment performance identified? Yes
- (5) Adequate similarity between equipment and test specimen established? Yes
- (6) Aging degradation evaluated adequately? Yes
- (a) Mechanical and/or cycle aging addressed? N/A
- (b) Equipment aged to end of life condition prior to application of DBE conditions? N/A
- (c) Absence of preaging in test/analysis justified? N/A
- (d) Materials susceptible to thermal/radiation aging identified? Yes

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B10 OF B11
 BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 5/15/86 R R
 CHECKED ETD DATE 5/15/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>N/A</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>N/A</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>N/A</u>
(9) Criteria regarding test sequence satisfied?	<u>N/A</u>
(10) Criteria regarding spray satisfied?	<u>N/A</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>N/A</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>N/A</u>
(11) Criteria regarding submergence satisfied?	<u>N/A</u>
(12) Criteria regarding radiation satisfied?	<u>N/A</u>
(a) Was dose rate considered?	<u>N/A</u>
(b) Was beta radiation considered?	<u>N/A</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>N/A</u>

BINDER NO. WBNEQ-JBOX-001 PLANT WBN UNIT(S) 1 SHEET B11 OF B11
 BINDER TITLE JUNCTION BOXES COMPUTED JLH DATE 5/15/86 R R
 CHECKED ETA DATE 5/15/86

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>N/A</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>N/A</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>N/A</u> |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>N/A</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>N/A</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>N/A</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>N/A</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>N/A</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>N/A</u> |
| (19) Criteria regarding margins satisfied? | <u>N/A</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

F. DISCUSSION

