


BAR NUCLEAR PLANT UNIT 1

TENNESSEE VALLEY AUTHORITY

w/ ltr. dtd. 4/30/91

50-390



9103090262

-NOTICE-

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE INFORMATION & REPORTS MANAGEMENT BRANCH. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS & ARCHIVES SERVICES SECTION P1-22 WHITE FLINT. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

-NOTICE-

SUPPLEMENTAL INFORMATION-
TVA'S COMPLIANCE TO 10 CFR50.49-
ENVIRONMENTAL QUALIFICATION OF
ELECTRIC EQUIPMENT
IMPORTANT TO SAFETY FOR
NUCLEAR POWER PLANTS

SUPPLEMENTAL INFORMATION
TVA'S COMPLIANCE TO 10CFR50.49 - ENVIRONMENTAL QUALIFICATION
OF ELECTRIC EQUIPMENT IMPORTANT TO SAFETY
FOR NUCLEAR POWER PLANTS
VOLUME 4

TABLE OF CONTENTS

<u>BINDER NUMBER</u>	<u>REVISION</u>	<u>EQUIPMENT TYPE</u>	<u>VENDOR</u>
WBNEQ-MOT-001	2	Large Electric Induction Motors - Outside Containment	Westinghouse
WBNEQ-MOT-002	3	Electric Induction Motors with Type RH Insulation - Inside Containment	Joy Fan/ Reliance Electric
WBNEQ-MOT-003	3	Electric Induction Motors with Type RH Insulation - Outside Containment	Reliance
WBNEQ-MOT-004	2	Electric Squirrel Cage Induction Motor - Outside Containment	Louis Allis
WBNEQ-MOV-001	4	Motorized Valve Actuators with Type RH Insulation	Limitorque
WBNEQ-MOV-003	5	Motorized Valve Actuators with Class B Insulation	Limitorque
WBNEQ-PENT-002	3	Primary Containment Electrical Penetration, Low Voltage Power and Control	Conax Corp.
WBNEQ-PENT-003	2	Primary Containment Electrical Penetrations, Instrumentation and Indication	Conax Corp.

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZMUTH ELEV(12) RM/RAD CONTRACT	CAI OPER TIME EVENT SAFETY FUNCTION (2)
WBN-1-MTR -062-0104 CVCS PUMP MOTOR	-B 1-MTR -062-0104 HSDP	-B 692' A10 71C62-54114-1	A 100D A 1M0 A 1M0 A 1M0 A 1M0 L RH/A THE CCP'S MTRS ARE ESSENTIAL CV/A FOR PROPER OPERATION OF THE AF PMPS WHICH ARE REQUIRED FOR AB THE MITIGATION OF THESE EVENTS
WBN-1-MTR -062-0108 CVCS PUMP MOTOR	-A 1-MTR -062-0108 HSDP	-A 692' A09 71C62-54114-1	A 100D A 1M0 A 1M0 A 1M0 A 1M0 L RH/A THE CCP'S MTRS ARE ESSENTIAL CV/A FOR PROPER OPERATION OF THE AF PMPS WHICH ARE REQUIRED FOR AB THE MITIGATION OF THESE EVENTS
WBN-1-MTR -063-0010 SIS PUMP MOTOR	-A 1-MTR -063-0010 HSDP	-A 692' A13 71C62-54114-1	A 100D C C C C L RH/A THE SIS PMPS MUST FUNCTION FOR CV/A THE DURATION OF THE LOCA TO AF ASSURE ADEQUATE CORE COOLING. AB THEY ARE NOT REQ'D TO MITIGATE ANY EVENTS IN THE AUX BLDG.
WBN-1-MTR -063-0015 SIS PUMP MOTOR	-B 1-MTR -063-0015 HSDP	-B 692' A12 71C62-54114-1	A 100D C C C C L RH/A THE SIS PMPS MUST FUNCTION FOR CV/A THE DURATION OF THE LOCA TO AF ASSURE ADEQUATE CORE COOLING. AB THEY ARE NOT REQ'D TO MITIGATE ANY EVENTS IN THE AUX BLDG.
WBN-1-MTR -072-0010 CS PUMP MOTOR	-B 1-MTR -072-0010 HSW2	-B 676' A08 71C62-54114-1	A 30D C C C C L RH/A THE CSS PMPS ARE REQUIRED AND CV/A MUST OPERATE DURING THE AF MITIGATION OF A LOCA. THE CSS AB IS NOT REQUIRED TO MITIGATE ANY EVENTS IN THE AUX BLDG.

PREPARER/DATE R C Foust 7/30/86
CHECKED/DATE W B Kim 7/30/86

R 1
JON
2-7-89
KEL
2/8/89

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION ELEV(1) RM/RAD CONTRACT	CAI OPER TIME (2)	EVENT	SAFETY FUNCTION
WBN-1-MTR -072-0027 CS PUMP MOTOR	-A 1-MTR -072-0027 HSW2	-A 676' A09 71C62-54114-1	A 300 C C C	L RH/A CV/A AB AF	THE CSS PMPS ARE REQUIRED AND MUST OPERATE DURING THE MITIGATION OF A LOCA. THE CSS IS NOT REQUIRED TO MITIGATE ANY EVENTS IN THE AUX BLDG.
WBN-1-MTR -074-0010 RHR PUMP MOTOR	-A 1-MTR -074-0010 VSW1	-A 676' A11 79P64-160412	A 100D C C C	L RH/A CV/A AF AB	THESE PMPS FUNCTION AS PART OF THE ECCS TO ENSURE ADEQUATE CORE COOLING DURING A LOCA. ACTUATION OF THE ECCS IS NOT REQD FOR RH/A, CV/A, AF, OR AB
WBN-1-MTR -074-0020 RHR PUMP MOTOR	-B 1-MTR -074-0020 VSW1	-B 676' A10 71C62-54114-1	A 100D C C C	L RH/A CV/A AF AB	THESE PMPS FUNCTION AS PART OF THE ECCS TO ENSURE ADEQUATE CORE COOLING DURING A LOCA. ACTUATION OF THE ECCS IS NOT REQD FOR RH/A, CV/A, AF, OR AB

PREPARER/DATE	R C Foust	7/30/86	R 1	R	R
CHECKED/DATE	W B Kim	7/30/86	TDH		
			2-7-89		
			2/8/89		

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE WESTINGHOUSE COMPUTED /R1 JCH DATE 2-7-89
MOTORS ON RHR, CVCS, CS, AND SIS CHECKED /R1 KBN DATE 2/8/89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-1A R1 for source of Category and Operating Time assignments.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 27
R 1 R
BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 7/10/86 JDH
2-7-89
MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK DATE 7/21/86 KBN
2/8/89

A. DOCUMENTATION (see note) - |R1

Equipment Description CS, RHR, SIS, and CVCS pump motors
Vendor/Manufacturer Westinghouse
Equipment Model No.(s) See TAB A for complete listing of
the equipment covered by this report.

QUALIFICATION REPORTS (see note) |R1

- WCAP-8687
- *(1) Title/Number/Revision EQTR-A02A, Rev. 2 RIMS B43 85041 304
"Equipment Qualification Test Report
Westinghouse LMD Motor Ins." DATE March 1983
NEB
- (2) Title/Number/Revision WCAP-8754, RIMS 801215300
"Environmental Qualification of Class 1E
Motor for Nuclear Out-of-Containment Use". DATE June 1976
WCAP-8587
- (3) Title/Number/Revision EQDP AE-2, Rev. 5 RIMS B43 850401 303
"Environmental Qualification Data Package
Large Pump Motors (outside containment)." DATE March 1983

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (4) 3170 Application Data.
- (5) NP-1447 EPRI Report Project 893-1 dated July 1980, pages 3-14 through 3-20.
- (6) NP-4172SP dated August 1985 (see "Lubricants" - TAB C).
- (7) NP-3887 dated February 1985 (TAB G).
- (8) 47E235-74 R1 Environmental drawing.
- (9) 47E235-79 R1 Environmental drawing.
- (10) 47E235-81 R1 Environmental drawing.
- (11) EQ&T-EQT-3592 Rev 0 Westinghouse Report

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 1a OF 27
R 2 R _____
BINDER TITLE WESTINGHOUSE COMPUTED /R1 JDH DATE 2/7/89 AK
3/15/90
MOTORS ON RHR, CVCS, CS, AND SIS CHECKED /R1 KBN DATE 2/8/89 CT
3/15/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (12) EQ&T-EQT-2026 Rev 0 (B71 860530 004) Westinghouse Report
- (13) EQ&T-EQT-3827 Rev 0 Westinghouse Report
- (14) WBNOSG4-013 R12 (B26 900327200) ^{CO} System 62,
Category and Operating Times Calculation
- (15) WBNOSG4-014 R11 (B26 900309 227) System 63,
Category and Operating Times Calculation
- (16) WBNOSG4-019 R7 (B26 900309 234) System 72,
Category and Operating Times Calculation
- (17) WBNOSG4-020 R8 (B26 900309 232) System 74,
Category and Operating Times Calculation
- (18) GENNAL6-002 R2 (B45 860812 236) Areas with High Potential
for Condensate Formation
- (19) WBP EVAR 8602001 R0 (B43 860227 901) Degraded Voltage for
Environmental Qualification Project

R2

* WCAP-8687 is the only test report used for qualification purposes. However, WCAP-8754 and -8587 were included because they contain useful information on Westinghouse motors.

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 2 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RCF DATE 9/18/86 R R
ON RHR, CVCS, CS, and SIS CHECKED WBK/ANOT DATE 9/19/86

B. CONCLUSION OF REVIEW (Check only one block)

- | | |
|---------------|---|
| <u> X </u> | Equipment Qualified Pending Resolution of All Open Items. |
| <u> </u> | Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule |
| <u> </u> | Equipment Qualification Not Established by Documentation |
| <u> </u> | Equipment Not Qualified Based on Test Failures |

OPEN ITEMS AND QUALIFICATION DEFICIENCIES See Open Items in front
of binder.

- 1 - SCR EEB8618 must be resolved (see Open Item No. 6).
 - 2 - Watts Bar must supply termination data (see Open Item No. 1).
 - 3 - Watts Bar must supply documentation on installed motors
- S.O. No. 78F35296 and 79F55979 (see Open Item No. 5).

COMMENTS / RECOMMENDATIONS

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 3 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/10/86
ON RHR, CVCS, CS, and SIS CHECKED WJH DATE 7/21/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

Components are Qualified to the Criteria of 10CFR50.49
and/or NUREG-0588 Category I (IEEE323-1974)

X Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

NEMA Standard MG1-1972, IEEE 275-1966, IEEE 112A-1964, IEEE 344-1975.

Reg. Guide 1.89.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 4 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/30/86 R R
ON RHR, CVCS, CS, and SIS CHECKED AKK DATE 7/30/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- X Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The qualification of these motors is based
on a Westinghouse test in which only a stator was subjected to
environmental testing. Westinghouse denotes that only the
thermalastic epoxy insulation system is the limiting material in
these motors. The effects of accident conditions on lubricants,
bearings, and interfaces are discussed in TAB C and are
qualified by analysis. Westinghouse has provided a materials
comparison on the tested stator versus the TVA motors. This com-
parison is discussed in TAB C, "Similarity."

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 5 OF 27

BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/30/86 R R

ON RHR, CVCS, CS, and SIS CHECKED WPK DATE 7/30/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No
See Section A and C.

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Motor(s)</u>	<u>Stator</u>	<u>WCAP-8687</u> <u>page 2</u>
(2) Manufacturer	<u>Westinghouse</u>	<u>Same</u>	<u>WCAP-8687</u> <u>page 2</u>
(3) Model Number(s)	<u>See TAB C</u>	<u>S.O.# 76F60185</u>	<u>WCAP-8687</u> <u>page 2</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(4) Serial Number(s)	<u>See TAB C</u>	<u>1S-78</u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(5) Identify Component- Unique checksheet attached:	<u>Supplement 1, pages 26 and 27 of this tab.</u>		

JUSTIFICATION/COMMENTS TAB C provides a comparison between
the W test stator and the TVA motors. A discussion is provided
for all items which are not the same.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 6 OF 27
 R 1 R
 BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 7/10/86 JDH
2-7-89
 MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK DATE 7/21/86 KBN
2/8/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>*None</u>	<u>N/A</u>	
External Process Connections	<u>*None</u>	<u>N/A</u>	
Electrical Connections	<u>*None</u>	<u>N/A</u>	
Conduit Seals	<u>None</u>	<u>N/A</u>	
Connector Seals	<u>None</u>	<u>N/A</u>	
Orientation	<u>*None</u>	<u>N/A</u>	
Physical Configuration	<u>None</u>	<u>N/A</u>	
Other	<u>None</u>		

R1

JUSTIFICATION/COMMENTS *The W test was performed only on a
stator not the motor assembly as a whole. The interfaces listed
above have been analyzed and are noted in TAB C.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 7 OF 27
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RCF DATE 7/18/86 R R
 ON RHR, CVCS, CS, and SIS CHECKED WPK DATE 7/21/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>Pg. 7 of WCAP-8687</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Table 4 of WCAP-8687</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>Pg. 7 of WCAP-8687</u>
Radiation	<u>Yes</u>	<u>Pg. 8 of WCAP-8687</u>
Wear	<u>No</u>	<u> </u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Pg. 6&8 of WCAP-8687</u>
(e) Design basis event (DBE) exposure (radiation and humidity)	<u>Yes</u>	<u>Pg. 8&9 of WCAP-8687</u>
(f) Post-DBE exposure	<u>N/A</u>	<u> </u>
(g) Final inspection and disassembly	<u>No</u>	<u> </u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? No
 (Reference Table 1 and 2 of WCAP-8687).

JUSTIFICATION/COMMENTS (1)Wear aging was not defined as a pretest requirement. Following completion of the test, the stator was subjected to a series of electrical tests which proved the reliability of the insulation system. (2)Complete calibration data was not included within the text of the qualification report. However, this information is on file at Westinghouse and is available for audit.

PAGE B-7

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 8 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RCF DATE 7/30/86 R R
ON RHR, CVCS, CS, and SIS CHECKED WMMK DATE 7/30/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference Pg. 7&8 of WCAP-8687).

JUSTIFICATION/COMMENTS The test stator was subjected to thermal,
radiation, and vibration aging.

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Pg. 7 of WCAP-8687</u>
Radiation exposure	<u>Yes</u>	<u>Pg. 8 of WCAP-8687</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Pg. 6 & 8 of WCAP-8687</u>
Operational (electrical/mechanical/process) stress aging	<u>No</u>	<u> </u>

JUSTIFICATION/COMMENTS Only a stator was tested.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? N/A (Reference).

JUSTIFICATION/COMMENTS Based on available information, no known
synergistic effects exist in these motors.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
(yes/no/NA)? Yes (Reference Pg. 7 of WCAP-8687).

JUSTIFICATION/COMMENTS Only two materials were identified
as being significantly affected by thermal aging; they are
the thermalastic epoxy insulation and motor lubricant. Since
the motor lubricant is sampled and replaced periodically,
only the insulation was subjected to thermal aging.

PAGE B-8

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 9 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 2/17/86 R R
ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 2/21/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference: Pg. 7 of WCAP-8687 & TAB C).

JUSTIFICATION/COMMENTS Thermalastic Epoxy insulation, see
"Similarity" in TAB C.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Pg. 2&3 of WCAP-8687).

JUSTIFICATION/COMMENTS _____

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Pg. 7 of WCAP-8687).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	104°F or 40°C	210°C	See TAB C
Time	40 Years Normal	168hrs	See TAB C

JUSTIFICATION/COMMENTS See TAB C

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Pg. 7 of WCAP-8687).

JUSTIFICATION/COMMENTS	See TAB C

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes
(Reference Pg. 7 of WCAP-8687).

JUSTIFICATION/COMMENTS Activation energy of 1.11 ev was
derived from tests performed as required by IEEE-275-1966.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 10 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RJR DATE 7/10/86 R R
ON RHR, CVCS, CS, and SIS CHECKED WJK DATE 7/21/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? No (Reference Pg. 59 of WCAP-8687).

JUSTIFICATION/COMMENTS Arrhenius Methodology was used. See
TAB C.

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference _____).

JUSTIFICATION/COMMENTS Stator was meggered before and
after.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference Pg. 8 of WCAP-8687).

JUSTIFICATION/COMMENTS TID of 5×10^7 rads, gamma following thermal aging.

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes (Reference Pg. 7 of WCAP-8687 and TAB C).

JUSTIFICATION/COMMENTS Thermalastic Epoxy.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes (Reference Pg. 3 of WCAP-8687).

JUSTIFICATION/ COMMENTS

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 11 OF 27
 R 1 R
 BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 7/10/86 JDW
2-7-89
 MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK DATE 7/21/86 KEL
2/8/89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: Pg. 8 of WCAP 8687).

Plant normal ambient radiation dose (rd) 3.6×10^6 -40 Yr Norm

Test exposure dose (rd) 5×10^7 gamma

Test exposure dose rate (rd/hr) 9.4×10^5

Test exposure source type (e.g., Co-60 gamma) Cobalt-60

JUSTIFICATION/COMMENTS 267 percent greater than plant specific requirement.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ (YES/NO/NA)? Yes (Reference: Pg. 8 of WCAP-8687).

R1

JUSTIFICATION/COMMENTS The effects of the Vibration aging are noted on Table 4, pg 22, of WCAP-8687. Vibration aging had no effect on the insulation resistance.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: See below).

JUSTIFICATION/COMMENTS The basis for vibration aging was given in WCAP 8687, page 8.

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? No (Reference:).

JUSTIFICATION/COMMENTS Only the stator of the test motor was subjected to testing environment. It is not possible to define or consider the effects of these stresses when only a stator was tested.

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder.

R1

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 12 OF 27
R 1 R _____
BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 7/10/86 JDH
2-7-89
MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK DATE 7/21/86 KEN
2/8/89

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? N/A (Reference: _____).

JUSTIFICATION/COMMENTS _____

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: See TAB C _____).

Qualified life (Document in QMDS) 40 years

JUSTIFICATION/COMMENTS Westinghouse defines the qualified life as 5 years per pg 8 of WCAP-8687. For the TVA application, TAB C defines the qualified life.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: Pg. 2 of WCAP-8687 _____).

JUSTIFICATION/COMMENTS Westinghouse only requires periodic lubricant replacement, but since electrical tests were conducted throughout the test, TVA will perform periodic electrical tests to provide an indication of age related degradation and failure mechanisms (see TAB G).

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 13 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 7/19/86 R R
ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/21/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>See TAB C</u>	<u>(Similarity)</u>	<u> </u>	<u> </u>	<u> </u>
(b) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(c) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(d) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(e) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS Provided in TAB C.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 14 OF 27

BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 2/18/86 R R

ON RHR, CVCS, CS, and SIS _____ CHECKED [Signature] DATE 7/21/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference WCAP-8687, pgs. 3 and 12).

Identify Acceptance Criteria: The tested stator must measure greater than 5 megohms when subjected to a 2500 VDC megger and must pass a 6000 VAC hipot for one minute.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Sect. 5.1, pg. 7 of WCAP-8687).

Identify baseline and functional testing: Before and after each
major test sequence, the resistance of the stator insulation was
measured and the ambient temperature recorded. Resistance was
measured using a 2500 VDC megger where the stator leads were tied
together. The voltage was applied for 10 minutes and measurements
taken at 15, 30, 45, 60, 90, and 120 seconds and at 1 minute intervals
thereafter until test completion. Also see above.

JUSTIFICATION/COMMENTS

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? No
(Reference _____).

JUSTIFICATION/COMMENTS Only a stator was tested; therefore,
operational loading conditions could not be addressed. However, the
stator passage of the electrical test described in WCAP-8687
demonstrates that the insulation system had shown no signs of
significant wear and verified its integrity.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 15 OF 27
 R 1 R
 BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 7/10/86 JDH
2-7-89
 MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK DATE 7/21/86 KBN
2/12/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS.
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? No (Reference: _____).
 _____).

JUSTIFICATION/COMMENTS But the testing assures stator
reliability

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference	R1
Voltage	_____	_____	
Load	_____	_____	
Frequency	_____	_____	
Accuracy	_____	_____	
Other(s)	_____	_____	
_____	_____	_____	
_____	_____	_____	

JUSTIFICATION/COMMENTS See "Justification/Comments"
under 5(c) page 16 of this Tab. R1

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 16 OF 27
 R 1 R 1
 BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 7/10/86 JDH
2-7-89
 MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK DATE 7/21/86 KBN
2/8/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>	R1
Voltage	_____	_____	
Load	_____	_____	
Frequency	_____	_____	
Accuracy	_____	_____	
Other(s)	_____	_____	
_____	_____	_____	
_____	_____	_____	

JUSTIFICATION/COMMENTS _____

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>	R1
Voltage	_____	_____	
Load	_____	_____	
Frequency	_____	_____	
Accuracy	_____	_____	
Other(s)	_____	_____	
_____	_____	_____	
_____	_____	_____	

JUSTIFICATION/COMMENTS A discussion of these parameters is
included in TAB C.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 17 OF 27
R 1 R _____
BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 7/18/86 JH
2-7-89
MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK DATE 7/21/86 KBN
2/8/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-74, -79, and -81 | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104 (a) Temperature (°F) 110

(b) Pressure (psig) ATM(-) (b) Pressure (psig) ATM(-) | R1

(c) Humidity (%) 80 (c) Humidity (%) 90

*(d) Radiation (rd) 3.6×10^6 (d) Radiation (rd) 3.6×10^6

*Greatest value for any of the motors qualified in this binder.
(See TVA Calculation WBNAL3-025) | R1

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Temperature and humidity - Up to 8 hours per excursion and less than 1 percent of plant life (excluding accident conditions).

(5) Accident (worst case for any combination of specified accident parameters including peak, duration, and profile):

110 for 30 days

(a) Temperature (°F) 104 for 70 days Accident type LOCA

(b) Pressure (psig) ATM(-) Accident type LOCA | R1

(c) Humidity (%) 90 Accident type LOCA

(d) Radiation (rd) 1×10^7 Accident type LOCA

(e) Spray Type None Accident type LOCA

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 27
R 1 R _____
BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 9/17/86 JDH
2-7-89
MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK/AWT DATE 9/17/86 KB
2/6/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Under worse conditions of Post-LOCA, the

CVCS, RHR, and SIS motors are required to operate 100 days.

The CS motors are required for 30 days.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: _____)

See TAB C _____).

- (7) Subject to submergence (Yes/No/NA)? No (Reference: _____)

See "Submergence" in TAB C _____).

Identify initiation time and duration of submergence: _____

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No
(Reference: _____).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B Section A _____

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 19 OF 27
 R 1 R 1
 BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 7/18/86 TDH
2-7-89
 MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK DATE 7/21/86 KEW
2/8/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 Days</u>	<u>***48 Hours</u>	See TAB D Sec. 5.6 of WCAP 8687
Temperature (°F)	<u>110</u>	<u>95</u>	See TAB D Sec. 5.6 of WCAP 8687
Pressure (psig)	<u>-0-</u>	<u>-0-</u>	See TAB C
Relative Humidity (%)	<u>90</u>	<u>100</u>	See TAB C and TAB D Sec. 5.6 of WCAP 8687
Chemical Spray*	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Radiation (rd)**	<u>1.36x10⁷ gamma</u>	<u>5x10⁷ gamma</u>	See TAB C and TAB D Sec. 5.3 of WCAP 8687
Submergence	<u>N/A</u>	<u>N/A</u>	<u>N/A***</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

***Westinghouse subjected the test stator to a 100% relative humidity/environment for 48 hours. However, the TVA motors are not subject to this condition. The TVA motors are only subject to DBA radiation exposure with no appreciable increase in temperature, pressure, or humidity (see TAB C).

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 19a OF 27
 BINDER TITLE WESTINGHOUSE COMPUTED 1R1 JOK DATE 2-7-89
 MOTORS ON RHR, CVCS, CS, AND SIS CHECKED 1R1 KOK DATE 2/8/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(continued)

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>See TAB C</u>
Pressure	<u>Yes</u>	<u>See TAB C</u>
Relative Humidity	<u>Yes</u>	<u>See TAB C</u>
Chemical Spray	<u>Yes</u>	<u>N/A</u>
Submergence	<u>N/A</u>	<u>N/A</u>
JUSTIFICATION/COMMENTS		

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 20 OF 27
 BINDER TITLE WESTINGHOUSE COMPUTED RCF DATE 7/18/86 2-28-89
 MOTORS ON RHR, CVCS, CS, AND SIS CHECKED WBK. DATE 7/21/86 2/28/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA (Hot Spot Margin)</u>
*Temperature: +15 degrees F	<u>27°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>N/A</u>	<u>N/A</u>
Radiation: +10% of accident dose	<u>267%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>See TAB C</u>	
Voltage: ±10% of rated value	<u>See TAB C</u>	
Frequency: ±5% of rated value	<u>See TAB C</u>	
Environmental Transient: the initial transient and the peak temperature applied twice	<u>See TAB C and Below</u>	
Vibration: +10% added to acceleration	<u>See TAB C</u>	

JUSTIFICATION/COMMENTS The accident parameters are not significantly different from the max. normal with the exception of radiation. TAB C provides a discussion on each of the parameters listed above. Only a stator was tested by Westinghouse. In addition, 0588-Category I requires the application of the environmental transient twice. 0588-Category II does not.

*A 15°C (27°F) hot spot margin was added to the stator temperature as calculated in TAB C. This margin provides conservatism for the Arrhenius aging analysis.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 21 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RCF DATE 7/10/86 R R
ON RHR, CVCS, CS, and SIS CHECKED WML DATE 7/11/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference See TAB A).

JUSTIFICATION/COMMENTS _____

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? N/A
(Reference _____).

JUSTIFICATION/COMMENTS Only a stator was tested.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? N/A
(Reference _____).

JUSTIFICATION/COMMENTS Only a stator was tested.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? No (Reference _____).

JUSTIFICATION/COMMENTS Only a stator was tested.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? N/A
(Reference _____).

JUSTIFICATION/COMMENTS No abnormal conditions or anomalies
were identified.

PAGE B-21

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 22 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/10/86 R R
ON RHR, CVCS, CS, and SIS CHECKED WJK DATE 7/21/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See TAB G

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 23 OF 27
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/19/86 R R
ON RHR, CVCS, CS, and SIS CHECKED WJK DATE 7/21/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>N/A</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>Yes</u>
(b) Were specific features and failure modes and effects analyzed?	<u>Yes</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>Yes</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>Yes</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>N/A</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 24 OF 27
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED WFF DATE 7/10/86 R R
 ON RHR, CVCS, CS, and SIS CHECKED WPK DATE 7/21/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>N/A</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>N/A</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>N/A</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>N/A</u>
(11) Criteria regarding submergence satisfied?	<u>N/A</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>N/A</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>N/A</u>

PAGE B-24

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 25 OF 27
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RCF DATE 7/1/86 R R
 ON RHR, CVCS, CS, and SIS CHECKED WPK DATE 7/21/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>N/A</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>*No</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>N/A</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>Yes</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

*See TABS C and G. The accident conditions are not significantly different from the max. normal with the exception of radiation; therefore, the major concern is radiation and aging. TAB C provides a detailed discussion on each. Based on the analysis provided in TAB C along with this section, it is concluded that the motors covered by this report are qualified for 40 years plus 100 days post-accident.

PAGE B-25-

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 26 OF 27
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RCF DATE 7/30/86 R R
 ON RHR, CVCS, CS, and SIS CHECKED WHR DATE 7/30/86

SUPPLEMENT 1
 COMPONENT-UNIQUE CHECKLIST
 MOTORS

Page 1 of 2

EQUIPMENT IDENTIFICATION

- (1) Is the motor identified in the qualification report identical to the plant motors which require qualification (yes/no/NA)? No (Similar)

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(a) Insulation system Thermalastic materials	<u>Epoxy</u>	<u>Same</u>	<u>Yes</u>	See <u>TAB C</u>
(b) Coil construction (form or random wound, cast)	<u>Form</u>	<u>Form</u>	<u>Yes</u>	Form 3170 (See Section E7) See
(c) Insulation class (B, F, H)	<u>B</u>	<u>B</u>	<u>Yes</u>	<u>TAB C and WCAP-8687</u>
(d) Lubricant				
Manufacturer	<u>Var.</u>	<u>Var.</u>	<u>Yes</u>	See TAB <u>C and E</u>
Type	<u>*STO-2</u>	<u>Var.</u>	<u>Yes</u>	See <u>TAB C</u>
(e) Bearing				
Manufacturer	<u>Westing- house</u>	<u>Westing- house</u>	<u>Yes</u>	See <u>TAB C&E</u>
Type	<u>Split Sleeve & Ball</u>	<u>N/A</u>	<u>Yes</u>	See <u>TAB C&E</u>
Bearing life	<u>See Sec C</u>	<u>N/A</u>	<u>Yes</u>	See <u>TAB C&E</u>
(f) Seals				
Manufacturer	<u>Unknown</u>	<u>Unknown</u>	<u>Yes</u>	<u>Seals are metallic</u>
Type	<u>Metal</u>	<u>Metal</u>	<u>Yes</u>	<u>See (5) on next pg</u>
Material	<u>Brass</u>	<u>Brass</u>	<u>Yes</u>	<u>See (5) on next pg</u>

*STO-2 is a generic designator for Turbine Oils procured by TVA. See procurement specification 18.009 and TAB C.

PAGE B-26

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 27 OF 27

BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/30/86 R R

ON RHR, CVCS, CS, and SIS CHECKED WMA DATE 7/30/86

EQUIPMENT IDENTIFICATION (Continued)

Page 2 of 2

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(g) Motor lead insulation	<u>Same</u>	Treated Glass <u>Sleeving</u>	<u>Yes</u>	See <u>TAB C</u>

Comments: _____

- (2) Does the qualification report indicate that the motorette insulation system is the same as that used on the motors (yes/no/NA)? N/A
(Reference See TAB C "Similarity" & Sections E11, E12, and E13).

Comments: Qualification testing was not performed on a motorette,
but a full size stator.

- (3) Has the vendor provided the bearing rating (yes/no/NA)? Yes
(Reference TAB E).

Comments: Motor Data Sheets

- (4) Was the lubricant included in the test program (yes/no/NA)? No
(Reference Pg. 2 of WCAP-8687).

Comments: Motor lubricant is qualified separately in TAB C.

- (5) Were the seals included in the test program (yes/no/NA)? No
(Reference See WCAP-8754, pg. 8-4, paragraph 6, TAB D).

Comments: Only a stator was tested. The seals are brass construc-
tion and are not age sensitive or susceptible to radiation
degradation.

PAGE B-27

PRINT DATA

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-MOT -002
MANUFACTURER : JOY FAN/RELIANCE
PAGE 1 OF 1

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD CONTRACT				
WBN-1-MTR -030-0038 CONTAINMENT AIR RETURN FAN MOTORS	-A	1-MTR -030-0038	-A 250 42.25-26.5-1770	733' 1" AC3 77K35-83165		A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MTRS START ON A PHASE B CNTMT ISLN SIG & MUST OPR FOR DURATION OF EVENT. FANS ENHANCE ICE COND & CS HEAT REML. LIMIT H2 BUILD-UP
WBN-1-MTR -030-0039 CONTAINMENT AIR RETURN FAN MOTORS	-B	1-MTR -030-0039	-B 297 42.25-26.5-1770	740' 11" AC4 77K35-83165		A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MTRS START ON A PHASE B CNTMT ISLN SIG & MUST OPR FOR DURATION OF EVENT. FANS ENHANCE ICE COND & CS HEAT REML. LIMIT H2 BUILD-UP.

PAGE A-1 R3

R 2 R 3 R
PREPARER/DATE R. S. Raymond 6/9/86 JDH
1/18/89 9/24/89
CHECKED/DATE W. B. Kim 7/1/86 KBN
1/18/89 9/23/89

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE INDUCTION MOTOR- COMPUTED /R2 JDH DATE 1-23-89
TYPE RN INSULATION-INSIDE
CONTAINMENT CHECKED /R2 KBN DATE 1/25/89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-1 for source of Category and Operating Time assignments.

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 29
R 2 R 3
BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 JDH JDH
TYPE RN INSULATION-INSIDE 4/19/89 9/24/89
CONTAINMENT CHECKED WBK DATE 7/1/86 KBN KBN
4/28/89 9/24/89

A. DOCUMENTATION (SEE NOTE)

Equipment Description Squirrel-Cage Induction Motor
Vendor/Manufacturer Joy Fan/Reliance Electric
Equipment Model No.(s) 100hp, 460 VAC, 3ph, 60Hz, 1800rpm
Type RN Insulation
Inside Containment

QUALIFICATION REPORTS (SEE NOTE)

- (1) Title/Number/Revision Qualification Test- RIMS NEB 831213 426
ing of Joy Axivane Fan & Reliance Electric
Motor Report X-604, Rev. 2 (TAB D, Section DATE 3-20-80
D-1) DATE 3-20-80
- (2) Title/Number/Revision Type Test Support RIMS EEB 820602 304
Analysis Random Wound Motors, Report NUC-9
+ Supplement, Rev. 2 (TAB D, Section D-2) DATE 7-1-78/7-15-81
- (3) Title/Number/Revision End of Life Type RIMS B43 850919 500
Test-Random Wound Motors, Report NUC 22,
Rev. 2 (TAB D, Section D-3) DATE 2-10-84

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (4) WBN-OSG4-008 R11 (B45 870123 426) System 30, Category and
Operating Times Calculation.
- (5) 47E235-42 R2 Environmental Drawing
- (6) GENNAL3-002 R3 (B45 860423 235) Reduction of Beta dose by
sheet steel
- (7) QIR NEB85016 (B45 850426 254) Watts Bar Nuclear Plant-NUREG-0588
- (8) WBPEVAR 86 02001 R0 (B43 860227 901) Degraded voltage for
environmental qualification project
- (9) WBNAPS2-041 R0 (B45 890526 235) determination of long-term
post accident temperature inside containment

R3

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 2 OF 29
R 2 R 3
BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 9/8/86 JDH JDH
TYPE RN INSULATION-INSIDE 1/18/89 9/21/89
CONTAINMENT CHECKED WBK DATE 9/8/86 KBN KBN
1/18/89 9/23/89

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES (1) Water flow through
the fan must be adequately addressed after the SCR is closed.
See Open Item #1 in front of binder.

R3

COMMENTS/RECOMMENDATIONS Refer to TAB C, Section 11.0.

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 3 OF 29
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Lagman DATE 6-9-86
 INSULATION-INSIDE CONTAINMENT CHECKED W.D. King DATE 6/12/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

- X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- _____ Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/ COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 334-1974, Type Test of Continuous Duty Class 1E Motors

NEMA MG1-1967, Motors and Generators

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 4 OF 29
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L. L. Raymond DATE 6-9-86
 INSULATION-INSIDE CONTAINMENT CHECKED W. B. H. H. DATE 6/12/86

D. QUALIFICATION METHODOLOGY (Check only one block)

 Test of Identical Item Under Identical Conditions or Under Similar
 Conditions with Supporting Analysis

X Test of Similar Items with Supporting Analysis

Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

_____ Experience with Identical or Similar Equipment Under Similar
Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Refer to Tab C, Sections 1.0 and 3.0.

1. The first step in the process is to identify the problem or issue that needs to be addressed. This involves gathering information and understanding the context of the problem.

2. Once the problem is identified, the next step is to define the objectives and goals of the project. This helps to clarify what needs to be achieved and provides a clear direction for the team.

3. The third step is to develop a plan or strategy to address the problem. This involves breaking down the problem into smaller, manageable tasks and determining the resources needed to complete them.

4. The fourth step is to implement the plan. This involves putting the strategy into action and monitoring progress regularly to ensure that the project is on track.

5. Finally, the fifth step is to evaluate the results of the project. This involves assessing the outcomes against the objectives and goals to determine the effectiveness of the intervention.

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 5 OF 29
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.B. Hayward DATE 6-9-86
 INSULATION-INSIDE CONTAINMENT CHECKED W.B. Pitt DATE 6/12/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Axivane Fan/Motor</u>	<u>Axivane Fan/Motor</u>	<u>Qual Rpt 1, Page 1</u>
(2) Manufacturer	<u>Joy Fan/Reliance</u>	<u>Joy Fan/Reliance</u>	<u>Qual Rpt 1, Page 1</u>
(3) Model Number(s)	<u>Motor: Refer to</u>	<u>150/75hp,</u>	<u>Qual Rpt 1,</u>
	<u>TAB A</u>	<u>1185/590rpm</u>	<u>App E, Pg 3</u>
		<u>460VAC, 3ph</u>	
		<u>60Hz, Type</u>	
		<u>RN Insul.</u>	
	<u>Fan: NA</u>		
	<u>Motors:</u>		
(4) Serial Number(s)	<u>1XF-882396-A1</u>	<u>X-319739-A1-LT</u>	<u>Note 1 Below</u>
	<u>1XF-882396-A2</u>		
(5) Identify Component-Unique checksheet attached:	<u>Supplement 1. Component-Unique Checklist-</u>		
	<u>Motors</u>		

JUSTIFICATION/COMMENTS Note 1 - Serial numbers for plant motors are found
in TAB F, on page 1 of respective field verification sheets. The test
motor serial number is from page 3, Appendix E to Joy report X-604, Rev. 2
(TAB D, Section D-1).

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 6 OF 29
 R 2 R
 BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 ~~7-18-89~~
TYPE RN INSULATION-INSIDE
 CONTAINMENT CHECKED WBK DATE 7/1/86 ~~7/1/86~~

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below. If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>N/A</u>	<u>N/A</u>	
External Process Connections	<u>N/A</u>	<u>N/A</u>	
Electrical Connections	<u>Refer to Note 1 below</u>	<u>No</u>	<u>Qual Rpt 1, pg. 2</u>
Conduit Seals	<u>N/A</u>	<u>N/A</u>	<u>Refer to Note 2 below</u>
Connector Seals	<u>N/A</u>	<u>N/A</u>	
Orientation	<u>N/A</u>	<u>N/A</u>	
Physical Configuration	<u>N/A</u>	<u>N/A</u>	
Other			

R2

JUSTIFICATION/COMMENTS

Note 1: During the LOCA simulation, leads were connected inside the pressure chamber to terminal studs protruding through insulating and sealing plate. Plant terminations are made inside a terminal box using materials analyzed in Watts Bar Binder WBNEQ-SPLC-001, 600 volts and below, Type NMCK Motor Connection Kit.

R2

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 7 OF 29
R 2 R
BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 JDH
TYPE RN INSULATION-INSIDE 7-18-89
CONTAINMENT CHECKED WBK DATE 7/1/86 7/1/89

F. INSTALLATION INTERFACES (Continued)

JUSTIFICATION/COMMENTS

Note 2: During LOCA simulation, no attempt was made to prevent chemical spray and moisture from entering the motor lead conduit (reference TAB E, Div. 2 Joy/TVA Telecon Confirmation Letter).

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 8 OF 29
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.S. Raymond DATE 6-9-86 R R
INSULATION-INSIDE CONTAINMENT CHECKED W.H. [signature] DATE 6/12/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>TAB C, Sec 4.1</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Qual Rpt 1, Appendix E, p 2</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>Qual Rpt 1, page 5</u>
Radiation	<u>No</u>	<u>Qual Rpt 1, page 4</u>
Wear	<u>No</u>	<u>TAB C, Sec 4.2.4</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Qual Rpt 1, pages 7-11</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>Qual Rpt 1, pages 12-16</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>Qual Rpt 1, page 17</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>Qual Rpt 1, page 18</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes
(Reference Qual Rpt 1, App A, p 11).

JUSTIFICATION/COMMENTS Test equipment accuracies and calibration data
are not significant in establishing continued operability of the motor.

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 9 OF 29
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Leonard DATE 6-9-86 R R
INSULATION-INSIDE CONTAINMENT CHECKED W.L. Kiser DATE 7/1/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference Qual Rpt 1, page 5).

JUSTIFICATION/COMMENTS _____

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Qual Rpt 1, page 5</u>
Radiation exposure	<u>Yes</u>	<u>Qual Rpt 1, page 4</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Refer to TAB C, Sec 4.2.4</u>
Operational (electrical/mechanical/process) stress aging	<u>No</u>	<u>Refer to TAB C, Sec 4.2.4</u>

JUSTIFICATION/COMMENTS _____

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference _____).

JUSTIFICATION/COMMENTS There are no known synergistic effects based on review of the materials of construction for this motor.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
(yes/no/NA)? Yes (Reference Qual Rpt 1, page 5).

JUSTIFICATION/COMMENTS Motor aged in vertical non-rotating position. Accelerated aging involved aging motor at a temperature of 415°F (213°C) for 108 hours.

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 10 OF 29
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED R.L. Leonard DATE 6-9-86 R R
INSULATION-INSIDE CONTAINMENT CHECKED W.B. / J.B. DATE 6/12/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference: Qual Rpt 2, pages 3-7, 19, 20).

JUSTIFICATION/COMMENTS For a listing of materials in RN
insulation system, see Qual Rpt 1, App F.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Qual Rpt 1, page 5).

JUSTIFICATION/COMMENTS _____

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Qual Rpt 1, pages 5 and 6).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>TAB C, Sec 4.2.1</u>	<u>213°C</u>	<u>105°C</u>
Time	<u>TAB C, Sec 4.2.1</u>	<u>100 hrs</u>	<u>350,000 hrs</u>

JUSTIFICATION/COMMENTS _____

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.2.1

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA
(Reference _____).

JUSTIFICATION/COMMENTS Activation energies were used to
establish qualified life and are referenced in TAB C, Sec 5.0.

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 11 OF 29
R 3 R _____
BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 JDH
TYPE RN INSULATION-INSIDE 9/21/89
CONTAINMENT _____ CHECKED WBK DATE 6/12/86 XW
9/23/89

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? Yes (Reference Qual Rpt 1, page 6 Qual Rpt 2, "Supplement" Page 3).

JUSTIFICATION/COMMENTS _____

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? No (Reference: _____).

JUSTIFICATION/COMMENTS The effects of temperature rise during motor operation were accounted for in the establishment of qualified life for these motors.

Refer to TAB C, Section 5.0 and WAC-324.

| R3

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: Qual Rpt 1, Pg 4).

JUSTIFICATION/COMMENTS Irradiation was considered unnecessary because tests conducted on the motor components show that direct damage to materials is negligible at levels considered. Refer to TAB C, Section 4.2.2 for additional information.

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? Yes (Reference: Qual Rpt 1, Appendix F).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.2.2 for additional justification.

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? NA (Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.2.2 for additional justification.

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 12 OF 29
R 2 R
BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 JDH
TYPE RN INSULATION-INSIDE 7-18-89
CONTAINMENT CHECKED WBK DATE 6/12/86 WBA
10/89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? NA (Reference: _____).

Plant normal ambient radiation
dose (rd) _____

Test exposure dose (rd) _____

Test exposure dose rate (rd/hr) _____

Test exposure source type
(e.g., Co-60 gamma) _____

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.2.2

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ Yes (Reference: Qual Rpt | R2
1, pp. 7 and 8).

JUSTIFICATION/COMMENTS _____

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? NA
(Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.2.4

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: Qual Rpt 2, Page 19 _____).

JUSTIFICATION/COMMENTS _____

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R2

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 13 OF 29
R 2 R 2
BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 10/18/89
TYPE RN INSULATION-INSIDE
CONTAINMENT _____ CHECKED WBK DATE 6/12/86 1/18/89

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? NA (Reference: _____)

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.2.4

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: _____)

Qualified life (Document in QMDS) 40 years with maintenance program in TAB G.

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: _____)

|R2

JUSTIFICATION/COMMENTS Component replacement intervals are given in the Joy Axivane Fan Operators Handbook (TAB H) and in the QMDS (TAB G).

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1SHEET 14 OF 29
R 1 R BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED RSR - DATE 6/9/86INSULATION-INSIDE CONTAINMENT CHECKED WBK DATE 6/9/86HSR
6/13/86
RF, b, JPA
6/20/86I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>References</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Type RN insulation system</u>	<u>-</u>	<u>Note 1</u>	<u>1.17</u>	<u>TAB C</u> <u>Att. 1</u>
(b) <u>Bearing lubricant</u> <u>(Chevron SRI-2 grease)</u>	<u>2×10^8</u>	<u>Note 2</u>	<u>N/A</u>	<u></u>
(c) <u></u>	<u></u>	<u></u>	<u></u>	<u></u>
(d) <u></u>	<u></u>	<u></u>	<u></u>	<u>-</u>
(e) <u></u>	<u></u>	<u></u>	<u></u>	<u>-</u>

JUSTIFICATION/COMMENTS

Note 1: Analysis of test data on insulation components show that direct damage to materials is negligible at greater radiation doses than experienced by TVA motors. Type RH insulation, which is similar to type RN, has withstood a total radiation dose of 2.2×10^8 RADS and maintained its ability to perform its required function. Refer to TAB C, Section 4.2.2 for additional information.

Note 2: Refer to Digital Material Aging and Radiation Effects Library, Library Code No. 157-83A and TAB C, Paragraph 6.0.

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 15 OF 29
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED Bob Raymond DATE 6-9-86 R R
INSULATION-INSIDE CONTAINMENT CHECKED W.B. Kim DATE 7/2/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Qual Rpt 1, pages 5-19).

Identify Acceptance Criteria: Motor/fan assembly must operate during and after a simulated DBE described on page 16, following accelerated thermal aging and seismic testing.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Qual Rpt 1, App. A).

Identify baseline and functional testing: During DBE testing, several conditions were monitored and periodically recorded as indicated in the referenced document. Continued motor operability or a lack thereof was the sole failure criteria.

JUSTIFICATION/COMMENTS Refer to Tab C, Sections 4.1, 4.3.1, and 10.0, Qualification Report X-604, Appendix A (TAB D).

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Qual Rpt 1, pages 13-15).

JUSTIFICATION/COMMENTS In a telecon between Bob Raymond of TVA and Tom Bissett of Joy on 5-8-86, (TAB E, Div. 2), it was confirmed that the motor/vaneaxial fan assembly was operated under low speed conditions, 75 hp, 590 rpm, during the DBE simulation. A bypass loop was provided to allow for recirculation of fan air flow.

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 16 OF 29
 R 2 R
 BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 JDH
TYPE RN INSULATION-INSIDE 5/17/89
 CONTAINMENT CHECKED WBK DATE 7/2/86 KB
5/22/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: Qual.

Rpt. 1, Appendix E, Page 2).

JUSTIFICATION/COMMENTS Baseline testing conditions were
equal to or more severe than normal operating condiditions.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a)	Parameter	Plant Normal Conditions	Reference
	Voltage	<u>480 V</u>	<u>45W760-30-13</u>
	Load	<u>40,000 CFM</u>	<u>77K35-83165</u>
	Frequency	<u>60 Hz</u>	<u>77K35-83165</u>
	Accuracy	<u>N/A</u>	
	Other(s)		

R2

JUSTIFICATION/COMMENTS Refer to TAB C, Section 7.0
for discussion of voltage and frequency requirements.

PAGE B-16 R2

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 17 OF 29
 R 2 R 2
 BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 7/1/88-89
TYPE RN INSULATION-INSIDE
CONTAINMENT CHECKED WBK DATE 7/2/86 1/18/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u> R2
Voltage	<u>(1) 453.13 VAC (2) 458.38 VAC</u>	<u>WBPEVAR8602001</u> <u>Sheets D165 & D225</u>
Load	<u>Refer to Note 1 below</u>	
Frequency	<u>60 Hz</u>	<u>TAB C</u> <u>Section 7.0</u>
Accuracy	<u>N/A</u>	
Other(s)		

JUSTIFICATION/COMMENTS Minimum accident voltages for motors 1-MTR-30-38-A and -39-B (453.13 VAC and 458.38 VAC, respectively) are terminal voltages at T=15 seconds after a phase B containment isolation signal.

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u> R2
Voltage	<u>460 VAC</u>	<u>Qual Report 1</u> <u>App. E. Page 3</u>
Load	<u>Refer to Note 1 below</u>	
Frequency	<u>60 HZ</u>	<u>Qual. Report 1</u> <u>App. E. Page 3</u>
Accuracy	<u>N/A</u>	
Other(s)		

JUSTIFICATION/COMMENTS Note 1: Load consists of vane axial fans of similar design but of different size. Motors are sized by the fan manufacturer to ensure proper fan performance. TVA motors are rated 100 hp, 1800 rpm. The tested motor was a 2-speed motor rated 150/75 hp, 1200/600 rpm.

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 18 OF 29
R 2 R
BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 9/5/86 JOH 1-18-89
TYPE RN INSULATION-INSIDE
CONTAINMENT CHECKED WBK DATE 9/5/86 1/18/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-42 | R2

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>120</u> (0.3 psig)	(a) Temperature (°F) <u>130</u> (0.3 psig)
(b) Pressure (psig) <u>14.7 psia</u>	(b) Pressure (psig) <u>14.7 psia</u>
(c) Humidity (%) <u>80</u> <u>2 x 10⁷</u>	(c) Humidity (%) <u>100</u>
(d) Radiation (rd) <u>MAX</u>	(d) Radiation (rd) <u>--</u>

(3) Process Interfaces: Fan mounted on motor shaft using a 3/4"
x 3/4" key. Motor is mounted to fan casing through 4 threaded
stud bolts in the front section of the motor.

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hours per excursion and will occur less than
1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>327</u> (11.2 psig)	Accident type <u>LOCA/HELB</u> R2
(b) Pressure (psig) <u>25.6 psia</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>100</u> <u>4.7x10⁸ Beta</u> (refer to Sect. P)	Accident type <u>LOCA/MSLB</u> R2
(d) Radiation (rd) <u>4x10⁷ Gamma</u> Refer to	Accident type <u>LOCA</u>
(e) Spray Type <u>Comments</u>	Accident type <u>LOCA/HELB</u>

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 19 OF 29
R 2 R 3
BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 JDH JDH
TYPE RN INSULATION-INSIDE 1/18/89 9/21/89
CONTAINMENT CHECKED WBK DATE 6/12/86 KBN KBN
1/18/89 9/23/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Actual accident environment is a composite of several profiles. Refer to TAB C, Section 2.0, for additional details. Chemical spray is addressed in TAB C, Section 4.3.2.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: TAB C, Section 4.2.3 and 4.3.3).

- (7) - Subject to submergence (Yes/No/NA)? No (Reference: TAB C, Section 9.0).
- Identify initiation time and duration of submergence: _____

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: Environmental DWG. 47E235-42).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

2 x 10⁶ See Section P

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B, Section A

|R3

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 20 OF 29
 R 2 R
 BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 9/5/86 10/1-12-89
TYPE RN INSULATION-INSIDE
 CONTAINMENT CHECKED WBK DATE 9/5/86 1/18/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>2400 hrs.</u>	<u>10,145 hrs.</u>	Qual Rpt 1, page 17
Temperature (°F)	<u>327</u>	<u>350 peak, 330 for 4 hours</u>	Qual Rpt 1, pgs. 14 & 15
Pressure (psig)	<u>11.2</u>	<u>78</u>	Qual Rpt 1 pg. 14, item 5a
Relative Humidity (%)	<u>100</u>	<u>100</u>	Qual Rpt 1, App. A., pg. 8
Chemical Spray*	<u>Refer to TAB C, Section 4.3.2</u> <u>2x10⁶ Beta</u>		
Radiation (rd)**	<u>6x10⁷ Gamma</u>	<u>Refer to TAB C, Sec 4.2.2</u>	
Submergence	<u>No</u>	<u>No</u>	Refer to TAB C, Sec. 9.0

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>L. (1) above</u>
Pressure	<u>Yes</u>	<u>L. (1) above</u>
Relative Humidity	<u>Yes</u>	<u>L. (1) above</u>
Chemical Spray	<u>Refer to TAB C, Section 4.3.2</u>	
Submergence	<u>N/A</u>	
JUSTIFICATION/COMMENTS	<u>Additional discussion in TAB C, Section 5.0</u>	

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 21 OF 29
 R 3 R
 BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 6/9/86 TDH
TYPE RN INSULATION-INSIDE 9/23/89
 CONTAINMENT CHECKED WBK DATE 6/12/86 KW
9/23/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>23°F</u>	<u>Yes</u>
	<u>550%</u>	
Pressure: +10% but no more than 10 psig	<u>(AP=66psig)</u>	<u>Yes</u>
Radiation: +10% of accident dose		<u>No</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>Refer to WAC-324 (TAB C)</u>	<u>Yes</u>
Voltage: ±10% of rated value		<u>No</u>
Frequency: ±5% of rated value		<u>No</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>Refer to Qual Rpt 1, pgs 13-16</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>+33%</u>	<u>Yes</u>

R3

JUSTIFICATION/COMMENTS For elaboration, refer to following sections of TAB C:

Temperature Section 4.3.1

Pressure Section 4.3.1

Radiation Section 4.2.2

Time Section 5.0

*Voltage Section 7.0 *Also. See TAB E, Div. 2, Degraded Voltage Correspondence

Frequency Section 7.0

Vibration Section 4.2.4

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 22 OF 29
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Hayward DATE 6-9-86
INSULATION-INSIDE CONTAINMENT CHECKED W.H. Hester DATE 6/12/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference _____).

JUSTIFICATION/COMMENTS	Refer to TAB A

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference Qual Rpt 1, pgs. 13-16).

JUSTIFICATION/ COMMENTS

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference Qual Rpt 1, page 17).

JUSTIFICATION/ COMMENTS

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference Qual Rpt 1, p 17).

JUSTIFICATION/COMMENTS Per TAB A, TVA equipment required to operate for a period of 100 days. The equipment tested performed in post-DBE environment for 10,145 hours.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes
(Reference _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.3.3

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 23 OF 29

BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L. L. Raymond DATE 6-9-86 R R

INSULATION-INSIDE CONTAINMENT CHECKED W. H. [Signature] DATE 6/12/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS Refer to TAB G for maintenance and surveillance practices generally accepted within industry.

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 24 OF 29
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Laguarda DATE 6-9-86 R R
INSULATION-INSIDE CONTAINMENT CHECKED W.B. Kien DATE 6/12/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>Yes</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>Yes</u>
(b) Were specific features and failure modes and effects analyzed?	<u>Yes</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>Yes</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>Yes</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>Yes</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 25 OF 29
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.S. Raymond DATE 6-9-86 R R
INSULATION-INSIDE CONTAINMENT CHECKED W.H. Kiser DATE 6/12/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>No</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 26 OF 29
 R 2 R 2
 BINDER TITLE INDUCTION MOTOR- COMPUTED RSR DATE 9/5/86 1-18-89
TYPE RN INSULATION-INSIDE
 CONTAINMENT WBK CHECKED WBK DATE 9/5/86 1/18/89

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>No</u> |
| (c) Has the test analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>NA</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>NA</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

The accident radiation doses shown in Section K, Part (5) are 4.7×10^8 rads Beta and 4×10^7 rads Gamma. The effect of this Beta radiation is reduced by motor enclosure thickness which is a minimum of 9/32 inch (see TAB E, Division 5, RIMS B70 860428 004). The value is also applicable to this binder since the same 444 frame motors were furnished for both Sequoyah and Watts Bar Nuclear Plants. The Beta reduction factor for 1/4 inch steel (see TAB E, Division 5, GENNAL3-002) is 0.004, which yields an effective Beta value of less than 2×10^6 , which is insignificant in comparison to the Gamma level. Beta effect on the motor leads (which go through 2 1/2 inch conduit of 0.195 nominal wall thickness) is likewise insignificant; conduit size from vendor drawing in TAB I and wall thickness from Design Standard DS-E13.1.3. For Section O(10)(b) and O(15)(b) justifications, see TAB C, 4.3.2 and TAB B J(2) respectively.

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 27 OF 29
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L. S. Leonard DATE 6-9-8 R R
 INSULATION-INSIDE CONTAINMENT CHECKED W. S. Leonard DATE 7/7/86

SUPPLEMENT 1
 COMPONENT-UNIQUE CHECKLIST
 MOTORS

EQUIPMENT IDENTIFICATION

- (1) Is the motor identified in the qualification report identical to the plant motors which require qualification (yes/no/NA)? No

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(a) Insulation system materials	<u>Type RN</u>	<u>Type RN</u>	<u>Yes</u>	<u>Refer to TAB C, Section 3.1</u>
(b) Coil construction (form or random wound, cast)	<u>Random</u>	<u>Random</u>	<u>Yes</u>	<u>Qual Rpt 2, page 5</u>
(c) Insulation class (B, F, H)	<u>H</u>	<u>H</u>	<u>Yes</u>	<u>Qual Rpt 1, page 1</u>
(d) Lubricant				
Manufacturer	<u>Chevron</u>	<u>Chevron</u>	<u>Yes</u>	<u>Refer to TAB C, Section 6.0</u>
Type	<u>SRI-2</u>	<u>SRI-2</u>	<u>Yes</u>	
(e) Bearing				
Manufacturer		<u>New Departure Hyatt</u>	<u>Yes</u>	<u>Refer to (3)</u>
Type	<u>Anti-friction</u>	<u>Anti-friction</u>	<u>Yes</u>	
Bearing life	<u>156 yr</u>	<u>--</u>	<u>Yes</u>	<u>Refer to TAB E, Div. 1</u>
(f) Seals				
Manufacturer				
Type	<u>Laby-rinth</u>	<u>Laby-rinth</u>	<u>Yes</u>	<u>Refer to TAB C, Section 6.0</u>
Material	<u>Brass</u>	<u>Brass</u>	<u>Yes</u>	

INSULATION- INSIDE CONTAINMENT CHECKED W.B. King DATE 7/17/86

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 29 OF 29
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED T.L. Seymour DATE 6-9-86 R R
INSULATION-INSIDE CONTAINMENT CHECKED W.B. Price DATE 6/12/86

EQUIPMENT IDENTIFICATION (Continued)

- (5) Were the seals included in the test program (yes/no/NA)? Yes
(Reference Qual Rpt 2, Pg 18).

Comments: _____

PRINT DATE: 01/11/89

BINDER NO. : WBNEQ-MOT -003
MANUFACTURER : RELIANCE
PAGE 1 OF 3

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT	DEVICE ID NO.	AZMITH	ELEV(1)	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION		MODEL NUMBER		CONTRACT		(2)			
WBN-1-MTR -030-0146 ABGTS FAN MOTOR	-A	1-MTR -030-0146 1YF-832365	-A	737' 76K35-083246-1	A05	A	1000	L	MOTOR IS REQUIRED TO DRIVE COOLER TO INSURE ADEQUATE COOLING AND CONTINUED OPERATION OF THE ABGTS.
WBN-2-MTR -030-0157 ABGTS FAN MOTOR	-B	2-MTR -030-0157 1YF882365	-B	737' 76K35-083246-1	A09	A	1000	L	MOTOR IS REQUIRED TO DRIVE COOLER TO INSURE ADEQUATE COOLING AND CONTINUED OPERATION OF THE ABGTS.
WBN-1-MTR -030-0175 RHR PUMP ROOM COOLER MOTOR	-A	1-MTR -030-0175 1YF-833397	-A	676' 84K5-334550-1	A11	A	1000	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS THE SAFETY-RELATED RHR PUMP MOTORS.
WBN-1-MTR -030-0176 RHR PUMP ROOM COOLER MOTOR	-B	1-MTR -030-0176 1YF-833397	-B	676' 84K5-834550-1	A10	A	1000	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS THE SAFETY-RELATED RHR PUMP MOTORS.
WBN-1-MTR -030-0177 CTN SPR PUMP RM COOLER MOTOR	-A	1-MTR -030-0177 2YF-333397	-A	676' 84K5-834550-1	A09	A	1000	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS THE SAFETY-RELATED CONTAINMENT SPRAY PUMP MOTORS.

PREPARER/DATE D. F. Ackerly 9/20/86
CHECKED/DATE N.M. Burstein 9/20/86
R 2 R R
JAH
2-73-89
182
3/9/89

PRINT DATE: 01/11/89

BINDER NO. : W8NEQ-MOT -003
MANUFACTURER : RELIANCE
PAGE 2 OF 3

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZMIH ELEV(1) RM/RAO CONIRACI	CAI OPER TIME (2)	EVENT	SAFETY FUNCTION
WBN-1-MTR -030-0178 CTN SPR PUMP RM COOLER MOTOR	-B 1-MTR -030-0178 2YF-883397	676' A03 84K5-834550-1	A 100D	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS THE SAFETY-RELATED CONTAINMENT SPRAY PUMP MOTORS.
WBN-1-MTR -030-0179 SIS PUMP ROOM COOLER MOTOR	-B 1-MTR -030-0179 1YF-383397	692' A12 84K5-834550-1	A 100D	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS THE SAFETY-RELATED SIS PUMP MOTORS.
WBN-1-MTR -030-0180 SIS PUMP ROOM COOLER MOTOR	-A 1-MTR -030-0180 1YF-383397	692' A13 84K5-834550-1	A 100D	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS THE SAFETY-RELATED SIS PUMP MOTORS.
WBN-1-MTR -030-0182 CEN CHG PUMP RM COOLER MOTOR	-B 1-MTR -030-0182 3YF-383397	692' A10 84K5-834550-1	A 100D A 1MO A 1MO A 1MO A 1MO	L AF/A CV/A RH/A AB	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS THE SAFETY-RELATED CENT. CHG. PUMP MOTORS
WBN-1-MTR -030-0183 CEN CHG PUMP RM COOLER MOTOR	-A 1-MTR -030-0183 3YF-883397	692' A09 84K5-834550-1	A 100D A 1MO A 1MO A 1MO A 1MO	L AF/A CV/A RH/A AB	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS THE SAFETY-RELATED CENT. CHG. PUMP MOTORS

PREPARER/DATE D. F. Ackerly 9/20/86

CHECKED/DATE N. M. Burstein 9/20/86

R_2_ R_ R_
JRH
2-23-89
KBL
3/9/89

PRINT DATE: 01/11/89

BINDER NO. : W9NEQ-MOT -003
MANUFACTURER : RELIANCE
PAGE 3 OF 3

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EGIS NUMBER	UNIT DEVICE ID NO.	MODEL NUMBER	LOCATION	CONTRACT	CAI OPER TIME	EVENT	SAFETY FUNCTION
WBN-3-MTR -065-0023 EGTS FAN MOTOR	-A 0-MTR -065-0023	-A 1YF-832366	757' A16 76K35-083246-1	A	1000	L	MOTOR DRIVES FAN WHICH MUST RUN FOR THE EGTS TO PERFORM ITS SAFETY-RELATED FUNCTION.
WBN-3-MTR -065-0042 EGTS FAN MOTOR	-B 0-MTR -065-0042	-B 1YF-892366	757' A16 76K35-083246-1	A	1000	L	MOTOR DRIVES FAN WHICH MUST RUN FOR THE EGTS TO PERFORM ITS SAFETY-RELATED FUNCTION.

PREPARER/DATE D. F. Ackerly 9/20/86
CHECKED/DATE N. M. Burstein 9/20/86
R 2 R R
JPH
2-23-89
KAI
3/9/89

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE RELIANCE-RANDOM COMPUTED R2 JDH DATE 2-23-89
WOUND MOTORS- OUTSIDE CONTAIN-
MENT CHECKED R2 XBN DATE 3/9/89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-1 for source of Category and Operating Time assignments.

164
BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 28
R 2 R 3
BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDH 1/31/90
WOUND MOTORS- OUTSIDE CONTAIN- 2-23-89
MENT 1/31/90 CHECKED NMB DATE 9/20/86 KBN 3-9-89
1/31/90

A. DOCUMENTATION (See Note)

Equipment Description Continuous Duty 460 volt motors
Vendor/Manufacturer Reliance Electric Company
Equipment Model No.(s) Totally enclosed fan-cooled random wound
motors on shop orders 1YF--, 2YF-, and
3YF-883397, 1YF-882365, and 1YF-882366.

QUALIFICATION REPORTS (See Note)

- (1) Title/Number/Revision Summary Report RIMS EEB 820602304
Nuclear Power Motor System/NUC-9/July 1,
1978 including Supplement R2 dated July 15, DATE July 15, 1981
1981 (TAB D-1)
- (2) Title/Number/Revision Qualification Report/RIMS B43 850919 500
End of Life Tests/NUC-22 Rev. 2 (TAB D-2) DATE Feb. 10, 1984
- (3) Title/Number/Revision Limitorque PWR Valve RIMS MED 830510 219
Operator Test Report No. 600456 (excerpt
TAB D-3) DATE Dec. 9, 1975

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (4) TVA Radiation Calculation WBNNAL3-025, R0 (B45 860401 235)
- (5) TVA Radiation Calculation WBNNAL3-031, R1 (B45 880826 235)
- (6) System 30 Cat. & Op. Times WBNOSG4-008, R14 (B26 900110 206) | R3
- (7) System 65 Cat. & Op. Times WBNOSG4-015, R8 (B45 870209 428)
- (8) TVA degraded Voltage Calc WBP-EVAR 8602001, R0 (B43 860227 901)

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 1a OF 28
R R
BINDER TITLE RELIANCE-RANDOM COMPUTED R2 JOH DATE 2-23-89
WOUND MOTORS- OUTSIDE CONTAIN-
MENT CHECKED R2 KBN DATE 3/9/89

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (9) WBN Environmental Drawing 47E235-48 R3
- (10) WBN Environmental Drawing 47E235-74 R1
- (11) WBN Environmental Drawing 47E235-78 R3
- (12) WBN Environmental Drawing 47E235-79 R1
- (13) WBN Environmental Drawing 47E235-81 R1
- (14) TVA Condensation Calc GENNAL6-002 R2 (B45 860812 236)

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

MOTORS-OUTSIDE CONTAINMENT CHECKED 18 DATE 9/29/86

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 4 OF 28
BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Adjudy DATE 9/20/86 R R
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/24/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- X Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.1 for additional details.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 5 OF 28
 R 2 R
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDH
WOUND MOTORS- OUTSIDE CONTAIN- 4-19-89
MENT CHECKED NMB DATE 9/20/86 KBN
4/28/89

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Induction Motors</u>	<u>Induction Motors</u>	<u>NUC-22, Section IV, TAB D-2</u>
(2) Manufacturer	<u>Reliance</u>	<u>Reliance</u>	<u>NUC-22, Section I, TAB D-2</u> R2
(3) Model Number(s)	<u>RH Insulation Systems</u>	<u>3 hp</u>	<u>NUC-22, Section III, TAB D-2</u>
	<u>Other data</u>	<u>575 VAC,</u>	R2
	<u>in TAB A</u>	<u>3 ph, 60 Hz</u>	
		<u>1800 rpm-</u>	
		<u>no load</u>	
		<u>RH Insulation System</u>	
(4) Serial Number(s)	<u>Note 1</u>	<u>1YF-882616-A1</u>	<u>TAB D-2, NUC-22, Section III</u>
(5) Identify Component- Unique checksheet attached:	<u>Motors - Supplement 1</u>		

JUSTIFICATION/COMMENTS Refer to TAB C, Section 2.0, Similarity.

NOTE 1 - Motor serial numbers may be referred to as either model
or serial numbers on the field verification data sheets
in TAB F.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 6 OF 28
 R 2 R
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDH
WOUND MOTORS- OUTSIDE CONTAIN- 2-23-89
MENT CHECKED NMB DATE 9/20/86 KBA
3/9/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) R2
 If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>	
Mounting Bolts	<u>NA</u>	<u>NA</u>		
External Process Connections	<u>NA</u>	<u>NA</u>		
Electrical Connections	<u>NA</u>	<u>NA</u>		
Conduit Seals	<u>NA</u>	<u>NA</u>		
Connector Seals	<u>NA</u>	<u>NA</u>		
Orientation	<u>NA</u>	<u>NA</u>		R2
Physical Configuration	<u>NA</u>	<u>NA</u>		
Other	<u>NA</u>	<u>NA</u>		

JUSTIFICATION/COMMENTS See TAB C. Section 6.0. Interfaces

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 7 OF 28
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Q. Cheyly DATE 9/20/86 R R
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/24/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>See comments</u> <u>NUC-22, IV.A</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>(p 3) TAB D-2</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>NUC-22, IV.B.1</u> <u>(p 3) TAB D-2</u>
Radiation	<u>Yes</u>	<u>NUC-22, IV.E</u> <u>(p 5) TAB D-2</u>
Wear	<u>Yes</u>	<u>NUC-22, IV.B.3</u> <u>(p 3) TAB D-2</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>NUC-22, IV.C&F</u> <u>(pp 4&6)</u> <u>TAB D-2</u>
(e) Design basis event (DBE) exposure	<u>NA</u>	<u>See comments</u>
(f) Post-DBE exposure	<u>NA</u>	<u>See comments</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>NUC-22, IV.H</u> <u>(p 6) TAB D-2</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes*
 (Reference TAB D-2, NUC-22, Section IV.C & E).

JUSTIFICATION/COMMENTS G.1.a-Though not documented, inspection for damage is inherent in baseline performance tests. G.1.e&f-In the locations indicated in TAB A, significant transients do not occur, and the effects of the DBE result in only moderate increases in the temperature, humidity, and in some cases, a marked increase in radiation. This represents an extension of conditions existing during normal and abnormal operating conditions which are addressed by the thermal/radiation aging phase of the test series. (See TAB C, Section 3.3).

*Although some of the test equipment used in the series of seismic tests may have been out of calibration, this has no bearing on the fact that the motor satisfactorily performed at rated conditions following testing intended to simulate the effects of all service conditions.

P.10.1.1.1

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 8 OF 28
BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Achery DATE 9/20/86 R R
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/29/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference TAB D-2, NUC-22, Section IV.B).

JUSTIFICATION/ COMMENTS

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>H.4.a</u>
Radiation exposure	<u>Yes</u>	<u>Refer to H.5.a</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Refer to H.6.a</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>Refer to H.7.a</u>

JUSTIFICATION/ COMMENTS

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference).

JUSTIFICATION/COMMENTS A review of the materials used in these motors indicates that there are no known synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, p 3, Section IV.B, p 3 and Appendix 3.)

JUSTIFICATION/COMMENTS Stator winding and leads were aged
88 days at 255°C (491°F).

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 9 OF 28
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Ackley DATE 9/20/86 R R
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
 (Reference TAB D-1, NUC-9, p 19, Section VI).

JUSTIFICATION/COMMENTS Components susceptible to thermal degradation are the insulation and lubricants. Lubricant is routinely replaced, in accordance with the QMDS (TAB G) and, therefore, not subject to long-term thermal degradation.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, Section IV.B.1, & App 3, p 2).

JUSTIFICATION/COMMENTS In accordance with IEEE 334-1974, Section 9.0, a regression line developed in NUC-9 was used to obtain equivalent aging time and temperature.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, Section IV.B and App 3).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>Refer to TAB C, Section 8.1</u>	<u>255°C</u>	<u>155°C</u>
Time	<u>40 years</u>	<u>88 days</u>	<u>44 years</u>

JUSTIFICATION/COMMENTS Refer to TAB C, Section 8.1.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 10 OF 28
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Actualy DATE 9/20/86 R R
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

H. AGING (Continued)

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, Section IV.B and App. 3).

JUSTIFICATION/COMMENTS

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA
(Reference _____).

JUSTIFICATION/COMMENTS	<u>Accelerated aging parameters</u>

developed in accordance with Section 9 of IEEE 334-1974

using a system regression line.

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference TAB D-1, NUC-9, Supp.
p 2)

JUSTIFICATION/COMMENTS

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference TAB D-2 NUC-22, p 6
Section IV, F&G,).

JUSTIFICATION/COMMENTS The accelerated thermal aging process

of the complete stator assembly and the motor leads accounts

for the thermal stresses which would occur from prolonged

normal operation. Following this process, the assembled motor,

complete with the aged stator assembly and leads, was operated

in a series of performance tests.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 11 OF 28
 R 2 R _____
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDH
WOUND MOTORS- OUTSIDE CONTAIN- 2-23-89
MENT CHECKED NMB DATE 9/20/86 KBN
3/9/89

H. AGING (Continued)

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: TAB D-2, NUC-22, p 5 Section IV.E).

JUSTIFICATION/COMMENTS Complete motor assembly,
including bearings and lubricant, was exposed to a total
integrated dose of 2.2×10^8 rads, gamma.

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D-1, NUC-9, p 8, Section III, and TAB D-2, NUC-22, Appendix I, p 1).

JUSTIFICATION/COMMENTS Organic materials of the Reliance
RH system, Spec. 4824-GZ, and bearing lubricants are
identified by Reliance specification number in Section
III of the NUC-9 report.

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? Yes (Reference: TAB D-1, NUC-9, Section I.B (pp 1 & 2)).

JUSTIFICATION/COMMENTS Radiation test dose was selected
to envelop applications occurring throughout a
significant radiation range.

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: TAB D-2, NUC-22, App. 5).

Plant normal ambient radiation dose (rd)	<u>3.6×10^6</u>	R2
Test exposure dose (rd)	<u>2.2×10^8</u>	

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 12 OF 28
R 2 R _____
BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDA
WOUND MOTORS- OUTSIDE CONTAIN- 2-23-89
MENT CHECKED NMB DATE 9/20/86 BN
3/9/89

H. AGING (Continued)

220.5 hrs at .55 MRad/hr | R2
20 hrs at .05 MRad/hr
Test exposure dose rate (rd/hr) 85.7 hrs at 1.14 MRad/hr

Test exposure source type
(e.g., Co-60 gamma) Co-60, gamma

JUSTIFICATION/COMMENTS Co-60 gamma source confirmed in
telecon on August 29, 1986, between Don Ackery of TVA
and Gary Wheeler of Reliance Electric.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ Yes (Reference: _____ | R2
TAB D-2, NUC-22, p 3, Section IV.B.3).

JUSTIFICATION/COMMENTS Mechanically aged per Section 9
of IEEE 334-1975 for one hour at 60 cycle per second
vibration, with a deflection of 8 mils pk-pk.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes
(Reference: TAB D-2, NUC-22, p 3, Section IV.B.3).

JUSTIFICATION/COMMENTS _____

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: TAB D-2, NUC-22, p 3, Section IV.B.3; p 4, Section IV.C.4; and p 6, Section IV.F).

JUSTIFICATION/COMMENTS Motor operated under load during
multiple frequency seismic tests which followed thermal,
radiation, and vibration aging. Motor also operated
under no-load conditions during vibration aging
addressed in TAB B, Section H, Item 6.

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R2

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 13 OF 28
R 2 R _____
BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDH
WOUND MOTORS- OUTSIDE CONTAIN- 2-23-89
MENT CHECKED NMB DATE 9/20/86 KBN
3/9/89

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: _____).
Refer to references in 7a

JUSTIFICATION/COMMENTS Motor operated under rated
conditions during both series of seismic tests. This
results in stresses much greater than those encountered
through normal operation.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: TAB D-2, NUC-22, p 7, Section V _____).

Qualified life (Document in QMDS) 40+ years

JUSTIFICATION/COMMENTS NUC-22 documents a qualified life of
40 years plus 10% margin, i.e., 44 years at a total temperature
of 155°C.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: TAB D-1, NUC-9, p 17, Section V.2&3 _____).

JUSTIFICATION/COMMENTS No replaceable items were identified
in the insulation system. The bearings and lubricants are
routine maintenance items, the replacement of which is
addressed in the Qualification Maintenance Data Sheets in
TAB G. Basically, lubrication schedules, bearing replacement
intervals and electrical and mechanical surveillance recommen-
dations are detailed.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1SHEET 14 OF 28
R 1 R BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED DFA DATE 9/20/86 NOR
6/13/88
MOTORS-OUTSIDE CONTAINMENT CHECKED NMB DATE 9/20/86 REF. JSEA
6/10/88I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>References</u>	<u>Activation Energy</u>	<u>Reference TAB C</u>
(a) <u>DuPont 10/Electrical/Insulation</u>	<u>2.2×10^8</u>	<u>Note 1</u>	<u>1.02 eV</u>	<u>Note 3</u>
(b) <u>Chevron/Mechanical/Lubricant SRI No. 2</u>	<u>2×10^8 rad</u>	<u>Note 2</u>	<u>Note 4</u>	<u></u>
(c) <u></u>	<u></u>	<u></u>	<u></u>	<u></u>
(d) <u></u>	<u></u>	<u></u>	<u></u>	<u>-</u>
(e) <u></u>	<u></u>	<u></u>	<u></u>	<u>-</u>

JUSTIFICATION/COMMENTS

Note 1: The Reliance RH/DuPont 10 insulation system withstood a total dose of 2.2×10^8 RADS and maintained its ability to perform its required function as documented in Reliance Report NUC-22, TAB D-2.

Note 2: Refer to Digital Material Aging and Radiation Effects Library Code No. 157-83A and TAB C, Section 4.2.

Note 3: Refer to material Aging Calculation WAD-34. Refer to TAB D-4.

Note 4: Consideration of long-term thermal degradation of the grease is not required because it is not considered to be a substance with an infinite life. A surveillance and maintenance program is established in the QMDS in TAB G to ensure proper operation.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 15 OF 28
R 2 R _____
BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/26/86 JDH
WOUND MOTORS- OUTSIDE CONTAIN- 4-19-89
MENT CHECKED NMB DATE 9/26/86 KMN
4/24/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (Yes/No/NA)? Yes
(Reference: TAB D-2, NUC-22, p 6, Section IV.G).

Identify Acceptance Criteria: Following accelerated aging and seismic testing intended to simulate the effects of all service conditions, the motor must continue to operate at its rated load.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (Yes/No/NA)? Yes
(Reference: TAB D-2, NUC-22, App. 2).

Identify baseline and functional testing: No load, locked rotor, and dielectric tests done to baseline motor performance parameters. After all environmental aging and testing, baseline tests were repeated and full load tests were also performed.

JUSTIFICATION/COMMENTS Motor test results were essentially identical with no indication of diminished capability.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (Yes/No/NA)? Yes
(Reference: TAB D-2, Nuc-22, pg 6, Sect. IV.G).

JUSTIFICATION/COMMENTS The motor functioned under rated electrical and mechanical conditions during and following a simulation of the service conditions. The effects of the DBE result in only moderate increases in the temperature, humidity, and, in some cases, a marked increase in radiation. This can be represented as an extension of conditions existing during normal and abnormal operating conditions which is addressed by the thermal/radiation aging phase of the test series.

|R2

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
 R 2 R 2
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDK
WOUND MOTORS- OUTSIDE CONTAIN- 2-23-89
MENT CHECKED NMB DATE 9/20/86 KBN
3/9/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: TAB D-1, NUC-22, Section I).

JUSTIFICATION/COMMENTS Baseline tests performed are
industry-standard tests used to determine performance
characteristics during normal operating conditions.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>NA</u>	<u></u>
Load	<u>NA</u>	<u></u>
Frequency	<u>NA</u>	<u></u>
Accuracy	<u>NA</u>	<u></u>
Other(s)	<u></u>	<u></u>

R2

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0
for discussion of voltage and frequency requirements.

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>NA</u>	<u></u>
Load	<u>NA</u>	<u></u>
Frequency	<u>NA</u>	<u></u>
Accuracy	<u>NA</u>	<u></u>
Other(s)	<u></u>	<u></u>

R2

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0 for
discussion of voltage and frequency requirements.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 16a OF 28

R R

BINDER TITLE RELIANCE-RANDOM COMPUTED R2 JDH DATE 2-23-89

WOUND MOTORS- OUTSIDE CONTAIN-
MENT CHECKED R2 KBN DATE 3/9/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>NA</u>	<u> </u>
Load	<u>NA</u>	<u> </u>
Frequency	<u>NA</u>	<u> </u>
Accuracy	<u>NA</u>	<u> </u>
Other(s)		
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0 for
discussion of voltage and frequency requirements.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17 OF 28
 R 3 R
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 KFL
WOUND MOTORS- OUTSIDE CONTAIN- 1/31/90
MENT CHECKED NMB DATE 9/20/86 KRU
1/31/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Worst Case Summary of the Next
5 Sheets

- | | |
|--|---------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM-</u> | (b) Pressure (psig) <u>ATM</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>3.6x10⁶</u> | (d) Radiation (rd) <u>NA</u> |
- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of
plant life and a total of 1600 hours during life of plant.
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|---|--------------------------------|
| (a) Temperature (°F) <u>110 for 30 days</u> | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>NA</u> | Accident type <u>HELB/LOCA</u> |
| (c) Humidity (%) <u>NA</u> | Accident type <u>HELB/LOCA</u> |
| (d) Radiation (rd) <u>1x10⁸</u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u> | Accident type <u>NA</u> |

R3

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17a OF 28
 R 2 R 3
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/26/86 JDH 1/3/90
WOUND MOTORS- OUTSIDE CONTAIN- 2/23/89
MENT CHECKED NMB DATE 9/26/86 KRN 1/3/90
 3/9/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-48

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) ATM-

(c) Humidity (%) 80

(d) Radiation (rd) 8.8x10⁵

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) ATM-

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>110 for 30 days</u>	Accident type	<u>LOCA</u>	R3
(b) Pressure (psig)	<u>NA</u>	Accident type	<u>LOCA</u>	
(c) Humidity (%)	<u>NA</u>	Accident type	<u>LOCA</u>	
(d) Radiation (rd)	<u>1x10⁸</u>	Accident type	<u>LOCA</u>	
(e) Spray Type	<u>NA</u>	Accident type	<u>NA</u>	

Affected Motors: 1-MTR-30-146-A, RM A5
 2-MTR-30-157-B, RM A9

Motors listed are required to operate only during conditions resulting from a LOCA. R3

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17b OF 28
R 2 R 3
BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDH 474
WOUND MOTORS- OUTSIDE CONTAIN- 2/23/89 1/31/90
MENT CHECKED NMB DATE 9/20/86 KBN KBN
3/9/89 1/31/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-74

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) ATM-

(c) Humidity (%) 80

(d) Radiation (rd) 4.3x10⁵

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) ATM-

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 110 for 30 days Accident type LOCA | R3

(b) Pressure (psig) NA Accident type LOCA | R3

(c) Humidity (%) NA Accident type LOCA

(d) Radiation (rd) 1x10⁷ Accident type LOCA

(e) Spray Type NA Accident type NA

Affected Motors: 1-MTR-30-175-A, Rm A11 | R3
1-MTR-30-176-B, Rm A10

Motors listed are required to operate only during conditions resulting from a LOCA. | R3

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17c OF 28
 R 2 R 3
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/26/86 JDH HPK
WOUND MOTORS- OUTSIDE CONTAIN- 2/23/89 2/6/90
MENT CHECKED NMB DATE 9/26/86 KBN KBN
 3/19/89 2/7/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-78

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) ATM

(c) Humidity (%) 80

(d) Radiation (rd) 1.8×10^3

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) ATM

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a)	Temperature (°F)	<u>110 for 30 days</u>	Accident type	<u>LOCA</u>	R3
(b)	Pressure (psig)	<u>NA</u>	Accident type	<u>LOCA</u>	
(c)	Humidity (%)	<u>NA</u>	Accident type	<u>LOCA</u>	R3
(d)	Radiation (rd)	<u>1.4×10^6 **</u>	Accident type	<u>LOCA</u>	
(e)	Spray Type	<u>NA</u>	Accident type	<u>NA</u>	R3

Affected Motors: 0-MTR-65-23-A, Rm A16
 0-MTR-65-42-B, Rm A16

Motors listed are required to operate only during conditions resulting from a LOCA. | R3

**WBNNAL3-031

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17d OF 28
 R 2 R 3
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDH 2/2/89
WOUND MOTORS- OUTSIDE CONTAIN- 2/2/89 1/31/90
MENT CHECKED NMB DATE 9/20/86 KBN 3/9/89 1/31/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-79

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) ATM

(c) Humidity (%) 80

(d) Radiation (rd) 3.6x10⁶

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) ATM

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 110 for 30 days Accident type LOCA | R3

(b) Pressure (psig) NA Accident type LOCA/HELB | R3

(c) Humidity (%) NA Accident type LOCA/HELB | R3

(d) Radiation (rd) 1x10⁷ Accident type LOCA

(e) Spray Type NA Accident type NA | R3

Affected Motors: *1-MTR-30-179-B, Rm A12

*1-MTR-30-180-A, Rm A13

**1-MTR-30-182-B, Rm A10

**1-MTR-30-183-A, Rm A9

*Motor is required to operate only during conditions resulting from a LOCA.
 **Motor required to operate during a LOCA or HELB condition.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17e OF 28
R 2 R 3
BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 JDH 87
WOUND MOTORS- OUTSIDE CONTAIN- 2/23/89 11/31/90
MENT CHECKED NMB DATE 9/20/86 KBN 120
3/9/89 11/31/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-81

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) ATM-

(c) Humidity (%) 80

(d) Radiation (rd) 3.5x10⁴

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) ATM-

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>110 for 30 days</u>	Accident type	<u>LOCA</u>	R3
(b) Pressure (psig)	<u>NA</u>	Accident type	<u>LOCA</u>	R3
(c) Humidity (%)	<u>NA</u>	Accident type	<u>LOCA</u>	R3
(d) Radiation (rd)	<u>1x10⁷</u>	Accident type	<u>LOCA</u>	
(e) Spray Type	<u>NA</u>	Accident type	<u>NA</u>	R3

Affected Motors: 1-MTR-30-177-A, Rm A9
1-MTR-30-178-B, Rm A8

Motors listed are required to operate only during conditions resulting from a LOCA. R3

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 18 OF 28
R 2 R
BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20 86 JDH
WOUND MOTORS- OUTSIDE CONTAIN- 2-23-89
MENT CHECKED NMB DATE 9/20/86 KAN
3/9/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): _____

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: _____)

TAB C, Section 7.0, Submergence and moisture intrusion).

- (7) Subject to submergence (Yes/No/NA)? No (Reference: _____)

Flooding in Auxiliary Building - B45, 860110 218 and TAB C, Section 7.0, Submergence and moisture intrusion.).

Identify initiation time and duration of submergence: _____

No motors of this binder are subject to submergence.

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? NA (Reference: Section P-Note 1).

R2

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

R2

WBNNAL3-031

See TAB B, Section A

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 19 OF 28
R 2 R _____
BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/20/86 TDH
WOUND MOTORS- OUTSIDE CONTAIN- 2-23-89
MENT CHECKED NMB DATE 9/20/86 KBN
3/9/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u> R2
Operating Time	40 years + <u>100 days</u>	<u>44 years</u>	NUC-22, Section V, <u>TAB D-2</u>
Temperature (°F)	<u>135°C</u>	<u>155°C</u>	See TAB C, <u>Section 8.1</u>
Pressure (psig)	<u>ATM</u>	<u>ATM</u>	See TAB C, <u>Section 9.0</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	TAB C, <u>Section 8.3</u>
Chemical Spray*	<u>NA</u>	<u>NA</u>	<u>NA</u> NUC-22, Section V, p 7, TAB D-2 and TAB C, <u>Section 8.2</u>
Radiation (rd)**	<u>1.04x10⁸</u>	<u>2.2x10⁸</u>	Refer to TAB C, <u>Section 7.0</u>
Submergence	<u>NA</u>	<u>NA</u>	

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 20 OF 28
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Achely DATE 9/20/86 R R
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>TAB C, Sect. 8.1</u>
Pressure	<u>Yes</u>	<u>TAB C, Sect. 3.5</u>
Relative Humidity	<u>Yes</u>	<u>TAB C, Sect. 8.3</u>
Chemical Spray	<u>NA</u>	<u>TAB C, Sect. 3.4</u>
Submergence	<u>NA</u>	<u>TAB C, Sect. 7.0</u>

JUSTIFICATION/COMMENTS _____

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>Note 1</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u> </u>	<u>NA(Note 2)</u>

PAGE B-25

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 21 OF 28
BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Ackerly DATE 9/26/86 R R
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/26/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

Radiation: +10% of accident dose	<u>10%</u>	<u>Yes (Note 3)</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>10%</u>	<u>Yes (Note 1)</u>
Voltage: \pm 10% of rated value	<u> </u>	<u>NA (Note 4)</u>
Frequency: \pm 5% of rated value	<u> </u>	<u>NA (Note 4)</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u> </u>	<u>NA (Note 5)</u>
Vibration: +10% added to acceleration	<u> </u>	<u>NA (Note 6)</u>

JUSTIFICATION/COMMENTS

Note 1 - Refer to TAB C, Section 8.1.

Note 2 - Refer to TAB C, Section 3.5.

Note 3 - Refer to TAB C, Section 8.2.

Note 4 - Refer to TAB C, Section 5.0.

Note 5 - Refer to TAB C, Section 3.3.

Note 6 - These motors do not experience significant process-

related vibration and as such, the vibration margin

has been accounted for during the seismic/vibration

tests documented in the Nuc-22 report.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 22 OF 28
BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED 9/20/86 DATE 9/20/86
MOTORS-OUTSIDE CONTAINMENT CHECKED 9/20/86 DATE 9/20/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference _____).

JUSTIFICATION/COMMENTS Refer to TAB A and J(1).

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference _____).

JUSTIFICATION/COMMENTS TAB C, Section 3.3.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference _____).

JUSTIFICATION/COMMENTS TAB C, Section 3.3.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference NUC-22, p 7, Section V).

JUSTIFICATION/COMMENTS Motor operated under full-load conditions following accelerated thermal aging, irradiation, and mechanical aging.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? NA
(Reference _____).

JUSTIFICATION/COMMENTS No test anomalies were reported.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 23 OF 28
BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Achery DATE 9/20/86 ° R R
MOTORS-OUTSIDE CONTAINMENT CHECKED 12 DATE 9/20/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS No replaceable items were identified in the
insulation system qualification program described in NUC-9 and NUC-22.
The bearings and lubricants are routine maintenance items, the replace-
ment of which is addressed in the Qualification Maintenance Data Sheets
(QMDS) in this binder. Basically, lubrication schedules, bearing
replacement intervals and electrical and mechanical surveillance
recommendations are detailed in the QMDS located in TAB G.

BINDER NO WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 24 OF 28
BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Rejuly DATE 9/26/86 R R
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/24/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>NA</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>Yes</u>
(b) Were specific features and failure modes and effects analyzed?	<u>Yes</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>Yes</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>Yes</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 25 OF 28
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Actualy DATE 9/20/86
MOTORS-OUTSIDE CONTAINMENT CHECKED [Signature] DATE 9/20/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>NA</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Section P Note 1</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 26 OF 28

BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Adhary DATE 9/20/86 R R

MOTORS-OUTSIDE CONTAINMENT CHECKED PJ DATE 9/21/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>Yes</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. Discussion

Note 1: Motors are located in areas throughout the auxiliary building.
Beta-radiation is confined to the reactor building by plant
design; therefore, these motors are not required to be eval-
uated for the effects of beta radiation.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 27 OF 28
 R 2 R 2
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/26/86 JDH
WOUND MOTORS- OUTSIDE CONTAIN- 5/22/89
MENT CHECKED NMB DATE 9/26/86 KH
5/24/89

SUPPLEMENT 1
 COMPONENT-UNIQUE CHECKLIST
 MOTORS

Page 1 of 2

EQUIPMENT IDENTIFICATION

- (1) Is the motor identified in the qualification report identical to the plant motors which require qualification (Yes/No/NA)? No
 (Refer Note 1)

Item	Plant	Report	Acceptable (Yes/No/NA)	Report Section
(a) Insulation system materials	<u>RH</u>	<u>RH</u>	<u>Yes</u>	TAB C, Sect. 2.1
(b) Coil construction (form or random wound, cast)	<u>Random</u>	<u>Random</u>	<u>Yes</u>	TAB D-1, Nuc-9, Sect. I.D
(c) Insulation class (B, F, H)	<u>H</u>	<u>H</u>	<u>Yes</u>	TAB D-2, Nuc-22, Sect. III
(d) Lubricant				TAB D-2, NUC-22, App 1, Sect. I
Manufacturer	<u>Chevron</u>	<u>Chevron</u>	<u>Yes</u>	TAB D-2, NUC-22, App 1, Sect. I
Type	<u>SRI-2</u>	<u>SRI-2</u>	<u>Yes</u>	
(e) Bearing				
Manufacturer	<u>Note 2</u>	<u>Note 2</u>	<u>Yes</u>	
Type	<u>Anti Friction</u>	<u>Anti Friction</u>	<u>Yes</u>	TAB C, Sect. 4.1
Bearing life	<u>*</u>	<u>*</u>	<u>Yes</u>	TAB C, Sect. 4.1

R2

*See TAB G, QMDS.

R2

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 28 OF 28
 R 2 R 2
 BINDER TITLE RELIANCE-RANDOM COMPUTED DFA DATE 9/26/86 JDH
WOUND MOTORS- OUTSIDE CONTAIN- 4/24/89
MENT CHECKED NMB DATE 9/26/86 KBN
4/24/89

EQUIPMENT IDENTIFICATION (Continued)

Page 2 of 2

Item	Plant	Report	Acceptable (Yes/No/NA)	Report Section
(f) Seals				
Manufacturer	<u>Note 2</u>	<u>Note 2</u>	<u>Yes</u>	
Type	<u>400654</u>	<u>400654</u>	<u>Yes</u>	<u>NUC-9, Sect.V.C.TAB D</u>
Material	<u>Steel</u>	<u>Steel</u>	<u>Yes</u>	<u>NUC-9, Sect.V.C.TAB D</u>
(g) Motor lead insulation	<u>RH</u>	<u>RH</u>	<u>Yes</u>	<u>NUC-9, Sect. III. 8, p 12. TAB D</u>

Comments: Note 1: Tested motors are the same as installed except for the actual physical size and rating. Differences are achieved through the use of long-time, industry standard design and construction principles.

Note 2: Tested equipment utilized components determined to be acceptable by Reliance. Bearings and seals for equipment in TAB A were also provided by Reliance.

- (2) Does the qualification report indicate that the motorette insulation system is the same as that used on the motors (Yes/No/NA)? Yes
 (Reference: Refer to TAB C, Section 2.1).
 Comments: _____
- (3) Has the vendor provided the bearing rating (Yes/No/NA)? Yes
 (Reference: Refer to TAB C, Section 4.1).
 Comments: _____
- (4) Was the lubricant included in the test program (Yes/No/NA)? Yes
 (Reference: NUC-22).
 Comments: Lubricant is maintenance item only. Refer to TAB C Section 4.2
- (5) Were the seals included in the test program (Yes/No/NA)? Yes
 (Reference: NUC-9, Section V.C.).
 Comments: Refer to TAB C, Section 4.3

PRINT DATE: 01/11/89

BINDER NO. : WBNEQ-MOT -004
MANUFACTURER : LOUIS ALLIS
PAGE 1 OF 2

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	MODEL NUMBER	LOCATION	CONTRACT	CAI	OPER TIME	EVENT	SAFETY FUNCTION
WBNE-1-MTR -030-0194 EL 737 PENETRATION ROOM COOLER MOTOR	-A 1-MTR -030-0194 M.O. 4-147740	-A	737' A05 84K5-834550-2	A 1000 A 1MO A 1MO A 1MO A 1MO	L AF/A CV/A RH/A AB			MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM
WBNE-2-MTR -030-0194 EL 737 PENETRATION ROOM COOLER MOTOR	-A 2-MTR -030-0194 M.O. 4-147745	-A	737' A09 84K5-834550-2	A 1000 A 1MO A 1MO A 1MO A 1MO	L AF/A CV/A RH/A AB			MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM
WBNE-1-MTR -030-0195 EL 737 PENETRATION ROOM COOLER MOTOR	-B 1-MTR -030-0195 M.O. 4-147740	-B	737' A05 84K5-834550-2	A 1000 A 1MO A 1MO A 1MO A 1MO	L AF/A CV/A RH/A AB			MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM
WBNE-2-MTR -030-0195 EL 737 PENETRATION ROOM COOLER MOTOR	-B 2-MTR -030-0195 M.O. 4-147745	-B 321	737' A09 84K5-834550-2	A 1000 A 1MO A 1MO A 1MO A 1MO	L AF/A CV/A RH/A AB			MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM
WBNE-1-MTR -030-0196 EL 713 PENETRATION ROOM COOLER MOTOR	-A 1-MTR -030-0196 M.O. 4-147739	-A	713' A06 84K5-834550-2	A 1000 A 1MO A 1MO A 1MO A 1MO	L AF/A CV/A RH/A AB			MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM

PAGE A-1

R2

PREPARER/DATE D F Ackerly 9/2/86 JDN
CHECKED/DATE N M Burstein 9/2/86 JDN
R 2 R R

PRINT DATE: 01/11/89

SINDER NO. : WBNEQ-MOT -004
MANUFACTURER : LOUIS ALLIS
PAGE 2 OF 2

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EGIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZIMUTH ELEV(1) CONTRACT	BM/RAD (2)	OPER TIME (2)	EVENT	SAFETY FUNCTION
WBN-1-MTR -030-0197 EL 713 PENETRATION ROOM COOLER MOTOR	-B 1-MTR -030-0197 M.O. 4-147739	-B 713' A06 84K5-834550-2	A A A A	100D 1MO 1MO 1MO	L AF/A CV/A RH/A AB	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM
WBN-2-MTR -030-0200 EGTS COOLER FAN MOTOR	-A 2-MTR -030-0200 M.O. 4-147746	-A 757' A16 84K5-834550-2	A C C C	100D	L RH/A CV/A AF AB	EVENT L:THE EGTS MUST WORK TO PREVENT RELEASE OF RADIOACTIVE GASES.THESE MTRS MUST FUNCTION TO PREVENT OVERHEATING EGTS.
WBN-2-MTR -030-0207 EGTS COOLER FAN MOTOR	-B 2-MTR -030-0207 M.O. 4-147746	-B 757' A16 84K5-534550-2	A C C C	100D	L RH/A CV/A AF AB	EVENT L:THE EGTS MUST WORK TO PREVENT RELEASE OF RADIOACTIVE GASES.THESE MTRS MUST FUNCTION TO PREVENT OVERHEATING EGTS.

PAGE A-2

R2

PREPARER/DATE D F Ackerly 9/2/86
CHECKED/DATE N M Burstein 9/2/86

R 2 R R
JRK
2-2-89
2-2-89
2-2-89

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE LOUIS ALLIS - COMPUTED /R2 JDA DATE 2-2-89
INDUCTION MOTORS - OUTSIDE
CONTAINMENT CHECKED /R2 KBN DATE 2/8/89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-3 R2 for source of Category and Operating Time Assignments.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adg. by DATE 8/23/86 R R
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 8/23/86

TAB B

TABLE OF CONTENTS

- TAB B-1 Louis Allis NH5 Insulation System
(For service to 1×10^5 rads total)
- TAB B-2 Louis Allis NH7 Insulation System
(For service to 1×10^7 rads total)
- TAB B-3 Louis Allis NH9 Insulation System
(For service to 1×10^9 rads total)

LOUIS ALLIS NH5 INSULATION SYSTEM

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 30
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 9/15/86 JDH
INDUCTION MOTORS - OUTSIDE 3-9-89
CONTAINMENT CHECKED NMB DATE 9/15/86 KBN
3/9/89

A. DOCUMENTATION (see note)

| R2

Equipment Description Squirrel-Cage Induction Motor
Vendor/Manufacturer Louis Allis
Equipment Model No.(s) 3hp, 460 Vac, NH5 insulation system
M.O. No. 4-147739

QUALIFICATION REPORTS (see note)

| R2

- (1) Title/Number/Revision Insulation Sys Study RIMS B71 860512 103
Class H - Safety Class 1E-600 Volt AC Stator
(for SVC to 1×10^5 rads); M&M Report 272 DATE January 28, 1977
(2) Title/Number/Revision _____ RIMS _____
DATE _____

OTHER (ANALYSIS, VENDOR DATA, ETC.)

| R2

- (3) System 30 Category and Operating Times WBNOSG4-008 R11
(B45 870123 426)
(4) WBN Environmental Dwg. 47E235-56 R1.
(5) TVA Radiation Calculation WBNNAL3-029 R1 (B26 881031 011).
(6) Nuclear Qualification Report 4-147739-NQR, Rev. A (TAB E-1).
(7) TVA Degraded Voltage Calculation WBP-EVAR 8602001 R0
(B43 860227 901).
(8) Material Aging Calculation WAC-081 (TAB D-7).

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

| R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 2 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Advisory DATE 9/15/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 9/15/86

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES Refer to open items
listed in the front of this binder.

1. Weephole to be drilled in terminal box (Open Item 6)

COMMENTS/RECOMMENDATIONS _____

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 3 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Aggeling DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED 18 DATE 8/28/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- | | |
|---------------|---|
| <u>X</u> | Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974) |
| <u> </u> | Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN) |

JUSTIFICATION/ COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 334-1974 Type Test of Continuous Duty Class 1E Motors

NEMA MG1-1982 Motors and Generators

IEEE 117-1974 Evaluation of Insulating Materials for Random-Wound

AC Electric Machinery

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 4 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adjudy DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED 12 DATE 8/28/86

D. QUALIFICATION METHODOLOGY (Check only one block)

 Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

 Test of Similar Items with Supporting Analysis

 X Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

 Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.0, for additional details.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 5 OF 30
 R 2 R 2
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
 CONTAINMENT CHECKED NMB DATE 8/28/86 183 4-8-89

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Induction Motor</u>	<u>Motorettes</u>	<u>TAB C</u> <u>Sect 3.1</u> <u>Qual Rpt 1</u>
(2) Manufacturer	<u>Louis Allis</u>	<u>Louis Allis</u>	<u>Title Pg</u>
(3) Model Number(s)	<u>3hp, 460 Vac</u>	<u>NH5 Ins. Sys.</u>	
	<u>NH5 Ins. Sys.</u>		
	<u>M.O. 4-147739</u>		
(4) Serial Number(s)	<u>4-147739-001</u>	<u>NA</u>	<u>TAB E-1</u> <u>R2</u> <u>Rpt</u> <u>4-147739-NQR</u> <u>Rev A, Sect B</u>
	<u>4-147739-002</u>		
(5) Identify Component- Unique checksheet attached:	<u>Supp 1. Component Unique Checklist.</u> <u>Motors.</u>		

JUSTIFICATION/COMMENTS The equipment provided for the plant
consists of complete motor assemblies which included a random-
wound stator with the NH5 insulation system. The qualification
report documents the motorette testing performed on the NH5
insulation system in accordance with IEEE 117-1974. Applicability
of the data from the qualification report is dependent solely
upon the use of the NH5 system (L.A. System P4-9060) in the
stator assembly and is independent of the motor horsepower rating.

PAGE B-7 R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 6 OF 30
 R 2 R 2
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDA
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 R2 FILE

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	
External Process Connections	<u>NA</u>	<u>NA</u>	
Electrical Connections	<u>NA</u>	<u>NA</u>	
Conduit Seals	<u>NA</u>	<u>NA</u>	
Connector Seals	<u>NA</u>	<u>NA</u>	
Orientation	<u>NA</u>	<u>NA</u>	
Physical Configuration	<u>NA</u>	<u>NA</u>	
Other			

R2

JUSTIFICATION/COMMENTS Refer to TAB C. Section 6.0. Interfaces.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 7 OF 30
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Agnew DATE 8/28/86
 MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>TAB C, Sect 3.2</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Note 1, Also TAB C</u> <u>Att 1, Sect B.2</u>
(c) Equipment aged:		<u>Qual. Rpt 1, App 1,</u> <u>pg 1, Subsect C.1,</u> <u>also TAB C,</u>
Thermal	<u>Yes</u>	<u>Att 1, Sect B.4</u>
Radiation	<u>NA</u>	<u>TAB C,</u> <u>Att 1, Sect C.2</u>
Wear	<u>NA</u>	<u>TAB C, Sect 3.1</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>TAB C, Sect 3.2</u>
(e) Design basis event (DBE) exposure	<u>NA</u>	<u>TAB C, Sect 3.3</u>
(f) Post-DBE exposure	<u>NA</u>	<u>TAB C, Sect 3.3</u>
(g) Final inspection and disassembly	<u>NA</u>	<u>Note 2</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? NA
 (Reference Note 2)

JUSTIFICATION/COMMENTS Note 1 - Refer to Qual. Rpt 1, App I,
Att 2, LTP-110, pg 1, Method of Test, Sect 2.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 8 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adkins DATE 8/28/86 R 0 R 0
MOTORS - OUTSIDE CONTAINMENT CHECKED lg DATE 8/29/86

G. TEST SEQUENCE (continued)

Note 2 - The continued ability of the motorette and the insulation
system to function is predicated upon its ability to
withstand dielectric proof tests as shown in TAB C, Att.1,
Sect B.7. Failure of a dielectric proof test is a con-
clusive failure and does not require accurate and calibrat-
ed test equipment.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 9 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Quickly DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference Qual Rpt 1, App I, pg 1, Test Procedure, Sect A).

JUSTIFICATION/COMMENTS Aging factors were applied to models of the stator insulation following methods outlined in IEEE 117-1974.

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Refer to H.4.a</u>
Radiation exposure	<u>Yes</u>	<u>Refer to H.5.a</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Refer to H.6.a</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>Refer to H.7.a</u>

JUSTIFICATION/COMMENTS Motorette testing consists of subjecting models of insulation systems to a series of exposures to heat, vibration, moisture, and other environmental parameters to simulate the effects of long service, thereby simulating the cumulative effect of extended operation. Refer to TAB C, Section 3.1.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference)

JUSTIFICATION/COMMENTS A review of the materials used in these motors indicates that there are no known synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
(yes/no/NA)? Yes (Reference Qual. Rpt 1, App I, pg 1, Test Procedure, Section C.1). PAGE B-11

JUSTIFICATION/COMMENTS Also refer to TAB C, Att 1, Sect B.4.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 10 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Acquidy DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED Bz DATE 8/28/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference: Qual Rpt 1, App I, Att 1).

JUSTIFICATION/COMMENTS Refer to TAB C, Att 1, Sect B.1.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Qual Rpt 1, App 1, Att 2, LTP-110, pg 2, Method of Test, Sect 3.a).

JUSTIFICATION/COMMENTS Refer to TAB C, Att 1, Sect B.4.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference _____).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	_____	_____	_____
Time	_____	_____	_____

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.0.

- (e) Was the Arrhenius methodology used for accelerated aging?
(yes/no/NA)? Yes (Reference _____
_____).

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.0.

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA
(Reference _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.0.

BINDER NO. WBNEQ-MOT-QQ4 PLANT WBN UNIT(S) 1 SHEET 11 OF 30
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 JDH

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? Yes
(Reference: _____).

JUSTIFICATION/COMMENTS Qualification of motors through the use of motorette tests involves the use of the equation of a regression-type implied average life characteristic. Refer to TAB C. Sect 3.0.

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? NA (Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C. Sect 3.1.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C. Att 1. Sect C.2.

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? Yes
(Reference: Qual Rept 1. App 2).

JUSTIFICATION/COMMENTS Refer to TAB C. Attachment 1, Section C.2

R2

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? NA
(Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C. Att 1. Sect C.2.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 12 OF 30
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 40122

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? NA (Reference: _____).
_____).

Plant normal ambient radiation dose (rd) 9.3 x 10³

Test exposure dose (rd) _____

Test exposure dose rate (rd/hr) _____

Test exposure source type (e.g., Co-60 gamma) _____

JUSTIFICATION/COMMENTS Refer to TAB C, Att 1, Sect C.2

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ Yes (Reference: _____) | R2
_____).

JUSTIFICATION/COMMENTS Refer to TAB c, Att 1, Sect B.5

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes
(Reference: Qual Rpt 1, App 1, Att 2, LTP-110, pg 2,
Method of Test, Sect 3.b _____).

JUSTIFICATION/COMMENTS Mechanical stress testing
performed in accordance with Sect 2.2.3 of IEEE 117-1974
to simulate forces on the winding that occur in an
actual motor.

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 13 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Ackerly DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED Bj DATE 8/28/86

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes
(Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.1

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.1

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes
(Reference

Qualified life (Document in QMDS) Expected qualified life is 40+ years.

JUSTIFICATION/COMMENTS Refer to TAB C, Att 1, Sect D.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 14 OF 30
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 KBJ
2/6/89

H. AGING (Continued)

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: _____)

JUSTIFICATION/COMMENTS No replacement items were identified
in the insulation system qualification program described in
M&M Rpt 272. The bearings and lubricants are routine
maintenance items, the replacement of which are addressed in
individual Qualification Maintenance Data Sheets in this binder.
Basically, lubrication schedules, bearing replacement
intervals and electrical and mechanical surveillance
recommendations, particularly regarding the neoprene slingers
and gaskets, are detailed.

BINDER NO: WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 15 OF 30
R 1 R

BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Ackerly DATE 9/2/86 *SAH*

MOTORS - OUTSIDE CONTAINMENT CHECKED NMB DATE 9/2/86 *SAH*

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation, Degradation and Aging. (See Section C of EQC Binder for Detailed Materials Analysis).

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>References</u>	<u>Activation Energy</u>	<u>Reference</u>
				TAB D-7, WAC-081, Calc No 1
(a) <u>Type NH5 insulation system</u>	<u>1 x 10⁻⁵</u>	<u>Note 1</u>	<u>1.24</u>	<u>Calc No 1</u>
<u>Bearing Lubricant</u>				
(b) <u>(Chevron SRI-2 Grease)</u>	<u>2 x 10⁻⁸</u>	<u>Note 2</u>	<u>Note 4</u>	
<u>Neoprene/Mechanical/</u>				
(c) <u>slinger & gasket</u>	<u>2 x 10⁻⁶</u>	<u>Note 3</u>	<u>Note 4</u>	
(d) <u></u>	<u></u>	<u></u>	<u></u>	<u></u>
(e) <u></u>	<u></u>	<u></u>	<u></u>	<u></u>

JUSTIFICATION/COMMENTS

Note 1: Radiation threshold is actual rating of system. Refer to TAB C,
Att. 1, Sec. C.

Note 2: Refer to Digital Material Aging and Radiation Effects Library,
Library Code No. 157-83A, and TAB C, Section 4.2

Note 3: Refer to Digital Material Aging and Radiation Effects Library,
Library Code No. 202-83, Radiation Library Code 094-83.

Note 4: Consideration of long-term thermal degradation is not required
because lubricant and slingers are not considered to be substances
and devices with infinite lives. A surveillance and maintenance
program is established in the QMDS in TAB G to ensure proper
operation.

WBEP - 0111R
06/15/88

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 16 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED *Rehder* DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED *B* DATE 8/28/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Qual Rpt 1, App 1, Att 2,

LTP-110, pg 2, Method of Test, Sect 3.d).

Identify Acceptance Criteria: Failure to withstand 10 minute applied potential tests at the following levels: turn to turn - 120 Vac; coil to coil - 600 Vac; coil to ground - 600 Vac.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Qual Rpt 1, App 1,

Att 2, LTP-110, pg 1, Method of Test, Sect 2).

Identify baseline and functional testing: Functional tests listed in section J.1 above. Each motorette was subjected to the following baseline tests: turn to turn - 400 Vac; coil to coil - 2000 Vac; coil to ground - 2000 Vac.

JUSTIFICATION/COMMENTS Also refer to TAB C, Att 1, Sects B.2. & B.7.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? NA
(Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.3.

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____)

JUSTIFICATION/COMMENTS Voltages applied to the motorettes during baseline testing described in J.2 were chosen to be above the maximum service voltage for motors rated 460 Vac.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	NA	
Load	NA	
Frequency	NA	
Accuracy	NA	
Other(s)		

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 5.0 for
discussion of Voltage and Frequency requirements.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 18 OF 30
 R 2 R
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 10/2/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) Parameter	Specific Accident Conditions	Reference
Voltage	NA	
Load	NA	
Frequency	NA	
Accuracy	NA	
Other(s)		

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 5.0 for
discussion of voltage and frequency requirements.

(c) Parameter	Demonstrated Conditions	Reference
Voltage	NA	
Load	NA	
Frequency	NA	
Accuracy	NA	
Other(s)		

JUSTIFICATION/COMMENTS Refer to TAB C, Sect. 5.0 for
discussion of voltage and frequency requirements.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 19 OF 30
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 9/15/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 9/15/86 10/1/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-56 | R2

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>ATM-</u>	(b) Pressure (psig) <u>ATM-</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>9.3x10³*</u>	(d) Radiation (rd) <u>-</u>

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hours per excursion and will occur less than
1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameters including peak, duration, and profile):

(1) 196/15 min
decaying to
110 in 24 hrs
continuing for
30 days

(a) Temp (°F) **	(2) 110 for 100 days	Accident type <u>HELB</u>	R2
		<u>LOCA</u>	
(b) Pressure (psig)	<u>ATM</u>	Accident type <u>HELB</u>	
(c) Humidity (%)	<u>100</u>	Accident type <u>HELB</u>	
(d) Radiation (rd)	<u>1.1 x 10⁴*</u>	Accident type <u>LOCA</u>	
(e) Spray Type	<u>NA</u>	Accident type <u> </u>	

* Radiation site specific dose per TVA Calculation
WBNNAL3-029

| R2

• ** For additional details, refer to TAB C, Att 1,
Section C.1.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 20 OF 30
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 3-9-89
CONTAINMENT CHECKED NMB DATE 8/28/86 KBN
3/9/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Motors are located outside containment and are not subject to chemical spray.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: _____)

WBN Environmental Drawing 47E235-56, | R2
also refer to TAB C, Sect 7.0).

- (7) Subject to submergence (Yes/No/NA)? No (Reference: _____)

TAB C, Sect 7.0 and WBN Environmental Dwg. 47E235-56). | R2

Identify initiation time and duration of submergence: _____

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? NA
(Reference: Section P - Note 1).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

R2

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

WBNNAL3-029

See TAB B-1 Sect A

| R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 21 OF 30
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Dejuly DATE 8/28/86 R R
 MOTORS - OUTSIDE CONTAINMENT CHECKED fg DATE 8/28/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>Note 1</u>	<u> </u>	<u> </u>
Temperature (^o F)	<u>Note 1</u>	<u> </u>	<u> </u>
Pressure (psig)	<u>ATM</u>	<u>Att 1, Sect 3.5</u>	<u> </u>
Relative Humidity (%)	<u>100</u>	<u>TAB C,</u> <u>Att 1 Sect B.6</u>	<u> </u>
*Chemical Spray	<u>NA</u>	<u>TAB C, Sect 3.4</u>	<u> </u>
**Radiation (rd)	<u>2.03x10⁴</u>	<u>TAB C,</u> <u>Att 1, Sect C.2</u>	<u> </u>
Submergence	<u>NA</u>	<u>TAB C, Sect 7.0</u>	<u> </u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile</u> <u>Envelopes Specified</u> <u>(Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>TAB C,</u> <u>Att 1, Sect C.1</u>
Pressure	<u>Yes</u>	<u>TAB C, Sect 3.5</u>
Relative Humidity	<u>Yes</u>	<u>TAB C,</u> <u>Att 1, Sect B.6</u>
Chemical Spray	<u>NA</u>	<u>TAB C, Sect 3.4</u>
Submergence	<u>NA</u>	<u>TAB C, Sect 7.0</u>

JUSTIFICATION/COMMENTS Note 1: Worst case temperature is the result
of a HELB and is 196°F (91°C) for 15 minutes, decaying to 110°F
(43.3°C) in 24 hrs. and continuing for 30 days.

Worst case life is based upon conditions resulting from a LOCA which
is 110°F for a duration of 100 days. See TAB C, Att 1, Sect C.1.

PAGE 23 - 23

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 22 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED *Dejany* DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED *15* DATE 8/28/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>Note 1</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u> </u>	<u>NA (2)</u>
Radiation: +10% of accident dose	<u> </u>	<u>Yes(6)</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>Note 1</u>	<u>Yes</u>
Voltage: <u>+10%</u> of rated value	<u> </u>	<u>NA (3)</u>
Frequency: <u>+5%</u> of rated value	<u> </u>	<u>NA (3)</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u> </u>	<u>NA (4)</u>
Vibration: +10% added to acceleration	<u> </u>	<u>NA (5)</u>

JUSTIFICATION/ COMMENTS :

Note 1 Per TAB C, Att 1, Sect C.1, a worst case expected life
is 15,079.61 years with a max. hot spot temp of 88.33°C.
The required operating time is 40.27 years. A significant
margin exists in the relationship between time and
temperature criteria.

(2) Refer to TAB C, Sect 3.5.

(3) Refer to TAB C, Sect 5.0.

(4) Refer to TAB C, Sect 3.3.

(5) These motors do not experience significant process-related vibration and as such, a vibration margin above the levels addressed in TAB C, Att 1, Sect B.5 is not required.

(6) Refer to TAB C, Att 1, Sect C.2.

PAGE B-24

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 23 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Ackerly DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference _____)

JUSTIFICATION/COMMENTS Motors utilizing the stator insulation
system tested, must be capable of starting and maintaining operation.
Refer to TAB A.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? NA
(Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.3.

- (3). Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? NA
(Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.3.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? NA (Reference

JUSTIFICATION/COMMENTS TAB C, Att 1, Sect D.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 25 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adjusted DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED 12 DATE 8/28/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS No replaceable items were identified in the
insulation system qualification program described in M&M Report 272
relative the insulation system. The bearings and lubricants are
routine maintenance items, the replacement of which are addressed in
individual Qualification Maintenance Data Sheets in this binder.
Basically, lubrication schedules, bearing replacement intervals and
electrical and mechanical surveillance recommendations, particularly
regarding the neoprene slingers and gaskets, are detailed in the QMDS
located in TAB G.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 26 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED October DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 9/28/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>Yes</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>Yes</u>
(b) Were specific features and failure modes and effects analyzed?	<u>Yes</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>Yes</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>Yes</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 27 OF 30
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Checked DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED BZ DATE 8/28/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>NA</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>NA</u>
(b) Was beta radiation considered?	<u>Section P - Note 1</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 28 OF 30
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Objectively DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED 15 DATE 8/28/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>NA</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA</u>
(18) Criteria regarding synergistic effects satisfied?	<u>NA</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

NOTE: Motors are located in areas throughout the Auxiliary Building.
Beta-radiation is confined to the Reactor Bldg. by plant
design; therefore, these motors are not required to be
evaluated for the effects of beta radiation.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 29 OF 30
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Aggley DATE 8/28/86
 MOTORS - OUTSIDE CONTAINMENT CHECKED 13 DATE 8/28/86

SUPPLEMENT 1
 COMPONENT-UNIQUE CHECKLIST
 MOTORS

Page 1 of 2

EQUIPMENT IDENTIFICATION

- (1) Is the motor identified in the qualification report identical to the plant motors which require qualification (yes/no/NA)? No

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(a) Insulation system materials	<u>NH5</u> (P4-9060)	<u>NH5</u> (P4-9060)	<u>Yes</u>	refer to (2) <u>supplement</u>
(b) Coil construction (form or random wound, cast)	<u>Random</u>	<u>Random</u>	<u>Yes</u>	Qual Rpt 1, <u>App 1, Intro</u>
(c) Insulation class (B, F, H)	<u>H</u>	<u>H</u>	<u>Yes</u>	Qual Rt 1, <u>pg 1, Scope</u>
(d) Lubricant				
Manufacturer	<u>Chevron</u>	<u>NA</u>	<u>Yes</u>	refer to TAB C,
Type	<u>SRI-2</u>	<u>NA</u>	<u>Yes</u>	<u>Sect 4.2</u>
(e) Bearing				
Manufacturer	<u>MRC</u>	<u>NA</u>	<u>Yes</u>	refer to (3) <u>this supplement</u>
Type	<u>Anti-friction</u>	<u>NA</u>	<u>Yes</u>	
Bearing life				
(f) Seals				
Manufacturer	<u>-</u>	<u>NA</u>		
Type	<u>Slinger</u>	<u>NA</u>	<u>Yes</u>	refer to (5) <u>this supplement</u>
Material	<u>Neoprene</u>		<u>Yes</u>	

PAGE B-31

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 30 OF 30
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 10/18/88

EQUIPMENT IDENTIFICATION (Continued)

Page 2 of 2

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable</u> <u>(Yes/No/NA)</u>	<u>Report</u> <u>Section</u>
(g) Motor lead insulation	Si <u>Rubber</u>	Si <u>Rubber</u>	<u>Yes</u>	TAB C, Att 1, Sect C.3

Comments: _____

- (2) Does the qualification report indicate that the motorette insulation system is the same as that used on the motors (Yes/No/NA)? Yes (Reference: _____).

Comments: TAB E-1, document 4-147739-NQR, Rev A, Sheet 1, | R2
item B.2

- (3) Has the vendor provided the bearing rating (Yes/No/NA)? Yes (Reference: _____).

Comments: Refer to TAB C, Sect 4.1.

- (4) Was the lubricant included in the test program (Yes/No/NA)? No (Reference: _____).

Comments: Refer to TAB C, Sect 4.2.

- (5) Were the seals included in the test program (Yes/No/NA)? No (Reference: _____).

Comments: Refer to TAB C, Sect 4.3.

LOUIS ALLIS NH7 INSULATION SYSTEM

2-9

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 29
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/23/86 JDH
INDUCTION MOTORS - OUTSIDE 3-9-89
CONTAINMENT CHECKED NMB DATE 8/25/86 KBN
3-9-89

A. DOCUMENTATION (See Note)

|R2

Equipment Description Squirrel-Cage Induction Motor
Vendor/Manufacturer Louis Allis
Equipment Model No.(s) 3hp, 460VAC, NH7 Insulation System
M.O. Nos. 4-147740 and 4-147745

QUALIFICATION REPORTS (See Note)

|R2

- (1) Title/Number/Revision Insulation Sys Study RIMS B71 860512 102
Class 200°C - Safety Class 1E-600 Volt A.C. DATE March 26, 1986
Random Wound Stator (1 x 10⁷ Rads Total) M&M
Report No. 280B
- (2) Title/Number/Revision Insulation Sys Study RIMS B71 860512 101
Class 200 + °C - Safety Class 1E - 600 VAC DATE November 13, 1980
Random Wound Stator (1 x 10⁷ Rads Total) M&M
Report No. 280A-1
- (3) Title/Number/Revision _____ RIMS _____
_____ DATE _____

OTHER (ANALYSIS, VENDOR DATA, ETC.)

|R2

- (4) IEEE paper 32C3-76 and support documentation (proprietary-
TAB D-5)

PAGE B-34 R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 1a OF 29

R 2 R

BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 9/15/86 JDH

INDUCTION MOTORS - OUTSIDE 3-9-89

CONTAINMENT CHECKED NMB DATE 9/15/86 KR

3/9/89

(5) WBN Environmental Dwg. 47E235-48 R3

(6) Material Aging Calculation WAC-169 (TAB D-6)

(7) TVA Radiation Calculation WBNNAL3-007 R1 (B45 860919 235) R3

(8) Nuclear Qualification Report 4-147740-NQR, Rev. A (TAB E-2)

(9) Nuclear Qualification Report 4-147745-NQR, Rev. A (TAB E-3)

(10) System 30 Category and Operating Times-WBNOSG4-008 R11

(B45 870123 426)

(11) TVA Degraded Voltage Calculation WBP-EVAR 8602001 R0

(B43 860227 901)

R2

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

R2

PAGE B-35 R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 3 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Ackley DATE 8/23/86
MOTORS - OUTSIDE CONTAINMENT CHECKED 12 DATE 8/28/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- _____ Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET
NEMA MG-11982 Motors and Genertors.

IEEE 334-1974 Type Test of Continuous Duty Class 1E Motors.

IEEE 117-1974 Evaluation of Insulating Materials for Random-Wound
AC Electric Machinery.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 4 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Agurly DATE 8/23/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/25/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- X Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.0 for additional details.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 5 OF 29
 R 2 R 2
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/23/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/25/86 JDH

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Induction Motor</u>	<u>Motorette</u>	<u>TAB C, Sect. 3.1 Qual Rpt 1</u>
(2) Manufacturer	<u>Louis Allis</u>	<u>Louis Allis</u>	<u>Title Page</u>
(3) Model Number(s)	<u>3 hp, 460VAC</u>	<u>NH7 ins. sys.</u>	
	<u>4-147740</u>		
	<u>4-147745</u>		
(4) Serial Number(s)	<u>4-147740-001</u>	<u>NA</u>	<u>Note 1</u>
	<u>4-147740-002</u>		
	<u>4-147745-001</u>		
	<u>4-147745-002</u>		
(5) Identify Component- Unique checksheet attached:	<u>Supplement 1. Component - Unique Checklist. Motors</u>		

R2

JUSTIFICATION/COMMENTS The equipment provided for the plant consists of complete motor assemblies which includes a random wound stator with the NH7 insulation system. The qualification report documents the motorette testing performed on the NH7 insulation in accordance with IEEE 117-1974. Applicability of the data from the qualification report is dependent solely upon the use of the NH7 system (Louis Allis System P4-9128) in the stator assembly and is independent of the motor horsepower rating.

NOTE 1: Serial numbers were obtained from Section B of the appropriate NQR report. These reports are in sub-tabs located in TAB E.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 7 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Adelberg DATE 8/23/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/25/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>TAB C, Sect. 3.2</u> <u>TAB C, Att. 2,</u> <u>Sect. B.3.b</u>
(b) Baseline performance measurements taken	<u>Yes</u>	
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>TAB C, Att. 2,</u> <u>Sect. B.3.d</u>
Radiation	<u>Yes</u>	<u>TAB C, Att. 2,</u> <u>Sect. C. 2</u>
Wear	<u>NA</u>	<u>TAB C,</u> <u>Sect. 3.1</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>TAB C, Sect. 3.2, and</u> <u>Att. 2, Sect. B.3.e</u>
(e) Design basis event (DBE) exposure	<u>NA</u>	<u>TAB C, Sect. 3.3</u>
(f) Post-DBE exposure	<u>NA</u>	<u>TAB C, Sect. 3.3</u>
(g) Final inspection and disassembly	<u>NA</u>	<u>Note 1</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? NA
(Reference Note 1).

JUSTIFICATION/COMMENTS _____

Note 1 - The ability of the motorette and the insulation system to function is predicated upon its ability to withstand dielectric proof tests in TAB C, Attachment 2, Section B.3.e. Failure of a dielectric proof test is a conclusive failure and does not require accurate and calibrated test equipment.

PAGE B-44

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 8 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Actully DATE 8/23/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/26/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference)

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2, Sections

B.1, B.2, and B.3.d.

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Refer to H.4.a</u>
Radiation exposure	<u>Yes</u>	<u>Refer to H.5.a</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Refer to H.6.a</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>Refer to H.7.a</u>

JUSTIFICATION/COMMENTS Motorettes testing consists of subjecting
models to heat, vibration, and moisture to simulate the effects of
long service, thereby, simulating the cumulative effect of extended
operation.

- (3) Were all known synergistic effects which are believed to have a
significant effect on equipment performance considered in the aging
program (yes/no/NA)? NA (Reference)

JUSTIFICATION/COMMENTS A review of the materials used in these
motors indicates that there are no known synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
(yes/no/NA)? Yes (Reference)

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2,

Section B.1.

PAGE B 42

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 9 OF 29
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/23/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/26/86 WJL/HB

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (Yes/No/NA)? Yes
(Reference: Qualification Report 1, pp 2-4, Section B).

JUSTIFICATION/COMMENTS Also refer to TAB C, Attachment

2, Section B.

- (c) Was the basis for thermal aging identified in the qualification program (Yes/No/NA)? Yes
(Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2,

Sections B.2 and B.3.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (Yes/No/NA)? Yes (Reference: _____).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
------------------	-----------------------------	-------------	-------------------

Temperature	_____	_____	_____
Time	_____	_____	_____

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2,

Section B.3.d.

- (e) Was the Arrhenius methodology used for accelerated aging (Yes/No/NA)? Yes (Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.0 |R2

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (Yes/No/NA)? NA
(Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.0 |R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 10 OF 29
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/23/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/25/86 KB

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? Yes
(Reference:).

JUSTIFICATION/COMMENTS Qualification of the motors
through the use of motorette tests involves the use of
the equation of a regression-type implied average life
characteristic. Refer to TAB C, Section 3.0

R2

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? NA (Reference:).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.1

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: Qualification
Report, 1, p 5, Data Evaluation, Section B).

JUSTIFICATION/COMMENTS Also refer to TAB C, Attachment
2, Section C.2.

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? Yes
(Reference: Qualification Report 1, Attachment 7).

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2,
Section C.2

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? NA
(Reference:).

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2,
Section C.2.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 11 OF 29
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/23/86 JDH
INDUCTION MOTORS - OUTSIDE
CONTAINMENT CHECKED NMB DATE 8/26/86 2-2-89
KBJ

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? NA (Reference: _____).

Plant normal ambient radiation dose (rd) 8.8 x 10⁵

Test exposure dose (rd) _____

Test exposure dose rate (rd/hr) _____

Test exposure source type (e.g., Co-60 gamma) _____

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2, Section C.2.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ Yes (Reference: _____) | R2

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2, Section B.3.e.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2, Section B.3.e.

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 12 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Actualy DATE 8/23/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/25/86

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes
(Reference _____)

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.1

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference)

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.1.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes
(Reference

Qualified life (Document in QMDS) Expected qualified life is 40 + years.

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2, Section D.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 13 OF 29
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/23/86 JDH
INDUCTION MOTORS - OUTSIDE
CONTAINMENT CHECKED NMB DATE 8/25/86 2-2-89
2/18/89

H. AGING (Continued)

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: _____)

JUSTIFICATION/COMMENTS No replaceable items were identified
in the insulation system qualification program described in
M&M Reports 280B and 280A-1. The bearings and lubricants are
routine maintenance items, the replacement of which are
addressed in individual Qualification Maintenance Data Sheets
in this binder. Basically, lubrication schedules, bearing
replacement intervals and electrical and mechanical
surveillance recommendations, particularly regarding the
neoprene slingers and gaskets, are detailed.

BINDER NO: WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 14 OF 29
R 1 R
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Ackerly DATE 8/28/86 AT/6/88
 MOTORS - OUTSIDE CONTAINMENT CHECKED NMB DATE 8/28/86 JAA 6/21/88

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

	<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>References</u>	<u>Activation Energy</u>	<u>Reference</u>
(a)	<u>NH7 Insulation/Electrical</u>	<u>1 x 10²</u>	<u>Note 1</u>	<u>.92</u>	<u>WAC-169 TAB D-6</u>
(b)	<u>Chevron SRI-2/Lubricant</u>	<u>2 x 10⁸</u>	<u>Note 2</u>	<u>Note 4</u>	
(c)	<u>Neoprene/mechanical/ slinger & gasket</u>	<u>2 x 10⁶</u>	<u>Note 3</u>	<u>Note 4</u>	
(d)					
(e)					

JUSTIFICATION/COMMENTS Detailed Material Analysis is TAB C, Attachment 2.

Note 1: Value shown is insulation rating. Radiation threshold is actual rating of system. Refer to TAB C, Attachment 2.

Note 2: Refer to Digital Material Aging and Radiation Effects Library, Library Code No. 157-83, and TAB C, Section 4.2.

Note 3: Refer to Digital Material Aging and Radiation Effects Library, Library Code No. 202-83A, Radiation Library Code 094-83.

Note 4: Consideration of long term thermal degradation is not required because lubricant and slingers are not considered to be substances and devices with infinite lives. A surveillance and maintenance program is established in the QMDS in TAB G to ensure proper operation.

WBEP - 0111R
06/15/88

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 15 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Adg DATE 8/23/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED 15 DATE 8/25/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes _____ (Reference _____)

Identify Acceptance Criteria: Refer to TAB C, Attachment 2, Section
B.3.e.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes _____ (Reference _____)

Identify baseline and functional testing: Refer to TAB C, Attachment 2,
Sections B.3.b and B.3.e.

JUSTIFICATION/COMMENTS

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? NA
(Reference _____)

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.3.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 16 OF 29
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/23/86 JDA
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/25/86 KER

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____)

JUSTIFICATION/COMMENTS Voltages applied to the motorettes during baseline testing addressed in TAB C, Attachment 2, Section B.3.b are conservatively typical of the stressing occurring in motors rated 460 VAC.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>NA</u>	<u> </u>
Load	<u>NA</u>	<u> </u>
Frequency	<u>NA</u>	<u> </u>
Accuracy	<u>NA</u>	<u> </u>
Other(s)	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

R2

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0 for discussion of Voltage and Frequency requirements.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 17 OF 29
 R 2 R
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/23/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/25/86 10/14/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>	R2
Voltage	<u>NA</u>		
Load	<u>NA</u>		
Frequency	<u>NA</u>		
Accuracy	<u>NA</u>		
Other(s)			

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0 for
discussion of voltage and frequency requirements.

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>	R2
Voltage	<u>NA</u>		
Load	<u>NA</u>		
Frequency	<u>NA</u>		
Accuracy	<u>NA</u>		
Other(s)			

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0 for
discussion of voltage and frequency requirements.

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-48 | R2

- | | |
|--|-----------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>104</u> | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM(-)</u> | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>90</u> |
| (d) Radiation (rd) <u>8.8×10^5</u> | (d) Radiation (rd) <u>-</u> |

- (3) Process Interfaces: None
- (4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hours per excursion and will occur less than 1% of the plant life.

- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- (1) 196 for 15 min.
decaying to 110
in 24 hours and
continuing for
30 days

- | | | | |
|---------------------|----------------------------|-------------------------------|----|
| | (2) 110 for 100 | (1) HELB | R2 |
| (a) Temp. (°F) (**) | <u>days</u> | Accident type (2) <u>LOCA</u> | |
| (b) Pressure (psig) | <u>ATM(-)</u> | Accident type <u>HELB</u> | |
| (c) Humidity (%) | <u>100</u> | Accident type <u>HELB</u> | |
| (d) Radiation (rd) | <u>1.2x10⁶*</u> | Accident type <u>LOCA</u> | |
| (e) Spray Type | <u>NA</u> | Accident type | |

Affected Motors: 1-MTR-30-194-A
1-MTR-30-195-B
2-MTR-30-194-A
2-MTR-30-195-B

* Location specific radiation value from TVA Calculation
WBNNAL3-007

** For additional details, refer to TAB C, Att 2, Sect C.1.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 19 OF 29
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 9/15/86 JDH
INDUCTION MOTORS - OUTSIDE 3-9-89
CONTAINMENT CHECKED NMB DATE 9/15/86 KBN
3-9-89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Motors are located outside containment and are not subject to chemical spray.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: WBN Environmental Dwg 47E235-48 and TAB C, Section 7.0). | R2

- (7) Subject to submergence (Yes/No/NA)? No (Reference: WBN Environmental Dwg 47E235-48 and TAB C, Section 7.0). | R2
Identify initiation time and duration of submergence: _____

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? NA (Reference: Section P-NOTE 1). | R2
If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

- (9) Special environmental calculations (temp., rad., etc.)

Type	RIMS No.
<u>WBNNAL3-007</u>	<u>See TAB B-2, Sect. A</u>
_____	_____

 | R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 20 OF 29
 BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Adhigley DATE 8/23/96 R R
 MOTORS - OUTSIDE CONTAINMENT CHECKED BZ DATE 8/25/96

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>Note 1</u>	<u> </u>	<u> </u>
Temperature (°F)	<u>Note 1</u>	<u> </u>	<u> </u>
Pressure (psig)	<u>ATM(-)</u>	<u>Sect. 3.5</u>	<u> </u>
Relative Humidity (%)	<u>100%</u>	<u>TAB C, Att.2,</u> <u>Sect. B.3.e</u>	<u> </u>
*Chemical Spray	<u>NA</u>	<u>TAB C,</u> <u>Sect. 3.4</u>	<u> </u>
**Radiation (rd)	<u>2.08x10⁶</u>	<u>TAB C, Att. 2,</u> <u>Sect. C.2</u>	<u> </u>
Submergence	<u>NA</u>	<u>TAB C,</u> <u>Sect. 7.0</u>	<u> </u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>TAB C, Att.2, Sect. C.1</u>
Pressure	<u>Yes</u>	<u>TAB C, Sect. 3.5</u>
Relative Humidity	<u>Yes</u>	<u>TAB C, Att.2, Sect. B.3.e</u>
Chemical Spray	<u>NA</u>	<u>TAB C, Sect. 3.4</u>
Submergence	<u>NA</u>	<u>TAB C, Sect. 7.0</u>

JUSTIFICATION/COMMENTS Note 1: Worst case temperature is the result of an
HELB and is 196°F (91°C) for 15 minutes, decaying to 110°F (43.3°C) in
24 hours and continuing for 30 days.

PAGE B-54 Worst case life is based upon conditions resulting from a LOCA which is
110°F for a duration of 100 days. See TAB C, Attachment 2, Section C.1.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 21 OF 29
 R 2 R 2
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/23/86 JOH
INDUCTION MOTORS - OUTSIDE 5/16/89
 CONTAINMENT CHECKED NMB DATE 8/25/86 KH/ML
5/16/89 KBN

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>Note 1</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig		<u>NA (2)</u>
Radiation: +10% of accident dose		<u>Yes (6)</u> R2
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>Note 1</u>	<u>Yes</u>
Voltage: ±10% of rated value		<u>NA (3)</u>
Frequency: ±5% of rated value		<u>NA (3)</u>
Environmental Transient: the initial transient and the peak temperature applied twice		<u>NA (4)</u>
Vibration: +10% added to acceleration		<u>NA (5)</u>

JUSTIFICATION/COMMENTS

Note (1) Per TAB C, Attachment 2, Section C.1, a worst case expected life is 6,066.79 years with a maximum hot spot temperature of 95.40°C. The required operating time is 40.27 years. A significant margin exists in the relationship between time and temperature criteria.

Note (2) Refer to TAB C, Section 3.5.

Note (3) Refer to TAB C, Section 5.0.

Note (4) Refer to TAB C, Section 3.3.

Note (5) These motors do not experience significant process-related vibration and as such, a vibration margin above the levels addressed in TAB C, Attachment 3, Section B.3.e, is not required.

Note (6) Refer to TAB C, Attachment 2, Section C.2.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 22 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Acharya DATE 8/23/86
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/25/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference _____)

JUSTIFICATION/COMMENTS Motors utilizing the stator insulation
system tested, must be capable of starting and maintaining
operation. Refer to TAB A.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? NA
(Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.3.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? NA
(Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.3.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? _____ (Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 2, Section D.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 23 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Ackerly DATE 8/23/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/25/86

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes
(Reference _____)

JUSTIFICATION/COMMENTS In the DuPont test, results were reported on only 9 motorettes at 260°C. The omission of the data regarding one motorette out of a total set of 50 motorettes does not have a significant adverse effect upon the implied average life characteristic developed through the use of the test data.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 24 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Qcheely DATE 8/23/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/25/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS No replaceable items were identified in the
insulation system qualification program. The bearings and lubricants
are routine maintenance items, the replacement of which are addressed
in individual Qualification Maintenance Data Sheets in this binder.
Basically, lubrication schedules, bearing replacement intervals and
electrical and mechanical surveillance recommendations particularly
regarding the neoprene slingers and gaskets, are detailed in the QMDS
located in TAB G.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 25 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Agility DATE 8/23/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/26/86

0. SUMMARY OF REVIEW

Yes/No/NA

- | | |
|--|------------|
| (1) Documented evidence of qualification adequate
(Have all assumptions, mathematical models, and
all extrapolations of test data used in an
analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary)
taken to the specified qualification level
adequately justified? | <u>Yes</u> |
| (3) Choice of qualification methodology adequately
justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements
identified? | <u>Yes</u> |
| (b) Were specific features and failure modes and
effects analyzed? | <u>Yes</u> |
| (c) Were assumptions and mathematical models used
together with appropriate justification for
their use? | <u>Yes</u> |
| (d) Were environmental parameters which affect
equipment performance identified? | <u>Yes</u> |
| (5) Adequate similarity between equipment and test
specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u> |
| (b) Equipment aged to end of life condition prior to
application of DBE conditions? | <u>Yes</u> |
| (c) Absence of preaging in test/analysis justified? | <u>NA</u> |
| (d) Materials susceptible to thermal/radiation
aging identified? | <u>Yes</u> |

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 26 OF 29
 BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Achury DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>NA</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Section P- Note 1</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 27 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Rechecked DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED BZ DATE 8/28/86

O. SUMMARY OF REVIEW (Continued)

Yes/No/NA

- (15) Criteria regarding functional testing satisfied? Yes
- (a) Does the test plan/report specify an acceptance criteria for equipment performed? Yes
- (b) Was an initial base line test done to establish required performance characteristics? Yes
- (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g.. voltage. load frequency. and other electrical characteristics) can be ensured? Yes
- (16) Criteria regarding instrument accuracy satisfied? NA
- (17) Test duration margin (1 hour + function time) satisfied? Yes
- (a) Is the minimum specified operating time at least 1 hour? Yes
- (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? NA
- (18) Criteria regarding synergistic effects satisfied? NA
- (19) Criteria regarding margins satisfied? Yes
- (20) Maintenance and surveillance requirements adequately identified? Yes

P. DISCUSSION

NOTE 1: Motors are located throughout the Auxiliary Building. Beta
radiation is confined to the Reactor Building by plant
design; therefore, these motors are not required to be
evaluated for the effects of beta radiation.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 28 OF 29
 BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Adhedy DATE 8/23/86
 MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/25/86

SUPPLEMENT 1
 COMPONENT-UNIQUE CHECKLIST
 MOTORS

Page 1 of 2

EQUIPMENT IDENTIFICATION

- (1) Is the motor identified in the qualification report identical to the plant motors which require qualification (yes/no/NA)? No

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(a) Insulation system materials	<u>NH7 (P4-9128)</u>	<u>NH7 (P4-9128)</u>	<u>Yes</u>	<u>Qual. Rpt.1, p 1, Object</u>
(b) Coil construction (form or random wound, cast)	<u>random</u>	<u>random</u>	<u>Yes</u>	<u>Qual. Rpt. 1, Title Page</u>
(c) Insulation class (B, F, H)	<u>H</u>	<u>H</u>	<u>Yes</u>	<u>Qual. Rpt. 1, p 5, Data Eval. Sect.A, Thermal</u>
(d) Lubricant				
Manufacturer	<u>Chevron</u>	<u>NA</u>	<u>Yes</u>	<u>Refer to TAB C, Sect. 4.2</u>
Type	<u>SRI-2</u>	<u>NA</u>	<u>Yes</u>	
(e) Bearing				
Manufacturer	<u>MRC</u>	<u>NA</u>	<u>Yes</u>	<u>Refer to (3) this supplement</u>
Type	<u>Anti-friction</u>	<u>NA</u>	<u>Yes</u>	
Bearing life				
(f) Seals				
Manufacturer		<u>NA</u>		<u>Refer to (5) this supplement</u>
Type	<u>Slinger</u>	<u>NA</u>	<u>Yes</u>	
Material	<u>Neoprene</u>		<u>Yes</u>	

PAGE B-62

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 29 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Ackley DATE 8/23/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/25/86

EQUIPMENT IDENTIFICATION (Continued)

Page 2 of 2

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(g) Motor lead insulation	Nomex w/ <u>Glass Braid</u>	Nomex/w <u>Glass Braid</u>	<u>Yes</u>	TAB C, Att. 2, <u>Sect. C.3</u>

Comments: _____

- (2) Does the qualification report indicate that the motorette insulation system is the same as that used on the motors (yes/no/NA)? Yes
(Reference _____)
_____).

Comments: Refer to TAB C, Attachment 3, Sections B.1 and B.2.

- (3) Has the vendor provided the bearing rating (yes/no/NA)? Yes
(Reference _____)
_____).

Comments: Refer to TAB C, Section 4.1.

- (4) Was the lubricant included in the test program (yes/no/NA)? No
(Reference _____)
_____).

Comments: Refer to TAB C, Section 4.2.

- (5) Were the seals included in the test program (yes/no/NA)? No
(Reference _____)
_____).

Comments: Refer to TAB C, Section 4.3.

PAGE B-63

LOUIS ALLIS NH9 INSULATION SYSTEM

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 29
 R 2 R
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 9/15/86 JDA
INDUCTION MOTORS - OUTSIDE 3-7-89
 CONTAINMENT CHECKED NMB DATE 9/15/86 KBN
3/9/89

A. DOCUMENTATION (See Note) | R2

Equipment Description Squirrel-Cage Induction Motor
 Vendor/Manufacturer Louis Allis
 Equipment Model No.(s) 3hp, 460 Vac, NH9 insulation system,
M.O. 4-147746

QUALIFICATION REPORTS (See Note) | R2

- (1) Title/Number/Revision Insulation System RIMS B71 860512 104
Evaluation Qualification for Safety Class DATE Sept. 20, 1983
1E Normal Service. M&M Report No. 282
 (2) Title/Number/Revision _____ RIMS _____
 _____ DATE _____

OTHER (ANALYSIS, VENDOR DATA, ETC.) | R2

- (3) Material Aging Calculation WAC-082 (TAB D-8).
 (4) WBN Environmental Dwg. 47E235-78 R3.
 (5) TVA Radiation Calculation WBNNAL3-031 R1 (B45 880826 235).
 (6) System 30 Category and Operating Times WBNOSG4-008 R11
(B45 870123 426).
 (7) Nuclear Qualification Report 4-147746-NQR. Rev. A (TAB E-4)
 (8) TVA Degraded Voltage Calculation WBP-EVAR 8602001 Rev. 0
(B43 860227 901).

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references. | R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 2 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Qch DATE 9/15/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED 12 DATE 9/15/86

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES Refer to Open Items listed in the front of this binder.

1. Obtain revised field verification (Open Item 1)

COMMENTS/RECOMMENDATIONS

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 3 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Checked DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED Bj DATE 8/28/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- ☒ X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- ☐ Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS _____

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 334-1974 Type Test of Continuous Duty Class 1E Motors.

NEMA MG1-1982 Motors and Generators

IEEE 117-1974 Evaluation of Insulating Materials for Random-Wound

AC Electric Machinery

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 4 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED 8/28/86 DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED 12 DATE 8/28/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- ☐ Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- ☐ Test of Similar Items with Supporting Analysis
- ☒ Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- ☐ Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.0 for additional details.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 5 OF 29
 R 2 R 2
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 TDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 2/2/89

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Induction Motor</u>	<u>Motorettes</u>	<u>TAB C</u> <u>Sect. 3.1</u> <u>Qual. Rpt 1</u>
(2) Manufacturer	<u>Louis Allis</u>	<u>Louis Allis</u>	<u>Title Page</u>
(3) Model Number(s)	<u>3hp, 460 Vac</u>	<u>NH9 Ins. Sys.</u>	
	<u>NH9 Ins. Sys</u>		
	<u>MO 4-147746</u>		
(4) Serial Number(s)	<u>4-147746-001</u>	<u>NA</u>	<u>TAB E-4</u> <u>Rpt 4-</u> <u>147746-</u> <u>NQR, Rev A,</u> <u>Sect B</u>
	<u>4-147746-002</u>		
(5) Identify Component- Unique checksheet attached:	<u>Supplement 1, Component - Unique</u> <u>Checklist, Motors</u>		

R2

R2

JUSTIFICATION/COMMENTS The equipment provided for the plant
consists of complete motor assemblies which includes a random-
wound stator with the NH9 insulation system. The qualification
report documents the motorette testing performed on the NH9
insulation system in accordance with IEEE 117-1974. Applicability
of the data from the qualification report is dependent solely
upon the use of the NH9 system (Louis Allis System P4-9061) in
the stator assembly and is independent of the motor horsepower
rating.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 6 OF 29
 R 2 R 2
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 KBJ
2/2/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u></u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u></u>
Electrical Connections	<u>NA</u>	<u>NA</u>	<u></u>
Conduit Seals	<u>NA</u>	<u>NA</u>	<u></u>
Connector Seals	<u>NA</u>	<u>NA</u>	<u></u>
Orientation	<u>NA</u>	<u>NA</u>	<u></u>
Physical Configuration	<u>NA</u>	<u>NA</u>	<u></u>
Other	<u></u>	<u></u>	<u></u>

| R2

JUSTIFICATION/COMMENTS Refer to TAB C, Section 6.0, Interfaces

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 7 OF 29
 R 2 R 2
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDA
INDUCTION MOTORS - OUTSIDE 2-2-89
 CONTAINMENT CHECKED NMB DATE 8/28/86 KW 2/2/89

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (Yes/No/NA)? (Note below.)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>TAB C</u> <u>Sect 3.2</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Note 1 also,</u> <u>TAB C, Att 3,</u> <u>Sect B-2</u> <u>Qual Rpt 1, p2</u> <u>Discussion</u>
(c) Equipment aged: Thermal	<u>Yes</u>	<u>Sect D</u> <u>Qual Rpt 1, p1</u> <u>Discussion</u>
Radiation	<u>Yes</u>	<u>Sect C</u>
Wear	<u>NA</u>	<u>TAB C, Sect 3.1</u> R2
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>TAB C, Sect 3.2</u>
(e) Design basis event (DBE) exposure	<u>NA</u>	<u>TAB C, Sect 3.3</u>
(f) Post-DBE exposure	<u>NA</u>	<u>TAB C, Sect 3.3</u>
(g) Final inspection and disassembly	<u>NA</u>	<u>Note 2</u> R2

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately document (Yes/No/NA)? Yes (Reference: Note 2).

JUSTIFICATION/COMMENTS Note 1 - Refer to Qualification Report 1,

Attachment 6, Document LTP-110, page 1, Method of Test, Sect 2.

Note 2 - The ability of the motorette and the insulation system
function is predicated upon its ability to withstand dielectric
proof tests in TAB C, Attachment 3, Section B.7. Failure of a
dielectric proof test is a conclusive failure and does not require
accurate and calibrated test equipment.

PAGE B-71 R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 8 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Ok DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED Pg DATE 8/28/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference Qualification Report 1,
page 1, Discussion, Section B).

JUSTIFICATION/COMMENTS Aging factors were applied to models of
the stator insulation following methods outlined in IEEE 117-1974.

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>H.4.a</u>
Radiation exposure	<u>Yes</u>	<u>H.5.a</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>H.6.a</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>H.7.a</u>

JUSTIFICATION/COMMENTS Motorette testing consists of subjecting
models of insulation systems to a series of exposures to
radiation, heat, vibration, and moisture to simulate the effects
of long service, thereby simulating the cumulative effect of
extended operation. Refer to TAB C, Section 3.1.

- (3) Were all known synergistic effects which are believed to have a
significant effect on equipment performance considered in the aging
program (yes/no/NA)? NA (Reference

JUSTIFICATION/COMMENTS A review of the materials used in these
motors indicates that there are no known synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
(yes/no/NA)? Yes (Reference Qualification Report 1,
page 4, Test Program, Section B, Thermal Qualification.).

JUSTIFICATION/COMMENTS Also refer to TAB C, Attachment 3, PAGE B-72
Section B.4.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 9 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Adgely DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED 12 DATE 8/28/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference: Qualification Report 1, Attachment 3).

JUSTIFICATION/COMMENTS Refer to TAB C, Att. 3, Section B.1.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Qualification Report 1, page 4, Section B, Thermal Qualification).

JUSTIFICATION/COMMENTS Refer to TAB C, Att. 3, Section B.4.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u> </u>	<u> </u>	<u> </u>
Time	<u> </u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.0

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.0

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA
(Reference).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.0

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 10 OF 29
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 1/1/87

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? Yes
(Reference: _____).

JUSTIFICATION/COMMENTS Qualification of the motors
through the use of motorette tests involves the use of
the equation of a regression-type implied average life
characteristic. Refer to TAB C, Section 3.0

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? NA (Reference: _____).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.1.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: Qualification
Report 1, page 2, Section A. Radiation Qualification).

JUSTIFICATION/COMMENTS Also refer to TAB C, Attachment
3, Section B.3.

R2

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? Yes
(Reference: Qualification Report 1, Attachment 3).

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? Yes
(Reference: Qualification Rpt 1, page 2, Subsection A.1
General).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 11 OF 29
R 2 R _____
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDA
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT _____ CHECKED NMB DATE 8/28/86 KEH/12/89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: Qualification Report 1, page 3, Section A.4.a.).

Plant normal ambient radiation dose (rd) 1.8×10^3 TID normal
Test exposure dose (rd) 1.1×10^2 TID
Test exposure dose rate (rd/hr) 0.49×10^6 for 2245 hrs
Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

R2

JUSTIFICATION/COMMENTS _____

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ Yes (Reference: Qualification Report 1, page 4, Section B.1).

R2

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 3, Section B.5.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Qualification Rpt 1, page 4, Sect B.3.b).

JUSTIFICATION/COMMENTS Mechanical stress testing performed in accordance with Section 2.2.3 of IEEE 117-1974 to simulate winding forces that occur in an actual motor.

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder.

R2

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 12 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Ochley DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes
(Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.1.

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.1.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes
(Reference

Qualified life (Document in QMDS) Expected qualified life is
40+ years.

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 3, Section D.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 13 OF 29
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 HR/89

H. AGING (Continued)

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: _____)

JUSTIFICATION/COMMENTS No replaceable items were identified
in the insulation system qualification program described in
M&M report 282. The bearings and lubricants are routine
maintenance items, the replacement of which are addressed in
individual Qualification Maintenance Data Sheets in this
binder. Basically, lubrication schedules, bearing replacement
intervals and electrical and mechanical surveillance recommen-
dations, particularly regarding the neoprene slingers and
gaskets, are detailed.

BINDER NO: WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 14 OF 29
 R 1
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Ackerly DATE 8/28/86 *AK*
 MOTORS - OUTSIDE CONTAINMENT CHECKED NMB DATE 8/28/86 *AK*

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation, Degradation and Aging (See Section C of EQC Binder for Detailed Materials Analysis).

<u>Material/Property/Function</u>	<u>Radiation</u>		<u>Activation</u>	
	<u>Threshold</u>	<u>References</u>	<u>Energy</u>	<u>Reference</u>
(a) <u>Type NH9 Insulation Sys</u>	<u>1.1×10^2</u>	<u>Note 1</u>	<u>1.22</u>	<u>Note 3</u>
(b) <u>Bearing Lubricant</u> <u>(Chevron SRI-2 grease)</u>	<u>2.0×10^8</u>	<u>Note 2</u>	<u>Note 5</u>	
(c) <u>Neoprene/mechanical/</u> <u>slinger & gasket</u>	<u>2×10^6</u>	<u>Note 4</u>	<u>Note 5</u>	
(d) _____	_____	_____	_____	_____
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS Note 1: The NH9 system withstood a total dose of
 1.1×10^2 rads and maintained its ability to perform its required
function as demonstrated by passing a post-exposure dielectric test.

Refer to Qualification Report 1, page 2, Section A.

Note 2: Refer to Digital Material Aging and Radiation Effects,

Library Code No. 157-83A, and TAB C, Section 4.2.

Note 3: Refer to Material Aging Calculation WAC-082. Refer to TAB D-8.

Note 4: Refer to Digital Material Aging and Radiation Effects Library,

Library Code No. 202-83A, Radiation Library Code 094-83.

Note 5: Consideration of long term thermal degradation is not required

because lubricant and slingers are not considered to be substances

or devices with infinite lives. A surveillance and maintenance

program is established in the QMDS in TAB G to ensure proper

operation.

R1

WBEP - 0111R
 06/15/88

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 15 OF 29
R 2 R _____
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT _____ CHECKED NMB DATE 8/28/86 WCB

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (Yes/No/NA)? Yes
(Reference: Qualification Report 1, page 4, Section B.3.d

Identify Acceptance Criteria: Failure to withstand 30 minute applied potential tests at the following levels: turn-to-turn, 120 VAC; coil-to-coil and coils-to-ground, 600 VAC.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (Yes/No/NA)? Yes
(Reference: Qualification Report 1, Attachment 6, LTP-110,

page 1, Method of Test, Section 2). | R2

Identify baseline and functional testing: Functional tests listed in section J.1 above. Each motorette was subjected to the following baseline tests: turn-to-turn, 400 VAC; coil-to-coil, 2000 VAC; coils-to-ground, 2000 VAC.

JUSTIFICATION/COMMENTS Also refer to TAB C, Att 3, Sections B.2 and B.7. | R2

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (Yes/No/NA)? NA
(Reference: _____

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.3

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 16 OF 29
 R 2 R
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 8/28/86 4/6/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____)

JUSTIFICATION/COMMENTS Voltages applied to the motorettes during baseline testing described in J.2 were chosen to be above the maximum service voltage for motors rated 460 VAC.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>NA</u>	<u> </u>
Load	<u>NA</u>	<u> </u>
Frequency	<u>NA</u>	<u> </u>
Accuracy	<u>NA</u>	<u> </u>
Other(s)	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

R2

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0 for discussion of voltage and frequency requirements.

BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JPH

INDUCTION MOTORS - OUTSIDE 2-2-89

CONTAINMENT CHECKED NMB DATE 8/28/86 *KON* *WLS*

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>	R2
----------------------	-------------------------------------	------------------	----

Voltage NA

Load	NA
------	----

Frequency	NA
-----------	----

Accuracy NA

Other(s)

JUSTIFICATION/COMMENTS Refer to TAB C, Sect. 5.0 for
discussion of voltage and frequency requirements.

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>	<u>R2</u>
----------------------	--------------------------------	------------------	-----------

Voltage _____ NA

Load	NA
1	0.00
2	0.00
3	0.00
4	0.00
5	0.00
6	0.00
7	0.00
8	0.00
9	0.00
10	0.00
11	0.00
12	0.00
13	0.00
14	0.00
15	0.00
16	0.00
17	0.00
18	0.00
19	0.00
20	0.00
21	0.00
22	0.00
23	0.00
24	0.00
25	0.00
26	0.00
27	0.00
28	0.00
29	0.00
30	0.00
31	0.00
32	0.00
33	0.00
34	0.00
35	0.00
36	0.00
37	0.00
38	0.00
39	0.00
40	0.00
41	0.00
42	0.00
43	0.00
44	0.00
45	0.00
46	0.00
47	0.00
48	0.00
49	0.00
50	0.00
51	0.00
52	0.00
53	0.00
54	0.00
55	0.00
56	0.00
57	0.00
58	0.00
59	0.00
60	0.00
61	0.00
62	0.00
63	0.00
64	0.00
65	0.00
66	0.00
67	0.00
68	0.00
69	0.00
70	0.00
71	0.00
72	0.00
73	0.00
74	0.00
75	0.00
76	0.00
77	0.00
78	0.00
79	0.00
80	0.00
81	0.00
82	0.00
83	0.00
84	0.00
85	0.00
86	0.00
87	0.00
88	0.00
89	0.00
90	0.00
91	0.00
92	0.00
93	0.00
94	0.00
95	0.00
96	0.00
97	0.00
98	0.00
99	0.00
100	0.00

Frequency	NA
-----------	----

Accuracy NA

Other(s)

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 5.0 for
discussion of voltage and frequency requirements.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 18 OF 29
R 2 R
BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 9/15/86 JDH
INDUCTION MOTORS - OUTSIDE 2-2-89
CONTAINMENT CHECKED NMB DATE 9/15/86 1/2/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-78 | R2

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>ATM</u>	(b) Pressure (psig) <u>ATM</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>1.8×10^3</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temp. (°F)(**)	<u>110 for 100 days</u>	Accident type <u>LOCA</u> R2
(b) Pressure (psig)	<u>NA</u>	Accident type <u> </u>
(c) Humidity (%)	<u>NA</u>	Accident type <u> </u>
(d) Radiation (rd)	<u>1.9×10^6*</u>	Accident type <u>LOCA</u> R2
(e) Spray Type	<u>NA</u>	Accident type <u> </u>

* Location specific dose per TVA calculation WBNAL3-031.

** For additional details, refer to TAB C, Att 3, Section C.

PAGE B-82 | R2

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Motors are located outside containment and are not subject to chemical spray.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference:)

TAB C, Section 7.0 and WBN Environmental Dwg 47E235-78). | R2

- (7) Subject to submergence (Yes/No/NA)? No (Reference:)

TAB C, Section 7.0 and WBN Environmental Dwg 47E235-78). | R2

Identify initiation time and duration of submergence:

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? NA (Reference: Section P - Note 1).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify:

R2

- (9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>	
<u>WBNNAL3-031</u>	<u>See TAB B-3, Sect A</u>	R2
<u> </u>	<u> </u>	
<u> </u>	<u> </u>	

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 20 OF 29
 R 2 R
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JDH
INDUCTION MOTORS - OUTSIDE 3-9-89
CONTAINMENT CHECKED NMB DATE 8/28/86 KBN
3/9/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>TAB C, Att. 3,</u> <u>Sect. D</u>	
Temperature (°F)	<u>110</u>	<u>TAB C, Att. 3,</u> <u>Sect. D</u>	
Pressure (psig)	<u>ATM</u>	<u>TAB C,</u> <u>Sect. 3.5</u>	
Relative Humidity (%)	<u>100</u>	<u>TAB C, Att. 3,</u> <u>Sect. B.6</u>	
Chemical Spray*	<u>NA</u>	<u>TAB C,</u> <u>Sect. 3.4</u>	
Radiation (rd)**	<u>1.9018x10⁶</u> <u>gamma</u>	<u>TAB C, Att. 3,</u> <u>Sect. D</u>	
Submergence	<u>NA</u>	<u>TAB C,</u> <u>Sect. 7.0</u>	

R2

R2

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile</u> <u>Envelopes Specified</u> <u>(Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>TAB C, Att. 3,</u> <u>Sect D</u>
Pressure	<u>Yes</u>	<u>TAB C,</u> <u>Sect. 3.5</u>
Relative Humidity	<u>Yes</u>	<u>TAB C, Att. 3,</u> <u>Sect. B.6</u>
Chemical Spray	<u>NA</u>	<u>TAB C,</u> <u>Sect 3.4</u>
Submergence	<u>NA</u>	<u>TAB C,</u> <u>Sect 7.0</u>

R2

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 21 OF 29
 BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Ackerly DATE 8/28/86 R R
 MOTORS - OUTSIDE CONTAINMENT CHECKED PB DATE 8/28/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>Note 1</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u> </u>	<u>NA(2)</u>
Radiation: +10% of accident dose	<u>10%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>Note 1</u>	<u>Yes</u>
Voltage: +10% of rated value	<u> </u>	<u>NA(3)</u>
Frequency: +5% of rated value	<u> </u>	<u>NA(3)</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u> </u>	<u>NA(4)</u>
Vibration: +10% added to acceleration	<u> </u>	<u>NA(5)</u>

JUSTIFICATION/COMMENTS: Note 1: Per TAB C, Att. 3, Sect. C.1, a worst case expected life was calculated to be 1,098,226 years with a maximum hot spot temperature of 78.33°C. The required operating time is 40.27 years. A significant margin exists in the relationship between the time and temperture criteria.

(2) Refer to TAB C, Section 3.5.

(3) Refer to TAB C, Section 5.0.

(4) Refer to TAB C, Section 3.3.

(5) These motors do not experience significant process-related vibration and as such, a vibration margin above the levels addressed in TAB C, Att. C, Section B.5 is not required.

PAGE B-85

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 22 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Ackerly DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED Bj DATE 8/28/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference

JUSTIFICATION/COMMENTS Motors utilizing the stator insulation
system tested, must be capable of starting and maintaining
operation. Refer to TAB A.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? NA
(Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.3.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? NA
(Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.3.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? NA (Reference

JUSTIFICATION/COMMENTS Refer to TAB C, Attachment 3, Section D.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 23 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Ackley DATE 8/28/86
MOTORS - OUTSIDE CONTAINMENT CHECKED Bz DATE 8/29/86

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? NA
(Reference _____)

JUSTIFICATION/COMMENTS No anomalies were noted throughout the
motorette testing.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 24 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Rechny DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED BZ DATE 8/28/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS No replaceable items were identified in the
insulation system qualification program described in M & M report 282.
The bearings and lubricants are routine maintenance items, the replace-
ment of which are addressed in individual Qualification Maintenance
Data Sheets in this binder. Basically, lubrication schedules, bearing
replacement intervals, and electrical and mechanical surveillance
recommendations, particularly regarding the neoprene slingers and
gaskets, are detailed in the OMDS located in TAB G.

PAGE B-88

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 25 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED October DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED Bj DATE 8/28/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>Yes</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>Yes</u>
(b) Were specific features and failure modes and effects analyzed?	<u>Yes</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>Yes</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>Yes</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

PAGE B-89

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 26 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Accuracy DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>NA</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Section P - Note 1</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

PAGE B-90

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 27 OF 29
BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Reckley DATE 8/28/86 R R
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>NA</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA</u>
(18) Criteria regarding synergistic effects satisfied?	<u>NA</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

NOTE 1: Motors are located throughout the Auxiliary Building. Beta
radiation is confined to the Reactor Building by plant
design; therefore, these motors are not required to be
evaluated for the effects of beta radiation.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 28 OF 29
 BINDER TITLE LOUIS ALLIS - INDUCTION COMPUTED Checked DATE 8/28/86
 MOTORS - OUTSIDE CONTAINMENT CHECKED 13 DATE 8/28/86

SUPPLEMENT 1
 COMPONENT-UNIQUE CHECKLIST
 MOTORS

Page 1 of 2

EQUIPMENT IDENTIFICATION

- (1) Is the motor identified in the qualification report identical to the plant motors which require qualification (yes/no/NA)? No

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(a) Insulation system materials	<u>NH9 (P4-9061 -115)</u>	<u>NH9 (P4-9061 -115)</u>	<u>Yes</u>	<u>Refer to (2) this supplement</u>
(b) Coil construction (form or random wound, cast)	<u>RANDOM</u>	<u>RANDOM</u>	<u>Yes</u>	<u>Qual. Rpt 1 p 1, OBJECT Refer to</u>
(c) Insulation class (B, F, H)	<u>H</u>	<u>H</u>	<u>Yes</u>	<u>Note 1 in Comments</u>
(d) Lubricant				
Manufacturer	<u>CHEVRON</u>	<u>NA</u>	<u>Yes</u>	<u>Refer to TAB C</u>
Type	<u>SRI-2</u>	<u>NA</u>	<u>Yes</u>	<u>Section 4.2</u>
(e) Bearing				
Manufacturer	<u>MRC</u>	<u>NA</u>	<u>Yes</u>	<u>Refer to (3) this Supplement</u>
Type	<u>Antifriction</u>	<u>NA</u>	<u>Yes</u>	
Bearing life	<u> </u>	<u>NA</u>	<u> </u>	<u> </u>
(f) Seals				
Manufacturer	<u>-</u>	<u>NA</u>	<u>-</u>	<u>-</u>
Type	<u>Slinger</u>	<u>NA</u>	<u>Yes</u>	<u>Refer to (5) this Supplement</u>
Material	<u>Neoprene</u>	<u>NA</u>	<u>Yes</u>	<u> </u>

PAGE B-92

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 29 OF 29
 R 2 R
 BINDER TITLE LOUIS ALLIS - COMPUTED DFA DATE 8/28/86 JOH
INDUCTION MOTORS - OUTSIDE 3-9-89
 CONTAINMENT CHECKED NMB DATE 8/28/86 KBN
3/9/89

EQUIPMENT IDENTIFICATION (Continued)

Page 2 of 2

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(g) Motor lead insulation	NOMEX w/ Glass Braid	NOMEX w/ Glass Braid	Yes	TAB C, Att. 3, Sect. D

Comments: Note 1 - TAB E-4, Document 4-147746-NQR, Rev A. | R2
page 3, Item 12.

(2) Does the qualification report indicate that the motorette insulation system is the same as that used on the motors (Yes/No/NA)? Yes
 (Reference: TAB E-4, Document 4-147746-NQR, Rev A, page 1 | R2
Section D.2).

Comments: _____

(3) Has the vendor provided the bearing rating (Yes/No/NA)? Yes
 (Reference: TAB E-4, Document 4-147746-NQR, Rev A, page 4 | R2
item 13).

Comments: Also refer to TAB C, Section 4.1

(4) Was the lubricant included in the test program (Yes/No/NA)? No
 (Reference: _____).

Comments: Refer to TAB C, Section 4.2.

(5) Were the seals included in the test program (Yes/No/NA)? No
 (Reference: _____).

Comments: Refer to TAB C, Section 4.3.

PRINT DATE: 06/27/90

BINDER NO. : WBNEQ-1
MANUFACTURER : LIMIT
PAGE 1 OF 5

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-MVOP-062-0061 -B 1-FCV -062-0061 SEAL FLOW RETURN ISOLATION VALVE	SB-00	-B 280	729' 7"	AC4 71C62-54114-1	A A A A A	100D 1MO 1MO 100D 100D	L RH/C CV/C FW/C MS/C	REQUIRED TO CLOSE AND REMAIN CLOSED AFTER PHASE AISOLATION SIGNAL IS RECEIVED AND RESET. SEE NOTE 4.
WBN-1-MVOP-063-0072 -A 1-FCV -063-0072 CNTMT SUMP TO RHR PUMP A-A	SB-3	-A	685'	A07' 71C62-54114-1	A B B B B	100D 1MO 1MO 1MO 1MO	L RH/A CV/A AB AF	L: NORM CLOSED VLV MUST OPEN TO ALIGN SUCTION OF RHR PUMP TO SUMP FOR "SI" RECIRC, MUST REMAIN OPEN DURING RECIRC MODE CLOSE TO MITIGATE SING FAILURE
WBN-1-MVOP-063-0073 -B 1-FCV -063-0073 CNTMT SUMP TO RHR PUMP B-B	SB-3	-B	685'	A07' 71C62-54114-1	A B B B B	100D 1MO 1MO 1MO 1MO	L RH/A CV/A AB AF	L: NORM CLOSED VLV MUST OPEN TO ALIGN SUCTION OF RHR PUMP TO SUMP FOR "SI" RECIRC, MUST REMAIN OPEN DURING RECIRC MODE CLOSE TO MITIGATE SING FAILURE
WBN-1-MVOP-063-0172 -B 1-FCV -063-0172 RHR TO RCS HOTLEG 1 & 3 FLOW ISLN VLV	SB-2	-B	713'	A28 71C62-54114-1	A A A A A	100D 1MO 1MO 1MO 1MO	L RH/A CV/A AB AF	NEEDED TO TRANSFER FROM COLD LEG RECIRC TO HOT LEG RECIRC. SEE NOTE 4.
WBN-1-MVOP-067-0087 -A 1-FCV -067-0087 LOWER CNTMT A COOLER DISCH ISLN VALVE IC		-A			A A A A A	100D 1MO 1MO 100D 100D	L RH/C CV/C FW/C MS/C	ISOL FLOW TO VENT COOLER UPON RECEIPT OF PHASE 'A' CONTAINMENT ISOLATION SIGNAL. SEE NOTE 4.

PAGE A-1

R4

PREPARER/DATE KEITH B. NAPIER 12/12/89 R 3
CHECKED/DATE D. L. KIRBY 12/12/89 R 4
CSH
2/10/90
2/10/90

PRINT DATE: 12/07/89

BINDER NO. : WBNEQ-1.0V -001
MANUFACTURER :
PAGE 2 OF 5

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-MVOP-067-0095 LOWER CNTMT C COOLER DISCH ISLN VALVE IC	-A 1-FCV -067-0095	-A			A	100D	L	ISOL FLOW TO VENT COOLER
					A	1MO	RH/C	UPON RECEIPT OF PHASE 'B'
					A	1MO	CV/C	CONTAINMENT ISOLATION SIGNAL
					A	100D	FW/C	SEE NOTE 4.
					A	100D	MS/C	
WBN-1-MVOP-067-0103 LOWER CNTMT B COOLER DISCH ISLN VALVE IC	-B 1-FCV -067-0103	-B			A	100D	L	ISOL FLOW TO VENT COOLER
					A	1MO	RH/C	UPON RECEIPT OF PHASE 'B'
					A	1MO	CV/C	CONTAINMENT ISOLATION SIGNAL
					A	100D	FW/C	SEE NOTE 4.
					A	100D	MS/C	
WBN-1-MVOP-067-0111 LOWER CNTMT D COOLER DISCH ISLN VALVE IC	-B 1-FCV -067-0111	-B			A	100D	L	VLV MUST CLOSE ON A CONTAIN
					A	1MO	RH/C	MENT ISOL SIGNAL AND REMAIN
					A	1MO	CV/C	CLOSED. SEE NOTE 4.
					A	100D	FW/C	
					A	100D	MS/C	
WBN-1-MVOP-067-0295 UPPER CNTMT VENT CLR A ISLN VALVE IC	-A 1-FCV -067-0295	-A 030	807' 6" UC		A	100D	L	VLV MUST CLOSE ON A CONTAIN
	SMB-000		79KA2-824589-1		A	1MO	RH/C	MENT ISOL SIGNAL AND REMAIN
					A	1MO	CV/C	CLOSED. SEE NOTE 4.
					A	100D	FW/C	
					A	100D	MS/C	
WBN-1-MVOP-067-0296 UPPER CNTMT VENT CLR C ISLN VALVE IC	-A 1-FCV -067-0296	-A 206	807' 7" UC		A	100D	L	VLV MUST CLOSE ON A CONTAIN
	SMB-000		79KA2-824589-1		A	1MO	RH/C	MENT ISOL SIGNAL AND REMAIN
					A	1MO	CV/C	CLOSED. SEE NOTE 4.
					A	100D	MS/C	
					A	100D	FW/C	

PAGE A-2

R3

PREPARER/DATE

Kath B. Nguyen
12/10/89

R 3

R R

CHECKED/DATE

12/10/89

12/10/89

PRINT DATE: 12/07/89

BINDER NO. : WBNEQ-100V -001
MANUFACTURER : LIMITORQUE
PAGE 3 OF 5

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-MVOP-067-0297 UPPER CNTMT VENT CLR B ISLN VALVE IC	-B	1-FCV -067-0297	-B 148 SMB-000	807' 7" UC 79KA2-824589-1	A	100D	L	VLV MUST CLOSE ON A CONTAIN	
					A	1MO	RH/C	MENT ISOL SIGNAL AND REMAIN	
					A	1MO	CV/C	CLOSED. SEE NOTE 4.	
					A	100D	FW/C		
					A	100D	MS/C		
WBN-1-MVOP-067-0298 UPPER CNTMT VENT CLR D ISLN VALVE IC	-B	1-FCV -067-0298	-B 338 SMB-000	807' 7" UC 79KA2-824589-1	A	100D	L	VLV MUST CLOSE ON A CONTAIN	
					A	1MO	RH/C	MENT ISOL SIGNAL AND REMAIN	
					A	1MO	CV/C	CLOSED. SEE NOTE 4.	
					A	100D	FW/C		
					A	100D	MS/C		
WBN-1-MVOP-068-0332 RCS PRZR REL FLOW CONTROL	-B	1-FCV -068-0332	-B 104 SB-00	787' 7" UC 71C62-54114-1	A	100D	L	VLVS MUST BE CAPABLE OF	
					A	1MO	RH/C	FUNCTIONING AT ANY TIME	
					A	1MO	CV/C	FOR ACCIDENT MITIGATION	
					A	100D	FW/C		
					A	100D	MS/C		
WBN-1-MVOP-068-0333 RCS PRZR REL FLOW CONTROL	-A	1-FCV -068-0333	-A 104 SB-00	787' 7" UC 71C62-54114-1	A	100D	L	VLVS MUST BE CAPABLE OF	
					A	1MO	RH/C	FUNCTIONING AT ANY TIME	
					A	1MO	CV/C	FOR ACCIDENT MITIGATION	
					A	100D	FW/C		
					A	100D	MS/C		
WBN-1-MVOP-070-0087 RC PMP THERM BAR RET CNTMT ISLN VALVE	-B	1-FCV -070-0087	-B 302 SMB-00	732' 11" AC4 78K24-823298	A	100D	L	CLOSE ON PHASE 'B' ISOL	
					A	1MO	RH/C	SIGNAL AND STAY CLOSED	
					A	1MO	CV/C	AFTER RESET OF SIGNAL TO	
					A	100D	FW/C	MAINTAIN CNTMT ISOLATION.	
					A	100D	MS/C	SEE NOTE 4.	

PAGE A-3

R3

PREPARER/DATE

CHECKED/DATE

R 3 R R

12/1/89

12/12/89

PRINT DATE: 06/27/90

BINDER NO. : WBNEQ-MO
MANUFACTURER :
PAGE 4 OF 5

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO.	MODEL NUMBER	AZMITH	ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-MVOP-070-0089 RC PMP OIL CLR RET	-B 1-FCV -070-0089	-B				A 100D A 1MO A 1MO A 100D A 100D		L RH/C CV/C FW/C MS/C	CLOSE ON PHASE 'B' ISOLATION SIGNAL AND STAY CLOSED AFTER RESET OF SIGNAL TO MAINTAIN CNTMT ISOLATION. SEE NOTE 4.
WBN-1-MVOP-074-0001 RHR SYSTEM ISOLATION VALVE	-A 1-FCV -074-0001	SB-2	-A 354	710'11" LC 71C62-54114-1		C NA A/B 15MN/1MO C NA C NA C NA		L RH/C CV/C FW/C MS/C	VLV MUST CLOSE IF OPEN AND REMAIN CLOSED TO MITIGATE RHR BREAK
WBN-1-MVOP-074-0002 RHR SYSTEM ISOLATION VALVE	-B 1-FCV -074-0002	SB-2	-B 300	723' 0" AC4 71C62-54114-1		C NA A 1MO C NA C NA C NA		L RH/C CV/C FW/C MS/C	VLV MUST CLOSE IF OPEN AND REMAIN CLOSED TO MITIGATE RHR BREAK. POS IND IS PAM VARIABLE AND MUST BE MONITORED FOR RHR BREAK. SEE NOTE 4.
WBN-1-MVOP-074-0003 RHR PUMP A-A INLET FLOW CNTRL VLV	-A 1-FCV -074-0003	SB-2	-A	676' A11 71C62-54114-1		A/B 1WK/100D C NA C NA C NA C NA		L RH/A CV/A AB AF	VLV MUST CLOSE DURING SWITCH-OVER FROM THE RWST TO THE CNTMT SUMP
WBN-1-MVOP-074-0008 RHR SYSTEM ISOLATION BYPASS VALVE	-A 1-FCV -074-0008	SB-1	-A 304	722' 1" AC4 71C62-54114-1		C NA A 1MO C NA C NA C NA		L RH/C CV/C FW/C MS/C	VLV MUST CLOSE IF OPEN AND REMAIN CLOSED TO MITIGATE RHR BREAK. POS IND IS PAM VARIABLE AND MUST BE MONITORED FOR RHR BREAK. SEE NOTE 4.

PAGE A-4 R4

PREPARER/DATE KEITH B. NAPIER 12/12/89 R 3
CHECKED/DATE D. L. KIRBY 12/12/89 R 4

PRINT DATE: 08/01/89

BINDER NO. : WBNEQ-MOV -001
MANUFACTURER : LIMITORQUE
PAGE 5 OF 5

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EOIS NUMBER	UNIT DEVICE ID NO.	LOCATION	DESCRIPTION	MODEL NUMBER	AZMITH	ELEV(1)	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
								(2)			
WBN-1-MVOP-074-0009	-B 1-FCV -074-0009	-B 348	RHR SYSTEM ISOLATION BYPASS VALVE	SB-1		709'11" LC 71C62-54114-1		C NA A/B 15MN/1MO C NA C NA C NA		L RH/C CV/C FW/C MS/C	IF OPEN, VLV MUST CLOSE AND REMAIN CLOSED FOR ACCIDENT MITIGATION
WBN-1-MVOP-074-0021	-B 1-FCV -074-0021	-B	RHR PUMP B-B INLET FLOW CONTROL VALVE	SB-2		676' A10 71C62-54114-1		A/B 1WK/100D C NA C NA C NA C NA		L RH/A CV/A AB AF	VLV MUST CLOSE DURING SWITCH-OVER FROM THE RWST TO THE CONTAINMENT SUMP

PREPARER/DATE DFC 5/20/86

CHECKED/DATE WBK 5/21/86

R 1 R 2 R

RHM 2/8/89 *RHM*

KBN 2/8/89 *KBN*

2/8/89 *2/8/89*

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R 3 R 4
BINDER TITLE LIMITORQUE COMPUTED /R1 RHM DATE 2/8/89 KBN CST
MOTORIZED VALVE OPERATORS WITH 12/12/89 7/10/90
TYPE RH INSULATED MOTOR CHECKED /R1 KBN DATE 2/8/89 DLK KBN
12/12/89 7/10/90

TAB A - EQUIPMENT IDENTIFICATION MATRIX

The following notes apply to all pages of this TAB A.

- 1) Elevations shown are actual elevations for equipment located in the Reactor Building and floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
- 2) See TAB B, Section A for a complete listing of the calculations used in this binder and their revision level.

The following notes are equipment specific.

- 3) Field verification for valve 1-FCV-74-3 shows an incorrect floor elevation. As constructed drawing 47W432-1 Rev. H shows the valve to be located in 1A-A RHR Pump Room and floor elevation 676'-0".
- 4) The category and operating time listed for this device is the most limiting, and is for the internal limit switch which is being used to monitor a PAM function. The safety function listed is for the MVOP. The PAM safety function is as follows: This limit switch performs a PAM type B function and must be monitored for the duration of each event.

R4

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 33
R 1 R 1
BINDER TITLE LIMITORQUE COMPUTED DFC DATE 9/22/86 2/8/89
MOTORIZED VALVE OPERATORS WITH
TYPE RH INSULATED MOTOR CHECKED WBK/HDR DATE 9/22/86 2/8/89

A. DOCUMENTATION

Equipment Description Motorized Valve Actuator with Type RH
insulation
Vendor/Manufacturer Limatorque
Equipment Model No.(s) See EOC TAB A

QUALIFICATION REPORTS (See EOC TAB D Table of Contents)

|R1

- (1) Title/Number/Revision Limatorque Valve RIMS NEB820421203
Actuator, Qualification for Nuclear Service
#B0058 and Appendix A DATE 1-11-80
- (2) Title/Number/Revision Limatorque Valve RIMS NEB820421203
Actuator, Actuators for PWR Service
#600456 DATE 12-9-75
- (3) Title/Number/Revision Limatorque Valve RIMS NEB820421203
Actuator, Temperature Related to High Rev. A
Superheat Ambient #B0027 DATE 10-18-78

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (4) Limatorque Valve Actuators with Type LR Motor for Westinghouse
PWR Report B0212 Dated 4/10/85.
- (5) Supplement report to NUC-9 Rev. 1, 4-14-80, Reliance Electric
Company Summary Report - Nuclear Power Plant Motor Systems
Type Test Support Analysis - Random Wound Motors.
- (6) Qualification Type Test Report of Multi-Point Terminal Strips,
for Use in Limatorque. Valve Actuators for PWR Service Dated
July 1, 1982. Report B0119.
- (7) Limatorque telex dated March 24, 1986.
- (8) WAC-49
- (9) Limatorque letter dated September 25, 1985 (B70 850925 012)
- (10) Limatorque letter dated September 5, 1985 (B70 850910 004)
- (11) Limatorque telex dated November 6, 1985 (B70 851107 021)
- (12) TVA telex dated November 6, 1985, (B70 851107 022)
- (13) WAC-67

|R1

|R1

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 1a OF 33
R 3 R 4
BINDER TITLE LIMITORQUE COMPUTED /R1 RHM DATE 2/8/89 KBN CSH
MOTORIZED VALVE OPERATORS WITH 12/12/89 7/10/90
TYPE RH INSULATED MOTOR CHECKED /R1 KBN DATE 2/8/89 DLK PBN
12/12/89 7/10/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (14) Category and Operating Times, System 62, WBNOSG4-013 R12
B26 900327 200
- (15) Category and Operating Times, System 63, WBNOSG4-014 R11
B26 900309 227
- (16) Category and Operating Times, System 67, WBNOSG4-016 R14
B26 900319 215
- (17) Category and Operating Times, System 68, WBNOSG4-017 R9
B26 890510 506
- (18) Category and Operating Times, System 70, WBNOSG4-018 R13
B26 900110 200
- (19) Category and Operating Times, System 74, WBNOSG4-020 R8
B26 900309 232
- (20) Environmental Drawing No. 47E235-41 R1
- (21) Environmental Drawing No. 47E235-42 R2
- (22) Environmental Drawing No. 47E235-61 R1
- (23) Environmental Drawing No. 47E235-74 R1
- (24) Environmental Drawing No. 47E235-77 R1
- (25) Calculation GENNAL3-001 R0 - 40 year Containment Dose
B45 851117 235
- (26) Calculation WBNNAL3-004 R0 - Accident Dose - Reactor Building
B45 860205 235
- (27) Calculation WBNNAL3-025 R0 - 40 year Dose-Outside Shield
Building B45 860401 235
- (28) Calculation WBNTSR-051, R0 - Reduction of Beta Dose by Sheet
Steel B26 891129 202
- (29) Environmental drawing number 47E235-59, R2, and
DCA-P-02351-18-0 in accordance with DCN P-02351-A
(B26 881210 801)

Note: Documents listed above are used throughout this binder for equipment qualifications. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 2 OF 33
R 1 R
BINDER TITLE LIMITORQUE COMPUTED DFC DATE 9/22/86 RNM
MOTORIZED VALVE OPERATORS WITH 2/8/89
TYPE RH INSULATED MOTOR CHECKED WBK/HDR DATE 9/22/86 LBN
2/8/89

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
☐ Equipment Qualification Not Established by Documentation
☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

- (1) Qualification Status of Actuators 1-MVOP-67-87-A, 1-MVOP-67-95-A,
1-MVOP-67-103-B, 1-MVOP-67-111-B, and 1-MVOP-70-89-B must be R1
established after replacement. See Open Item No. 1.
- (2) Deficient internal cable is to be replaced per ECN 6025. Complete
field verification must be resubmitted to the DNE binder preparer
upon resolution of Open Item No. 2. R1
- (3) Nylon crimp connectors on the field winding leads must be replaced
with acceptable nuclear grade connectors. Complete revised field
verification must be resubmitted to the DNE binder preparer upon
resolution of Open Item No. 3. R1
- (4) Heaters in the motor and limit switch compartments must be
decommissioned prior to unit start-up. Complete revised field
verification must be resubmitted to the DNE binder preparer upon
resolution of Open Item No. 4. R1
- (5) Black durez limit switch rotors must be replaced with qualified sub-
components. Complete revised field verification must be resubmitted
to the DNE binder preparer upon resolution of Open Item No. 5. R1
- (6) Verification of the manufacturer and model number of the terminal
blocks installed in the limit switch compartment must be determined
before qualification status of the terminal block can be established.
See Open Item No. 6. R1

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 2a OF 33
R R
BINDER TITLE LIMITORQUE COMPUTED /R/ RYM DATE 2-14-89
MOTORIZED VALVE OPERATORS WITH
TYPE RH INSULATED MOTOR CHECKED /R/ KEN DATE 2/16/89

B. CONCLUSION OF REVIEW (Check only one block)
(continued)

- ☒ X Equipment Qualified
☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
☐ Equipment Qualification Not Established by Documentation
☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES (continued)

- (7) Valve actuators must be fitted with T-drains in the low point of the
limit switch compartments. Revised field verification must be
submitted upon resolution of Open Item No. 7.
- (8) OMDS requires that Class H Reliance motors must have a T-drain
installed in the low point of the motor housing. Revised field
verification must be submitted upon resolution of Open Item No. 8.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 3 OF 33
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D. J. Cox DATE 5/21/86
OPERATORS WITH TYPE RH INSULATED MOTOR
CHECKED W. B. [signature] DATE 5/21/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- _____ Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS

The Limitorque Environmental Qualification Program was conducted per IEEE-382 (1972), "IEEE Guide for Type Test of Class 1E Electric Valve Operators for Nuclear Power Generating Stations" and meets the requirements of IEEE-323 (1974) as they apply to valve actuators (TR B0058, Section 2.1).

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET
IEEE 382-1972

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 4 OF 33
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D. J. Cox DATE 5/21/86 R R
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W. B. Smith DATE 5/21/86

D. QUALIFICATION METHODOLOGY (Check only one block)

 Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

 X Test of Similar Items with Supporting Analysis

 Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

 Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The Limitorque Qualification Program was
conducted to encompass the entire family of actuators - SMB, SB,
SBD, and SMB/HBC in all available unit sizes (SMB-000 to SMB-5).
This was accomplished by type testing. See EQC TAB C, Section 1.0.
EQC TAB E Attachment 1 identifies the actuator plant ID number, the
Limitorque shop order number, the actuator serial number, and the
documentation reference which establishes traceability to the appli-
cable test report.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 5 OF 33
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED WJL DATE 5/21/86 R R
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJL DATE 5/21/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Motor Operated Valve Actuator</u>	<u>Motor Operated Valve Actuator</u>	<u>600456, Sect. 2.0</u>
(2) Manufacturer	<u>Limitorque</u>	<u>Limitorque</u>	<u>600456, Sect. 2.0</u>
(3) Model Number(s)	<u>See EQC TAB A</u>	<u>SMB-0</u>	<u>Sect. 2.0</u>
	<u>See EQC TAB E Attachment 1</u>	<u>Actuator 189835</u>	<u>600456, Sect. 2.0</u>
(4) Serial Number(s)		<u>Motor 2Y267074A1EZ</u>	<u>600456, Sect. 2.0</u>
Order No.	<u>See EQC TAB E Attachment 1</u>	<u>Actuator 600456-A</u>	<u>600456, Sect. 2.0</u>
(5) Identify Component-Unique checksheet attached:	<u>None</u>		

JUSTIFICATION/COMMENTS The Limitorque qualification program was conducted to encompass the entire family of actuators - SMB, SB, SBD, and SMB/HBC in all available unit sizes (SMB-000 to SMB-5, Reference #B0058, Section 2.1). This was accomplished by conducting the testing on a mid-size unit SMB-0 with a Reliance motor, 60 HZ, 460 VAC, insulation Class RH, type-P motor, size 40 ft.-lb. stall, 8 ft.-lb. run (Reference #600456, Section 2.0). See EQC TAB C, Section 1.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 6 OF 33
 R 1 R 1
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RHM
MOTORIZED VALVE OPERATORS WITH 2-4-89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 TEH
2/16/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification. R1

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>See Comments</u>	<u>Yes</u>	<u>600456 Sect. 3.4.1</u>
Conduit Seals	<u>None</u>	<u>NA</u>	<u>NA</u>
Connector Seals	<u>None</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>NA</u>	<u>NA</u>	<u>NA</u>
Physical Configuration	<u>NA</u>	<u>NA</u>	<u>NA</u>
Other	<u>NA</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Control and power lead connections were made through flexible pressure tight conduit connections run between the unit tested and the access ports of the test chamber (reference #600456, Section 3.4.1); however, conduit seals and special connections are not required. See EOC TAB C, Section 2 for justification. There are no specific "installation interfaces" R1 for this equipment specified throughout the qualification program.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 7 OF 33
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED Q. J. Cag DATE 5/21/86 R R
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W. B. How DATE 5/21/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>See</u> <u>Comment</u> <u>600456,</u> <u>Tabl II&III, &</u> <u>App. B</u>
(b) Baseline performance measurements taken	<u>Yes</u>	
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>600456,</u> <u>Sect. 3.1.1</u>
Radiation	<u>Yes</u>	<u>600456,</u> <u>Sect. 3.1.3 & 3.3</u>
Wear	<u>Yes</u>	<u>600456, Sect.</u> <u>3.1.2</u>
(d) Vibration/seismic testing conducted	<u>Yes</u> <u>Seismic</u>	<u>B0058, Sect.</u> <u>2.1; 600456,</u> <u>Sect. 3.2</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>600456, Sect. 4.4.1,</u> <u>4.4.5, Tabl III</u> <u>Fig 6</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>600456, Sect. 4.4.1,</u> <u>4.4.5, Tabl III</u> <u>Fig 6</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>600456, Sect. 3.7,</u> <u>4.5, & 4.7</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes, 600456 Sect. 4.7.1; see TAB C, Section 4 for details.
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes
(Reference #600456, App. F, Tabl I).

JUSTIFICATION/COMMENTS Low level vibration is addressed in the
EQC TAB C, Section 3. See EQC TAB C, Section 5.0 for discussion of
test sequence with respect to radiation exposure. Preinspection is
not a requirement of IEEE 323-1974; however, the equipment was manu-
factured per Limitorque standard nuclear B/M and no damage or
deficiencies were noted per 600456, Section 2.

PAGE B-7

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 8 OF 33
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D. J. Cox DATE 5/21/86 R R
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W. J. Cox DATE 5/21/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference B0058, Section 3.0 and 600456, Section 3.1).

JUSTIFICATION/COMMENTS None

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>B0058, Sect. 3.2</u> <u>600456, Sect. 3.1.1</u>
Radiation exposure	<u>Yes</u>	<u>600456, Sect. 3.1.3</u> <u>B0058, Sect. 3.4</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>B0058, Sect. 2.1</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>600456, Sect. 3.1.2</u> <u>B0058, Sect. 3.3</u>

JUSTIFICATION/COMMENTS None

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS No known synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
(yes/no/NA)? Yes (Reference 600456, Sect. 3.1.1; B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS Thermal aging was conducted on

Reliance motor stator. See EQC TAB C, Section 4.0 for full details.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 9 OF 33
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D. J. Cox DATE 5/21/86 R R
 OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W. B. H. DATE 5/21/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS All organic materials subject to thermal aging degradation.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS See EQC TAB C, Section 4.0 for full details.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference 600456, Sect. 3.1.1; B0058, Sect. 3.2).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>120°F</u>	<u>180°C</u>	<u>130°F</u>
Time	<u>40 Years</u>	<u>100 Hr</u>	<u>40 Yrs</u>

JUSTIFICATION/COMMENTS Motor stator thermal aging conducted; analysis conducted on other organic materials. See EQC TAB C, Section 4.0.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS Thermal regression curve used for motor stator; analysis used for other materials. See EQC TAB C, Section 4.0.

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS See EQC TAB C, Section 4.0.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 10 OF 33
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D4 Cop DATE 5/21/86 R R
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH DATE 5/21/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference B0058, Sect. 3.2.1.2).

JUSTIFICATION/COMMENTS Thermal regression curve used for
motor stator. See EQC TAB C, Section 4.0.

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference NA).

JUSTIFICATION/COMMENTS Operation of equipment during thermal
aging is not required.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference 600456, Sect. 3.1.3).
B0058, Sect. 3.4

JUSTIFICATION/COMMENTS None

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes
(Reference B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS A specific listing of materials subject
to radiation degradation was not provided; however, organic
materials, as stated in Section 3.2 of B0058, would be subject
to radiation degradation. During the radiation exposure for
the test, the whole actuator was radiation aged.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes
(Reference 600456, Sect. 3.1.3 & 3.3, and B0058, Sect. 3.4).

JUSTIFICATION/COMMENTS Aging dose was combined with the
accident dose. 4 Mrd was applied for normal dose; 200 Mrd
was applied for accident dose.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 11 OF 33
 R 1 R 1
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RJM
MOTORIZED VALVE OPERATORS WITH 2/8/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 RJM
2/8/89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: 600456, Section 3.1.3, 3.3, and Appendix C).

Plant normal ambient radiation dose (rd) 20E06

Test exposure dose (rd) 204E06

Test exposure dose rate (rd/hr) 1.0E06

Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS Test dose included normal aging plus accident dose.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* Yes (Reference: B0058, Section 2.1).

JUSTIFICATION/COMMENTS Non-seismic vibration is not addressed in the Limitorque Test Program. See EOC TAB C, Section 3.0.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? No (Reference: B0058, Section 2.1).

JUSTIFICATION/COMMENTS See EOC TAB C, Section 3.0 for justification of omission of non-seismic vibration aging.

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 12 OF 33
BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 R 1 R 2/18/89
MOTORIZED VALVE OPERATORS WITH
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 R 2/18/89

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: 600456, Section 3.1.2,

Appendix B).

JUSTIFICATION/COMMENTS The actuator was cycled (mechanical aging) 1208 times; seating thrust was monitored.

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: 600456, Section 3.1.2, Appendix B).

JUSTIFICATION/COMMENTS The actuator was cycled (mechanical aging) 1208 times; seating thrust was monitored.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes (Reference: B0058, Section 3.2).

Qualified life (Document in QMDS) 40 Years

JUSTIFICATION/COMMENTS See EOC TAB C, Section 4.0 for full details on qualified life and aging.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 12a OF 33
R R
BINDER TITLE LIMITORQUE COMPUTED /R1 R2M DATE 2/8/89
MOTORIZED VALVE OPERATORS WITH
TYPE RH INSULATED MOTOR CHECKED /21 YAN DATE 2/8/89

H. AGING (Continued)

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: B0058, Section 5.0 and 7.0

_____).

| R1

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 13 OF 33
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DJ Cap DATE 5/21/86 R R
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH/ind DATE 5/2/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Melamine (white)</u>	<u>2.04x10⁸</u> <u>Rads</u>	<u>600456</u> <u>Sect. 3.1.3</u>	<u>1.35</u>	<u>See</u> <u>Comments</u>
(b) <u>Fiberite (brown)</u>	<u>2.09x10⁸</u> <u>Rads</u>	<u>B0212</u> <u>Sect. 6.7</u>	<u>1.78</u>	<u>See</u> <u>Comments</u>
(c) <u>G.P. Phenolic (black)</u>	<u>2.09x10⁸</u> <u>Rads</u>	<u>B0212</u> <u>Sect. 6.7</u>	<u>1.63</u>	<u>See</u> <u>Comments</u>
(d) <u>Motor Insulation-RH</u>	<u>2.04x10⁸</u> <u>Rads</u>	<u>600456</u> <u>Sect. 3.1.3</u>	<u>1.02</u>	<u>See</u> <u>Comments</u>
(e) <u>Wiring Insulation</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>TAB C</u> <u>Sect. 4.4</u>

JUSTIFICATION/COMMENTS Radiation threshold does not apply. Limitorque
has done radiation exposure per the referenced Limitorque test reports.
The values listed in threshold column represent the testing parameters.
Activation energies are documented in TABS "D" and "E" as follows:

- (a) Melamine - Output display from aging data calculation (WAC-49)
(TAB "E").
- (b) Fiberite - Limitorque test report B0212, Sect. 6.2 (TAB "D").
- (c) G. P. Phenolic - Limitorque letter dated 9/5/85 (B70 850910 004)
(TAB "E").
- (d) Motor Insulation - RH (WAC-49) (TAB "E").

See TAB C, Section 4.1 for material analysis of phenolics and Section 4.2
for analysis of motor insulation.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 14 OF 33
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED AT Cap DATE 5/21/86 R R
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W/B/ DATE 5/21/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference B0058, Sect. 4.1.8).

Identify Acceptance Criteria: The actuator must be capable of opening or closing a valve on demand.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Report 600456, Sect. 4.6).
and Appendix B

Identify baseline and functional testing: Motor potential, run current, power, stroke time, peak current, and seating thrust were measured prior to the start of the test and are summarized in Table III of Report 600456. Insulation resistance to ground is tabulated in Table II. See TAB C, Section 9 for summary.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes
(Reference See Comment).

JUSTIFICATION/COMMENTS Load cycling during the test is tabulated in Table III of the test report.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 15 OF 33
 R 1 R 1
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RJM
MOTORIZED VALVE OPERATORS WITH 2/8/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 WBM
2/8/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS.
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: 600456 Section 3.1.2).

JUSTIFICATION/COMMENTS Thrust measurements correspond to
the thrust rating for the actuator. In addition, Appendix B
of the test report shows baseline, mechanical aging, and
post-test thrust measurements.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>490 VAC</u>	<u>600456</u> <u>Table III</u>
Load	<u>Approx 20,000 lbs thrust</u>	<u>600456</u> <u>Table III</u>
Frequency	<u>See Comment</u>	
Accuracy	<u>NA</u>	
Other(s)		
<u>NA</u>		
<u>NA</u>		

R1

JUSTIFICATION/COMMENTS Although not specifically
stated, we have no reason to believe that Limitorque
used anything other than a 60 Hz power source.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 16 OF 33
 R 1 R 1
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RJM
MOTORIZED VALVE OPERATORS WITH 2-1489
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 KJA
2/6/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS.
 (Continued)

(b) Parameter	Specific Accident Conditions	Reference	R1
Voltage	See TAB C, Section 6	NA	
Load	See Comment	NA	
Frequency	60 Hz	See comments below	
Accuracy	NA		
Other(s)			
NA			

JUSTIFICATION/COMMENTS Load required will be thrust necessary
to stroke the valve. Frequency variations would only occur
during the loading of the diesel generators. Since Unit 2 is
not operational, the diesels cannot be overloaded to the point
of causing frequency variations. This is based on maximum
loading occurring during a LOCA on Unit 1 with a full load
rejection on Unit 2.

(c) Parameter	Demonstrated Conditions	Reference	R1
Voltage	475VAC	600456 Table III	
Load	Approx. 20,000 lbs thrust	600456 Table III	
Frequency	See Comment	See Comment	
Accuracy	NA	NA	
Other(s)			

JUSTIFICATION/COMMENTS Justification for lack of reduced
voltages starting tests under accident conditions is presented
in EOC TAB C, Section 6.0. Although not specifically stated,
we have no reason to believe that Limitorque used anything
other than a 60 Hz power source.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 17 OF 33
 R 1 R 1
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RAM
MOTORIZED VALVE OPERATORS WITH 2/18/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 2/21/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. See pp. 17A-E

(1) Normal Max

(2) Abnormal Max

- | | |
|---------------------------------------|---------------------------------------|
| (a) Temperature (°F) <u>See Above</u> | (a) Temperature (°F) <u>See Above</u> |
| (b) Pressure (psig) <u>See Above</u> | (b) Pressure (psig) <u>See Above</u> |
| (c) Humidity (%) <u>See Above</u> | (c) Humidity (%) <u>See Above</u> |
| (d) Radiation (rd) <u>See Above</u> | (d) Radiation (rd) <u>See Above</u> |

- (3) Process Interfaces: Valve body and stem connection configuration eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

- (4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal temperatures could occur as a result of outside temperature excursions, temporarily greater than design heat loads, or degraded environment control system. This could exist for up to 8 hours per excursion and will occur less than 1% of the plant life. See TAB C, Sect. 4.0.

- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- | | | | |
|---|----------|--------------------------------|--|
| (a) Temperature (°F) <u>327</u> | MSLB-See | Accident type <u>EQC TAB A</u> | |
| (b) Pressure (psig) <u>12</u> | LOCA-See | Accident type <u>EQC TAB A</u> | |
| (c) Humidity (%) <u>100</u> | LOCA-See | Accident type <u>EQC TAB A</u> | |
| (d) Radiation (rd) <u>4.7x10⁸(beta)*</u> | LOCA-See | Accident type <u>EQC TAB A</u> | |
| <u>4x10⁷(gamma)</u> | | | |
| <u>8.35pH, 0.18M</u> | | | |
| <u>H₃BO₃ 2000PPM</u> | | | |
| <u>boron 0.033M</u> | | | |
| <u>NaOH</u> | | | |
| (e) Spray Type <u>Duration 30d</u> | LOCA-See | Accident type <u>EQC TAB A</u> | |

* The effect of beta radiation was considered, see TAB C
 Section 10.0

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 17a OF 33
 R 1 R 1
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 9/12/86 RJW
MOTORIZED VALVE OPERATORS WITH 2/8/89
TYPE RH INSULATED MOTOR CHECKED WBK/HDR DATE 9/12/86 KBN
2/8/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-41 | R1

(1) Normal Max

(a) Temperature (°F) 110

(b) Pressure (psig) 0.3

(c) Humidity (%) 80

(d) Radiation (rd) 1.0×10^6

(2) Abnormal Max

(a) Temperature (°F) 120

(b) Pressure (psig) 0.3

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: Valve body and stem connection configuration eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 160 Accident type LOCA

(b) Pressure (psig) 12.0 Accident type LOCA

(c) Humidity (%) 100 Accident type LOCA

(d) Radiation (rd) 4.7×10^8 (beta) Accident type LOCA

(e) Spray Type See Sheet 17 Accident type LOCA

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 17b OF 33
R 1 R 1
BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RBM
MOTORIZED VALVE OPERATORS WITH 2/8/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 WBN
2/8/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-42 | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>120</u>	(a) Temperature (°F) <u>130</u>
(b) Pressure (psig) <u>0.3</u>	(b) Pressure (psig) <u>0.3</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>100</u>
(d) Radiation (rd) <u>8×10^7</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: Valve body and stem connection configuration eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>327</u>	Accident type <u>MSLB</u>
(b) Pressure (psig) <u>12.0</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>100</u>	Accident type <u>LOCA</u>
(d) Radiation (rd) <u>4.7×10^8 (beta)</u>	Accident type <u>LOCA</u> R1
(e) Spray Type <u>See Sheet 17</u>	Accident type <u>LOCA</u>

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 17c OF 33
BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 R BHM 1 R 4
MOTORIZED VALVE OPERATORS WITH 2/8/89 7/10/90
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 KBN KBN
2/8/89 7/10/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-61

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>ATM(-)</u>	(b) Pressure (psig) <u>ATM(-)</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>7.5×10^6</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: Valve body and stem connection configuration eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>210</u>	Accident type <u>HELB</u> R4
(b) Pressure (psig) <u>ATM</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>NA</u>	Accident type <u>LOCA</u>
(d) Radiation (rd) <u>5×10^6</u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u></u>

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 17d OF 33
 R 1 R 1
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RDM
MOTORIZED VALVE OPERATORS WITH 218/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 KIN
218/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-74 | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104

(a) Temperature (°F) 110

(b) Pressure (psig) ATM(-)

(b) Pressure (psig) ATM(-)

(c) Humidity (%) 80

(c) Humidity (%) 90

(d) Radiation (rd) 4.3×10^5

(d) Radiation (rd) LOCA

(3) Process Interfaces: Valve body and stem connection configuration eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 110

Accident type LOCA

(b) Pressure (psig) NA

Accident type LOCA

(c) Humidity (%) NA

Accident type LOCA

(d) Radiation (rd) 1×10^7

Accident type LOCA

(e) Spray Type NA

Accident type LOCA

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 17e OF 33
 R 1 R 1
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 9/12/86 RTH
MOTORIZED VALVE OPERATORS WITH 2/18/89
TYPE RH INSULATED MOTOR CHECKED WBK/HDR DATE 9/12/86 KJN
2/18/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-77 | R1

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) ATM

(c) Humidity (%) 80

(d) Radiation (rd) 1.8x10⁶

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) ATM

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: Valve body and stem connection configuration eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 190 Accident type LOCA

(b) Pressure (psig) ATM Accident type LOCA

(c) Humidity (%) 90 Accident type LOCA

(d) Radiation (rd) 1x10⁷ Accident type LOCA

(e) Spray Type NA Accident type LOCA

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 33
R 1 R _____
BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RHM
MOTORIZED VALVE OPERATORS WITH 218189
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 KBN
218189

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): See EOC TAB C, Item 11.0 for discussion

R1

on chemical spray

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: _____)

See EOC TAB C, Item 2).

- (7) Subject to submergence (Yes/No/NA)? Yes (Reference: _____)

EOC TAB C, Item 13.0).

R1

Identify initiation time and duration of submergence: _____

See discussion on submergence in EOC TAB C, Item 13.0. Sub-

R1

mergence is not a qualification concern based on assessment.

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: EOC TAB C, Item 10).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

4.69×10^7 beta see discussion on beta radiation in TAB C,

R1

Item 10.0

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B Section A.

items 25, 26 and 27

R1

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 19 OF 33
 R 1 R
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 PM
MOTORIZED VALVE OPERATORS WITH 2/8/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 PM
46/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>	
Operating Time	<u>100d</u>	<u>30d</u>	600456, Sect. 4.4.1, Fig 6	
Temperature (°F)	<u>327</u>	<u>315</u>	600456, Sect. 4.4.1, Fig 6	
Pressure (psig)	<u>12.0</u>	<u>78</u>	600456, Sect. 4.4.1, Fig 7	
Relative Humidity (%)	<u>100</u>	<u>100</u>	600456 Sect. 4.4.3	
	8.2pH; 0.18M H ₃ BO ₃			
	30d; 2000PPM Boron	TAB C	600456	
Chemical Spray*	<u>0.033M NaOH</u>	<u>Item 11.0</u>	Sect. 4.4.2	R1
			600456	
Radiation (rd)**	<u>120E06</u>	<u>204E06</u>	Sect. 3.3	
	TAB C,			
Submergence	<u>Item 13.0</u>	<u>None</u>	<u>NA</u>	R1

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

***See K(8) for discussion on Beta Radiation.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>	
Temperature	<u>No</u>	600456 Fig 6	
Pressure	<u>Yes</u>	600456 Fig 5.6.7	
Relative Humidity	<u>Yes</u>	600456 Sect. 4.4.3	
Chemical Spray	<u>Yes</u>	600456 Sect. 4.4.2	
Submergence	<u>No</u>	TAB C, Item 13.0	R1

JUSTIFICATION/COMMENTS EOC TAB C. Section 7.0 presents justification for comparison of required V.S. test profile for time and temperature. See TAB C. Item 12.0. for enveloping test profile breakdown.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 20 OF 33
 R 1 R
 BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RBM
MOTORIZED VALVE OPERATORS WITH 2/8/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 LBN
2/8/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

See TAB C. Item 13.0. for discussion on submergence. With R1
respect to beta radiation, the metallic mass of the operator
eliminates the concern for beta radiaion.

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>None</u>	<u>No</u>
Pressure: +10% but no more than 10 psig	<u>10%</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>10%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>+10%</u>	<u>Yes</u>
Voltage: ±10% of rated value	<u>See Comment</u>	<u>No</u>
Frequency: ±5% of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>2 DWELLS</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS #600456. Section 3.0 states that the
test actuator was subjected to additional load cycling after
environmental tests and prior to final inspection as an added
test margin. EOC TAB C. Section 7.0 presents justification
for margin with respect to test temperature and time. See
EOC TAB C. Section 6.0 for justification for lack of reduced
voltage testing.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 21 OF 33
R 1 R _____
BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RAM
MOTORIZED VALVE OPERATORS WITH 2/8/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 LGW
o 2/8/89

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference: B0058, Section 2.4

_____.
JUSTIFICATION/COMMENTS The basic function of a valve
actuator is to provide the required torque and/or thrust
to open or close the valve as required.

- (2) Did the equipment perform its intended function during the
simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: 600456, Section 4.4.5 and 5.0

_____.
JUSTIFICATION/COMMENTS The test unit functioned adequately
throughout the entire test.

- (3) Did the equipment perform its intended function during the
simulated post-design basis accident exposure
(Yes/No/NA)? Yes (Reference: 600456, Section 4.4.5 and
5.0

_____.
JUSTIFICATION/COMMENTS The test unit functioned adequately
throughout the entire test.

- (4) Did the test demonstrate the operability requirements for the
required time interval for which the equipment is required to
operate (Yes/No/NA)? No (Reference: _____
600456, Figure 6

_____.
JUSTIFICATION/COMMENTS See EOC TAB C, Section 7.0 for
justification of actuator operability post-accident.

R1

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 21a OF 33
R 1 R _____
BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RAN
MOTORIZED VALVE OPERATORS WITH 2/8/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 KAN
2/8/89

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: 600456, Section 4.4.5 and 4.6)

JUSTIFICATION/COMMENTS Minor problems were experienced
during and after the LOCA test; however, these had no
effect on actuator performance. See referenced sections of
Limitorque report 600456.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 22 OF 33
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D. J. Cox DATE 5/21/86 R R
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W. J. H. H. DATE 5/21/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See EQC TAB G.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 23 OF 33
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DF Cap DATE 5/21/86 R R
 OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WBP DATE 5/4/86

O. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>NA</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>NA</u>
(b) Were specific features and failure modes and effects analyzed?	<u>NA</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>NA</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes*</u>
(c) Absence of preaging in test/analysis justified?	<u>Yes</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

*Only the motor was pre-aged prior to application of DBE conditions. See
TAB C for aging of switch materials.

BINDER NO. WBNEQ-MOV-001 PLANT WBN UNIT(S) 1 SHEET 25 OF 33
R 1 R 1
BINDER TITLE LIMITORQUE COMPUTED DFC DATE 5/21/86 RSM
MOTORIZED VALVE OPERATORS WITH 218/89
TYPE RH INSULATED MOTOR CHECKED WBK DATE 5/21/86 KBN
218/89

O. SUMMARY OF REVIEW (Continued)

- Yes/No/NA
- (15) Criteria regarding functional testing satisfied? Yes
- (a) Does the test plan/report specify an acceptance criteria for equipment performed? Yes
- (b) Was an initial base line test done to establish required performance characteristics? Yes
- (c) Has the test analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? Yes
- (16) Criteria regarding instrument accuracy satisfied? NA
- (17) Test duration margin (1 hour + function time) satisfied? Yes
- (a) Is the minimum specified operating time at least 1 hour? Yes
- (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? NA
- (18) Criteria regarding synergistic effects satisfied? Yes
- (19) Criteria regarding margins satisfied? Yes
- (20) Maintenance and surveillance requirements adequately identified? Yes

P. DISCUSSION

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R 4 R 5
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED | R1 RHM DATE 2/8/89 KBN 12/12/89 7/18/90
OUTSIDE CONTAINMENT WITH CLASS B CHECKED | R1 KBN DATE 2/16/89 DLK EGM
MOTORS 12/12/89 7/18/90

TAB A - EQUIPMENT IDENTIFICATION MATRIX

The following notes apply to all pages of this TAB A.

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See TAB B, Section A for a complete listing of the calculations used in this binder and their revision level.

The following notes are equipment specific.

3. Power is to be removed from 1-FCV-62-98 and 1-FCV-62-99 motors by ECN 6701. After the ECN and field verification is complete, the binder must be revised to reflect the motors as Cat. C and the actuators as Cat. B.
4. The category and operating time listed for this device is the most limiting, and is for the internal limit switch which is being used to monitor a PAM function. The safety function listed is for the MVOP. The PAM safety function is as follows: This limit switch performs a PAM type B function and must be monitored for the duration of each event.

R5

PAGE A-1 R5

PRINT DATE: 01/20/89

BINDER NO. : WBNEQ-MOV -003
MANUFACTURER : LIMITORQUE
PAGE 1 OF 17

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZMIH ELEV(1) RM/RAD CONTRACT	CAI OPER TIME EVENT SAFETY FUNCTION (2)
WBH-1-MVOP-026-0241 ANN STANDPIPE ISLN VALVE	-B 1-FCV -026-0241 SB-00	713° A28 77K51-822598-6	A/B 5MN/100D L VLV MUST CLOSE ON A PHASE A CONTAINMENT ISOL SIGNAL
WBN-1-MVOP-026-0242 ANN STANDPIPE ISLN VALVE	-A 1-FCV -026-0242 SB-00	713° A28 77K51-822598-6	A/B 5MN/100D L VLV MUST CLOSE ON A PHASE A CONTAINMENT ISOL SIGNAL
WBN-1-MVOP-026-0243 REACTOR COOLANT PUMP SPRAY ISLN VALVE	-A 1-FCV -026-0243 SB-00	713° A28 77K51-822598-6	A/B 5MN/100D L VLV MUST CLOSE ON A PHASE A CONTAINMENT ISOL SIGNAL
WBN-1-MVOP-026-0244 ANN SPRINKLER SYS ISLN VALVE	-B 1-FCV -026-0244 SB-00	713° A28 77K51-822598-6	A/B 5MN/100D L VLV MUST CLOSE ON A PHASE A CONTAINMENT ISOL SIGNAL
WBN-1-MVOP-026-0245 ANN SPRINKLER SYS ISLN VALVE CONT	-A 1-FCV -026-0245 SB-00	713° A28 77K51-822598-6	A/B 5MN/100D L VLV MUST CLOSE ON A PHASE A CONTAINMENT ISOL SIGNAL

PREPARER/DATE JWH 9/9/86
CHECKED/DATE NMB 9/12/86

R 1 R R
RDM
2/8/89
RDM
4/10/89

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-MOV -003
MANUFACTURER : LIMITORQUE
PAGE 2 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-MVOP-062-0063 -A SEAL FLOW RETURN ISLN VALVE	1-FCV -062-0063 -A SB-00		713'	A28	A	100D	L	VLV IS REQUIRED TO CLOSE AND REMAIN CLOSED AFTER THE PHASE A ISOLATION SIGNAL IS RECEIVED AND RESET. SEE NOTE 4.
			71C62-54114-1		A	1MO	RH/A	
					A	1MO	CV/A	
					A	1MO	AF	
					A	1MO	AB	
WBN-1-MVOP-062-0090 -A CHARGING FLOW ISLN VALVE	1-FCV -062-0090 -A SMB-00		713'	A28	A/B	5MN/100D	L	FOR LENGTHY DISCUSSION OF SAFETY FUNCTION SEE CAT & OP TIMES CALCULATION WBNOSG4-013. SEE TAB B FOR REVISION LEVEL.
			71C62-54114-1		A/B	5D/1MO	RH/A	
					A/B	15MN/1MO	CV/A	
					A/B	5D/1MO	AB	
					A	1MO	AF	
WBN-1-MVOP-062-0091 -B CHARGING FLOW ISLN VALVE	1-FCV -062-0091 -B SMB-00		713'	A28	A/B	5MN/100D	L	FOR LENGTHY DISCUSSION OF SAFETY FUNCTION SEE CAT & OP TIMES CALCULATION WBNOSG4-013. SEE TAB B FOR REVISION LEVEL.
			71C62-54114-1		A/B	5D/1MO	RH/A	
					A/B	15MN/1MO	CV/A	
					A/B	5D/1MO	AB	
					A	1MO	AF	
WBN-1-MVOP-062-0098 -A CHARGING PUMP 1A-A MIN FLOW	1-FCV -062-0098 -A SMB-00		713'	A28	B	100D	L	FOR LENGTHY DISCUSSION OF SAFETY FUNCTION SEE CAT & OP TIMES CALCULATION WBNOSG4-013. SEE TAB B FOR REVISION LEVEL.
			71C62-54114-1		B	1MO	RH/A	
					B	1MO	CV/A	
					B	1MO	AB	
					B	1MO	AF	
WBN-1-MVOP-062-0099 -B CHARGING PUMP 1A-A MIN FLOW	1-FCV -062-0099 -B SMB-00		713'	A28	B	100D	L	FOR LENGTHY DISCUSSION OF SAFETY FUNCTION SEE CAT & OP TIMES CALCULATION WBNOSG4-013. SEE TAB B FOR REVISION LEVEL.
			71C62-54114-1		B	1MO	RH/A	
					B	1MO	CV/A	
					B	1MO	AB	
					B	1MO	AF	

RS

PAGE A-3 RS

PREPARER/DATE JWH 9/9/86
CHECKED/DATE NMB 9/12/86
R 5 R R
KEN 7/14/90
EEM 7/18/90

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-MOV -003
MANUFACTURER : LIMITORQUE
PAGE 3 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-MVOP-062-0132 -A 1-LCV -062-0132 -A VCT OUTLET ISOLATION VALVE LEVEL CONTROL SB-00			713'	A07'	A	100D	L	FOR LENGTHY DISCUSSION OF
			71C62-54114-1		A	1MO	RH/A	SAFETY FUNCTION SEE CAT & OP
					A	1MO	CV/A	TIMES CALCULATION WBNOSG4-013.
					A	1MO	AB	SEE TAB B FOR REVISION LEVEL.
					A	1MO	AF	SEE NOTE 4.
WBN-1-MVOP-062-0133 -B 1-LCV -062-0133 -B VCT OUTLET ISOLATION VALVE LEVEL CONTROL SB-00			713'	A07'	A	100D	L	FOR LENGTHY DISCUSSION OF
			71C62-54114-1		A	1MO	RH/A	SAFETY FUNCTION SEE CAT & OP
					A	1MO	CV/A	TIMES CALCULATION WBNOSG4-013.
					A	1MO	AB	SEE TAB B FOR REVISION LEVEL.
					A	1MO	AF	SEE NOTE 4.
WBN-1-MVOP-063-0001 -A 1-FCV -063-0001 -A RWST TO RHR PUMP FLOW CONTROL VALVE SB-2			692'	A08	A/B	1WK/100D	L	FOR L.VLV MUST OPEN AND
			71C62-54114-1		A/B	1WK/1MO	RH/A	REMAIN OPEN TO PERMIT
								SAFETY INJECTION. FOR RH/A
								VLV MUST CLOSE AND REMAIN
								CLOSED TO PREVENT RWST DRN
WBN-1-MVOP-063-0003 -A 1-FCV -063-0003 -A SIS PUMP RECIRC TO RWST VALVE SMB-00			692'	A08	A/B	1WK/100D	L	VALVE MUST CLOSE WHEN GOING
			71C62-54114-1					FRM INJ PHASE TO RECIRC AND
								MUST STAY CLOSED DURING
								RECIRC.
WBN-1-MVOP-063-0004 -B 1-FCV -063-0004 -B SIS PUMP 1A-A DISCH TO RWST SHUTOFF VLV SMB-00			692'	A13	A/B	1WK/100D	L	VLV MUST BE CLOSED BEFORE
			71C62-54114-1					ALIGNING THE SIS FOR RECIR
								VLV MUST REMAIN CLOSED TO
								PREVENT FLOW FROM SUMP
								INTO THE RWST

R5

PAGE A-4 R5

PREPARER/DATE JWH 9/9/86
CHECKED/DATE NMB 9/12/86
R S R R
R5 7/6/90
EEM 7/18/90

PRINT DATE: 01/20/89

BINDER NO. : WBNEQ-MOV -003
MANUFACTURER : LIMITORQUE
PAGE 4 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	LOCATION	ELEV(1)	RH/BAD	CAT OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION	MODEL NUMBER				(2)		
WBN-1-MVOP-063-0005 RWST TO SIS PUMP FLOW CONTROL VALVE	-B 1-FCV -063-0005 SB-00	692"	A08		A/B 1WK/1000	L	VLV MUST CLOSE WHEN GOING FROM INJECTION PHASE TO RECIRC AND MUST STAY CLOSED DURING RECIRC TO PREVENT FLOW FROM SUMP INTO THE RWST
WBN-1-MVOP-063-0006 SIS PUMP INLET TO CVCS CHG PUMP VALVE	-B 1-FCV -063-0006 SB-00	692"	A08		A/B 1WK/1000	L	VLV IS NORMALLY CLOSED AND MUST BE OPERABLE TO PROVIDE SUPPLY FROM RHR TO SIS DURING ECCS RECIRC.
WBN-1-MVOP-063-0007 SIS PUMP INLET TO CVCS CHG PUMP VALVE	-A 1-FCV -063-0007 SB-00	692"	A08		A/B 1WK/1000	L	VLV IS NORMALLY CLOSED AND MUST BE OPERABLE TO PROVIDE SUPPLY FROM RHR TO SIS DURING ECCS RECIRC.
WBN-1-MVOP-063-0008 RHR HXA TO CVCS CHG PUMP	-A 1-FCV -063-0008 SB-00	713"	A28		A/B 1WK/1000	L B 1MO RH/A	L: OPEN & REMAIN OPEN DURING RECIRC TO ALLOW SUCTION FOR SI & CC PMP. RH/A: REMAIN CLOSED TO PREVENT DRAINING RWST
WBN-1-MVOP-063-0011 RHR HTX B TO SIS PUMP	-B 1-FCV -063-0011 SB-00	713"	A28		A/B 1WK/1000	L B 1MO RH/A	L: OPEN & REMAIN OPEN DURING RECIRC TO ALLOW SUCTION FOR SI & CC PMP. RH/A: REMAIN CLOSED TO PREVENT DRAINING RWST.

PREPARER/DATE	JWH	9/9/86	R 1	R	R
CHECKED/DATE	NMB	9/12/86	Rdm		
			2/8/89		
			1/8/89		
			2/11/89		

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-MOV -003
MANUFACTURER : LIMITORQUE
PAGE 5 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u>	<u>UNIT DEVICE ID NO.</u>	<u>AZMITH</u>	<u>LOCATION</u>	<u>ELEV(1)</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
<u>DESCRIPTION</u>	<u>MODEL NUMBER</u>			<u>CONTRACT</u>		<u>(2)</u>			
WBN-1-MVOP-063-0022 -B SIS PMP COLD LEG INJECTION	1-FCV -063-0022 -B SBD-00		713'	A28		A	100D	L	VLV MUST SWITCH FROM COLD
			71C62-54114-1			A	1MO	RH/A	LEG TO HOT LEG RECIRC.
						A	1MO	CV/A	SEE NOTE 4.
						A	1MO	AF	
						A	1MO	AB	
WBN-1-MVOP-063-0025 -B SIS BORON INJECTION TANK SHUTOFF VALVE	1-FCV -063-0025 -B SBD-00		713'	A28		A	100D	L	FOR L:VLV MUST OPEN AND REMAIN
			71C62-54114-1			A	1MO	RH/A	OPEN AFTER AN SI SIGNAL.FOR
						A	1MO	CV/A	OTHERS: VLV MUST REMAIN CLOSED
						A	1MO	AB	TO MAINTAIN RCP SEAL INJ PATH
						A	1MO	AF	SEE NOTE 4.
WBN-1-MVOP-063-0026 -A SIS BORON INJECTION TANK SHUTOFF VALVE	1-FCV -063-0026 -A SBD-00		713'	A28		A	100D	L	FOR L:VLV MUST OPEN AND REMAIN
			71C62-54114-1			A	1MO	RH/A	OPEN AFTER AN SI SIGNAL.FOR
						A	1MO	CV/A	OTHERS: VLV MUST REMAIN CLOSED
						A	1MO	AB	TO MAINTAIN RCP SEAL INJ PATH
						A	1MO	AF	SEE NOTE 4.
WBN-1-MVOP-063-0047 -A SIS PMP 1A-A INLET VALVE	1-FCV -063-0047 -A SB-00		692'	A13		A	100D	L	VLV MUST REMAIN OPEN
			71C62-54114-1						DURING BOTH INJ AND RECIRC
									PHASE OF SI ,AND REMAIN
									OPERABLE TO ISOLATE
									PASSIVE FAILURE
WBN-1-MVOP-063-0048 -B SIS PMP 1B-B INLET VALVE	1-FCV -063-0048 -B SB-00		692'	A12		A	100D	L	VLV MUST REMAIN OPEN DURING
			71C62-54114-1						BOTH INJ AND RECIRC PHASE OF
									SI, AND REMAIN OPERABLE TO
									ISOLATE PASSIVE FAILURES.

R5

PAGE A-6 R5

PREPARER/DATE JWH 9/9/86 R 5 R
CHECKED/DATE NMB 9/12/86 R 11/1/90 R
R 11/1/90 R

11

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-MOV -003
MANUFACTURER : LIMITORQUE
PAGE 6 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMIH	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-MVOP-063-0093 RHR TO RCS 2 AND 3 FLOW CONTROL VALVE	-A 1-FCV -063-0093 SBD-2	-A	713'	A28 71C62-54114-1	A	100D	L	VLV IS REQUIRED TO OPERATE TO TRANSFER FROM COLD LEG TO HOT LEG RECIRC. SEE NOTE 4.
					A	1MO	RH/A	
					A	1MO	CV/A	
					A	1MO	AF	
					A	1MO	AB	
WBN-1-MVOP-063-0094 RHR TO RCS 1 AND 4 FLOW CONTROL VALVE	-B 1-FCV -063-0094 SBD-2	-B	713'	A28 71C62-54114-1	A	100D	L	VLV IS REQUIRED TO OPERATE TO TRANSFER FROM COLD LEG TO HOT LEG RECIRC SEE NOTE 4.
					A	1MO	RH/A	
					A	1MO	CV/A	
					A	1MO	AF	
					A	1MO	AB	
WBN-1-MVOP-063-0152 SIS PUMP 1A-A OUTFLOW CONT VALVE	-A 1-FCV -063-0152 SB-00	-A	713'	A28 71C62-54114-1	A	100D	L	VLV MUST BE OPEN FOR COLD LEG INJECTION AND RECIRC MODES OF SI.VLV IS CLOSED FOR HOT LEG RECIRC
WBN-1-MVOP-063-0153 SIS PUMP 1B-B OUTFLOW CONT VALVE	-B 1-FCV -063-0153 SB-00	-B	713'	A28 71C62-54114-1	A	100D	L	VLV MUST OPEN FOR COLD LEG INJECTION AND RECIRC MODES OF SI.VLV IS CLOSED FOR HOT LEG RECIRC
WBN-1-MVOP-063-0156 SIS PUMP OUTLET TO RCS LOOP 1 AND 3 HL	-A 1-FCV -063-0156 SBD-00	-A	713'	A28 71C62-54114-1	A	100D	L	VLV MUST SWITCH FROM COLD LEG HOT LEG RECIRC. SEE NOTE 4.
					A	1MO	RH/A	
					A	1MO	CV/A	
					A	1MO	AF	
					A	1MO	AB	

R5

R5

PAGE A-7 R5

PREPARER/DATE JWH 9/9/86

CHECKED/DATE NMB 9/12/86

R 5
RBN
7/11/90
58m
7/18/90

PRINT DATE: 07/07/90

BINDER NO.: WBNEQ-MOV -003
MANUFACTURER: LIMITORQUE
PAGE 7 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-MVOP-063-0157 SIS PUMP OUTLET TO RCS LOOP 2 AND 4 HL	-B 1-FCV -063-0157 SBD-00		713'	A28 71C62-54114-1	A A A A A	100D 1MO 1MO 1MO 1MO	L RH/A CV/A AF AB	VLV MUST SWITCH FROM COLD LEG HOT LEG RECIRC. SEE NOTE 4.
WBN-1-MVOP-063-0175 SIS PUMP 1B-B DISCHARGE TO RWST SHUT VLV	-B 1-FCV -063-0175 SMB-00		692'	A12 71C62-54114-1	A/B	1WK/100D	L	VLV MUST BE CLOSED BEFORE ALIGNING THE SIS FOR RECIRC. VLV MUST REMAIN CLOSED TO PREVENT FLOW FROM SUMP INTO THE RWST.
WBN-1-MVOP-063-0177 SIS PUMP INLET TO CVCS CHG PUMP	-A 1-FCV -063-0177 SB-00		692'	A08 71C62-54114-1	A	100D	L	N.O. VLV MUST REMAIN OPEN TO ALLOW OPER OF RECIRC MODES OF SI AND MUST REMAIN OPERABLE TO ISOLATE PASSIVE FAILURE OF AN ADJACENT COMPONENT.
WBN-1-MVOP-067-0083 LOWER CNTMT A COOLER SUPPLY ISLN VALVE	-A 1-FCV -067-0083 SMB-000	008	718' 2"	ANN 74C38-083015	A A A A A	100D 1MO 1MO 100D 100D	L RH/C CV/C FW/C MS/C	VLV MUST CLOSE AND REMAIN CLOSED AFTER A PHASE B ISOL SIGNAL. SEE NOTE 4.
WBN-1-MVOP-067-0088 LOWER CNTMT A CLRS DISCH ISLN VALVE IC	-B 1-FCV -067-0088 SMB-000	010	718'	ANN 74C38-083015	A A A A A	100D 1MO 1MO 100D 100D	L RH/C CV/C FW/C MS/C	VLV MUST CLOSE AND REMAIN CLOSED ON A PHASE B ISOL SIGNAL. SEE NOTE 4.

R5

PAGE A-8 R5

PREPARER/DATE JWH 9/9/86
CHECKED/DATE NMB 9/12/86
R 5
R
R
7/11/90
66m
7/18/90

PRINT DATE 12/07/89

BINDER NO. : WBNEQ-003
MANUFACTURER : LIMITORQUE
PAGE 8 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
					(2)			
WBN-1-MVOP-067-0091 -A 1-FCV -067-0091 -A 190 LOWER CNTMT C CLRS SUPPLY ISLN VALVE SMB-000			720'	ANN	A	100D	L	VLV MUST CLOSE AND REMAIN
			74C38-083015		A	1MO	RH/C	CLOSED ON A PHASE B ISOL
					A	1MO	CV/C	SIGNAL. SEE NOTE 4.
					A	100D	FW/C	
					A	100D	MS/C	
WBN-1-MVOP-067-0096 -B 1-FCV -067-0096 -B 190 LOWER CNTMT C CLRS DISCH ISLN VALVE SMB-000			720'	ANN	A	100D	L	VLV MUST CLOSE AND REMAIN
			74C38-083015		A	1MO	RH/C	CLOSED ON A PHASE B ISOL
					A	1MO	CV/C	SIGNAL. SEE NOTE 4.
					A	100D	FW/C	
					A	100D	MS/C	
WBN-1-MVOP-067-0099 -B 1-FCV -067-0099 -B 172 LOWER CNTMT B CLRS SUPPLY ISLN VALVE SMB-000			720'	ANN	A	100D	L	VLV MUST CLOSE AND REMAIN
			74C38-083015		A	1MO	RH/C	CLOSED AFTER A PHASE B
					A	1MO	CV/C	ISOL SIGNAL. SEE NOTE 4.
					A	100D	FW/C	
					A	100D	MS/C	
WBN-1-MVOP-067-0104 -A 1-FCV -067-0104 -A 170 LOWER CNTMT B CLRS DISCH ISLN VALVE OC SMB-000			720'	ANN	A	100D	L	VLV MUST CLOSE AND REMAIN
			74C38-083015		A	1MO	RH/C	CLOSED ON A PHASE B
					A	1MO	CV/C	ISOL SIGNAL. SEE NOTE 4.
					A	100D	FW/C	
					A	100D	MS/C	
WBN-1-MVOP-067-0107 -B 1-FCV -067-0107 -B 000 LOWER CNTMT D CLRS SUPPLY ISLN VALVE SMB-000			719'	ANN	A	100D	L	VLV MUST CLOSE AND REMAIN
			74C38-083015		A	1MO	RH/C	CLOSED AFTER A PHASE B
					A	1MO	CV/C	ISOL SIGNAL. SEE NOTE 4.
					A	100D	FW/C	
					A	100D	MS/C	

PAGE A-9

R4

PREPARER/DATE Kath B. Higgins 12/14/89 R 4
CHECKED/DATE 82 K. Higgins 12/14/89 R _____ R _____

PRINT DATE: 12/07/89

BINDER NO. : WBNEQ-M 003
MANUFACTURER : LIMITURQUE
PAGE 9 OF 17

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZMITH ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-MVOP-067-0112 -A 1-FCV -067-0112 -A LOWER CNTMT D CLRS DISCH ISLN VALVE OC SMB-000	350	720' ANN 74C38-083015	A	100D	L	VLV MUST CLOSE AND REMAIN CLOSED ON A PHASE B ISOL SIGNAL. SEE NOTE 4.
WBN-1-MVOP-067-0123 -B 1-FCV -067-0123 -B CNTMT SPRAY HTX B SUPPLY CONTROL VALVE SMB-000		737' A01 74C38-083015	A	30D	L	VLV MUST OPEN TO PROVIDE WATER TO CNTMT SPRAY HTX
WBN-2-MVOP-067-0123 -B 2-FCV -067-0123 -B CNTMT SPRAY HTX B SUPPLY CONTROL VALVE SMB-000		737' A01 74C38-083015	B	100D	L	VLV IS NORMALLY CLOSED AND MUST REMAIN CLOSED DURING MITIGATION OF EVENT
WBN-1-MVOP-067-0124 -B 1-FCV -067-0124 -B CNTMT SPRAY HTX B DISCHARGE VALVE SMB-000		713' A06 74C38-083015	A	30D	L	VLV MUST OPEN TO PROVIDE WATER TO CNTMT SPRAY HTX
WBN-2-MVOP-067-0124 -B 2-FCV -067-0124 -B CNTMT SPRAY HTX B DISCHARGE VALVE SMB-000		713' A19 74C38-083015	B	100D	L	VLV NORMALLY CLOSED AND MUST REMAIN CLOSED DURING MITIGATION OF EVENT

PAGE A-10 R4

PREPARER/DATE K. H. B. N. N. N. 12/12/89 R 4
CHECKED/DATE J. K. K. 12/12/89 R R

PRINT DA. 12/07/89

BINDER NO. : WBNEQ-1.03
MANUFACTURER : LIMITEQUE
PAGE 10 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	NO.	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
					CONTRACT		(2)			
WBN-1-MVOP-067-0125 CNTMT SPRAY HTX A SUPPLY CNTRL VALVE	-A	1-FCV -067-0125	-A		737'	A01	A	30D	L	VLV MUST OPEN TO PROVIDE WATER TO CNTMT SPRAY HTX
		SMB-000			74C38-083015					
WBN-2-MVOP-067-0125 CNTMT SPRAY HTX A SUPPLY CNTRL VALVE	-A	2-FCV -067-0125	-A		737'	A01	B	100D	L	VLV NORMALLY CLOSED AND MUST REMAIN CLOSED DURING MITIGATION OF EVENT.
		SMB-000			74C38-083015					
WBN-1-MVOP-067-0126 CNTMT SPRAY HTX A DISCH VALVE	-A	1-FCV -067-0126	-A		713'	A06	A	30D	L	VLV MUST OPEN TO PROVIDE WATER TO CNTMT SPRAY HTX
		SMB-000			74C38-083015					
WBN-2-MVOP-067-0126 CNTMT SPRAY HTX A DISCH VALVE	-A	2-FCV -067-0126	-A		713'	A19	B	100D	L	VLV NORMALLY CLOSED AND MUST REMAIN CLOSED DURING MITIGATION OF EVENT.
		SMB-000			74C38-083015					
WBN-1-MVOP-067-0130 UPPER CNTMT VENT CLR A SUPPLY ISLN VALVE	-A	1-FCV -067-0130	-A	300	796' 3" ANN		A	100D	L	VLV MUST CLOSE AND REMAIN CLOSED ON A CNTMT ISOL SIGNAL. SEE NOTE 4.
		SMB-000			79KA2-824589-1		A	1MO	RH/C	
							A	1MO	CV/C	
							A	100D	FW/C	
							A	100D	MS/C	

PAGE A-11 R4

PREPARER/DATE

CHECKED/DATE

R 4

R R

12/12/89

12/12/89

PRINT DATE: 12/07/89

BINDER NO. : WBNEQ-1103
MANUFACTURER : LIMITORQUE
PAGE 11 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.		AZMITH	LOCATION		ELEV(1)	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION			MODEL NUMBER			CONTRACT		(2)			
WBN-1-MVOP-067-0131	-B	1-FCV -067-0131	-B	300	795' 3" ANN	79KA2-824589-1	A	100D	L	VLV MUST FUNCTION TO ISOLATE	
UPPER CNTMT VENT CLR A ISLN VALVE OC		SMB-000					A	1MO	RH/C	FLOW TO COOLER UPON RECEIPT	
							A	1MO	CV/C	OF A PHASE B CNTMT ISOL	
							A	100D	FW/C	SIGNAL. SEE NOTE 4.	
							A	100D	MS/C		
WBN-1-MVOP-067-0133	-A	1-FCV -067-0133	-A	300	798' 4" ANN	79KA2-824589-1	A	100D	L	VLV MUST CLOSE AND REMAIN	
UPPER CNTMT VENT CLR C SUPPLY ISLN VALVE		SMB-000					A	1MO	RH/C	CLOSED ON A CNTMT ISOL	
							A	1MO	CV/C	SIGNAL. SEE NOTE 4.	
							A	100D	FW/C		
							A	100D	MS/C		
WBN-1-MVOP-067-0134	-B	1-FCV -067-0134	-B	320	799' 5" ANN	79KA2-824589-1	A	100D	L	VLV MUST FUNCTION TO ISOLATE	
UPPER CNTMT CLR C DISCH ISLN VALVE		SMB-000					A	1MO	RH/C	FLOW TO COOLER UPON RECEIPT	
							A	1MO	CV/C	OF A PHASE B CNTMT ISOL	
							A	100D	FW/C	SIGNAL. SEE NOTE 4.	
							A	100D	MS/C		
WBN-1-MVOP-067-0138	-B	1-FCV -067-0138	-B	310	797' 2" ANN	79KA2-824589-1	A	100D	L	VLV MUST CLOSE AND REMAIN	
UPPER CNTMT VENT CLR B SUPPLY ISLN VALVE		SMB-000					A	1MO	RH/C	CLOSED ON A CNTMT ISOL SIGNAL.	
							A	1MO	CV/C	SEE NOTE 4.	
							A	100D	FW/C		
							A	100D	MS/C		
WBN-1-MVOP-067-0139	-A	1-FCV -067-0139	-A	310	798' 4" ANN	79KA2-824589-1	A	100D	L	VLV MUST CLOSE AND REMAIN	
UPPER CNTMT VENT CLR B ISLN VALVE OC		SMB-000					A	1MO	RH/C	CLOSED ON A CNTMT ISOL SIGNAL.	
							A	1MO	CV/C	SEE NOTE 4.	
							A	100D	FW/C		
							A	100D	MS/C		

PAGE A-12 R4

PREPARER/DATE *Keith B. Brown*

CHECKED/DATE *01/12/89*

R 4 R R

12/12/89

12/12/89

PRINT DATE: 12/12/89

BINDER NO. : WBNEQ-003
MANUFACTURER : LIMITORQUE
PAGE 12 OF 17

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
				CONTRACT	(2)			
WBN-1-MVOP-067-0141 -B 1-FCV -067-0141 -B 310 UPPER CNTMT VENT CLR D SUPPLY ISLN VALVE SMB-000			808'	ANN 79KA2-824589-1	A A A A	100D 1MO 1MO 100D 100D	L RH/C CV/C FW/C MS/C	VLV MUST CLOSE AND REMAIN CLOSED ON A CNTMT ISOL SIGNAL. SEE NOTE 4.
WBN-1-MVOP-067-0142 -A 1-FCV -067-0142 -A 312 UPPER CNTMT VENT CLR D ISLN VALVE OC SMB-000			809'	ANN 79KA2-824589-1	A A A A	100D 1MO 1MO 100D 100D	L RH/C CV/C FW/C MS/C	VLV MUST FUNCTION TO ISOLATE FLOW TO COOLER UPON RECEIPT OF A PHASE B CNTMT ISOL SIGNAL. SEE NOTE 4.
WBN-1-MVOP-070-0090 -A 1-FCV -070-0090 -A RCP THERM BAR RET CNTMT ISLN VALVE SMB-00			713'	A28 74C38-083015	A A A A	100D 1MO 1MO 1MO 1MO	L AB AF/A CV/A RH/A	VLV MUST CLOSE AND REMAIN CLOSED AFTER A PHASE B ISOL IS INITIATED. SEE NOTE 4.
WBN-1-MVOP-070-0092 -A 1-FCV -070-0092 -A RCP OIL CLR RET CNTMT ISLN VALVE SMB-000			713'	A28 74C38-083015	A A A A	100D 1MO 1MO 1MO 1MO	L AB AF/A CV/A RH/A	VLV MUST CLOSE AND REMAIN CLOSED ON A PHASE B ISOL SIGNAL. SEE NOTE 4.
WBN-1-MVOP-070-0133 -A 1-FCV -070-0133 -A RCP THERM BAR CNTMT ISLN VALVE SMB-000			737'	A05 74C38-083015	A/B	5MN/100D	L	VLV MUST CLOSE AND REMAIN CLOSED AFTER A PHASE B ISOL IS INITIATED

PAGE A-13

R4

PREPARER/DATE

CHECKED/DATE

R 4

R

R

12/12/89

12/12/89

PRINT DATE: 12/07/89

BINDER NO.: WBNEQ-103
MANUFACTURER: LIMITORQUE
PAGE 13 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-MVOP-070-0134 -B 1-FCV -070-0134 -B RCP THERM BAR CNTMT ISLN VALVE SMB-000			737'	A05	A	100D	L	VLV MUST CLOSE AND REMAIN
			74C38-083015		A	1MO	AB	CLOSED AFTER A PHASE B ISOL
					A	1MO	AF/A	IS INITIATED. SEE NOTE 4.
					A	1MO	CV/A	
					A	1MO	RH/A	
WBN-1-MVOP-070-0140 -B 1-FCV -070-0140 -B RCP OIL CLR HDR CNTMT ISLN VALVE SMB-000			713'	A28	A	100D	L	VLV MUST CLOSE AND REMAIN
			74C38-083015		A	1MO	AB	CLOSED ON A PHASE B ISOL
					A	1MO	AF/A	SIGNAL. SEE NOTE 4.
					A	1MO	CV/A	
					A	1MO	RH/A	
WBN-1-MVOP-070-0143 -A 1-FCV -070-0143 -A EXCESS LETDOWN HTX CNTMT INLET ISLN VLV SMB-000			713'	A28	A	100D	L	VLV MUST CLOSE AND REMAIN
			74C38-083015		A	1MO	AB	CLOSED ON A PHASE A ISOL
					A	1MO	AF/A	SIGNAL. SEE NOTE 4.
					A	1MO	CV/A	
					A	1MO	RH/A	
WBN-1-MVOP-070-0183 -A 1-FCV -070-0183 -A SAMPLE HTX HDR OUTLET VALVE SMB-000			713'	A13	A	100D	L	VALVE IS REQUIRED TO BE
			74C38-083015		A	1MO	RH/A	OPERABLE TO ISOLATE NON-
					A	1MO	CV/A	QUALIFIED PIPING IN THE EVENT
					A	1MO	AB	OF A CCS LINE BREAK.
					A	1MO	AF/A	
WBN-0-MVOP-070-0206 -B 0-FCV -070-0206 -B CDWE BLDG RETURN SMB-000			692'	A01	A/B	1WK/100D	L	FOR L: VLV MUST BE OPERABLE TO
			77K32-822484-1		A	1MO	RH/A	REALIGN CCS TO POSTACCIDENT
					A	1MO	CV/A	CONFIG. OTHERS: VLV REQ'D TO
					A	1MO	AB	FUNCTION TO PROTECT AGAINST A
					A	1MO	AF/A	BREAK IN NON-Q PIPING IN CDWE.

PAGE A-14

R4

PREPARER/DATE

CHECKED/DATE

R 4

R R

12/12/89

12/12/89

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-MOV -003
MANUFACTURER : LIMITORQUE
PAGE 14 OF 17

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-MVOP-070-0207 COND DEMIN WASTE EVAP BLDG SUPPLY	-B 1-FCV -070-0207 SMB-000		737'	A01	A/B	1WK/100D	L	FOR L: VLV MUST BE OPERABLE TO
			77K32-822484-1		A	1MO	RH/A	REALIGN THE CCS TO THE POST
					A	1MO	CV/A	ACCIDENT CONFIG. FOR OTHERS:
					A	1MO	AB	VLV MUST BE OPERABLE TO
					A	1MO	AF	ISOLATE THE CDWE.
WBN-2-MVOP-070-0207 COND DEMIN WASTE EVAP BLDG SUPPLY	-B 2-FCV -070-0207 SMB-000		737'	A01	A/B	1WK/100D	L	FOR L: VLV MUST BE OPERABLE TO
			77K32-822484-1		A	1MO	RH/A	REALIGN THE CCS TO THE POST
					A	1MO	CV/A	ACCIDENT CONFIG. FOR OTHERS:
					A	1MO	AB	VLV MUST BE OPERABLE TO
					A	1MO	AF	ISOLATE THE CDWE.
WBN-0-MVOP-070-0208 COND DEMIN WASTE EVAP BLDG SUPPLY	-A 0-FCV -070-0208 SMB-000		737'	A01	A/B	1WK/100D	L	FOR L: VLV MUST BE OPERABLE TO
			77K32-822484-1		A	1MO	RH/A	REALIGN THE CCS TO POST
					A	1MO	CV/A	ACCIDENT CONFIG. FOR OTHERS:
					A	1MO	AB	VLV MUST BE OPERABLE TO
					A	1MO	AF/A	ISOLATE THE CDWE.
WBN-1-MVOP-070-0215 SAMPLE HX INLET ISLN VALVE	-A 1-FCV -070-0215 -A				A	100D	L	VLV IS REQUIRED TO OPERATE TO
					A	1MO	RH/A	ISOLATE NON-Q PIPING IN EVENT
					A	1MO	CV/A	OF CSC LINE BREAK
					A	1MO	AB	
					A	1MO	AF	
WBN-1-MVOP-072-0002 CNTMT SPRAY HDR B ISLN VALVE	-B 1-FCV -072-0002 SB-0		737'	A05	A	100D	L	VLV MUST BE OPEN AND REMAIN
			71C62-54114-1		A	1MO	RH/A	OPEN DURING THE MITIGATION OF
					A	1MO	CV/A	THE EVENT TO PERMIT FLOW TO
					A	1MO	AF	THE CONTAINMENT SPRAY HEADERS.
					A	1MO	AB	SEE NOTE 4.

PAGE 1-15 R5

PREPARER/DATE JWH 9/9/86

CHECKED/DATE NMB 9/12/86

R 5
KEN
7/11/90
EEM
7/18/90
R
R

R5

PRINT DATE: 07/07/90

BINDER NO.: WBNEQ-MOV -003
MANUFACTURER: LIMITORQUE
PAGE 15 OF 17WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	MODEL NUMBER	LOCATION AZMITH ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-MVOP-072-0013 CNTMT SPRAY PMP B RECIRC FLOW VLV	-B 1-FCV -072-0013 SMB-000		692' A08 74C38-083015	A	30D	L	VLV MUST REMAIN OPERABLE TO ALLOW MINIMUM RECIRC TO PREVENT PUMP BURNOUT
WBN-1-MVOP-072-0021 RWST TO SPRAY HDR B FLOW CONTROL VALVE.	-B 1-FCV -072-0021 SB-0		676' A16 71C62-54114-1	A/B A A A A	1WK/100D 30D 30D 30D 30D	L RH/A CV/A AB AF	FOR LENGTHY DISCUSSION OF SAFETY FUNCTION SEE CAT & OP TIMES CALCULATION WBNOSG4-019. SEE TAB B FOR REVISION LEVEL.
WBN-1-MVOP-072-0022 RWST TO SPRAY HDR A FLOW CONTROL VALVE	-A 1-FCV -072-0022 SB-0		676' A16 71C62-54114-1	A/B A A A A	1WK/100D 30D 30D 30D 30D	L RH/A CV/A AB AF	FOR LENGTHY DISCUSSION OF SAFETY FUNCTION SEE CAT & OP TIMES CALCULATION WBNOSG4-019. SEE TAB B FOR REVISION LEVEL.
WBN-1-MVOP-072-0034 CNTMT SPRAY PMP A RECIRC FLOW CONT VLV	-A 1-FCV -072-0034 SMB-000		692' A08 74C38-083015	A	30D	L	VLV MUST REMAIN OPERABLE TO ALLOW MINIMUM RECIRC TO PREVENT PUMP BURNOUT.
WBN-1-MVOP-072-0039 CNTMT SPRAY HDR A ISLN VALVE	-A 1-FCV -072-0039 SB-0		737' A05 71C62-54114-1	A A A A A	100D 1MO 1MO 1MO 1MO	L RH/A CV/A AF AB	VLV MUST BE OPEN AND REMAIN OPEN DURING THE MITIGATION OF THE EVENT TO PERMIT FLOW TO THE CONTAINMENT SPRAY HEADERS. SEE NOTE 4.

PAGE A-16 R5

PREPARER/DATE JWH 9/9/86 R 5 R R
 CHECKED/DATE NMB 9/12/86 7/14/90 7/18/90

R5

PRINT DATE: 07/07/90

BINDER NO. : WBNEQ-MOV -003
MANUFACTURER : LIMITORQUE
PAGE 16 OF 17WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-MVOP-072-0040 -A RHR SPRAY HDR A ISLN VALVE	1-FCV -072-0040 SB-00		713' A08 71C62-54114-1	A A A A	100D 1MO 1MO 1MO	L RH/A CV/A AF AB	VLV INITIALLY CLOSED DURING A LOCA MAY BE MANUALLY OPENED TO ASSIST CS SYSTEM. SEE NOTE 4.
WBN-1-MVOP-072-0041 -B RHR SPRAY HDR B ISLN VALVE	1-FCV -072-0041 SB-00		713' A28 71C62-54114-1	A A A A	100D 1MO 1MO 1MO	L RH/A CV/A AF AB	VLV INITIALLY CLOSED DURING A LOCA MAY BE MANUALLY OPENED TO ASSIST CS SYSTEM. SEE NOTE 4.
WBN-1-MVOP-072-0044 -A CNTMT SUMP TO HDR A FLOW CONTROL VALVE	1-FCV -072-0044 SB-0		685' A07' 71C62-54114-1	A A A A	100D 1MO 1MO 1MO	L RH/A CV/A AB AF	VLV CLOSED WHEN CS PMPS TAKING SUCTION FROM RWST. MUST OPEN FOR SUCTION FROM SUMP. MUST NOT FAIL IN MANNER TO DRAIN RWST. SEE NOTE 4.
WBN-1-MVOP-072-0045 -B CNTMT SUMP TO HDR B FLOW CONTROL VALVE	1-FCV -072-0045 SB-0		685' A07' 71C62-54114-1	A A A A	100D 1MO 1MO 1MO	L RH/A CV/A AB AF	VLV CLOSED WHEN CS PMPS TAKING SUCTION FROM RWST. MUST OPEN FOR SUCTION FROM SUMP. MUST NOT FAIL IN MANNER TO DRAIN RWST. SEE NOTE 4.
WBN-1-MVOP-074-0012 -A RHR PMP A-A MINI FLOW VALVE	1-FCV -074-0012 SMB-000		692' A08 71C62-54114-1	A	100D	L	MUST OPEN FOR PMP PROTECTION DURING ECCS OPER. WHEN RCS PRESS ABOVE PMP SHUTOFF HEAD A SAFETY REQMT TO CLOSE TO ALLOW THE RHRS TO MEET FLOW.

R5

PAGE A-17 R5

PREPARER/DATE JWH 9/9/86

CHECKED/DATE NMB 9/12/86

R 5	R	R
WBN		
7/14/90		
2/18/90		

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD CONTRACT		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-MVOP-074-0024 RHR PMP B-B MINI FLOW VALVE	-B 1-FCV -074-0024 SMB-000		676' A08 71C62-54114-1		A	100D	L	MUST OPEN FOR PMP PROTECTION DURING ECCS OPER. WHEN RCS PRESS ABOVE PMP SHUTOFF HEAD A SAFETY REQMT TO CLOSE TO ALLOW THE RHRS TO MEET FLOW.
WBN-1-MVOP-074-0033 RHR HT EXH A BYPASS	-A 1-FCV -074-0033 SB-00		713' A12 71C62-54114-1		A	100D	L	VLV N.O. TO ASSURE ALIGN FOR INJ PHASE OF ECCS. MUST REMAIN OPERABLE TO SWITCH FROM COLD TO HOT LEG RECIRC TO PROTECT AGAINST PASSIVE FAILURES.
WBN-1-MVOP-074-0035 RHR HT EXH B BYPASS CROSS TIE VALVE	-B 1-FCV -074-0035 SB-00		713' A11 71C62-54114-1		A	100D	L	VLV N.O. TO ASSURE ALIGN FOR INJ PHASE OF ECCS. MUST REMAIN OPERABLE TO SWITCH FROM COLD TO HOT LEG RECIRC TO PROTECT AGAINST PASSIVE FAILURES.

PREPARER/DATE JWH 9/9/86 RHM 2/8/89 RHM 9/21/89
CHECKED/DATE NMB 9/12/86 RBN 2/16/89 KHN 9/21/89

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE LIMITORQUE COMPUTED 9/16 DATE 8/22/86 R R
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED 13 DATE 8/22/86
CLASS B MOTORS

INTRODUCTION TO TAB B

Use of Test Reports

<u>Report No.</u>	<u>Purpose in Binder</u>
B0003	Main Test Report for Qualification
B0058	Summary Report of Limitorque EQ Testing and EQ Philosophy
B0212	Aging of General Purpose Phenolic Material and Low Level Vibration Testing
B0119	Qualification of Marathon Terminal Blocks
B0080	Thermal Aging of Class B Motors
600198	Used to Show Actuators do not Require Conduit Sealing

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 9/9/86 RJM
2/8/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 9/12/86 KBN
MOTORS 2/16/89

A. DOCUMENTATION

Equipment Description Motor Operated Valve Actuators

Vendor/Manufacturer Limitorque

Equipment Model No.(s) See Tab A

QUALIFICATION REPORTS

(1) Title/Number/Revision Limitorque Valve RIMS B70851119105

Actuators for Outside Containment #B0003 DATE 6-2-76

(2) Title/Number/Revision Limitorque Valve RIMS NEB820421203

Actuator Qualification
for Nuclear Services #B0058 DATE 1-11-80

OTHER (ANALYSIS, VENDOR DATA, ETC.)

(3) Valve ID. Test Report. Contract Cross Reference

(4) MEB 811215 508

(5) MEB 820604 547

(6) MEB 841212 503

(7) B70 850910 004

(8) B70 850925 012

(9) B70 850926 001

(10) B70 851107 022

(11) B70 851213 001 - Limitorque Test Report B0080 Class B Motor

Effect of Thermal Aging on Locked Rotor Performance

R1

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1a OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 9/9/86 RHM
2-15-89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 9/12/86 KBN
MOTORS 2/16/89

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (12) Limitorque Test Report B0212
- (13) Limitorque Test Report B0119
- (14) WAD-28 (AD-67)
- (15) WAD-27 (AD-74)
- (16) WAC-101
- (17) WAC-111
- (18) WAC-130
- (19) WAC-131
- (20) WCAP-7410-L
- (21) B71 860623 004
- (22) B70 851107 021 ...
- (23) B71 860806 004
- (24) Limitorque Letter dated March 19, 1987 (B70 870325 001)
- (25) Limitorque Telex dated July 11, 1988 (B36 890208 001)

R1

Copies of the above reports and documents can be found in
TABS D and E.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1b OF 28
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 9/9/86 XBN
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 9/12/86 7/18/90
MOTORS

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

Other calculations used are:

- (26) WBNNAL3-025 (B45 860328 236)
- (27) WBNNAL3-026 (B45 860238 237)
- (28) NEB86052 (#4) (B45 860527 265)
- (29) WBNTSR-012 (B26 890317 001)
- (30) WBNNAL3-004 (B45 860205 235)
- (31) Category and Operating Times, System 26, WBNOSG4-007 R3
B45 851121 218
B26 900706 211
- (32) Category and Operating Times, System 62, WBNOSG4-013 R13
B26 900713 212
- (33) Category and Operating Times, System 63, WBNOSG4-014 R12
B26 900319 215
- (34) Category and Operating Times, System 67, WBNOSG4-016 R14
B26 900110 200
- (35) Category and Operating Times, System 70, WBNOSG4-018 R13
B26 900717202
- (36) Category and Operating Times, System 72, WBNOSG4-019 R9
B26 9003090232
- (37) Category and Operating Times, System 74, WBNOSG4-020 R8
- (38) Environmental Drawing No. 47E235-44 R1
- (39) Environmental Drawing No. 47E235-46 R1
- (40) Environmental Drawing No. 47E235-48 R3
- (41) Environmental Drawing No. 47E235-50 R1
- (42) Environmental Drawing No. 47E235-52 R1
- (43) Environmental Drawing No. 47E235-56 R1
- (44) Environmental Drawing No. 47E235-57 R2
- (45) Environmental Drawing No. 47E235-58 R1
- (46) Environmental Drawing No. 47E235-59 R2 & DCA P-02351-18-0

PAGE B-4 R5

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1c OF 28
R 2 R 5
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED/R1 RHM DATE 02/08/89 RHM KBN
8/89 7/18/90
OUTSIDE CONTAINMENT WITH CLASS B CHECKED /R1 KBN DATE 02/16/89 KBN ESM
MOTORS 8/89 7/18/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (47) Environmental Drawing No. 47E235-60 R1
- (48) Environmental Drawing No. 47E235-61 R1
- (49) Environmental Drawing No. 47E235-62 R1
- (50) Environmental Drawing No. 47E235-63 R2 & DCA P-02351-19-0
- (51) Environmental Drawing No. 47E235-64 R2 & DCA P-02351-20-0,21-0
- (52) Environmental Drawing No. 47E235-65 R2 & DCA P-02351-22-0
- (53) Environmental Drawing No. 47E235-77 R1
- (54) Environmental Drawing No. 47E235-79 R1
- (55) Category and Operating Times, Unit 2 for Unit 1.
- WBNOSG4-40 R 7 B26 900327 203

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

PAGE B-4A R5

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 2 OF 28
R 1 R _____
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 9/12/86 Rdu
2-15-89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 9/12/86 RBN
MOTORS 2/16/89

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES _____

- 1) Degraded voltage for actuators 1-FCV-62-63, 1-FCV-62-90,
1-FCV-62-91, 1-FCV-62-98, 1-LCV-62-132, 1-LCV-62-133,
1-LCV-62-135, 1-LCV-62-136, 1-FCV-63-26, 1-FCV-72-2 and
1-FCV-72-39 must be justified. See Open Item No. 1.
- 2) 1-FCV-70-215 has a Rotork valve actuator. See Open Item No. 2.
- 3) Final response to NRC IE Bulletin 85-03. See Open Item No. 3. R1
- 4) Replace control cable internal to the actuator. See Open Item
No. 4.
- 5) Replace nylon crimped motor lead connector with Raychem
connector. See Open Item No. 5. R1
- 6) Disconnect limit switch and motor compartment heaters. See
Open Item No. 6. R1
- 7) Motor on valve operator 1-FCV-62-99 must be replaced. See
Open Item No. 7. R1
- 8) Field verification sheets do not adequately identify the
terminal blocks installed in the actuators. See Open Item No. 8. R1

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 2a OF 28
R _____ R _____
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED /R/ Rm DATE 2-15-89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED /R/ Rm DATE 2/16/89
MOTORS

OPEN ITEMS AND QUALIFICATION DEFICIENCIES (Continued)

9) Provisions are required to eliminate the possibility of condensate draining into the limit switch compartments of valve actuators. A T-drain is to be added to the low point of the limit switch compartment for those actuators that are subjected to high humidity. The binder to be revised upon resolution of this open item. See Open Item #9.

BINDER NO. WNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 3 OF 28
R 3 R _____
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RJM
9/2/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED B DATE 8/22/86 KBN
MOTORS 9/21/89

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974) | R3

_____ Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS _____

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

The Limitorque Environmental Qualification program was conducted per IEEE-382 (1972), "IEEE Guide for Type Test of Class 1

Electric Valve Operators for Nuclear Power Generating Stations"

and meets the requirements of IEEE-323 (1974) as they apply to valve actuators (#B0058, Section 2.1).

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 4 OF 28
BINDER TITLE LIMITORQUE COMPUTED GW DATE 8/22/86 R R
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/22/86
CLASS B MOTORS

D. QUALIFICATION METHODOLOGY (Check only one block)

 Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

 X Test of Similar Items with Supporting Analysis

 Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

 Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The Limitorque qualification program was
conducted to encompass the entire family of actuators - SMB, SB,
SBD, and SMB/HBC in all available unit sizes (SMB-000 to SMB-5).
This was accomplished by type testing - see Tab C, Section 1.
Tab E, Attachment 1 identifies the actuator plant ID number, the
Limitorque shop order number, the actuator serial number, and the
documentation which establishes traceability to the applicable test
report.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 5 OF 28
 BINDER TITLE LIMITORQUE COMPUTED Jul 15 DATE 8/22/86 R R
 ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED 15 DATE 8/22/86
 CLASS B MOTORS

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Motor Operated Valve Actuator</u>	<u>Motor Operated Valve Actuator</u>	<u>B0003, Sect. 3.0</u>
(2) Manufacturer	<u>Limitorque</u>	<u>Limitorque</u>	<u>B0003, Sect. 3.0</u>
(3) Model Number(s)	<u>See Tab A</u>	<u>SMB-0</u>	<u>B0003, Sect. 3.0</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(4) Serial Number(s)	<u>See Tab E</u>	<u>195004</u>	<u>B0003, Sect. 3.0</u>
	<u> </u>	<u> </u>	<u> </u>
Order Number(s)	<u>See Tab E</u>	<u>600461</u>	<u>B0003, Sect. 3.0</u>
	<u> </u>	<u> </u>	<u> </u>
(5) Identify Component-Unique checksheet attached:	<u>None</u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS See Tab C, Section 1.

(4 and 5) Tab E, Attachment 1, information was taken from Field

Verification Sheet in Tab F.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 6 OF 28
 R 1 R 1
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RJM
2-15-89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 WBN
MOTORS 2/16/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>NA</u>	<u>NA (See Comment)</u>	<u>NA</u>
Conduit Seals	<u>None</u>	<u>No</u>	<u>B0058 Sect 3.2.3 and 4.1.2</u> R1
Connector Seals	<u>None</u>	<u>No</u>	<u>B0058 Sect 3.2.3 & 4.1.2</u>
Orientation	<u>Motor horizontal with limit switch compartment up</u>	<u>No</u>	<u>See TAB G, Sect A1</u>
Physical Configuration	<u>NA</u>	<u>NA</u>	<u>NA</u>
Other	<u>NA</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Report B0003 makes no mention of any specific installation interface requirements; however, B0058 Sections 3.2.3 and 4.1.2 concludes that sealing of the actuators (i.e conduit seals, seals and gaskets) are of no importance for the qualification of the actuators. See TAB C, Section 3.0. See TAB C, Section 7, concerning orientation of the actuator. See TAB C, Section 8.2, concerning electrical connection of the actuator. For electrical connections, a qualified cable shall be used. |R1

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 7 OF 28
 BINDER TITLE LIMITORQUE COMPUTED [Signature] DATE 9/9/86
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED B DATE 9/12/86
CLASS B MOTORS

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>See Comments</u> <u>B0003, Fig.</u> <u>2A and 2B</u>
(b) Baseline performance measurements taken	<u>Yes</u>	
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>B0003,</u> <u>Sect. 4.1</u>
Radiation	<u>Yes</u>	<u>B0003,</u> <u>Sect. 4.3</u>
Wear	<u>Yes</u>	<u>B0003,</u> <u>Sect. 4.2</u>
(d) Vibration/seismic testing conducted	<u>Yes-Seismic</u>	<u>B0003,</u> <u>Sect. 4.4</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>B0003,</u> <u>Sect. 4.5.1</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>B0003,</u> <u>Sect. 4.5.1</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>B0003,</u> <u>Sect. 4.5.3</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes
 (Reference B0003, Appendix I _).

JUSTIFICATION/COMMENTS (a) There is no evidence in the report that
the equipment was inspected prior to start of the test. However,
pre-inspection is not a requirement of IEEE 323 (1974). (b) Baseline
performance measurements were taken at time 0. They are within nominal
and are acceptable. (d) Low level vibration is addressed in Tab C,
Section 2.0

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 8 OF 8
BINDER TITLE LIMITORQUE COMPUTED Jys DATE 8/22/86 R R
ACTUATORS OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED B DATE 8/22/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference B0058, Sect. 3.0).

JUSTIFICATION/COMMENTS None

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>B0003, Sect. 4.1.4</u> <u>B0058, Sect. 3.2</u>
Radiation exposure	<u>Yes</u>	<u>B0058, Sect. 3.4</u> <u>B0003, Sect. 4.3</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>B0058, Sect. 2.1</u> <u>B0058, Sect. 3.3</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>B0003, Sect. 4.2</u>

JUSTIFICATION/COMMENTS None

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS No known synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
(yes/no/NA)? Yes (Reference B0003, Sect. 4.1).
B0058, Sect. 3.2

JUSTIFICATION/COMMENTS See Tab C, Section 8.

BINDER NO. WBNEO-MOV-003 PLANT WBN UNIT(S) 1 SHEET 9 OF 28
 BINDER TITLE LIMITORQUE COMPUTED July DATE 9/9/86
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED 12 DATE 9/14/86
CLASS B MOTORS

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
 (Reference: B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect.4.1
B0058, Sect.3.2.1.1).

<u>Parameter</u>	<u>Plant Maximum</u> <u>Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>110°F</u>	<u>See Comments</u>	<u>See Comments</u>
Time	<u>40 years</u>	<u>See Comments</u>	<u>See Comments</u>

JUSTIFICATION/COMMENTS See Tab C, Section 8. All materials
which are potentially susceptible to aging have qualified
or expected life of greater than 40 years.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA
 (Reference NA).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 10 OF 28
BINDER TITLE LIMITORQUE COMPUTED gws DATE 8/22/86 R R
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/22/86
CLASS B MOTORS

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference B0058, Sect. 3.2.1.3).

JUSTIFICATION/COMMENTS See Tab C, Section 8. Regression analysis provided for Class "B" insulated motor.

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference B0003, Sect. 4.1).

JUSTIFICATION/COMMENTS None

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect. 2.3).
App. II, and
B0058, Sect. 3.4

JUSTIFICATION/COMMENTS None

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? NA
(Reference B0058, Sect. 3.4).

JUSTIFICATION/COMMENTS Limitorque concluded after several tests that "there was no noticeable detrimental effect of radiation on any component in any of the test sequence or radiation level employed".

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes
(Reference B0058, Sect. 3.4).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 11 OF 28
R 1 R _____
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RBM
2/8/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KAN
MOTORS 2/16/89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: _____)

B0003, Sect. 2.3, 4.3 and App. II).

Plant normal ambient radiation dose (rd) 1.8×10^7
 2.04×10^8 - Motor only
Test exposure dose (rd) 2×10^7 - Other - See Comments

Test exposure dose rate (rd/hr) 1.0×10^6

Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS See TAB C, Section 9.0

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* Yes (Reference: B0058, Sect 2.1).

JUSTIFICATION/COMMENTS Non-seismic (low level) vibration was considered but determined to be of no consequence based on experience. See TAB C, Section 2.0

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? NA (Reference: B0058, Section 2.1).

JUSTIFICATION/COMMENTS See TAB C, Section 2.0 for justification of omission of non-seismic vibration aging

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 12 OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RJM
2/10/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 XBN
MOTORS 2/10/89

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: B0003, Sect. 4.1.5 and 4.2). R1

JUSTIFICATION/COMMENTS The actuator was cycled
(mech aging) 1993 times.

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: B0003, Sect. 4.2, B0058, Sect. 3.3).

JUSTIFICATION/COMMENTS The actuator was required to
provide its full output rating at the torqued seated
position during cycling.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: B0058, Sect. 3.2 and 7.0).

Qualified life (Document in QMDS) greater than 40 years

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 12a OF 28
R 1 R _____
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RNM
2-15-89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBA
MOTORS 2/16/89

H. AGING (Continued)

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: B0058, Section 7.0)

_____).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 13 OF 28
 R 3 R _____
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 9/9/86 RHM
9/21/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 9/12/86 KEN
MOTORS 9/24/89

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Durez (Red)</u>	<u>2x10⁷</u>	<u>B0003(4.3)</u>	<u>1.02</u>	<u>TAB E, item 18</u> <u>See Comments</u>
(b) <u>G.P. Phenolic (Black)</u>	<u>2.09x10⁸</u>	<u>B0212(6.7)</u>	<u>1.63</u>	<u>See Comments</u>
(c) <u>Motor Insulation-CL-"B"</u>	<u>2.04x10⁸</u>	<u>B0003(2.3)</u> <u>and App. II</u>	<u>0.93</u>	<u>See Comments</u>
(d) <u>Wiring Insulation</u>	<u>2.0x10⁸</u>	<u>WBNEQ-CABL</u> <u>-044</u>	<u>NA</u>	<u>See Tab C,</u> <u>Sect. 4.0</u>
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS Radiation threshold does not apply.

Limitorque has performed radiation exposure per the referenced
Limitorque test reports. The values listed in the threshold column
represent the testing parameters. (a) See Tab C, Section 9.0

Activation energies are documented in Tab E as follows:

- a. Durez - Limitorque telex September 25, 1985 (B70850926001)
- b. G. P. Phenolic - Limitorque letter September 15, 1985(B70850910004)
- c. Motor insulation - Limitorque letter September 25, 1985
(B70850926001). Motors may be upgraded to inside containment
type (Class RH insulation). Qualification of these motors is
addressed in Binder MOV-001.

R3

See Tab C, Section 8.0 for material analysis. Limitorque's telex
dated November 6, 1985 (B70 851107 021). shows the correlation
between the material color, material name, and the test report.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 14 OF 28
BINDER TITLE LIMITORQUE COMPUTED Jyk DATE 8/22/86 R R
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/25/86
CLASS B MOTORS

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference B0058, Sect. 4.1.8).

Identify Acceptance Criteria: The actuator must be capable of opening or closing a valve on demand. TVA Quality Assurance procedures and pre-operational test results provide assurance that the actuator will perform its intended function.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference B0003, Sect. 4.0, Fig. 1, 2A, and 2B)

Identify baseline and functional testing: See Tab C, Section 11.

JUSTIFICATION/COMMENTS None

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? No (Reference NA).

JUSTIFICATION/COMMENTS B0003 does not describe mechanical loads during DBE testing. Electrical characteristics and stroke time during DBE cycling are shown in Figure 2B of B0003.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 15 OF 28
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RSM
2-15-89
 OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KAN
2/16/89
 MOTORS

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____)

B0003, Sect. 4.1, 4.2 and 4.5 & Fig. 2A and 2B).

JUSTIFICATION/COMMENTS None

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>490 VAC</u>	<u>*600456</u> <u>Table III</u>
Load	<u>Approx 20,000 lbs thrust</u>	<u>*600456</u> <u>Table III</u>
Frequency	<u>See Comment</u>	<u>See Comment</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		
<u>NA</u>		
<u>NA</u>		

JUSTIFICATION/COMMENTS Although not specifically
stated, we have no reason to believe that Limitorque
used anything other than a 60 Hz power source.

* Report 600456 is Appendix C of Report B0058 and a copy can be found in WBNEQ-MOV-001, TAB D.

R1

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 15a OF 28
 R 1 R 1
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RJM
2/18/89
 OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN
2/16/89
 MOTORS

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) Parameter	Specific Accident Conditions	Reference	R1
Voltage	<u>See Comment</u>	<u>See Comment</u>	
Load	<u>See Comment</u>	<u>NA</u>	
Frequency	<u>60 Hz \pm 3.2%</u>	<u>WBN FSAR</u> <u>p 8.3-17</u>	
Accuracy	<u>NA</u>	<u>NA</u>	
Other(s)			

JUSTIFICATION/COMMENTS Justification for lack of reduced voltage starting tests under accident conditions is presented in TAB C, Sect. 5.0. Actuators are sized to produce the required torque for each valve under specified applications and conditions.

(c) Parameter	Demonstrated Conditions	Reference	R1
Voltage	<u>490 - 500 VAC</u>	<u>B0003,</u> <u>Fig. 2B</u>	
Load	<u>Thrust 20,000 lbs</u>	<u>B0003,</u> <u>Sect. 4.1</u>	
Frequency	<u>See Comment</u>	<u>B0003, App.</u> <u>III, page 3A</u>	
Accuracy	<u>NA</u>	<u>NA</u>	
Other(s)			

JUSTIFICATION/COMMENTS Although the test report does not address demonstrated frequency, we have no reason to believe that the operator was tested at other than 60Hz. Also, per Limitorque letter dated 6/18/86 (B71 860623 004, TAB E, item 19) the actuator motor is purchased to NEMA standards that require the motor to operate at plus or minus 5 percent of nominal frequency.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
 R 1 R 1
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RJA
2/10/89
 OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN
2/16/89
 MOTORS

K. REQUIRED OPERATING ENVIRONMENT

Worst case listed below - See
 Reference Environmental Drawing No. pp 16A through 16M for all
operating environments

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>110</u>	(a) Temperature (°F) <u>120</u>
(b) Pressure (psig) <u>0</u>	(b) Pressure (psig) <u>0</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>1.8×10^7</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: Valve body and stem connection configuration isolates the degradable actuator parts from significant additional heating due to the high temperature of process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal temperatures could occur as a result of outside temp. excursions, temporarily greater than design heat loads, or degraded environment control systems. This could exist for up to eight hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

* (a) Temperature (°F) <u>162.00</u>	LOCA Accident type (See TAB A)
(b) Pressure (psig) <u>0</u>	HELB Accident type (See TAB A)
(c) Humidity (%) <u>100</u>	HELB Accident type (See TAB A)
** (d) Radiation (rd) <u>1.2×10^7</u>	LOCA Accident type (See TAB A) R1
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

*This is the most severe temperature because the duration of the temperature does not drop off as rapidly as the peak temperatures listed on sheet 16G, 16H, 16I (209°F) and sheet 16K (190°F).

**This dose includes a beta contribution of 6×10^5 rads. See environmental drawing 47E235-44, Note 37.

| R1

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16a OF 28
R 1 R 1
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RHM
2/8/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-44 (Annulus) | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>110</u>	(a) Temperature (°F) <u>120</u>
(b) Pressure (psig) <u>0</u>	(b) Pressure (psig) <u>0</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>1×10^6</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>133.7</u>	Accident type <u>LOCA</u>
(b) Pressure (psig) <u>0</u>	Accident type <u>HELB</u>
(c) Humidity (%) <u>61</u>	Accident type <u>HELB</u>
(d) Radiation (rd) <u>1.2×10^7</u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RJM
2/8/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-46 (737 A1) | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>0</u>	(b) Pressure (psig) <u>0</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>2.1×10^5</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>128</u>	Accident type <u>HELB</u>
(b) Pressure (psig) <u>0</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>100</u>	Accident type <u>HELB</u>
(d) Radiation (rd) <u>$<1 \times 10^4$</u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RJM
2/8/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KAN
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-48 (737 A5, A9) | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104 (a) Temperature (°F) 110

(b) Pressure (psig) 0 (b) Pressure (psig) 0

(c) Humidity (%) 80 (c) Humidity (%) 90

(d) Radiation (rd) 8.8×10^5 (d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 110 Accident type LOCA

(b) Pressure (psig) 0 Accident type LOCA

(c) Humidity (%) NA Accident type LOCA

** (d) Radiation (rd) 1.8×10^6 Accident type LOCA

(e) Spray Type NA Accident type NA

** See QIRNEB86092 (B46860721252) for accident radiation dose.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RHM
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-50 (713 A11, A12, A15, A16) | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>0</u>	(b) Pressure (psig) <u>0</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>4.3×10^5</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>110</u>	Accident type <u>LOCA</u>
(b) Pressure (psig) <u>0</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>NA</u>	Accident type <u>LOCA</u>
(d) Radiation (rd) <u>1.0×10^7</u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
R 1 R _____
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RSM
2/18/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KAN
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-52 (713 A1, A13, A14) | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104

(a) Temperature (°F) 110

(b) Pressure (psig) 0

(b) Pressure (psig) 0

(c) Humidity (%) 80

(c) Humidity (%) 90

(d) Radiation (rd) 1.8×10^7

(d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 128

Accident type HELB

(b) Pressure (psig) 0

Accident type HELB

(c) Humidity (%) 100

Accident type HELB

(d) Radiation (rd) $<1.0 \times 10^4$

Accident type LOCA

(e) Spray Type NA

Accident type NA

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RHA
2/8/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KAU
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-56 (713 A6, A19) | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104 (a) Temperature (°F) 110

(b) Pressure (psig) 0 (b) Pressure (psig) 0

(c) Humidity (%) 80 (c) Humidity (%) 90

(d) Radiation (rd) 2.2 x 10⁶ (d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 110 Accident type LOCA

(b) Pressure (psig) 0 Accident type LOCA

(c) Humidity (%) NA Accident type LOCA

(d) Radiation (rd) 2.0 x 10⁶ Accident type LOCA

(e) Spray Type NA Accident type NA

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
 R 1 R 5
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RHM KBN
 2/89 7/18/90
 OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN EE
 MOTORS 2/16/89 7/18/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-58 (676, A16, A17)

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104 (a) Temperature (°F) 110

(b) Pressure (psig) 0 (b) Pressure (psig) 0

(c) Humidity (%) 80 (c) Humidity (%) 90

(d) Radiation (rd) 7.5×10^6 (d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 210 Accident type HELB R5

(b) Pressure (psig) 0 Accident type HELB

(c) Humidity (%) 100 Accident type HELB

(d) Radiation (rd) 5.0×10^6 Accident type LOCA

(e) Spray Type NA Accident type NA

PAGE B-27 R5

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RNM
2/18/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-60, -59 (692 A8, A24) | R1

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) 0

(c) Humidity (%) 80

(d) Radiation (rd) 7.5×10^6

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) 0

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 209 Accident type HELB

(b) Pressure (psig) 0 Accident type HELB

(c) Humidity (%) 100 Accident type HELB

(d) Radiation (rd) 5.0×10^6 Accident type LOCA

(e) Spray Type NA Accident type NA

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RHM
2/18/89
OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED NMB DATE 8/22/86 KMN
2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-61, 59 (713,A28,A29) | R1

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) 0

(c) Humidity (%) 80

(d) Radiation (rd) 7.5×10^6

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) 0

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 209 Accident type HELB

(b) Pressure (psig) 0 Accident type HELB

(c) Humidity (%) 100 Accident type HELB

(d) Radiation (rd) 5.0×10^6 Accident type LOCA

(e) Spray Type NA Accident type NA

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
 R 1 R 5
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RHM KBN
 2/89 7/18/90
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN LEM
MOTORS 2/16/89 7/18/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-62, -63, -64, -65 (692 A1)

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104

(a) Temperature (°F) 110

(b) Pressure (psig) 0

(b) Pressure (psig) 0

(c) Humidity (%) 80

(c) Humidity (%) 90

(d) Radiation (rd) 5.6×10^5

(d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 144

Accident type HELB | R5

(b) Pressure (psig) 0

Accident type HELB

(c) Humidity (%) 100

Accident type HELB

(d) Radiation (rd) $<1.0 \times 10^4$

Accident type LOCA

(e) Spray Type NA

Accident type NA

PAGE B-30 R5

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
R 1 R _____
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 Rm
2/18/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-77 (RSVR) (685 A7', A25') | R1

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) 0

(c) Humidity (%) 80

(d) Radiation (rd) 1.8×10^6

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) 0

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 190 Accident type LOCA

(b) Pressure (psig) 0 Accident type LOCA

(c) Humidity (%) 90 Accident type LOCA

(d) Radiation (rd) 1.0×10^7 Accident type LOCA

(e) Spray Type NA Accident type NA

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RHM
2/18/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86 KBN
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-79 (692 A9, A10, A11, A12, A13, A19, A20, A21, A22, A23) | R1

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) 0

(c) Humidity (%) 80

(d) Radiation (rd) 3.5×10^4

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) 0

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 110 Accident type LOCA

(b) Pressure (psig) 0 Accident type LOCA

(c) Humidity (%) NA Accident type LOCA

(d) Radiation (rd) 1.0×10^7 Accident type LOCA

(e) Spray Type NA Accident type NA

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
R 1 R 2/18/89
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/22/86
MOTORS 2/16/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-56, -57 (713 A7') | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>ATM(-)</u>	(b) Pressure (psig) <u>ATM(-)</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>5.8×10^6</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>190</u>	Accident type <u>HELB</u>
(b) Pressure (psig) <u>0</u>	Accident type <u>HELB</u>
(c) Humidity (%) <u>100</u>	Accident type <u>HELB</u>
(d) Radiation (rd) <u>5.0×10^6</u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 17 OF 28
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 Rhu
2-5-89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/23/86 KBR
MOTORS 2/6/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): None

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: _____)

TAB C, Section 7.0 and Open Item #9). | R1

- (7) Subject to submergence (Yes/No/NA)? No (Reference: _____)

TAB C, Section 12.0).

Identify initiation time and duration of submergence: _____

NA

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes
(Reference: Environmental drawing 47E235-44, Note 37).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: NA

R1

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

Radiation QIR NEB 86092

B46 860721 252

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 18 OF 28
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED 9/15/86 DATE 8/22/86
OUTSIDE CONTAINMENT WITH CHECKED 13 DATE 8/22/86
CLASS B MOTORS

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>16 days</u>	<u>B0003, Sect. 4.5 & Fig. 1</u>
Temperature (°F)	<u>209</u>	<u>250</u>	<u>B0003, Fig. 1</u>
Pressure (psig)	<u>0</u>	<u>25</u>	<u>B0003, Fig. 1</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>B0003, Sect. 2.5.2 & Fig. 1</u>
*Chemical Spray	<u>NA</u>	<u>NA</u>	<u>NA</u>
**Radiation (rd)	<u>1.8×10^7</u>	<u>2×10^7 - Other 2.04×10^8 - Motor Only</u>	<u>B0003, Sect. 2.3 & App. II See Comments</u>
Submergence	<u>NA</u>	<u>NA</u>	<u>NA</u>

*Includes spray concentration, flowrate, density, duration, and pH.
 **Enter 40-year integrated normal dose plus integrated accident dose and specify type.

JUSTIFICATION/COMMENTS Please note that the radiation levels in K(1) and K(5) on page 16 are not additive and the worst case is based on sheet 16E. See Tab C, Section 9.0 for discussion of radiation testing for switches. See Tab C, Section 6.0 for post-accident operability time justification.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>B0003, Fig. 1</u>
Pressure	<u>Yes</u>	<u>B0003, Fig. 1</u>
Relative Humidity	<u>Yes</u>	<u>B0003 Sect. 4.1.4</u>
Chemical Spray	<u>NA</u>	<u>NA</u>
Submergence	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 19 OF 28
 R 1 R 1
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RJM
2/8/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/23/86 KBN
MOTORS 2/16/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	15°F	Yes-B0003 Fig. 1
Pressure: +10% but no more than 10 psig	10%	Yes-B0003 Fig. 1
Radiation: +10% of accident dose	10%	Yes-B0003 Sect 4.3
Time: +10% (or 1 hour + operating time per NUREG-0588)	-	No - See Comment
Voltage: ±10% of rated value	+8.7%	No - See Comments TAB C Sect 5
Frequency: ±5% of rated value		See Comments
Environmental Transient: the initial transient and the peak temperature applied twice	2 Dwells	Yes-B0003 Fig. 1
Vibration: +10% added to acceleration	NA	NA-TAB C Sect 2

R1

JUSTIFICATION/COMMENTS See above references for all items
except time margin. See TAB C, Section 6.0. See comments on
frequency in TAB B, Section J(5). Although the test margin is
only 8.7% Limitorque letter dated 6-19-86 (B71 860623 004,
TAB E, Item 20) states that Limitorque purchase actuator
motors to Nema standards requiring the motors to be capable
of operating at plus or minus 10% voltage or plus or minus 5%
of nominal frequency.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 20 OF 28
R 1 R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RJA
2/10/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/25/86 KBN
2/16/89
MOTORS

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference: B0058, Section 2.4

_____.
JUSTIFICATION/COMMENTS The actuator must be capable of
providing the required torque and/or thrust to open or close
the valve as required.

- (2) Did the equipment perform its intended function during the
simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: B0003, Section 5.0

_____.
JUSTIFICATION/COMMENTS None

- (3) Did the equipment perform its intended function during the
simulated post-design basis accident exposure
(Yes/No/NA)? Yes (Reference: B0003, Section 5.0

_____.
JUSTIFICATION/COMMENTS None

- (4) Did the test demonstrate the operability requirements for the
required time interval for which the equipment is required to
operate (Yes/No/NA)? No (Reference: _____

B0003, Figure 1, 2A and 2B _____).

JUSTIFICATION/COMMENTS See TAB C, Section 6.0 for

justification of post-accident actuator operability.

R1

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 20a OF 28
R 1 R 1
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 RNM
2-15-89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED NMB DATE 8/25/86 KBN
MOTORS 2/16/89

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: B0003, Section 4.5.2)

JUSTIFICATION/COMMENTS Minor problems were experienced
during the LOCA test. These problems had no effect on
overall actuator performance. See the referenced section
of report B0003.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 21 OF 28
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED [Signature] DATE 8/22/86
OUTSIDE CONTAINMENT WITH
CLASS B MOTORS CHECKED [Signature] DATE 8/23/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

[illegible]

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 22 OF 28
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED Just DATE 8/22/86
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/22/86
CLASS B MOTORS

O. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>NA</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>NA</u>
(b) Were specific features and failure modes and effects analyzed?	<u>NA</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>NA</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>Yes</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

PAGE B-39

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 23 OF 28
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JW DATE 8/22/86
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/25/86
CLASS B MOTORS

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 24 OF 8
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED Jws DATE 8/22/81
OUTSIDE CONTAINMENT WITH R R
CLASS B MOTORS CHECKED B DATE 8/25/81

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>NA</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 25 OF 28
R R
BINDER TITLE LIMITORQUE ACTUATORS COMPUTED /R/ RDM DATE 2/8/89
OUTSIDE CONTAINMENT WITH CLASS B CHECKED /R/ KBN DATE 2/16/89
MOTORS

THIS PAGE INTENTIONALLY LEFT BLANK

Pages B-42 thru B-45 were deleted per revision 1 .

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 JH DATE 1-24-89
PENETRATION, LV POWER & CONTROL CHECKED /R1 JH DATE 1-25-89

TAB A

Equipment Identification Matrix

Notes:

1. Elevation shown are actual elevations for equipment located in the Reactor Building. Actual elevations are documented in TAB F and on drawing 45W860-3 in TAB E.
2. Category and Operating Times for penetrations, which are passive devices, are not assigned directly but are dictated by the category and operating times of devices served.

PRINT DATE: 06/25/90

BINDER NO. : WBNEQ-PENT-002
MANUFACTURER : CONAX CORPORATION
PAGE 1 OF 3

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT	DEVICE ID NO.	AZMITH	LOCATION	ELEV(1)	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION		MODEL NUMBER			CONTRACT		(2)			
WBN-1-PENT-293-0006 PRIMARY CONTAINMENT	-A	1-PENT-293-0006 ELEC PENETRATION	-A 015 7429-10001-02	737'	ANN 76K61-087064		A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)
WBN-1-PENT-293-0007 PRIMARY CONTAINMENT	-B	1-PENT-293-0007 ELEC PENETRATION	-B 167 7429-10001-02	737'	ANN 76K61-087064		A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)
WBN-1-PENT-293-0008 PRIMARY CONTAINMENT	-A	1-PENT-293-0008 ELEC PENETRATION	-A 199 7429-10001-02	727' 8"	ANN 76K61-087064		A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)
WBN-1-PENT-293-0009 PRIMARY CONTAINMENT	-B	1-PENT-293-0009 ELEC PENETRATION	-B 333 7429-10001-02	738' 1"	ANN 76K61-087064		A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)
WBN-1-PENT-293-0014 PRIMARY CONTAINMENT	-A	1-PENT-293-0014 ELEC PENETRATION	-A 097 7429-10002-04	737' 6"	ANN 76K61-087064		A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)

PAGE A-2
R3

PREPARER/DATE DDD 7-26-86 R 3 R R
CHECKED/DATE WBK 7-27-86 7/23/90 8-30-90

PR. 06/25/90

BINDER NO. : WBNEQ-PENT
MANUFACTURER : CONAX CO
PAGE 2 OF 3

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMUTH	ELEV(1) CONTRACT				
WBN-1-PENT-293-0015 PRIMARY CONTAINMENT	-A	1-PENT-293-0015	-A 101 7429-10002-03		737' 6" ANN 76K61-087064	A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)
WBN-1-PENT-293-0016 PRIMARY CONTAINMENT	-B	1-PENT-293-0016	-B 112 7429-10002-03		737' 6" ANN 76K61-087064	A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)
WBN-1-PENT-293-0017 PRIMARY CONTAINMENT	-B	1-PENT-293-0017	-B 120 7429-10002-04		737' 7" ANN 76K61-087064	A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTERGRITY (CAT A)
WBN-1-PENT-293-0021 PRIMARY CONTAINMENT	-A	1-PENT-293-0021	-A 238 7429-10002-02		718' 9" ANN 76K61-087064	A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)

PAGE A-3

R3

PREPARER/DATE DDD 7-26-86 OKZ
CHECKED/DATE WBK 7-27-86 WBL
8-30-90

DATE: 06/25/90

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-PENT
MANUFACTURER : CONAX CO
PAGE 3 OF 3

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-PENT-293-0027 PRIMARY CONTAINMENT ELEC PENETRATION	-A 1-PENT-293-0027 7429-10002-05	-A 019	727'11" ANN 76K61-087064		A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	100/100D 100/100D 100/100D 1MO/1MO 1MO/1MO	LOCA MS/C FW/C RH/C CV/C	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)
WBN-1-PENT-293-0036 PRIMARY CONTAINMENT ELEC PENETRATION	-B 1-PENT-293-0036 7429-10002-05	-B 150	737' 7" ANN 76K61-087064		A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	100/100D 100/100D 100/100D 1MO/1MO 1MO/1MO	LOCA MS/C FW/C RH/C CV/C	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)
WBN-1-PENT-293-0044 PRIMARY CONTAINMENT ELEC PENETRATION	-A 1-PENT-293-0044 7429-10002-05	-A 209	733' 6" ANN 76K61-087064		A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	100/100D 100/100D 100/100D 1MO/1MO 1MO/1MO	LOCA MS/C FW/C RH/C CV/C	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)
WBN-1-PENT-293-0052 PRIMARY CONTAINMENT ELEC PENETRATION	-B 1-PENT-293-0052 7429-10001-05	-B 345	738'10" ANN 76K61-087064		A/B 100/100D A/B 100/100D A/B 100/100D A/B 1MO/1MO A/B 1MO/1MO	100/100D 100/100D 100/100D 1MO/1MO 1MO/1MO	LOCA MS/C FW/C RH/C CV/C	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A)

PAGE A-4

R3

PREPARER/DATE DDD 7-26-86 7/23/90 8-30-90
CHECKED/DATE WBK 7-27-86
R 3 R R

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 29
R 1 R 3
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 JFW 7/25/90
1/24/89
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/8/86 WCG 400
1/25/89 8-3-90

A. DOCUMENTATION

Equipment Description Electrical Penetration, Low Voltage Power and Control
Vendor/Manufacturer Conax Corporation
Equipment Model No.(s) 7429-10001 and 7429-10002

QUALIFICATION REPORTS

- (1) Title/Number/Revision "Design Qualifica- RIMS EEB 820115 315
tion Report for Electrical Penetration
Assemblies for Watts Bar Nuclear Plant DATE December 09, 1981
Units 1 & 2"/IPS-752/Rev. A.
- (2) Title/Number/Revision "Design Qualifica- RIMS EEB 811110 300
tion Mtl Test Report for Materials Used in
Conax Electrical Penetration Assemblies DATE May 14, 1981
and Electric Conductor Seal Assemblies"/
IPS-325/Rev. D.
- (3) Title/Number/Revision "Design Qualifica- RIMS EEB 811110 304
tion Test Report of a Low Volt Pwr & Control
Service Classification (BF-LVP/C) Electri- DATE February 11, 1981
cal Penetration Assembly"/IPS-585.3/Rev. A.

|R3

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (5) IPS-325, Rev. E, Design Qualification Material Test Report for Materials Used in Conax Electrical Penetration Assemblies and Electric Conductor Seal Assemblies
- (6) IPS-214, Rev. C, Instruction and Maintenance Manual for Electric Penetration Assemblies for Watts Bar Nuclear Plant, Units 1 and 2
- (7) IPS-213, Rev. 0, Packaging, Shipping, and Storage Procedures |R3
for Electric Penetration Assemblies for Watts Bar Nuclear Plant, Units 1 and 2
- (8) IPS-250, Packaging, Shipping, and Storage Procedures for Spare Parts for Electrical Penetration Assemblies for Watts Bar Nuclear Plant, Units 1 and 2

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 1a OF 29
 R 1 R 2
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 JFW 12-13-89
 1/24/89
 PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/8/86 WCG 12/24/89
 1/25/89

A. DOCUMENTATION (Continued)

- (8) IPS-250, Packaging, Shipping, and Storage Procedures for Spare Parts for Electrical Penetration Assemblies for Watts Bar Nuclear Plant, Units 1 and 2
- (9) Conax Drawing PL7429-10001-01, Rev. C, Sheets 1, 2, & 3 of 3, Parts List
- (10) Conax Drawing PL7429-10001-02, Rev. C, Sheets 1, 2, & 3 of 3, Parts List
- (11) Conax Drawing PL7429-10001-03, Rev. C, Sheets 1, 2, & 3 of 3, Parts List
- (12) Conax Drawing PL7429-10001-04, Rev. C, Sheets 1, 2, & 3 of 3, Parts List
- (13) Conax Drawing PL7429-10001-05, Rev. C, Sheets 1, 2, & 3 of 3, Parts List
- (14) Conax Drawing PL7429-10001-06, Rev. C, Sheets 1, 2, & 3 of 3, Parts List
- (15) Conax Drawing PL7429-10002-01, Rev. D, Sheets 1, 2, & 3 of 3, Parts List
- (16) Conax Drawing PL7429-10002-02, Rev. D, Sheets 1, 2, & 3 of 3, Parts List
- (17) Conax Drawing PL7429-10002-03, Rev. D, Sheets 1, 2, & 3 of 3, Parts List
- (18) Conax Drawing PL7429-10002-04, Rev. D, Sheets 1, 2, & 3 of 3, Parts List
- (19) Conax Drawing PL7429-10002-05, Rev. D, Sheets 1, 2, & 3 of 3, Parts List
- (20) Conax Drawing PL7429-10002-06, Rev. D, Sheets 1, 2, & 3 of 3, Parts List
- (21) Conax Drawing 7429-10001, Rev. E, Sheets 1 & 2 of 2, - LVP Electric Penetrations for Watts Bar Units 1 & 2 (Rev. E in binder for information only. Refer to DCRM for latest revision)

R2

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 1b OF 29
R 2 R 3
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 RCF AFH
12/13/89 8/29/90
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/8/86 KFL 7/10/90
1/8/90 8-30-90

A. DOCUMENTATION (Continued)

- (23) Conax Drawing 7429-24001, Sheet 1, Rev. 0 - Enclosure Sub-Assy
- (24) Conax Drawing 7429-24002, Sheet 1, Rev. A - Enclosure Sub-Assy
- (25) WBN Drawing 45N860-3, R7 - Conduit and Grounding,
Floor E1 702.78, Details - Sheet 1
- (26) WBN Drawing 45W860-10, R8 - Conduit and Grounding, Electrical
Penetration Details
- (27) Watts Bar Environmental Drawings 47E235-41 R1, -42 R2, -44 R1,
and -45 R1. Drawings -41R1, -42R2 and -45R1 have been
modified by DCN P-04104-C (B26 0908 819) and S-09715-A. | R3
- (28) Reference deleted | R3
- (29) Calculation deleted.
- (30) Reference deleted
- (31) Reference deleted
- (32) WBNEQ-GEN-001 - Environmental Qualification Generic Binder
- (33) WBNEQ-SPLC-001 - Environmental Qualification Binder for
Raychem Heat Shrink Splices
- (34) WB-DC-30-5, R3 (B26 880713 055)
- (35) GENAPS3-023 (B04 900320 300)
- (36) WBNEEB-MS-TI06-0002, R6 (B26 900629 422) | R3
- (37) WBNEEB-MS-TI08-0015, R3, (B26 900615 412)
- (38) WBNEEB-MS-TI08-0028, R7, (B26 900615 408)

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET OF
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 JW DATE 1-23-89 R R
PENETRATION, LV POWER & CONTROL CHECKED /R1 WET DATE 1-25-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-4 was deleted per revision 1 .

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 1c of 29 | R1
R 1 R 3
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 8/19/86 JFW 1/23/89
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/20/86 WCG 1/25/89

IPS-752 is the document submitted by Conax Corporation as the key qualification report for the Watts Bar Penetrations. It is a very comprehensive summary report and documents qualification by analysis and comparison to similar modular-type low voltage power and control penetration assemblies of a universal design previously qualified by type tests conducted in accordance with IEEE 317-1976 at levels equal to or more severe than TVA specified requirements for Watts Bar. Most references in this binder are to IPS-752. | R3

IPS-325 documents qualification of Conax Electric Penetration Assemblies from the standpoint of material tests, as a minimum satisfying requirements of Section 6.3 of IEEE 317-1976. Appendix A of IPS-325 includes Conax's thermal evaluation program. IPS-325 is referenced in this binder for identification of materials susceptible to aging degradation and to support Arrhenius Aging Calculations. IPS-325 documents an ongoing test program. Revision D of IPS-325 is referenced in IPS-752 and is included in Binder TAB D, Section D-2. A later revision of IPS-325, Rev. E is included in Binder TAB E, Section E-4, and is referenced in several places in this binder. Contrary to the note on page B3 | R3
IPS-325 revision levels are repeated throughout TAB B.

IPS-585.3 documents tests on the low voltage power and control penetration assembly referred to as test data base one in IPS-752. It is a more detailed test report than IPS-752 that includes raw data and therefore it is referenced in a few places in this binder.

R3

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 2 OF 29
 R 1 R 3
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 JFW 8/16/90
 12/20/88
 PENETRATION, LV POWER & CONTROL CHECKED OM DATE 9/23/86 WCG 7/8/89
 1/25/89

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

Open Item Number

Punchlist Item Number

1

PENT-002-001

R3

COMMENTS/RECOMMENDATIONS These modular-type electrical penetrations are used to convey both safety-related and non-safety related low voltage power and control circuits (480V nominal or less) into primary containment. These penetrations are qualified to maintain pressure integrity and electrical integrity within prescribed limits before, during, and after a LOCA, steam line, CVCS, RHR, or FW break occurring any time within the 40-year plant design life, contingent on satisfactory resolution of open items and qualification deficiencies noted above.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 *gpc* DATE 1-23-89
PENETRATION, LV POWER & CONTROL CHECKED /R1 *web* DATE 1-25-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-7 was deleted per revision 1 .

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 3 OF 29
R R
BINDER TITLE CONAX ELECTRICAL COMPUTED DD DATE 7/26/86
PENETRATION, LV POWER
& CONTROL CHECKED WJR DATE 7/27/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS Contract Date: 11/14/75. Although procured, delivered, and installed prior to 2/22/83, these electrical penetrations meet NUREG-0588, Category I requirements.

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 317-1976 - Standard for Electrical Penetration Assemblies in

Containment Structures for Nuclear Power Generating Stations.

ASME Boiler and Pressure Vessel Code Section III, Subsection NE, for

Class MC Components, 1974 Edition & Addenda Through Winter 1974.

IEEE 344-1975 - Recommended Practices for Seismic Qualification of

Class 1E Equipment for Nuclear Power Generating Stations.

U. S. Nuclear Regulatory Commission Regulatory Guide 1.63, Revision

2, July 1978 - Electric Penetration Assemblies in Containment

Structures for Light-Water-Cooled Nuclear Power Plants.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 4 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DOE DATE 8/19/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WPK DATE 8/20/86

D. QUALIFICATION METHODOLOGY (Check only one block)

 Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

 X Test of Similar Items with Supporting Analysis

 Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

 Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Conax Qualification Report IPS-752, Section

1.2. See binder TAB D, Section D-1 for copy of IPS-752.

IPS-752, Section 4.3 states "The design and construction of the sub-
ject penetrations of Para. 3.1 contains the identical leakage paths,
leak mechanisms, feedthrough concepts, seals, insulation systems,
and materials as test data bases one, two, three, and four and no
differences exist between the test data bases and the Watts Bar
design which would affect qualification."

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 5 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DOE DATE 7/26/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WAK DATE 7/21/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Elec. Pen. LVP & C</u>	<u>Same</u>	<u>IPS-752, Sect. 4.1</u>
(2) Manufacturer	<u>Conax Corporation</u>	<u>Same</u>	<u>IPS-752, Sect. 4.1</u>
(3) Model Number(s)	<u>See TAB A</u>	<u>7508-10003</u>	<u>IPS-585.3, Sect. 4.2</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(4) Serial Number(s)	<u>See TAB F</u>	<u>NA</u>	<u>IPS-585.3 Appx. A</u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(5) Identify Component- Unique checksheet attached:	<u>See TAB B, Supplement 3.</u>		

JUSTIFICATION/COMMENTS Conax Summary Qualification Report IPS-752
documented qualification by analysis and comparison to similar
modular-type low voltage power and control penetration assemblies
previously qualified by type tests conducted at levels equal to or
more severe than TVA specified requirements for Watts Bar. Test data
base one is the applicable test specimen for low voltage power and

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 5A OF 29
R 3 R
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 8/19/86 HL
8/25/86
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/20/86 HL
8-30-86

JUSTIFICATION/COMMENTS (Continued)

control classification penetrations. See IPS-752, Table 4.1, for a
detailed description of the tested penetration (test data base one).
IPS-585.3 is the type test report for test data base one described
in IPS-752. IPS-585.3 is much more detailed and therefore it is
referenced at some points in this binder. Some Watts Bar penetrations
include spliced-on outboard pigtail extension for size 8 AWG and larger
which are not part of test base one. However, the annulus does not
experience any steam accident environment. The splice insulations are
Raychem WCSF-N as shown in instruction manual IPS-214 (binder TAB H,
Section H-1) and are qualified in accordance with binder WBNEQ-SPLC-001.
See Sheets 5B and 5C for correlation of plant devices EQIS No.'s,
Model No.'s, Serial No.'s, and Types.

All WBN Primary Containment Penetrations are tabulated on
TVA Drawing 45N860-3 in binder TAB E, Section E-2. Penetrations
covered in this binder are low voltage power and control types and
are listed on 46N860-3 as being for node voltage levels 3A, 3B, 4A,
and 4B.

R3

Penetrations for node voltage levels 2A, 2B, 2D, 2E, 2F, and 2G are
covered in binder WBNEQ-PENT-003.

R3

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 5B OF 29
 R 3 R
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 *HL*
7/25/86
 PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 7/27/86 *HL*
8-30-86

<u>EQIS NO.</u>		<u>MODEL NO.</u>	<u>SERIAL NO.</u>	<u>TYPE</u>	
					R3
WBN-1-PENT-293-0006	-A	7429-10001-03	374	L.V. Power	
WBN-1-PENT-293-0007	-B	7429-10001-03	375	L.V. Power	
WBN-1-PENT-293-0008	-A	7429-10001-03	376	L.V. Power	
WBN-1-PENT-293-0009	-B	7429-10001-03	383	L.V. Power	
					R3
WBN-1-PENT-293-0014	-A	7429-10002-04	363	L.V. Power	
WBN-1-PENT-293-0015	-A	7429-10002-03	370	L.V. Power	
WBN-1-PENT-293-0016	-B	7429-10002-03	371	L.V. Power	
WBN-1-PENT-293-0017	-A	7429-10002-04	364	L.V. Power	
WBN-1-PENT-293-0021	-A	7429-10002-02	365	L.V. Power	

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 5C OF 29
 R 3 R
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 *7/25/90*
 PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 7/27/86 *7/28*
8-30-90

<u>EQIS NO.</u>		<u>MODEL NO.</u>	<u>SERIAL NO.</u>	<u>TYPE</u>	
					R3
WBN-1-PENT-293-0027	-A	7429-10002-05	358	L.V. Control	
					R3
WBN-1-PENT-293-0036	-B	7429-10002-05	359	L.V. Control	
					R3
WBN-1-PENT-293-0044	-A	7429-10002-05	360	L.V. Control	
					R3
WBN-1-PENT-293-0052	-B	7429-10001-05	379	L.V. Control	

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 6 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86
PENETRATION, LV POWER & CONTROL CHECKED WTK DATE 7/27/86

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>NA-See Note 1 below</u>	<u>NA</u>	<u>NA</u>
Conduit Seals	<u>NA</u>	<u>NA</u>	<u>NA</u>
Connector Seals	<u>NA</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>NA</u>	<u>NA</u>	<u>NA</u>
Physical Configuration	<u>NA-See Note 2 below</u>	<u>Yes</u>	<u>IPS-752, Table 4.1</u>
Other	<u>NA</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Note 1: In-line splice insulations for connection of field cable to penetration conductor pigtails were provided by TVA and are not part of the penetration assembly qualification. See binder WBNEQ-SPLC-001 for splice qualification.

Note 2: Header plate, feedthrough tube material, feedthrough seal, conductor sealants, conductor insulation, copper conductors, installation weld. There are no required external process requirements, no conduit seals (penetrations are seals), and orientation is not a consideration for penetrations.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 7 OF 29
 R 1 R 1
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 AW
2/20/88
1-25-89
 PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 7/26/86 awp

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (Yes/No/NA)? (Note below.)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>NA</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Sect. 5.0</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>Sect. 5.7.4</u>
Radiation	<u>Yes</u>	<u>Sect. 5.7.5</u>
Wear	<u>No</u>	<u>NA</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Sect. 5.12</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>Sect. 5.14.1</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>Sect. 5.14.1</u>
(g) Final inspection and disassembly	<u>No</u>	<u>NA</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately document (Yes/No/NA)? Yes
 (Reference: IPS-585.3, p. 32).

JUSTIFICATION/COMMENTS

G(1)(a) - Although Conax does not state that an initial visual inspection was done, they have completed numerous successful test programs and there is no reason to believe a visual inspection was not done. However, an initial visual inspection is not required by IEEE 317-1976.

G(1)(c) - Electrical penetrations are passive devices and are not subject to wear as an aging mechanism. Wear aging is not required by IEEE 317-1976. The penetrations, however, were subjected to simulated operational stresses which included thermal cycling (IPS-752, Section 5.7.3) and short-term overload and fault current tests (IPS-752, Sections 5.10.1 and 5.11.1) as recommended by IEEE 317-1976. R1

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 7A OF 29
R 3 R _____
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 8/25/90
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 7/27/86 8/25/90
9-30-90

JUSTIFICATION/COMMENTS G(1)(g)-Conax does not state that a final
inspection and disassembly was done, but extensive final evaluation
testing was performed (IPS-752, Section 5.14.2) in accordance with
IEEE 317-1976, fully proving the post-accident integrity and opera-
bility of the assembly. It is reasonable to assume that a manufac-
turer of Conax's experience did make a visual inspection. However,
a final visual inspection and disassembly are not required by
IEEE 317-1976.

G(1)(e) and G(2) - Test data base 1 was exposed to the sequence as
listed above. However, the DBE exposure did not include any chemical
spray. All of the penetrations listed herein are located such that
they are not subject to chemical spray. Per environmental drawing
47E235-42 the only areas in lower compartment subject to chemical
spray outside the crane wall is in Accumulator Room #3 between
Az 242° and 269° below elevation 733 and Accumulator Room #4 between
Az 289° and 305°, below elevation 739.5. None of the penetrations
listed herein are located in these areas.

R3

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 8 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDO DATE 8/19/86
PENETRATION, LV POWER & CONTROL CHECKED WJR DATE 8/20/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference IPS-752, Section 5.7).

JUSTIFICATION/COMMENTS _____

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>IPS-752 Reference</u>
Thermal aging	<u>Yes</u>	<u>Sect. 5.7.4</u>
Radiation exposure	<u>Yes</u>	<u>Sect. 5.7.5</u>
Vibration (non-seismic) aging	<u>No</u>	<u>NA</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>Sect. 5.7.3, 5.9.2, 5.10.1, 5.11.1, 5.12.1, 5.13.1 & 5.15.1</u>

JUSTIFICATION/COMMENTS Vibration aging not required by IEEE 317-1976
(Penetrations are passive devices and vibrational stress is not a sig-
nificant aging degradation mechanism).

- (3) Were all known synergistic effects which are believed to have a
significant effect on equipment performance considered in the aging
program (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS No synergistic effects known for these
penetrations, based on a literature review of applicable materials
data for materials used in Conax L. V. Power and Control
Penetrations.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
(yes/no/NA)? Yes (Reference IPS-752, Section 5.7.4).

PAGE B-17 JUSTIFICATION/COMMENTS Aging based on materials tests and
analysis done in IPS-325 (binder TAB D, Section D-2) by Conax.

BINDER NO. WBNEQ-PENT-QQ2 PLANT WBN UNIT(S) 1 SHEET 9 OF 29
R 1 R 1
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 8/19/86 QW
1-5-87
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/20/86 WCS
1-25-87

H. AGING (Continued)

- (4) (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (Yes/No/NA)? Yes
(Reference: IPS-325, Table 3.1 and IPS-752, Tables 3.2 and 3.3).

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for thermal aging identified in the qualification program (Yes/No/NA)? Yes (Reference: _____
IPS-752, Section 5.7.24.2).

JUSTIFICATION/COMMENTS Thermal aging based on conductor feed-through life. See analysis of feedthrough in IPS-325, Appx. A.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (Yes/No/NA)? Yes (Reference: IPS-752, Section 5.7.24.2).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>	
Temperature	<u>110°F</u>	<u>150°C</u>	<u>120°C</u>	R1
Time	<u>40 yrs.</u>	<u>100 hrs.</u>	<u>40 yrs.</u>	

JUSTIFICATION/COMMENTS See Sheet 9A

- (e) Was the Arrhenius methodolgy used for accelerated aging (Yes/No/NA)? Yes (Reference: IPS-752, Section 5.7.24.2).

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (Yes/No/NA)? Yes
(Reference: IPS-325, Rev. E, Section 6.4.1 (Footnote at bottom of page) in binder TAB E, Section E-4).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 9A OF 29
R 2 R
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 8/19/86 12-13-88
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/20/86 12/20/89

H.(4)(d) Aging:

The thermal age conditioning curve shown in IPS-752, Figure 5.7.1,
shows a 40-year life at 120°C. Note in IPS-752, Table 5.9.4, that
the full load current test ambient temperature (TIA) is greater than
the normal ambient at Watts Bar, the test total operating temperature
(TIF) is less than 90°C in every case, and the test current is greater
than the Watts Bar required current (See *contract 76K61-87064, | R2
Section E4g.(1) in binder TAB E, Section E-1) in every case. There-
fore, a greater than 40-year thermal life is conservatively
established for the subject penetration assemblies. Conax document
IPS-325 covers an ongoing test program. A newer revision of
IPS-325/Rev. E shows the latest Conax calculation of activation
energy for their feed-throughs is 3.916, which agrees closely with
the regression line presented in IPS-325, Figure 5.7.1. See in
binder TAB E, Section E-4, IPS-325, Rev. E, page 26. See Material
Aging Calculation Report WAC-343 in binder TAB C, Section C-1 for | R2
calculation of qualified life at 90°C.

*NOTE - Contract reference is not required for qualification but
is for information only. Refer to DCRM at WBN for latest
revision of Design Specification WBNP-DS-1805-2697-00
applicable to this contract. | R2

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 10 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DOE DATE 8/19/86
PENETRATION, LV POWER & CONTROL CHECKED WJK DATE 8/20/86

H. AGING (Continued)

- (4) (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference IPS-325, Rev. E, Appendix A in binder TAB E, Section E-4).

JUSTIFICATION/COMMENTS Also, see IPS-752, Figure 5.7.1 and
binder sheet 9A.

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference NA).

JUSTIFICATION/COMMENTS Not required by IEEE 317-1976. Aging
time and temperature was sufficient to account for penetration
operating temperature which is ambient, plus temperature rise
due to electrical loading.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference IPS-752, Sect. 5.7.5).

JUSTIFICATION/COMMENTS

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes
(Reference IPS-325, Table 3.1 and IPS-752, Tables 3.2 and 3.3).

JUSTIFICATION/COMMENTS All materials were irradiated to the same level.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? No (Reference NA).

JUSTIFICATION/COMMENTS Dose applied exceeded Watts Bar 40-
year plus accident dose to penetrations.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 11 OF 29
R 1 R
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 WJ
1-23-89
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 7/26/86 WJ
1-25-89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: IPS-752, Section 5.7.5).

Plant normal ambient radiation dose (rd)

2.0E+07

Test exposure dose (rd)

1.28E+08 (H₂O) or

1.156E+08 (air)

R1

Test exposure dose rate (rd/hr)

1.09E+06 (H₂O) or

0.98E+08 (air)

Test exposure source type
(e.g., Co-60 gamma)

Co-60 gamma

JUSTIFICATION/COMMENTS Test exposure dose is the sum of
40-year normal dose plus accident dose. See Sheet 11A
for dose conversion from water to air equivalent.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* No (Reference: NA).

JUSTIFICATION/COMMENTS Not required by IEEE 317-1976.
(Penetrations are passive devices and vibrating stress is
not a significant aging degradation mechanism).

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? NA
(Reference: NA).

JUSTIFICATION/COMMENTS See H(6)(a).

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in Tab C of the binder.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 11A OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 7/24/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WJK DATE 7/27/86

Dose conversion from rads water to rads air for the incident Co-60 gamma ray
flux used in the irradiation portion of the test program is proportional to
the ratio of the mass absorption coefficient (μ_a/ρ) for gamma rays in air and
water, assuming an average Co-60 gamma energy of 1.25 meV. The air
equivalent dose is 1.285×10^8 rads (μ_a/ρ) air / (μ_a/ρ) water or 1.156×10^8
rads. Mass absorption coefficient values of $0.0268 \text{ cm}^2/\text{gm}$ for air and 0.0298
 cm^2/gm for water were used. (Reference: ANL-5800, reactor physics
constants)

In the same manner the test exposure dose rate of 1.09×10^6 rad/hr (water)
converts to 0.98×10^6 rad/hr (air).

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 12 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 7/26/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WKK DATE 7/21/86

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference IPS-752, Sect. 5.7.3, 5.9.2, 5.10.1, 5.11.1, 5.13.1, and 5.15.1).

JUSTIFICATION/COMMENTS Thermal cycle test, continuous current test, short time overload test, short circuit test, repeat continuous current test, and maximum duration of short circuit tests.

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference IPS-752, Sect. 5.7.3, 5.9.2, 5.10.1, 5.11.1, 5.12.1, 5.13.1, & 5.15.1).

JUSTIFICATION/COMMENTS Stresses induced were in accordance with IEEE 317-1976.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes (Reference IPS-752, Sect 1.4).

Qualified life (Document in QMDS) 40 years

JUSTIFICATION/COMMENTS See Justification/Comments in H(9).

BINDER NO. WBNEQ-PENT-QQ2 PLANT WBN UNIT(S) 1 SHEET 13 OF 29
R 1 R 1
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 8/19/86 Wu
1-5-87
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/19/86 WCK
1-25-87

H. AGING (Continued)

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? NA
(Reference: NA

_____).

|R1

JUSTIFICATION/COMMENTS IPS-752, Section 1.4 states
"...materials as used in Conax electric penetration are not
susceptible to any significant degradation due to thermal
aging and radiation and that no age or service related common
failure modes exist that would preclude a qualified life of
40 years."

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 14 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDJ DATE 8/19/86 R R
PENETRATION, LV POWER & CONTROL CHECKED WPK DATE 8/20/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Polysulfone/Sealant</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>
<u>Kapton Polyimide Film/</u>				
(b) <u>Conductor Insulation</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>
(c) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(d) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(e) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS Penetration feedthrough sealant and conductor
insulation materials are considered susceptible to thermal and radiation
degradation implicitly when test programs are developed based on IEEE 317-
1976 guidelines. Testing was done in accordance with IEEE Standard 317-
1976. Test program included tests on insulation and sealant materials. No
materials analysis by TVA is required.
Refer to TAB D, Section D-2, IPS-325, for Conax's discussion of materials
susceptible to thermal and radiation degradation and aging.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 15 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 7/26/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WPK DATE 7/27/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference IPS-752, Sect. 1.5, 5.1.1.1, 5.4.1, 5.5.1 & 5.14.2).

Identify Acceptance Criteria: Baseline acceptance criteria includes leak rate less than 1E-06 SCC/SEC helium, dielectric strength test at 2.7 kV for 5 seconds with no failures, and insulation resistance greater than 1E+08 ohms. During DBA, function and operate at specified service levels without loss of mechanical or electrical integrity. After DBA, gas leak rate less than 1E-02 scc/sec nitrogen, dielectric strength test with no failures, insulation resistance greater than 1E+08 ohms.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference IPS-752, Sect. 5.0, 5.14.1, 5.14.2, and 5.15.3.1).

Identify baseline and functional testing: Baseline testing included gas leak rate, pneumatic pressure, dielectric strength, insulation resistance, and conductor continuity. During DBA test, penetration was energized and carrying load except for 10 intervals when insulation resistance was taken. Post-DBA tests included gas leak rate, dielectric strength, insulation resistance, and conductor continuity.

JUSTIFICATION/COMMENTS Tests were in accordance with IEEE 317-1976.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference IPS-752, Sect. 5.14.1.1 and 5.14.1.2).

PAGE B-26

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 16 OF 29
R 1 R 3
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/23/86 JFW 1/5/89
PENETRATION, LV POWER & CONTROL CHECKED OM DATE 9/23/86 WGG 1/25/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? No (Reference: IPS-752, Sections 5.1 - 5.5).

JUSTIFICATION/COMMENTS Baseline testing consisted of insulation resistance, conductor continuity, and hipot tests which provide an indication of the electrical condition of the penetration, but are not the actual voltage and load carried by the penetrations in service in the plant. Tests were in accordance with IEEE 317-1976.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a)	Parameter	Plant Normal Conditions	Reference
	Voltage	<u>480 VAC, max nom system volt</u>	<u>(34)</u>
	Load	<u>Various</u>	<u>**</u>
	Frequence	<u>NA</u>	<u>NA</u>
	Accuracy	<u>NA</u>	<u>NA</u>
	Other(s)	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Electrical penetrations are not frequency sensitive and have no accuracy requirements.

**See TAB C, Section C-1.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 17 OF 29
 R 1 R 3
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/23/86 JFW 1/23/89 5/16/90
 PENETRATION, LV POWER & CONTROL CHECKED OM DATE 9/23/86 WCG 1/25/89 8-30-90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(5) (b)	<u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>	
	Voltage	<u>526.9 VAC max.</u>	<u>(36)</u>	R3
	Load	<u>Various</u>	<u>**</u>	
	Frequency	<u>NA</u>	<u>NA</u>	
	Accuracy	<u>NA</u>	<u>NA</u>	
	Other(s)	<u>NA</u>	<u>NA</u>	

JUSTIFICATION/COMMENTS **See J.(5)(a). Reference (36) documents that 480 VAC circuits could reach a maximum potential of 526.9 VAC during unit shutdown.

(5) (c)	<u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
			IPS-752 Sections
	Voltage	<u>528 VAC during the DBA Simulation</u>	<u>5.14.1.2</u>
	Load	<u>Various</u>	IPS-752 Section <u>5.14.1.1</u>
	Frequency	<u>60 Hz</u>	IPS-585.3 Sect. 3.2
	Accuracy	<u>NA</u>	<u>NA</u>
	Other(s)		
	Insulation Resistance	<u>1E+06 minimum</u>	IPS-752 Section <u>5.14.1.3</u>
	Leakage Current	<u>0.12 milliamps maximum</u>	IPS-752 Section <u>5.14.1.4</u>

JUSTIFICATION/COMMENTS

The penetration maintained required loads throughout the DBA test. For low voltage power and control penetrations, a minimum insulation resistance of 1E+06 ohms and a maximum leakage current of 0.12 milliamps at the maximum application voltage

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 17a OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 JFW DATE 1-23-89 ^{R 23 R}
PENETRATION, LV POWER & CONTROL CHECKED /R1 WCG DATE 1-25-89 ^{7/25/90}
₈₋₃₀₋₉₀

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

(5) (c)

is also sufficient to support the electrical operability and circuit integrity for category A and B devices served. See generic binder WBNEQ-GEN-001, Section III.C.4 for discussion of low voltage power and control cable applications.

For nondivisional and other devices served that may not be qualified and could fail in an accident, electrical circuit protection has been provided to ensure penetration containment boundary integrity. All divisional circuits are also similarly protected. See references 37 and 38.

R3

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 18 OF 29
 R 2 R 3
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 RCF KFL
 12/13/85 8/29/86
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/8/86 KFL KFL
 1/09/90 8-31-96

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. See Sheet 19a

- | | |
|-----------------------------------|---------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>120</u> | (a) Temperature (°F) <u>130</u> |
| (b) Pressure (psig) <u>0.3</u> | (b) Pressure (psig) <u>0.3</u> |
| (c) Humidity (%) <u>80</u> | (c) Humidity (%) <u>100</u> |
| (d) Radiation (rd) <u>2.0E+07</u> | (d) Radiation (rd) <u>NA</u> |
- (3) Process Interfaces: None.
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Up to eight hours per excursion and occurring less than 1% of plant life. 20°F difference in maximum temperature for this time period is negligible.
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|---|--------------------------------|
| (a) Temperature (°F) ³²⁷ <u>128° long-term</u> | Accident type <u>HELB</u> |
| (b) Pressure (psig) <u>11.2</u> | Accident type <u>LOCA</u> |
| (c) Humidity (%) <u>100</u> | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>1.2E+07 gamma</u> | |
| (d) Radiation (rd) <u>4.7E06 beta</u> | Accident type <u>LOCA</u> |
| (e) *Spray Type <u>N/A</u> | Accident type <u></u> |

R3

*See Tab B, Section G.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 19 OF 29
R 2 R 3
DER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 8/19/86 RCF JFL
12/15/89 7/25/89
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/20/86 KFL JFL
12/28/89 8-30-90

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): One end of each penetration is exposed to annulus environment. Containment ends are in lower compartment (outermost small rooms), or lower compartment instrument room. Parameters shown are worst case; see Sheet 19a.

R3

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: IPS-752, Sect. 5.14.1).

- (7) Subject to submergence (Yes/No/NA)? No Reference: See note 5 on environmental drawing 47 E235-42 for maximum containment water level for flood elevation (EL 717.7 outside crane wall) where penetrations are located and field verification in binder TAB F for location.

R3

Identify initiation time and duration of submergence: NA

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: See Sheet 19a).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: See Sheet 19b

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See Section A

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 19a OF 29
 R 2 R 3
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/23/86 RCF PFL
 12/13/89 7/25/90
 PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 9/23/86 KFL 2/04
 01/09/90 8-30-90

AREA/ENVIRONMENTAL DWG SUMMARY

	Lower* Compartment (47E235-42)**	Annulus (47E235-44)	Instrument Room (47E235-45)**
Max Normal Temperature, °F	120(1) (105)	110	75
Max Abnormal Temperature, °F	130	120	120
Max Normal Pressure, PSIG	0.3	ATM(-)	0.3
Max Abnormal Pressure, PSIG	0.3	ATM(-)	0.3
Max Normal R.H. %	80	80	60
Max Abnormal R.H. %	100	90	90
40-Yr Normal (gamma) Radiation, Rads	2.0E+07	1.0E+06	3.5E+05
Peak Accident Temperature, °F	327	134	327
Peak Accident Pressure, PSIG	11.2	ATM(-)	11.2
Accident (gamma) Radiation, Rads (beta)	1.0E+07 4.7E6(2)	1.2E+07 included	1.0E+07 4.7E6(2)
Total 40-Year Plus Accident Radiation, Rads	3.47E7 gamma plus beta	1.3E+07 gamma plus beta	1.5E7 gamma plus beta

*Fan rooms and accumulator rooms (outermost small rooms).

**These drawings have been modified by DCN P-04104-C and S-09715-A

(1) Documented average temperature. See note 34 on 47E235-42

(2) See Sheet 19b.

R3

BINDER NO. WBNEQ-PENT-QQ2 PLANT WBN UNIT(S) 1 SHEET OF
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 AW DATE 1/24/89 R R
PENETRATION, LV POWER & CONTROL CHECKED /R1 WY DATE 1/25/89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-32 was deleted per revision 1 .

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 19b of 29
R 2 R 3
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 8/19/86 RCF DFL
12/13/89 8/25/90
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/20/86 KFL WBR
01/09/90 8-21-90

The accident beta radiation dose to the penetrations is determined as follows: The maximum containment accident beta dose is $4.7E+08$ rads in accordance with environmental drawing 47E235-45.
(Note: None of these penetrations are located in upper compartments.)

R3

The penetration terminal boxes, which enclose all radiation sensitive materials, are constructed of 18 gauge minimum sheet steel as shown on drawings 7429-24001 and 7429-24002 in TAB I. Per reference 35 the Reduction of Beta Dose by Sheet Steel, for 26 gauge (or thicker) box is less than one percent. Therefore the reduced beta dose is $1.E-2 \times 4.7E8 = 4.7E6$.

R3

R3

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 20 OF 29
 R 2 R 3
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 RCF 12-13-89 *2/27/89*
 PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 7/27/86 KFL 1-9-90 *8-30-90*

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>IPS-752 Reference</u>
Operating Time	<u>100 days</u>	<u>13.54 days</u>	<u>Fig. 5.14.1</u>
Temperature (°F)	<u>327</u>	<u>370</u>	<u>Fig. 5.14.1</u>
Pressure (psig)	<u>11.2</u>	<u>75</u>	<u>Fig. 5.14.1</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>Fig. 5.14.1</u>
Chemical Spray*	<u>N/A</u>	<u>N/A</u>	<u>See Tab B, Section G</u>
Radiation (rd)**	<u>3.47E7 gamma plus beta</u>	<u>1.156E+08(air) or 1.285E+08(H₂O) 2</u>	<u>Sect. 5.7.5</u>
Submergence	<u>None</u>	<u>None</u>	<u>NA</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

^A See page B-31

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>Fig. 5.14.1</u>
Pressure	<u>Yes</u>	<u>Fig. 5.14.1</u>
Relative Humidity	<u>Yes</u>	<u>Fig. 5.14.1</u>
Chemical Spray	<u>NA</u>	<u>N/A</u>
Submergence	<u>NA</u>	<u>N/A</u>

JUSTIFICATION/COMMENTS None of the penetrations listed herein
are located below flood level or subject to chemical spray.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 20a OF 29
R 2 R 3
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 8/19/86 RCF 7/25/90
12/13/89
PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/20/86 KFL 7/25/90
12/20/89

JUSTIFICATION/COMMENTS (Continued)

~~Parameters shown are a composite resultant concentration.~~ All of | R3
these penetrations are enclosed in junction boxes and are not subject
to chemical spray impingement. All penetrations, are protected from | R3
chemical spray by the concrete floor slab above them. These physical
barriers negate the effects of spray. Also see TAB B, sheet 7A,
Justification/Comments for G(1)(e) and G(2). As is seen in TAB C,
Section C-1, Report WAC-343, the test profile does not envelop the
WBN accident profile for approximately the first 100 seconds. This
exists due to starting at a lower temperature and the difficulty in
getting the temperature to rise in the steam chamber as fast as the
WBN accident profile does, a common problem in steam tests. Report
WAC-343 does not include the first test temperature transient. This
extra transient and the significantly higher test temperatures
compensate for the slightly slower transient rise time. Also, noted
in IPS-752, Section 5.14.10.1, testing without a terminal box is
more severe than with the box due to thermal lag and dew point
effects associated with the box. Thus, this small deviation in the
profile for the first few seconds is not significant.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 21 OF 29
 R 2 R 3
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 8/19/86 RCF 12/13/89
 PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 8/20/86 KFL 12/20/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	43°F	Yes
Pressure: +10% but no more than 10 psig	63.8 psig	Yes
Radiation: +10% of accident dose	> 10%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	See TAB C, Sect. C-1	Yes
Voltage: 10% of rated value	480 VAC + 10% during test	Yes
Frequency: 5% of rated value	0 transient	No
Environmental Transient: the initial transient and the peak temperature applied twice	applied twice	Yes
Vibration: +10% added to acceleration	NA	NA

R3

JUSTIFICATION/COMMENTS Margins applied per IEEE 317-1976.

Frequency margin not required by IEEE 317-1976. Electrical penetrations function electrically as insulated conductors, and they are not frequency sensitive in the low frequency range of power and control applications. Sheet 1 of Material Aging Calculation Report WAC-343 (see TAB C, Section C-1) shows the test post-accident operating time equivalent is considerably more than 10% over the Watts Bar required operating time.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 22 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DOE DATE 7/26/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WAX DATE 7/27/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference IPS-752, Sect. 1.5).

JUSTIFICATION/COMMENTS Maintain pressure boundary and electrical integrity.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes (Reference IPS-752, Sect. 5.14.1).

JUSTIFICATION/COMMENTS

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes (Reference IPS-752, Sect. 5.14.1).

JUSTIFICATION/ COMMENTS

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference IPS-752, Sect. 5.14.1 & 5.14.2).

JUSTIFICATION/COMMENTS Test was for 13 1/2 days. See analysis
extending time to 100 days in IPS-752, Sect. 5.14.10.1C.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 23 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 7/26/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED 4/4K DATE 7/26/86

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Reference IPS-585.3,

Sect. 6.18.1.1, 6.21.1.1, and 6.24).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 24 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED OKD DATE 7/26/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WVK DATE 7/27/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See TAB G - QMDS.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 25 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 7/26/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WJK DATE 7/27/86

0. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|--|---------------------------------|
| (1) Documented evidence of qualification adequate
(Have all assumptions, mathematical models, and
all extrapolations of test data used in an
analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary)
adequately justified? | <u>NA (No exceptions taken)</u> |
| (3) Choice of qualification methodology adequately
justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements
identified? | <u>NA</u> |
| (b) Were specific features and failure modes and
effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used
together with appropriate justification for
their use? | <u>NA</u> |
| (d) Were environmental parameters which affect
equipment performance identified? | <u>NA</u> |
| (5) Adequate similarity between equipment and test
specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u> |
| (b) Equipment aged to end of life condition prior to
application of DBE conditions? | <u>Yes</u> |
| (c) Absence of preaging in test/analysis justified? | <u>NA (preaging performed)</u> |
| (d) Materials susceptible to thermal/radiation
aging identified? | <u>Yes</u> |

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 26 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 7/26/86 7/25/90
 PENETRATION, LV POWER & CONTROL CHECKED WBK DATE 7/27/86 7/27/90
8-30-90

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>N/A</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>N/A</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>N/A (See TAB B, Sect. L(2))</u>
(11) Criteria regarding submergence satisfied?	<u>N/A (Penetrations not submerged)</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

R3

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 27 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 7/26/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WJK DATE 7/27/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>NA</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA (penetrations qualified for 100 days)</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 27A OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 7/26/86 R R
PENETRATION, LV POWER CHECKED WJK DATE 7/27/86
& CONTROL

P. DISCUSSION

Conax Report IPS-752 is the qualification document for these penetrations.
The penetrations contain the identical possible leakage paths, leak mech-
anisms, feedthrough concepts, seals, insulation system, and materials as
the test data base penetration No. 1 described in IPS-752. Detailed raw
test data for the tested assemblies is contained in IPS-585.3. IPS-752 is
a summary document of the reports on the tested assemblies. It is a very
thorough summary and is the document submitted by Conax Corporation as the
key qualification report for the subject low voltage power and control
penetration assemblies.

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 28 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED QDB DATE 7/26/86 R R
PENETRATION, LV POWER & CONTROL CHECKED WEX DATE 7/27/86

SUPPLEMENT 3
 COMPONENT-UNIQUE CHECKLIST
 ELECTRICAL PENETRATIONS

Page 1 of 2

EQUIPMENT IDENTIFICATION

- (1) Are the penetrations identified in the qualification program identical to the plant penetrations which require qualification (yes/no/NA)? No

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable Yes/No/NA</u>	<u>IPS-752 Report Section</u>
(a) Penetration type	<u>LVP & C</u>	<u>LVP & C</u>	<u>Yes</u>	<u>Table 4.1</u>
(b) Mounting	<u>See p 29A</u>	<u>See p 29A</u>	<u>Yes</u>	<u>NA</u>
(c) External connections	<u>in-line splices</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>

Comments: TVA provided in-line splices. Conax test was of similar items with supporting analysis, per IPS-752, Sect. 1.0.

- (2) Does the qualification report identify the following performance characteristics:

<u>Performance Characteristics</u>	<u>Acceptable (Yes/No/NA)</u>	<u>IPS-752 Report Section</u>
(a) Temperature rating	<u>Yes</u>	<u>5.7.24.2</u>
(b) Voltage rating	<u>Yes</u>	<u>See Sheet 29A</u>
(c) Continuous current rating	<u>Yes</u>	<u>5.9.5</u>
(d) Short-time overload current rating & duration	<u>Yes</u>	<u>5.10.4</u>
(e) Rated short circuit current & duration	<u>Yes</u>	<u>5.11.2</u>
(f) Pressure rating	<u>Yes</u>	<u>5.1 & 5.2</u>

PAGE B-44

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 29 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 7/24/86
PENETRATION, LV POWER & CONTROL CHECKED WBR DATE 8/8/86

EQUIPMENT IDENTIFICATION (Continued)

Page 2 of 2

<u>Performance Characteristics</u>	<u>Acceptable (Yes/No/NA)</u>	<u>IPS-752 Report Section</u>
(g) Maximum gas leakage rate	<u>Yes</u>	<u>5.1.1.1</u>

Comments: See page 29A

(3) Does the qualification program address the following tests:

<u>Item</u>	<u>Acceptable Yes/No/NA</u>	<u>IPS-752 Report Section</u>
(a) Continuous current rating	<u>Yes</u>	<u>5.9.2</u>
(b) Short-time overload current rating and duration	<u>Yes</u>	<u>5.10.1</u>
(c) Short circuit current rating and duration	<u>Yes</u>	<u>5.11.1</u>
(d) Rated maximum duration of rated short circuit current	<u>Yes</u>	<u>5.15.1</u>
(e) Pneumatic pressure rating	<u>Yes</u>	<u>5.2.1</u>
(f) Maximum gas leakage rate	<u>Yes</u>	<u>5.1.1</u>
(g) Conductor continuity	<u>Yes</u>	<u>5.3.1</u>
(h) Dielectric strength	<u>Yes</u>	<u>5.4.1</u>
(i) Impulse	<u>NA</u>	<u>NA</u>
(j) Insulation resistance	<u>Yes</u>	<u>5.5.1</u>
(k) Flame	<u>Yes</u>	<u>6.3</u>

Comments: Impulse tests not required for low voltage penetrations
per IEEE 317-1976.

PAGE B-45

BINDER NO. WBNEQ-PENT-002 PLANT WBN UNIT(S) 1 SHEET 29A OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 7/24/86 R R
PENETRATION, LV POWER
& CONTROL CHECKED WJK DATE 7/27/86

Additional Comments for Supplement 3

- (1)(b) Watts Bar L. V. Power and Control Penetrations are mounted by welding the penetration assembly header plate to the annulus (outside containment) end of the containment nozzle. The containment nozzles are horizontal. The inboard ends are supported by a support plate resting in the inboard end of the nozzle and located by support rods attached to the header plate. Inside containment junction boxes for connection of penetration conductor pigtails to field cables are bolted to slip-on flanges welded to the inboard end of the containment nozzle. Outside containment junction boxes, where used, are bolted to the penetration header plate in the annulus.

The test penetration assembly was inserted horizontally into the environmental test chamber as shown in IPS-585.3, Appendix D, photographs 5.0 through 8.0. Whether it was bolted in or welded in or whether it incorporated an inboard support plate is not stated, but this is in no way material to the results of the DBA test. No junction boxes were used as stated in IPS-752, Section 5.14.1, which is conservative as discussed in IPS-752, Section 5.14.10.1A.

- (2)(b) The voltage rating of the penetrations is implied but not specifically stated in the qualification report. The voltage rating was specified to be 600 volts in contract 76K61-87064. Dielectric strength tests before the DBA test at 2.7 kV and after the DBA tests at 660 volts are consistent with a voltage rating of 600 volts in accordance with IEEE 317-1976, Sections 4.2.1, 7.3.2, and 6.4.13. See IPS-752, Sections 5.4.1 and 5.14.2.2.

PAGE B-46

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 *gmu* DATE 2-16-89
PENETRATION, INSTRUMENTATION CHECKED /R1 *gmu* DATE 2-17-89
& INDICATION

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building. Actual elevations are documented in TAB F and on drawing 45W860-3 in TAB E.
2. Category and Operating Times for penetrations, which are passive devices, are not assigned directly but are dictated by the category and operating times of devices served.

PEN 1-003

PRINT DATE: 01/20/89

BINDER NO. : WBNEQ-PENT-003
MANUFACTURER : CONAX CORPORATION
PAGE 1 OF 5

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	ALPHA	ELEV(1)	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION	MODEL NUMBER		CONTRACT		(2)			
WBN-1-PENT-293-0018 PRIMARY CONTAINMENT ELEC PENETRATION	-B 1-PENT-293-0018 7429-10003-05	-8 093	737' 7" ANN 76K61-087064		A/B 100/1000 A/B 100/1000 A/B 100/1000 A/B 1M0/1M0 A/B 1M0/1M0	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
WBN-1-PENT-293-0019 PRIMARY CONTAINMENT ELEC PENETRATION	-E 1-PENT-293-0019 7429-10003-03	-E 017	733' 7" ANN 76K61-087064		A/B 100/1000 A/B 100/1000 A/B 100/1000 A/B 1M0/1M0 A/B 1M0/1M0	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
WBN-1-PENT-293-0020 PRIMARY CONTAINMENT ELEC PENETRATION	1-PENT-293-0020 7429-10003-10	116-30	733' 7" ANN 76K61-087064		B 100D B 100D B 100D B 1M0 B 1M0	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B)
WBN-1-PENT-293-0022 PRIMARY CONTAINMENT ELEC PENETRATION	1-PENT-293-0022 7429-10003-10	073-30	718' 10" ANN 76K61-087064		B 100D B 100D B 100D B 1M0 B 1M0	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B).
WBN-1-PENT-293-0023 PRIMARY CONTAINMENT ELEC PENETRATION	-F 1-PENT-293-0023 7429-10003-06	-F 241-45	731' 11" ANN 76K61-087064		A/B 100/1000 A/B 100/1000 A/B 100/1000 A/B 1M0/1M0 A/B 1M0/1M0	LOCA MS/C FW/C RH/C CV/C		MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).

PAGE A-2

PREPARER/DATE DDD 9/15/86

CHECKED/DATE OM 9/18/86

R 1 R R

24/3/89
2-11-89

PRINT DATE: 01/20/39

BINDER NO. : W3NEQ-PENT-003
MANUFACTURER : CONAX CORPORATION
PAGE 2 OF 5

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION ALMITH ELEV(1) RM/BAD CONTRACT	CAT	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-PENT-293-0025 PRIMARY CONTAINMENT ELEC PENETRATION	1-PENT-293-0025 7429-10003-01	254-30° 770° 1" ANN 76K61-087064	B	1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B).
			B	1000	MS/C	
			B	1000	FW/C	
			B	1MO	RH/C	
			B	1MO	CV/C	
WBN-1-PENT-293-0028 PRIMARY CONTAINMENT ELEC PENETRATION	1-PENT-293-0028 7429-10003-02	027 737° 7" ANN 76K61-087064	B	1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B).
			B	1000	MS/C	
			B	1000	FW/C	
			B	1MO	RH/C	
			B	1MO	CV/C	
WBN-1-PENT-293-0029 PRIMARY CONTAINMENT ELEC PENETRATION	1-PENT-293-0029 7429-10003-04	030 737° 7" ANN 76K61-087064	B	1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B).
			B	1000	MS/C	
			B	1000	FW/C	
			B	1MO	RH/C	
			B	1MO	CV/C	
WBN-1-PENT-293-0030 PRIMARY CONTAINMENT ELEC PENETRATION	-B 1-PENT-293-0030 7429-10003-09	-B 021 725° 11" ANN 76K61-087064	A/B	100/1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
			A/B	100/1000	MS/C	
			A/B	100/1000	FW/C	
			A/B	1MO/1MO	RH/C	
			A/B	1MO/1MO	CV/C	
WBN-1-PENT-293-0031 PRIMARY CONTAINMENT ELEC PENETRATION	-G 1-PENT-293-0031 7429-10003-05	-G 025 733° 7" ANN 76K61-087064	A/B	100/1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
			A/B	100/1000	MS/C	
			A/B	100/1000	FW/C	
			A/B	1MO/1MO	RH/C	
			A/B	1MO/1MO	CV/C	

PAGE A-3

PREPARER/DATE DDD 9/15/86
CHECKED/DATE OM 9/18/86
R 1 R R

PRINT DATE: 01/23/89

SINDER NO. : WBNEG-PENT-003
MANUFACTURER : CONAX CORPORATION
PAGE 3 OF 5

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBH-1-PENT-293-0033 PRIMARY CONTAINMENT ELEC PENETRATION	-A 1-PENT-293-0033 7429-10003-04	737' 7" ANN 76K61-087064	A/B A/B A/B A/B A/B	100/100D 100/100D 100/100D 1M0/1M0 1M0/1M0	LOCA MS/C FW/C RH/C CV/C	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
WBN-1-PENT-293-0034 PRIMARY CONTAINMENT ELEC PENETRATION	- 1-PENT-293-0034 7429-10003-02	733' 7" ANN 76K61-087064	B B B B B	100D 100D 100D 1M0 1M0	LOCA MS/C FW/C RH/C CV/C	MAINTAIN PRESSURE BOUNDARY (CAT B).
WBN-1-PENT-293-0037 PRIMARY CONTAINMENT ELEC PENETRATION	-A 1-PENT-293-0037 7429-10003-07	736' 6" ANN 76K61-087064	A/B A/B A/B A/B A/B	100/100D 100/100D 100/100D 1M0/1M0 1M0/1M0	LOCA MS/C FW/C RH/C CV/C	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
WBN-1-PENT-293-0038 PRIMARY CONTAINMENT ELEC PENETRATION	-D 1-PENT-293-0038 7429-10003-03	727' 6" ANN 76K61-087064	A/B A/B A/B A/B A/B	100/100D 100/100D 100/100D 1M0/1M0 1M0/1M0	LOCA MS/C FW/C RH/C CV/C	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
WBN-1-PENT-293-0039 PRIMARY CONTAINMENT ELEC PENETRATION	- 1-PENT-293-0039 7429-10003-02	737' 7" ANN 76K61-087064	B B B B B	100D 100D 100D 1M0 1M0	LOCA MS/C FW/C RH/C CV/C	MAINTAIN PRESSURE BOUNDARY (CAT B).

PAGE A-4

PREPARED/DATE DDD 9/15/86
CHECKED/DATE OM 9/18/86
R1 R R

PRINT DATE: 01/20/89

BINDER NO. : WBNEQ-PENT-003
MANUFACTURER : CONAX CORPORATION
PAGE 4 OF 5

W A T T S B A R N U C L E A R P L A N T
T A B A - E Q U I P M E N T I D E N T I F I C A T I O N M A T R I X

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION ELEV(1) RM/RAD CONTRACT	CAT	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-PENT-293-0040 PRIMARY CONTAINMENT ELEC PENETRATION	-A 1-PENT-293-0040 7429-10003-08	-A 207 737' 7" ANN 76K61-087064	A/B	100/1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
WBN-1-PENT-293-0043 PRIMARY CONTAINMENT ELEC PENETRATION	-D 1-PENT-293-0043 7429-10003-06	-D 205 733' ANN 76K61-087064	A/B	100/1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
WBN-1-PENT-293-0045 PRIMARY CONTAINMENT ELEC PENETRATION	-F 1-PENT-293-0045 7429-10003-03	-F 197 733' ANN 76K61-087064	A/B	100/1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
WBN-1-PENT-293-0049 PRIMARY CONTAINMENT ELEC PENETRATION	-G 1-PENT-293-0049 7429-10003-03	-G 335 733' 1" ANN 76K61-087064	A/B	100/1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B) AND ELECTRICAL INTEGRITY (CAT A).
WBN-1-PENT-293-0050 PRIMARY CONTAINMENT ELEC PENETRATION	- 1-PENT-293-0050 7429-10003-02	339 727' 8" ANN 76K61-087064	B	1000	LOCA	MAINTAIN PRESSURE BOUNDARY (CAT B).

PAGE A-5

PREPARER/DATE DDD 9/15/86
CHECKED/DATE OM 9/18/86

PRINT DATE: 01/20/89

BINDER NO. : WBNEQ-PENT-003
MANUFACTURER : CONAX CORPORATION
PAGE 5 OF 5

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	LOCATION	DESCRIPTION	MODEL NUMBER	ELEV(1) RM/RAD	CONTRACT	CAT	OPER TIME	EVENT	SAFETY FUNCTION
-------------	--------------------	----------	-------------	--------------	----------------	----------	-----	-----------	-------	-----------------

WBN-1-PENT-293-0054	-E 1-PENT-293-0054	-E 306-30	717*10" ANN	76K61-087064						
PRIMARY CONTAINMENT ELEC PENETRATION	7429-10003-06									

A/B 100/100D	LOCA	(MAINTAIN PRESSURE BOUNDARY
A/B 100/100D	HS/C	(CAT 8) AND ELECTRICAL
A/B 100/100D	FW/C	INTEGRITY (CAT A).
A/B 1M0/1M0	RH/C	
A/B 1M0/1M0	CV/C	

PAGE A-6

PREPARER/DATE	DDD	9/15/86	R I	R	R
CHECKED/DATE	OM	9/18/86			

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 29
R 1 R _____
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 *9/16/89*
PENETRATION, INSTRUMENTATION
& INDICATION _____ CHECKED OM DATE 9/18/86 *9/18/89*

A. DOCUMENTATION

Equipment Description Electrical Penetrations, Instrumentation & Indication
Vendor/Manufacturer Conax Corporation
Equipment Model No.(s) 7429-10003-01 through 7429-10003-10

QUALIFICATION REPORTS

- (1) Title/Number/Revision Design Qualification Report for Electrical Penetration Assemblies for Watts Bar Nuclear Plant Units 1&2/IPS-752/Rev. A. RIMS EEB 820115 315
DATE 12/9/81
- (2) Title/Number/Revision Design Qualification Material Test Report for materials used in Conax Electrical Penetration Assemblies and Electric Conductor Seal Assemblies/IPS-325/Rev. D. RIMS EEB 811110 300
DATE 5/14/81
- (3) Title/Number/Revision Test Report Qualification of Instrumentation Service Classification Electric Penetration/IPS-585.2 RIMS EEB 811110 306
DATE 1/18/81
- (4) Title/Number/Revision Test Report Qualification of Conax Instrumentation Classification Coaxial Feedthrough Subassemblies/IPS-585.4 RIMS EEB 811110 303
DATE 1/16/81
- (5) Title/Number/Revision Design Qualification Rpt for a 42 Conductor #18 AWG Conax Low Volt. Service Classification Feedthrough Assembly Consistent with the Requirements of IEEE Standard 317-1976 & NRC Regulatory Guide 1.63. 7/78"/IPS-353.10/Rev. B. RIMS B26 860801 048
DATE 6/23/83

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (6) IPS-325, Rev. E. Design Qualification Material Test Report for Materials Used in Conax Electrical Penetration Assemblies and Electric Conductor Seal Assemblies.

R1

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 1a OF 29
 R 1 R 2
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 JFW 8/11
PENETRATION, INSTRUMENTATION 2/6/89 10-16-89
& INDICATION CHECKED OM DATE 9/18/86 CAG 2/10/89
 2/17/89 10-17-89

QUALIFICATION REPORTS

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (7) IPS-214, Rev C, Instruction and maintenance manual for electric penetration assemblies for Watts Bar Nuclear Plant, Units 1 and 2.
- (8) IPS-213, Packaging, shipping, and storage procedures for electric penetration assemblies for Watts Bar Nuclear Plant, Units 1 and 2.
- (9) IPS-250, Packaging, shipping, and storage procedures for spare parts for electrical penetration assemblies for Watts Bar Nuclear Plant, Units 1 and 2.
- * (10) Conax Drawing 7429-10003, Rev. F, Sheets 1&2 of 2, Electrical Penetrations for Watts Bar. (Rev. E in binder for information only. Refer to DCRM for latest revision) R2
- (11) Conax Drawing 7429-24002, Sheet, Rev A - Enclosure SUB-ASSY.
- (12) Conax Drawing PL7429-10003-01, Rev. E, Sheets 1 & 2 of 2, Parts List.
- (13) Conax Drawing PL7429-10003-02, Rev. E, Sheets 1 & 2 of 2, Parts List.
- (14) Conax Drawing PL7429-10003-03, Rev. E, Sheets 1 & 2 of 2, Parts List.
- (15) Conax Drawing PL7429-10003-04, Rev. E, Sheets 1 & 2 of 2, Parts List.
- (16) Conax Drawing PL7429-10003-05, Rev. E, Sheets 1 & 2 of 2, Parts List.
- (17) Conax Drawing PL7429-10003-06, Rev. E, Sheets 1 & 2 of 2, Parts List.
- (18) Conax Drawing PL7429-10003-07, Rev. E, Sheets 1 & 2 of 2, Parts List.
- (19) Conax Drawing PL7429-10003-08, Rev. E, Sheets 1 & 2 of 2, Parts List.
- (20) Conax Drawing PL7429-10003-09, Rev. E, Sheets 1 & 2 of 2, Parts List.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 1b OF 29
R 1 R 2
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 JFW 8/21
PENETRATION, INSTRUMENTATION 2/17/89 10-16-89
& INDICATION CHECKED OM DATE 9/18/86 CAG 1/82
2/17/89 10-17-89

QUALIFICATION REPORTS (continued)

- (21) Conax Drawing PL7429-10003-10, Rev. E, Sheets 1 & 2 of 2, Parts List.
- * (22) WBN Drawings 45A8601-1 to -54, Electric Penetration connection Drawings.
- (23) WBN Drawing 45N860-3 R9 - Conduit and Grounding - Floor E1702.78, Details - Sheet 1
- (24) 45W860-10, R8 - Conduit and Grounding - Electrical Penetration Details
- * (25) Watts Bar Environmental Drawings 47E235-41 R1, -42 R2, -44 R1, and -45 R1. Drawings -41 R1, -42 R2 and -45 R1 have been modified by DCN P-04104-C (B26 0908819) R2
- (26) TI-RPS-48 (R2) - Integrated Accident Dose Inside Primary Containment (B45 851105 235).
- (28) GENNAL3-002 - Reduction of Beta Dose by Sheet Steel (B45-860423-235). R2
- (29) GENNAL3-013 - Beta Dose Reduction from Finite Volume (B45-860624-235).
- (30) QIR NEB 86160-Beta Dose to Low Voltage Electrical Penetrations (B46 860917 257).
- (31) WBNEQ-IXT-001 - Environmental Qualification Binder for Acoustic Monitors.
- (32) WBNEQ-SPLC-001 - Environmental Qualification Binder for Raychem Heat Shrink Splices.
- * (33) WB-DG-30-5R3 - "Power, Control and Signal Cables for use in Category I Structures - (See TAB G).

* Not Included in Binder.

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 1c OF 29
R 1 R 2
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 JFW HW
PENETRATION, INSTRUMENTATION 2/6/89 10-16-89
& INDICATION CHECKED OM DATE 9/18/86 CAG HW
2/17/89 10-17-89

QUALIFICATION REPORTS (continued)

IPS-752 is the document submitted by Conax Corporation as the key qualification report for the Watts Bar Penetrations. It is a very comprehensive summary report and documents qualifications by analysis and comparison to similar modular-type low voltage power and control penetration assemblies of a universal design previously qualified by type tests conducted in accordance with IEEE 317-1976 at levels equal to or more severe than TVA specified requirements for Watts Bar. Most references in this binder are to IPS-752.

IPS-325 documents qualification of Conax Electric Penetration Assemblies from the standpoint of material tests, as a minimum satisfying requirements of Section 6.3 of IEEE 317-1976. Appendix A of IPS-325 includes Conax's thermal evaluation program. IPS-325 is referenced in this binder for identification of materials susceptible to aging degradation and to support Arrhenius Aging Calculation. IPS-325 documents an ongoing test program. Revision D of IPS-325 is referenced in IPS-752 and is included in Binder TAB D, Section D-2. A later revision of IPS-325, Rev. E, is included in Binder TAB E, Section E-4, and is referenced in several places in this binder. Contrary to the note on sheet 1b, wherever IPS-325 is referenced in this binder the proper revision level is listed.

IPS-585.4 documents tests on a coax penetration assembly referred to as test data base 3 in IPS-752. It is a more detailed test report than IPS-752 that includes raw data and therefore requires reference in a few places in this binder. Only the RG-59 coax is applicable to Watts Bar as indicated in IPS-752, Table 4.3.

IPS-585.2 documents tests on an instrumentation penetration assembly referred to as test data base 4 in IPS-752. It also is more detailed than IPS-752, contains raw data, and requires reference in a few places in this binder. IPS-752, Table 4.4 indicates which portions of test data base 4 are applicable to Watts Bar.

IPS-353.10 document qualification tests of a low voltage penetration module consistent with the requirements of IEEE 317-1976. For this binder it provides environmental qualification documentation for chemical spray, supporting IPS-752 in the same way that IPS-325, Rev. D, IPS-585.2, and IPS-585.4 do. |R2

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 *gmu* DATE 2-16-89
PENETRATION, INSTRUMENTATION
& INDICATION CHECKED /R1 *gmu* DATE 2-17-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-5 was deleted per revision 1 .

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 2 OF 29
R 1 R 2
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 JFW 9W
PENETRATION, INSTRUMENTATION 2/6/89 10-16-89
& INDICATION CHECKED OM DATE 9/18/86 CAG HAR
2/17/89 10-17-89

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

<u>Open Item Number</u>	<u>Punchlist Item Number</u>
<u>1</u>	<u>PENT-003-001</u>
<u>2</u>	<u>PENT-003-002</u>

|R2

COMMENTS/RECOMMENDATIONS These modular-type electrical penetrations are used to convey both safety related and non-safety related low voltage indication, communications, annunciation, and instrumentation circuits into primary containment. These penetrations are qualified to maintain pressure integrity and electrical integrity for the worst case postulated environmental conditions at their location before, during and after a LOCA or steam line break occurring any time within the 40 year plant design life, pending satisfactory resolution of the above open items.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 *gfu* DATE 2-16-89
PENETRATION, INSTRUMENTATION
& INDICATION CHECKED /R1 *gfu* DATE 2-17-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-7 was deleted per revision 1 .

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 3 OF 29
R 1 R _____
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 gfw
PENETRATION, INSTRUMENTATION 2-16-84
& INDICATION _____ CHECKED OM DATE 9/18/86 CLP
2-17-84

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

_____ Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS Contract Date: Nov. 14, 1975. Although
procured, delivered, and installed prior to February 22, 1983,
these electrical penetrations meet NUREG-0588, Category I
Requirments.

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET
IEEE 317-1976 - Standard for Electrical Penetration Assemblies in
Containment Structures for Nuclear Power Generating
Stations.

IEEE 323-1974 - Standard for Qualifying Class 1E Equipment for
Nuclear Power Generation Station.

ASME Boiler and Pressure Code, Section III, Subsection NE, for
Class MC Components, 1974 Edition, and Addenda
through Winter 1974.

R1

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 4 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DD DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION & INDICATION CHECKED Am DATE 9.18.86

D. QUALIFICATION METHODOLOGY (Check only one block)

 Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

 X Test of Similar Items with Supporting Analysis

 Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

 Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Conax Qualification Report IPS-752.

Section 1.2. See binder TAB D, Section D-1 for copy of IPS-752.

IPS-752. Section 4.3 states "The design and construction of the
subject penetrations of para. 3.1 contains the identical leakage
paths, leak mechanisms, feedthru concepts, seals, insulation systems,
and materials as test data bases one, two, three, and four and no
differences exist between the test data bases and the Watts Bar
Design which would affect qualification." Test data bases 3 and 4
are the applicable test items for this binder. See IPS-752,
Table 3.3 for a general description of the WBN LVI type penetration
and Tables 4.3 and 4.4 for a description of the test data bases.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 5 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION CHECKED Qm DATE 9-18-86
& INDICATION

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Elec. Pene.</u>	<u>Elec. Pene.</u>	<u>IPS-752</u>
	<u>Instr. & Ind.</u>	<u>Assemblies</u>	<u>Sec. 4.1</u>
(2) Manufacturer	<u>Conax</u>	<u>Conax</u>	<u>IPS-752</u>
	<u>Corporation</u>	<u>Corporation</u>	<u>Sec. 4.1</u>
(3) Model Number(s)	<u>See TAB A</u>	<u>Data Base</u>	<u>IPS-752</u>
		<u>Three</u>	<u>Table 4.3</u>
		<u>Data Base</u>	<u>IPS-752</u>
		<u>Four</u>	<u>Table 4.4</u>
(4) Serial Number(s)	<u>See TAB F</u>	<u>Not stated</u>	<u>NA</u>
(5) Identify Component- Unique checksheet attached:	<u>See TAB B, Supplement 3</u>		

JUSTIFICATION/COMMENTS

IPS-752, Section 4.3 states "The design and construction of the
subject penetrations of para. 3.1 contains the identical leakage
paths, leak mechanisms, feedthru concepts, seals, insulation systems,
and materials as test data bases one, two, three, and four and no
differences exist between the test data bases and the Watts Bar
Design which would affect qualification." Test data bases 3 and 4
are the applicable test items for this binder. See IPS-752,
Table 3.3 for a general description of the WBN LVI type penetration
and Tables 4.3 and 4.4 for a description of the test data bases.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 5a OF 29
R 1 R 2
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 JFW 8/16/89
PENETRATION, INSTRUMENTATION 2/6/89 10-16-89
& INDICATION CHECKED OM DATE 9/20/86 CAG 10-17-89
2/17/89 10-17-89

EQUIPMENT DESCRIPTION (Continued)

IPS-585.2 and IPS-585.4 are the type test reports for test data bases three and four described in IPS-752. IPS-585.2 and IPS-585.4 are much more detailed and therefore require reference at some points in this binder. Test data base 3 is the test item for RG-59 coax. Test data base 4 is the test item for RG-11 triax, 14 AWG, 16 AWG, and thermocouple types. Other conductor types in the test items (RG-114 for example) are not used at Watts Bar. See *Contract 76K61-87064 in | R2
TAB E, Section E-1, for description of WBN penetrations. Although Conax does state a type for test data bases 3 or 4, they include the conductor types TVA used for instrumentation, indication, communication, and annunciation circuits in the electrical penetrations at WBN.

See sheet 5b for correlation of WBN plant device EQIS numbers, model numbers, serial numbers, and types. Test data bases do not have model or serial numbers. This is not significant since the test data bases include the same conductor types as the WBN penetrations and Conax states there are no significant differences that would affect qualification.

All WBN primary containment electrical penetrations are tabulated on TVA Drawing 45N860-3 in binder TAB E, Section E-2. Penetrations covered in this binder are instrumentation and indication types and are listed on 45N860-3 as being for node voltage levels 1, 1A, 1B, 2, 2A, 2B, 2D, 2E, 2F, and 2G. (Penetrations for node voltage level 5 are covered in ~~Binder WBNEQ-PENT-001 and those for node voltage levels 3, 3A, 3B, 4, 4A, and 4B are covered in Binder WBNEQ-PENT-002).~~

*Note: Contract reference is not required for qualification but is for information only. Refer to DCRM at WBN for latest revision of Design Specification WBNP-DS-1805-2697-00 applicable to this contract. | R2

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 5b OF 29
 R 1 R
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 240
PENETRATION, INSTRUMENTATION 246-84
 & INDICATION CHECKED OM DATE 9/18/86 247-84

EQUIPMENT DESCRIPTION (Continued)

<u>EQIS NO.</u>	<u>MODEL NO.</u>	<u>SERIAL NO.</u>	<u>TYPE</u>	
<u>WBN-1-PENT-293-0018-B</u>	<u>7429-10003-05</u>	<u>400</u>	<u>Instrumentation</u>	R1
<u>WBN-1-PENT-293-0019-E</u>	<u>7429-10003-03</u>	<u>391</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0020</u>	<u>7429-10003-10</u>	<u>404</u>	<u>Instr. & Indic.</u>	
<u>WBN-1-PENT-293-0022</u>	<u>7429-10003-10</u>	<u>405</u>	<u>Instr. & Indic.</u>	
<u>WBN-1-PENT-293-0023-F</u>	<u>7429-10003-06</u>	<u>393</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0025</u>	<u>7429-10003-01</u>	<u>397</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0028</u>	<u>7429-10003-02</u>	<u>385</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0029</u>	<u>7429-10003-04</u>	<u>398</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0030-B</u>	<u>7429-10003-09</u>	<u>402</u>	<u>Instr. & Post- Acc. Rad. Monit.</u>	
<u>WBN-1-PENT-293-0031-G</u>	<u>7429-10003-06</u>	<u>394</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0033-A</u>	<u>7429-10003-04</u>	<u>399</u>	<u>Instrumentation</u>	R1
<u>WBN-1-PENT-293-0034</u>	<u>7429-10003-02</u>	<u>386</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0037-A</u>	<u>7429-10003-07</u>	<u>401</u>	<u>Instr. & Indic. & Post-Acc.Rad.Monit.</u>	
<u>WBN-1-PENT-293-0038-D</u>	<u>7429-10003-03</u>	<u>392</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0039</u>	<u>7429-10003-02</u>	<u>387</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0040-A</u>	<u>7429-10003-08</u>	<u>403</u>	<u>Instr. & Indic.</u>	
<u>WBN-1-PENT-293-0043-D</u>	<u>7429-10003-06</u>	<u>395</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0045-F</u>	<u>7429-10003-03</u>	<u>389</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0049-G</u>	<u>7429-10003-03</u>	<u>390</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0050</u>	<u>7429-10003-02</u>	<u>388</u>	<u>Instrumentation</u>	
<u>WBN-1-PENT-293-0054-E</u>	<u>7429-10003-06</u>	<u>396</u>	<u>Instrumentation</u>	

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 6 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DD DATE 9/15/86 R R
 PENETRATION, INSTRUMENTATION & INDICATION CHECKED Qu DATE 9.18.86

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

Interface	Identify Interface	Plant Requirement? (Yes/No)	Reference Test Report
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>See Note 1</u>	<u>Yes*</u>	<u>IPS-752, Table 4.3 & 4.4</u>
Conduit Seals	<u>NA</u>	<u>NA</u>	<u>NA</u>
Connector Seals	<u>NA</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>NA</u>	<u>NA</u>	<u>NA</u>
Physical Configuration	<u>NA</u>	<u>NA</u>	<u>NA</u>
Other	<u>NA</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS There are no required external process requirements, no conduit seals (penetrations are seals), and orientation is not a consideration for penetrations. The Watts Bar penetrations are welded into their nozzles. (Continued on sheet 6A)

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 6a OF 29
R 1 R _____
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 9/16
PENETRATION, INSTRUMENTATION 3-4-89
& INDICATION _____ CHECKED OM DATE 9/20/86 9/20
2-17-99

INSTALLATION INTERFACES (Continued)

Note 1: Raychem WCSF-N in-line splice insulations for connection of field cables, other than coax and triax, to penetration conductor pigtails were provided by TVA and are not part of the penetration assembly qualification. For coax and triax connectors Conax furnished R1
jacks and plugs with Raychem WCSF-N sleeves. See TVA drawing 45W860-10, detail J10 in binder TAB E, Section E-3, and Conax manual IPS-214, sections 5.4.4 and 5.4.5 in binder TAB H, Section H-1 for installation instructions and details. See binder WBNEQ-SPLC-001 for Raychem
WCSF-N splice insulation qualification. R1

*Interface is an installation requirement but needs no maintenance and is not listed in QMDS.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 7 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION CHECKED Qu DATE 9.18.86
& INDICATION

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>IPS-752 Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>NA</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>5.0</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>5.7.15, 5.7.21</u>
Radiation	<u>Yes</u>	<u>5.7.16, 5.7.22</u>
Wear	<u>No</u>	<u>NA</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>5.12</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>5.14.3, 5.14.5</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>5.14.3, 5.14.5</u>
(g) Final inspection and disassembly	<u>No</u>	<u>NA</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes
 (Reference IPS-585.2, page 32 and IPS-585.4, page 27).

JUSTIFICATION/COMMENTS G(1)(a) Although Conax does not state
that an initial visual inspection was done, they have completed
numerous successful test programs and there is no reason to

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 7A OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DD DATE 9/16/86 R R
PENETRATION, INSTRUMENTATION & INDICATION CHECKED DATE 9.18.86

believe a visual inspection was not done. However, an initial visual
inspection is not required by IEEE 317-1976.

G(1)(c) Electrical penetrations are passive devices and are not subject to
wear as an aging mechanism. Wear aging is not required by IEEE 317-1976.

G(1)(g) Conax does not state that a final inspection and disassembly was
done, but extensive evaluation testing was performed (IPS-752, Sect 5.14.4 and
5.14.6) in accordance with IEEE 317-1976, fully proving post-accident
integrity and operability of the assembly. It is reasonable to assume that a
manufacturer of Conax's experience did make a visual inspection. However, a
final visual inspection and disassembly are not required by IEEE 317-1976.

G(1)(e) and G(2) Test data bases 3 and 4 were exposed to the sequence as
listed above. However the DBA test for test data base 3 did not include
any chemical spray and the DBA test for test data base 4 included only a
short period of spray. Spray compatibility of Conax penetrations was
established in report IPS-353.10 as stated in IPS-752, Section 5.14.10.2.
Report IPS-353.10 documents environmental qualification tests on another
(not test data base 3 or 4) penetration assembly. This assembly received
sequential thermal aging, thermal cycling, radiation exposure, and DBA
accident profile at levels approximately equal to test data bases 3 and 4
and in excess of WBN requirements. Thermal aging was somewhat less and
radiation exposure somewhat more than test data bases 3 and 4. See Conax
Justification/Comparison in IPS-752, Section 5.14.10.

PAGE B-16

PENETRATION, INSTRUMENTATION & INDICATION

CHECKED Ans DATE 9.18.86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference IPS-752, Sec. 5.7).

JUSTIFICATION/COMMENTS

- (2) Were the following effects considered in the aging program:

	IPS-752
<u>Aging Effect</u>	<u>Yes/No/NA</u> <u>Reference</u>
Thermal aging	<u>Yes</u> <u>5.7.15, 5.7.21</u>
Radiation exposure	<u>Yes</u> <u>5.7.16, 5.7.22</u>
Vibration (non-seismic) aging	<u>No</u> <u>NA</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u> <u>5.7.14, 5.7.20</u>

JUSTIFICATION/COMMENTS Vibration aging not required by IEEE 317-
1976 (penetrations are passive devices and vibrational stress is not
a significant aging degradation mechanism).

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS No synergistic effects known for these penetrations, based on a literature review of applicable materials data for materials used in Conax instrumentation and indication penetrations.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference IPS-752, Sec. 5.7.15 and 5.7.21).

JUSTIFICATION/COMMENTS Aging based on materials tests and analysis done in IPS-325 (binder TAB D, Section D-2) by Conax.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 9 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DD DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION & INDICATION CHECKED Ch DATE 9.18.86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference: IPS-325, Table 3.1 and IPS-752, Table 3.3.).

JUSTIFICATION/COMMENTS See IPS-325, Rev. D, in binder TAB D,
Section D-2.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference IPS-752, Sec. 5.7.24.2).

JUSTIFICATION/COMMENTS Thermal aging based on conductor
feedthru life. See analysis of feedthrus in IPS-325,
Appendix A.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference IPS-752, Sec. 5.7.24.2).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test⁽¹⁾</u>	<u>Equivalent</u>
Temperature	110°F ⁽²⁾	150°C	120°C
Time	40 years	100 hrs	40 years

JUSTIFICATION/COMMENTS ⁽¹⁾ Test data base three was aged at 151.6°C
for 102 hours. ⁽²⁾ Worst case, see sheet 19A. See sheet 9A for
discussion of aging.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference IPS-752, Sec. 5.7.24.2)

JUSTIFICATION/COMMENTS

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes
(Reference IPS-325, Rev. E, Sect 6.4.1 (Footnote at bottom of page) in Binder TAB E, Section E-4.

PAGE B-18

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 9a OF 29
R 2 R _____
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 9/15
PENETRATION, INSTRUMENTATION 10-18-89
& INDICATION _____ CHECKED OM DATE 9/18/86 7/10/2
10-16-89

The thermal age conditioning curve shown in IPS-752, Figure 5.7.1 shows a 40 year life at 120°C. This is far greater than the plant maximum normal and maximum abnormal temperature for penetrations (120°F and 130°F, respectively), and therefore a far greater than 40 year qualified life is established for the subject penetrations. There is little or no temperature rise associated with the low power indication, communication, annuciation, and instrumentation circuits passing through these penetrations. |R2

Conax document IPS-325 covers an ongoing test program. A newer revision of IPS-325 (Rev. E) shows the latest Conax calculation of activation energy is 3.916, which agrees closely with the regression line presented in IPS-752, Figure 5.7.1. See page 26 of IPS-325, Rev. E in binder TAB E, Section E-4.

See Material Aging Calculation Report WAC-344, page C-8, in binder TAB C, Section C-1, for calculation of qualified life at 130°F (54.44°C). Worst case maximum normal ambient temperature is 120°F, however the qualified life is calculated at 130°F for conservatism. |R2
|R2

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 10 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION CHECKED Qu DATE 9.18.86
& INDICATION

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference IPS-325, Rev. E,
in Appendix A, binder TAB E, Section E-4).
JUSTIFICATION/COMMENTS Also see IPS-752, figure 5.7.1. and
binder Sheet 9A.

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference NA).
JUSTIFICATION/COMMENTS Not required by IEEE 317-1976.
Aging times and temperatures were based on typical penetra-
tion operating temperature, which is ambient plus temperature
rise due to loading. However, there is little or no
temperature rise for these penetrations which are used for
low power instrumentation, communication, annunciation, and
indication circuits.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference IPS-752, Sec.
5.7.16 and 5.7.22).
(b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes
(Reference IPS-325, Table 3.1 and IPS-752, Table 3.3).
JUSTIFICATION/COMMENTS All materials were irradiated to
the same level.
(c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? No
(Reference NA).
JUSTIFICATION/COMMENTS Dose applied exceeded Watts Bar
40 year plus accident dose to penetrations.

PAGE B-20

BINDER NO. WBNEQ-PENT-003 PLANT .WBN UNIT(S) 1 SHEET 11 OF 29
 R 1 R _____
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 mu
2-6-89
 PENETRATION, INSTRUMENTATION
 & INDICATION _____ CHECKED OM DATE 9/18/86 mu
2-17-84

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: _____).
IPS-752, Sec. 5.7.16 and 5.7.22

Plant normal ambient radiation dose (rd)	<u>2.0E+07 gamma</u>	<u>2.0E+07 gamma</u>	
	Data Base Three	Data Base Four	

Test exposure dose (rd)	<u>1.1E+08(H₂O)</u>	<u>1.9E+08(H₂O)</u>	R1
-------------------------	--------------------------------	--------------------------------	----

Test exposure dose rate (rd/hr)	<u>5.4E+05 (H₂O)</u>	<u>7.7E+05 (H₂O)</u>	
---------------------------------	---------------------------------	---------------------------------	--

Test exposure source type (e.g., Co-60 gamma)	<u>Co-60 Gamma</u>	<u>Co-60 Gamma</u>	
---	--------------------	--------------------	--

JUSTIFICATION/COMMENTS Test exposure dose is the sum of 40 year normal dose plus accident dose. See Sheet 11A for dose conversion from water to air equivalent.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* No (Reference: NA). R1

JUSTIFICATION/COMMENTS Not required by IEEE 317-1976 (penetrations are passive devices and vibrational stress is not a significant aging degradation mechanism).

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? NA (Reference: NA).

JUSTIFICATION/COMMENTS See H(6)(a)

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. R1

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 11A OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 9/16/86 R R
PENETRATION, INSTRUMENTATION & INDICATION CHECKED Qu DATE 9.18.86

Dose conversion from rads water to rads air for the incident Co-60 gamma ray flux used in the irradiation portion of the test program is proportional to the ratio of the mass absorption coefficient (Na/p) for gamma rays in air and water, assuming an average Co-60 gamma energy of 1.25 meV. The air equivalent dose for test data base 3 is 1.1×10^8 rads water $\times \frac{(Na/p)_{air}}{(Na/p)_{water}} = 0.989 \times 10^8$ rads air. Mass absorption coefficient values of $0.0268 \text{ cm}^2/\text{gm}$ for air and $0.0298 \text{ cm}^2/\text{gm}$ for water were used. (Reference: ANL-5800, Reactor Physics Constants). In the same manner the test exposure dose rate of $5.4 \times 10^5 \text{ rad/hr}$ (water) for test data base 3 converts to $4.856 \times 10^5 \text{ rad/hr}$ (air).

For test data base four the test exposure of 1.9×10^8 rads (water) converts to 1.709×10^8 rads (air) and the dose rate of $7.7 \times 10^5 \text{ rads/hr}$ (water) converts to $6.925 \times 10^5 \text{ rads (air)}$.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 12 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 9/16/86 R R
 PENETRATION, INSTRUMENTATION & INDICATION CHECKED Qu DATE 9.18.86

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes
 (Reference IPS-752, Sec. 5.7.13, 5.7.14, 5.7.18, and 5.7.20).

JUSTIFICATION/COMMENTS Shipping and storage tests and thermal cycle test.

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference IPS-752, Sec. 5.7.13, 5.7.14, , 5.7.18, and 5.7.20).

JUSTIFICATION/COMMENTS Stresses induced were in accordance with IEEE 317-1976.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes
 (Reference IPS-752, Sec. 1.4).

Qualified life (Document in QMDS) 40 years

JUSTIFICATION/COMMENTS See Justification/Comments in H(9).

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 13 OF 29
R 1 R _____
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 9/16
PENETRATION, INSTRUMENTATION 24-89
& INDICATION _____ CHECKED OM DATE 9/18/86 9/18
24-89

H. AGING (Continued)

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? No
(Reference: NA _____)

_____).

|R1

JUSTIFICATION/COMMENTS IPS-752, Sec. 1.4 states "...Materials as used in Conax electric penetrations are not susceptible to any significant degradation due to thermal aging and radiation and that no age or service related common failure modes exist that would preclude a qualified life of 40 years."

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 14 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDF DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION & INDICATION CHECKED Qui DATE 9.18.86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Polysulfone/sealant</u> <u>Kapton Polyimide film/</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>
(b) <u>Conductor Insulation</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>
(c) _____	_____	_____	_____	_____
(d) _____	_____	_____	_____	_____
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS Penetration feedthru sealant and conductor
insulation materials are considered susceptible to thermal and radiation
degradation implicitly when test programs are developed based on IEEE
317-1976 guidelines. Testing was done in accordance with IEEE 317-1976
and test program included tests on insulation and sealant materials. No
materials analysis by TVA is required.

Refer to TAB D, Section D-2, IPS-325 for Conax's discussion of materials susceptible to thermal and radiation degradation and aging.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 15 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DD DATE 7/14/86 R R
PENETRATION, INSTRUMENTATION & INDICATION CHECKED Qu DATE 9.18.86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference IPS-752, Sections 1.5, 5.1.3, 5.1.4, 5.5.3, 5.5.4, 5.14.4, and 5.14.6).

Identify Acceptance Criteria: Baseline gas leak rate less than 1E-06 SCC/SEC helium (1E-08 for test data base three). Insulation resistance greater than 1E+08 ohms for 16 AWG, 1E+12 ohms for coax and triax. During DBA, function and operate at specified service levels without loss of mechanical or electrical integrity. After DBA, gas leak rate less than 1E-02 SCC/SEC nitrogen, continuity and dielectric strength test with no failures.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference IPS-752, Sections 5.1.3, 5.1.4, 5.2.1, 5.3.1, 5.4.3, 5.4.4, 5.5.3, 5.5.4, 5.14.3, 5.14.4, 5.14.5, and 5.14.6).

Identify baseline and functional testing: Baseline testing included gas leak rate, pneumatic pressure, dielectric strength, insulation resistance, and conductor continuity. During DBA test, penetrations were energized and leakage current monitored except for 11 intervals when insulation resistance was measured on triax. Post-DBA tests included leak rate, conductor continuity, dielectric strength, and an insulation resistance on the 16 AWG size conductors.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 29
 R 1 R
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 9/15/86
 PENETRATION, INSTRUMENTATION 2-4-86
 & INDICATION CHECKED OM DATE 9/18/86 2-4-86
2-7-86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (Yes/No/NA)? Yes
 (Reference: IPS-752, Sec. 5.14.3.1 and 5.14.5.1)

JUSTIFICATION/COMMENTS

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? No (Reference: IPS-752, Sections 5.1 through 5.5)

JUSTIFICATION/COMMENTS Electrical baseline testing consisted of insulation resistance and hipot tests which provide an indication of the electrical condition of the penetrations but are not the actual voltage and load carried by the penetrations in service in the plant. Tests were in accordance with IEEE 317-1976.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>Various</u>	<u>Open Item</u>
Load	<u>NA</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		

R1

JUSTIFICATION/COMMENTS See J.(5)(b)

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 16a OF 29
 R 1 R _____
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 mc
26-89
 PENETRATION, INSTRUMENTATION
 & INDICATION _____ CHECKED OM DATE 9/18/86 2/4
217-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(5)(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>Various</u>	<u>Open Item</u>
Load	<u>NA</u>	<u>NA</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		

R1

JUSTIFICATION/COMMENTS For instrumentation/indication penetrations the required electrical characteristics depend on the end device served. Category A and B divisional devices served by these penetrations can be categorized into 6 groups.

<u>Group</u>	<u>Device Served</u>
1	Switches
2	Transmitters
3	RTDs
4	Incore Thermocouples
5	Acoustic Monitors
6	GA Post-Accident Radiation Monitors (PAM)

Refer to TVA drawing 45N860-3 in binder TAB E, Section E-2, for a general description of each penetration's use. For a complete tabulation of devices and/or cables connected to each penetration, see TVA drawing series 45A860.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 16B OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DD DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION & INDICATION CHECKED Qu DATE 9-18-86

Except for PAM circuits, category A divisional devices served by these
penetrations operate at a maximum nominal system voltage of 120 VAC or
125 VDC. The PAM monitors are served by RG11 A/U triax modules added to
penetrations 30 and 37. See notes 6 and 7 on TVA Drawing 45W 860-10
binder TAB E, Section E-3) and penetration circuit tabulation Drawing
45A860-3 and 45A860-37. The GA radiation monitor operates at 875 VDC
bias voltage and requires a minimum insulation resistance of 1×10^9
ohms.

These instrumentation and indication penetrations are not assigned any
rated current. Loads served carry 1 ampere or less, with most in the
milliamp range. These small currents cause essentially no heat rise or
other stress in the penetrations.

Electrical penetrations are not frequency sensitive and have no accuracy
requirements themselves. Loop accuracy for the end devices served is
addressed in the individual device binder.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 17 OF 29
 R 1 R 1
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86
 PENETRATION, INSTRUMENTATION 2-6-89
 & INDICATION CHECKED OM DATE 9/18/86
6-17-84

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(5)(c) Parameter	Demonstrated Conditions	Reference	R1
Voltage	300 VDC	IPS-752, Sec. 5.14.3.1 and 5.14.5.1	
Load	50 mA for 16 AWG	IPS-752 Sec. 5.14.5.1	
Frequency	NA	NA	
Accuracy	NA	NA	
Other(s)		IPS-585.2,	
Insulation Resistance for TRIAX	1.0E + 10 ohms minimum	App. A, Sheet 1	R1
Insulation Resistance for 16 AWG	1.8E + 05 ohms minimum	IPS-585.2, App. A, Sheet 3	

JUSTIFICATION/COMMENTS Devices in Groups 1 through 5 switches, transmitters, RTDs, thermocouples and acoustic monitors - See Sheet 16) operate at 125 volts or less. The 300 volt DBA test voltage represents a 140 percent margin.

The Group 6 PAM monitors are the only divisional devices served by these penetrations Triax circuits that must operate after a DBA. Conax performed a baseline dielectric strength test on the Triax module at 5.0kVAC for 1 minute (IPS-752, Sec. 5.4.4) and a post-DBA test at 3.0 KVAC for 5 minutes (IPS-752, Sec. 5.4.4) and a post-DBA test at 3.0 KVAC for 5 minutes (IPS-752, sec. 5.14.6.3) with no breakdown. This shows the basic insulation rating is well over 1000 volts and remains that good after 40 years thermal and radiation aging and a DBA much more severe than the maximum postulated at Watts Bar. During the DBA test, the insulation resistance was measured at 500 VAC on 11 occasions with values ranging from 1.0E+10 to 4.0E+11 ohms (IPS-752, sec. 5.14.5.2), which exceeds the requirement of 1.0E+09 ohms. The first measurement was made at 5 hours with the temperature over 330°F and the pressure over 50 psig, in excess of the peak Watts Bar values. During the DBA test, Conax energized the triax with 300 VDC with maximum measured leakage current of 0.13 milliamps (IPS-752, sec. 5.14.5.1). Assuming leakage current is

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 17a OF 29
 R 1 R _____
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 mu
 PENETRATION, INSTRUMENTATION 2-6-89
 & INDICATION _____ CHECKED OM DATE 9/18/86 2-11-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

JUSTIFICATION/COMMENTS (Continued)

proportional to voltage in this small range indicates a leakage current maximum of 0.38 milliamps at 875 VDC, which is acceptable. Since the triax module passed the post-DBA tests at 3.0 KVAC center conductor to shield with no signs of insulation failure and the insulation resistance values and leakage currents measured during the DBA indicate no problem would be experienced at 875 volts, the triax module is qualified for this service. This is additionally proven by other tests Conax has performed on the same triax modules using 1000 volts during DBA testing. These tests are documented in Conax Qualification Report IPS-1334 and Test Report IPS-1054, which Conax furnished TVA to qualify triax penetrations for identical GA radiation monitors at Sequoyah Nuclear Plant. Those triax modules were originally furnished on Watts Bar Contract 76K61-87064 along with the rest of the penetrations covered in this binder and were transferred to Sequoyah as discussed in Sequoyah Binder SQNEQ-PENE-005. R1

Devices in Groups 1 through 5 are all served by 16 AWG copper conductors in these penetrations. Group 6 devices are served by RG 11A/U Triax. Group 1 switches are very similar to low voltage power and control devices due to their applications, such as 120 volts at 1 amp. A minimum insulation resistance of $1.8E+05$ ohms is acceptable for these applications. Group 5 acoustic monitors do not have accuracy requirements that would be adversely affected by a penetration insulation resistance of $1.8E+05$ ohms minimum. See Binder WBNEQ-IXT001. R1

For Groups 2, 3, 4, and 6, adequacy of penetration DBA insulation resistance is covered by Open Item No. 3 in this binder.

Penetration coax conductors, thermocouple conductors, and 14 AWG conductors do not serve any Category A or B divisional devices and therefore they have no DBA electrical requirements.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 *ju* DATE 2-16-89
PENETRATION, INSTRUMENTATION
& INDICATION CHECKED /R1 *ju* DATE 2-17-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-32 was deleted per revision 1 .

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 18 OF 29
 R 1 R 2
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 JFW 2/4/89
 PENETRATION, INSTRUMENTATION 2/4/89
 & INDICATION CHECKED OM DATE 9/18/86 CAG 2/17/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. See Sheet 19a

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>120</u>	(a) Temperature (°F) <u>130</u> R2
(b) Pressure (psig) <u>0.3</u>	(b) Pressure (psig) <u>0.3</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>100</u>
(d) Radiation (rd) <u>2.0E+07</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Up to 8 hours per excursion and occurring less than 1% of plant life. 20°F difference in maximum temperature for this time period is negligible.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>327</u>	Accident type <u>HELB</u> R2
128° long term	
(b) Pressure (psig) <u>11.2</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>100</u>	Accident type <u>LOCA/HELB</u>
1.34E+07 gamma	
(d) Radiation (rd) <u>3.7E+07</u> beta	Accident type <u>LOCA</u> R1 JAA
(e) Spray Type <u>Chemical*</u>	Accident type <u>LOCA/HELB</u>

*0.19 molar H₃BO₃, 0.033 molar NaOH, pH 8.3.

| R1 JAA

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 19 OF 29
 R 1 R 2
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 JFW 2/6/89
 PENETRATION, INSTRUMENTATION & INDICATION CHECKED OM DATE 9/18/86 CAG 2/17/89
 10-16-89 10-17-89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): One end of each penetration is exposed to annulus environment. Containment ends are in lower compartment (outermost small rooms), lower compartment instrument room, or upper compartment. Parameters shown are worst case: see Sheet 19a.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: IPS-752, Sections 5.14.3 and 5.14.5).

- (7) Subject to submergence (Yes/No/NA)? No (Reference:

See note 5 on environmental drawings for maximum containment water level for flood elevation (EL 717.7 outside crane wall where penetrations are located), and binder TAB A for penetration elevation. Also, see DWG. 45N860-3 in binder TAB E, Section E-2 and field verification in binder TAB F for location).

R2

Identify initiation time and duration of submergence: NA

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: See Sheet 19a).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: See Sheet 19a and QIR NEB 86160 (TAB E, Section E-11)

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See Section A

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 19a OF 29
R 1 R 2
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/16/86 JFW 9/16/89
PENETRATION, INSTRUMENTATION & INDICATION CHECKED OM DATE 9/18/86 CAG 2/17/89

AREA/ENVIRONMENTAL DWG SUMMARY

	Upper Compartment (47E235-41)**	Lower* Compartment (47E235-42)**	Annulus (47E235-44)	Instrument Room (47E235-45)**	R2
Max Normal Temperature, °F	110	120 ⁽¹⁾	110	75	R2
Max Abnormal Temperature, °F	120	130	120	120	
Max Normal Pressure, PSIG	0.3	0.3	ATM(-)	0.3	
Max Abnormal Pressure, PSIG	0.3	0.3	ATM(-)	0.3	
Max Normal R.H. %	80	80	80	60	
Max Abnormal R.H. %	90	100	90	90	
40-Yr Normal (gamma) Radiation, Rads	1.0E+06	2.0E+07	1.0E+06	3.5E+05	
Peak Accident Temperature, °F	161	327	134	327	
Peak Accident Pressure, PSIG	11.2	11.2	ATM(-)	11.2	
Accident Radiation, Rads (gamma)	1.34E+07 ⁽³⁾	1.0E+07	1.2E+07	1.0E+07	
(beta)	3.7E+07 ⁽²⁾	3.7E+07 ⁽²⁾	included	3.7E+07 ⁽²⁾	
Total 40-Year Plus Accident Radiation, Rads	5.14E+07 gamma plus beta	6.7E+07 gamma plus beta	1.3E+07 gamma plus beta	4.735E+07 gamma plus beta	

* Fan rooms and accumulator rooms (outermost small rooms).

** These drawings have been modified by DCN P-04104-C.

R2

(1) Documented average temperature is 105°F.

(2) See QIR release NEB 86160 (TAB E, Section E-11)

(3) See Calculation TI-RPS-48, Sheet 7:19.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE CONAX ELECTRICAL COMPUTED /R1 Jw DATE 2-16-89
PENETRATION, INSTRUMENTATION
& INDICATION CHECKED /R1 Bld DATE 2-17-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-36 was deleted per revision 1 .

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 20 OF 29
 R 1 R
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 9/26/89
 PENETRATION, INSTRUMENTATION
 & INDICATION CHECKED OM DATE 9/18/86 2-17-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

Parameter	Specified	Data Base 3,4	IPS-752	Reference	
		Demonstrated			
Operating Time	<u>100 days</u>	<u>13 days,</u> <u>15 days</u>		<u>Fig. 5.14.2</u> & <u>5.14.3</u>	R1
Temperature (°F)	<u>327</u>	<u>400,395</u>		<u>Fig. 5.14.2</u> & <u>5.14.3</u>	
Pressure (psig)	<u>11.2</u>	<u>70,80</u>		<u>Fig. 5.14.2</u> & <u>5.14.3</u>	R1
Relative Humidity (%)	<u>100</u>	<u>100,100</u>		<u>Fig. 5.14.2</u> & <u>5.14.3</u>	
Chemical Spray*		6200 ppm boron			
		0.19 molar H_3BO_3			R1
		0.033 molar NaOH ³			
	<u>pH 8.3</u>	50 ppm Hydrazine			
		& Trisodium Phos-			
		phate, pH 9.23		<u>5.14.10.2</u>	
		0.989E+08			
		gamma (air)		<u>5.7.16 &</u>	R1
	<u>6.7E+07 gamma</u>	0.709E+08			
Radiation (rd)**	<u>plus beta</u>	<u>gamma (air)</u>		<u>5.7.22</u>	
Submergence	<u>None</u>	<u>None</u>		<u>NA</u>	

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

Parameter	Test Profile	IPS-752
	Envelopes Specified (Yes/No/NA)	
Temperature	<u>Yes</u>	<u>Reference</u> <u>Fig. 5.14.2</u> & <u>5.14.3</u>
Pressure	<u>Yes</u>	<u>Fig. 5.14.2</u> & <u>5.14.3</u>
Relative Humidity	<u>Yes, See Sheet 20B</u>	<u>Fig. 5.14.2</u> & <u>5.14.3</u>
Chemical Spray	<u>NA</u>	<u>Section</u> <u>5.14.10.2</u>
Submergence	<u>NA</u>	

JUSTIFICATION/COMMENTS

L(1) Chemical Spray - Specified containment spray is 30 days and the flow rate is 0.92 gpm/ft². Spray chemistry varies with

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 20a OF 29
 R 2 R
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 9W
PENETRATION, INSTRUMENTATION 10-16-89
& INDICATION CHECKED OM DATE 9/18/86 10-17-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

JUSTIFICATION/COMMENTS (Continued)

time. Parameters shown are a composite resultant concentration. All of these penetrations are enclosed in junction boxes and are not subject to direct chemical spray impingement. All penetrations except No. 25 (which is nondivisional) are additionally protected from chemical spray by the concrete floor slab above them. These physical barriers negate the effect of spray flow rate and difference in spray chemistry. Also see TAB B, sheet 7A, Justification/Comments for G(1)(e) and G(2).

L(1) Radiation - Worst case total radiation is in lower compartment. See Sheet 19a.

L(2) Temperature - As is seen in TAB C, Section C-1, Report WAC-344, the test profiles do not envelop the WBN accident profile for approximately the first 100 seconds. This exists due to starting at a lower temperature and the difficulty in getting the temperature to rise in the steam chamber as fast as the WBN accident profile does, a common problem in steam tests. Report WAC-344 does not include the first test temperature transients. This extra transient and the significantly higher test temperatures compensate for the slightly slower transient rise times. Also, as noted in IPS-752, Section 5.14.10.1, testing without a terminal box is more severe than with the box due to thermal lag and dew point effects, associated with the box. Thus, this small deviation in the profiles for the first few seconds is not significant. |R2

L(2) Relative Humidity - Conax test reports do not state the humidity in the environmental chamber during DBE testing. The relative humidity was not maintained at 100% throughout the entire tests conducted by Conax, but did occur at various times. Because the test profiles were a combination of both the LOCA and HELB conditions, saturated steam, obviously, could not be the test medium throughout. However, portions of the tests were performed under saturated steam, while the HELB conditions were simulated by low humidity superheated steam. Both the temperatures and pressures used throughout the tests were well in excess of maximum Watts Bar values which is conservative for electrical penetrations. |R2

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE CONAX ELECTRICAL COMPUTED /R2 *gaw* DATE 10-16-89
PENETRATION, INSTRUMENTATION
& INDICATION CHECKED /R2 *HOR* DATE 10-18-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-39 was deleted per revision 2 .

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 21 OF 29
 R 1 R 2
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 JFW 9W
 PENETRATION, INSTRUMENTATION 2/6/89 10-16-89
 & INDICATION CHECKED OM DATE 9/18/86 CAG HOR
2/17/89 10-18-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>>15°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>>10 psig</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>>10%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>See Note 1</u>	<u>Yes</u>
Voltage: ±10% of rated value	<u>See Note 2</u>	<u>Yes</u>
Frequency: ±5% of rated value	<u>0</u>	<u>No</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>Transient applied twice</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Electrical penetrations are not frequency sensitive in this range and frequency margin is not required by IEEE 317-1976.

Note 1: Material Aging Calculation Report WAC-344 in binder | R2
TAB C shows the time margin (conservatism factor) far exceeds 10%. Note 2: Voltage margin was 150% of maximum plant voltage for size 16 AWG and 14 AWG conductors used for instrumentation and indication service. Margin was 0 for coax and triax conductors. See discussion on sheet 17a.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 22 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED COO DATE 9/16/86 R R
PENETRATION, INSTRUMENTATION & INDICATION CHECKED Om DATE 9.20.86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference IEEE 317-1976 _____).

JUSTIFICATION/COMMENTS Maintain pressure boundary and
electrical integrity.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference IPS-752, Sec. 5.14.3, 5.14.4, 5.14.5, and 5.14.6).

JUSTIFICATION/COMMENTS

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference IPS-752, Sec. 5.14.3, 5.14.4, 5.14.5, 5.14.6).

JUSTIFICATION/COMMENTS

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference IPS-752, Sec. 5.14.10.1.C).

JUSTIFICATION/COMMENTS Tests were for 13 and 15 days. See
analysis extending time to 100 days in IPS-752, Sec. 5.14.10.1.C.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 23 OF 29
R 1 R _____
BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 2-16-89
PENETRATION, INSTRUMENTATION
& INDICATION CHECKED OM DATE 9/18/86 2-17-89

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: _____)

JUSTIFICATION/COMMENTS

No anomalies were reported in IPS-752 for test data bases three and four. IPS-585.2, Sec. 5.2.6.6.1 does report shipping damage that was the probable cause of eventual problems with the 14 AWG feedthru in test data base four; see IPS-752, Sec. 5.3.3.1. This is reasonable since no problems were experienced with the 16 AWG feedthru of the same design and construction. Also 14 AWG feedthru was included in test data base one and was fully qualified as documented in IPS-752. At Watts Bar 14 AWG conductors do not serve any Category A or B divisional devices. See Sheets 17 through 17a. The minimum measured insulation resistance for 16 AWG during DBE was $1.8E \times 05$ ohm. Adequacy of this value for WBN applications is covered by open item No. 3 in this binder. RG-59 coax and thermocouple conductor types do not serve any Category A or B divisional devices and their DBA electrical characteristics do not need to be addressed.

R1

R1

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 25 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 9/16/86 R R
PENETRATION, INSTRUMENTATION CHECKED my DATE 9.20.86
& INDICATION

0. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|--|--------------------------|
| (1) Documented evidence of qualification adequate
(Have all assumptions, mathematical models, and
all extrapolations of test data used in an
analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified? | NA (No exceptions taken) |
| (3) Choice of qualification methodology adequately justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements identified? | <u>NA</u> |
| (b) Were specific features and failure modes and effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used together with appropriate justification for their use? | <u>NA</u> |
| (d) Were environmental parameters which affect equipment performance identified? | <u>NA</u> |
| (5) Adequate similarity between equipment and test specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u> |
| (b) Equipment aged to end of life condition prior to application of DBE conditions? | <u>Yes</u> |
| (c) Absence of preaging in test/analysis justified? | NA (Preaging performed) |
| (d) Materials susceptible to thermal/radiation aging identified? | <u>Yes</u> |

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 26 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION CHECKED Jim DATE 9.18.86
& INDICATION

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	NA (See TAB B Sec. L(2)) NA (Penet. not submerged)
(11) Criteria regarding submergence satisfied?	<u>submerged</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

PAGE B-45

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 27 OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DDP DATE 9/18/86 R R
PENETRATION, INSTRUMENTATION & INDICATION CHECKED Om DATE 9.18.86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>NA</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA (Penet. qualified for 100 days)</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

Conax Report IPS-752 is the qualification document for these penetra-
tions. The penetrations contain the identical possible leakage paths,
leak mechanisms, feedthru concepts, seals, insulation systems, and
materials as the test data base penetrations number three and four
described in IPS-752. Detailed raw test data for the tested
assemblies is contained in IPS-585.2 and IPS-585.4. IPS-752 is a

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 27A OF 29
BINDER TITLE CONAX ELECTRICAL COMPUTED DD DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION CHECKED DM DATE 9.18.86
& INDICATION

P. DISCUSSION (Continued)

summary document of the reports on the tested assemblies. It is a very
thorough summary and is the document submitted by Conax Corporation
as the key qualification report for the subject penetration
assemblies.

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 28 OF 29

BINDER TITLE CONAX ELECTRICAL COMPUTED DDG DATE 9/15/86 R R

PENETRATION, INSTRUMENTATION & INDICATION CHECKED Om DATE 9.18.86

SUPPLEMENT 3
COMPONENT-UNIQUE CHECKLIST
ELECTRICAL PENETRATIONS

Page 1 of 2

EQUIPMENT IDENTIFICATION

- (1) Are the penetrations identified in the qualification program identical to the plant penetrations which require qualification (yes/no/NA)? No

			Acceptable	Report
			Yes/No/NA	Section
<u>Item</u>	<u>Plant</u>	<u>Report</u>		
	Instrm.&	Instrm.&		Tables
(a) Penetration type	<u>Indication</u>	<u>Indication</u>	<u>Yes</u>	<u>4.3&4.4</u>
		Welded		Tables
(b) Mounting	<u>Welded</u>	<u>& Bolted</u>	<u>Yes</u>	<u>4.3&4.4</u>
	Connectors	Connectors		Tables
(c) External connections	<u>or Splices</u>	<u>or Splices</u>	<u>Yes</u>	<u>4.3&4.4</u>

Comments: Conax test was of similar items with supporting analysis

per IPS-752, Sec. 1.0. TVA provides the in-line splices.

- (2) Does the qualification report identify the following performance characteristics:

<u>Performance Characteristics</u>	<u>Acceptable</u> <u>(Yes/No/NA)</u>	<u>IPS-752</u>	
		<u>Report</u>	<u>Section</u>
(a) Temperature rating	<u>Yes</u>	<u>5.7.24.2</u>	
		<u>5.4.3 &</u>	
(b) Voltage rating	<u>Yes</u>	<u>5.4.4</u>	
(c) Continuous current rating	<u>NA</u>	<u>5.9.4</u>	
(d) Short-time overload current rating & duration	<u>NA</u>	<u>5.10.3</u>	
(e) Rated short circuit current & duration	<u>NA</u>	<u>5.11.3</u>	
(f) Pressure rating	<u>Yes</u>	<u>5.1 & 5.2</u>	

PAGE B-48

BINDER NO. WBNEQ-PENT-003 PLANT WBN UNIT(S) 1 SHEET 29 OF 29
 BINDER TITLE CONAX ELECTRICAL COMPUTED DDD DATE 9/15/86 R R
PENETRATION, INSTRUMENTATION CHECKED Om DATE 9.18.86
& INDICATION

EQUIPMENT IDENTIFICATION (Continued)

Page 2 of 2

<u>Performance Characteristics</u>	<u>Acceptable (Yes/No/NA)</u>	<u>IPS-752 Report Section</u>
(g) Maximum gas leakage rate	<u>Yes</u>	<u>5.1.3 & 5.1.4</u>
Comments: _____		

(3) Does the Qualification program address the following tests:

<u>Item</u>	<u>Acceptable Yes/No/NA</u>	<u>IPS-752 Report Section</u>
(a) Continuous current rating	<u>NA</u>	<u>5.9.4</u>
(b) Short-time overload current rating and duration	<u>NA</u>	<u>5.10.3</u>
(c) Short circuit current rating and duration	<u>NA</u>	<u>5.11.3</u>
(d) Rated maximum duration of rated short circuit current	<u>NA</u>	<u>5.15.6</u>
(e) Pneumatic pressure rating	<u>Yes</u>	<u>5.2</u>
(f) Maximum gas leakage rate	<u>Yes</u>	<u>5.1.3 & 5.1.4</u>
(g) Conductor continuity	<u>Yes</u>	<u>5.3.1</u>
(h) Dielectric strength	<u>Yes</u>	<u>5.4.3 & 5.4.4</u>
(i) Impulse	<u>NA</u>	<u>NA</u>
(j) Insulation resistance	<u>Yes</u>	<u>5.5.3 & 5.4.4</u>
(k) Flame	<u>Yes</u>	<u>6.3</u>

Comments: Impulse tests not require for low voltage penetrations per IEEE 317-1976.

PAGE B-49

SUPPLEMENTAL INFORMATION
TVA'S COMPLIANCE TO 10CFR50.49 - ENVIRONMENTAL QUALIFICATION
OF ELECTRIC EQUIPMENT IMPORTANT TO SAFETY
FOR NUCLEAR POWER PLANTS
VOLUME 5

TABLE OF CONTENTS

<u>BINDER NUMBER</u>	<u>REVISION</u>	<u>EQUIPMENT TYPE</u>	<u>VENDOR</u>
WBNEQ-SOL-001	2	Solenoid Operated Valves Target Rock for NSSS Systems	Target Rock
WBNEQ-SOL-002	2	Solenoid Operated Valves Target Rock for B.O.P. Systems	Target Rock
WBNEQ-SOL-003	5	Solenoid Operated Valves - ASCO Model 206-381	ASCO
WBNEQ-SOL-004	2	MSIV Air Manifold Assembly Solenoid Operated Valves	Gould Allied
WBNEQ-SOL-005	1	Solenoid Operated Valves - ASCO Model 206-380	ASCO
WBNEQ-SOL-006	4	Solenoid Operated Valves - ASCO Model NP8316	ASCO
WBNEQ-SOL-007	2	Solenoid Operated Valves - ASCO Model NP8320	ASCO
WBNEQ-SPLC-001	3	Heat Shrink Cable Splices (600 Raychem VAC or Less)	Raychem
WBNEQ-TB-001	5	Terminal Blocks	General Electric
WBNEQ-XMTR-001	5	Transmitter 764 Lots 7 & 4 (Westinghouse)	Barton
WBNEQ-XMTR-004	4	Transmitter 763 Lot 7	Barton

BINDER NO. WBNEQ-SOL -001 PLANT WBN UNIT(S) 1 SHEET 1
BINDER TITLE SOLENOID VALVES COMPUTED RSP DATE 7/7/86 R —
TARGET ROCK - MODELS 79AB-001 CHECKED SSB DATE 7/4/86
AND 79AB-003

TABLE OF CONTENTS

TAB A

EQUIPMENT IDENTIFICATION

Section A-1 - Tab A, Equipment Identification Matrix

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER		UNIT DEVICE ID NO.		LOCATION		CAT OPER TIME		EVENT SAFETY FUNCTION	
DESCRIPTION		MODEL NUMBER		ELEV(1) RM/RAD		(2)			
MBN-1-FSV -068-0394		-A 1-FSV -068-0394		050		741° 8" LC		A 100D	
REACTOR VESSEL HEAD VENT ISLN VALVE		79AB-001		71C62-54114-1		A 100D		L	
						A 100D		MS/C	
						A 1MO		FW/C	
						A 1MO		RH/C	
						A 1MO		CV/C	
								L	
								TO RELEASE NONCONDENSABLES	
								FROM REACTOR VESSEL HEAD	
MBN-1-FSV -068-0395		-B 1-FSV -068-0395		045-30		742° 3" LC		A 100D	
REACTOR VESSEL HEAD VENT ISLN VALVE		79AB-001		71C62-54114-1		A 100D		L	
						A 100D		MS/C	
						A 100D		FW/C	
						A 1MO		RH/C	
						A 1MO		CV/C	
								L	
								TO RELEASE NONCONDENSABLES	
								FROM REACTOR VESSEL HEAD	
MBN-1-FSV -068-0396		-B 1-FSV -068-0396		060		742° 8" LC		A 100D	
REACTOR VESSEL HEAD VENT THROTTLE VALVE		79AB-003		71C62-54114-1		A 100D		L	
						A 100D		MS/C	
						A 1MO		FW/C	
						A 1MO		RH/C	
						A 1MO		CV/C	
								L	
								TO RELEASE NONCONDENSABLES	
								FROM REACTOR VESSEL HEAD	
MBN-1-FSV -068-0397		-A 1-FSV -068-0397		063		742° 3" LC		A 100D	
REACTOR VESSEL HEAD VENT THROTTLE VALVE		79AB-003		71C62-54114-1		A 100D		L	
						A 100D		MS/C	
						A 1MO		FW/C	
						A 1MO		RH/C	
						A 1MO		CV/C	
								L	
								TO RELEASE NONCONDENSABLES	
								FROM REACTOR VESSEL HEAD	

PAGE 4-2R1

PREPARER/DATE	RJP	7/7/86	R	R
CHECKED/DATE	SRP	7/10/86		

2/23/89
KRA
3/21/89

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE SOLENOID VALVES COMPUTED /R1 *QPM* DATE 2/23/89
TARGET ROCK -
MODELS 79AB-001 AND 79AB-003 CHECKED /R1 *KBN* DATE 3/21/89

TAB A

NOTES

1. Floor/Actual Elevation - All elevations shown are actual elevations as documented on field verification sheets found in TAB F.
2. See TAB B, Section A for Category and Operating Times Calculations used in this binder.
3. Contract Column - Contract numbers shown in this TAB were obtained by tracing the serial number on each valve through TVA procurement records and did not depend on field verification data for contract numbers.

BINDER NO. WBNEQ-SOL -001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE SOLENOID VALVES COMPUTED RSP DATE 7/7/84 R R
TARGET ROCK - MODELS 79AB-001 CHECKED CS DATE 7/10/80
AND 79AB-003

TABLE OF CONTENTS

TAB B

CHECKLIST FOR EVALUATION OF ENVIRONMENTAL QUALIFICATION

Section B-1 - Qualification Checklist

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 24
R 1 R
BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 7/15/86 ATM
TARGET ROCK - 2/23/89
MODELS 79AB-001 AND 79AB-003 CHECKED SRP DATE 7/15/86 SRP
3/21/89

A. DOCUMENTATION

Equipment Description Solenoid Valves
Vendor/Manufacturer Target Rock
Equipment Model No.(s) 79AB-001
79AB-003

QUALIFICATION REPORTS

- (1) Title/Number/Revision Equipment Qualifica- RIMS B45 851205 360
tion Data Package/EODP-HE-10A/Revision 2 DATE January 1985
- (2) Title/Number/Revision Equipment Qualifica- RIMS B45 851205 364
tion Test Report/WCAP-8687.Supp.2-H10A/R2 DATE January 1985
- (3) Title/Number/Revision Equipment Qualifica- RIMS B45 851205 359
tion Data Package/EODP-HE-10C/Revision 1 DATE January 1985
- (4) Title/Number/Revision Equipment Qualifica- RIMS B45 851205 362
tion Test Report/WCAP-8687.Supp.2-H10C/R1 DATE January 1985

NOTE: Throughout this binder, references are made to the above qualification reports which may be identified as "(1)", "(2)", "(3)", or "(4)" as shown in these references.

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (5) Target Rock Test Report No. 4207 (B71 860616 101)
(TAB C, Section C-2)
- (6) Target Rock Letter No. TRC C5815 (B70 851121 004)
(TAB C, Section C-1)
- (7) Target Rock Letter No. TRC C5702 (B71 860616 102)
(TAB E, Section E-2)

R1

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 1a OF 24
R 2 R
BINDER TITLE SOLENOID VALVES COMPUTED /R1 AFM DATE 2/23/89 AFM
TARGET ROCK - 8/24/90
MODELS 79AB-001 AND 79AB-003 CHECKED /R1 KBN DATE 3/21/89 CKL
8/24/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (8) Target Rock Drawing 79AB-001 (TAB I, Section I-1)
- (9) Target Rock Drawing 79AB-003 (TAB I, Section I-2)
- (10) Target Rock Letter dated May 21, 1986, Rims No: B71 860602 001 with attachments (TAB C, Section C-2)
- (11) WBNP Environmental Data Drawing 47E235-42 R2 with DCAs P-04104-02-0, -03-0, -05-0 R2
- (12) Calculation TI-RPS-048 R2 (B45 851105 235), Integrated Accident Dose I/C
- (13) Calculation WBNNAL3-004 R0 (B45 860205 235), Accident Dose Inside Reactor Building
- (14) DNE Calculation WBNTSR-051 (B26 891129 202), Reduction of Beta Dose by Sheet Steel
- (15) Category and Operating Times Calculation WBNOSG4-017 ~~R1~~ R10 R2
(~~B18 900612 252~~)
B18 890828 251
- (16) Calculation WBNOSG4-045 R1 (B45 860902 219), Status and Duty Cycles of Solenoid Valves
- (17) DNE Calculation WBN-EEB-MS-TI11-0004 R0 (B26 900202 407) "125 VDC Voltage Analysis" R2

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 2 OF 24
R 2 R
BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 9/12/86 ASM
TARGET ROCK - 8/24/90
MODELS 79AB-001 AND 79AB-003 CHECKED RKW DATE 9/12/86 CRJ
8/24/90

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

(1) DELETED PER REVISION 2.

(2) DELETED PER REVISION 2.

(3) Deleted per revision 2.

COMMENTS/RECOMMENDATIONS

BINDER TITLE SOLENOID VALVES -
TARGET ROCK - MODELS 79AB-001
AND 79AB-003

COMPUTED RJP DATE 7/7/86 _____
CHECKED SP DATE 7/10/86 _____

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

Components are Qualified to the Criteria of NUREG-0588
Category II or the DOR Guidelines of IE Bulletin No.
79-01B (IEEE323-1971) (DOR Guidelines Applicable to
only BFN)

JUSTIFICATION/COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 382-1972 "IEEE Trial Use Guide for Type Test of Class I
Electric Valve Operators for Nuclear Power Genera-
ting Stations"

IEEE 323-1974 "IEEE standard for Qualifying Class IE Equipment for Nuclear Power Generating Stations"

IEEE 344-1975 "Guide for Seismic Qualification of Class IE Elec-
trical Equipment for Nuclear Power Generating
Stations"

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 4 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R R
TARGET ROCK - MODELS 79AB-001
AND 79AB-003 CHECKED SJ DATE 7/10/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- ☒ X Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- ☐ Test of Similar Items with Supporting Analysis
- ☐ Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- ☐ Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 5 OF 24
 BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 7/7/86 R R
TARGET ROCK - MODELS 79AB-001
AND 79AB-003 CHECKED GR DATE 7/10/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Valve</u>	<u>Solenoid Valve</u>	<u>Ref. (2) & (4)</u>
(2) Manufacturer	<u>Target Rock</u>	<u>Target Rock</u>	<u>Sect. 2.0</u>
(3) Model Number(s)	<u>79AB-001</u>	<u>79AB-001</u>	<u>Ref. (2),</u>
	<u>79AB-003</u>	<u>79AB-003*</u>	<u>Sect. 2.0</u>
(4) Serial Number(s)	<u>See TAB F</u>	<u>55</u>	<u>Ref. (1)</u>
		<u>Design No. 1032110-4</u>	<u>Sect. 2.1</u>
	<u>See TAB F</u>	<u>Design No. 1033110-1</u>	<u>Ref. (4)</u>
(5) Identify Component-Unique checksheet attached:	<u>None</u>		<u>Sect. 2.0</u>

JUSTIFICATION/COMMENTS In references (2) and (4), Section 2.0,
Westinghouse lists solenoid valve design identification numbers that
are considered generically qualified by these reports. The Westing-
house solenoid valve design number (WNEED Tag No.) as specified on
the valve drawings contained in TAB I and listed in the afore-
mentioned references are as follows:

<u>Target Rock Model No.</u>	<u>WNEED Tag No.</u>
79AB-001	1IS88RA
79AB-003	1RS78RA

*The controllers for the Model 79AB-003 modulating valves are located in the Auxiliary Building in a mild environment in the Control Rod Drive Equipment Room, room No. A1.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 6 OF 24
 R 1 R 1
 BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 7/07/86 97M
 TARGET ROCK - 2/23/89
 MODELS 79AB-001 AND 79AB-003 CHECKED SRP DATE 7/10/86 KEA
3/21/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) R1
 If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u> </u>	<u> </u>
External Process Connections	<u>NA</u>	<u> </u>	<u> </u>
Electrical Connections	<u>NA</u>	<u> </u>	<u> </u>
Conduit Seals	<u>Conax Seal Used</u>	<u>Yes</u>	<u>Ref. (2), Sect 5.8</u> <u>Ref. (4), Sect 6.9</u>
Connector Seals	<u>NA</u>	<u> </u>	<u> </u>
Orientation	<u>NA</u>	<u> </u>	<u>Ref. (1), Sect. 1.2</u> <u>Ref. (3), Sect. 1.2</u>
Physical Configuration	<u>NA</u>	<u> </u>	<u> </u>
Other	<u>NA</u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS Refer to QMDS Section B.1 for Conax seal
to be used as required by TVA Environmental Qualification Binder
No. WBNEQ-CSC-001.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 7 OF 24
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 7/16/86
TARGET ROCK - MODELS 79AB-001 AND 79AB-003 CHECKED SRP/xx DATE 7/16/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	Ref. (2) & (4) <u>Sect. 5.3</u>
(b) Baseline performance measurements taken	<u>Yes</u>	Ref. (2) & (4) <u>Sect. 5.3 & Tbl 2</u>
(c) Equipment aged:		Ref. (2), Sect. 5.4.2
Thermal	<u>Yes</u>	Ref. (4), <u>Sect. 5.4</u>
Radiation	<u>Yes</u>	Ref. (2), Sect. 5.5.1 Ref. (4), <u>Sect. 5.5</u>
Wear	<u>Yes</u>	Ref. (2), Sect. 5.4.1 & Sect. 5.4.2 Ref. (4) <u>Sect. 5.4</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	Ref. (2) & (4), <u>Sect. 5.6</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	Ref. (2) & (4), Sections <u>5.7 & 5.8</u>
(f) Post-DBE exposure	<u>Yes</u>	Ref. (2) & (4) <u>Sect. 5.8</u>
(g) Final inspection and disassembly	<u>Yes</u>	Ref. (2), Sect. 6.5 Ref. (4), <u>Sect. 5.8</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes (See comment on sheet 7A).
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? No (See comment on sheet 7B). (Reference Ref. (2) & (4), Table I).

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 7A OF 24
BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R R
TARGET ROCK - MODELS 79AB-001
AND 79AB-003 CHECKED CAF DATE 7/10/86

COMMENT FOR SECTION G(2):

Model 79AB-001: 2 reed switches and cover-to-body gasket were repaired
(Ref. (2), Section 6.5, Pg. 20). Silicone potting around reed switches
had worked loose due to handling and gasket had been broken during
disassembly. Switches were repotted and gasket was repaired with RTV
and the entire solenoid valve was then subjected to the steam/spray
exposure.

Model 79AB-003: Same valve was used. However, during the HELB
simulation the LVDT failed and the terminal board shorted to ground.
These failures were attributed to the fact that the caustic spray/steam
combination had entered the unsealed conduit connection, since the LVDT
did not show insulation degradation due to thermal aging, radiation
aging or cyclic aging. This assumption was proven correct when a new,
unaged LVDT was installed in the test valve and degraded in the same
manner, and at an equivalent time into the HELB test, as the fully aged
LVDT. The second test showed that the degradation was not an aging
related phenomenon, but rather a result of the HELB test environment
entering the electrical compartment and attacking the insulation of the
LVDT. After installation of new LVDT, terminal board, terminal board
strip marker, cover gasket, and Conax conduit seal to prevent HELB test
environment intrusion, the test was successfully completed (Ref. (4),
Sect. 6.9).

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 7B OF 24
BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/15/86 R R
TARGET ROCK - MODELS 79AB-001
AND 79AB-003 CHECKED SEP DATE 7/15/86

COMMENT FOR SECTION G(3):

A list of instrumentation used in testing is attached to qualification report Ref. (2) as Table I; however, accuracy and calibration are not mentioned. In Ref. (4), Table 1 lists equipment and calibration dates but accuracy is not addressed. Even though Westinghouse failed to provide the aforementioned information, it does not significantly impact the qualification status of the valves in this binder, due to the fact that the qualification tests would still envelop the WBN requirements even if an instrumentation inaccuracy as high as 5% was present during testing.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 8 OF 24
 BINDER TITLE SOLENOID VALVES - COMPUTED ESP DATE 7/7/86
TARGET ROCK - MODELS 79AB-001 CHECKED ESP DATE 7/14/86
AND 79AB-003

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes
 (Reference Ref. (2), Sect. 4.1.2 & Ref. (4), Sect. 5.4).

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Ref. (2), Sect. 4.1.2 Ref. (4), Sect. 5.4</u>
Radiation exposure	<u>Yes</u>	<u>Ref. (2), Sect. 4.1.3 Ref. (4), Sect. 5.5</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Ref. (2), & (4), Sect. 5.6.1 Ref. (2), Sect. 5.4.1 Ref. (4), Sect. 5.4</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>Sect. 5.4</u>

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? Yes (Reference Ref. (2), Section 5.1).

JUSTIFICATION/COMMENTS Ref. (4) did not address synergistic effects, however, since similarity of Model 79AB-001 to Model 79AB-003 is documented by Target Rock Letter No. C5815 (see TAB C, Section C-1, Attachment 6) it is safe to conclude that both model valves would not have any synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (Yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.4.2 & Ref. (4), Sect. 5.4).

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes*/No**
(Reference: *Ref. (2), Attachment 3).

JUSTIFICATION/COMMENTS **Ref. (4), Sect. 5.4 and 7.3.5.

Value of 0.5 eV was assumed for all valve components.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.4.2 & Ref. (4), Sect. 5.4).

JUSTIFICATION/ COMMENTS

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.4.2
Ref. (4), Sect. 5.4).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>120°F</u>	<u>325°F</u>	<u>120°F</u>
Time	<u>40 Years</u>	<u>485hrs</u>	<u>6.16 yrs.</u>

JUSTIFICATION/COMMENTS References (2) and (4) state that the thermal aging performed during the tests corresponded to 6.16 years at 120°F assuming an activation energy of 0.5eV. We prove a longer life in TAB C.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.4.2 & Ref. (4), Sect. 5.4).

JUSTIFICATION/COMMENTS

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? No (Reference Ref. (2), Att. 3 & Ref. (4), Sect. 5.4).

JUSTIFICATION/COMMENTS Westinghouse conservatively assumed

an activation energy of 0.5 eV for all valve materials.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 10 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 7/7/86 R R

TARGET ROCK - MODELS 79AB-001

AND 79AB-003 CHECKED SM DATE 7/10/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? N/A (Reference _____).

JUSTIFICATION/COMMENTS

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.4.2 & Ref. (4), Sect. 5.4).

JUSTIFICATION/COMMENTS Both the Model 79AB-001 and Model 79AB-003 were cycled more than 4,850 times during thermal aging.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.5.1 & Ref. (4), Sect. 5.5).

JUSTIFICATION/COMMENTS

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes*/No**
(Reference *Ref. (2), Attachment 3).

JUSTIFICATION/COMMENTS **Ref. (4) radiation qualification by
test.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.5.1 & Ref. (4), Sect. 5.5).

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 11 OF 24
R 1 R 2
BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 7/07/86 AFM AFM
TARGET ROCK - 2/23/89 8/24/90
MODELS 79AB-001 AND 79AB-003 CHECKED SRP DATE 7/10/86 KBN CST
3/21/89 8/24/90

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: _____)

Ref (2), Sect. 5.7 & Ref (4), Sect. 5.5 _____).

Plant normal ambient radiation 7
dose (rd) 2×10^7 rads
*185 Megarads (Mod 79AB-001)
Test exposure dose (rd) *205.1 Megarads (Mod 79AB-003)
Test exposure dose 1.46 Mrad/Hr (Mod 79AB-001)
rate (rd/hr) .67&.75 Mrads/Hr (Mod 79AB-003)

Test exposure source type
(e.g., Co-60 gamma) Co-60 GAMMA

JUSTIFICATION/COMMENTS The tested values of 185 Mrads
and 205.1 Mrads exceed plant TID of 1.34×10^8 rads (see
sheet 18A).
Westinghouse, who designed and installed the head vent
system, determined the radiation dose rates necessary
for qualification of these valves to be 1.75×10^7 rads
GAMMA for a 40 year TID or a 10 year dose of 8.76×10^5
rads GAMMA combined with a 10 year neutron dose of
 3.15×10^{13} N/cm² (reference (2), Att. 2, page 49). The
test enveloped the requirement in that it consisted of
both a 40 year TID of 1.85×10^8 rads GAMMA and a 10
year Neutron dose of 3.52×10^{13} N/cm².

R2

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 11a OF 24
R 1 R _____
BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 7/07/86 2/23/89
TARGET ROCK -
MODELS 79AB-001 AND 79AB-003 CHECKED SRP DATE 7/10/86 3/21/89

H. AGING (continued)

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ Yes (Reference: _____)

Ref. (2) & (4), Sect. 5.6.1 _____).

JUSTIFICATION/COMMENTS _____

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes
(Reference: Ref (2), Sect. 3.1.6, 5.6.1, and Fig 1

Ref. (4), Sect. 3.1.5, 5.6.1, and Fig. 1 _____).

JUSTIFICATION/COMMENTS The vibration aging documented in Ref. (2) & (4) is identical to that in IEEE 382-1980. Vibration aging testing provides a vibratory environment which is representative of normal plant-induced vibration. Normal service flow vibration is not significant for the valves in the binder because vessel head venting is performed only during an accident or after refueling.

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: Ref. (2) & (4), Sect.

5.4 _____).

JUSTIFICATION/COMMENTS _____

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 12 OF 24
R 1 R _____
BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 7/15/86 AFM
TARGET ROCK - 2/23/89
MODELS 79AB-001 AND 79AB-003 CHECKED SRP DATE 7/15/86 KBN
3/21/89

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Rev. (2) & (4)

Sects. 3.4 & 5.4 _____).

JUSTIFICATION/COMMENTS _____

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: Ref (2), Sect. 5.4.2 & Ref. (4), Sect. 5.4

Qualified life (Document in QMDS) 40 years*

JUSTIFICATION/COMMENTS *Providing the elastomers are changed at intervals specified in the QMDS. Westinghouse conservatively qualified the valves for 6.16 years. We have extended elastomer life to 17.3 years using the rationale listed in TAB C.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: Ref. (2), Sect. 6.5 & Ref. (4), Sect. 6.9, p 23

|R1

JUSTIFICATION/COMMENTS The tests qualify the complete valves for 6.16 years based on a very conservative activation energy of 0.5 eV. We prove a longer qualified life in TAB C. of the binder. Also, Section 6.5 of Reference (2) and Section 6.9 of Reference (4) require the cover gasket to be replaced every time it is disturbed or the cover is removed.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 13 OF 24
 R R
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86
 TARGET ROCK - MODELS 79AB-001
 AND 79AB-003 CHECKED SP DATE 7/10/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Class H Insulation/ Solenoid Assy. & LVDT</u>	<u>NA</u>	<u> </u>	<u>See Below</u>	Ref. (2), Att. 3 Ref. (4), Sect. 5.4 TRC Letter C5815
(b) <u>Silicone Rubber (RTV)/ Seal/Potting</u>	<u>NA</u>	<u> </u>	<u>See Below</u>	Ref. (2), Att. 3 Ref. (4), Sect. 5.4
(c) <u>Silicone Rubber/Gasket</u>	<u>NA</u>	<u> </u>	<u>See Below</u>	Ref. (2), Att. 3 Ref. (4), Sect. 5.4
(d) <u>Silicone Rubber/O-Ring</u>	<u>NA</u>	<u> </u>	<u>See Below</u>	Ref. (2), Att. 3 Ref. (4), Sect. 5.4
(e) <u>GP Phenolic/Term. Board</u>	<u>NA</u>	<u> </u>	<u>See Below</u>	Ref. (2), Att. 3 Ref. (4), Sect. 5.4

JUSTIFICATION/COMMENTS Although Reference 4 does not provide a detailed
list of the materials of construction, Target Rock Letter No. TRC C5815
(see Attachment 6, TAB C, Section C-1) states that the materials of
construction are the same for Models 79AB-001 and 79AB-003 except for
the LVDT which is contained only in the Model 79AB-003 valve. The
LVDT in the Model 79AB-003 valve is constructed of Class H insulation
which is listed above. Also, it should be noted that in the above
references, Westinghouse assigned a conservative value of 0.5 eV to
the entire valve. Refer to TAB C, Section C-1, Attachments 1 and 3.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 14 OF 24
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 7/7/86 R R
TARGET ROCK - MODELS 79AB-001
AND 79AB-003 CHECKED LS DATE 7/10/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Ref. (2) & (4), Sect. 5.1).

Identify Acceptance Criteria: Valve model 79AB-001 must shift position under all postulated conditions at maximum and minimum differential pressure upon application of 90-140 VDC power and shift to closed position when power is removed. Valve model 79AB-003 must position proportionally to a 4-20 mA signal corresponding to fully closed and open and with either a loss of power or a signal from the controller return to fully closed and remain closed at any value between the maximum and minimum pressure differential. Position indication must indicate valve states under all conditions.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Ref. (2) & (4), Sect. 5.3).

Identify baseline and functional testing: Hydrostatic proof tests, seat leakage test, operational performance test, insulation and solenoid resistance tests.

JUSTIFICATION/COMMENTS

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Ref. (2), Sect. 4.1.6, 5.7, 5.8, & 6.5 & Ref. (4) Sect. 4.1.6, 5.7, 5.8, & 6.9).

JUSTIFICATION/COMMENTS The valves were connected to high pressure lines and cycled under pressure throughout the DBE, thermal aging, cyclic aging, and vibration aging exposures.

- (4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Ref. (2) & (4), Sect. 5.3)

JUSTIFICATION/COMMENTS Model 79AB-001: Voltage was varied from 55-140 VDC. Valve was under process pressure of 2485 psig. Model 79AB-003: Valve was cycled via controller from fully closed (4mA input to controller) to fully opened (20 mA) while valve was under process pressure of 2500 psig.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 15 OF 24
R 1 R 2
BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 7/07/86 AFM 97M
TARGET ROCK - 2/23/89 8/24/90
MODELS 79AB-001 AND 79AB-003 CHECKED SRP DATE 7/10/86 KBWN 1/28
3/21/89 8/24/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>125 VDC</u>	<u>TVA Drawing 45W600-68-2</u>
Load	<u>1.0 Amps (Max)</u> <u>@ Any Condition</u>	<u>T.R. Dwgs 79AB-001 & 79AB-003</u>
Frequency	<u>NA</u>	
Accuracy	<u>NA</u>	
Other(s)		

JUSTIFICATION/COMMENTS

(b) Parameter	Specific Accident Conditions	Reference
Voltage	<u>84.37 VDC Min.</u>	<u>See comments</u>
Load	<u>See J(5)(a)</u>	
Frequency	<u>NA</u>	
Accuracy	<u>NA</u>	
Other(s)		

JUSTIFICATION/COMMENTS DNE Calculation WBN-EEB-MS-TI11-0004.

SEE TAB C, SECTION C-2 "ACCIDENT VOLTAGE VS OPERATION" FOR
JUSTIFICATION OF OPERATION UNDER SUPPLIED VOLTAGE DURING
AN ACCIDENT.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 15a OF 24
 R 1 R 2
 BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 7/07/86 AFM AFM
 TARGET ROCK - 2/23/89 3/24/90
 MODELS 79AB-001 AND 79AB-003 CHECKED SRP DATE 7/10/86 KBN CRH
3/2/89 3/24/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(c) Parameter	Demonstrated Conditions	Reference
		Ref. (1)&(3)
		Sect. 1.1.1,
Voltage	<u>90-140 VDC</u>	Ref. (2) SECT. 5.1 & 6.5 REF. (4) SECT. 5.8
		Ref. (1)&(3)
Load	<u>NA</u>	Sect. 1.1.3
		Ref. (1)&(3)
Frequency	<u>NA</u>	Sect. 1.1.2
Accuracy	<u>NA</u>	
Other(s)		
	<u>NA</u>	

JUSTIFICATION/COMMENTS THE CONDITIONS LISTED WERE DEMONSTRATED DURING HELB TESTING. IN REFERENCE (2) WESTINGHOUSE STATED THAT THE VALVE WAS ACTUATED DURING THE TEST WITH THE APPLICATION OF 90-140V DC. IN REFERENCE (4) WESTINGHOUSE STATED THAT THE VALVE WAS CYCLED DURING THE HELB TEST UTILIZING A VOLTAGE OF 90 V DC. ALSO, DRAWING NO. 79AB-003 STIPULATES THAT VOLTAGE DROP BETWEEN THE CONTROLLER AND VALVE SHALL NOT EXCEED 2.5 VOLTS AT 1 AMP COIL CURRENT DRAIN. DUE TO THE DISTANCE BETWEEN THE CONTROLLER AND VALVE (488 FT. FOR 1-FSV-68-396), WE EXPECT A VOLTAGE DROP OF 3.33 VOLTS. PER TARGET ROCK'S LETTER NO. CG52 (SEE SECTION E-4), WHICH WAS WRITTEN FOR CONDITIONS AT SQN, THIS WILL NOT INTERFERE WITH OPERATION OF THE VALVE EXCEPT POSSIBLY AT WORST-CASE CONDITIONS WHERE VALVE MAY BE ABLE TO OPEN ONLY 90 PERCENT. SINCE VALVE CV IS HIGHER THAN SPECIFIED, REDUCED FLOW IS NOT A PROBLEM.

SEE TAB C, SECTION C-2 "ACCIDENT VOLTAGE VS OPERATION" FOR JUSTIFICATION OF OPERATION UNDER SUPPLIED VOLTAGE DURING AN ACCIDENT.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 16 OF 24
 R 1 R 2
 BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 9/05/86 AFM 9/22/90
 TARGET ROCK - 2/23/89
 MODELS 79AB-001 AND 79AB-003 CHECKED SRP/AWT DATE 9/08/86 KBN 3/21/89
3/24/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-42

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>120</u>	(a) Temperature (°F) <u>130</u>
(b) Pressure (psia) <u>14.7</u>	(b) Pressure (psia) <u>14.7</u>
(c) Humidity (%) <u>80</u> <u>2×10^7</u>	(c) Humidity (%) <u>100</u>
(d) Radiation (rd) <u>TID</u>	(d) Radiation (rd) <u>N/A</u>

(3) Process Interfaces: The temperature of the process fluid dead-headed against the Model 79AB-001 valves could be the only interface with a significant impact. Since the process fluid is non-condensable gases, which would cool to ambient temperature by the time it reaches the valves through over 50 feet of one inch pipe, it is safe to conclude that the process fluid temperature would have no detrimental effect on the valves.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Will occur less than 1% of plant life and could exist for up to 8 hours per excursion.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>327</u>	Accident type <u>LOCA/HELB</u>
(b) Pressure (psia) <u>25.6</u>	Accident type <u>LOCA/HELB</u>
(c) Humidity (%) <u>100</u>	Accident type <u>LOCA/HELB</u>
(d) Radiation (rd) <u>7.4×10^7 (BETA)*</u> <u>4×10^7 (GAMMA)*</u> <u>2000 ppm Boron</u>	Accident type <u>LOCA/HELB</u>
(e) Spray Type <u>pH 8.3</u>	Accident type <u>LOCA/HELB</u>

* See comment on Sheet 18A.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 17 OF 24
R 1 R
BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 9/05/86 ATM
TARGET ROCK - 2/23/88
MODELS 79AB-001 AND 79AB-003 CHECKED SRP/AWT DATE 9/08/86 KPA
3/2/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): The duration of the containment spray is 30 days. Containment spray flow rate is equal to 9500 Gal/Min or 0.92 GPM per square foot of containment cross section.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: See comment on sheet 17A). | R1

- (7) Subject to submergence (Yes/No/NA)? No (Reference: Dwg. 47E235-42). | R1

Identify initiation time and duration of submergence: Following an accident inside primary containment, only those valves below elevation 722' are subject to submergence. All valves in this binder are above that elevation.

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: TAB B, Section L(1)). | R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: See TAB B, Section L(1)

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B, Section A for a listing of all calculations used in this binder.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 17A OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R R
TARGET ROCK - MODELS 79AB-001
AND 79AB-003 CHECKED ESP DATE 7/10/86

COMMENTS FOR SECTION K(6):

All valves in this binder have Conax conduit seals installed. Refer to
QMDS Section B.1 (Binder TAB G) for Conax seal to be used as required by
TVA Environmental Qualification Binder No. WBNEQ-CSC-001.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 24
 R 2 R
 BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 9/05/86 40M
 TARGET ROCK - 8/24/90
 MODELS 79AB-001 AND 79AB-003 CHECKED SRP/AWT DATE 9/08/86 CAZ
8/24/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

Parameter	Specified	Demonstrated	Reference
Operating Time	<u>100 Days</u>	<u>30 Days</u>	Ref. (2)&(4) Sect. 5.8 Ref. (2), Sect. 5.8 & Fig. 16
Temperature (°F)	<u>327°F</u>	<u>435°F(79AB-001)</u> <u>500°F(79AB-003)</u>	Ref. (4), Fig. 15
Pressure (psig)	<u>25.6 psia</u> <u>(11.2 psig)</u>	<u>57 psig</u> <u>(79AB-001)</u> <u>70 psig</u> <u>(79AB-003)</u>	Ref. (1), Tbl 1, p 16, Ref. (3), Tbl. 1 p 14
Relative Humidity (%)	<u>100%</u>	<u>100%</u>	Ref. (1) & (3), Tbl. 1 Ref. (2), Sect. 3.3.1&5.8
Chemical Spray*	<u>2000ppm Boron</u> <u>pH 8.3;2.92</u> <u>GPM/Ft. 30 Days</u>	<u>2500ppm Boron</u> <u>pH 10.5;2.15</u> <u>GPM/Ft. 23 Hrs</u> <u>1.85x10⁸</u> <u>(79AB-001)</u>	Ref. (4), Sects. 3.3.2.2 & 5.8
Radiation (rd)**	<u>1.34x10⁸</u> <u>(BETA/GAMMA)</u>	<u>2.05x10⁸ rads</u> <u>(79AB-003)</u>	Ref. (1)&(3) Tbl.1,Ref.(2)&(4) Att.1&Sec. 5.7
Submergence	<u>N/A</u>	<u>None</u>	<u>N/A</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type. See comment on sheet 18A.

(2) Comparison of worst-case profiles and margin assessment:

Parameter	Test Profile Envelopes Specified (Yes/No/NA)	Reference
Temperature	<u>Yes</u>	See (1) Above
Pressure	<u>Yes</u>	See (1) Above
Relative Humidity	<u>Yes</u>	See (1) Above
Chemical Spray	<u>Yes</u>	See comment on sheet 18B
Submergence	<u>N/A</u>	<u>N/A</u>

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 18a OF 24
R 1 R 2
BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 7/17/86 AFM 10/1
TARGET ROCK - 2/23/89 8/24/90
MODELS 79AB-001 AND 79AB-003 CHECKED SRP/DLK DATE 7/17/86 KBN 08/1
3/21/89 8/24/90

COMMENTS FOR SECTION L(1) (RADIATION):

The 100-day accident radiation doses given by Environmental Data

Drawing 47E235-42 are 4.7×10^8 rads BETA and 4×10^7 rads GAMMA. R2

Post-DBA BETA Radiation must be addressed for all equipment located inside containment which is required for LOCA mitigation. The valves in this binder are within that scope. All non-metallic parts of these solenoid valves are enclosed by metal and the minimum metal thickness is the cover, which is .048" thick (18 ga) 300-series stainless steel.

DNE Calculation WBNTSR-051 "Reduction of Beta Dose by Sheet Steel," R2

page 3, shows the beta reduction factor for 18-gauge steel is equal

to .158. This reduces the total 100-day BETA dose to the valve

internal parts to $(4.7 \times 10^8) \times (1.58 \times 10^{-1}) = 7.4 \times 10^7$ rads TID BETA. R2

In the Lower Compartment, the total combined 100-day BETA and GAMMA

accident radiation dose will equal $(7.4 \times 10^7 \text{ BETA}) + (4 \times 10^7 \text{ GAMMA}) =$

1.14×10^8 rads. The combined 100-day accident radiation plus the 40 year R2

dose (2×10^7 rads) equal a total radiation dose of 1.34×10^8 rads (BETA/

GAMMA). These Target Rock valves are qualified to 1.85×10^8 rads for

the Model 79AB-001 valves and 2.05×10^8 rads for the Model 79AB-003

valves, which envelop the requirement.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 18B OF 24
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/5/86 R R
TARGET ROCK - MODELS 79AB-001
AND 79AB-003 CHECKED SRP/HWT DATE 9/8/86

COMMENTS FOR SECTION L(1) AND (2) (CHEMICAL SPRAY):

Containment spray flow rate is equal to 9500 gal/min or 0.92 GPM per square foot
of containment cross section. The chemical spray concentration is 2000 ppm
Boron with a pH of 8.3. The test valve was subjected to a spray solution of
2500 ppm Boron with a pH of 10.5. The spray rate was 0.15 GPM per square foot
of projected area of the test valve. The test solution is more corrosive than
the containment spray. Therefore, all valves listed in this binder fall within
the qualification provided by the test valve. Additionally, these valves have
gasketed covers and are not susceptible to spray. This was demonstrated by the
23 hour spray test. Since spray or leakage intrusion is not acknowledged to be
time dependent in enclosed devices, it can be concluded that the device is
qualified for 30 days in spray based on the 23 hour test.

BINDER NO. WENEO-SOL-001 PLANT WBN UNIT(S) 1 SHEET 19 OF 24
R 1 R 2
BINDER TITLE SOLENOID VALVES COMPUTED RJP DATE 9/05/86 ATM ATM
TARGET ROCK - 2/23/89 3/24/90
MODELS 79AB-001 AND 79AB-003 CHECKED SRP/AWT DATE 9/08/86 KBA CSH
3/21/89 3/24/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
(Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

	Margin	
<u>Suggested Margins per IEEE-323(74)</u>	<u>Applied</u>	<u>Yes/No/NA</u>
<u>(Mod. 79AB-001/Mod. 79AB-003)</u>		
Temperature: +15 degrees F	<u>>15°F</u>	<u>Yes</u>
	<u>+45.8 psig/</u>	
Pressure: +10% but no more than 10 psig	<u>+58.8 psig</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>+45%/+62%</u>	<u>Yes</u> R2
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>See Comment</u>	
	<u>Below</u>	<u>No</u>
	<u>+12% to -56%/</u>	
Voltage: ±10% of rated value	<u>+12% to -28%</u>	<u>Yes</u>
Frequency: ±5% of rated value	<u>NA/NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>+108°F/+173°F</u>	<u>Yes</u>
	<u>Ref (2) &</u>	
	<u>(4), Sect.</u>	
(Seismic) Vibration: +10% added to acceleration	<u>5.6.3</u>	<u>Yes</u>

JUSTIFICATION/COMMENTS see TAB C, Section C-2, which proves
the 30-day test envelops the 100-day post-accident requirement.
Voltage variations were applied during testing ranging from
55 VDC minimum to 140 VDC maximum (Model 79AB-001) and 90 VDC
minimum to 140 VDC maximum (Model 79AB-003).

BINDER TITLE	SOLENOID VALVES -
TARGET ROCK	- MODELS 79AB-001
	AND 79AB-003

(1) Identify the safety function(s) of this equipment:
(Reference See TAB A).

Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference Ref. (2), Sect. 6.5 & Ref. (4), Sect. 7.2).

Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference Ref. (2), Sect. 6.5 & Ref. (4), Sect. 6.9).

Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? No (Reference).

Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes
(Reference Ref. (2), Sect. 7.2 & Ref. (4), Sect. 6.2).

PAGE B-28

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 21 OF 24
BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R R
TARGET ROCK - MODELS 79AB-001
AND 79AB-003 CHECKED SP DATE 7/10/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS (Ref. (1) & (3), Section 1.4).

See QMDS (TAB G).

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 22 OF 24
BINDER TITLE SOLENOID VALVES - COMPUTED RSL DATE 7/7/86 R R
TARGET ROCK - MODELS 79AB-001
AND 79AB-003 CHECKED SH DATE 7/10/86

0. SUMMARY OF REVIEW

Yes/No/NA

- | | |
|--|------------|
| (1) Documented evidence of qualification adequate
(Have all assumptions, mathematical models, and
all extrapolations of test data used in an
analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary)
taken to the specified qualification level
adequately justified? | <u>N/A</u> |
| (3) Choice of qualification methodology adequately
justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements
identified? | <u>N/A</u> |
| (b) Were specific features and failure modes and
effects analyzed? | <u>N/A</u> |
| (c) Were assumptions and mathematical models used
together with appropriate justification for
their use? | <u>N/A</u> |
| (d) Were environmental parameters which affect
equipment performance identified? | <u>N/A</u> |
| (5) Adequate similarity between equipment and test
specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u> |
| (b) Equipment aged to end of life condition prior to
application of DBE conditions? | <u>Yes</u> |
| (c) Absence of preaging in test/analysis justified? | <u>N/A</u> |
| (d) Materials susceptible to thermal/radiation
aging identified? | <u>Yes</u> |

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 23 OF 24

BINDER TITLE SOLENOID VALVES -
TARGET ROCK - MODELS 79AB-001
AND 79AB-003

COMPUTED RSP

DATE 7/7/86

R

R

CHECKED SP

DATE 7/10/86

0. SUMMARY OF REVIEW (Continued)

Yes/No/NA

- | | |
|---|------------|
| (e) Normally operating state of device (e.g., normally energized) considered? | <u>Yes</u> |
| (7) Qualified life or replacement schedule established? | <u>Yes</u> |
| (8) Criteria regarding temperature/pressure exposure satisfied? | <u>Yes</u> |
| (a) Peak temperature adequate | <u>Yes</u> |
| (b) Peak pressure adequate | <u>Yes</u> |
| (c) Duration adequate | <u>Yes</u> |
| (d) Required profile enveloped adequately | <u>Yes</u> |
| (e) Steam exposure adequate | <u>Yes</u> |
| (9) Criteria regarding test sequence satisfied? | <u>Yes</u> |
| (10) Criteria regarding spray satisfied? | <u>Yes</u> |
| (a) Was the spray testing done while under the extremes of pressure and temperature? | <u>Yes</u> |
| (b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant? | <u>Yes</u> |
| (11) Criteria regarding submergence satisfied? | <u>N/A</u> |
| (12) Criteria regarding radiation satisfied? | <u>Yes</u> |
| (a) Was dose rate considered? | <u>Yes</u> |
| (b) Was beta radiation considered? | <u>Yes</u> |
| (13) Criteria regarding operability status/mode satisfied? | <u>Yes</u> |
| (14) Criteria regarding test failures or anomalies satisfied? | <u>Yes</u> |

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 24 OF 24
BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R R
TARGET ROCK - MODELS 79AB-001 AND 79AB-003 CHECKED GP DATE 7/10/86

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>N/A</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>N/A</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EOIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-FCV -001-0007 SG1 BLOWDOWN FLOW SOL VALVE	-B 1-FCV -001-0007 82AB-001	-B 001	729' A01 82K22-832045	A/B (3)/1000 A/B 5MN/1000	MS V FW V	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE STEAM GENERATOR	
WBN-1-FCV -001-0014 SG2 BLOWDOWN FLOW SOL VALVE	-A 1-FCV -001-0014 82AB-001	-A 001	729' A01 82K22-832045	A/B (3)/1000 A/B 5MN/1000	MS V FW V	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE STEAM GENERATOR	
WBN-1-FCV -001-0025 SG3 BLOWDOWN FLOW SOL VALVE	-B 1-FCV -001-0025 82AB-001	-B 350	729' A01 82K22-832045	A/B (3)/1000 A/B 5MN/1000	MS V FW V	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE STEAM GENERATOR	
WBN-1-FCV -001-0032 SG4 BLOWDOWN FLOW SOL VALVE	-A 1-FCV -001-0032 82AB-001	-A 350	729' A01 82K22-832045	A/B (3)/1000 A/B 5MN/1000	MS V FW V	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE STEAM GENERATOR	
WBN-1-FCV -001-0181 SG1 BLOWDOWN ISLN VALVE INSIDE CONTMT	-A 1-FCV -001-0181 82AB-001	-A 349	734'10" FN1 82K22-832045	A/B 5MN/1000 A/B 5MN/1000 A/B 5MN/1000 A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT	

PREPARER/DATE RJP 9/9/86CHECKED/DATE R.K. WHITE 9/10/86R 1 R R 9/10/868/27/87

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL -002
MANUFACTURER : TARGET ROCK
PAGE 2 OF 6

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-FCV -001-0182 SG2 BLOWDOWN ISLN VALVE INSIDE CONTMT	-B 1-FCV -001-0182 82AB-001	-B 011	732' 4" FN1 82K22-832045	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT
WBN-1-FCV -001-0183 SG3 BLOWDOWN ISLN VALVE INSIDE CNTNMT	-A 1-FCV -001-0183 82AB-001	-A 012	733' 10" FN1 82K22-832045	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT
WBN-1-FCV -001-0184 SG4 BLOWDOWN ISLN VALVE INSIDE CNTNMT	-B 1-FCV -001-0184 82AB-001	-B 347	735' 1" FN1 82K22-832045	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT
WBN-1-FSV -030-0134 CNTMNT ANNULUS DP ISLN VALVE	-B 1-FSV -030-0134 77J-001	-B 291	740' 1" AC4 77K3-821270	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT
WBN-1-FSV -030-0135 CNTMNT ANNULUS DP ISLN VALVE	-A 1-FSV -030-0135 77J-001	-A 288	745' 7" ANN 77K3-821270	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT

PREPARER/DATE RJP 9/9/86 R 1 R 1
CHECKED/DATE R.K. WHITE 9/10/86 R 1 R 1

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-FSV -043-0250 POST ACD SMPLG HOT	-A 1-FSV -043-0250 LEG NO.1 ISLN VALVE 82KK-001	-A 285	730' ANN 82K29-830702	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.
WBN-1-FSV -043-0251 POST ACD SMPLG HOT	-A 1-FSV -043-0251 LEG NO.1 ISLN VALVE 82KK-001	-A 289	728' 7" AC4 82K29-830702	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.
WBN-1-FSV -043-0268 POST ACD SMPLG RHR HEAT EXCH 1A ISLN VLV	-A 1-FSV -043-0268 82KK-001	-A	713' A28 82K29-830702	A B B B B	100D 1MO 1MO 1MO 1MO	L CV/A AF/A AB/A RH/A	CAT A - MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES. CAT B - VLV MUST REMAIN CLOSED.
WBN-1-FSV -043-0287 POST ACD SMPLG AIR ISLN VALVE	-A 1-FSV -043-0287 82KK-002	-A 304	731' 8" ANN 82K29-830702	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.
WBN-1-FSV -043-0288 POST ACD SMPLG CNTMNT AIR ISLN VLV	-A 1-FSV -043-0288 82KK-002	-A 305	726' 1" AC4 82K29-830702	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.

PREPARER/DATE RJP 9/9/86CHECKED/DATE R.K. WHITE 9/10/86

R 1 R R
 9/9/86
 7/24/89
 8/24/89

PRINT DATE: 04/17/90

BINDER NO. : WBNEQ-SOL -002
MANUFACTURER : TARGET ROCK
PAGE 4 OF 6

H A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMUTH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -043-0307 -A 1-FSV -043-0307 -A POST ACD SMPLO AIR ISLN VALVE	82KK-002	300	733'	ANN	A	100D	L	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.
			82K29-830702		A	100D	MS/C	
					A	100D	FW/C	
					A	1MO	RH/C	
					A	1MO	CV/C	
WBN-1-FSV -043-0309 -B 1-FSV -043-0309 -B POST ACD SMPLO HOT LEG NO.3 ISLN VALVE	82KK-001	252	729' 6"	ANN	A	100D	L	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.
			82K29-830702		A	100D	MS/C	
					A	100D	FW/C	
					A	1MO	RH/C	
					A	1MO	CV/C	
WBN-1-FSV -043-0310 -B 1-FSV -043-0310 -B POST ACD SMPLO HOT LEG NO.3 ISLN VALVE	82KK-001	235	719' 5"	AC3	A	100D	L	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.
			82K29-830702		A	100D	MS/C	
					A	100D	FW/C	
					A	1MO	RH/C	
					A	1MO	CV/C	
WBN-1-FSV -043-0312 -B 1-FSV -043-0312 -B POST ACD SMPLO RHR HEAT EXCH 1B ISLN VLV	82KK-001		713'	A28	A	100D	L	CAT A - MUST OPERATE DURING OR AFTER LOCA TO OBTAIN SAMPLES.
			82K29-830702		B	1MO	CV/A	
					B	1MO	AF/A	
					B	1MO	AB/A	CAT B - VLV MUST REMAIN CLOSED.
					B	1MO	RH/A	
WBN-1-FSV -043-0318 -B 1-FSV -043-0318 -B POST ACD SMPLO CNTMNT AIR ISLN VLV	82KK-002	281	733' 7"	ANN	A	100D	L	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.
			82K29-830702		A	100D	MS/C	
					A	100D	FW/C	
					A	1MO	RH/C	
					A	1MO	CV/C	

R2

PREPARER/DATE RJP 9/9/86 R 1 R 2 R
CHECKED/DATE R.K. WHITE 9/10/86 AFM 07M
7/24/89 5/2/90
EEM CSA
8/24/89 7/12/90

PAGE A-4 R2

PRINT DATE: 04/17/90

BINDER NO. : WBNEQ-SOL -002
MANUFACTURER : TARGET ROCK
PAGE 5 OF 6

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO.	MODEL NUMBER	AZMUTH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
WBN-1-FSV -043-0319 POST ACD SMPLO CNTMNT AIR ISLN VLV	-B 1-FSV -043-0319	82KK-002	289	728' 7"	AC4 82K29-830702	A	100D	L	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
WBN-1-FSV -043-0325 POST ACD SMPLO CNTMNT AIR ISLN VLV	-B 1-FSV -043-0325	82KK-002	282	723'	ANN 82K29-830702	A	100D	L	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES.
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
WBN-1-FSV -043-0341 POST ACD SMPLO DR TOCHTMNT SUMP ISLN VLV	-B 1-FSV -043-0341	82KK-004	282	724'	ANN 82K29-830702	A	100D	L	MUST OPERATE DURING OR AFTER ACCIDENT TO EMPTY PAS WASTE HOLDUP TANK
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
WBN-1-FSV -043-0342 POST ACD SMPLO DR TOCHTMNT SUMP ISLN VLV	-A 1-FSV -043-0342	82KK-004	301	730' 8"	ANN 82K29-830702	A	100D	L	MUST OPERATE DURING OR AFTER ACCIDENT TO EMPTY PAS WASTE HOLDUP TANK
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
WBN-1-PCV -068-0334 RCS PRZR PWR RELIEF VALVE	-B 1-PCV -068-0334	82UU-001	099	785' 10"	PRS 82K22-831934	A	100D	L	PRESSURIZER VENTING PURPOSES. R2 MUST OPERATE UNTIL RCS IS SUFFICIENTLY DEPRESSURIZED THEN REMAIN CLOSED.
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
						A	1MO	CV/C	

PREPARER/DATE RJP 9/9/86
CHECKED/DATE R.K. WHITE 9/10/86

R 1 AFM 7/6/89
R 2 AFM 5/2/90
R AFM 5/2/90

PAGE A-5R2

PRINT DATE: 04/17/90

BINDER NO. : WBNEQ-SOL -002
MANUFACTURER : TARGET ROCK
PAGE 6 OF 6

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION ELEV(1) RM/RAD CONTRACT	CAT	OPER TIME	EVENT	SAFETY FUNCTION
HBN-1-PCV -068-0340A -A RCS PRZR PWR RELIEF VALVE	1-PCV -068-0340A -A 82UU-001	097	785'10" PRS 82K22-831934	A 100D A 100D A 100D A 1M0 A 1M0	L	100D 100D 100D 1M0 1M0	MS/C FW/C RH/C CV/C	PRESSURIZER VENTING PURPOSES. R2 MUST OPERATE UNTIL RCS IS SUFFICIENTLY DEPRESSURIZED THEN REMAIN CLOSED.

PREPARER/DATE	RJP 9/9/86	R 1 AFM 10/4/86	R 2 AFM 5/2/90	R
CHECKED/DATE	R.K. WHITE 9/10/86	EFM 9/21/86	CAF 7/14/90	

PAGE A-6 R2

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R 2 R
BINDER TITLE SOLENOID VALVES - COMPUTED /R1 AFM DATE 4/25/89 CRH
5/16/90
TARGET ROCK CHECKED /R1 EEM DATE 8/24/89 CRH
7/12/90

TAB A

NOTES

1. Floor/Actual Elevation - Actual Elevations are documented on field verification sheets found in TAB F. All elevations shown are floor elevations except actual elevations are shown for those devices located inside the reactor building.
2. See TAB B, Section A for a complete listing of Category and Operating Times Calculations used in this binder.
3. Operating Time is dependent on MSLB size, refer to TAB C, Section C-2, Group III valves, for further information. | R2
4. Contract Column - Contract numbers shown in this TAB were obtained by tracing the serial number on each valve through TVA procurement records and did not depend on field verification data for contract numbers.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 26
R 1 R 2
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 AFM 9/7/90
4/25/89 6/18/90
TARGET ROCK CHECKED WBK DATE 8/27/86 EEM/AFM CSH
8/24/89 7/12/90

A. DOCUMENTATION

Equipment Description Solenoid Valves
Vendor/Manufacturer Target Rock Corporation
Equipment Model No.(s) 82AB-001, 77J-001, 82KK-001, 82KK-002,
82KK-004, 82UU-001

QUALIFICATION REPORTS

- (1) Title/Number/Revision Qualification Test RIMS EEB831003510
Report/2375/G DATE 5/3/83
- (2) Title/Number/Revision Qualification Exten- RIMS EEB830324501
sion Analysis/3543 DATE 1/10/83
- (3) Title/Number/Revision Qualification Exten- RIMS EEB830215500
sion Analysis/3563 DATE 1/10/83
- (4) Title/Number/Revision Qualification Exten- RIMS EEB840130501
sion Analysis/3619/A DATE 12/13/83
- (5) Title/Number/Revision Analysis Report/ RIMS B71860611101
557-1468/A DATE 11/2/83
- (6) Title/Number/Revision Qualification Extens- RIMS B43 80913 001
sion LetterNo. C5631 - Model 77J-001 valves DATE 9/6/85

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- ° Target Rock Test Report No. 4207 (B71 860616 101) (TAB E, Section E-3).
- ° OE Calculation WBNOSG4-004 R10 (B45 861017 218) "Main Steam System (1) NUREG 0588 Category and Operating Times"
- ° OE Calculation WBNOSG4-008 R14 (B26 900110 206) "Containment Ventilation System (30) NUREG 0588 Category and Operating Times"
- ° OE Calculation WBNOSG4-011 R9 (B45 860623 218) "Sampling System (43) NUREG 0588 Category and Operating Times"

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 1A OF 26
R 1 R 2
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 AFM AKM
8/21/89 6/19/90
TARGET ROCK CHECKED WBK DATE 8/27/86 EEM CRH
8/24/89 7/12/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- ° OE Calculation WBNOSG4-017 R9 (B26 890510 506) "Reactor Coolant System (68) NUREG 0588 Category and Operating Times"
- ° DNE Calculation WBNOSG4-045 R1 (B45 860902 219) "Status and Duty Cycles of 1E Solenoid Valves Located in Potentially Harsh Environments"
- ° OE Calculation WBNOSG4-003 R2 (B45 851112 218) "Safety Evaluation of Superheated Steam in the Valve Vaults caused by a Main Steam Line Break"
- ° OE Calculation WBNTSR-051 R0 (B26 891129 202) "Reduction of Beta Dose by Sheet Metal"
- ° WBNP Environmental Data Drawing 47E235-42 R2 With DCA's P04104-02-0, -03-0, -05-0
- ° WBNP Environmental Data Drawing 47E235-44 R1
- ° WBNP Environmental Data Drawing 47E235-59 R2 W/DCA-P02351-18-0
- ° WBNP Environmental Data Drawing 47E235-61 R1
- ° WBNP Environmental Data Drawing 47E235-76 R3
- ° OE Calculation WBNNAL3-004 R0 (B45 860205 235) "Accident Dose Inside Reactor Building"
- ° Calculation WBNTSR-022 R0 (B26 891106 202) "Flowing Media Radiation Doses".
- ° DNE Calculation WBN-EEB-MS-TI06-0017 R0 (B26 900202 410) "120 VAC Vital Instrument Power Voltage Profile."
- ° DNE Calculation WBN-EEB-MS-TI11-0004 R0 (B26 900202 407) "125V DC Voltage Analysis."

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

R2

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 2 OF 26
R 1 R 2
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/16/86 AFM AFM
8/21/89 7/11/90
TARGET ROCK _____ CHECKED RKW DATE 9/16/86 EEM CAF
8/24/89 7/12/90

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES _____

(1) THE QUALIFICATION TEST REPORT DOES NOT DEMONSTRATE THAT
THE VALVES WILL OPERATE DURING ACCIDENT CONDITIONS
AT THE MIN. VOLTAGE.

R2

(2) A conduit seal for Target Rock, Valve 1-FSV-30-134 is required.

(3) Deleted by revision 2

R2

(4) Deleted by revision 2

(6) VALVES 1-FSV-1-7, 14, 25, 32, 181, 182, 183, 184 MUST BE ANALYZED
FOR HEAT RISE DUE TO PROCESS AND ENERGIZED SOLENOID.
COMMENTS/RECOMMENDATIONS VALVE 1-FSV-30-135 MUST HAVE THE
FIELD WIRING REPLACED.

R2

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 3 OF 26
BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86 R R
TARGET ROCK CHECKED WPK DATE 8/29/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 382-1972 "IEEE Trial Use Guide for Type Test of Class I

Electric Valve Operators for Nuclear Power

Generating Stations"

IEEE 323-1974 "IEEE Standard for Qualifying Class IE Equipment for

Nuclear Power Generating Stations"

IEEE 344-1975 "Guide for Seismic Qualification for Class IE

Electrical Equipment for Nuclear Power Generating

Stations"

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 4 OF 26
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 R 2 R 2
TARGET ROCK CHECKED WJK DATE 8/27/86 R 2 R 2
7/12/90

D. QUALIFICATION METHODOLOGY (Check only one block)

- ☐ Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- ☒ Test of Similar Items with Supporting Analysis
- ☐ Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- ☐ Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Target Rock Report No. 2375 is a type test
for Target Rock Solenoid Operated valves. All Target Rock valves
listed in this binder are qualified by analysis or comparison to
the test valve in the 2375 report. All valves listed in TAB A use
the same/similar materials, details of construction, and design
features as the tested Model 77CC-001. Target Rock certifies this
similarity by their Qualification Extension Analyses Nos. 3543,
3563, and 3619, all of which are in TAB D, AND QUALIFICATION
EXTENSION LETTER NO. C5631, ALL OF WHICH ARE IN
TAB D.

R2

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 5 OF 26

BINDER TITLE SOLENOID VALVES - COMPUTED ESP DATE 8/22/86 R R

TARGET ROCK CHECKED WBS/K DATE 8/27/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Vlv</u>	<u>Solenoid Vlv</u>	<u>2375, Sec. 1.0</u>
(2) Manufacturer	<u>Target Rock</u>	<u>Target Rock</u>	<u>2375, Sec. 1.0</u>
(3) Model Number(s)	<u>See TAB A</u>	<u>77CC-001</u>	<u>2375, Sec. 1.0</u>
(4) Serial Number(s)	<u>See TAB F</u>		
(5) Identify Component-Unique checksheet attached:	<u>None</u>		

JUSTIFICATION/ COMMENTS

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 6 OF 26
 R 1 R _____
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 adm
8/21/89
 TARGET ROCK _____ CHECKED WBK DATE 8/27/86 EE-m
8/24/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification | R1
 documentation and/or evaluation and reference the source. Is the
 interface a requirement for our application (Yes/No)? (Note below.)
 If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>None Specified</u>	<u>N/A</u>	
External Process Connections	<u>None Specified</u>	<u>N/A</u>	
Electrical Connections	<u>None Specified</u>	<u>N/A</u>	
Conduit Seals	<u>Rubber Cement Sealing Used at Conduit Conn.</u>	<u>No</u>	<u>2375 Section 4.1.15</u>
Connector Seals	<u>None Specified</u>	<u>N/A</u>	
	<u>Solenoid Coil must be Tilted 45° below Horizontal for</u>		
Orientation	<u>1-PCV-68-334, 340A</u>	<u>Yes</u>	<u>Target Rock Dwg. 82UU-001</u>
Physical Configuration	<u>None Specified</u>	<u>N/A</u>	
Other	<u>N/A</u>		

JUSTIFICATION/COMMENTS Rubber cement sealing compound was used during qualification testing to seal the test instrumentation wires at the conduit connection. During the course of the test, this sealing compound shrivelled and pulled away, completely opening the switch compartment to the borated water spray. Although the test valve remained operational throughout the test, valves subject to borated water spray will be sealed with a qualified Conax conduit seal in accordance with TVA Environmental Qualification Binder No. WBNEQ-CSC-001.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 7 OF 26
BINDER TITLE SOLENOID VALVES - COMPUTED RL DATE 8/27/86 R R
TARGET ROCK CHECKED WJK DATE 8/29/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>2375</u> <u>Sec. 4.1.1</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>2375</u> <u>Sec. 4.1.1</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>2375 App.A</u> <u>Sec. 4.1.1</u>
Radiation	<u>Yes</u>	<u>2375</u> <u>Sec. 4.1.2 & 4.1.11</u>
Wear	<u>Yes</u>	<u>2375, App.A</u> <u>Sec. 4.2</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>2375, App.A</u> <u>Sec. 4.3</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>2375, Sec.</u> <u>4.1.9 & App. A</u> <u>Sec. 4.4</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>2375 Sec. 4.1.10</u> <u>& App. A Sec. 4.4.8</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>2375 Sec. 4.1.15</u> <u>& App. E</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes
(Reference 2375, App.A, Sec.2.0).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 8A OF 26
R 1 R
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 *8/21/85*
TARGET ROCK _____ CHECKED WBK DATE 8/27/86 *6/6/87*
8/24/87

COMMENT FOR H(3):

Target Rock did not address synergistic effects in Test Report 2375.
However, it is apparent that Target Rock solenoid valves contain
materials in which radiation-induced synergisms, even though mild,
could occur. Silicone rubber (per NUREG/CR-2763) and ethylene
propylene rubber (per NUREG/CR-2157) exhibit insignificant dose rate
effects at doses up to 20 Mrad. The worst case 40-year TID for the
valves in this binder is 20 Mrad. Therefore, synergistic effects will
be negligible for normal service aging. Also, potential dose rate and
test sequence synergisms will not impact qualification for accident
conditions as demonstrated by 2375. In the event an accident occurs,
dose rates will be comparable to test conditions. Therefore the test
sequence of thermal aging followed by aging plus accident radiation is
a reasonable simulation of actual plant requirements. Additional
assurance is provided by the severity of the radiation test because
the specimen was exposed to 135 Mrads, whereas a worst case actual
dose of 124 Mrads is required.

| R1

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 9 OF 26
R 1 R
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 8/21/89
TARGET ROCK _____ CHECKED WBK DATE 8/27/86 8/24/89

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference: 2375, App. F-IC, Para. 3).

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? YES
(Reference: 2375, App. F-I, Para. 3)

JUSTIFICATION/COMMENTS _____

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? YES
(Reference: 2375, App. A, Sec. 4.1.1) |R1

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	130°F (worst Case)	350°F	120°F
Time	40 years	792 hours	40 years R1

JUSTIFICATION/COMMENTS See Qualified Life Calculations in TAB C.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? YES
(Reference: 2375, App. F-I, Para. 3)

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? YES
(Reference: 2375, App. F-IC, Para. 3)

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 10 OF 26
 BINDER TITLE SOLENOID VALVES - COMPUTED RL DATE 8/27/86
TARGET ROCK CHECKED WPK DATE 8/29/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? N/A (Reference _____).

JUSTIFICATION/COMMENTS

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference 2375, App. A, Sec. 4.1.1).

JUSTIFICATION/COMMENTS The test valve was de-energized
throughout thermal aging except when it was energized to
cycle open once each day for the 33-day duration of the aging
test.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference 2375, App. F, Sec. 4.2 & 6.5).

JUSTIFICATION/COMMENTS

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? No
(Reference 2375, App. F, Sec. 4.2 & 6.5 and App. C).

JUSTIFICATION/COMMENTS The entire valve assembly was
irradiated without regard for specific components, thus
demonstrating operability regardless of radiation threshold
values.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes
(Reference 2375, App. F-I, Para. 2).

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 11 OF 26
R 1 R _____
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 CTM
4/25/89
TARGET ROCK _____ CHECKED WBK DATE 8/27/86 EE
8/24/89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: 2375, App. F-I, Paragraph 2 & App. C).

Plant normal ambient radiation dose (rd)	<u>2.0×10^7 rads</u> <u>(worst case)</u>
Test exposure dose (rd)	<u>1.35×10^8 rads</u>
Test exposure dose rate (rd/hr)	<u>.45 MRADS/HR - Post-DBE</u> <u>Not Specified-Pre Aging</u>
Test exposure source type (e.g., Co-60 gamma)	<u>Co-60 gamma - Post-DBE</u> <u>Not Specified-Pre Aging</u>

JUSTIFICATION/COMMENTS _____

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ No (Reference: _____) | R1

JUSTIFICATION/COMMENTS See item 1 under "Discussion"
on sheet 25.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? No (Reference: _____).

JUSTIFICATION/COMMENTS See item 1 under "Discussion"
on sheet 25.

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 12 OF 26
R 1 R
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 97M
425/89
TARGET ROCK CHECKED WBK DATE 8/27/86 86.7
9/24/89

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: 2375, App. A, Sec. 4.2, App. F, Sec. 4.6 and App. F-IC, Para. 4).

R1

JUSTIFICATION/COMMENTS _____

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: 2375, App. A, Sec. 4.2 and App. F-IC, Para. 4).

JUSTIFICATION/COMMENTS _____

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes (Reference: 2375, App. F-IB, Para. 3).

Qualified life (Document in QMDS) 40 years

JUSTIFICATION/COMMENTS Parameters are defined (see Ref.) but actual life is determined by qualified life calculations (see TAB C)

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes (Reference: 3543, 3563 & 3619).

R1

JUSTIFICATION/COMMENTS In Qualification Extension Analysis Reports 3543, 3563, and 3619 (see TAB D) Target Rock recommends replacement of all silicone rubber O-rings and gaskets every five years. However, our calculations, which are based on the Target Rock test parameters project a longer life. See TAB C.

BINDER NO. <u>WBNEQ-SOL-002</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>13</u> OF <u>26</u>
		R <u>2</u>	R <u>2</u>
BINDER TITLE <u>SOLENOID VALVES - COMPUTED</u>	RJP	DATE <u>9/09/86</u>	<u>ATM</u> <u>7/5/90</u>
TARGET ROCK	CHECKED <u>RKW</u>	DATE <u>9/09/86</u>	<u>ATM</u> <u>7/14/90</u>

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) Silicone rubber/ sealing/potting			1.14	557-1468, Sec. 5.2.13
(b) EPR/O-Ring			0.95	557-1468, Sec. 5.2.5
(c) * RECTIFIER			0.98	557-1468, Tbl. III
(d) * COIL ASSEMBLY & REED SWITCH			1.05	557-1468, Tbl. III
(e) TERMINAL BOARD			1.04	557-1468, Tbl. III

JUSTIFICATION/COMMENTS In Test Report 2375 Target Rock defined the most temperature sensitive material as silicone rubber with an assigned activation energy of 0.61 eV. However, Target Rock later had National Technical Systems perform a materials analysis on a randomly selected solenoid valve to determine the parameters for the accelerated aging of the materials to a state of degradation equivalent to that incurred in normal service. We have listed above, and will use, the activation energies founded by NTS in the referenced report for all life calculations performed for the valves in this binder (see TAB C).

* THE ACTIVATION ENERGY LISTED IS THE LOWEST ACTIVATION ENERGY OF ANY MATERIAL IN THE COMPONENT.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 14 OF 26
BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 8/22/86
TARGET ROCK CHECKED WPK DATE 8/21/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference 2375, App. G, p. 18-).

Identify Acceptance Criteria: Valve must operate at minimum 60 Vac

and maximum 144 Vac. Allowable seat leakage must not exceed 0.4cc/

12 min. Position indicators, when applicable, must satisfactorily

indicate when valve is cycled.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference 2375, App. G).

Identify baseline and functional testing: See (1) above

JUSTIFICATION/COMMENTS

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes
(Reference 2375, App. A, Sec. 4.4).

JUSTIFICATION/COMMENTS The valve was connected to high pressure lines
and cycled under pressure throughout the DBE, thermal aging, and
cyclic aging exposure.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 15 OF 26
R 1 R 2
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 AFM qjm
8/21/89 5/2/90
TARGET ROCK _____ CHECKED WBK DATE 8/27/86 EEM CSH
8/24/89 1/12/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: 2375, App. B).

JUSTIFICATION/COMMENTS Voltage was varied from 60-144 Vac.

Valve was under process pressure of 2485 psig.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
		Dwgs. 45N600-1-3
		45N600-30-10
		45W600-68-1
		45N600-43-4
Voltage	<u>125 Vdc - 120 Vac</u>	Vendor Drawings
Load	<u>See comments</u>	<u>TAB I</u>
Frequency	<u>60 Hz for AC</u>	
Accuracy	<u>NA</u>	
Other(s)		

JUSTIFICATION/COMMENTS _____

Model	Voltage	Load (Amps)
77J-001	125 VDC	0.5
82AB-001	125 VDC	3.5
82KK-001	120 VAC	0.6
82KK-002	120 VAC	0.6
82UU-001	125 VDC	1.3
82KK-004	120 VAC	0.6

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 16 OF 26
 R 1 R 2
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 AFM gfm
 8/24/89 7/11/90
 TARGET ROCK _____ CHECKED WBK DATE 8/27/86 EEM gfm
 8/24/89 7/12/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) Parameter	Specific Accident Conditions	Reference
Voltage	<u>84.37 VDC MIN.</u> <u>93.9 VAC MIN.</u>	<u>SEE COMMENTS</u>
Load	<u>See J (5)(a)</u>	
Frequency	<u>60 Hz for AC</u>	
Accuracy	<u>NA</u>	
Other(s)		

JUSTIFICATION/COMMENTS DNE Calculation WBN-EEB-MS-TI06-0017
(AC Voltage) and WBN-EEB-MS-TI11-0004 (DC Voltage).

(c) Parameter	Demonstrated Conditions	Reference
Voltage	<u>60-144 VAC (SEE COMMENTS)</u>	<u>(1) App B</u>
Load	<u>365 mA @ 120 VAC</u>	<u>(1) App B</u>
Frequency	<u>60 Hz</u>	<u>(1) App B</u>
Accuracy	<u>NA</u>	
Other(s)		

JUSTIFICATION/COMMENTS The tested valve successfully completed pre-DBE and post-DBE simulation functional testing at voltages ranging from 60 VAC minimum to 144 VAC maximum. However, the DBE simulation test, the valve was cycled using 120 VAC only. THEREFORE, THE TEST DOES NOT DEMONSTRATE THAT THE VALVE WILL OPERATE DURING ACCIDENT CONDITIONS AT THE MIN. VOLTAGE. THIS DISCREPANCY MUST BE RESOLVED (SEE OPEN ITEM #1).

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 17 OF 26
 R 1 R
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/9/86 DEM
8/21/89
 TARGET ROCK CHECKED RKW DATE 9/9/86 DEM
8/24/89

K. REQUIRED OPERATING ENVIRONMENT (Worst Case for All Environmental Areas) R1

Reference Environmental Drawing No. 47E235-61, 47E235-44, 47E235-76 R1
47E235-42

- | | |
|--|--------------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| (a) Temperature (°F) <u>130°F</u> | (a) Temperature (°F) <u>140°F</u> |
| (b) Pressure (psig) <u>14.4 psia</u> | (b) Pressure (psig) <u>14.4 psia</u> |
| (c) Humidity (%) <u>80%</u> | (c) Humidity (%) <u>100%</u> |
| (d) Radiation (rd) <u>2 x 10⁷ rads;</u>
<u>40 yr TID</u> | (d) Radiation (rd) <u>N/A</u> |
- (3) Process Interfaces: See TAB C for addressing of appropriate process interface.
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Will occur less than 1% of plant life and could exist for up to 8 hours per excursion.
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|--|--------------------------------|
| (a) Temperature (°F) <u>327°F</u> | Accident type <u>LOCA/HELB</u> |
| (b) Pressure (psig) <u>25.6 psia</u> | Accident type <u>LOCA/HELB</u> |
| (c) Humidity (%) <u>100%</u> | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>7.4 x 10⁷ rads</u>
<u>(beta)*</u>
<u>3.3 x 10⁷ rads</u>
<u>(gamma)*</u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>2000ppm Boron</u>
<u>pH 8.3</u> | Accident type <u>LOCA/HELB</u> |

* See comments on Sheet 19A.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 18 OF 26
R 1 R 1
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/16/89 ADM
8/21/89
TARGET ROCK _____ CHECKED RKW DATE 9/16/89 LEM
8/24/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): The duration of the containment spray is 30 days. Containment spray flow rate is equal to 9500 gal/min or 0.92 gpm per square foot of containment cross section.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: See Sec. P2 "Discussion").
- (7) Subject to submergence (Yes/No/NA)? No (Reference: TVA Environmental Dwg 47E235-42): |R1

Identify initiation time and duration of submergence: See Justification Comments on Sheet 19.

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: TAB B, Section L (1)).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

See TAB B, Section L(1)

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B, Section A for a listing of calculations used in this binder.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 19 OF 26
 R 1 R 2
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/9/86 AFM 9/21/86
 8/24/89 5/2/90
 TARGET ROCK _____ CHECKED RKW DATE 9/9/86 EEM CZH
 8/24/89 7/12/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>14 days</u>	<u>2375, App. A</u> <u>Sec. 4.4.6</u>
Temperature (°F)	<u>327°F</u> <u>25.6 psia</u>	<u>385°F</u>	<u>2375, App. A</u> <u>Sec. 4.4.2</u>
Pressure (psig)	<u>(11.2 psig)</u>	<u>66 psig</u>	<u>2375, App. A</u> <u>Sec. 4.4.2</u>
Relative Humidity (%)	<u>100%</u> <u>2000 ppm</u>	<u>100%</u> <u>6200 ppm</u>	<u>2375, App. A</u> <u>Sec. 4.4.2</u>
*Chemical Spray	<u>Boron (H₂BO₃)</u> <u>pH 8.3</u> <u>1.24x10⁸ rads</u>	<u>Boron (H₃BO₃)</u> <u>pH 8.6-10.0</u> <u>1.35x10⁸ rads</u>	<u>2375, App. A</u> <u>Sec. 4.4.2</u>
**Radiation (rd)	<u>(beta/gamma)</u>	<u>gamma</u>	<u>2375, App. C</u>
Submergence	<u>NA</u>	<u>NA</u>	<u>***</u>

*Includes spray concentration, flowrate, density, duration and pH.
 **Enter 40-year integrated normal dose plus integrated accident dose and specify type. See comments on Sheet 19A.

(2) Comparison of worst case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile</u> <u>Envelopes Specified</u> <u>(Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>YES</u>	<u>See (1) above</u>
Pressure	<u>YES</u>	<u>See (1) above</u>
Relative Humidity	<u>YES</u>	<u>See (1) above</u>
Chemical Spray	<u>YES</u>	<u>See Sec.</u>
Submergence	<u>NA</u>	<u>Page 3</u> <u>***</u>

JUSTIFICATION/COMMENTS ***Equipment located inside containment inside the crane wall below elevation 722 (surge level) could become submerged following an accident. Outside the crane wall, the steady state flood level is 717.7'. None of the valves inside containment are located below these levels. All valves in the Auxiliary Building and south valve room are located above the max. flood levels of 713'3" in the auxiliary Bldg (Rm A28) and 731.5' for significant wetting in the south valve room. Therefore, no valves in this binder are subject to submergence.

R2

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 19A OF 26
 R 1 R 2
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86 AFM 9/11/90
 8/24/89 5/16/90
 TARGET ROCK _____ CHECKED WBK DATE 8/27/86 EEM 8/12/90
 8/24/89 7/12/90

COMMENTS FOR SECTION L(1) (RADIATION):

The worst-case total radiation dose is in the reactor building lower compartment. The 100-day accident dose given by WBN Environmental Data Drawing 47E235-42 is 4.7×10^8 rads BETA and 4×10^7 rads GAMMA. The 40 year dose is 2.0×10^7 rads. All of the solenoid valves in this binder that are located in the lower compartment are in a fan room, or an accumulator room, except the System 68 valves which are located above the pressurizer at elevation 78 $\frac{2}{10}$ '. The 100-day accident GAMMA dose for the accumulator and fan rooms is 1×10^7 rads given by drawing 47E235-42. OE Calculation WBNNAL3-004 recommends an accident dose of 4.0×10^7 for equipment next to the sump water level (Elev. 722') and 3.3×10^7 rads for equipment further above it. Since the System 68 valves are located at Elev. 78 $\frac{2}{10}$ ', the accident radiation dose for these valves is 3.3×10^7 rads. Therefore, the worst-case radiation dose for the solenoid valves in this binder is 4.7×10^8 rads BETA and 3.3×10^7 rads GAMMA for the 100-day accident dose and 2.0×10^7 rads GAMMA for the 40 year dose.

Post-DBA BETA Radiation must be addressed for all equipment located inside containment which is required for LOCA mitigation. The valves listed in TAB C, Section C-1 (I) & (II) are within that scope. All non-metallic parts of these solenoid valves are contained in a .048" thick (18ga) 300-series stainless steel metal enclosure. OE Calculation WBNTSR-051 "Reduction of Beta Dose by Sheet Steel, " page 3, shows the beta reduction factor for 18-gauge steel is equal to .158. This reduces the total 100-day BETA dose to the valve internal parts to $(4.7 \times 10^8) \times (1.58 \times 10^{-1}) = 7.4 \times 10^7$ rads BETA.

VALVES LOCATED IN A FAN ROOM OR ACCUMULATOR ROOM

The total combined 100-day BETA and GAMMA accident radiation dose for the non-metallic parts of these solenoid valves is $(7.4 \times 10^7 \text{ BETA}) + (1.0 \times 10^7 \text{ GAMMA}) = 8.4 \times 10^7$ rads. The combined 100-day accident radiation plus the 40-year dose (2×10^7 rads) equal a total radiation dose of 1.04×10^8 rads (BETA/GAMMA). The Target Rock valves contained in this binder are qualified to 1.35×10^8 rads, which envelops the requirement with margin.

BINDER NO. <u>WBNEQ-SOL-002</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>19B</u> OF <u>26</u>
			R <u>2</u> R
BINDER TITLE <u>SOLENOID VALVES - COMPUTED</u>		/R1 AFM DATE <u>8/24/89</u>	<u>97M</u> <u>5/2/90</u>
TARGET ROCK		CHECKED <u>/R1 EEM</u> DATE <u>8/24/89</u>	<u>CRT</u> <u>7/12/90</u>

SYSTEM 68 VALVES LOCATED ABOVE PRESSURIZER

The total combined 100-day BETA and GAMMA accident dose to the non-metallic parts of these solenoid valves is 7.4×10^7 rads BETA + 3.3×10^7 rads GAMMA = 1.07×10^8 (BETA/GAMMA). The 40-year TID (2.0×10^7) + 100-day TID (1.07×10^8) + 10% margin (1.07×10^7) = 1.38×10^8 rads. In order to meet the radiation requirement to the qualification level, the dose must be reduced. The qualified dose (1.35×10^8) - 10% margin - accident dose (1.07×10^8) = 1.73×10^7 rads. The TID cannot be greater than 1.73×10^7 rads. Forty years ($1.73 \times 10^7 \div 2.0 \times 10^7$) = 34.6 years. Therefore, all non-metallic materials in the System 68 valves must be replaced every 34.6 years to meet the radiation requirements (See TAB G). The total radiation dose will be (1.73×10^7) + (1.07×10^8) = 1.24×10^8 rads.

This sounds like the govt. on taxes. Tax it everywhere it changes hands. Looks to me like the 10% has already been accounted for. CRT

POST ACCIDENT AIR SAMPLING VALVES

Sampling valves 1-FSV-43-287, 288, 307, 318, 319, and 325 have discs made from organic compounds and, therefore, are subject to the effects of radiation from the containment atmosphere. Calculation WBNTSR-022 gives the 100 day accident dose from all sources as 6.62×10^6 . The 40-year dose for any of these valves is 2×10^7 rad TID. The combined total dose is 2.662×10^7 rads. The Target Rock valves contained in this binder are qualified to 1.35×10^8 rads, which envelopes the requirement with margin. VALVES 1-FSV-43-287, 288, 307, 318, AND 325 ARE LOCATED IN THE ANNULUS, AND 1-FSV-43-288, 319 ARE LOCATED IN THE LOWER COMPARTMENT.

R2

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 20 OF 26
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/9/86 AFM
4/25/89
 TARGET ROCK _____ CHECKED RKW DATE 9/9/86 EEH
9/24/87

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	+58°F	Yes
Pressure: +10% but no more than 10 psig	+54.8 psig	Yes
Radiation: +10% of accident dose	+10%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	See Below	No
Voltage: ±10% of rated value	Later	
Frequency: ±5% of rated value	N/A	N/A
Environmental Transient: the initial transient and the peak temperature applied twice		Yes
Vibration: +10% added to acceleration	2375, App A Sec. 4.3.2	Yes

R1

JUSTIFICATION/COMMENTS See TAB C, Sections C-1 and C-2, which proves the 14-day test envelops the 100-day post-accident requirements. Voltage variations were applied during testing ranging from 60V ac minimum to 144V ac maximum.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 21 OF 26
BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86
TARGET ROCK CHECKED WIK DATE 8/27/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference See TAB A).

JUSTIFICATION/COMMENTS Functions are varied. All are listed
in TAB A.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference 2375, Sec. 2.0 & App. A, 5.3).

JUSTIFICATION/COMMENTS _____

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference 2375, Sec. 2.0 & App. A, 5.3).

JUSTIFICATION/COMMENTS _____

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference 2375, Sec. 2.0 & App. A, 4.4).

JUSTIFICATION/COMMENTS See TAB C, Sections C-1 and C-2, "Post-
Accident Life"

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes
(Reference 2375, Sec. 2.0/4.1.10).

JUSTIFICATION/COMMENTS The test anomaly addressed in Sec. 4.1.10
relative to relay contacts, applies only to the model 77J-001
valves in this binder, since they are the only valves herein
having relays. The relays failed to make contact due to surface
corrosion but functioned properly after they were polished.
Target Rock did not address the cause of the relay contact corrosion.
However, after reviewing the test report it is reasonable to deduce
that moisture entered the test valve during accident simulation
via an unsealed conduit entry to cause the damage. The model 77J-
001 valves in this binder, which are subject to moisture
intrusion, are equipped with Conax conduit seals to prevent such
intrusion, and therefore, prevent the aforementioned anomaly.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 23 OF 26
BINDER TITLE SOLENOID VALVES - COMPUTED RL DATE 8/27/86 R R
TARGET ROCK CHECKED WBL DATE 8/27/86

O. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>N/A</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>N/A</u>
(b) Were specific features and failure modes and effects analyzed?	<u>N/A</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>N/A</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>N/A</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>N/A</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 24 OF 26
BINDER TITLE SOLENOID VALVES - COMPUTED R/S DATE 8/27/86 R R
TARGET ROCK CHECKED W/K DATE 8/27/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 25 OF 26
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86 R 2 R 6/13/90
TARGET ROCK CHECKED WPK DATE 8/27/86 CRJ 7/12/90

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>Yes</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>N/A</u>
(18) Criteria regarding synergistic effects satisfied?	<u>YES</u> <u>9JM</u> <u>6/13/90</u> <u>R2</u> N/A
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

1. Non-seismic vibration aging (sec. H.(6)). Non-seismic vibration aging was not performed as required by IEEE 323-1974. This does not affect the qualification of the tested or installed valves for the following reasons:

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 26 OF 26
BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 8/27/86 R R
TARGET ROCK CHECKED WKR DATE 8/29/86

P. DISCUSSION (Continued)

(A) There were no test anomalies associated with the seismic portion of the qualification testing.

(B) Non-seismic vibration aging is not a recognized problem for solenoid valves. Other solenoid valves, including some Target Rock models, have been subjected to this type testing with no discrepancies noted.

(C) Periodic maintenance and surveillance activities will detect any problems which would result from the effects of non-seismic vibration aging.

2. Moisture or liquid intrusion (Sec.K (6)).

The valves requiring protection from moisture or liquid intrusion have had Conax conduit seals installed and are identified in Section 1 of the OMDS, which is located in TAB G of the binder.

3. Chemical Spray (Sec. L (1) & (2)).

The containment spray flow rate is equal to 9500 gal/min or 0.92 gpm per square foot of containment cross section. The chemical spray concentration is 2000ppm boron with a pH of 8.35. The Target Rock test valve was subjected to a spray solution of 6200ppm boron and 50ppm hydrazine with a pH of 8.6-10.0. The spray rate was 0.15 gpm per square foot of projected area of the test valve. The test solution is more corrosive than the containment spray. Therefore, all valves listed in this binder fall within the qualification provided by the test valve.

PRINT DATE: 09/29/90

WATTS BAR NUCLEAR PLANT
 TAB A - EQUIPMENT IDENTIFICATION MATRIX

QIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-PSV -001-0006A SG1 MAIN STM HDR PWR RELF CONT VLV PILOT	-A 1-PSV -001-0006A X206-381-3RF	729' A01 80KJ3-827551	B	100D 100D	MS/V FW/V	PSV MUST NOT FAIL DURATION OF EACH EVENT IN A MANNER THAT WOULD PREVENT THE PAM FUNCTION OF ITS ASSOC LIMIT SWITCHES.
WBN-1-PSV -001-0006B SG1 MAIN STEAM HDR PWR RELIEF CNTL VLV	-A 1-PSV -001-0006B X206-381-3RF	729' A01 80KJ3-827551	A B	100D 100D	FW/V MS/V	MUST ENERGIZE TO ASSURE SECONDARY SIDE PORV CLOSURE. MUST NOT FAIL DURATION OF EACH EVENT IN A MANNER TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-PSV -001-0013A SG2 MAIN STM HDR PRESS RLF CNTL VLV	-B 1-PSV -001-0013A X206-381-3RF	729' A02 80KJ3-827551	B	100D 100D	MS/V FW/V	PSV MUST NOT FAIL DURATION OF EACH EVENT IN A MANNER THAT WOULD PREVENT THE PAM FUNCTION OF ITS ASSOC LIMIT SWITCHES.
WBN-1-PSV -001-0013B SG2 MAIN STEAM HDR PRESS RLF CNTL VLV	-B 1-PSV -001-0013B X206-381-3RF	729' A02 80KJ3-827551	A B	100D 100D	FW/V MS/V	MUST ENERGIZE TO ASSURE SECONDARY SIDE PORV CLOSURE. MUST NOT FAIL DURATION OF EACH EVENT IN A MANNER TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-PSV -001-0024A SG3 MAIN STM HDR PRESS RLF CNTL VLV	-A 1-PSV -001-0024A X206-381-3RF	729' A02 80KJ3-827551	B	100D 100D	MS/V FW/V	PSV MUST NOT FAIL DURATION OF EACH EVENT IN A MANNER THAT WOULD PREVENT THE PAM FUNCTION OF ITS ASSOC LIMIT SWITCHES.

PAGE A-1 R5

PREPARER/DATE EEM 8/21/86
 CHECKED/DATE WBK 8/21/86
 R 4 CDH 8/21/90 AFM 12/17/90
 R 5 CDH 12/17/90 PEN
 R

SOL-003

PRINT DATE: 09/29/90

BINDER NO. : WBNEQ-SOL -003
MANUFACTURER : ASCO
PAGE 2 OF 25

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-PSV -001-0024B -A SG3 MAIN STEAM HDR PRESS RLF CNTL VLV	1-PSV -001-0024B -A X206-381-3RF		729'	A02	A	100D	FW/V	MUST ENERGIZE TO ASSURE
			80KJ3-827551		B	100D	MS/V	SECONDARY SIDE PORV CLOSURE.
								MUST NOT FAIL DURATION OF EACH
								EVENT IN A MANNER TO PREVENT
								PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-PSV -001-0031A -B SG4 MAIN STM HDR PRESS RLF CNTL VLV	1-PSV -001-0031A -B X206-381-3RF		729'	A01	B	100D	MS/V	PSV MUST NOT FAIL DURATION OF
			80KJ3-827551		B	100D	FW/V	EACH EVENT IN A MANNER THAT
								WOULD PREVENT THE PAM FUNCTION
								OF ITS ASSOC LIMIT SWITCHES.
WBN-1-PSV -001-0031B -B SG4 MAIN STEAM HDR PRESS RLF CNTL VLV	1-PSV -001-0031B -B X206-381-3RF		729'	A01	A	100D	FW/V	MUST ENERGIZED TO ASSURE
			80KJ3-827551		B	100D	MS/V	SECONDARY SIDE PORV CLOSURE.
								MUST NOT FAIL DURATION OF EACH
								EVENT IN A MANNER TO PREVENT
								PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -001-0147 -A SG LOOP 1 WARMING VALVE	1-FSV -001-0147 -A X206-381-6RVF		729'	A01	A/B	5MN/100D	FW/V	MUST DEENERGIZE TO CLOSE ASSOC
			84PK4-343461		B	100D	MS/V	FCV AND REMAIN CLOSED TO
								PREVENT REOPENING. MUST NOT
								FAIL IN A MANNER TO PREVENT
								PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -001-0148 -B SG LOOP 2 WARMING VALVE	1-FSV -001-0148 -B X206-381-6RVF		729'	A02	A/B	5MN/100D	FW/V	MUST DEENERGIZE TO CLOSE ASSOC
			84PK4-343461		B	100D	MS/V	FCV AND REMAIN CLOSED TO
								PREVENT REOPENING. MUST NOT
								FAIL IN A MANNER TO PREVENT
								PAM FUNCT OF ASSOC LIMIT SWS.

PAGE A-2

RS

PREPARER/DATE EEM 8/21/86

CHECKED/DATE WDK 8/21/86

R 4
CDH 8/21/90
AFM 8/28/90
R 5
CDH 8/21/90
AFM 8/28/90
R
19/1/90

08/15/90

WATTS BAR NUCLEAR PLANT

TAB A - EQUIPMENT IDENTIFICATION MATRIX

 BINDER NO. : WBNEQ-SOL-003
 MANUFACTURER : ASCO
 PAGE 3 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -001-0149 -A SG LOOP 3 WARMING VALVE	1-FSV -001-0149 -A X206-381-6RVF		729'	A02 84PK4-343461	A/B B	5MN/100D 100D	FW/V MS/V	MUST DEENERGIZE TO CLOSE ASSOC FCV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL IN A MANNER TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
✓ WBN-1-FSV -001-0150 -B SG LOOP 4 WARMING VALVE	1-FSV -001-0150 -B X206-381-6RVF		729'	A01 84PK4-343461	A/B B	5MN/100D 100D	FW/V MS/V	MUST DEENERGIZE TO CLOSE ASSOC FCV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL IN A MANNER TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
✓ WBN-1-LSV -003-0172 -A SG3 LEVEL CONTROL SOL VLV	1-LSV -003-0172 -A 206-381-3RVU		737'	A05 80KJ3-827551	A/B B B B B	5MN/100D 1 MO 1 MO 1 MO 1 MO	LOCA AF RH/A CV/A AB	LOCA: MUST DEENERGZ AND REMAIN TO PREVENT ASSOC LCV CLOSING. ALL OTHER EVENTS: MUST NOT FAIL IN MANNER TO PREVENT PAM FUNCTION OF ASSOC LIMIT SWS.
✓ WBN-1-LSV -003-0173 -B SG2 LEVEL CONTROL SOL VLV	1-LSV -003-0173 -B 206-381-3RVU		737'	A05 80KJ3-827551	A/B B B B B	5MN/100D 1 MO 1 MO 1 MO 1 MO	LOCA AF RH/A CV/A AB	LOCA: MUST DEENERGZ AND REMAIN TO PREVENT ASSOC LCV CLOSING. ALL OTHER EVENTS: MUST NOT FAIL IN MANNER TO PREVENT PAM FUNCTION OF ASSOC LIMIT SWS.
✓ WBN-1-LSV -003-0174 -B TDAFWP STM GEN 1 LEVEL SOL VALVE	1-LSV -003-0174 -B 206-381		729'	A01	B A/B	100D 5MN/100D	MS/V FW/V	MS/V: MUST NOT FAIL IN MANNER THAT WOULD PREVENT PAM FUNCT OF ASSOC LIMIT SWS. FW/V: MUST DEENERGIZE AND REMAIN SO ASSOC LCV WILL MODULATE.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

 R 4
 CTM
 8/21/86
 ATM
 8/22/86

R R

PAGE A-3

R4

PH. 08/15/90

BINDER NO. : WBNEQ-SOL-003
MANUFACTURER : ASCO
PAGE 4 OF 25

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-LSV -003-0175 -A 1-LSV -003-0175 -A TDAFWP STM GEN 4 LEVEL SOL VALVE	206-381-3RVU	729' A01 80KJ3-827551	B	100D	MS/V FW/V	100D	MS/V	MS/V, MUST NOT FAIL IN MANNER THAT WOULD PREVENT PAM FUNCT OF ASSOC LIMIT SWS. FW/V, MUST DEENERGIZE AND REMAIN SO ASSOC LCV WILL MODULATE.
WBN-1-FSV -003-0185 -B 1-FSV -003-0185 -B SG1 MAIN FW CHECK VALVE BYPASS	206-381-2F	729' A01 78K3-822950	A/B (3)/100D	5MN/100D	MS/V FW/V	100D	MS/V	VLVS ARE ISOLATED ON A FW ISOLATION SIGNAL. VLVS MUST DEENERGIZE TO VENT OPR FOR MS/V EVENT.
WBN-1-FSV -003-0186 -A 1-FSV -003-0186 -A SG2 MAIN FW CHECK VALVE BYPASS	206-381-2F	729' A02 78K3-822950	A/B (3)/100D	5MN/100D	MS/V FW/V	100D	MS/V	VLVS ARE ISOLATED ON A FW ISOLATION SIGNAL. VLVS MUST DEENERGIZE TO VENT OPR FOR MS/V EVENT.
WBN-1-FSV -003-0187 -B 1-FSV -003-0187 -B SG3 MAIN FW CHECK VALVE BYPASS	206-381-2F	729' A02 78K3-822950	A/B (3)/100D	5MN/100D	MS/V FW/V	100D	MS/V	VLVS ARE ISOLATED ON A FW ISOLATION SIGNAL. VLVS MUST DEENERGIZE TO VENT OPR FOR MS/V EVENT.
WBN-1-FSV -003-0188 -A 1-FSV -003-0188 -A SG4 MAIN FW CHECK VALVE BYPASS	206-381	729' A01	A/B (3)/100D	5MN/100D	MS/V FW/V	100D	MS/V	VLVS ARE ISOLATED ON A FW ISOLATION SIGNAL. VLVS MUST DEENERGIZE TO VENT OPR FOR MS/V EVENT.

PREPARER/DATE EEM 8/21/86 R 4
CHECKED/DATE WBK 8/21/86 R 8/21/86
R 8/23/86

08/15/90

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL-003
MANUFACTURER : ASCO
PAGE 5 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -003-0236A -A 1-FSV -003-0236A -A UPPER TAP MAIN FW SG1 ISLN VALVE 206-381			729'	A01	A/B (3)/100D A/B 5MN/100D	MS/V FW/V		VLVS MUST CLOSE ON FW ISLN SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION. VLVS MUST DEENERGIZE FOR MS/V EVENT.
WBN-1-FSV -003-0236B -B 1-FSV -003-0236B -B UPPER TAP MAIN FW SG1 ISLN VALVE 206-381			729'	A01	A/B (3)/100D A/B 5MN/100D	MS/V FW/V		VLVS MUST CLOSE ON FW ISLN SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION. VLVS MUST DEENERGIZE FOR MS/V EVENT.
✓ WBN-1-FSV -003-0239A -A 1-FSV -003-0239A -A UPPER TAP MAIN FW SG2 ISLN VALVE 206-381-2F			729' 78K3-822950	A02	A/B (3)/100D A/B 5MN/100D	MS/V FW/V		VLVS MUST CLOSE ON FW ISLN SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION. VLVS MUST DEENERGIZE FOR MS/V EVENT.
✓ WBN-1-FSV -003-0239B -B 1-FSV -003-0239B -B UPPER TAP MAIN FW SG2 ISLN VALVE 206-381			729'	A02	A/B (3)/100D A/B 5MN/100D	MS/V FW/V		VLVS MUST CLOSE ON FW ISLN SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION. VLVS MUST DEENERGIZE FOR MS/V EVENT.
✓ WBN-1-FSV -003-0242A -A 1-FSV -003-0242A -A UPPER TAP MAIN FW SG3 ISLN VALVE 206-381			729'	A02	A/B (3)/100D A/B 5MN/100D	MS/V FW/V		VLVS MUST CLOSE ON FW ISLN SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION. VLVS MUST DEENERGIZE FOR MS/V EVENT.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R 4
8/21/86
8/28/90

PAGE A-5

R4

08/15/90

WATTS BAR NUCLEAR PLANT

TAB A - EQUIPMENT IDENTIFICATION MATRIX

 BINDER NO. : WBNEQ-SOL-003
 MANUFACTURER : ASCO
 PAGE 6 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
✓ WBN-1-FSV -003-0242B -B 1-FSV -003-0242B -B UPPER TAP MAIN FW SG3 ISLN VALVE	206-381-2F		729'	A02 78K3-822950	A/B (3)/100D A/B 5MN/100D	MS/V FW/V		VLVS MUST CLOSE ON FW ISLN SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION. VLVS MUST DEENERGIZE FOR MS/V EVENT.
✓ WBN-1-FSV -003-0245A -A 1-FSV -003-0245A -A UPPER TAP MAIN FW SG4 ISLN VALVE	206-381		729'	A01	A/B (3)/100D A/B 5MN/100D	MS/V FW/V		VLVS MUST CLOSE ON FW ISLN SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION. VLVS MUST DEENERGIZE FOR MS/V EVENT.
✓ WBN-1-FSV -003-0245B -B 1-FSV -003-0245B -B UPPER TAP MAIN FW SG4 ISLN VALVE	206-381-2F		729'	A01 78K3-822950	A/B (3)/100D A/B 5MN/100D	MS/V FW/V		VLVS MUST CLOSE ON FW ISLN SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION. VLVS MUST DEENERGIZE FOR MS/V EVENT.
✓ WBN-1-FSV -030-0002 -A 1-FSV -030-0002 -A PURGE AIR SUP FAN A ISLN VALVE	206-381-3RF		737'	A05 84K6-835731	A/B 5MN/100D	L		DAMPERS ARE ACTIVATED BY A CNTMT VENT ISLN SIGNAL AND REQUIRED TO CLOSE AND REMAIN CLOSED FOR THE DURATION OF THE EVENT.
✓ WBN-1-FSV -030-0005 -A 1-FSV -030-0005 -A PURGE AIR SUP FAN B ISLN VALVE	206-381-3RF		737'	A05 84K6-835731	A/B 5MN/100D	L		DAMPERS ARE ACTIVATED BY A CNTMT VENT ISLN SIGNAL AND REQUIRED TO CLOSE AND REMAIN CLOSED FOR THE DURATION OF THE EVENT.

PREPARER/DATE

EEM 8/21/86

R 4

R

R

CHECKED/DATE

WBK 8/21/86

R 4

R

R

8/28/90

PAGE A-6

R4

PR: 08/15/90

BINDER NO. : WBNEQ-SOL-002
MANUFACTURER : ASCO
PAGE 7 OF 25

WATTS BAR NUCLEAR PLANT TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
✓ WBN-1-FSV -030-0007 UPPER COMPT PURGE ISLN VALVE	-A 1-FSV -030-0007 X206-381-3RF	-A 286	795'8"	ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV'S ON A CNTMT VENT ISLN SIGNAL AND RESET.
WBN-1-FSV -030-0008 UPPER COMPT PURGE ISLN VALVE	-B 1-FSV -030-0008 X206-381-3RF	-B 289	797'2"	UC 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH CNTMT VENT ISO SIG PRESENT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -030-0009 UPPER COMPT PURGE ISLN VALVE	-B 1-FSV -030-0009 X206-381-3RF	-B 263	800'9"	ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV'S ON A CNTMT VENT ISLN SIGNAL & RESET.
✓ WBN-1-FSV -030-0010 UPPER COMPT PURGE ISLN VALVE	-A 1-FSV -030-0010 X206-381-3RF	-A 261	797'	UC 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH CNTMT VENT ISO SIG PRESENT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
✓ WBN-1-FSV -030-0012 ANNULUS PURGE VALVE SOLENOID	-A 1-FSV -030-0012 X206-381-2RU	-A 260	795'8"	ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A CNTMT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R 4
8/21/86
WFM
8/28/90

R
R

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL-003
MANUFACTURER : ASCO
PAGE 8 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -030-0013 INTERIM ABSCE ISLN VALVE	-A 1-FSV -030-0013	-A X206-381-2RU	713'	A06 80KJ3-827551	A/B 5MN/100D	L		MUST DEENERGIZE TO CLOSE ASSOCIATED FCV ON ABI SIGNAL. MUST REMAIN DEENERGIZED TO PREVENT VALVE OPENING AFTER SIGNAL IS RESET.
WBN-1-FSV -030-0014 LOWER COMPT PURGE ISLN VALVE	-A 1-FSV -030-0014	-A 305 X206-381-3RF	738'10" ANN	80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A CNTMT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN.
WBN-1-FSV -030-0015 LOWER COMPT PURGE ISLN VALVE	-B 1-FSV -030-0015	-B 298 X206-381-3RF	740'5" AC4	80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH CNTMT VENT ISO SIG PRESENT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -030-0016 LOWER COMPT PURGE ISLN VALVE	-B 1-FSV -030-0016	-B 239 X206-381-3RF	732'10" ANN	80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV ON A CNTMT VENT ISOLATION SIGNAL AND RESET.
WBN-1-FSV -030-0017 LOWER COMPT PURGE ISLN VALVE	-A 1-FSV -030-0017	-A 233 X206-381-3RF	741'3" AC3	80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH CNTMT VENT ISO SIG PRESENT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R

R

R

PAGE A-8

R4

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
✓ WBN-1-FSV -030-0018 INTERIM ABSCE ISLN VALVE	-B	1-FSV -030-0018	-B X206-381-2RU	713'	A06 80KJ3-827551	A/B	5MN/100D	L	MUST DEENERGIZE AND REMAIN DEENERGIZED SO FCO DOES NOT OPEN WITH AN ABI SIGNAL PRESENT.
WBN-1-FSV -030-0019 INCORE INSTR RM PURGE ISLN VALVE	-B	1-FSV -030-0019	-B 057 X206-381-3RF	730'	ANN 80KJ3-827551	A/B	5MN/100D 5MN/100D 5MN/100D 15MN/1MO 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE ON A CNTMT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN.
✓ WBN-1-FSV -030-0020 INCORE INSTR RM PURGE ISLN VALVE	-A	1-FSV -030-0020	-A 057 X206-381-3RF	727'11"	IIR 80KJ3-827551	A/B	5MN/100D 5MN/100D 5MN/100D 15MN/1MO 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH CNTMT VENT ISO SIG PRESENT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -030-0028 INTERIM ABSCE ISLN VALVE	-A	1-FSV -030-0028	-A X206-381-2RU	737'	A05 80KJ3-827551	A/B	5MN/100D	L	MUST DEENERGIZE ON AN ABI SIGNAL AND REMAIN DEENERGIZED TO PREVENT VALVE OPENING AFTER RESET.
WBN-1-FSV -030-0029 INTERIM ABSCE ISLN VALVE	-B	1-FSV -030-0029	-B X206-381-2RU	737'	A05 80KJ3-827551	A/B	5MN/100D	L	MUST DEENERGIZE ON AN ABI SIGNAL AND REMAIN DEENERGIZED TO PREVENT VALVE OPENING AFTER RESET.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R 4
CST
8/24/90
JFM
8/28/90

R R

08/15/90

WATTS BAR NUCLEAR PLANT

TAB A - EQUIPMENT IDENTIFICATION MATRIX

 BINDER NO. : WBNEQ-SOL-003
 MANUFACTURER : ASCO
 PAGE 10 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-FSV -030-0037 -B LOWER COMPT PURGE SOLENOID	1-FSV -030-0037 -B 285 X206-381-3RF	714'6" ANN 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED ON A CNTMT VENT ISLN SIGNAL AND RESET.
WBN-1-FSV -030-0040 -A LOWER COMPT PURGE SOLENOID	1-FSV -030-0040 -A 286 X206-381-3RF	721'11" AC4 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH CNTMT VENT ISO SIG PRESENT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -030-0050 -B UPPER CNTMT EXHAUST ISLN VALVE	1-FSV -030-0050 -B 292 X206-381-3RF	718'9" AC4 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO CLOSE ASSO FCV'S ON CNTMT VENT ISO SIG & PREVENT OPENING ON SIG RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNC ASSO LS'S.
WBN-1-FSV -030-0051 -A UPPER CNTMT EXHAUST ISLN VALVE	1-FSV -030-0051 -A 290 X206-381-3RF	745'10" ANN 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV ON A CNTMT VENT ISLN SIGNAL AND RESET.
WBN-1-FSV -030-0052 -A UPPER CNTMT EXHAUST ISLN VALVE	1-FSV -030-0052 -A 252 X206-381-3RF	754' UC 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH CNTMT VENT ISO SIG PRESENT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R

R

R

PAGE A-10

R4

WATTS BAR REAR PLANT TAB A - EQUIPMENT LOCATION MATRIX

 BINDER NO. 1000000000
 MANUFACTURER : ASCO
 PAGE 11 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-FSV -030-0053 UPPER CNTMT EXHAUST ISLN VALVE	-B 1-FSV -030-0053 X206-381-3RF	-B 252	747'11" ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV ON A CNTMT VENT ISLN SIGNAL AND RESET.
WBN-1-FSV -030-0054 ANNULUS EXHAUST ISLN VALVE SOLENOID	-A 1-FSV -030-0054 X206-381-2RU	-A 039	729' ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A CNTMT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN.
WBN-1-FSV -030-0056 LOWER CNTMT EXHAUST ISLN VALVE	-A 1-FSV -030-0056 X206-381-3RF	-A 038	737'10" AC1 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH CNTMT VENT ISO SIG PRESENT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -030-0057 LOWER CNTMT EXHAUST ISLN VALVE	-B 1-FSV -030-0057 X206-381-3RF	-B 033	732'8" ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A CNTMT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN.
WBN-1-FSV -030-0058 INCORE INSTR RM EXHAUST ISLN VALVE	-B 1-FSV -030-0058 X206-381-3RF	-B 118	738'9" IIR 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO CLOSE ASSO FCV'S ON CNTMT VENT ISOL SIG AND PREVENT REOPENING MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R

4

R

R

JAH

8/21/86

JAH

8/29/90

PAGE A-11 R4

WATTS BAR NUCLEAR PLANT

TAB A - EQUIPMENT IDENTIFICATION MATRIX

 BINDER NO. : WBNEQ-SOL-003
 MANUFACTURER : ASCO
 PAGE 12 OF 25

EQIS NUMBER	UNIT	DEVICE ID NO.	AZMITH	LOCATION ELEV(1) RM/RAD	CONTRACT	CAT	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION		MODEL NUMBER				(2)			
WBN-1-FSV -030-0059 INCORE INSTR RM EXHAUST ISLN VALVE	-A	1-FSV -030-0059	-A 116	740'11" ANN	80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A CNTMT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN.
WBN-1-FSV -030-0060 INTERIM ABSCE ISLN VALVE	-A	1-FSV -030-0060	-A	757' A16	80KJ3-827551	A/B 5MN/100D	L		MUST DEENERGIZE ON AN ABI SIGNAL AND REMAIN DEENERGIZED TO PREVENT VALVE OPENING AFTER SIGNAL IS RESET.
WBN-1-FSV -030-0061 PURGE AIR EXH UNIT A SUCTION VALVE	-A	1-FSV -030-0061	-A	713' A06	84K6-835731	A/B 5MN/100D	L		DAMPERS ARE ACTIVATED BY CNTMN VENT ISLN SIGNAL AND ARE REQUIRED TO CLOSE AND REMAIN CLOSED FOR DURATION OF EVENT.
WBN-1-FSV -030-0062 PURGE AIR EXH UNIT B SUCTION VALVE	-A	1-FSV -030-0062	-A	713' A06	84K6-835731	A/B 5MN/100D	L		DAMPERS ARE ACTIVATED BY CNTMN VENT ISLN SIGNAL AND ARE REQUIRED TO CLOSE AND REMAIN CLOSED FOR DURATION OF EVENT.
WBN-1-FSV -030-0069 INTERIM ABSCE ISLN VALVE	-B	1-FSV -030-0069	-B	757' A16	80KJ3-827551	A/B 5MN/100D	L		MUST DEENERGIZE ON ABI SIGNAL AND REMAIN DEENERGIZED TO PREVENT VLV OPENING AFTER SIGNAL IS RESET.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R

4

R

R

CST

8/21/90

8/28/90

08/15/90

WATTS BAR NUCLEAR PLANT TAB A - EQUIPMENT IDENTIFICATION MATRIX

 BINDER NO. : WBNEQ-SOL-003
 MANUFACTURER : ASCO
 PAGE 13 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1) CONTRACT	RM/RAD				
WBN-1-FSV -030-0296 -A INTERIM ISLN DAMPER CDWE	1-FSV -030-0296 -A 206-381		729'	A04		A/B 5MN/100D	L	VLVS MUST CLOSE AND REMAIN CLOSED AFTER ABI.
WBN-1-FSV -030-0297 -B INTERIM ISLN DAMPER CDWE	1-FSV -030-0297 -B 206-381		729'	A04		A/B 5MN/100D	L	VLVS MUST CLOSE AND REMAIN CLOSED AFTER ABI.
WBN-1-FSV -030-0298 -B INTERIM ISLN DAMPER CDWE	1-FSV -030-0298 -B 206-381		729'	A04		A/B 5MN/100D	L	VLVS MUST CLOSE AND REMAIN CLOSED AFTER ABI.
WBN-1-FSV -030-0299 -A INTERIM ISLN DAMPER CDWE	1-FSV -030-0299 -A 206-381		729'	A04		A/B 5MN/100D	L	VLVS MUST CLOSE AND REMAIN CLOSED AFTER ABI.
WBN-1-FSV -031-0305 -B INCORE INST RM CHILL A CNR ISLN VALVE	1-FSV -031-0305 -B 060 X206-381-2RU		736'8"	ANN 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET.

PREPARER/DATE

EEM 8/21/86

R 4

R

R

CHECKED/DATE

WBK 8/21/86

CST

8/21/90

8/28/90

PAGE A-13

R4

08/15/90

BINDER NO. : WBNEQ-SOL-003
MANUFACTURER : ASCO
PAGE 14 OF 25

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT	DEVICE ID NO.	AZMITH	LOCATION	ELEV(1)	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION			MODEL NUMBER		CONTRACT		(2)			
WBN-1-FSV -031-0306 INCORE INST RM CHILL	-A	1-FSV -031-0306	-A 063 X206-381-3RF	738'	IIR 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH PHASE A CONT ISO SIG PRESNT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -031-0308 INCORE INST RM CHILL	-A	1-FSV -031-0308	-A 060 X206-381-2RU	739'	IIR 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH PHASE A CONT ISO SIG PRESNT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -031-0309 INCORE INST RM CHILL	-B	1-FSV -031-0309	-B 060 X206-381-2RU	738'8"	ANN 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET.
WBN-1-FSV -031-0326 INCORE INST RM CHILL	-A	1-FSV -031-0326	-A 100 X206-381-2RU	733'2"	ANN 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET.
WBN-1-FSV -031-0327 INCORE INST RM CHILL	-B	1-FSV -031-0327	-B 103 X206-381-2RU	733'7"	IIR 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH PHASE A CONT ISO SIG PRESNT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.

PREPARER/DATE

CHECKED/DATE

EEM 8/21/86

WBK 8/21/86

R 4
CDD
8/24/9
AFM
8/28/5

R. R.

PAGE A-14

R4

08/15/90

WATTS BAR NUCLEAR PLANT TAB A - EQUIPMENT IDENTIFICATION MATRIX

 BINDER NO. : WBNEQ-SOL-09
 MANUFACTURER : ASCO
 PAGE 15 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-FSV -031-0329 INCORE INST RM CHILL B CWR ISLN VALVE	-B 1-FSV -031-0329 X206-381-2RU	-B 102	733'2" IIR 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH PHASE A CONT ISO SIG PRESNT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -031-0330 INCORE INST RM CHILL B CWS ISLN VALVE	-A 1-FSV -031-0330 X206-381-2RU	-A 109	733'10" ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET.
WBN-1-FSV -043-0002 PRESSURIZER GAS CNTMT ISLN VALVE	-B 1-FSV -043-0002 206-381-3RF	-B 282	720' 5" AC4 75C63-085629-2	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF A PHASE A CNTMT ISOLATION SIGNAL.
WBN-1-FSV -043-0003 PRESSURIZER GAS CNTMT ISLN VALVE	-A 1-FSV -043-0003 X206-381-3RF	-A 293	721'10" ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0011 PRESSURIZER LIQUID CNTMT ISLN VALVE	-B 1-FSV -043-0011 206-381-3RU	-B 289	723'8" AC4 84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF A PHASE A CNTMT ISOLATION SIGNAL.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

 R 4
 CAT
 8/21/90
 8/28/90

R R

PAGE A-15 R4

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
		AZMITH	ELEV(1) CONTRACT				
WBN-1-FSV -043-0012 -A 1-FSV -043-0012 -A 289 PRESSURIZER LIQUID CNTMT ISLN VALVE X206-381-3RF			720' ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0022 -B 1-FSV -043-0022 -B 291 RCS HOT LEG HDR CNTMT ISLN VALVE 206-381-3RU			721'3" AC4 84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF A PHASE A CNTMT ISOLATION SIGNAL.
WBN-1-FSV -043-0023 -A 1-FSV -043-0023 -A 314 RCS HOT LEG HDR CNTMT ISLN VALVE X206-381-3RF			729'10" ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0034 -B 1-FSV -043-0034 -B 295 ACCUM TK HDR CNTMT ISLN VALVE 206-381-3RU			735'11" AC4 84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF A PHASE A CNTMT ISOLATION SIGNAL.
WBN-1-FSV -043-0035 -A 1-FSV -043-0035 -A 285 ACCUM TK HDR CNTMT ISLN VALVE 206-381-3RU			717'10" ANN 84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.

PREPARER/DATE EEM 8/21/86 8/21/86 R 4 R 4 R 4
 CHECKED/DATE WBK 8/21/86 8/21/86 R 4 R 4 R 4
8/28/90

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD (2)	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-FSV -043-0054D -B 1-FSV -043-0054D STEAM GEN 1 SAMPLE CNTMT ISLN VALVE	-B 298 X206-381-3RF		721'9" AC4 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0055 -A 1-FSV -043-0055 STEAM GEN 1 BLDN SAMPLE ISLN VALVE	-A 291 206-381-3RU		718' ANN 84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0056D -B 1-FSV -043-0056D STEAM GEN 2 CNTMT ISLN VALVE	-B 287 206-381-3RU		719'10" AC4 84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0058 -A 1-FSV -043-0058 STEAM GEN 2 BLDN SAMPLE ISLN VALVE	-A 288 206-381-3RU		717'9" ANN 84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0059D -B 1-FSV -043-0059D STEAM GEN 3 CNTMT ISLN VALVE	-B 285 206-381		718'11" AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.

PREPARER/DATE EEM 8/21/86 8/21/90 R 4 R 4
CHECKED/DATE WBK 8/21/86 8/21/90 R 4 R 4

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNQ-SOL-003
MANUFACTURER : ASCO
PAGE 18 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -043-0061 STEAM GEN 3 BLOWDOWN SAMPLE ISLN VALVE	-A 1-FSV -043-0061 206-381-3RU	-A 285	723'	ANN	84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0063D STEAM GEN 4 CNTMT ISLN VALVE	-B 1-FSV -043-0063D 206-381-3RU	-B 285	718'7"	AC4	84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0064 STEAM GEN 4 BLOWDOWN SAMPLE ISLN VALVE	-A 1-FSV -043-0064 206-381-3RU	-A 286	721'5"	ANN	84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.
WBN-1-FSV -043-0075 DNSTR EXCESS LETDOWN HTX ISLN VALVE	-B 1-FSV -043-0075 206-381-3RU	-B 318	721'2"	AC4	84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF PHASE A CNTMT ISOLATION SIGNAL.
WBN-1-FSV -043-0077 DNSTR EXCESS LETDOWN HTX ISLN VALVE	-A 1-FSV -043-0077 206-381-3RU	-A 313	721'	ANN	84PJ5-835888	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R 4
CSH
8/21/86
JFM
8/28/90

R
R
R
R

WATTS BAR NUCLEAR PLANT

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL-002
MANUFACTURER : ASCO
PAGE 19 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO.	MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			AZMITH	ELEV(1) CONTRACT				
WBN-1-FSV -043-0201 LOCA H2 CNTMT MONITOR ISLN SOL VLV	-A 1-FSV -043-0201	-A 226 X206-381-2RU	723° 3"	AC3 80KJ3-827551	A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST FUNCTION TO ALLOW SAMPLING OF CNTMT ATMOSPHERE DURING THESE EVENTS.
WBN-1-FSV -043-0202 LOCA H2 CNTMT MONITOR ISLN SOL VLV	-A 1-FSV -043-0202	-A 230 X206-381-2RU	723°	AC3 80KJ3-827551	A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST FUNCTION TO ALLOW SAMPLING OF CNTMT ATMOSPHERE DURING THESE EVENTS.
WBN-1-FSV -043-0207 LOCA H2 CNTMT MONITOR ISLN SOL VLV	-B 1-FSV -043-0207	-B 300 X206-381-2RU	728°	AC4 80KJ3-827551	A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST FUNCTION TO ALLOW SAMPLING OF CNTMT ATMOSPHERE DURING THESE EVENTS.
WBN-1-FSV -043-0208 LOCA H2 CNTMT MONITOR ISLN SOL VLV	-B 1-FSV -043-0208	-B 287 X206-381-2RU	727° 8"	AC4 80KJ3-827551	A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST FUNCTION TO ALLOW SAMPLING OF CNTMT ATMOSPHERE DURING THESE EVENTS.
WBN-2-FSV -065-0007 EGTS TRAIN A UNIT 2 SUCTION VALVE	-B 2-FSV -065-0007	-B 206-381-3RF	757°	A16 85K8-836669	B	100D	L	FOR A UNIT 1 LOCA, THIS FSV MUST NOT FAIL IN A MANNER THAT COULD OPEN THE ASSOCIATED FCV.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R 4
8/21/86
97M
8/28/90

R R

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -065-0008 -B 1-FSV -065-0008 -B EGTS TRAIN A UNIT 1 SUCTION VALVE 206-381-3RU			757'	A16 84PJ5-835888	A	100D	L	THESE REDUNDANT ISOLATION SOLENOIDS ARE MANUALLY OPERATED AND MAY BE REQUIRED ANYTIME DURING LOCA.
WBN-1-FSV -065-0010 -A 1-FSV -065-0010 -A EGTS TRAIN A UNIT 1 SUCTION VALVE 206-381-3RF			757'	A16 84K6-835731	A	100D	L	MUST ENERGIZE TO OPEN ASSOCIATED FCV AND REMAIN ENERGIZED FOR DURATION OF EVENT.
WBN-1-FSV -065-0026 -A 1-FSV -065-0026 -A UNIT 1 SHIELD BLDG EXHAUST A VALVE 206-381-3RF			757'	A16 84K6-835731	A	100D	L	DAMPERS MUST OPEN ON A CNTMT ISLN SIGNAL SO EGTS CAN DISCHARGE.
WBN-1-FSV -065-0027 -B 1-FSV -065-0027 -B UNIT 1 SHIELD BLDG EXHAUST B VALVE 206-381-3RF			757'	A16 84K6-835731	A	100D	L	DAMPERS MUST OPEN ON A CNTMT ISLN SIGNAL SO EGTS CAN DISCHARGE.
WBN-0-FSV -065-0028A -B 0-FSV -065-0028A -B EGTS TRAIN A DECAY COOL VALVE A 206-381-3RU			757'	A16 84PJ5-835888	A	100D	L	AUTOMATICALLY ACTIVATES TO OPEN DAMPERS WHICH REMOVE DECAY HEAT WHENEVER TRAIN IS ISOLATED.

PREPARER/DATE EEM 8/21/86 CSH 8/21/86 R 4
CHECKED/DATE WPK 8/21/86 QTM 8/28/86 R R

WATTS BAR NUCLEAR PLANT TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL-003
MANUFACTURER : ASCO
PAGE 21 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-0-FSV -065-0028B -B 0-FSV -065-0028B -B EGTS TRAIN A DECAY COOL VALVE B 206-381-3RU			757' 84PJ5-835888	A16	A	100D	L	AUTOMATICALLY ACTIVATES TO OPEN DAMPERS WHICH REMOVE DECAY HEAT WHENEVER TRAIN IS ISOLATED.
WBN-1-FSV -065-0030 -B 1-FSV -065-0030 -B EGTS TRAIN B UNIT 1 SUCTION VALVE 206-381-3RF			757' 84K6-835731	A16	A	100D	L	MUST ENERGIZE TO OPEN ASSOCIATED FCV AND REMAIN ENERGIZED FOR DURATION OF EVENT.
WBN-0-FSV -065-0047A -A 0-FSV -065-0047A -A EGTS TRAIN B DECAY COOL VALVE A 206-381-3RU			757' 84PJ5-835888	A16	A	100D	L	AUTOMATICALLY ACTIVATES TO OPEN DAMPERS WHICH REMOVE DECAY HEAT WHENEVER TRAIN IS ISOLATED.
WBN-0-FSV -065-0047B -A 0-FSV -065-0047B -A EGTS TRAIN B DECAY COOL VALVE CONT 206-381-3RU			757' 84PJ5-835888	A16	A	100D	L	AUTOMATICALLY ACTIVATES TO OPEN DAMPERS WHICH REMOVE DECAY HEAT WHENEVER TRAIN IS ISOLATED.
WBN-2-FSV -065-0050 -A 2-FSV -065-0050 -A EGTS TRAIN B UNIT 2 SUCTION VALVE 206-381-3RF			757' 85K8-836669	A16	B	100D	L	FOR A UNIT 1 LOCA, THIS FSV MUST NOT FAIL IN A MANNER THAT COULD OPEN THE ASSOCIATED FCV.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R 4
8/21/90
ATM
8/20/90

R R

PRINT DATE: 09/29/90

BINDER NO. : WBNEQ-SOL -003
MANUFACTURER : ASCO
PAGE 22 OF 25

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -065-0051 -A 1-FSV -065-0051 -A EGTS TRAIN B UNIT 1 SUCTION VALVE	206-381-3RU		757'	A16 84PJ5-835888	A	100D	L	THESE REDUNDANT ISLN SOLENOIDS ARE MANUALLY OPERATED & MAY BE REQUIRED ANYTIME DURING LOCA.
WBN-1-FSV -065-0052 -A 1-FSV -065-0052 -A CNTMT ANNULUS VAC FANS ISLN DMPR	X206-381-3RF		757'	A16 80KJ3-827551	A/B	5MN/100D	L	DAMPERS MUST CLOSE ON A CNTMT ISLN SIGNAL TO ISOLATE THE ANNULUS VACUUM FANS.
WBN-1-FSV -065-0053 -B 1-FSV -065-0053 -B CNTMT ANNULUS VAC FANS ISLN DMPR	X206-381-3RF		757'	A16 80KJ3-827551	A/B	5MN/100D	L	DAMPERS MUST CLOSE ON A CNTMT ISLN SIGNAL TO ISOLATE THE ANNULUS VACUUM FANS.
WBN-1-FSV -068-0307 -A 1-FSV -068-0307 -A 313 RCS FLOW CNTL VALVE WDS GA TO PRT	206-381-3RF		718'	ANN 75C63-85629-2	A/B	5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING UPON RECPT PHASE A CNTMT ISO SIGNAL. MUST NOT FAIL IN MANNER TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -070-0085 -B 1-FSV -070-0085 -B EXCESS LETDOWN HTX OUTLET VALVE	X206-381-2RU		713'	A28 80KJ3-827551	A/B	5MN/100D B 1MO B 1MO B 1MO B 1MO	L CV/A RH/A AF/A AB/A	MUST REMAIN DEENERZD DURATION ALL EVENTS AS LISTED TO ENSURE FCV CONT ISOL FOR LOCA AND LS PAM FUNCTION ALL OTHER EVENTS.

PAGE A-22

R5

PREPARER/DATE EEM 8/21/86

CHECKED/DATE WBK 8/21/86

R 4
CDH
8/21/86
AFM
8/22/86
R 5
CDH
10/17/90
R
10/17/90

WATTS BAR NUCLEAR PLANT

TAB A - EQUIPMENT IDENTIFICATION MATRIX

 BINDER NO. : WBNEQ-SOL-003
 MANUFACTURER : ASCO
 PAGE 23 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO.	MODEL NUMBER	LOCATION			CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			AZMUTH	ELEV(1)	RM/RAD				
WBN-1-FSV -077-0127 -B REAC BLDG SUMP DISCH FLOW SOL VALVE	1-FSV -077-0127 -B	X206-381	296	720'10"	AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE TO CLOSE ASSOC ISOL VLV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCTION OF ASSOC LIMIT SWS.
WBN-1-FSV -077-0128 -A REAC BLDG SUMP DISCH FLOW SOL VALVE	1-FSV -077-0128 -A	X206-381-3RF		713' 80KJ3-827551	A28	B 1MO B 1MO B 1MO B 1MO A/B 5MN/100D	RH/A CV/A AF AB L		MUST DEENERGIZE TO CLOSE ASSOC ISOL VLV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -090-0107 -A CNTMT BLDG LWR COMPT MON ISLN VALVE	1-FSV -090-0107 -A	X206-381-3RF	294	741'11"	ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.
WBN-1-FSV -090-0108 -B CNTMT BLDG LWR COMPT MON ISLN VALVE	1-FSV -090-0108 -B	X206-381-3RF	297	737'9"	AC4 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.
WBN-1-FSV -090-0109 -B CNTMT BLDG LWR COMPT MON ISLN VALVE	1-FSV -090-0109 -B	X206-381	298	737' 7"	AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.

R4

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R

R

R

8/21/90

JFM

8/28/90

PR. 08/15/90

WATTS BAR NUCLEAR PLANT TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL-003
MANUFACTURER : ASCO
PAGE 24 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -090-0110 -B 1-FSV -090-0110 -B 296 CNTMT BLDG LWR COMPT MON ISLN VALVE X206-381-3RF			738'1" AC4 80KJ3-827551		A/B 5MN/100D L A/B 5MN/100D MS/C A/B 5MN/100D FW/C A/B 15MN/1MO RH/C A/B 1HR/1MO CV/C			MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.
WBN-1-FSV -090-0111 -A 1-FSV -090-0111 -A 293 CNTMT BLDG LWR COMPT MON ISLN VALVE X206-381-3RF			741'11" ANN 80KJ3-827551		A/B 5MN/100D L A/B 5MN/100D MS/C A/B 5MN/100D FW/C A/B 15MN/1MO RH/C A/B 1HR/1MO CV/C			MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.
WBN-1-FSV -090-0113 -A 1-FSV -090-0113 -A 292 CNTMT BLDG UPPER COMPT MON ISLN VALVE X206-381-3RF			740'5" ANN 80KJ3-827551		A/B 5MN/100D L A/B 5MN/100D MS/C A/B 5MN/100D FW/C A/B 15MN/1MO RH/C A/B 1HR/1MO CV/C			MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.
WBN-1-FSV -090-0114 -B 1-FSV -090-0114 -B 295 CNTMT BLDG UPPER COMPT MON ISLN VALVE X206-381-3RF			737'9" AC4 80KJ3-827551		A/B 5MN/100D L A/B 5MN/100D MS/C A/B 5MN/100D FW/C A/B 15MN/1MO RH/C A/B 1HR/1MO CV/C			MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.
WBN-1-FSV -090-0115 -B 1-FSV -090-0115 -B 294 CNTMT BLDG UPPER COMPT MON ISLN VALVE X206-381-3RF			737'9" AC4 80KJ3-827551		A/B 5MN/100D L A/B 5MN/100D MS/C A/B 5MN/100D FW/C A/B 15MN/1MO RH/C A/B 1HR/1MO CV/C			MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.

PREPARER/DATE

EEM 8/21/86

CHECKED/DATE

WBK 8/21/86

R 4

R

R

8/21/86

8/28/90

PAGE A-24 R4

PRINTED 08/15/90

WATTS BAR NUCLEAR PLANT TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL-003
MANUFACTURER : ASCO
PAGE 25 OF 25

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -090-0116 CNTMT BLDG UPPER COMPT MON ISLN VALVE	-B 1-FSV -090-0116 X206-381	-B 291	737' 8"	AC4	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.
WBN-1-FSV -090-0117 CNTMT BLDG UPPER COMPT MON ISLN VALVE	-A 1-FSV -090-0117 X206-381-3RF	-A 290	741' 7"	ANN 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISOLATION SIGNAL PRESENT OR RESET.

PREPARER/DATE EEM 8/21/86 CSH 8/21/86 R 4
CHECKED/DATE WBK 8/21/86 ATM 8/28/90 R R

PAGE A-25 R4

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R 4 R
BINDER TITLE ASCO SOLENOID COMPUTED /R2 CDH DATE 4/30/90 CDH
VALVES, MODEL 206-381 - SERIES 8/21/90
(DC CONSTRUCTION) CHECKED /R2 AFM DATE 4/30/90 AFM
8/28/90

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-3 for source of Category and Operating Time assignments.
3. See TAB C-4, page C-90 for a discussion on post-accident conditions for these valves.
4. Contract numbers shown in this TAB were obtained by tracing the serial number on each valve through TVA procurement records and did not depend on field verification data for contract numbers.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 26
 BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381 - SERIES (DC CONSTRUCTION) COMPUTED EEM DATE 8/21/86 4/30/90
 CHECKED WBK DATE 8/21/86 4/30/90

A. DOCUMENTATION (See Note on Page B-3)

R2

Equipment Description Solenoid Valves
 Vendor/Manufacturer Automatic Switch Company (ASCO)
 Equipment Model No.(s) 206-381-2RU 206-281-3RVU
206-381-3RU 206-381-6RVF
206-381-3RF 206-381-2F

QUALIFICATION REPORTS (See TAB C, "Discussion")(See Note on Page B-3)

R2

- (1) Title/Number/Revision "Report on Qualifi- cation of Automatic Switch Co. (ASCO) Catalog NP-1 Solenoid Vlvs for Safety-Related Applications in Nuclear Power Generating Stations", AQR-67368, Rev. 1 RIMS B45 850514 428 DATE 8/19/83
- (2) Title/Number/Revision "Equipment Qualifi- cation Research-Test Program & Failure Analysis of Class 1E Solenoid Vlvs", F-C5569-309/315, Appendix C. RIMS NEB 840925 351 DATE Nov. 1983
- (3) Title/Number/Revision "Aging and Qualifi- cation Research on Solenoid Operated Valves," NUREG/CR-5141 RV RIMS B74 890623 502 DATE August 1988
- (4) Title/Number/Revision "ASCO Engineering Report No. 177" RIMS B25 870612 003 DATE 12/11/79

OTHER (ANALYSIS, VENDOR DATA, ETC.)

Refer to Sheets 1A & 1B

Note: Throughout this TAB, references are made to the ASCO qualification report listed above. This report is identified as (2) in these references. Although the COCs in TAB E certify compliance to ASCO test report AQS21678/TR, Rev. A, NRC Information Notice 85-08, para. 4.b (see TAB J-4) considers all ASCO NP-1 valves (except NP8316 series) qualified to (1) above. Therefore, we are using (1) above for qualification of the valves in this binder.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 1a OF 26 | R1
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/24/86 CRH
 VALVES, MODEL 206-381 - SERIES 4/30/90
 (DC CONSTRUCTION) CHECKED WBK/HDR DATE 9/24/86 CRH
4/30/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

R2

Description	RIMs No.
(5) Wyle Test Report No. 17523-1, Test Program on Sealants for Class 1E Devices	EEB 840731 501
(6) Wyle Laboratories Letter dated December 10, 1985.	B45 851213 008
(7) ASCO Letter dated April 29, 1985; NP Valve Mounting Orientation.	B43 850502 015
(8) ASCO Letters dated May 8, 1986 and May 16, 1986; respectively; Coil Heat Rise Versus Ambient Temperature Data.	B71 860512 001 & B71 860520 001
(9) Status and Duty Cycles of 1E Solenoid Valves Located in Potentially Harsh Environments (WBNOSG4-045 R1).	B45 860902 219
(10) Reduction of Beta Dose by Sheet Steel (WBNTSR-051 R0).	B26 891129 202
(11) Deleted by Revision 2.	
(12) Beta Dose Reduction From Finite Volume (WBNTSR-057 R0).	B26 891221 201
(13) 100-Day LOCA Dose to Electrical Equipment in the EGTS Filter Train Room (WBNNAL3-031 R1).	B45 880826 235
(14) LOCA Temperature Profile in the Dead-Ended Compartments (QIR NEB86170).	B45 860922 253
(15) Safety evaluation of superheated steam in the valve vaults caused by a main steam line break (WBNOSG4-003 R2).	B45 851112 218
(16) Solenoid Valve Voltage Study (WBNEB-MS-TI11-0004 WBPE-VAR-8602002) <u>WBNEB-MS-TI11-0004</u> <u>B26 900202 407</u> <u>Later</u>	
(17) Integrated Accident Dose inside Primary Containment (TI-RPS-48 R2).	B45 851105 235

R2

CRH
4/17/90

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 1b OF 26
R 3 R 4
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/24/86 CDH CDH
VALVES, MODEL 206-381 - SERIES 5/11/90 8/23/90
(DC CONSTRUCTION) CHECKED WBK/HDR DATE 9/24/86 AFM CDH
5/17/90 8/23/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

Type	RIMS No.
Category and Operating Times	
(18) System 1 (WBNOSG4-004 R11)	B18 900612 253 R4
(19) System 3 (WBNOSG4-005 R10)	B45 900314 202
(20) System 30 (WBNOSG4-008 R15)	B26 900309 231
(21) System 31 (WBNOSG4-009 R7)	B26 900309 233
(22) System 43 (WBNOSG4-011 R10)	B26 900309 228 R4
(23) System 65 (WBNOSG4-015 R10)	B26 900309 226
(24) System 68 (WBNOSG4-017 R9)	B26 890510 506
(25) System 70 (WBNOSG4-018 R13)	B26 900110 200
(26) System 77 (WBNOSG4-021 R5)	B18 900612 251 R4
(27) System 90 (WBNOSG4-026 R7)	B45 870227 426
(28) U2 for U1 (WBNOSG4-040 R5)	B26 890321 016
(29) TVA Environmental Drawing 47E235-41 R1 and DCA-P04104-01-0 per DCN P-04104-C (B26 890908 819)	
(30) TVA Environmental Drawing 47E235-42 R2 and DCA-P04104-03-0 and DCA-P04104-05-0 per DCN P-04104-C (B26 890908 819)	
(31) TVA Environmental Drawing 47E235-44 R1	
(32) TVA Environmental Drawing 47E235-45 R1 and DCA-P04104-06-0 per DCN P-04104-C (B26 890908 819)	
(33) TVA Environmental Drawing 47E235-48 R3	
(34) TVA Environmental Drawing 47E235-56 R1	
(35) TVA Environmental Drawing 47E235-61 R1	
(36) TVA Environmental Drawing 47E235-76 R3	
(37) TVA Environmental Drawing 47E235-78 R3	
(38) Attenuation Factors for Postaccident Beta Dose B04 900320 300 in Primary Containment (GENAPS3-023 R0)	
(39) Dose Grid Around the EGTS Filter (WBNTSR-018 R0) B26 891106 203	

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 2 OF 26
R 3 R 4
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/24/86 CDH CRH
VALVES, MODEL 206-381 - SERIES 5/17/90 8/21/90
(DC CONSTRUCTION) CHECKED WBK/HDR DATE 9/24/86 AFM AFM
5/17/90 8/28/90

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

- (1) Deleted by revision 2.
- (2) Deleted by revision 2.
- (3) Deleted by revision 2.
- (4) Deleted by revision 2.
- (5) Solenoid valves with missing nameplates must be replaced
with qualified models and must be field verified.
- (6) Replace four solenoid valves which must be environmentally
qualified to perform their intended safety-related functions.
- (7) Deleted by revision 2.
- (8) Conduit seal must be installed on several valves to meet
PAM requirements.
- (9) WBN position on possibility of multiple ground faults
existing in DC distribution systems must be established.

R4

BINDER NO. WBNEQ-SOL-003

UNIT(S) ¹

SHEET 3 OF 26

R

R

ASC0 SOLENOID
BINDER TITLE VALVES, MODEL 206-381-SERIES
(DC CONSTRUCTION)

COMPUTED E.E.M.

DATE 8/21/86

CHECKED

DATE 8/2/80

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

<u>X</u>	Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
1	100% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
2	90% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
3	80% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
4	70% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
5	60% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
6	50% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
7	40% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
8	30% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
9	20% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
10	10% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)
11	0% of components are qualified to the criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)

Components are Qualified to the Criteria of NUREG-0588 .
Category II or the DOR Guidelines of 1E Bulletin No. 79-
01B (IEEE 323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 323-1974, IEEE 344-1975, IEEE 382-1980, and IEEE 627-1980

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S)¹ _____ SHEET 4 OF 26

BINDER TITLE ASCO SOLENOID COMPUTED EGM DATE 8/21/86 R _____ R _____
VALVES, MODEL 206-381-SERIES
(DC CONSTRUCTION) CHECKED WTK DATE 8/21/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- _____ Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- X Test of Similar Items with Supporting Analysis
- _____ Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- _____ Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS See TAB C

BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 *4/30/90*VALVES, MODEL 206-381 - SERIES(DC CONSTRUCTION) CHECKED WBK DATE 8/22/86 *5/1/90*E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>	
			Page 1	
(1) Equipment Type	<u>Solenoid Vlv</u>	<u>Solenoid Vlv</u>	of (1)	
			Page 1	
(2) Manufacturer	<u>ASCO</u>	<u>ASCO</u>	of (1)	
			Page 1 & 5	R2
(3) Model Number(s)	<u>206-381-2F</u>	<u>206-381-6RF</u>	of (1)	
		<u>K206-380-3RVF</u>	Table 3.2	
	<u>206-381-3RU</u>	<u>(Viton)</u>	of (1)	
		<u>NP832070E</u>	App. I	
	<u>206-381-RU</u>	<u>(Coil only)</u>	of (1)	
	<u>206-381-3RF</u>			
	<u>206-381-3RVU</u>			
	<u>206-381-6RVF</u>			
			Table 3.2	
(4) Serial Number(s)	<u>See TAB F</u>	<u>Test Valve #3</u>	of (1)	
		<u>Test Valve #2</u>	Table 3.2	R2
		<u>(Viton)</u>	of (1)	
(5) Identify Component-	<u>None</u>			
Unique checksheet				
attached:				

JUSTIFICATION/COMMENTS "X" Prefix to model numbers listed in TAB A
indicated A 1/2" NPT conduit connection in place of standard 3/4"
NPT connection. Differences between installed models and tested
models are orifice size, mode of operation (i.e., normally closed,
normally open, universal) and seat material. Orifice size and mode
of operation do not affect qualification. Both elastomeric
materials used as seats have been addressed in TAB C and metal-to-
mtal seats are not environmentally degradable.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 6 OF 26
 R 2 R
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/05/86 4/30/90
 VALVES, MODEL 206-381 - SERIES (DC CONSTRUCTION) CHECKED WBK/HDR DATE 9/05/86 5/1/90

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>	
Mounting Bolts	None Specified; See TAB C, "Interfaces"	No	NA	R2
External Process Connections	None Specified; See TAB C, "Interfaces"	Yes	See Below and Ref(1) Section 9.5.3 p D-98	
Electrical Connections	None Specified; See TAB C, "Interfaces"	Yes	NA	
Conduit Seals	See TAB C-9	Yes	Section 5.3 of (1)	
Connector Seals	N/A	No	NA	R2
Orientation	Vertical & Upright $\pm 45^\circ$	Yes	App. A, pg A2 of (1) & ASCO Letter (TAB E-9)	R2
Physical Configuration	Conduit/Junction Box must be oriented such that moisture does not drain into coil housing	No	Ref (1) Sec. 5.3 and P-1 this TAB	R2
Other	See below	Yes	See below	

JUSTIFICATION/COMMENTS ASCO does not identify specific interfacing requirements except to require a 90° street elbow facing downward connected to exhaust port or similar configuration to prevent moisture intrusion from liquid spray. This is required only on valves located inside containment and subject to containment spray. (Reference: Page A18, Section 9.5.3 of (1)). See TAB C-15 for TVA's position on this. TAB G lists valves requiring elbows. See TAB C for a description of the TVA interfaces. The process fluid for these valves is oil-free instrument air. See TAB J-2 for discussion.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 7 OF 26
 R 2 R
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 4/27/90
 VALVES, MODEL 206-381 - SERIES
 (DC CONSTRUCTION) CHECKED WBK DATE 8/22/86 4/27/90
5/1/90

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (Yes/No/NA)? (Note below.)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	Sect. 4, pg. 8 of (1)
(b) Baseline performance measurements taken	<u>Yes</u>	Sect. 4, pgs. 8,23,24 of (1)
(c) Equipment aged:		
Thermal	<u>Yes</u>	Sect. 4.1.1, pg. 8 of (1)
Radiation	<u>Yes</u>	Sect. 4.1.4, pg. 15 of (1)
Wear	<u>Yes</u>	Sect. 4.1.2, pg. 12 of (1)
(d) Vibration/seismic testing conducted	<u>Yes</u>	Sect. 4.1.5, pg. 15 Sect. 4.1.6, pg. 17 of (1)
(e) Design basis event (DBE) exposure	<u>Yes</u>	Sect. 4.2, pgs. 19-23 of (1)
(f) Post-DBE exposure	<u>Yes</u>	Sect. 4.2.3, pgs. 22 & 23 of (1)
(g) Final inspection and disassembly	<u>Yes</u>	Sect. 4.4, pg. 24 of (1)

R2

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)? Yes R2
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (Yes/No/NA)? Yes (Reference: Appendix G of (1)). R2

JUSTIFICATION/COMMENTS Test Valve #2 was utilized to qualify the Viton elastomers. Reference to this valve is in regard to Viton elastomers qualification only unless otherwise noted. R2

Appendix I of (1) is used for coil qualification. R2

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 8 OF 26
 BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381 - SERIES (DC CONSTRUCTION) COMPUTED EEM DATE 8/21/86 CRZ
 CHECKED WBK DATE 8/22/86 4/30/90
9/8/94
5/1/90

H. AGING

- (1) Was aging considered in the qualification program (Yes/No/NA)? Yes (Reference: Appendix A, Sect. 9.4,

pg. A10 of (1), and TAB C). R2

JUSTIFICATION/COMMENTS Aging was done using nitrogen as the process fluid in lieu of instrument air. See TAB C-11.

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>App. A, Sect. 9.4.1 of (1)</u>
Radiation exposure	<u>Yes</u>	<u>App. A, Sect. 9.4.4 of (1)</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>App. A, Sect. 9.4.5 of (1)</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>App. A, Sect. 9.4.2 and 9.4.3 of (1)</u>

JUSTIFICATION/COMMENTS _____

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (Yes/No/NA)? Yes (Reference: NA

JUSTIFICATION/COMMENTS See Discussion, P-4.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (Yes/No/NA)? Yes (Reference: App. A, Sect. 9.4.1,

pg. A10 of (1) and TAB C). R2

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 9 OF 26
R 2 R
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CEH
VALVES, MODEL 206-381 - SERIES 4/39/90
(DC CONSTRUCTION) CHECKED WBK DATE 8/22/86 ADM
5/1/90

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (Yes/No/NA)? Yes
(Reference: App. B of (1)). | R2

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for thermal aging identified in the qualification program (Yes/No/NA)? Yes
(Reference: Sect. 4.1.1 & App. A, sect. 9.4.1 of (1)). | R2

JUSTIFICATION/COMMENTS _____

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (Yes/No/NA)? Yes (Reference: App. A, Sect. 9.4.1 of (1)). | R2

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>130° F (worst case)</u>	<u>250°F</u>	<u>140°F</u>
Time	<u>40 years</u>	<u>18-1/4 days</u>	<u>8 years</u>

JUSTIFICATION/COMMENTS The above equivalent time is based | R2
on the activation energy of the EPDM Elastomers (0.94eV)
and does not consider heat rise due to the coil being
energized. See TAB C-13 for heat rise analysis. | R2

- (e) Was the Arrhenius methodology used for accelerated aging (Yes/No/NA)? Yes (Reference: Pg. 9 & App. A, Section 9.4.1 of (1) & TAB C). | R2

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (Yes/No/NA)? Yes
(Reference: App. B of (1)). | R2

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 10 OF 26
R. 2 R. 2
BINDER TITLE ASCO SOLENOID - COMPUTED EEM - DATE 8/21/86 CRL
VALVES, MODEL 206-381 - SERIES 420/2
(DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 ADM
5/1/90

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? N/A
(Reference: _____).

JUSTIFICATION/COMMENTS _____

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? Yes (Reference: Sect. 4.1.1, pg. 11 of

(1) _____). | R2

JUSTIFICATION/COMMENTS _____

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: App. A, Sect. 9.4.4 & 9.5.2 of (1) _____). | R2

JUSTIFICATION/COMMENTS _____

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? No
(Reference: _____).

JUSTIFICATION/COMMENTS ASCO's intent was not to subject the test specimen to radiation exposure in accordance with the limiting material. Their intent was to demonstrate operability regardless of the radiation threshold values by testing the entire assembly.

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? Yes
(Reference: Sect. 4.1.4 & 4.2.2 & App. A, Sect. 9.4.4 & 9.5.2 of (1) _____). | R2

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 11 OF 26
R 2 R
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/26/86 CDL
VALVES, MODEL 206-381 - SERIES 4/30/90
(DC CONSTRUCTION) CHECKED WBK DATE 8/26/86 ADM
5/1/90

H. AGING (Continued)

- (5) (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: Sect. 4.1.4 of (2)).

Plant normal ambient radiation dose (rd) 2×10^7 (worst case)

Test exposure dose (rd) 2.3×10^7 gamma

Test exposure dose rate (rd/hr) 0.71 Mrad/hr

Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS Test valve was exposed to a combined aging and accident dose of 2.05×10^8 Rads, which exceeds the worst case combined plant dose of 6×10^7 Rads. Valves with Viton elastomers must be limited to 2×10^7 Rads combined normal and accident dose if required to shift position after exposure.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program? Yes (Reference: App. A, Sect. 9.4.5, pg. A13; and Sect. 4.1.5 of (1)).

JUSTIFICATION/COMMENTS No failure which could be attributed to vibration aging was identified.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Sect. 4.1.5; App. A, Sect. 9.4.5; of (1)).

JUSTIFICATION/COMMENTS _____

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: Sect. 4.1.2, 4.1.3, & 4.1.5 of (1)).

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 12 OF 26
R 2 R
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CZJ
VALVES, MODEL 206-381 - SERIES 4/30/90
(DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 WFM
5/1/90

H. AGING (Continued)

- (7) (a) JUSTIFICATION/COMMENTS Effects resulting from these
stresses were not discernable from other effects.
However, the valves successfully passed the baseline
tests following thermal aging, wear aging, pressurization
aging, and radiation aging.
- (b) Was the basis for stresses induced during operational
aging identified and justified in the qualification
program (Yes/No/NA)? Yes (Reference: App. A, Sects. 9.4.2, 9.4.3 & 9.4.5 of (1)). | R2
JUSTIFICATION/COMMENTS _____

- (8) Was the qualified life of the equipment and its basis defined
in the qualification program (Yes/No/NA)? Yes
(Reference: Sect. 4.1.1 of (1)). | R2

Qualified life (Document in QMDS) See TABS C and G
JUSTIFICATION/COMMENTS The qualified life is different,
in most cases, from the value given in the test report.
TAB C provides rationale.
- (9) Were replacement intervals for the equipment or its components
defined in the qualification program (Yes/No/NA)? Yes
(Reference: App. C of (1)). | R2
JUSTIFICATION/COMMENTS Replacement intervals and qualified
life are a function of plant specific conditions in
comparison to test conditions. TABS C and G define the
replacement intervals and qualified life and their basis. | R2

BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/23/86 4/30/90VALVES, MODEL 206-381 - SERIES ATM(DC CONSTRUCTION) CHECKED WBK DATE 8/23/86 5/1/90I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

<u>Material/Property/Function</u>	<u>Radiation</u>		<u>Activation</u>	
	<u>Threshold</u>	<u>Reference</u>	<u>Energy</u>	<u>Reference</u>
(Coil) IsoMica bonded				App. B, pg. B5-
(a) <u>with Hi-Temp Epoxy</u>	<u>NA</u>	<u>NA</u>	<u>1.00</u>	<u>B7 of (1)</u>
(Seats) Ethylene Propylene				App. B, pg.
(b) <u>Terpolymer</u>	<u>NA</u>	<u>NA</u>	<u>0.94</u>	<u>B3 of (1)</u>
(c) <u>Viton (Seats)</u>	<u>NA</u>	<u>NA</u>	<u>1.04</u>	App. B, pg. B4 of (1)
(d) <u>*DC 550 Lubricant</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>
(e) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>

R2

JUSTIFICATION/COMMENTS Note: The Class H coil is composed of six primary materials. Of these, the one with the lowest activation energy is Iso-Mica bonded with hi-temperature epoxy. Its activation energy is 1.00 eV. The materials of coil construction along with their activation energies are identified in Appendix B, page B5 through B7 of (1). Radiation values are not required because no analysis was performed. The devices were qualified by test.

*Although not stated in reference 1, DC 550 lubricant was used on tested valves as verified by ASCO letter dated January 5, 1988 (see TAB E-12).

R2

BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CRT
VALVES, MODEL 206-381 - SERIES 430/90
(DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 ATM
5/1/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (Yes/No/NA)? Yes
(Reference: App. A, Sect. 6.1, 6.2, and 6.3 of (1)). R2

Identify Acceptance Criteria: Coil only taken from (1) -
Must operate at any voltage between 90VDC and 140VDC.
Battery operated DC valves must operate on demand at any
voltage between 28% below and 12% above the specified
nominal DC voltage. Insulation resistance must measure
greater than or equal to 1 megohm at 500VDC. Leakage
current must be less than 0.5 milliamps at 1250 VAC for
1 minute. For seats and discs, as taken from (1) - Valves R2
must operate at the minimum and maximum operating pressure
differential. Valves must not have a pressure increase at
a cylinder port which is required to be vented or a pressure
decrease at a cylinder port which is required to be
pressurized in excess of 10% of the maximum operating
pressure differential. Valves must shift to energized
position upon application of power within limits specified
above and shift to deenergized position when power is
removed, with inlet press. applied at any value between
max. and min. pressure differential.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (Yes/No/NA)? Yes
(Reference: Ref. App. A, Sects. 6.1, 6.2, 7.1, 7.2, and

Table 4.4 of (1)). R2

Identify baseline and functional testing: Recording coil
excitation, coil dielectric, seat leakage at 125 psig and
10 psig in both the energized and deenergized state, noise
test, external leakage at 125 psi, operational test from
125 psig to 0 psig, insulation resistance and number of
active coil turns during initial baseline and following
DBA simulation.

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 15 OF 26
 R 2 R
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CAH
 VALVES, MODEL 206-381 - SERIES 4/30/90
 (DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 QAM
5/1/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

JUSTIFICATION/COMMENTS _____

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (Yes/No/NA)? Yes
 (Reference: Appendix A, Sect 9.5.3 & Fig 9.2, page A26 of (1)) | R2

JUSTIFICATION/COMMENTS _____

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: Table 4.3 and Table 4.4 of (1)) | R2

JUSTIFICATION/COMMENTS _____

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>125V DC</u>	<u>See Below</u>
Load	<u>35.1 Watts</u>	<u>Contracts, TAB E</u>
Frequency	<u>NA</u>	
Accuracy	<u>NA</u>	
Other(s)		

R2

JUSTIFICATION/COMMENTS Wiring diagrams drawings
#45N600-1-2,4; -3-2,11; -30-8,9,11,12; -31-1,
-43-1,2; -65-1,3; -68-1; -70; -77-2,6; -90-1.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 26
 R 2 R 4
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CDH CSH
 VALVES, MODEL 206-381 - SERIES 4/30/90 8/21/90
 (DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 AFM CSH
 5/1/90 8/28/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) Parameter	Specific Accident Conditions	Reference
Voltage	90 VDC Min. (See comment)	
Load	Not specified	
Frequency	NA	NA
Accuracy	NA	NA
Other(s)		

JUSTIFICATION/COMMENTS TVA Calculation WBN EEB-MS-TI11-0004
determines voltage available to each valve during accident
conditions. (See comment after J.(5)(c)).

(c) Parameter	Demonstrated Conditions	Reference
Voltage	90 VDC	Fig. 9.2 P. A26 of (1) App. IX , AI pg. AI-2 of (1)
Load	35.1 Watts	
Frequency	NA	
Accuracy	NA	
Other(s)		

R4

CSH
8/12/90

JUSTIFICATION/COMMENTS Ref. (1), App. A, Section 6.1.1,
requires 125VDC valves to operate on demand at any voltage
between 90-140VDC. Per Figure 9.2 of Ref. (1) the test valve
was successfully tested at 90VDC. A primary concern with
solenoid valves is that of voltage available at the coil
terminals. TVA calculation WBN EEB-MS-TI11-0004 shows that
the valves in this binder are supplied voltage within their
environmentally qualified minimum rating as required to
perform their safety functions during accident conditions.

R4

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 17 OF 26
 R 2 R 4
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CDH CDH
 VALVES, MODEL 206-381 - SERIES 4/30/90 8/21/90
 (DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 AFM AFM
 5/1/90 8/28/90

K. REQUIRED OPERATING ENVIRONMENT (Worst Case for All Environmental Areas)

Reference Environmental Drawing No. 47E235-42 and 47E235-76

- (1) Normal Max (2) Abnormal Max
- (a) Temperature (°F) 130°F (a) Temperature (°F) 140°F
- (b) Pressure (psig) 14.7 psia (b) Pressure (psig) 14.7 psia
- (c) Humidity (%) 80% (c) Humidity (%) 100%
- 2×10^7 rads
TID
- (d) Radiation (rd) (d) Radiation (rd) NA
- (3) Process Interfaces: The process fluid for these valves is oil-free instrument air with a maximum design temperature of 100°F. Therefore, the bounding temperature for these valves is the ambient.
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Up to eight hours per excursion and less than 1% of plant life.
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- (a) Temperature (°F) 327°F* Accident type LOCA/HELB
- 11.2 psig
- (b) Pressure (psig) 25.6 psia Accident type LOCA/HELB
- (c) Humidity (%) 100% Accident type LOCA/HELB
- 4.7×10^8 rads
(beta)
 3.8×10^7 rads
- (d) Radiation (rd) (gamma) Accident type LOCA/HELB
- 0.1847 molar H₃BO₃
(2000 ppm Boron)
0.333 molar NaOH
- (e) Spray Type pH 8.3 @ 25°C Accident type LOCA/HELB

*See Tab C-4, Page C-90, for discussion of MSLB in the main steam valve rooms.

|R4

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 18 OF 26
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/24/86 CH
 VALVES, MODEL 206-381 - SERIES 4/30/90
 (DC CONSTRUCTION) CHECKED WBK/HDR DATE 9/24/86 ATM
5/1/90

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): The duration of the containment spray is 30 days. Containment spray flow rate is equal to 9500 gal/min or 0.92 GPM per square foot of containment cross section.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: See Sect. P. (1) "Discussion").

- (7) Subject to submergence (Yes/No/NA)? Yes (Reference: See sheet 19A of this tab for discussion on valves subject to submergence.).

Identify initiation time and duration of submergence: See sheet 19A of this tab for discussion on valves subject to submergence.

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: Environmental Drawing 47E235-41, -42, -44, -45).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: See Section P(3) this TAB

- (9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B, Sect. A</u>	

WBNEQ-SOL-003

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-21 was deleted per revision 2.

WBEP-0007Q

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 19 OF 26
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 R 2 R 2
 VALVES, MODEL 206-381 - SERIES 4/30/90
 (DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 10/11
5/1/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
	<u>1</u>		
Operating Time	<u>100 days</u>	<u>30 days</u>	Fig. 4.2, pg. 26 of (1)
Temperature (°F)	<u>327°F</u>	<u>450°F</u>	Fig. 4.2, pg. 26 of (1)
Pressure (psig)	<u>25.6 psia</u>		Fig. 4.2, pg. 26 of (1)
	<u>11.2 psig</u>	<u>86 psig</u>	Fig. 4.2, pg. 26 of (1)
Relative Humidity (%)	<u>2</u>		Fig. 4.2, pg. 26 of (1)
	<u>100%</u>	<u>100%</u>	App. A, pg. A20 & A21 of (1)
Chemical Spray*	<u>2000 Boron (H₃BO₃)</u>	<u>3000 ppm Boron</u>	Sect. 4.1.4, 4.2.2, 5.2, Table 5.1, App. D of (1)
	<u>pH 8.3</u>	<u>pH 10.5</u>	
Radiation (rd)**	<u>6.42x10⁷ rads</u>	<u>2.01x10⁸ rads</u>	
		<u>gamma</u>	
Submergence	<u>Yes</u>	<u>No</u>	See Sheet 19A

R2

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type. 2.52×10^7 Beta (Attenuated dose) + 3.8×10^7 Gamma + 1×10^6 40-year dose = 6.42×10^7 Rads TID. (See Section P.(3) of this TAB for beta radiation discussion and TID to each room after attenuation of beta dose.

R2

- ¹ Within 30 days the temperature will return to maximum normal.
- ² At 27.78 hours the humidity declines linearly to the maximum normal at 30 days.
- ³ Valves containing viton elastomers are only qualified to a maximum of 2×10^7 rads gamma.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	See (1) above
Pressure	<u>Yes</u>	See (1) above
Relative Humidity	<u>Yes</u>	See (1) above
Chemical Spray	<u>Yes</u>	See Sect. P.(2)
		See Sheet 19A & TAB C, Sect. C-10
Submergence	<u>No</u>	

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 19a OF 26 | R2
R 2 R
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CZ
VALVES, MODEL 206-381 - SERIES 430/90
(DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 AM
5/1/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
(Continued)

JUSTIFICATION/COMMENTS

Equipment located inside containment inside the crane wall below elevation 722' (surge level) could become submerged following an accident. Outside the crane wall, the steady state flood level is 717'9". No valves listed in this binder are located inside the crane wall and none are located below these levels. Some valves in the Valve Vault Rooms could be subjected to submergence. Environmental Data Drawing 47E235-76 lists the maximum flood levels for the Valve Vault Rooms to be 730.84' for the South Room and 730.87' for the North Room. The valves in this binder located in the Valve Vault Rooms are addressed under TAB C, Section C-4 (Group D Valves). | R2

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 20 OF 26
 R 2 R
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CRJ
4/30/90
 VALVES, MODEL 206-381 - SERIES
 (DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 ATM
5/1/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	>15°F	Yes
Pressure: +10% but no more than 10 psig	>10%	Yes
Radiation: +10% of accident dose	>10%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	*	No
Voltage: ±10% of rated value	+12 to -28%	Yes
Frequency: ±5% of rated value	N/A	N/A
Environmental Transient: the initial transient and the peak temperature applied twice	Yes See Sect. 4.2.1	Yes
Vibration: +10% added to acceleration	of (1)	Yes

JUSTIFICATION/COMMENTS See Appendix E of (1) for detailed information on margins.

R2

*The post accident life calculation in TAB C proves that the 30-day test envelops the 100-day post accident requirement.

BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CSH

VALVES, MODEL 206-381 - SERIES 4/30/70

(DC CONSTRUCTION) _____ CHECKED WBK _____ DATE 8/21/86 *gfm* _____

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference: See TAB A).

JUSTIFICATION/COMMENTS Functions are varied. All are
listed in TAB A.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: Sect. 5, Table 5.1, pg. 59, App. J, and pg. 33
of (1))

JUSTIFICATION/COMMENTS The test valve is assumed to be normally energized and required to deenergize on receipt of accident signal, then to remain operable for 30 days post-DBA. The specific DBA functions of the TVA valves are described in TAB C.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (Yes/No/NA)? Yes (Reference: Sect. 4.2.3, App. J of (1)).

JUSTIFICATION/COMMENTS

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (Yes/No/NA)? Yes (Reference: Table 5.1, Pg. 59 and App. J, Table 1 of (1))

JUSTIFICATION/COMMENTS See TAB C for the analysis of the test DBA versus the plant specific DBA. The test valve demonstrated operability in accordance with the requirements defined in M(2) above.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: Sects. 5.2 and 5.3, pgs. 56 and 57 of (1)
and page 33 of (1))

JUSTIFICATION/COMMENTS We have reviewed and concur with the disposition of anomalies in the test report. There is no impact on installed equipment.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 22 OF 26

BINDER TITLE ASCO SOLENOID COMPUTED EEH DATE 8/21/86 R R
VALVES, MODEL NO. 206-381-SERIES
(DC CONSTRUCTION) CHECKED WJK DATE 8/21/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See TABS C and G

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 23 OF 26

BINDER TITLE ASCO SOLENOID COMPUTED EEH DATE 8/21/86
VALVES, MODEL NO. 206-381-SERIES
(DC CONSTRUCTION) CHECKED WAK DATE 8/21/86

O. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>N/A</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>N/A</u>
(b) Were specific features and failure modes and effects analyzed?	<u>N/A</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>N/A</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>N/A</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>N/A</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 24 OF 26

BINDER TITLE ASCO SOLENOID COMPUTED EGM DATE 8/21/86
VALVES, MODEL NO. 206-381-SERIES
(DC CONSTRUCTION) CHECKED WPK DATE 8/21/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 25 OF 26

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-381-SERIES COMPUTED EE m DATE 8/21/86
(DC CONSTRUCTION) CHECKED WKK DATE 8/21/86

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>N/A</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>N/A</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

(1) Moisture or liquid intrusion (Sect. K.(6)).
The valves requiring protection from moisture or liquid intrusion
have had Conax conduit seals installed and are identified in Section
1 of the QMDS, which is located in TAB G of the binder. See TAB C-9,
submergence for elaboration.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 26 OF 26
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/24/86 4/30/90
 VALVES, MODEL 206-381 - SERIES
 (DC CONSTRUCTION) CHECKED WBK/HDR DATE 9/24/86 5/1/90

P. DISCUSSION (Continued)

(2) Chemical Spray (Sec. L. (1) & (2)).

The containment spray flow rate is equal to 9500 gal/min or 0.92 GPM per square foot of containment cross section and the duration is 30 days. The chemical spray concentration is 2000 ppm Boron with a pH of 8.3. The ASCO test valve was subjected to a 30-day exposure to steam, chemical spray and clear water simulating a combined LOCA/HELB and post-accident cool-down. The chemical spray solution of 3000 ppm Boron as Boric Acid in solution with 0.064 molar sodium thiosulfate buffered with sodium hydroxide to a pH value of 10.5 at room temperature was applied at a rate of 0.7 GPM per square foot of valve area projected in a horizontal plane. The test solution is more corrosive than the containment spray. Therefore, all valves listed in this binder fall within the qualification provided by the test valve. R2

(3) Beta Radiation (Sec. O.(12)(b)).

Post-DBA beta radiation must be addressed for all equipment located inside containment which is required for LOCA mitigation. Solenoid valves in Group A are located inside containment in the Lower Compartment, in the Accumulator and Fan Rooms, Group B valves are in the Upper Compartment, Group C valves are in the Annulus and Group G valves are in the Instrument Room. R2

Per drawing 47E235-44, which covers the Annulus, the 100-day accident radiation dose is 1.2×10^7 rads (includes a Beta dose contribution of 6×10^5 rads). Since the ASCO valves are qualified to 2.05×10^8 rads, no credit for reduction of the beta dose is necessary for the valves in Group C. R2

Per drawing 47E235-45, which covers the Instrument Room, the 100-day accident radiation dose is 4.7×10^8 Rads Beta and 1×10^7 Rads Gamma. R2

Per drawing 47E235-42, which covers the Lower Compartment, the 100-day accident radiation dose is 4.7×10^8 rads beta and 1×10^7 rads gamma. R2

Per Drawing 47E235-41, which covers the Upper Compartment, the 100-day accident radiation dose is 4.7×10^8 beta and 3.8×10^7 rads gamma. R2

Since the combined gamma/beta doses possible in the Lower (Group A), Upper (Group B), Compartments and Instrument Room (Group G), exceed the qualified level of the valves on face value, it is necessary to consider the inherent shielding afforded these valves. R2

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 26a OF 26
R 2 R 4
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CDH PAJ
VALVES, MODEL 206-381 - SERIES 4/30/90 8/21/90
(DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 AFM AFM
5/1/90 8/28/90

P. DISCUSSION (Continued)

(3) Beta Radiation (Sec. 0.(12)(b)). (Continued)

All non-metallic parts of the valves are totally enclosed by metal with the exception of the 18" wire pigtails. The minimum thickness of metal is assumed to be the coil housing, which is 3/32" (0.09375) steel, per ASCO's Tom Hays telecon with TVA's Dean Helton on January 7, 1986. OE Calculation WBNTSR-051 "Reduction of Beta Dose by Sheet Steel," page 3.1, shows the beta reduction factor for 14 gauge (0.0747)" steel is equal to 0.0536. This reduces the total 100-day Beta dose to the valve internal parts to $(4.7 \times 10^8) \times (5.36 \times 10^{-2}) = 2.52 \times 10^7$ rads TID beta. | R4

In the Instrument Room, the total combined 100-day Beta and accident radiation dose will equal $(2.52 \times 10^7 \text{ Beta}) + (1 \times 10^7 \text{ Gamma}) = 3.52 \times 10^7$ Rads. The combined 100-day accident radiation plus the 40-year dose (3.5×10^5) equals a total radiation dose of 3.55×10^7 Rads TID.

In the Lower Compartment, the total combined 100-day beta and accident radiation dose will equal $(2.52 \times 10^7 \text{ beta}) + (1.0 \times 10^7 \text{ gamma}) = 3.52 \times 10^7$ rads. The combined 100-day accident radiation plus the 40-year dose (2×10^7) equals a total radiation dose of 5.52×10^7 rads TID.

In the Upper Compartment, the total combined 100-day Beta dose and Gamma accident radiation dose will equal $(2.52 \times 10^7 \text{ Beta}) + 3.8 \times 10^7 \text{ Gamma} = 6.32 \times 10^7$ rads. The combined 100-day accident radiation plus the 40-year dose (1×10^6) equals a total radiation dose of 6.42×10^7 rads TID.

The 2.01×10^8 rads the valves are qualified to clearly envelops the above requirements plus 10% Margin. | R4

The pigtail leads to valves No. 1-FSV-43-201, -202, -207, and -208 (subgroup A-2) terminate in a splice inside a piece of 1" solid conduit which attaches to a Conax connector. Inasmuch as these valves must be operable for 100 days after an accident, the pig-tails must be qualified for the full 100-day radiation dose. Since a calculation on the reduction of beta dose afforded by solid conduit has not been made at this time, we will relate the wall thickness of the conduit to the aforementioned "Reduction of Beta Dose by Sheet Steel" calculation for this calculation. One-inch rigid conduit has a wall thickness of 0.135". Page 3.1 of the sheet steel calculation shows the beta reduction factor for 1/8-inch sheet steel is equal to 0.0090. This reduces the total 100-day beta dose to $(4.7 \times 10^8) \times (9.03 \times 10^{-3}) = 4.24 \times 10^6$ rads.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 26b OF 26
R 2 R 4
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/21/86 CDH CSH
VALVES, MODEL 206-381 - SERIES 4/30/90 8/21/90
(DC CONSTRUCTION) CHECKED WBK DATE 8/21/86 AFM 9/11/90
5/1/90 8/28/90

P. DISCUSSION (Continued)

(3) Radiation (Sec. 0.(12)(b) (Continued)

Thus, the total combined 100-day beta and gamma accident radiation dose (4.24×10^6 beta) + (1.0×10^7 gamma) = 1.42×10^7 rads, plus the 40-year dose (2.0×10^7 rads) equals a total radiation dose of 3.42×10^7 rads. The 2.01×10^8 rads the valves are qualified to |R4 clearly envelops the requirement.

The pigtail leads of all other valves in Groups A and B are covered by 1/2 or 3/4 inch diameter flexible stainless steel conduit. Since these valves are required to operate for only 5 minutes into a LOCA, the pigtails are not required to be qualified for the full 100-day beta dose. OE Calculation TI-RPS-48 "Integrated Accident Dose Inside Primary Containment," Table VI-14, page 7.24, shows the total beta dose at 2 hours into the accident to equal 4.12×10^7 rads TID. The total combined beta and gamma radiation dose will equal (4.12×10^7 beta) + (3.8×10^7 gamma) = 7.92×10^7 rads TID. Accident radiation plus the larger upper compartment 40-year dose (1.0×10^6 rads) equals a total radiation dose of 8.02×10^7 rads TID. The ASCO valves are qualified for 2.01×10^8 rads. |R4

WBNTSR-057
OE Calculation ~~GENERAL-013~~, "Beta Dose Reduction from Finite Volume" provides reduction factors for beta radiation doses based on the free space or "box volume" found inside each device. The free space volume for the 206-381 series solenoid valves was calculated to be 692 cm^3 . This was done by calculating the volume of a cylinder with dimensions corresponding to the extreme outside dimensions shown on drawing JVA-206-381 (TAB I) for the coil housing. The cylindrical volume of the conduit entry nipple was added to this and the combined volume was treated as if none of the space was occupied by internal components (space occupied by coil, wiring, etc. was not subtracted). As can be seen from the drawing, this free space volume calculation is extremely conservative.

WBNTSR-057
Using the 692 cm^3 free space volume value and corresponding beta dose reduction factor (per ~~GENERAL-013~~), the effective beta radiation dose for the valves in this binder may be calculated:

$692 \text{ cm}^3 < 1000 \text{ cm}^3$; use 1.44×10^{-6} reduction factor

Effective Beta Dose = $(4.7 \times 10^8 \text{ rads})(1.44 \times 10^{-6}) =$
676.8 rads

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 26c OF 26
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/05/86 CDH CSH
 VALVES, MODEL 206-381 - SERIES 4/30/90 8/2/90
 (DC CONSTRUCTION) CHECKED WBK/HDR DATE 9/05/86 AFM AM
5/1/90 8/28/90

P. DISCUSSION (Continued)

(3) Radiation (Sec. 0.(12)(b) (Continued)

The beta dose due to free space volume inside the valve is insignificant (676.8 rads < 3×10^7 rads).

Recently issued DNE calculation GENAPS3-023, Attenuation Factors for postaccident beta dose in primary containment, in summary states: CSH
8/11/90

"With the thickness of standard plate given as . . . 18.75 mils for 26 guage sheet metal, all radiosensitive material contained in an enclosure formed of . . . 26 guage or thicker iron will receive a beta dose of no more than one percent of the free-field beta dose. The dose from airborne activity within the enclosure may be neglected due to the small volume."

The thinnest metal on these valves is the coil housing, which is 3/32" (0.09375) steel. Thus, the worst beta dose would be 4.7×10^6 , which is much less than the 2.52×10^7 from calculation WBNTSR-051 which we have used in this discussion. | R4

(4) Synergistic Effects (Sec. H(3))

Ethylene Propylene Terpolymer (EPDM) elastomer is used in the construction of ASCO solenoid valves as gaskets and diaphragms. EPDM is the only material having a potential for radiation induced synergisms based on a review of technical information provided in NUREG/CR-2157 and NUREG/CR-2553. Data in NUREG/CR-2157 suggests that dose rate effects in EPR materials are insignificant up to doses of 10 to 20 MRADs. A review of the location and environments of ASCO solenoid valves listed in TAB C-1 indicates that the maximum normal radiation dose will be seen by valves in subgroup A-2. These valves are qualified for 40 years without replacement of elastomer parts and will therefore be exposed to a maximum normal dose of 20 MRADs. Since all elastomer parts are totally enclosed in metal, the radiation dose to these parts will be less than 20 MRADs. Synergistic effects will be negligible for normal service aging.

Potential dose rate and test sequence synergisms will not impact qualification for accident conditions as demonstrated by Test Report AQR-67368. The test sequence of thermal aging followed by radiation aging plus accident radiation at high dose rates (0.71 MRADs/HR-Aging, 0.9 MRADs/HR-Accident) is a reasonable simulation of actual plant requirements. Additional assurance is provided by the severity of the radiation test because the test valve was exposed to 201 MRADs whereas an actual dose of about 48 MRADs (28 MRADs accident plus 20 MRADs normal service) is required.

BINDER NO. WBNEQ-SOL -004 PLANT WBN UNIT(S) 1 SHEET 1
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RAL DATE 6/11/86 R R
ASSEMBLY/SOLENOID VALVES-GOULD ALLIED CHECKED MSR DATE 6/12/86

TAB A

EQUIPMENT IDENTIFICATION MATRIX

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQUIP. NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	ALTIMETER CONTRACT	ELEV(1) CONTRACT	BM/BAD	CAT OPER. TIME (2)	EVENT	SAFETY FUNCTION
WBN-1-FSV -001-0004A -A SG 1 MAIN STM HDR ISLN VALVE	1-FSV -001-0004A -A 321X-21		729° 76K38-83080	A01	A/B 15S/100D A/B 5MN/100D	MS/V FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0004B -B SG 1 MAIN STM HDR ISLN VALVE	1-FSV -001-0004B -B 321X-21		729° 76K38-83080	A01	A/B 15S/100D A/B 5MN/100D	MS/V FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0004D -A SG 1 MAIN STM HDR ISLN VALVE	1-FSV -001-0004D -A 321X-21		729° 76K38-83080	A01	A/B 15S/100D A/B 5MN/100D	MS/V FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0004E -A SG 1 MAIN STM HDR ISLN VALVE	1-FSV -001-0004E -A 321X-21		729° 76K38-83080	A01	A/B 15S/100D A/B 5MN/100D	MS/V FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0004F -A SG 1 MAIN STM HDR ISLN VALVE TEST	1-FSV -001-0004F -A 321X-21		729° 76K38-83080	A01	A/C 15S/100D A/C 5MN/100D	MS/V FW/V	MUST DEENERGIZE TO OPEN MSIV VENT PATH. RE-ENERGIZATION WILL NOT ADVERSELY AFFECT MSIV.

PAGE A-2R1

PREPARER/DATE R. H. Loveday 6/11/86

CHECKED/DATE W. B. Kim 6/12/86

R. 1	R. ---	R. ---
2/12/89	---	---
4/21/89	---	---

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	LOCATION	ALPHABETIC	ELEV(11)	RM/RAD	CAI OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION	MODEL NUMBER					(2)		
WBN-1-FSV -001-0004G -B SG 1 MAIN STM HDR ISLN VALVE	1-FSV -001-0004G -B 321X-21	729°	A01	76K38-83080	A/B 15S/100D A/B 5MN/100D	MS/V FW/V		SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0004H -B SG 1 MAIN STM HDR ISLN VALVE	1-FSV -001-0004H -B 321X-21	729°	A01	76K38-83080	A/B 15S/100D A/B 5MN/100D	MS/V FW/V		SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0004J -B SG 1 MAIN STM HDR ISLN VALVE TEST	1-FSV -001-0004J -B 321X-21	729°	A01	76K38-83080	A/C 15S/100D A/C 5MN/100D	MS/V FW/V		MUST DEENERGIZE TO OPEN MSIV VENT PATH. RE-ENERGIZATION WILL NOT ADVERSELY AFFECT MSIV.
WBN-1-FSV -001-0011A -A SG 2 MAIN STM HDR ISLN VALVE	1-FSV -001-0011A -A 321X-21	729°	A02	76K38-83080	A/B 15S/100D A/B 5MN/100D	MS/V FW/V		SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0011B -B SG 2 MAIN STM HDR ISLN VALVE	1-FSV -001-0011B -B 321X-21	729°	A02	76K38-83080	A/B 15S/100D A/B 5MN/100D	MS/V FW/V		SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN

PAGE A-3R1

PREPARER/DATE R. H. Loveday 6/11/86

CHECKED/DATE W. B. Kim 6/12/86

R	1	R		R	
	2/11/89				
	2/11/89				

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZMIH ELEV(1) RM/RAD CONTRACT	CAT OPER TIME (2)	EVENT SAFETY FUNCTION
WBN-1-FSV -001-0011D -A SG 2 MAIN STM HDR ISLN VALVE	1-FSV -001-0011D -A 321X-21	729° A02 76K38-83080	A/B 15S/100D MS/V A/B 5MN/100D FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0011E -A SG 2 MAIN STM HDR ISLN VALVE	1-FSV -001-0011E -A 321X-21	729° A02 76K38-83080	A/B 15S/100D MS/V A/B 5MN/100D FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0011F -A SG 2 MAIN STM HDR ISLN VALVE TEST	1-FSV -001-0011F -A 321X-21	729° A02 76K38-83080	A/C 15S/100D MS/V A/C 5MN/100D FW/V	MUST DEENERGIZE TO OPEN MSIV VENT PATH. RE-ENERGIZATION WILL NOT ADVERSELY AFFECT MSIV.
WBN-1-FSV -001-0011G -B SG 2 MAIN STM HDR ISLN VALVE	1-FSV -001-0011G -B 321X-21	729° A02 76K38-83080	A/B 15S/100D MS/V A/B 5MN/100D FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0011H -B SG 2 MAIN STM HDR ISLN VALVE	1-FSV -001-0011H -B 321X-21	729° A02 76K38-83080	A/B 15S/100D MS/V A/B 5MN/100D FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN

PREPARER/DATE R. H. Loveday 6/11/86

CHECKED/DATE W. B. Kim 6/12/86

R 1 R R
97M
2/17/89
18M
2/27/89

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

IS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZMITH CONTRACT	ELEV(1) RM/RAD	CAT OPER TIME (2)	EVENT SAFETY FUNCTION
N-1-FSV -001-0011J -B 2 MAIN STM HDR ISLN VALVE TEST	1-FSV -001-0011J -B 321X-21	729° 76K38-83080	A02	A/C 15S/100D A/C 5MN/100D	MS/V FW/V MUST DEENERGIZE TO OPEN MSIV VENT PATH. RE-ENERGIZATION WILL NOT ADVERSELY AFFECT MSIV.
N-1-FSV -001-0022A -A 3 MAIN STM HDR ISLN VALVE	1-FSV -001-0022A -A 321X-21	729° 76K38-83080	A02	A/B 15S/100D A/B 5MN/100D	MS/V FW/V SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
N-1-FSV -001-0022B -B 3 MAIN STM HDR ISLN VALVE	1-FSV -001-0022B -B 321X-21	729° 76K38-83080	A02	A/B 15S/100D A/B 5MN/100D	MS/V FW/V SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
N-1-FSV -001-0022D -A 3 MAIN STM HDR ISLN VALVE	1-FSV -001-0022D -A 321X-21	729° 76K38-83080	A02	A/B 15S/100D A/B 5MN/100D	MS/V FW/V SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
N-1-FSV -001-0022E -A 3 MAIN STM HDR ISLN VALVE	1-FSV -001-0022E -A 321X-21	729° 76K38-83080	A02	A/B 15S/100D A/B 5MN/100D	MS/V FW/V SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN

PREPARER/DATE R. H. Loveday 6/11/86

CHECKED/DATE W. B. Kim 6/12/86

R 1
R 2/1/87
R 2/2/87

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

IS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION AZMIH ELEV(1) RM/RAD CONTRACT	CAT OPER TIME (2)	EVENT SAFETY FUNCTION
N-1-FSV -001-0022F -A 1-FSV -001-0022F -A 3 MAIN STM HDR ISLN VALVE TEST	321X-21	729° A02 76K38-83080	A/C 15S/1000 MS/V A/C 5MN/1000 FW/V	MUST DEENERGIZE TO OPEN MSIV VENT PATH. RE-ENERGIZATION WILL NOT ADVERSELY AFFECT MSIV.
N-1-FSV -001-0022G -B 1-FSV -001-0022G -B 174 3 MAIN STM HDR ISLN VALVE	321X-21	729° A02 76K38-83080	A/B 15S/1000 MS/V A/B 5MN/1000 FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
N-1-FSV -001-0022H -B 1-FSV -001-0022H -B 174 3 MAIN STM HDR ISLN VALVE	321X-21	729° A02 76K38-83080	A/B 15S/1000 MS/V A/B 5MN/1000 FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
N-1-FSV -001-0022J -B 1-FSV -001-0022J -B 174 3 MAIN STM HDR ISLN VALVE TEST	321X-21	729° A02 76K38-83080	A/C 15S/1000 MS/V A/C 5MN/1000 FW/V	MUST DEENERGIZE TO OPEN MSIV VENT PATH. RE-ENERGIZATION WILL NOT ADVERSELY AFFECT MSIV.
N-1-FSV -001-0029A -A 1-FSV -001-0029A -A 4 MAIN STM HDR ISLN VALVE	321X-21	729° A01 76K38-83080	A/B 15S/1000 MS/V A/B 5MN/1000 FW/V	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN

PAGE 4-681

PREPARER/DATE R. H. Loveday 6/11/86

CHECKED/DATE W. B. Kim 6/12/86

R 1
R 2/17/86
R 2/21/89

PRINT DATE:

BINDER NO. : WBNEQ-SOL -004
MANUFACTURER : GOULD ALLIED
PAGE 6 OF 7WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQUIPMENT IDENTIFICATION		LOCATION		CAT OPER TIME EVENT SAFETY FUNCTION	
DESCRIPTION	UNIT DEVICE ID NO.	AZUTH	ELEV(1) RM/RAD	CONTRACT	(2)
1-1-FSV -001-0029B -B 4 MAIN STM HDR ISLN VALVE	1-FSV -001-0029B -B 321X-21	729°	A01	76K38-83080	A/B 15S/100D MS/V A/B 5MN/100D FW/V SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
1-1-FSV -001-0029D -A 4 MAIN STM HDR ISLN VALVE	1-FSV -001-0029D -A 321X-21	729°	A01	76K38-83080	A/B 15S/100D MS/V A/B 5MN/100D FW/V SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
1-1-FSV -001-0029E -A 4 MAIN STM HDR ISLN VALVE	1-FSV -001-0029E -A 321X-21	729°	A01	76K38-83080	A/B 15S/100D MS/V A/B 5MN/100D FW/V SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
1-1-FSV -001-0029F -A 4 MAIN STM HDR ISLN VALVE TEST	1-FSV -001-0029F -A 321X-21	729°	A01	76K38-83080	A/C 15S/100D MS/V A/C 5MN/100D FW/V MUST DEENERGIZE TO OPEN MSIV VENT PATH. RE-ENERGIZATION WILL NOT ADVERSELY AFFECT MSIV.
1-1-FSV -001-0029G -B 4 MAIN STM HDR ISLN VALVE	1-FSV -001-0029G -B 321X-21	729°	A01	76K38-83080	A/B 15S/100D MS/V A/B 5MN/100D FW/V SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN

PAGE 4-781

PREPARER/DATE R. H. Loveday 6/11/86

CHECKED/DATE W. B. Kim 6/12/86

R	R	R
1		
2/17/87		
4/21/89		

PRINT DATE:

BINDER NO. : WBNEQ-SOL -004
MANUFACTURER : GOULD ALLIED
PAGE 7 OF 7

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

IS NUMBER		UNIT DEVICE ID NO.		LOCATION		CAT OPER TIME EVENT SAFETY FUNCTION	
DESCRIPTION		MODEL NUMBER		AZMIH ELEV(1) RM/RAD		(2)	
N-1-FSV -001-0029H -B 4 MAIN STM HDR ISLN VALVE		1-FSV -001-0029H -3 321X-21		729* A01 76K38-83080		A/B 15S/100D MS/V A/B 5MN/100D FW/V SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN	
N-1-FSV -001-0029J -B 4 MAIN STM HDR ISLN VALVE TEST		1-FSV -001-0029J -B 321X-21		729* A01 76K38-83080		A/C 15S/100D MS/V A/C 5MN/100D FW/V MUST DEENERGIZE TO OPEN MSIV VENT PATH. RE-ENERGIZATION WILL NOT ADVERSELY AFFECT MSIV.	

PREPARER/DATE R. H. Loveday 6/11/86
CHECKED/DATE W. B. Kim 6/12/86

R 1
2/27/89
R
R
2/27/89

PAGE A-8R1

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE MSIV AIR MANIFOLD COMPUTED /R1 *ATM* DATE 2/17/89
ASSEMBLY SOLENOID VALVES -
GOULD ALLIED CHECKED /R1 *KEN* DATE 2/22/89

TAB A NOTES

1. Floor/Actual Elevation - Actual elevations are documented on field verification sheets found in TAB F. All elevations shown are floor elevations except for those devices located inside the reactor building.
2. See TAB B, Section A for Category and Operating Times calculations used in this binder.
3. Contract Column - Contract numbers shown in this TAB were obtained by tracing the serial number on each valve through TVA procurement records and did not depend on field verification data for contract numbers.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RAH DATE 6/11/86 R R
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED CHECKED WPK DATE 6/12/86

TAB B

CHECKLIST FOR EVALUATION OF
ENVIRONMENTAL QUALIFICATION
INCLUDING SUMMARY AND CONCLUSION

NOTE: It is recommended that Section D - Justification/Comments (sheets 5 through 7) be closely reviewed for a clearer understanding of rationale applied towards qualification of the subject main steam isolation valves (MSIV) Air Manifold Assembly/Solenoid Valves.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 2 OF 30
R 1 R 2
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 AFM CRH
ASSEMBLY SOLENOID VALVES - 2/17/89 9/13/90
GOULD ALLIED CHECKED WBK DATE 6/12/86 KBN AM
2/27/89 9/19/89

A. DOCUMENTATION

Equipment Description MSIV Air Manifold Assembly/Solenoid Valves
Atwood & Morrill (Valve Actuator)
Chicago Fluid Power (Air Manifold Assembly)

Vendor/Manufacturer Gould Allied (Solenoid Valves)

Equipment Model No.(s) 321X-21

QUALIFICATION REPORTS

- (1) Title/Number/Revision A&M Valve Actuator RIMS B70 850917 100
Qualification Test Report/Procedure No.
201-39500/Rev. 0 DATE 5-18-79
- (2) Title/Number/Revision Wyle NEO Test RIMS B71 860514 100
Report/17514-1/Rev. A DATE 3-14-85

NOTE: Throughout this binder, references are made to the above qualification reports which may be identified as "(1)" or "(2)" as shown in these references.

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (3) Category and Operating Times Calculations, WBNOSG4-004 R11 (B18 900612 253) | R2
- (4) WBNP Environmental Data Drawing 47E235-76 R3.
- (5) Calculation WBNAPS2-001 R1 (B45 860822 235), Flooding Levels in the North and South Valve Vaults.
- (6) Calculation WBNOSG4-045 R1 (B45 860902 219), Status and Duty Cycles of Solenoid Valves.
- (7) Calculation WBNOSG4-003 R2 (B45 851112 218) Superheated Steam in Valve Vaults (MSLB).
- (8) Deleted by Revision 2. | R2

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 2a OF 30
R R
BINDER TITLE MSIV AIR MANIFOLD COMPUTED /R1 QJM DATE 2/17/89
ASSEMBLY SOLENOID VALVES -
GOULD ALLIED CHECKED /R1 KBW DATE 2/27/89

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (9) Calculation (B25 850920 800), Sequoyah Nuclear Plant -
Solenoid Valves Normal Status.

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-SOL-QQ4 PLANT WBN UNIT(S) 1 SHEET 3 OF 30
R 1 R 1
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 9/8/86 gfm
ASSEMBLY SOLENOID VALVES - 2/17/89
GOULD ALLIED CHECKED RKW DATE 9/9/86 KBN
2/27/89

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

R1

COMMENTS/RECOMMENDATIONS Equipment qualification is based primarily
on similarity to test devices noted in Atwood & Morrill test
procedure No. 201-39500 with supplemental justification provided
in Wyle Test Report 17514-1. For detailed explanation see Section D
Justification/Comments (Sheets 5 through 7).

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 4 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/14/86
ASSEMBLY/SOLENOID VALVES- GOULD ALLIED
CHECKED WBSK DATE 6/14/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

- Components are Qualified to the Criteria of 10CFR50.49
and/or NUREG-0588 Category I (IEEE323-1974)
- X Components are Qualified to the Criteria of NUREG-0588
Category II or the DOR Guidelines of 1E Bulletin No. 79-
01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE-323-1974: "IEEE Standard for Qualifying Class 1E Equipment
for Nuclear Power Generating Stations".

IEEE-344-1975: "IEEE Recommended Practices for Seismic Qualifica-
tion of Class 1E Equipment for Nuclear Power Generating Stations".

IEEE-382-1972: "IEEE Trial Use Guide for Type Test of Class 1E
Electric Valve Operators for Nuclear Power Generating Stations".

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 5 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 R R
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED CHECKED WJK DATE 6/14/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions of Under Similar Conditions with Supporting Analysis
- X Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS

WBN Main Steam Isolation Valve (MSIV) actuators provided by Atwood and Morrill (A&M) have Chicago Fluid Power air manifold assemblies with Gould Allied solenoid valves model No. 321X-21 which are 125V DC, Class C insulation. Environmental qualification of the subject items is based primarily on similarity to Hartsville Nuclear Plant (HTN) MSIV actuators tested for A&M Procedure No. 201-39500 (see Tab D/D1). HTN MSIV actuators provided by A&M have Chicago Fluid Power air manifold assemblies with Airmatic-Allied solenoid valves model No. 321X-22* which are 115V AC, Class C insulation. Justification for similarity to the above is noted in Tab C/C1 and C2. A detailed comparison of air manifold assemblies by means of respective instruction manuals (see Tab H [WBN] and E/E8 [HTN]) indicates that at a minimum materials are similar, and in most cases identical.

*Gould Allied officially changed titles to Airmatic-Allied (w/both being a subsidiary to Snap-tite, Incorporated) on March 17, 1978, and relocated headquarters from Plantsville, Connecticut, to Wilmington, Ohio.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 6 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHR DATE 6/11/86 R R
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED CHECKED WBN DATE 6/17/86

D. JUSTIFICATION/COMMENTS (Continued)

When A&M test data is applied to WBN environmental parameters (normal life, DBE & Post-DBE), all WBN requirements are enveloped. However, due to a very restricted thermal aging program, limiting materials (i.e., O-rings) have a qualified life of less than one year when Arrhenius equation is applied. Therefore an additional test report, WYLE NEQ 17514-1 (see Tab D/D2) is included which addresses similar air manifold assemblies that were subjected to a more extensive thermal aging program (as well as enveloping all other WBN environmental parameters). The WYLE test report is applicable to Browns Ferry Nuclear Plant (BFN) MSIV air manifold assemblies manufactured by Automatic Valve Corporation with Airmatic-Allied solenoid valves model No. V320X-XX. Three types of these solenoids were tested: 250V DC - Class H, 120V AC - Class H, and 120V AC - Class C. Similarity is justified to the 120V AC, Class C solenoid (test solenoid No. 3/test specimen No. 9A3), with exception of demonstrated voltage, and lubricant application to static seals which is justified by similarity to 250V DC Class H (test solenoid No. 1/test specimen No. 9D1), per Tab C/C2, C3, and C4 and Tab D/D2: WYLE test report 17514-1, page No. xvii, comment No. 10 & 11. Air manifold assemblies consist of mechanical valves. A detailed comparison of air manifold assemblies (less solenoid valves) indicates that materials are similar (with majority of parts being metallic) and the most limiting material is identical (O-rings: Fluorocarbon Rubber/Viton E60C per Tab D/D2: Section XVII, Table I-Aging Matrix, and Tab H: Chicago Fluid Power Service Manual DM52377 Reference Drawings). In addition WBN solenoid terminal strips (G.E. CR151B, see Tab B/Section I: item 5, page No. 17 and 18) are more compatible to WYLE-tested terminal strips (see Tab D/D2: page No. xviii, comment No. 14) than those tested by A&M.

Therefore, qualification for the items of this binder are based primarily on A&M test report No. 201-39500 with supplemental references to WYLE test report No. 17514-1 as necessary (i.e., thermal aging results, terminal strip similarity, vibration aging, and additional justification).

Additional References:

Material aging calculation reports (see Tab C/C4A - C4C).

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 7 OF 30
 R 1 R
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/25/86 2/17/89
 ASSEMBLY SOLENOID VALVES -
 GOULD ALLIED CHECKED WBK DATE 6/25/86 2/27/89

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? No

R1

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>	
	Air Manifold		(1) Intro.:	
	Assembly/Solenoid		p 1 (2) ppXVII-	
(1) Equipment Type	Valve	Same	10,-11,-12	
	Chicago Fluid Pwr/		(1) Intro.:	
(2) Manufacturer	Gould Allied	Same	p 1	
		Automatic Valve		
		Corp/Airmatic-	(2)ppXVII	
		Allied	-10,-11,-12	
(3) Model Number(s)	<u>321X-21</u>	<u>321X-22</u>	(1): Tab	
			C/C1	
		<u>V320X-XX</u>	(2) pp XVI-	
			8, -9	
(4) Serial Number(s)	<u>NA</u>	<u>NA</u>	(1) NA	
		<u>Specimen</u>	(2) p xxi	
		<u>9A3 (9D1 for</u>		
		<u>0-ring w/Parker</u>		
		<u>Super-0-Lube)</u>		
(5) Identify Component-Unique checksheet attached:	<u>NA</u>			

JUSTIFICATION/COMMENTS

R1

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 8 OF 30
R 1 R
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 gmm
ASSEMBLY SOLENOID VALVES - 2/17/89
GOULD ALLIED CHECKED WBK DATE 6/12/86 KBW
2/27/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.)
 If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No/NA)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>None Specified</u>	<u>NA</u>	(1) <u>NA</u> (1) Section 3.2, p5
External Process Connections	<u>None Required</u>	<u>NA</u>	(2) Section XVII, para. 1.3.4 (1) Section 3.2, p 5 (2) Section I, para. 2.2.1
Electrical Connections	<u>See Below</u>	<u>Yes</u>	(2) p xviii, Comment 12
Conduit Seals	<u>None Required/ See below</u>	<u>Yes</u>	(2) p xviii, Comment 12
Connector Seals	<u>See Below</u>	<u>Yes</u>	(1) Section 3.2, p 5 (2) Section XVII, para. 3.5.3.1
Orientation	<u>See Below</u>	<u>Yes</u>	(1) NA (2) p I-13, Fig. I-2
Physical Configuration	<u>See Below</u>	<u>Yes</u>	(1) Section 3.2
Other	<u>Supply Air Pressure: 90-100 psig</u>	<u>Yes</u>	(1) Section 3.2

JUSTIFICATION/COMMENTS See Page 8A

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 8a OF 30
R 2 R
BINDER TITLE MSIV AIR MANIFOLD COMPUTED /R1 AFM DATE 2/17/89 9/13/90
ASSEMBLY SOLENOID VALVES -
GOULD ALLIED CHECKED /R1 KBN DATE 2/27/89 9/15/90

F. INSTALLATION INTERFACES (continued)

JUSTIFICATION/COMMENTS: The three test solenoids were electrically connected (flexible conduit with 1" NPT conduit fitting) through a NEMA 4 junction box which houses a terminal strip ((2) pg. No. I-12, Figure I-1). Solenoid assembly was mounted at a 45° angle (with conduit hub directed downward) to simulate worst case in-service mounting. A 1/4" hole at the lowest point of the junction box eliminates conduit seal requirements. WBN MSIV solenoids are housed within a NEMA 4 junction box with terminal strips housed in an adjoining junction block (See TAB H, Drawing No. CFP-305C). Although not required, WBN electrical connections include Conax conduit seals* (see TAB F and Binder WBNEQ-CSC-001). Solenoid assembly is mounted at a 45° angle (with conduit hub directed upward). Weep hole requirements are met per TAB G, Section A, item 3. Wyle BFN test set-up was a worst case installation, therefore, WBN installation based on being similar and less severe is acceptable. |R2

*Not a requirement, see TAB C/G5.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 9 OF 30
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RAK DATE 6/14/86 R R
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED CHECKED WBR DATE 6/12/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	(2)Sect. I, para. 1.1;(1) No*
(b) Baseline performance measurements taken	<u>Yes</u>	(1)Sect. 3.2, 4.0,6.0, 9.0,10.0; (2)Sect. I, para 1.4
(c) Equipment aged:		
Thermal	<u>Yes</u>	(1)Sect. 3.5, 6.0; (2)Sect. VI, para 2.0
Radiation	<u>Yes</u>	(1)Sect. 3.4, 5.0; (2)Sect. II, para 1.0; Sect. IV, para 1.0
Wear	<u>Yes</u>	(1)Sect. 3.3,4.0; (2)Sect. VII, para 1.0
(d) Vibration/seismic testing conducted	<u>Yes</u>	(1)Sect. 3.6,3.7,3.8 7.0,8.0, & 9.0; (2)Sect. XI
(e) Design basis event (DBE) exposure	<u>Yes</u>	(1)Sect. 3.9, 10.0; (2)Sect. XIV, XV
(f) Post-DBE exposure	<u>Yes</u>	(1)Sect. 3.9, 10.0; (2)Sect. XIV, XV
(g) Final inspection and disassembly	<u>Yes</u>	(1)Results, p 3; (2)Sect. XVII, para. 3.6 & 3.7, Sect XVI, para 1.0

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes (w/exception of items 2 and 4, p. 10.)

- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes
 (Reference (1)Section 1.0; (2)See Instrumentation Equipment sheets in appendices of sections referenced above.)

JUSTIFICATION/COMMENTS *(1)IEEE-323-1974, paragraph 6.3.2 states

"Inspection may be performed to assure that a test unit has not been damaged due to handling..."; therefore, this is constituted as a precautionary measure and not an actual requirement.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 10 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/25/86 R R
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED CHECKED WHL DATE 6/25/86

G. TEST SEQUENCE (Continued)

(2) Wear aging was the first phase of the test sequence. Upon completion of the 39th test interval and prior to start-up of the 40th test interval (simulating the 40th-year of service), all non-metallics were replaced, and three solenoid valves were replaced due to noise emanating from air control panel assembly. Since normal hands-on maintenance was allowed between each interval, the replacement of seals and solenoids is considered to be normal maintenance procedures. No piece replacements of equipment were required for the duration of all remaining phases of the test sequence.

(3) In reference to G(1) Test Sequence: Section XVII of Wyle test report 17514-1 ((2) p. 10) established qualification sequence.

(4) 40-Year life could not be achieved due to problems experienced during Post-Radiation functional test. New solenoid test sets (specimens 9A and 9D) with revised 10-year and 5-year equivalent radiation exposure plus accident dose were subjected to baseline functional and radiation testing ((2) Notice of Anomaly No. 3 and 3, Rev. A; page No. iii of Wyle test report 17514-1). 120V AC Class C solenoid valve (test specimen 9A3) was used throughout the test sequence and is qualified for a 10-year life (see note).

Note: Qualified life figures referenced above are based on meeting BFN environmental parameters; for equivalency to WBN requirements see TAB C/C4A-C4C.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 11 OF 30
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED R.H.P. DATE 6/11/86
ASSEMBLY/SOLENOID VALVES- CHECKED W.H.K. DATE 6/12/86
GOULD ALLIED

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference (1) Section 3.1).

JUSTIFICATION/COMMENTS _____

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	(1)Sect. 3.5,6.0 (2)Sect. XVII: para. 3.4 & App. I & II
Radiation exposure	<u>Yes</u>	(1)Sect. 3.4, 5.0 (2)Sect XVII, para. 3.4.12
Vibration (non-seismic) aging	<u>Yes</u>	& 3.5.1.2.2 (1)Sect. 3.3,
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	4.0

JUSTIFICATION/COMMENTS A&M report yielded limiting thermal aging data; therefore, more extensive WYLE thermal aging results were used. In addition, WYLE vibration aging is used since A&M test results did not include these effects.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference --).

JUSTIFICATION/COMMENTS No known synergistic effects have been reported for the materials applicable to the subject devices with the exception of silicone rubber (lead wire insulation) as noted: Dose rate synergisms have been reported as minor in NUREG/CR-2763 and were observed to have no significant impact on qualification.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference (2)Sect. XVII: para. 3.4 and App. I & II).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 12 OF 30
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RLH DATE 6/11/86 R R
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED CHECKED WJR DATE 6/12/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
 (Reference: See Below).

JUSTIFICATION/COMMENTS _____

(2) Section XVII/para. 3.4.4.1-3.4.4.7, 3.4.1, 3.4.2, Table I
(aging matrix), and II.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference See Below).

JUSTIFICATION/COMMENTS (2) Section XVII/Appendix I.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference See Below).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
		125°C+38°C	
		Rise	See Tab C/
	130°F+58°C	120°C+38°C	C4A-C4C
Temperature	<u>Coil Heat Rise</u>	<u>Rise</u>	(C4B: Coil
		2407H(120°C)	Heat Rise)
		95H	Material
Time	<u>40 Years</u>	<u>(125°C)</u>	<u>Aging Rpt</u>

JUSTIFICATION/COMMENTS (2) Section XVII/Appendix I and II

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference See Sect. H(4)(d) above).

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes
 (Reference See Below).

JUSTIFICATION/COMMENTS (2) Section XVII/Table III Reference
list and para. 3.4.3.

BINDER TITLE MSIV AIR MANIFOLD
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED

COMPUTED RAL DATE 6/11/86

CHECKED WBL DATE 6/13/86

(g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? NA (Reference).

(h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference (1) Sect. 3.5, 2nd para;
(2) Sect. XVII/para. 3.4.6

(a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference (1) Sect. 3.4 & 5.0).

(b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? No
(Reference --).

(c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes
(Reference (1) Sect. 3.4, 1st para.).

PAGE B-13

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 14 OF 30
R 1 R _____
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 AFM
ASSEMBLY SOLENOID VALVES - 2/17/89
GOULD ALLIED _____ CHECKED WBK DATE 6/12/86 ABN
2/27/89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: _____)

(1) Sect. 3.4, 5.0 Appendix A (pg. 50) _____).

Plant normal ambient radiation dose (rd) *1.8x10³
(Total 40-yr integrated)

Test exposure dose (rd) 1.74x10⁷

Test exposure dose rate (rd/hr) 0.5 Mrd/hr.

Test exposure source type
(e.g., Co-60 gamma) Cobalt 60 gamma

JUSTIFICATION/COMMENTS *See WBNP Environmental Data | R1
Drawing 47E235-76.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program? Yes (Reference: _____) | R1
See below

JUSTIFICATION/COMMENTS (2) Section XVII/para. 3.4.12 and 3.5.1.2.2

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes
(Reference: See below _____).

(2) Section XVII/para. 2.1.3.1.1,
JUSTIFICATION/COMMENTS 3.4.12, and 3.5.1.2.2

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: _____)

(1) Sect. 3.3, 3.5, 3.9, 4.0, 5.0, 6.0, & 10.0 _____).

JUSTIFICATION/COMMENTS _____

- (1) Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 15 OF 30
R 1 R _____
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 qdm
ASSEMBLY SOLENOID VALVES - 2/17/89
GOULD ALLIED CHECKED WBK DATE 6/12/86 KBN
2/27/89

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: _____)

(1) Sect. 3.3 and 3.5 _____).

JUSTIFICATION/COMMENTS _____

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: (2) Page xxi & Section XVII, App. II/para. 1.1.3).

Qualified life (Document in QMDS) 12 years (normally energized solenoids), 40 years (exerciser solenoids, air manifold assembly mechanical valves, and terminal strips only) - see TAB G.

JUSTIFICATION/COMMENTS See TAB C/C4A-C4C for WBN equivalency to BFN WYLE test results.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: (2) pg. No. xxi _____).

|R1

JUSTIFICATION/COMMENTS See TAB C/C4A-C4C for WBN
equivalency to BFN WYLE test results.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 16 OF 30
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/10/86
ASSEMBLY/SOLENOID VALVES- CHECKED WPK DATE 6/12/86
GOULD ALLIED

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
Ryton R-4/Mechanical/				
(a) <u>Bobbin</u>	<u>5x10⁸</u>	<u>See Below</u>	<u>1.00</u>	<u>See Below</u>
Silicone Rubber/Mechanical/				
(b) <u>Insulation</u>	<u>1x10⁶</u>	<u>See Below</u>	<u>1.44</u>	<u>See Below</u>
(c) <u>Viton/Mechanical/Seal</u>	<u>5x10⁶</u>	<u>See Below</u>	<u>1.16</u>	<u>See Below</u>
Prye-ML/Electrical/				
(d) <u>Insulation</u>	<u>1.5x10⁸</u>	<u>See Below</u>	<u>1.42</u>	<u>See Below</u>
Phenolic/Electrical/				
(e) <u>Terminal Strip</u>	<u>3.8x10⁵</u>	<u>See Below</u>	<u>1.06</u>	<u>See Below</u>
Silicone/Electrical/				
(f) <u>Varnish</u>	<u>1x10⁸</u>	<u>See Below</u>	<u>1.25</u>	<u>See Below</u>
(g) <u>Polymide/Mechanical/</u>	<u>1.5x10⁸</u>	<u>See Below</u>	<u>1.73</u>	<u>See Below</u>
<u>Winding Cover</u>				

JUSTIFICATION/COMMENTS Reference: Digital Engineering System 1000

"Materials Aging & Radiation Effects Library" (see Tab C/C4A-C4C for detailed materials analysis calculation).

- (1) Gasket material was not addressed in materials analysis since its degradation does not affect operability of the solenoid valves ((2) page No. xv comment 2). The gaskets serve as a seal between the pilot exhaust tube nut and junction box cover, and between the junction box (which houses the solenoid valves), junction box cover and the dump valve assembly (see Tab H, dwg. No. CFP-305-C for exploded view). Failure of the gaskets would not result in moisture or liquid intrusion (see Tab C/C5). Material composition of the gaskets is primarily

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 17 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED BHL DATE 6/12/86 R R
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED CHECKED WJR DATE 6/12/86

I. MATERIALS ANALYSIS

JUSTIFICATION/COMMENTS (Continued)

- asbestos with neoprene acting as a binder. Because
asbestos is inorganic and considered not to be age-sensitive, it could
still provide a marginal level of sealing at a minimum (even though
sealing is not required - (2) page No. xviii, comment 12 for
justification.)
- (2) Electrical tape (Scotch brand #69 Glass Cloth - per Tab C/C1) was not
addressed in materials analysis since its degradation/failure is not con-
sidered detrimental to the safety function of the solenoids
((2) Section XVII/para. 3.4.4.7, and Table I: item No 1.24.2.1.3).
- (3) Although WBN solenoid valves are comprised of the same materials as
those solenoids (specimen 9A and 9D) tested at Wyle Labs, lower activa-
tion energies were applied to the most limiting materials in order to
factor a degree of conservatism into the comparative results (see Tab
C/C4A-C4C).
- (4) Bobbin material is not significant, as failure of this component is judged
to not adversely affect the safety-related function of the solenoids
((2) Section XVII, Appendix II, para. 1.1.3).
- (5) Visual inspections and per telecon with Richard Mills of Chicago Fluid
Power on September 26, 1985, indicate that General Electric CR151B

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 18 OF 30
R 1 R
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/25/86 *gfm*
ASSEMBLY SOLENOID VALVES - 2/17/89
GOULD ALLIED CHECKED WBK DATE 6/25/86 *KBW*
2/21/89

I. MATERIALS ANALYSIS

JUSTIFICATION/COMMENTS (Continued)

terminal strips were supplied in WBN MSIV solenoid junction blocks.

Per GE letter dated Feb. 24, 1978 (see TAB E/E1), these terminal |R1
strips are comprised of the same materials as noted by Wyle Labs for
a G.E. CR151A terminal strip (which was qualified based on similarity
to a tested Square D KC-1 terminal strip - (2) pg. No. xviii.
comment No. 14). Test results were applied to a conservative
terminal strip activation energy of 1.06 (See TAB C/C4C).

- (6) Per Tab H/Chicago Fluid Power drawings: Air manifold assembly/
solenoid valves contain O-rings and seals which are comprised of
either DuPont Viton E-60C or 3M Flourel 2170. Since both materials
are fluorocarbon rubber, Wyle Labs assumed Viton E-60C with an
activation energy of 1.18 as the worst case (see (2) Section XVII.
para. 3.4.4.1). As it has been determined that Viton E-60C has a
lower activation energy than 3M Flourel (1.16 vs. 1.26, see TAB
C/C4C: sheets 8 and 8A); Viton E-60C shall be the most limiting
O-ring/seal material.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 19 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86
ASSEMBLY/SOLENOID VALVES- CHECKED WJR DATE 6/12/86
GOULD ALLIED

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference (1)Section 3.2).

Identify Acceptance Criteria: Test parameters recorded during test sequence were compared against set limits; but if operation of valve actuator was not affected, failure to meet these limits would not be considered essential.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference (1)Section 3.2)

Identify baseline and functional testing: _____

Valve Closing Time: 3 to 5 seconds

Valve Opening Time: 6.5 to 19.5 seconds

Pneumatic System Leakage (valve open or closed): .5 SCFH max.

JUSTIFICATION/COMMENTS Exhaust pressures and times were measured during all subsequent functional tests ((1)Section 4.0, 5.0, 6.0, 9.0, and 10.0).

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference (1)Sect. 3.2, last para.).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 20 OF 30
 R 1 R _____
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 afm
ASSEMBLY SOLENOID VALVES - 2/17/89
GOULD ALLIED CHECKED WBK DATE 6/12/86 KBN
2/27/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____)

(1) Sect. 3.2 _____).

JUSTIFICATION/COMMENTS _____

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
	+12%	
Voltage	<u>125 -16% VDC</u>	<u>Vendor Drawing</u>
		<u>No. 13824-01-H</u>
— Load	<u>11 Watts</u>	<u>Solenoid</u>
		<u>Nameplate</u>
Frequency	<u>NA</u>	
Accuracy	<u>NA</u>	
Other(s)		

R1

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 21 OF 30
 R 1 R
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 MM
2/17/89
 ASSEMBLY SOLENOID VALVES -
 GOULD ALLIED CHECKED WBK DATE 6/12/86 KR
2/27/89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) Parameter	Specific Accident Conditions	Reference
Voltage	<u>NA**</u>	<u>R1</u>
Load	<u>NA</u>	
Frequency	<u>NA</u>	
Accuracy	<u>NA</u>	
Other(s)		

JUSTIFICATION/COMMENTS **Solenoid valves are deenergized
during accident conditions per calculation WBNOSG4-045. R1

(c) Parameter	Demonstrated Conditions	Reference
Voltage	<u>109 VDC min 140 VDC max*</u>	<u>(2) p xvii,</u> <u>comment No.10&11</u>
Load	<u>NA</u>	
Frequency	<u>NA</u>	
Accuracy	<u>NA</u>	
Other(s)	<u>NA</u>	

JUSTIFICATION/COMMENTS *125VDC coils are used in Gould Allied
model No. 321X-21 solenoid valves for WBN valve actuators.
Airmatic-Allied model No. 321X-22 solenoid valves tested by
A&M use AC coils. Demonstrated voltage is based on similarity
to Wyle DC test coil. Materials similarity is addressed in
TAB B/Section D: Justification/Comments, sheets 5 through 7
(based on comparison of instruction manuals-actual to tested,
see TAB H and E/E2). R1

BINDER NO. WBNEQ-SOL-QQ4 PLANT WBN UNIT(S) 1 SHEET 22 OF 30
 R 1 R
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 9/8/86 AFM
ASSEMBLY SOLENOID VALVES - 2/17/89
GOULD ALLIED CHECKED RKW DATE 9/9/86 KBN
2/27/89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-76 | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 130 (a) Temperature (°F) 140

(b) Pressure (psig) ATM(-) (b) Pressure (psig) ATM

(c) Humidity (%) 50 (c) Humidity (%) 100

(d) Radiation (rd) 1.8x10³ TID (d) Radiation (rd) NA | R1

(3) Process Interfaces: Main steam design process temperature =
600°F; valve body and stem configuration eliminate significant
additional thermal effects which could degrade solenoid
components beyond ambient conditions.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Will exist up to 8 hours per excursion and will
occur less than 1% of the plant life. Humidity only: could
exist up to 8 hours and return to normal max of 50% RH in 8
hour period linearly. This condition should occur no more
than twice during plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 325* Accident type HELB

(b) Pressure (psig) 25.18 psia* Accident type HELB

(c) Humidity (%) 100* Accident type HELB

(d) Radiation (rd) NA Accident type HELB

(e) Spray Type NA Accident type NA

*See Required Operating Environment on next page.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 23 OF 30
 R 1 R
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 9/8/86 *gfm*
 ASSEMBLY SOLENOID VALVES - 2/1/89
 GOULD ALLIED CHECKED RKW DATE 9/9/86 *BA*
2/27/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): **See TVA drawing No. 47E235-76 for duration and profiles, and TAB C/C8 and WBNOSG4-003 for temperature justification during a main steam line break/superheated steam condition. Valves are required to operate during an HELB outside containment accident only; therefore, 1×10^4 rd LOCA radiation dose is not applicable.

R1

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: TAB C/C5).

- (7) Subject to submergence (Yes/No/NA)? No (Reference: Calculation WBNAPS2-001).

R1

Identify initiation time and duration of submergence:
 Maximum flood level in steam valve vault will not exceed EL 730.87. MSIV air manifold assembly lowest elevation is EL 742.0; therefore, submergence is not applicable (see TAB F for reference to elevation).

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No (Reference: TAB B, Section L(1)).

R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify:

- (9) Special environmental calculations (temp., rad., etc.)

See TAB B Section A for a listing of all calculations used in this binder.

R1

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 24 OF 30
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86
ASSEMBLY/SOLENOID VALVES- CHECKED 10/11/86 DATE 6/12/86
GOULD ALLIED

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	FW/V: 5 min. MS/V: 15 sec	1 hour	(1) Figure 5, pg. 56; Tab C/C4C
Temperature (°F)	***380 (25.18-14.7)	***398	(1) Figure 5; Tab C/C9, C10; Tab C/C8 (MS/V only)
Pressure (psig)	= 10.48	110	(1) Sect. 3.2, Tab C/C9
Relative Humidity (%)	100@24hrs	100 @ 10 Days	(1) Figure 5, Tab C/C9
*Chemical Spray	NA 1.8x10 ³	NA	---
**Radiation (rd)	(gamma)	1.74x10 ⁷	(1) Sect. 3.4, App. A pg. 50
Submergence	NA	NA	---

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	Yes	See Sect.
Pressure	Yes	L.(1) Ref.
Relative Humidity	Yes	above
Chemical Spray	NA	---
Submergence	NA	---

JUSTIFICATION/COMMENTS Sect. L.(1) Radiation: Beta contributions not considered during testing since solenoid valves are sufficiently shielded by a junction box comprised of cold rolled steel. Beta dose is not applicable to the subject devices, as they are not required to operate during a LOCA and are located outside of containment.

***Specified and demonstrated temperatures include coil heat rise: See Tab C/C4B, items B and C.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 25 OF 30
 R 1 R
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 ARM
2/17/89
 ASSEMBLY SOLENOID VALVES -
 GOULD ALLIED CHECKED WBK DATE 6/12/86 KBN
2/27/89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>>15°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>10psig</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>>10%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>>10%</u>	<u>Yes</u>
Voltage: ±10% of rated value	<u>>±10%</u>	<u>Yes</u>
Frequency: ±5% of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>Same</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>>10%</u>	<u>Yes</u>

R1

JUSTIFICATION/COMMENTS These are suggested margins only.
Radiation, time, and temperature figures envelope postulated
DBE conditions to such a large degree that the margins are
not considered to be critical.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 26 OF 30
R 1 R
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 afm
ASSEMBLY SOLENOID VALVES - 2/17/89
GOULD ALLIED CHECKED WBK DATE 6/12/86 KEA
2/27/89

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference: See TAB A). R1

JUSTIFICATION/COMMENTS _____

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: (1) Section 10.0).

JUSTIFICATION/COMMENTS Valves are required to de-energize
5 min. into an Feedwater line break and 15 sec into a Main
Steam line break (ref. M(1)). Valves were operated every
10 min. during the first hour of test.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure ---
(Yes/No/NA)? Yes (Reference: (1) Figure 5).

JUSTIFICATION/COMMENTS During Post-DBE the solenoids are not
required to operate but must not fail in a manner detrimental
to plant safety (ref. M(1)) except test solenoids 1-FSV-001- R1
4F, 4J, 11F, 11J, 22F, 22J, 29F and 29J are category C
during post-DBE. Since DBE test conditions envelope actual
Post-DBE requirements, this criteria has been met (see TAB
C/C4C).

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (Yes/No/NA)? Yes (Reference: (1) Section 10.0).

JUSTIFICATION/COMMENTS See M.(2) above.

BINDER NO. WBNEQ-SOL-QQ4 PLANT WBN UNIT(S) 1 SHEET 26a OF 30
R R
BINDER TITLE MSIV AIR MANIFOLD COMPUTED /R1 *AM* DATE 2/17/89
ASSEMBLY SOLENOID VALVES -
GOULD ALLIED CHECKED /R1 *BN* DATE 2/27/89

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: (1) Results, pg. 2 and 3; (2) p iii through xix

JUSTIFICATION/COMMENTS We have reviewed and concur with the disposition of anomalies documented in the reference (1) and (2) test reports. There is no impact on installed equipment; however, TAB G documents those findings which resulted in maintenance activities for corrective action.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 27 OF 30
BINDER TITLE MSIV AIR MANIFOLD R R
ASSEMBLY/SOLENOID VALVES- COMPUTED RHL DATE 6/11/86
GOULD ALLIED CHECKED WJL DATE 6/12/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS (2) Page No. xv through xix, see items 7 and 15.

Note: Maintenance and surveillance requirements are based on more
extensive WYLE thermal aging results than results from A&M; therefore,
only WYLE information is included (for detailed explanation, see
Section D: Justification/Comments, sheets 5 through 7).

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 28 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/14/86
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED CHECKED WHL DATE 6/14/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>No</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>Yes</u>
(b) Were specific features and failure modes and effects analyzed?	<u>Yes</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>Yes</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>Yes</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 29 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RAH DATE 6/11/86 R R
ASSEMBLY/SOLENOID VALVES-
GOULD ALLIED CHECKED WJK DATE 6/12/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>NA</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 30 OF 30
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86
ASSEMBLY/SOLENOID VALVES- GOULD ALLIED CHECKED WPK DATE 6/12/86

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>NA</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

MANUFACTURER : ASCO
PAGE 1 OF 4

EGIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	ALMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT OPER TIME EVENT SAFETY FUNCTION (2)
WBN-1-FSV -030-0146A -A 1-FSV -030-0146A -A AUX BLDG GAS TMT FAN A-A EXH OMPR 206-380-2RVU	737 ¹ A05 80KJ3-827551	A	100D	L SOLENOIDS ARE ACTUATED BY AN ABI SIGNAL AND ARE REQUIRED TO BE OPERABLE DURING THE MITIGATION OF THIS EVENT.
WBN-1-FSV -030-0146B -A 1-FSV -030-0146B -A AUX BLDG GAS TMT FAN A-A EXH OMPR 206-380-2RVU	737 ¹ A05 80KJ3-827551	A	100D	L SOLENOIDS ARE ACTUATED BY AN ABI SIGNAL AND ARE REQUIRED TO BE OPERABLE DURING THE MITIGATION OF THIS EVENT.
WBN-2-FSV -030-0157A -B 2-FSV -030-0157A -B AUX BLDG GAS TMT FAN A-A EXH OMPR 206-380-2RVU	737 ¹ A09 80KJ3-827551	A	100D	L SOLENOIDS ARE ACTUATED BY AN ABI SIGNAL AND ARE REQUIRED TO BE OPERABLE DURING THE MITIGATION OF THIS EVENT.
WBN-2-FSV -030-0157B -B 2-FSV -030-0157B -B AUX BLDG GAS TMT FAN B-B SUCT 206-330-2RVU	737 ¹ A09 80KJ3-827551	A	100D	L SOLENOIDS ARE ACTUATED BY AN ABI SIGNAL AND ARE REQUIRED TO BE OPERABLE DURING THE MITIGATION OF THIS EVENT.
WBN-1-FSV -032-0090A -A 1-FSV -032-0080A -A 294 REACTOR BLDG UNIT 1 TRAIN A ISLN 206-380-3RU	724 ¹ AHN 78K3-822950	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C	SOLENOIDS MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED AFTER A PHASE B ISOLATION SIGNAL IS RECEIVED AND RESET

PAGE A-1R1

PREPARER/DATE Randy Foust 8/27/86
CHECKED/DATE W. B. Kim 8/27/86
R 1
R 2/10/89
R

500-705

DATE: 05/15/90

WATTS BAR NUCLEAR PLANT TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL-
MANUFACTURER : ASCO
PAGE 2 OF 4

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-FSV -032-0080B -A 1-FSV -032-0080B -A 296 REACTOR BLDG UNIT 1 TEST SOL	206-380-2RU	718' 4" ANN 80KJ3-827551	B 100D B 100D B 100D B 1MO B 1MO	L MS/C FW/C RH/C CV/C			SOLENOID FAILURE MUST NOT CAUSE ASSOCIATED CNTMT ISOL VALVE TO OPEN AFTER A PHASE B ISOLATION SIGNAL IS RECEIVED AND RESET
WBN-1-FSV -032-0102A -B 1-FSV -032-0102A -B 278 REACTOR BLDG UNIT 1 TRAIN B ISLN	206-380-3RU	727'10" ANN 78K3-822950	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C			SOLENOIDS MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED AFTER A PHASE B ISOLATION SIGNAL IS RECEIVED AND RESET
WBN-1-FSV -032-0102B -B 1-FSV -032-0102B -B 279 REACTOR BLDG UNIT 1 TEST SOL	206-380-2RU	727'10" ANN 80KJ3-827551	B 100D B 100D B 100D B 1MO B 1MO	L MS/C FW/C RH/C CV/C			SOLENOID FAILURE MUST NOT CAUSE ASSOCIATED CNTMT ISLN VLV TO OPEN AFTER A PHASE B ISOLATION SIGNAL IS RECEIVED AND RESET
WBN-1-FSV -032-0110A -A 1-FSV -032-0110A -A 295 RB UNIT 1 NON-ESNTL CONT AIR ISLN	206-380-3RU	718' 8" ANN 78K03-822950	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C			SOLENOIDS MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED AFTER A PHASE B ISOLATION SIGNAL IS RECEIVED AND RESET
WBN-1-FSV -032-0110B -A 1-FSV -032-0110B -A 296 RB UNIT 1 NON-ESNTL CONT AIR ISLN	206-380-2RU	718' 8" ANN 80KJ3-827551	B 100D B 100D B 100D B 1MO B 1MO	L MS/C FW/C RH/C CV/C			SOLENOID FAILURE MUST NOT CAUSE ASSOCIATED CNTMT ISLN VLV TO OPEN AFTER A PHASE B ISOLATION SIGNAL IS RECEIVED AND RESET

PAGE A-2 R2

PREPARER/DATE RANDY FOUST 8/27/86

CHECKED/DATE W.B. KIM 8/27/86

R 1	R 2	R
AFM	AFM	
2/17/89	5/21/90	
EEM	AFM	
2/23/89	5/21/90	

DATE: 05/15/90

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL-0
MANUFACTURER : ASCO
PAGE 3 OF 4

EQIS NUMBER	UNIT DEVICE ID NO.	MODEL NUMBER	LOCATION ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-0-FSV -065-0024 EGTS TRAIN A FAN A-AISLN DMPR	-A 0-FSV -065-0024 206-380-2RU	-A	757' A16 80KJ3-827551	A	100D	L	SOLENOIDS MUST REMAIN OPERABLE FOR THE DURATION OF THE LOCA.
WBN-0-FSV -065-0043 EGTS TRAIN B FAN B-B ISLN DMPR	-B 0-FSV -065-0043 206-380-2RU	-B	757' A16 80KJ3-827551	A	100D	L	SOLENOIDS MUST REMAIN OPERABLE FOR THE DURATION OF THE LOCA.
WBN-2-FSV -067-0336 EMERG GAS TRTMT ROOM COOLER A ICR	-A 2-FSV -067-0336 206-380-2RU	-A	757' A16 80KJ3-827551	A	100D	L	MUST OPERATE TO SUPPORT OPERATION OF EGTS & PEN ROOM COOLERS
WBN-2-FSV -067-0338 EMERG GAS TRTMT ROOM COOLER B ICR	-B 2-FSV -067-0338 206-380-2RU	-B	757' A16 80KJ3-827551	A	100D	L	MUST OPERATE TO SUPPORT OPERATION OF EGTS & PEN ROOM COOLERS
WBN-1-FSV -067-0350 PEN RM CLR A2 SUP CNTL VLV	-A 1-FSV -067-0350 206-380-2RU	-A	713' A06 80KJ3-827551	A	100D	L	SOLENOIDS MUST FUNCTION TO PROVIDE FLOW TO COOLERS WHICH SERVE ESF EQUIPMENT

PAGE A-3 R3

PREPARER/DATE RANDY FOUST 8/27/86
CHECKED/DATE W.B. KIM 8/27/86

R 1 AFM 2/17/89
EEM 2/23/89
R 2 CMM 5/21/90
R

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQUIS NUMBER		UNIT DEVICE ID NO.		LOCATION		CAT		OPER TIME		EVENT		SAFETY FUNCTION	
DESCRIPTION		MODEL NUMBER		ELEV(11) RM/BAQ		(2)							
WBN-1-FSV -067-0352	-B	1-FSV -067-0352	-B	713'	A06	A	100D	L				SOLENOIDS MUST FUNCTION TO	
PEN RM CLR B2 SUP	CNTL VLV	206-380-2RU		80KJ3-827551		A	1MO	RH/A				PROVIDE FLOW TO COOLERS	
						A	1MO	CV/A				WHICH SERVE ESF EQUIPMENT	
						A	1MO	AF/A					
						A	1MO	AB					
WBN-1-FSV -067-0354	-A	1-FSV -067-0354	-A	737'	A05	A	100D	L				SOLENOIDS MUST FUNCTION TO	
PEN RM CLR A3 SUP	CNTL VLV	206-380-2RU		80KJ3-827551		A	1MO	RH/A				PROVIDE FLOW TO COOLERS	
						A	1MO	CV/A				WHICH SERVE ESF EQUIPMENT	
						A	1MO	AF/A					
						A	1MO	AB					
WBN-2-FSV -067-0354	-A	2-FSV -067-0354	-A 313	737'	A09	A	100D	L				SOLENOIDS MUST FUNCTION TO	
PEN RM CLR A3 SUP	CNTL VLV	206-380-2RU		80KJ3-827551								PROVIDE FLOW TO COOLERS	
												WHICH SERVE ESF EQUIPMENT	
WBN-1-FSV -067-0356	-B	1-FSV -067-0356	-B	737'	A05	A	100D	L				SOLENOIDS MUST FUNCTION TO	
PEN RM CLR B3 SUP	CNTL VLV	206-380-2RU		80KJ3-827551		A	1MO	RH/A				PROVIDE FLOW TO COOLERS	
						A	1MO	CV/A				WHICH SERVE ESF EQUIPMENT	
						A	1MO	AF/A					
						A	1MO	AB					
WBN-2-FSV -067-0356	-B	2-FSV -067-0356	-B	737'	A09	A	100D	L				SOLENOIDS MUST FUNCTION TO	
PEN RM CLR B3 SUP	CNTL VLV	206-380-2RU		80KJ3-827551								PROVIDE FLOW TO COOLERS	
												WHICH SERVE ESF EQUIPMENT	

PREPARER/DATE Randy Foust 8/27/86

CHECKED/DATE W. B Kim 8/27/86

R 1
2/27/89
R
R
8/27/89

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE ASCO SOLENOID VALVES COMPUTED/R1 AW DATE 2/7/89
MODEL 206-380 SERIES
(AC CONSTRUCTION) CHECKED/R1 SEM DATE 2/23/89

TAB A NOTES:

1) Floor/Actual Elevation - Actual Elevations are documented on field
verification sheets found in TAB F. All elevations shown are
floor elevations except for those devices located inside the
reactor building.

2) See TAB B, Section A for a complete listing of Category and Opera-
ting Times Calculations used in this binder.

3) Contract Column - Contract numbers shown in this TAB were obtained
by tracing the serial number on each valve through TVA procure-
ment records and did not depend on field verification data for
contract numbers.

References: _____

TAB B

ENVIRONMENTAL QUALIFICATION CHECKLIST

NOTE: The units common, 1 and 2 solenoid valves covered by this binder are required for Unit 1 operation.

EQP098.51

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 1 OF 27
R 1 R 2
BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/28/86 AFM CSH
MODEL 206-380 SERIES 2/17/89 5/18/90
(AC CONSTRUCTION) CHECKED WBK DATE 8/28/86 EEM AJM
2/23/89 5/21/90

A. DOCUMENTATION

Equipment Description Solenoid Valves
Vendor/Manufacturer Automatic Switch Company (ASCO)
Equipment Model No.(s) 206-380-2RVU
206-380-3RU
206-380-2RU

QUALIFICATION REPORTS

- (1) Title/Number/Revision "Report on Qualifi- RIMS B45 850514 428
cation of Automatic Switch Co. (ASCO) Cata-
log NP-1 Solenoid Vlvs for Safety-Related DATE 8/19/83
Applications in Nuclear Power Generating
Stations", AQR-67368, Rev. 1.

NOTE: Throughout this Binder, references are made to the ASCO
qualification report listed above. This report is identified
as "(1)" in these references.

- (2) Title/Number/Revision "Equipment Qualifi- RIMS NEB 840925 351
cation Research-Test Program & Failure
Analysis of Class IE Solenoid Vlvs", DATE Nov. 1983
F-C5569-309/315 Appendix C, and pages F-3
and F-4.

R2

- (3) Title/Number/Revision "Aging and Quali- RIMS B74 890623 502
fication Research on Solenoid Operated
Valves," NUREG/CR-5141 RV DATE August 1988

- (4) Title/Number/Revision "ASCO Engineering RIMS B25 870612 003
Report No. 177"
DATE 12/11/79

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (5) Category and Operating Times Calculation WBNOSG4-008 R15
(System 30) (B26 900309 231)
(6) Category and Operating Times Calculation WBNOSG4-010 R4
(System 32) (B26 891205 200)

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 1a OF 27
 R 2 R 2
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED/R1 AFM DATE 2/17/89 5/2/90
 MODEL 206-380 SERIES
 (AC CONSTRUCTION) CHECKED/R1 EEM DATE 2/23/89 AFM
5/2/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- | | |
|--|----|
| (7) Category and Operating Times Calculation WBNOSG4-015 R10
(System 65) (B26 900309 226) | R2 |
| (8) Category and Operating Times Calculation WBNOSG4-016 R14
(System 67) (B26 900319 215) | |
| (9) WBNP Environmental Data Drawing 47E235-44 R1 | |
| (10) WBNP Environmental Data Drawing 47E235-48 R3 | |
| (11) WBNP Environmental Data Drawing 47E235-49 R2 and
DCA-P02351-11-0 per DCN P-02351-A (B26 88 1210 801) | R2 |
| (12) WBNP Environmental Data Drawing 47E235-56 R1 | |
| (13) WBNP Environmental Data Drawing 47E235-57 R2 and
DCA-P02351-17-0 per DCN P-02351-A (B26 88 1210 801) | R2 |
| (14) WBNP Environmental Data Drawing 47E235-78 R3 | |
| (15) Calculation WBNNAL3-007 R3 (B26 890605 308), Location
Specific Radiation Dose | R2 |
| (16) Deleted by Revision 2. | |
| (17) Calculation WBNOSG4-044 R1 (B45 860908 218), Flooding | |
| (18) Calculation GENNAL6-002 R2 (B45 860812 236), Moisture
Intrusion | |
| (19) Calculation WBNOSG4-045 R1 (B45 860902 219), Status and Duty
Cycles of Solenoid Valves | |
| (20) Calculation WBNNAL3-031 R1 (B45 880826 235), 100-day LOCA
Dose in EGTS Filter Train Room | |
| (21) Calculation WBN-EEB-MS-TI06-0017 (B26 900202 410)
Solenoid Valve Voltage Study | R2 |
| (22) Calculation TI-ECS-79 R2 (B45 860319 235), EGTS Room
Temperature | |

BINDER TITLE ASCO SOLENOID VALVES COMPUTED /R1 AFM DATE 2/17/89
MODEL 206-380 SERIES
(AC CONSTRUCTION) CHECKED /R1 EEM DATE 2/23/895/18/90
5/21/90A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (23) ASCO Letter, W. M. Brown to F. W. Chandler dated April 29, 1985 (B43 850502 015)
- (24) Material Aging Data Request WAD-3
- (25) ASCO Certification of Compliance (B43 850326 508, MED 840202 206, B26 860728 022) R2
- (26) TVA Memorandum D. L. Reed to EEB files dated October 9, 1984 (EEB 841010946)
- (27) Deleted by Revision 2. R2
- (28) ASCO Letter, W. M. Brown to D. L. Kitchel dated May 8, 1986 (B71 860512 001).
- (29) CATEGORY AND OPERATING TIMES CALCULATION WBNOSG4-040, R7
U2 COMPONENTS REQUIRED FOR U1 SAFE SHUTDOWN
(B26 900327 203).

NOTES:

- (1) Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.
- (2) Although most valves in this binder were purchased and certified to be in compliance with ASCO Test Report No. AQS21678/TR, NRC recognizes this model valve as being qualified to the later ASCO Test No. AQR 67368 (see NRC Information Notice 85-08 in TAB J). Therefore, qualification of the valves in this binder is to the parameters of the later test although the COCs from ASCO in TAB E are to the older test.

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 2 OF 27
R 1 R 2
BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/28/86 AFM CXH
MODEL 206-380 SERIES 2/23/89 4/9/90
(AC CONSTRUCTION) CHECKED WBK DATE 8/28/86 EEM MM
2/23/89 5/21/90

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

1) Conduit seals must be installed on valve Nos. 1-FSV-67-350-A,
-352-B, -354-A, and -356-B.

R2

COMMENTS/RECOMMENDATIONS None

BINDER TITLE ASCO SOLENOID
VALVES, MODEL NO. 206-380-SERIES
(AC CONSTRUCTION)

COMPUTED KJ DATE 8/27/86 _____
CHECKED WKR DATE 8/29/86 _____

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

Components are Qualified to the Criteria of NUREG-0588
Category II or the DOR Guidelines of IE Bulletin No. 79-
01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS

IEEE 323-1974, IEEE 344-1975, IEEE 382-1980, and IEEE 627-1980.

BINDER TITLE ASCO SOLENOID COMPUTED RCF DATE 8/27/86 R R
VALVES, MODEL NO. 206-380-SERIES
(AC CONSTRUCTION) CHECKED WPK DATE 8/27/86

X Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

_____ Experience with Identical or Similar Equipment Under Similar
Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS See TAB C

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 2 OF 27
 R 1 R 2
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/28/86 AFM CAF
 MODEL 206-380 SERIES 2/23/89 5/18/90
 (AC CONSTRUCTION) CHECKED WBK DATE 8/28/86 EEM AFM
 2/23/89 5/21/90

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (Yes/No/NA)? yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Vlv</u>	<u>Solenoid Vlv</u>	See <u>TAB C</u>
(2) Manufacturer	<u>ASCO</u>	<u>ASCO</u>	See <u>TAB C</u>
(3) Model Number(s)	<u>206-380-2RVU</u>	<u>K206-380-3RVF</u>	See TAB C & pg. <u>5 of (1)</u>
	<u>206-380-3RU</u>	<u>K206-380-3RF</u>	See TAB C & pg. <u>5 of (1)</u>
	<u>206-380-2RU</u>		
(4) Serial Number(s)	<u>See TAB F</u>	<u>Not Listed</u>	
(5) Identify Component Unique checksheet attached:	<u>NA</u>		

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 6 OF 27

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES COMPUTED RZ DATE 8/27/86 R 2 R 5/18/90
(AC CONSTRUCTION) CHECKED GP/PAK DATE 8/27/86 ARM 5/21/90

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>None Specified, See TAB C, "Interfaces"</u>	<u> </u>	<u> </u>
External Process Connections	<u>None Specified, See TAB C, "Interfaces"</u>	<u> </u>	<u> </u>
Electrical Connections	<u>TAB C, "Interfaces"</u>	<u> </u>	<u> </u>
Conduit Seals	<u>See TAB C, "Interfaces"</u>	<u> </u>	<u> </u>
Connector Seals	<u>NA</u>	<u> </u>	<u> </u>
Orientation	<u>Vertical & Upright $\pm 45^\circ$</u>	<u>Yes</u>	<u>App. A, Pg. A2 of (1) & ASCO Ltr IN TAB E-2</u>
Physical Configuration	<u>N/A</u>	<u> </u>	<u> </u>
Other	<u>See below</u>	<u>Yes</u>	<u>See below</u>

JUSTIFICATION/COMMENTS 1. ASCO requires the installation of a 90° street elbow facing downward connected to exhaust port or similar configuration to prevent moisture from entering valve internals (Reference: Page A18 of 1). The purpose of this requirement is to prevent moisture intrusion resulting from a liquid spray. Since these valves are not subject to any spray condition the installation of a 90° street elbow is not required.

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 7 OF 27
R 1 R 2
BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/28/86 GM CRH
MODEL 206-380 SERIES 2/17/89 5/18/90
(AC CONSTRUCTION) CHECKED WBK DATE 8/28/86 EEH GM
2/23/89 5/21/90

F. INSTALLATION INTERFACES (Continued)

JUSTIFICATION/COMMENTS (Continued)

2). Medium must be oil free instrument air and a strainer or
filter must be installed on the inlet as close to the valve
as possible (Reference: ASCO Bulletin for Model 206-380
valves Tab H). ASCO does not identify specific interfacing
requirements except as noted above. It is incumbent on each
utility to ensure that interfaces are such that they do not
interfere with the proper operation or qualification of the
solenoid valve. See TAB C for a description of the TVA
interfaces.

R2

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 8 OF 27

BINDER TITLE ASCO SOLENOID COMPUTED RC DATE 8/27/86 R 2 R
VALVES, MODEL NO. 206-380-SERIES CHECKED WJK DATE 8/21/86 5/18/90
(AC CONSTRUCTION) 5/21/90

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>Sect. 4,</u> <u>pg 3 of (1)</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Sect. 4,</u> <u>pg 8 of (1)</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>Sect 4.1.1, pg 8</u> <u>of (1).</u>
Radiation	<u>Yes</u>	<u>Sect 4.1.4, pg 15</u> <u>of (1).</u>
Wear	<u>Yes</u>	<u>Sect 4.1.2, pg 12</u> <u>of (1).</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Sect. 4.1.5, pg 15,</u> <u>Sect. 4.1.6, pg 17 &</u> <u>Sect. 4.2.1, pg 19</u> <u>of (1).</u>
(e) Design basis event (DBE exposure	<u>Yes</u>	<u>Sect. 4.2, pgs 19-</u> <u>23 of (1)</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>Sect. 4.2.3, pgs</u> <u>22 & 23 of (1)</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>Sect. 4.4, pg 24</u> <u>of (1).</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes
(Reference Appendix G of (1)).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 9 OF 27

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES COMPUTED [Signature] DATE 8/27/86 R 2 R 5/18/90
(AC CONSTRUCTION) CHECKED [Signature] DATE 8/29/86 R ADM 5/21/90

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference Appendix A, Sect. 9.4,
pg A10 of (1); and TAB C).

JUSTIFICATION/COMMENTS _____

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	App. A, Sect. 9.4.1 of (1)
Radiation exposure	<u>Yes</u>	App. A, Sect. 9.4.4 of (1)
Vibration (non-seismic) aging	<u>Yes</u>	App. A, Sect. 9.4.5 of (1)
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	App. A, Sect. 9.4.2 and 9.4.3 of (1).

JUSTIFICATION/COMMENTS _____

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? No (Reference _____).

JUSTIFICATION/COMMENTS Synergistic effects were considered in the qualification of these valves. Each section of TAB C contains a discussion on this subject.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.1, pg. A10 of (1), and TAB C).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 10 OF 27

BINDER TITLE ASCO SOLENOID
VALVES, MODEL NO. 206-380-SERIES
(AC CONSTRUCTION)

COMPUTED RTF

DATE 5/27/86

R 2 R

CHECKED WPK

DATE 8/27/86

5/18/90

ADM

5/21/90

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference: App. B of (1)).

R2

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference See H (1) this Tab).

JUSTIFICATION/COMMENTS _____

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference App. A. Sect. 9.4.1 of (1)).

R2

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	_____	_____	_____
Time	_____	_____	_____

JUSTIFICATION/COMMENTS See TAB C, "Aging"

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference See H(4)(d) this Tab & TAB C).

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes
(Reference See H(4)(b) this Tab).

JUSTIFICATION/COMMENTS _____

PAGE B-11 R2

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 11 OF 27

BINDER TITLE ASCO SOLENOID COMPUTED RCF DATE 8/28/86 R 2 R 5/18/90

VALVES, MODEL NO. 206-380-SERIES CHECKED WPAK DATE 8/28/86 ARM
(AC CONSTRUCTION) 5/21/90

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? N/A (Reference _____).

JUSTIFICATION/COMMENTS _____

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference Sect. 4.1.1, pg. 11 of (1)). | R2

JUSTIFICATION/COMMENTS _____

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.4 of (1)). | R2

JUSTIFICATION/COMMENTS _____

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? No (Reference _____).

JUSTIFICATION/COMMENTS ASCO's intent was not to subject the test specimen to radiation exposure in accordance with the limiting material. Their intent was to demonstrate operability regardless of the radiation threshold values.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes (Reference See H(5)(a) this Tab).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEO-SOL-005 PLANT WBN UNIT(S) 1 SHEET 12 OF 27
 R 1 R 2
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/28/86 CEM CRJ
 MODEL 206-380 SERIES 2/17/89 5/18/90
 (AC CONSTRUCTION) CHECKED WBK DATE 8/28/86 CEM APM
2/23/89 5/21/90

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: Section

4.1.4 of (I) and Appendix D of (I)) R2

Plant normal ambient radiation dose (rd)

Various-See TAB C

Test exposure dose (rd)

2.3 x 10⁷ rads, gamma

Test exposure dose rate (rd/hr)

0.71 Mrad/hr for 33 hours

Test exposure source type (e.g., Co-60 gamma)

Co-60, gamma

JUSTIFICATION/COMMENTS

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program? Yes (Reference: App. A.

Section 9.4.5 and Section 4.1.5 of (I)) R2

JUSTIFICATION/COMMENTS No failure which could be

attributed to vibration aging was identified.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: App. A. Section 9.4.5 of (I)) R2

JUSTIFICATION/COMMENTS

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder.

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 13 OF 27
R 1 R 2
BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/27/86 CFM CRH
MODEL 206-380 SERIES 2/17/89 4/8/90
(AC CONSTRUCTION) CHECKED WBK DATE 8/27/86 ESM CFM
2/23/89 5/21/90

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: App. A. Section 9.4.2 and 9.4.3 of (I)) R2

JUSTIFICATION/COMMENTS _____

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: App. A. Section 9.4.2 & 9.4.3 of (I)) R2

JUSTIFICATION/COMMENTS _____

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes (Reference: See below, TAB C, and Section 9.4.1 Appendix A of (I)) R2

Qualified life (Document in QMDS) _____

JUSTIFICATION/COMMENTS _____

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes (Reference: See below and TAB C) R2

JUSTIFICATION/COMMENTS Replacement intervals and qualified life are a function of plant specific conditions in comparison to test conditions. TABS C and G define the replacement intervals and qualified life and their basis.

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 14 OF 27
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/27/86 5/18/90
 MODEL 206-380 SERIES
 (AC CONSTRUCTION) CHECKED WBK DATE 8/27/86 5/21/90

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/ Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(Coil) IsoMica bonded	1×10^9			
(a) <u>with Hi-Temp Epoxy</u>	<u>rads</u>	<u>See below</u>	<u>1.00</u>	<u>See below</u>
<u>Ethylene Propylene</u>	1×10^7			<u>App. B pg</u>
(b) <u>Therpolymer (Seats)</u>	<u>rads</u>	<u>See below</u>	<u>0.94</u>	<u>B3 of (1)</u>
	5×10^6			<u>App. B pg</u>
(c) <u>Viton (Seats)</u>	<u>rads</u>	<u>See below</u>	<u>1.04</u>	<u>B4 of (1)</u>
(d) ⁵ <u>*DC 550 Lubricant</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS Note: The Class H coil is composed of six
primary materials. Of these, the one with the lowest activation
energy is Iso-Mica bonded with hi-temp epoxy. Its activation energy
is 1.00 eV. The materials of coil construction along with their
activation energies are identified in Appendix B, page B5 of (1).
Radiation threshold values are typical for these materials and
listed for information only. These values were not taken from the
test report but were supplied by the Digital Materials Data Base.
(See TAB E).

*Although not stated in Ref. (1), DC 550 lubricant was used on
tested valves as verified by ASCO letter dated 1/5/88
(see TAB E-11).

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 15 OF 27

BINDER TITLE ASCO SOLENOID
VALVES, MODEL NO. 206-380-SERIES
(AC CONSTRUCTION)

COMPUTED RJ DATE 8/27/86 R 2 R
CHECKED WJK DATE 8/27/86 5/18/90
GM
5/21/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference App. A, Sect. 6.1 and 6.2 of (1)).

Identify Acceptance Criteria: Coil only taken from (1) - Must operate at any voltage between 102 VAC and 132 VAC. Insulation resistance must measure greater than or equal to 1 megohm at 500 VDC. Leakage current must be less than 0.5 milliamps at 1240 VAC for 1 minute. For seats and discs, as taken from (1) - Valves must operate at the minimum and maximum operating pressure differentials. Valves must not have a pressure increase at a cylinder port which is required to be vented or a pressure decrease at a cylinder port which is required to be pressurized in excess of 10% of the maximum operating pressure differential.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Ref. App. A, Sects. 6.1, 6.2, and App. AIII of (1) .)

Identify baseline and functional testing: Recording coil excitation, coil dielectric, seat leakage at 150 psig and 10 psig in both the energized and de-energized state, noise test, external leakage at 150 psi, operational test from 150 psig to 0 psig, insulation resistance and number of active coil turns during initial baseline and following DBA simulation.

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 16 OF 27

BINDER TITLE ASCO SOLENOID COMPUTED RT DATE 8/27/86 R 2 R 5/18/90
VALVES, MODEL NO. 206-380-SERIES
(AC CONSTRUCTION) CHECKED WJA DATE 8/27/86 R ADM 5/21/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

JUSTIFICATION/COMMENTS

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes
(Reference Appendix A, Figure 9.2, page A26 of (1)).

|R2

JUSTIFICATION/COMMENTS

BINDER NO. WBNEO-SOL-005 PLANT WBN UNIT(S) 1 SHEET 17 OF 27

R 1 R 2

BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/28/86 17M CSH

MODEL 206-380 SERIES

(AC CONSTRUCTION) CHECKED WBK DATE 8/28/86 17M CSH
2/23/89 5/21/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: Tbl 4.3, page 30 of (1)) R2

JUSTIFICATION/COMMENTS Loads of voltage and pressure.

Actual plant voltage during normal operation is within the
+ 10%
required range of 120VAC - 15% except as noted below. Plant
operating pressure is within the range tested. However,
maximum operating pressure differential is function of the
specified valve design. (See TAB C).

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions ¹	Reference	
Voltage	<u>120 VAC ± 10%</u>	Procurement Contracts, Sec. E8 & E9	<u>R2</u>
Load	<u>SEE SHEET 18A</u>	Procurement Contracts, Sec. E8 & E9	<u>R2</u>
Frequency	<u>60 HZ</u>	Procurement Contracts Sec. E8 & E9	<u>R2</u>
Accuracy	<u>NA</u>	<u>—</u>	
Other(s)	<u>—</u>	<u>—</u>	
JUSTIFICATION/COMMENTS			<u>R2</u>

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 18 OF 27
 R 1 R 2
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/27/86 AFM CSZ
 MODEL 206-380 SERIES 2/17/89 5/18/90
 (AC CONSTRUCTION) CHECKED WBK DATE 8/27/86 EEM AFM
 2/23/89 5/21/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(5) (b) <u>Parameter</u>	<u>Specific Accident Conditions</u> ¹	<u>Reference</u>	
Voltage	<u>Varies</u>	<u>Procurement Contracts, Sec. E8 & E9</u>	R2
Load	<u>Not specified</u>	<u>Procurement Contracts, Sec. E8 & E9</u>	
Frequency	<u>Not specified</u>	<u>Procurement Contracts, Sec. E8 & E9</u>	
Accuracy	<u>NA</u>	<u>---</u>	
Other(s)	<u>---</u>	<u>---</u>	
JUSTIFICATION/COMMENTS <u>See Sheet 18A</u>			

(5) (c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>	
Voltage	<u>+ 10% 120 VAC - 15%</u>	<u>Tbl 4.3 pg 30, Sect. 4.2.3 p 22, App. A Sect. 9.5.3 and App. A Fig. 9.2 of (/)</u>	R2
Load	<u>0.249 amps₂ to 0.262 amps at 102 VAC</u>	<u>Tbl 4.3 p 30 of (/)</u>	R2
Frequency	<u>60 Hz ± 0%</u>	<u>App. A, pg. A26 of (/)</u>	R2
Accuracy	<u>NA</u>	<u>---</u>	
Other(s)	<u>---</u>	<u>---</u>	
JUSTIFICATION/COMMENTS <u>SEE SHEET 18A</u>			

BINDER TITLE ASCO SOLENOID VALVES COMPUTED /R1 AFM DATE 2/17/89 CZLMODEL 206-380 SERIES 4/9/90(AC CONSTRUCTION) CHECKED /R1 EEM DATE 2/23/89 ATM5/21/90

JUSTIFICATION/COMMENTS

- ¹ Valves were procured to be qualified in accordance with IEEE 323-1974 which specifies that operability shall be demonstrated at rated voltage $\pm 10\%$ and rated frequency $\pm 5\%$ unless otherwise specified. Contract 827551 and 822950 did not specify a plant unique range. None of the contracts specified frequency or frequency range. TVA Calculation WBN-EEB-MS-TI06-0017 documents that the terminal voltage for all 206-380 series solenoid valves is more than the demonstrated minimum voltage of 102 VAC. Additionally, testing performed by Franklin Research, as documented in Test Report F-C5569-309/315, demonstrates the ability of these valves to operate at a voltage much less than the 102 VAC. Franklin successfully demonstrated the ability of these valves to energize and shift position at voltages between 77 VAC and 95 VAC after exposure to conditions much more severe than what the TVA valves will experience. It is therefore concluded that adequate voltage is supplied for successful operation under worst-case accident conditions. R2
- ² The TVA valves have a 20 watt AC rating. Per ASCO Catalog NP-1 (TAB E, Section E1), these solenoids are rated at 41.5 volt-amps holding and 195 volt-amps in-rush. The demonstrated volt-amps holding is determined as follows:
 $0.262 \text{ amps} \times 102 \text{ VAC} = 26.72 \text{ volt-amps}.$

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 19 OF 27
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/27/86 CAH
 MODEL 206-380 SERIES 5/18/90
 (AC CONSTRUCTION) CHECKED WBK DATE 8/27/86 ATM
5/21/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Various - See TAB C

| R2

(1) Normal Max

(2) Abnormal Max

	Various See		Various See
(a) Temperature (°F)	<u>TAB C</u>	(a) Temperature (°F)	<u>TAB C</u>
	Various See		Various See
(b) Pressure (psig)	<u>TAB C</u>	(b) Pressure (psig)	<u>TAB C</u>
	Various See		Various See
(c) Humidity (%)	<u>TAB C</u>	(c) Humidity (%)	<u>TAB C</u>
	Various See		Various See
(d) Radiation (rd)	<u>TAB C</u>	(d) Radiation (rd)	<u>TAB C</u>

(3) Process Interfaces: The process fluid is oil free instrument air
with a design temperature of 100°F maximum. Therefore, the
bounding temperature for these valves is the ambient.

| R2

(4) State anticipated occurrence frequency and duration of abnormal
conditions: Up to eight hours per excursion and less than one
percent of plant life. See TAB C.

(5) Accident (worst case for any combination of specified accident
parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>110°F/230°F</u>	Accident Type	<u>LOCA/HELB</u>
(b) Pressure (psig)	<u>ATM(-)</u>	Accident type	<u>LOCA/HELB</u>
(c) Humidity (%)	<u>100%</u>	Accident Type	<u>LOCA/HELB</u>
(d) Radiation (rd)	<u>1 X 10³ RADS</u>	Accident Type	<u>LOCA/HELB</u>
(e) Spray Type	<u>N/A</u>	Accident Type	<u>N/A</u>

| R2

BINDER TITLE ASCO SOLENOID VALVES COMPUTED/R1 AFM DATE 2/17/89 5/18/90MODEL 206-380 SERIES(AC CONSTRUCTION) CHECKED/R1 EEM DATE 2/23/89 5/21/90K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Worst case accident environment for the valves in this binder is for the Group E valves.

Temperature will be 110°F for 30 days following a LOCA.

Following an RHR line break, temperature will spike to 200°F at 11 minutes, decreasing to maximum normal at 24 hours.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: All valves subject to such conditions require conduit seals and are identified in TAB G.)

- (7) Subject to submergence (Yes/No/NA)? No (Reference: See TAB C)

Identify initiation time and duration of submergence: N/A

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: Only ~~only~~ the Group B valves are subject to a Beta contribution.)

CAJ
5/18/90
If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: The total accident dose of 1.2×10^4 RADS includes a Beta dose contribution of 6×10^3 RADS per TVA environmental drawing 47E235-44.

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B, Section A for a listing of all calculations used in this binder.

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 21 OF 27R 1 R 2BINDER TITLE ASCO SOLENOID VALVES COMPUTED RCF DATE 8/28/86 ADM CRF
MODEL 206-380 SERIES 2/17/89 5/18/90(AC CONSTRUCTION) _____ CHECKED WBK DATE 8/28/86 EEH ADM
2/23/89 5/21/90L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

Parameter	Specified	Demonstrated	Reference
Operating Time	¹ <u>100 days</u> <u>200 @ 11</u>	<u>30 days</u>	Fig. 4.1, pg. 25 of (1)
Temperature (°F)	<u>minutes</u>	<u>448</u>	Fig. 4.1, pg. 25 of (1)
Pressure (psig)	<u>-0-</u>	<u>68 psig</u>	Fig. 4.1, pg. 25 of (1)
Relative Humidity (%)	² <u>100</u>	<u>100</u>	Fig. 4.1, pg. 25 of (1)
Chemical Spray*	³ <u>N/A</u>	<u>pH 10.5</u> <u>(22 hours)</u> <u>2.05x10⁸ gamma</u>	App. A, pg. A20 A21 of (1) App. D of (1) & IN
Radiation (rd)**	<u>1X10⁸ RADS</u>	⁴ <u>2x10⁷ gamma</u>	85-08 TAB J
Submergence	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

- 1 - At 30 days the temperature returns to maximum normal.
- 2 - At 24 hours the humidity returns to maximum normal.
- 3 - Valves are not subject to containment spray.
- 4 - Valves containing Viton elastomers are only qualified to a maximum of 2x10⁷ rads, gamma. See TAB C.

(2) Comparison of worst-case profiles and margin assessment:

Parameter	Test Profile Envelopes Specified (Yes/No/NA)	Reference
Temperature	<u>Yes</u>	<u>See TAB C</u>
Pressure	<u>Yes</u>	<u>See TAB C</u>
Relative Humidity	<u>Yes</u>	<u>See TAB C</u>
Chemical Spray	<u>N/A</u>	<u>See TAB C</u>
Submergence	<u>N/A</u>	<u>See TAB C</u>

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 22 OF 27
 BINDER TITLE ASCO SOLENOID COMPUTED RIF DATE 9/28/86 R 2 R 2
 VALVES, MODEL NO. 206-380-SERIES (AC CONSTRUCTION) CHECKED WTK DATE 8/28/86 5/18/90 ADM 5/21/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	15°F	Yes
Pressure: +10% but no more than 10 psig	68 psig	Yes
Radiation: +10% of accident dose	1.05×10^8 RADS	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	SEE EQUIV. CALCS. IN TAB C	Yes-See Generic Binder WBNEQ-GEN-001 Sec. III.C.4
Voltage: $\pm 10\%$ of rated value	+10% -15%	Yes
Frequency: $\pm 5\%$ of rated value	None	Yes
Environmental Transient: the initial transient and the peak temperature applied twice	See TAB. C for description of test	Yes
Vibration: +10% added to acceleration		Yes

JUSTIFICATION/COMMENTS: See TAB C for detailed information on margins as they apply to the TVA valves. TVA Calculation

WBN-EEB-MS-TIOG-0017 documents a degraded voltage condition which has the highest probability of occurrence. Thus, qualification is better substantiated by proving operability under a degraded voltage condition.

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 23 OF 27
BINDER TITLE ASCO SOLENOID COMPUTED RCE DATE 8/28/86 R 2 R 5/18/90
VALVES, MODEL NO. 206-380-SERIES CHECKED WAK DATE 8/28/86 ARM
(AC CONSTRUCTION) 5/21/90

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference See TAB A).

JUSTIFICATION/COMMENTS FUNCTIONS ARE VARIED. ALL ARE LISTED IN TAB A.

R2

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes (Ref. TBL 5.1, p.59; App. J, p. 30 OF (1)).

R2

JUSTIFICATION/COMMENTS The test valve was assumed to be normally energized and required to de-energize on receipt of accident signal, then to remain operable for 30 days post-DBA. The specific DBA functions of the TVA valves are described in TAB. C.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? YES (Ref. 4.2.3, App. J OF (1)).

JUSTIFICATION/COMMENTS _____

R2

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? YES (Reference TBL 5.1, p.59; App. J, TBL 1 OF (1)).

R2

JUSTIFICATION/COMMENTS See TAB C for the analysis of the test DBA versus the plant specific DBA. However, the test valve did demonstrate operability in accordance with the requirements defined in M(2) above.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Reference Sections 5.2 and 5.3, pgs. 56 and 57 of (1) and page 31 of (1)).

R2

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 24 OF 27

BINDER TITLE ASCO SOLENOID COMPUTED RF DATE 8/27/86 R R
VALVES, MODEL NO. 206-380-SERIES
(AC. CONSTRUCTION) CHECKED WVK DATE 8/27/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See TABS C and G

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 25 OF 27
BINDER TITLE ASCO SOLENOID COMPUTED RF DATE 8/28/86 R R
VALVES, MODEL NO. 206-380-SERIES CHECKED WHR DATE 8/28/86
(AC CONSTRUCTION)

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>N/A</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>N/A</u>
(b) Were specific features and failure modes and effects analyzed?	<u>N/A</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>N/A</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>N/A</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>N/A</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

PAGE B-25

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 26 OF 27

BINDER TITLE ASCO SOLENOID
VALVES, MODEL NO. 206-380-SERIES
(AC CONSTRUCTION)

COMPUTED [Signature]

DATE 5/27/86

R 2 R

CHECKED [Signature]

DATE 5/27/86

5/18/90
AM
5/21/90

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>N/A</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>N/A</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>N/A</u>
(11) Criteria regarding submergence satisfied?	<u>YES</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

R2

PAGE B-26 R2

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 27 OF 27
BINDER TITLE ASCO SOLENOID COMPUTED RF DATE 8/27/86 R R
VALVES, MODEL NO. 206-380-SERIES (AC CONSTRUCTION) CHECKED WAK DATE 8/27/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>N/A</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>N/A</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

The TVA valves as listed in this report are fully qualified to the requirements of NUREG 0588 Cat. I (IEEE 323-1974) and 10CFR50.49.
TAB C provides a detailed analysis to support this claim.

PAGE B-27

BINDER NO. WBNEQ-SOL-006 PLANT WRN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE ASCO SOLENOID VALVES - COMPUTED EEM DATE 7/24/86
MODEL NP 8316 SERIES CHECKED WHR DATE 7/16/86

TAB A
EQUIPMENT IDENTIFICATION MATRIX

SOL-006

PRINT DATE: 14/90

BINDER NO. : WBNEQ-SOL -U
MANUFACTURER : ASCO
PAGE 1 OF 6

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -061-0097 -B INLET ISLN VLV REACTOR BLDG	1-FSV -061-0097 -B NPX831654E	300	772' 1" UC 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE TO CLOSE ASSOC FCV ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -061-0122 -B OUTLET ISLN VLV REACTOR BLDG	1-FSV -061-0122 -B NPX831654E	300	776' 5" UC 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE TO CLOSE ASSOC FCV ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -061-0192 -B GYLCOL SUPPLY ISOLATION VALVE	1-FSV -061-0192 -B NPX831654E	300	807' 10" UC 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE TO CLOSE ASSOC FCV ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSO LIMIT SWS.
WBN-1-FSV -061-0194 -B GYLCOL RETURN ISOLATION VALVE	1-FSV -061-0194 -B NPX831654E	300	808' UC 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE TO CLOSE ASSOC FCV ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSO LIMIT SWS.
WBN-1-FSV -062-0069 -A RC LOOP 3 LETDOWN FLOW	1-FSV -062-0069 -A NPX831654E	132	728' 4" LC 80KJ3-827551		A/B 1HR/1MO	CV/C		THE CLOSING OF THIS VLV IS NECESSARY TO ISOLATE A BREAK IN THE CVCS LETDOWN LINE INSIDE CONTAINMENT.

PAGE A-2

R4

PREPARER/DATE

EEM 7/30/86

CHECKED/DATE

WBK 7/30/86

R 1

JDA

5/17/89

KBA

3/2/89

R 4

JDA

5/18/90

JDA

9/24/90

R

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. : WBNEQ-SOL
MANUFACTURER : ASCO
PAGE 2 OF 6

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
✓ WBN-1-FSV -062-0070 RC LOOP 3 LETDOWN FLOW	-A 1-FSV -062-0070 NPX831654E	-A 133	723' 9"	AC2 80KJ3-827551	A/B	1HR/1MO	CV/C	THE CLOSING OF THIS VLV IS NECESSARY TO ISOLATE A BREAK IN THE CVCS LETDOWN LINE INSIDE CONTAINMENT.
✓ WBN-1-FSV -062-0072 REGEN HTX LTDN ISLN VALVE A	-A 1-FSV -062-0072 NPX831654E	-A 042	703' 1"	RW 80KJ3-827551	A/B A/B A/B A/B	5MN/100D 5MN/100D 5MN/100D 15MN/1MO	L MS/C FW/C RH/C	MUST DEENERGIZE TO CLOSE ASSOC FCV'S ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS. R3
✓ WBN-1-FSV -062-0073 REGEN HTX LTDN ISLN VALVE B	-A 1-FSV -062-0073 NPX831654E	-A 052	703' 7"	RW 80KJ3-827551	A/B A/B A/B A/B	5MN/100D 5MN/100D 5MN/100D 15MN/1MO	L MS/C FW/C RH/C	MUST DEENERGIZE TO CLOSE ASSOC FCV'S ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS. R3
✓ WBN-1-FSV -062-0074 REGEN HTX LTDN ISLN VALVE C	-A 1-FSV -062-0074 NPX831654E	-A 052	704' 8"	RW 80KJ3-827551	A/B A/B A/B A/B	5MN/100D 5MN/100D 5MN/100D 15MN/1MO	L MS/C FW/C RH/C	MUST DEENERGIZE TO CLOSE ASSOC FCV'S ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS. R3
✓ WBN-1-FSV -062-0076 REGEN HTX LTDN ISLN VALVE	-A 1-FSV -062-0076 NPX831654E	-A 052	707' 1"	RW 80KJ3-827551	A/B A/B A/B A/B	5MN/100D 5MN/100D 5MN/100D 15MN/1MO	L MS/C FW/C RH/C	MUST DEENERGIZE TO CLOSE ASSOC FCV'S ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS. R3

PAGE A-3 R3

PREPARER/DATE EEM 9/19/86
CHECKED/DATE WBK 9/19/86

R 1
JDA
3/17/89

R 3
JDA
5/18/90

R
JDA
3/21/89

PRINT DATE 14/90

BINDER NO. : WBNEQ-SOL -
MANUFACTURER : ASCO
PAGE 3 OF 6

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	AZMITH	LOCATION	ELEV(1)	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION	MODEL NUMBER			CONTRACT		(2)			
WBN-1-FSV -062-0077 -B LETDOWN LINE ISOLATION VALVE	1-FSV -062-0077 -B NP8316		713'	A28'		A/B 5MN/100D B 1 MO A/B 15MN/1MO B 1 MO B 1 MO	L RH/A CV/A AF AB		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH PHASE A CONT ISO SIG PRESNT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -063-0023 -B SIS ACCUM FILL LINE ISLN SW	1-FSV -063-0023 -B NP831654E		713'	A28	84KK1-835541	A/B 5MN/100D B 1 MO B 1 MO B 1 MO B 1 MO	L RH/A CV/A AF AB		MUST DEENERGIZE TO CLOSE FCV IF OPEN AND NOT FAIL IN THE ENERGIZED POS. MUST NOT FAIL IN MANNER TO PREVENT PAM FUNCT OF ASSO LIMIT SWITCHES.
WBN-1-FSV -063-0064 -A SIS ACCUM TANK NO 2 HDR INLET VLV	1-FSV -063-0064 -A NP831654E		713'	A28	84KK1-835541	A/B 5MN/100D B 1 MO B 1 MO B 1 MO B 1 MO	L RH/A CV/A AF AB		MUST DEENERGIZE TO CLOSE FCV IF OPEN AND NOT FAIL IN THE ENERGIZED POS. MUST NOT FAIL IN MANNER TO PREVENT PAM FUNCT OF ASSOC LIMIT SWITCHES.
WBN-1-FSV -063-0071 -A SIS CHECK VLV LEAK TEST ISLN VALVE	1-FSV -063-0071 -A 290 NPX831654E		724' 1"	AC4	80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DEENERGIZE AND REMAIN TO PREVENT VLV OPENING WITH PHASE A CONT ISO SIG PRESNT & RESET. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -063-0084 -B SIS CHECK VLV LEAK TEST ISLN VALVE	1-FSV -063-0084 -B NP831654E		713'	A28	84KK1-835541	A/B 5MN/100D B 1 MO B 1 MO B 1 MO B 1 MO	L RH/A CV/A AF AB		MUST DEENERGIZE TO CLOSE FCV IF OPEN AND NOT FAIL IN THE ENERGIZED POS. MUST NOT FAIL IN MANNER TO PREVENT PAM FUNCT OF ASSOC LIMIT SWITCHES.

PAGE A-4

R4

PREPARER/DATE EEM 9/19/86

CHECKED/DATE WBK 9/19/86

R 1 JDH 3/17/89	R 3 CDH 5/18/90	R 4 JDT 9/18/90
RBN 3/24/89	AFM 5/18/90	AFM 9/24/90

PRINT DATE 14/90

BINDER NO. : WBNEQ-SOL
MANUFACTURER : ASCO
PAGE 4 OF 6

WATTS BAR NUCLEAR PLANT TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-PSV -065-0081 SHLD BLDG VENT AND CONT ANNLS ISLN VLV	-A 1-PSV -065-0081 NP831654E	-A 001	832'10" ANN 84KK1-835541	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE WHENEVER NEEDED TO HELP REGULATE ANNULUS PRESSURE.
WBN-1-PSV -065-0083 SHLD BLDG VENT AND CONT ANNLS ISLN VLV	-B 1-PSV -065-0083 NP831654E	-B 360	830'9" ANN 84KK1-835541	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MUST OPERATE WHENEVER NEEDED TO HELP REGULATE ANNULUS PRESSURE.
WBN-1-FSV -068-0305 RCS FLOW CNTL VLV WDS N2 MAN TO PRT	-A 1-FSV -068-0305 NP831654E	-A	713' A28 84KK1-835541	A/B B B B B	5MN/100D 1MO 1MO 1MO 1MO	L AB AF CV/A RH/A	MUST DEENERGIZE TO CLOSE ASSOC FCV ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -068-0308 RCS FLOW CNTL VLV WDS GA TO PRT	-B 1-FSV -068-0308 NPX831654E	-B 318	723'11" AC4 80KJ3-827551	A/B A/B A/B A/B A/B	5MN/100D 5MN/100D 5MN/100D 15MN/1MO 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE TO CLOSE ASSOC FCV ON CONT ISO SIG & REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -077-0009 RCDT PMP DISCH FLOW CONTROL VALVE	-B 1-FSV -077-0009 NPX831654E	-B 279	725' 3" AC4 80KJ3-827551	A/B A/B A/B A/B A/B	5MN/100D 5MN/100D 5MN/100D 15MN/1MO 1HR/1MO	L MS/C FW/C RH/C CV/C	MUST DEENERGIZE TO CLOSE ASSOC ISOL VLV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.

PAGE A-5

R4

PREPARER/DATE EEM 9/19/86

CHECKED/DATE WBK 9/19/86

R 1
JDH
3/19/89
RBN
3/21/89
R 4
CMT
9/18/90
R
CMT
9/24/90

PRINT DATE: 4/90

BINDER NO. : WBNEQ-SOL -
MANUFACTURER : ASCO
PAGE 5 OF 6

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -077-0010 RCDT PMP DISCH FLOW CONTROL VALVE	-A 1-FSV -077-0010 NP831654E	-A	713'	A28 84KK1-835541	B 1MO B 1MO B 1MO B 1MO A/B 5MN/100D		RH/A CV/A AF AB L	MUST DEENERGIZE TO CLOSE ASSOC ISOL VLV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -077-0016 RCDT TO GAS ANALYZER FLOW SOL VALVE	-B 1-FSV -077-0016 NPX831654E	-B 285	718' 9"	AC4 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO		L MS/C FW/C RH/C CV/C	MUST DEENERGIZE TO CLOSE ASSOC ISOL VLV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -077-0017 RCDT TO GAS ANALYZER FLOW CONTROL VALVE	-A 1-FSV -077-0017 NP831654E	-A	713'	A28 84KK1-835541	A/B 5MN/100D B 1MO B 1MO B 1MO B 1MO		L CV/A RH/A AB AF	MUST DEENERGIZE TO CLOSE ASSOC ISOL VLV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -077-0018 RCDT TO VENT HDR FLOW CONTROL VALVE	-B 1-FSV -077-0018 NPX831654E	-B 283	725' 4"	AC4 80KJ3-827551	A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO		L MS/C FW/C RH/C CV/C	MUST DEENERGIZE TO CLOSE ASSOC ISOL VLV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -077-0019 RCDT TO VENT HDR FLOW CONTROL VALVE	-A 1-FSV -077-0019 NP831654E	-A	713'	A28 84KK1-835541	B 1MO B 1MO B 1MO B 1MO A/B 5MN/100D		RH/A CV/A AF AB L	MUST DEENERGIZE TO CLOSE ASSOC ISOL VLV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.

PAGE A-6

R4

PREPARER/DATE

EEM 9/19/86

CHECKED/DATE

WBK 9/19/86

R 1
JDH
3/17/89
KBN
3/21/89

R 4
CAR
9/12/90
qom
9/24/90

R

R4

PRINT DATE 11/14/90

BINDER NO. : WBNEQ-SOL
MANUFACTURER : ASCO
PAGE 6 OF 6

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FSV -077-0020 -A RCDT N2 SUPPLY FLOW CONTROL VALVE	1-FSV -077-0020 -A NP831654E		713' 84KK1-835541	A28	B 1MO B 1MO B 1MO B 1MO A/B 5MN/100D		RH/A CV/A AF AB L	MUST DEENERGIZE TO CLOSE ASSOC ISOL VLV AND REMAIN CLOSED TO PREVENT REOPENING. MUST NOT FAIL SO AS TO PREVENT PAM FUNCT OF ASSOC LIMIT SWS.
WBN-1-FSV -081-0012 -A PW RCS PRESS RELIEF TK & RCP STAND PIPES	1-FSV -081-0012 -A NP831654E		713' 84KK1-835541	A28	A/B 5MN/100D	L		MUST DE-ENERGIZE TO CLOSE THE ISOLATION VALVES AND REMAIN IN THAT POSITION
WBN-1-FSV -087-0007 -A TEST LINE ISOLATION VALVE FLOW CONTROL	1-FSV -087-0007 -A 222 NPX831654E		708' 5" RW 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED.
WBN-1-FSV -087-0008 -A TEST LINE ISOLATION VALVE FLOW CONTROL	1-FSV -087-0008 -A 222 NPX831654E		706' 8" RW 80KJ3-827551		A/B 5MN/100D A/B 5MN/100D A/B 5MN/100D A/B 15MN/1MO A/B 1HR/1MO	L MS/C FW/C RH/C CV/C		MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED.

PAGE A-7

R4

PREPARER/DATE

EEM 9/19/86

CHECKED/DATE

WBK 9/19/86

R 1
JDA
3/17/89
KBN
3/21/89

R 4
JDA
9/12/90
JDM
9/24/90

R
R
R

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE ASCO SOLENOID COMPUTED /R1 JDH DATE 3/13/89
VALVES MODEL NP8316 SERIES CHECKED /R1 KBN DATE 3/2/89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-3 for source of Category and Operating Time assignments.
3. Contract numbers shown in this TAB were obtained by tracing the serial number on each valve through TVA procurement records and did not depend on field verification data for contract numbers.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEM DATE 7/14/86 R R
MODEL NP8316 SERIES CHECKED WJR DATE 7/16/86

TAB B

ENVIRONMENTAL QUALIFICATION CHECKLIST

PAGE B-1

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1 OF 33
R 1 R 2
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/19/86 JDH 3/13/89 3/22/90
VALVES MODEL NP8316 SERIES CHECKED WBK/HDR DATE 9/19/86 KBN 3/21/89 3/22/90

A. DOCUMENTATION (See Note on Page B-4)

Equipment Description Solenoid Valves
Vendor/Manufacturer ASCO
Equipment Model No.(s) NPX831654E
NP831654E

QUALIFICATION REPORTS (TAB D)(See also TAB C "Discussion" on
Page C-3) (See Note on Page B-4)

R2

- (1) Title/Number/Revision Automatic Switch RIMS B43 850627 322
Company Test Report No.
AQS21678/TR/Rev A DATE July 1979
- (2) Title/Number/Revision ASCO Catalog NP-1 RIMS NEB 840328 363
valves/AQS21678/TR/Supplement 3 DATE March 8, 1983
- (3) Title/Number/Revision Automatic Switch RIMS B45 850514 428
Company Test Report No.
AQR-67368, Rev 1 DATE August 19, 1983
- (4) Title/Number/Revision Franklin Research RIMS NEB 840925 351
Center Test Report
F-CS569-309/315, Appendix C DATE November 1983
- (5) Title/Number/Revision "Aging and RIMS B74 890623 502
Qualification Research on Solenoid DATE August 1988
Operated Valves," NUREG/CR-5141 RV
- (6) Title/Number/Revision "ASCO Engineering RIMS B25 870612 003 R2
Report No. 177" DATE Dec. 11, 1979

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (7) ASCO Letter dated April 29, 1985 (B43 850502 015) NP Valve
Mounting Orientation (TAB E-7).

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1a OF 33
 R 3 R 4
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/19/86 CDH 287
 5/18/90 9/18/90
 VALVES MODEL NP8316 SERIES CHECKED WBK/HDR DATE 9/19/86 AFM 87M
 5/18/90 9/21/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

<u>Type</u>	<u>RIMS No.</u>
Category and Operating Times	
(8) System 61 (WBNO SG4-012 R5)	B18 900531 252 R4
(9) System 62 (WBNO SG4-013 R12) ¹⁵	B26 900 ⁰⁸²⁹ 227 ²⁰² 290
(10) System 63 (WBNO SG4-014 R11)	B26 900309 227
(11) System 65 (WBNO SG4-015 R10)	B26 900309 226
(12) System 68 (WBNO SG4-017 R11)	B18 900612 252 R4
(13) System 77 (WBNO SG4-021 R5)	B18 900612 251
(14) System 81 (WBNO SG4-023 R3)	B45 851127 219
(15) System 87 (WBNO SG4-025 R3)	B45 860313 218
(16) Status and Duty Cycles of IE Solenoid Valves Located in Potentially Harsh Environments (WBN-OSG4-045 R1)	B45 860902 219
(17) Solenoid Valve Voltage Study (WBNEEB-MS-TI11-0004)	B26 900202 407
(18) Wyle Laboratories Test Report No. 17523-1	EEB 840731 501

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1b OF 33
 R 2 R 4
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/20/86 CDH CDH
 03/22/90 9/18/90
 VALVES MODEL NP8316 SERIES CHECKED WBK/HDR DATE 9/20/86 AFM AFM
 03/23/90 9/24/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

<u>Type</u>	<u>RIMS No.</u>	
(19) Integrated Accident Dose Inside Containment (TI-RPS-48 R2)	B45 851105 235	
(20) Deleted by Revision 2		
(21) Reduction of Beta Dose by Sheet Steel (WBNTSR-051 R0)	B26 891129 202	
(22) Flooding Level Outside the Crane Wall Following Main Feedwater (MFW) and Main Steamline Break (MSLB) (WBNNAL6-005 R0)	B45 860520 235	
(23) TVA Environmental Drawing 47E235-41 R1 and DCA-P04104-01-0 per DCN P-04104-C (B26 890908 819)		
(24) TVA Environmental Drawing 47E235-42 R2 and DCA-P04104-03-0 and DCA-P04104-05-0 per DCN P-04104-C (B26 890908 819)		
(25) TVA Environmental Drawing 47E235-44 R1		
(26) TVA Environmental Drawing 47E235-61 R1		
(27) Deleted by Revision 4.		R4
(28) QIR MNMWBN90099 R0, Flooding of CVCS Letdown Line Valves 1, 2-FCV-62-72, -73, -74 & -76.	B26 900720 259	R4

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 2 OF 33
R 3 R 4
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/19/86 CDH CDH
5/18/90 9/18/90
VALVES MODEL NP8316 SERIES NP8316 CHECKED WBK/HDR DATE 9/19/86 AFM AFM
5/18/90 9/24/90

B. CONCLUSION OF REVIEW (Check only one block)

 X Equipment Qualified

Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule

 Equipment Qualification Not Established by Documentation

 Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

- 1) Nameplate data not available for 1-FSV-62-77-B.

- 2) Deleted by revision 2.

- 3) Deleted by revision 2.

- 4) Deleted by revision 2.

- 5) Deleted by revision 2.

- 6) Deleted by revision 2.

- 7) Remove valves 1-FSV-087-7, -8 from TAB A upon completion of

ECN 6429.

- 8) Valves requiring conduit seals to comply with Reg. Guide 1.97

(PAM).

COMMENTS/RECOMMENDATIONS

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 3 OF 33
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEH DATE 7/12/86
 MODEL NP8316 SERIES CHECKED WAK DATE 7/16/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- | | |
|---------------|---|
| <u>X</u> | Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974) |
| <u> </u> | Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN) |

JUSTIFICATION/ COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET:

IEEE 323-1974 IEEE Standard for Qualifying Class IE Equipment for Nuclear Power Generating Stations.

IEEE 382-1972 IEEE Trial-Use Guide for Type Test of Class I Electric Valve Operators for Nuclear Power Generating Stations.

IEEE 382 (Draft 3, Rev. 1, June 1977) Draft American National Standard
for the Qualfication of Safety-Related Valve Actuators.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 4 OF 33
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEH DATE 7/14/86 R R
MODEL NP8316 SERIES CHECKED WBR DATE 7/16/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- X Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS See "Similarity Table", page 6

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 5 OF 33
 R 2 R 2
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEM DATE 7/14/86 3/22/90
 MODEL NP8316 SERIES _____ CHECKED WMK DATE 7/16/86 3/23/90

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (Yes/No/NA)? NO

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Vlv</u>	<u>Solenoid Vlv</u>	
(2) Manufacturer	<u>ASCO</u>	<u>ASCO</u>	
(3) Model Number(s)	<u>NPX831654E</u>	<u>NP 831665E</u>	Ref (1) Section 2 Table 1
	<u>NP 831654E</u>		
		<u>NP 832070E (coil only)</u>	Ref (3) Appendix I
(4) Serial Number(s)	<u>See TAB F</u>	<u>6</u>	Ref (1) Section 2 Table 1
		<u>2</u>	Ref (3) Section 3 Table 3.2
(5) Identify Component- <u>NONE</u>			
Unique checksheet attached:			

ASCO SOLENOID VALVES

MODEL NP8316 SERIES

SIMILARITY TABLE

Specification	ASCO Test Valve Model No. NP831665E	TVA Valve Model No. NPX831654E	TVA Valve Model No. NP831654E
Description	Three-way direct acting solenoid valve with packless const	Same	Same
Application	Pilot Vlv Controlling Oil Free Instr Air	Same	Same
Form of Flow	Normally Closed	Same	Same
Pipe Size	3/8"	3/8"	3/8"
Orifice Size	5/8"	5/8"	5/8"
Body Material	Brass	Brass	Brass
Coil Class	H	H	H
Seat & Disc Material	Ethylene Propylene	Ethylene Propylene	Ethylene Propylene
Disc Holder Material	303 Stainless Steel	303 Stainless Steel	303 Stainless Steel
Core Tube Material	300 Series Stainless Steel	300 Series Stainless Steel	300 Series Stainless Steel
Core Material	400 Series Stainless Steel	400 Series Stainless Steel	400 Series Stainless Steel
Coil Enclosure	NEMA 4,7,9	NEMA 6	NEMA 6
Maximum Operating Pressure			
Differential	175 psi	175 psi	175 psi
Nominal Voltage	125V DC	125V DC	125V DC
Power Rating	17.4 Watts	17.4 Watts	17.4 Watts
Conduit Connection	3/4" NPT	1/2" NPT	3/4" NPT
Applicable Form Number	V5967	V5967R1	V5967 R1
Terminal Connection	Pigtails (Splice)	Pigtails (Splice)	Pigtails (Splice)
Ambient Temperature	32 - 140°F	120°F - as specified	120°F - as specified
Maximum Fluid Temperature	180°F based on 140°F Ambient	Same	Same
Safe Working Pressure	300 psig	Same	Same

Notes: From Test Report
AQ8-21678 TR/Rev A (TAB D-1)
Form V5967 (TAB D-1) & ASCO
Cat. NP-1 (TAB E-5)

Notes: From Contract 827551,
(TAB E-1). Form V5967 R1
(TAB H) & ASCO Cat. NP-1
(TAB E-5). "X" in Model
Number denotes 1/2" NPT
conduit connection.

Notes: From Contract 835541 (TAB E-3)
Form V5967 R1 (TAB H) & ASCO Cat.
NP-1 (TAB E-5)

Preparer/Date	<u>E. E. M. Doe</u>	<u>7/14/86</u>	<u>R</u>	<u>R</u>	<u>R</u>
Checked/Date	<u>W. P. H. Doe</u>	<u>7/16/86</u>			

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 7 OF 33
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/14/86 JDH
3/13/89
 VALVES MODEL NP8316 SERIES CHECKED WBK DATE 7/16/86 KBW
3/21/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	None Specified, See TAB C-1, "Interfaces" For Typical Discussion, TABS C-2 through C-4 Identical	No	
External Process Connections	See TAB C-1 through C-4	Yes	See Below and Ref (3) App. A. Pg A2
Electrical Connections	None specified, See TAB C-1, "Interfaces" For Typical Discussion, TAB C-2 through C-4 Identical	Yes	
Conduit Seals	See TAB C-1 through C-4 "Conduit Seals"	No	Ref (3) Section 5.3
Connector Seals	N/A	N/A	
Orientation	Any orientation	N/A	See Note Below
Physical Configuration	Conduit/junction box must be orientated such that moisture does not drain into coil housing	No	Ref (3) Sec. 5.3 & P-1 this TAB
Other	NONE		

NOTE: See ASCO letter in TAB E-7.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 7a OF 33
R 2 R
BINDER TITLE ASCO SOLENOID COMPUTED R1 JDH DATE 3/13/89 CM
3/22/90
VALVES MODEL NP8316 SERIES CHECKED R1 KBN DATE 3/21/89 COM
3/23/90

F. INSTALLATION INTERFACES (Continued)

JUSTIFICATION/COMMENTS ASCO does not identify specific inter-
facing requirements except as follows: (1) ASCO requires a 90°
street elbow facing downward connected to exhaust port or similar
configuration to prevent moisture intrusion from liquid spray.
This is required only on valves located inside containment and
subject to containment spray (See TAB C-7). (2) Flowing Medium | R2
must be oil-free instrument air and a strainer or filter must be
installed on the inlet as close to the valve as possible. See
TAB C for a description of the TVA interfaces and TAB J-2 for
disucssion of TVA instrument air system.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 8 OF 33
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/14/86 JDH
3/13/89
 VALVES MODEL NP8316 SERIES CHECKED WBK DATE 7/16/86 KAN
3/21/89

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (Yes/No/NA)? (Note below.)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	Ref (3) p 8 & Ref (1) App. A, Sec. 9.4.2.1
(b) Baseline performance measurements taken	<u>Yes</u>	Ref (3) p 8 & Ref (1) App. A, Sec. 9.4.2.2
(c) Equipment aged: Thermal	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.3.1 & Ref (3), p 8
Radiation	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.3.2 & Ref (3), App D
Wear	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.3.3 & Ref (3), p 12
(d) Vibration/seismic testing conducted	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.4 & Ref (3), p 15
(e) Design basis event (DBE) exposure	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.4 & Ref (3), p 15
(f) Post-DBE exposure	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.4 & Ref (3), p 23
(g) Final inspection and disassembly	<u>Yes</u>	Ref (1), App. A, Sec. 9.4.3 & Ref (3), p 24

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately document (Yes/No/NA)? Yes
 (Reference: Ref (1), App. C., Ref (3), Appendix G).

JUSTIFICATION/COMMENTS AQR-67368. was utilized to qualify the | R1
Class H coils. Reference to this report is in regard to coil
qualification only unless otherwise noted.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 9 OF 33
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/14/86 3/22/90
 VALVES MODEL NP8316 SERIES CHEKED WBK DATE 7/16/86 3/23/90

H. AGING

- (1) Was aging considered in the qualification program
 (Yes/No/NA)? Yes (Reference: Ref (1) Sec. 4.2, App. A.
Sec. 9.4.2.3 & Ref (3) Sec. 4.1, App. A, Section 9.4).

JUSTIFICATION/COMMENTS See TAB C-1 Thru C-4

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Ref (1), App. A</u> <u>Section</u> <u>9.4.2.3.1</u>
Radiation exposure	<u>Yes</u>	<u>Section</u> <u>9.4.2.3.2</u>
Vibration (nonseismic) aging	<u>Yes</u>	<u>Section</u> <u>9.4.2.3.4</u>
Operational (electrical/mechanical/ process) stress aging	<u>Yes</u>	<u>9.4.2.3.3</u>

JUSTIFICATION/COMMENTS See Reference (3), App. A, Section
9.4. Also, thermal aging was done using nitrogen as the
process fluid in lieu of instrument air (see TAB C-8).

R2

- (3) Were all known synergistic effects which are believed to have a
 significant effect on equipment performance considered in the
 aging program (Yes/No/NA)? Yes (Reference: NA).

JUSTIFICATION/COMMENTS See Discussion, Section P-4.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
 (Yes/No/NA)? Yes (Reference: Ref (1) App. A.
Section 9.4.2.3.1, Ref (3) App. A, Section 9.4.1).

JUSTIFICATION/COMMENTS See TAB C-1 Thru C-4 "Aging."

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 10 OF 33

BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEM DATE 7/14/86 R R

MODEL NP8316 SERIES CHECKED WBR DATE 7/16/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference: Ref (2) Sections 1-6).

JUSTIFICATION/COMMENTS

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Ref (2) Sections 1-6).

JUSTIFICATION/COMMENTS

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Ref (1) App. A Section 9.4.2.3.1 & Ref. 3, App. A, Section 9.4.1).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>*</u>	<u>*</u>	<u>*</u>
Time	<u> </u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS *See TAB C-1 through C-4, "Aging".

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Ref (2) Section 6).

JUSTIFICATION/COMMENTS

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference Ref (2), Section 4).

MODEL NP8316 SERIES

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 12 OF 33
R 1 R _____
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/14/86 JDH
3/13/89
VALVES MODEL NP8316 SERIES _____ CHECKED WBK DATE 7/16/86 HBN
3/21/89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: Ref (1) Section 4.3, App. D Ref (3) App. D).

Plant normal ambient radiation dose (rd)	Various - See <u>TABS C-1 through C-4</u>
	<u>5×10^7 - Aging</u>
Test exposure dose (rd)	<u>1.5×10^8 - Accident</u>
	<u>5.1×10^5 for 99 hours</u>
	<u>8.0×10^5 for 188.5 hrs</u>
Test exposure dose rate (rd/hr)	<u>accident</u>
Test exposure source type (e.g., Co-60 gamma)	<u>Co-60 gamma</u>

JUSTIFICATION/COMMENTS _____

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ (Yes/No/NA)? Yes (Reference: Ref (1), Section 4.5, Ref (3), Section 4.1.5) | R1

JUSTIFICATION/COMMENTS _____

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Ref (1) App. A Section 8.1.6, Ref (3), App. A, Sec. 9.4.5).

JUSTIFICATION/COMMENTS _____

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: (1) Section 4.4, Ref (3) Section 4.1.2).

JUSTIFICATION/COMMENTS _____

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Ref (1) App. A Section 7.1 & 5.2, Ref (3), App. A, Section 9.4.2).

JUSTIFICATION/COMMENTS

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: Ref (2), Section 6 Ref (1), Section 3.2.2,
Ref (3), Appendix C, p. C-8)

Qualified life (Document in QMDS) See TABS C and G

JUSTIFICATION/COMMENTS The qualified life is different, in most cases, from the value given in the test report. TAB C, page C-3, provides rationale.

R2

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: Ref (2) Section 8)

JUSTIFICATION/COMMENTS Replacement interval depends upon
maximum normal ambient temperature and percentage time
solenoid valve is energized.

R2

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 14 OF 33
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/14/86 3/21/90
 VALVES MODEL NP8316 SERIES CHECKED WBK DATE 7/16/86 3/23/90

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

<u>Material/Property/Function</u>	<u>Radiation</u>		<u>Activation</u>	
	<u>Threshold</u>	<u>Reference</u>	<u>Energy</u>	<u>Reference</u>
(a) EPDM	1 x 10 ⁷	See TAB E6	0.94	Ref (2) Sec. 4.1.1
(b) VITON	5 x 10 ⁶	See TAB E6	1.04	Ref (2) Sec. 4.1.2
(c) NOMEX	7 x 10 ⁶	See TAB E6	0.96	Ref (2) Sec. 4.1.3
(d) MAGNET-WIRE ENAMEL	1 x 10 ⁷	See TAB E6	1.16	Ref (2) Sec. 4.2.1
(e) ISO-MICA W/EPOXY	1 x 10 ⁹	See TAB E6	1.00	Ref (2) Sec. 4.2.6
(f) SILICONE RUBBER LEAD WIRE INSULATION	1 x 10 ⁶	See TAB E6	1.59	Ref (2) Sec. 4.2.5
* (g) DC 550 LUBRICANT	NA	NA	NA	NA R2

JUSTIFICATION/COMMENTS The above materials are those with lowest
activation energies listed in reference (2), Section 4.1, and 4.2.
Radiation threshold values are typical for these materials and are
listed for information only. These values were not taken from the
test report, but were supplied by the Digital Engineering System
1000, Materials Data Base (see TAB E6).

*Although not stated in reference (2), DC 550 lubricant was used on
tested valves as verified by ASCO letter dated January 5, 1988 (see
TAB E-12). R2

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 15 OF 33
BINDER TITLE ASCO SOLENOID VALVES COMPUTED CEM DATE 7/24/86 R R
MODEL NP8316 SERIES CHECKED WPK DATE 7/16/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Ref (1), App. A, Sec.6.1 & 6.2).

Identify Acceptance Criteria: Valves must operate from 90-140VDC at minimum and maximum operating pressure differential. Coil insulation resistance must be a minimum of 1.0 megohm at 500VDC. During Hypot test, current leakage must be less than 0.5 milliamp at twice the rated voltage plus 1000VAC applied for a period of one minute. Valves must operate at test or low voltage condition (90VDC) at maximum pressure differential under all conditions. Valves are not to have a pressure build-up at a vented cylinder port or a pressure decrease at a cylinder port which is required to be pressurized in excess of 10% the nominal inlet supply pressure under all postulated environmental conditions.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Ref (1) Section 4.1).

Identify baseline and functional testing: Recording coil excitation seat leakage, noise test, operational test, external leakage in energized and de-energized state before and after thermal, radiation, wear and vibration aging, and accident radiation and LOCA simulation. Measurement of insulation resistance & coil dielectric tests before thermal aging & after completion of accident radiation and LOCA simulation.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Ref (1) Appendix A, Section 7.0).
- (4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Ref (1), Section 4.8 & Ref (3), Table 4.3).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 16 OF 33
 R 1 R 2
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/14/86 JDH CAH
 3/13/89 3/29/90
 VALVES MODEL NP8316 SERIES CHECKED WBK DATE 7/16/86 KBN MM
 3/21/89 3/29/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a)	<u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>	
	Voltage	<u>125 VDC</u>	<u>TAB E-1, p. E-6</u> <u>TAB E-3, p. E-22</u>	
	Load	<u>Not specified</u>		R2
	Frequency	<u>NA (all valves DC)</u>		
	Accuracy	<u>NA</u>		
	Other(s)			

JUSTIFICATION/COMMENTS _____

(b)	<u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>	
	Voltage	<u>90 VDC min.</u> <u>(See comment below)</u>		
	Load	<u>Not specified</u>		R2
	Frequency	<u>NA (All valves DC powered)</u>	<u>NA</u>	
	Accuracy	<u>NA</u>	<u>NA</u>	
	Other(s)			

JUSTIFICATION/COMMENTS TVA Calculation WBN EEB-MS-Till-0004
determines voltage available to each valve during accident
conditions (see comment after J.(5) (C)).

R2

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 16a OF 33
 R 2 R 4
 BINDER TITLE ASCO SOLENOID COMPUTED R1 JDH DATE 3/13/89 CDH CAH
 3/22/90 9/12/90
 VALVES MODEL NP8316 SERIES _____ CHECKED R1 KBN DATE 3/21/89 AFM AFM
 3/23/90 9/24/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>	R4
Voltage	90 VDC	Ref(3) Fig. 9.2 p A26, App. A	
Load	.080 AMPS	Ref(3) Table 4.7	
Frequency	NA		
Accuracy	NA		
Other(s)			

JUSTIFICATION/COMMENTS Reference (3), Appendix A, Section
6.1.1, requires 125 VDC valves to operate on demand at any
voltage between 90-140 VDC. Per Figure 9.2 of reference (3).
the test valve was successfully tested at 90 VDC. A primary
concern with solenoid valves is that of voltage available at
the coil terminals. TVA Calculation WBN EEB-MS-TI11-0004
shows that the valves in this binder are supplied voltage
within their environmentally qualified minimum ratings as
required to perform their safety function during accident
conditions.

R4

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 17 OF 33
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7-14-86 R 2 R 3/23/90
 VALVES MODEL NP8316 SERIES CHECKED WBK DATE 7-16-86 R 3/23/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Various - See TABS C-1 thru C-4

- (1) Normal Max (2) Abnormal Max
- (a) Temperature (°F) Various (a) Temperature (°F) Various
 (b) Pressure (psig) Various (b) Pressure (psig) Various
 (c) Humidity (%) Various (c) Humidity (%) Various
 (d) Radiation (rd) Various (d) Radiation (rd) Various
- (3) Process Interfaces: The process fluid for these valves is
oil-free instrument air with a maximum design temperature of
100°F. Therefore, the bounding temperature for these valves
is the ambient.
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Will occur less than 1 percent of plant life and
could exist for up to 8 hours per excursion.
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- (a) Temperature (°F) 327°F Accident type LOCA/HELB
 (b) Pressure (psig) 25.6 psia Accident type LOCA/HELB R2
(11.2 psig)
 (c) Humidity (%) 100% Accident type LOCA/HELB
 (d) Radiation (rd) 4.7x10⁸ rads beta Accident type LOCA/HELB R2
4.0x10⁷ rads gamma
 (e) Spray Type 2000 PPM BORON Accident type LOCA/HELB
pH 8.3 at 25°C

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 18 OF 33
R 2 R 4
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/14/86 CDH CAH
3/22/90 9/18/90
VALVES MODEL NP8316 SERIES CHECKED WBK DATE 7/16/86 AFM MM
3/23/90 9/24/90

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): The worse case accident profile combination was not utilized as the enveloping environment. Qualification to the environment would only produce replacement/refurbishment schedules which would be overly conservative for many of the valves. Qualification and replacement schedules were based on valve specific environments which are defined in TAB C-1 through C-4, TAB G defines the maintenance which is reflective of these environments.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference:

See P.1 "Discussion").

- (7) Subject to submergence (Yes/No/NA)? Yes (Reference:

See P.1, "Discussion," TAB C-4).

Identify initiation time and duration of submergence:

Following an accident inside primary containment, valves

identified in TAB C-4 and located below elevation 722'

inside the crane wall or 717.7' outside the crane wall are

subject to submergence. However, these valves will all

complete their safety function prior to submergence

(See TAB C-4). No valves located outside containment and

covered by this binder are subject to submergence.

R4

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes
(Reference: Environmental Drawing 47E235-42).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify:

See Section P

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 19 OF 33
R 1 R
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/19/86 TDH
3/13/89
VALVES MODEL NP8316 SERIES CHECKED WBK/HDR DATE 9/19/86 KBN
3/21/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

(9) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>See TAB B Sect. A</u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>

R1

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-23 was deleted per revision 1.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 21 OF 33
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7-14-86 R 2 R 3/22/90
 VALVES MODEL NP8316 SERIES CHECKED WBK DATE 7-16-86 9PM 3/23/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>	
Operating Time	<u>100 Days</u>	<u>30 days</u>	<u>Ref (1)</u> <u>Fig 2</u>	
Temperature (°F)	<u>327°F</u>	<u>346°F</u>	<u>Ref (1)</u> <u>Sec 4.7</u>	
Pressure (psig)	<u>25.6 psia</u> <u>(11.2 psig)</u>	<u>110 psig</u>	<u>Ref (1)</u> <u>Sec 4.7</u>	R2
Relative Humidity (%)	<u>100%</u>	<u>100%</u>	<u>Ref (1)</u> <u>Sec 4.7</u>	
Chemical Spray*	<u>2000 ppm Boron</u> <u>pH 8.3</u>	<u>3000 ppm Boron</u> <u>pH 9.5-10.5</u>	<u>Ref (1)</u> <u>Sec 4.7</u>	R2
Radiation (rd)**	<u>8.52x10⁷ rads</u>	<u>2.01 x 10⁸</u>	<u>Ref (1)</u> <u>app D</u>	
Submergence	<u>Yes</u>	<u>Yes</u>	<u>See P. 1</u> <u>"Discussion"</u>	

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type. 2.52×10^7 beta (attenuated dose) + 4.0×10^7 gamma + 2×10^7 40-year dose = 8.52×10^7 rads TID. The total dose on the pigtailed only is 1.01×10^8 (see section P.3 of this TAB). R2

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 22 OF 33
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE m DATE 7/14/86 R R
MODEL NP8316 SERIES CHECKED WPK DATE 7/16/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	Test Profile Envelopes Specified <u>(Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>See (1)</u> <u>above</u>
Pressure	<u>Yes</u>	<u>See (1)</u> <u>above</u>
Relative Humidity	<u>Yes</u>	<u>See (1)</u> <u>above</u>
Chemical Spray	<u>Yes</u>	<u>See P. 2</u> <u>"Discussion"</u>
Submergence	<u>Yes</u>	<u>See P. 1</u> <u>"Discussion"</u>
<u>JUSTIFICATION/COMMENTS</u>		

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 23 OF 33
 R 2 R 4
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7-14-86 CDH 9/18/90
 VALVES MODEL NP8316 SERIES CHECKED WBK DATE 7-16-86 AFM 9/24/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	+19°F	Yes
Pressure: +10% but no more than 10 psig	+98psig	NA
Radiation: +10% of accident dose	+136%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	None	Yes*
Voltage: ±10% of rated value	No**	No**
Frequency: ±5% of rated value	N/A	N/A
Environmental Transient: the initial transient and the peak temperature applied twice	Yes	Yes
Vibration: +10% added to acceleration (during seismic testing)	Ref (1), Section 9.4.2.4.2 Ref (3) Sec. 4.1.6	Yes

JUSTIFICATION/COMMENTS *Accident degradation calculation (see TAB C) proves that the 30-day test envelops the 100-day post-accident requirement. See Generic Binder WBNEP-GEN-001, Section III.C.4.

**The valve was tested at a minimum 90 VDC during operability testing which is better proof of operability than increased coil voltage. During all other tests, either the nominal voltage of 125VDC or the test current of .080 amps was used.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 25 OF 33

BINDER TITLE ASCO SOLENOID VALVES COMPUTED CEM DATE 7/14/86 R R

MODEL NP8316 SERIES CHECKED WAK DATE 7/16/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See TABS C and G.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 26 OF 33
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86 R R
MODEL NP8316 SERIES CHECKED WJK DATE 7/16/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>NA</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>NA</u>
(b) Were specific features and failure modes and effects analyzed?	<u>NA</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>NA</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 27 OF 33
BINDER TITLE ASCO SOLENOID VALVES COMPUTED ESM DATE 7/14/86 R R
MODEL NP8316 SERIES CHECKED WAK DATE 7/16/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes*</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

*See P. 3 "Discussion".

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 23 OF 33
 R 3 R 4
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7-14-86 CDH 5/18/90 9/18/90
 VALVES MODEL NP8316 SERIES CHECKED WBK DATE 7-16-86 AFM 5/18/90 9/24/90

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | <u>NA</u> |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>Yes</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>NA</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

1. Moisture or liquid intrusion and submergence (Sec. K(6) & K(7)).
All solenoid valves covered by this binder that are subject to
moisture intrusion other than submergence are required to operate
only 1-hour into an accident, deenergize and remain deenergized.

R4.

BINDER NO. WBNEQ-SOL-006	PLANT	WBN	UNIT(S)	1	SHEET	29 OF 33
					R 3	R 4
BINDER TITLE ASCO SOLENOID	COMPUTED	EEM	DATE	7-14-86	CDH	<i>CXH</i>
					5/18/90	9/18/90
VALVES MODEL-NP8316 SERIES	CHECKED	WBK	DATE	7-16-86	AFM	<i>AFM</i>
					5/18/90	9/24/90

P. DISCUSSION (Continued)

Each solenoid valve is enclosed in a NEMA 6 enclosure. Per NEMA publication 250, section 3.09 (c), the design test required for a NEMA 6 rating requires the enclosure to be submerged to a depth of 6 feet of water for 30 minutes without moisture intrusion. In addition, testing done by Wyle Laboratories for TVA (reference Test Report 17523-1, and Wyle letter in TAB E-10) demonstrated that an ASCO solenoid valve (specimen A) operated 114.5 hours and a second valve (specimen D) operated for the full 30-day LOCA test with their enclosures full of water. Based on the above facts, we conclude that these valves will operate for 1 hour regardless of moisture intrusion from condensation. All valves in this binder subject to submergence will perform their safety function for all events prior to being flooded (See TAB C-4, pages C-91 and C-92).

The above rationale notwithstanding, TVA has thoroughly analyzed moisture intrusion and has installed conduit seals as necessary. TVA's Environmental Data Drawings list areas in the plant subject to moisture intrusion. To determine which valves required conduit seals, TVA's analysis considered NRC Information Notice 88-86 (TAB J-9), Reg. Guide 1.97 PAM concerns, and Category A to Category C interaction. From this analysis, those valves determined to require seals are listed in the OMDS (TAB G). TVA utilizes either Conax or Namco conduit seals for this application. Binder No. WBNEQ-CSC-001 documents qualification of the Conax seals. The Namco seals are qualified in Binder WBNEQ-CSC-002.

R4

R4

R4

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 30 OF 33
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EBM DATE 9/19/86 R R
MODEL NP8316 SERIES CHECKED WBK/2430 DATE 9/19/86

P. DISCUSSION (Continued)

2. Chemical Spray (Sec L. (1) & (2)).

The containment spray flow rate is equal to 9500 gal/min or 0.92
gpm per square foot of containment cross section. The spray duration
is 30 days. The chemical spray composition is an Alkaline borate
solution (ph 8.3) produced by mixing boric acid (H_3BO_3) with sodium
tetraborate ($Na_2B_4O_7 \cdot 10 H_2O$). The ASCO test valve was subjected
to a spray solution of 3000ppm Boron as Boric Acid in solution with
0.064 molar sodium thiosulfate buffered with sodium hydroxide to a pH
value of 10 at room temperature at a rate of 0.306 gpm per square
foot of area covered by the spray for the full 30 days of the test.
The test solution is more corrosive than the containment spray.
Therefore all valves listed in this binder subjected to containment
spray fall within the qualification provided by the test valve.

Reference: Environmental Drawings 47E235-41 and -42.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 31 OF 33
R 1 R 2
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/18/86 JDH CSJ
3/13/89 3/22/90
VALVES MODEL NP8316 SERIES CHECKED WBK DATE 9/19/86 KBN gmm
3/21/89 3/23/90

P. DISCUSSION

3. Beta Radiation (Sect. 0.12.b)

Post-DBA beta radiation must be addressed for all equipment located inside containment which is required for LOCA mitigation. Solenoid valves in Group D are located inside containment in the Lower Compartment, in the Accumulator Rooms and Fan Rooms; Group A valves are in the Upper Compartment; and Group B valves are in the Annulus.

Per drawing 47E235-44, which covers the Annulus, the 100-day accident radiation dose is 1.2×10^7 rads (includes a Beta dose contribution of 6×10^5 rads). Since the ASCO valves are qualified to 2.01×10^8 rads, no credit for reduction of the beta dose is necessary for the valves in Group B.

Per drawing 47E235-42, which covers the Lower Compartment, the 100-day accident radiation dose is 4.7×10^8 rads beta and 4×10^7 rads gamma. R2

Per drawing 47E235-41, which covers the Upper Compartment, the 100-day accident radiation dose is 4.7×10^8 rads beta and 3.8×10^7 rads gamma.

Since the combined gamma/beta doses possible in the Lower (Group D) and Upper (Group A) Compartments exceed the qualified level of the valves on face value, it is necessary to consider the inherent shielding afforded these valves.

All non-metallic parts of the valves are totally enclosed by metal with the exception of the 18" wire pigtails. The minimum thickness of metal is assumed to be the coil housing, which is 3/32" (0.09375) steel, per ASCO's Tom Hays telecon with TVA's Dean Helton on January 7, 1986. OE Calculation WBNTSR-051 "Reduction of Beta Dose by Sheet Steel," page 3.1, shows the beta reduction factor for 14 gauge (0.0747)" steel is equal to 0.0536. This reduces the total 100-day beta dose to the valve internal parts to $(4.7 \times 10^8) \times (5.36 \times 10^{-2}) = 2.52 \times 10^7$ rads TID beta.

In the Lower Compartment, the total combined 100-day beta and accident radiation dose will equal $(2.52 \times 10^7 \text{ beta}) + (4.0 \times 10^7 \text{ gamma}) = 6.52 \times 10^7$ rads. The combined 100-day accident radiation plus the 40-year dose (2×10^7) equals a total radiation dose of 8.52×10^7 rads TID.

BINDER NO.	WBNEQ-SOL-006	PLANT	WBN	UNIT(S)	1	SHEET	33	OF	33
BINDER TITLE	ASCO SOLENOID	COMPUTED	EEM	DATE	7/14/86	R	2	R	
VALVES MODEL	NP8316	SERIES	CHECKED	WBK	DATE	7/16/86	3/22/90		
							3/23/90		

P. DISCUSSION (Continued)

4. Synergistic Effects (Sec. H(3))

Ethylene Propylene Terpolymer (EPDM) elastomer is used in the construction of ASCO solenoid valves as gaskets and diaphragms. EPDM is the only material having a potential for radiation induced synergisms based on a review of technical information provided in NUREG/CR-2157 and NUREG/CR-2553. Data in NUREG/CR-2157 suggests that dose rate effects in EPR materials are insignificant up to doses of 10 to 20 MRADS. A review of the location and environments of ASCO solenoid valves listed in TABs C-1 through C-4 indicate that the maximum normal radiation dose will be seen by valves in subgroup D-2. These valves are qualified for 40 years without replacement of elastomer parts and will therefore be exposed to a maximum normal doses to 20 MRADS. Since all elastomer parts are totally enclosed in metal, the radiation dose to these parts will be less than 20 MRADS. Synergistic effects will be negligible for normal service aging.

Potential dose rate and test sequence synergisms will not impact qualification for accident conditions as demonstrated by Test Report AQS-21678. The test sequence of thermal aging followed by radiation aging plus accident radiation at high (0.8 MRAD/HR) dose rate is a reasonable simulation of actual plant requirements. Additional assurance is provided by the severity of the radiation test because the test valve was exposed to 201 MRADS whereas an actual dose of about 101 MRADS (81 MRADS accident plus 20 MRADS normal service) is required.

| R2

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE ASCO SOLENOID VALVES - COMPUTED EEH DATE 7/24/86
MODEL NP 8321 SERIES CHECKED FW DATE 7/28/86

TAB A
EQUIPMENT IDENTIFICATION MATRIX

500-007

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE ASCO SOLENOID COMPUTED R1 CAM DATE 3/13/89 R R
VALVES-MODEL NP8321 SERIES CHECKED R1 JDH DATE 3/13/89

TAB A

NOTES

1. Floor/Actual Elevation - Actual elevations are documented on field verification sheets found in TAB F. All elevations shown are floor elevations.
2. See TAB B, Section A for Category and Operating Times calculations used in this binder.
3. Contract Column - Contract numbers shown in this TAB were obtained by tracing the serial number on each valve through TVA procurement records and did not depend on field verification data for contract numbers.

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	AZMTH	ELEV(1)	RM/RAD	CAI OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION	MODEL NUMBER		CONTRACI		(2)		
WBN-2-FSV -065-0004 -B CNTMT ANN VAC FAN ISLN DMPR	2-FSV -065-0004 -B NP8321A2E		757°	A16	A/B 5MM/1000	L	MUST DEENERGIZE TO CLOSE DAMPER AFTER A PHASE A CNTMT ISOL SIGNAL TO ISOLATE VACUUM FANS.
WBN-2-FSV -065-0005 -A CNTMT ANN VAC FANS ISLN DMPR	2-FSV -065-0005 -A NP8321A2E		757°	A16	A/B 5MM/1000	L	MUST DEENERGIZE TO CLOSE DAMPER AFTER A PHASE A CNTMT ISLN SIGNAL TO ISOLATE VACUUM FANS.
WBN-2-FSV -065-0009 -A EGTS TRAIN A UNIT 2 SUCTION	2-FSV -065-0009 -A NP8321A2E		757°	A16	B 1000	L	DAMPER IS NORMALLY CLOSED AND MUST REMAIN CLOSED DURING THE MITIGATION OF THIS ACCIDENT.
WBN-2-FSV -065-0029 -B EGTS TRAIN B UNIT 2 SUCTION	2-FSV -065-0029 -B NP8321A2E		757°	A16	B 1000	L	DAMPER IS NORMALLY CLOSED AND MUST REMAIN CLOSED DURING THE MITIGATION OF THIS ACCIDENT.

PAGE 4-2R1

PREPARER/DATE E.E. McBEE 9/18/86

CHECKED/DATE F.W. VOSBURY 9/18/86

R 1
R
R
JDN
3/13/89

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/24/86 R R
MODEL NP8321 SERIES CHECKED FW DATE 7/28/86

TAB B

ENVIRONMENTAL QUALIFICATION CHECKLIST

PAGE B-1

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 1 OF 28
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/18/86 AFM 284
 VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 9/18/86 JDH 1311
 3/13/89 3/13/89 3/13/89

A. DOCUMENTATION

Equipment Description Solenoid Valves
 Vendor/Manufacturer ASCO
 Equipment Model No.(s) NP8321A2E

QUALIFICATION REPORTS

- (1) Title/Number/Revision Automatic Switch RIMS B43 850627 322
Company Test Report AQS-21678/TR/Rev. A DATE July, 1979
- (2) Title/Number/Revision Automatic Switch RIMS B45 850514 428
Company Test Report AQR-67368, Rev. 1 DATE August 19, 1983
- (3) Title/Number/Revision ASCO Catalog NP-1 RIMS NEB 840328 363
Valves AQS 21678/TR/Supplement 3 DATE March 8, 1983
- (4) Title/Number/Revision Franklin Research RIMS NEB 840925 351
Center Test Report F-C5569-309/315,
Appendix C DATE November, 1983
- (5) Title/Number/Revision "Aging and RIMS B74 890623 502
Qualification Research on Solenoid Operated
Valves," NUREG/CR-5141 RV DATE August 1988
- (6) Title/Number/Revision "ASCO Engineering RIMS B25 870612 003
Report No. 177" DATE Dec. 11, 1979

R2

NOTE: Throughout this binder references are made to the above qualification reports which may be identified as (1), (2), or (3), etc., as shown, in these references.

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- | | <u>RIMS Number</u> | |
|---|--------------------|----|
| (7) Category and Operating Times for Unit 2
Components Required for Unit 1 Operation
(WBNOSG4-040 R8) | B26 900626 224 | R2 |
| (8) Status and Duty Cycles of IE
Solenoid Valves Located in Potentially
Harsh Environments (WBNOSG4-045 R1) | B45 860902 219 | R2 |

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 1A OF 28
R 1 R 2
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/18/86 AFM CSH
3/13/89 7/20/90
VALVES-MODEL NP8321 SERIES --- CHECKED FWV DATE 9/18/86 JDH ajm
3/13/89 8/7/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

	<u>RIMS Number</u>	
(9) Solenoid Valve Voltage Study (WBN EEB-MS-TI11-0004)	B26 900202 407	
(10) 100-Day Loss of Coolant Accident Dose to Electrical Equipment in the EGTS Filter Train Room (WBNNAL3-031 R1)	B45 880826 235	R2
(11) WBNP Environmental Data Drawing 47E235-78 R3		

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 2 OF 28
R 1 R 2
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/29/86 AFM CRT
3/13/89 7/20/90
VALVES-MODEL NP8321 SERIES CHECKED KW/FWV DATE 9/29/86 JDH ATM
3/13/89 8/7/90

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES 1) Deleted by Revision 2

R2

2) Valve 2-FSV-65-4 not installed. Nameplate data not available
for 2-FSV-65-9.

3) Deleted by Revision 2.

R2

4) Location specific radiation calculations must be reanalyzed for
all valves.

5) Deleted by Revision 2.

6) Deleted by Revision 2.

R2

7) Deleted by Revision 2.

COMMENTS/RECOMMENDATIONS

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 3 OF 28
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/24/96 R R
 MODEL NP8321 SERIES CHECKED KW DATE 7/28/96

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- _____ Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/ COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 323-1974 IEEE Standard for Qualifying Class 1E Equipment for

Nuclear Power Generating Stations.

IEEE 382-1972 IEEE Trial-Use Guide for Type Test of Class 1 Electric

Valve Operators for Nuclear Power Generating Stations.

IEEE 382 (Draft 3, Rev 1, June 1977) Draft American National

Standard for the Qualification of Safety-Related Valve Actuators.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 4 OF 28
BINDER TITLE ASCO SOLENOID VALVES COMPUTED ECM DATE 7/24/86 R R
MODEL NP8321 SERIES CHECKED FW DATE 7/28/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- X Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS See "Similarity Table," page 6.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 5 OF 28
 R 2 R 2
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEM DATE 7/31/86 CAJ
7/20/90
 MODEL NP8321 SERIES _____ CHECKED FWV DATE 7/31/86 ajm
8/7/90

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (Yes/No/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Vlv</u>	<u>Solenoid Vlv</u>	
(2) Manufacturer	<u>ASCO</u>	<u>ASCO</u>	
(3) Model Number(s)	<u>NP8321A2E</u>	<u>NP8321A5E</u>	Ref (1) Section 2 Table 1
		<u>NP832070E</u>	Ref (2) App. I
		<u>(coil only)</u>	
(4) Serial Number(s)	<u>See TAB F</u>	<u>Test Valve 8</u>	Ref (2) Section 3 Table 3.2
		<u>(coil only)</u>	
		<u>Test Valves</u>	Ref (2) App. I Sec. 2
		<u>15 and 16</u>	
(5) Identify Component	<u>None</u>		
Unique checksheet attached:			

R2

JUSTIFICATION/COMMENTS

See "Similarity Table," page 6. Valve data sheets in TAB E indicate a NEMA 4 enclosure was specified. The valve furnished by ASCO has a NEMA 6 enclosure. The NEMA 6 enclosure is a tighter closure than NEMA 4.

ASCO SOLENOID VALVES

MODEL NP8316 SERIES

SIMILARITY TABLE

Specification	ASCO Test Valve Model No. NP8321A5E	TVA Valve Model No. NP8321A2E
Description	Three-way direct acting solenoid valve with packless const	Same
Application	Pilot Vlv Controlling Oil Free Instr Air	Same
Form of Flow	Normally Closed	Same
Pipe Size	1/4"	3/8"
Orifice Size	9/32" Pressure 11/32" Exhaust	9/32" Pressure 11/32" Exhaust
Body Material	Brass	Brass
Coil Class	H	H
Seals & Disc Material	Ethylene Propylene	Ethylene Propylene
Disc Holder Material	Stainless Steel	Stainless Steel
Core Tube Material	300 Series Stainless Steel	300 Series Stainless Steel
Core Material	400 Series Stainless Steel	400 Series Stainless Steel
Coil Enclosure	NEMA 4,7,9	NEMA 6
Maximum Operating Pressure		
Differential	150 psi	150 psi
Nominal Voltage	125V DC	125V DC
Power Rating	17.4 Watts	17.4 Watts
Conduit Connection	3/4" NPT	3/4" NPT
Applicable Form Number	V5971	V5971R1
Terminal Connection	Pigtails (Splice)	Pigtails (Splice)
Ambient Temperature	32 - 180°F	120°F - as specified
Maximum Fluid Temperature	180°F based on 140°F Ambient	Same
Safe Working Pressure	200 psig	Same
Notes: From Test Report AQS-21678 TR/Rev A (TAB D-1) Form V5971 (TAB D-1) & ASCO Cat. NP-1 (TAB E-3)		Notes: From Contract 827551 (TAB E-1), Form V5971 R1 (TAB H) & ASCO Cat. NP-1 (TAB E-3)

R R R

Preparer/Date B. E. McRae 7/24/86 _____

Checked/Date FWD King 7/28/86 _____

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 7 OF 28
 R 1 R
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 97M
3/13/89
 VALVES-MODEL NP8321 SERIES _____ CHECKED FWV DATE 7/28/86 JDA
3/13/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.)
 If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	None specified; See TAB C-3. "Interfaces"	No	
External Process Connections	See TAB C-3	Yes	See Below and Ref. (2) App. A, p A2
Electrical Connections	None specified; See TAB C-3. "Interfaces"	Yes	
Conduit Seals	See TAB C-3 "Conduit Seals"	No	Ref (2) Section 5.3
Connector Seals	N/A	N/A	
Orientation	Any Orientation	Yes	See Note Below
Physical Configuration	Conduit/Junction box must be oriented such that moisture does not drain into coil housing	N/A	Ref (2) Section 5.3 and TAB C-3
Other	None		

JUSTIFICATION/COMMENTS

ASCO does not identify specific interfacing requirements except as follows: (1) ASCO requires a 90° street elbow facing downward connected to exhaust port or similar configuration to prevent moisture intrusion from liquid spray. This is required only on valves located inside containment and subject to containment spray. (2) Flowing medium must be oil-free instrument air and a strainer or filter must be installed on the inlet as close to the valve as possible. See TAB C for a description of the TVA interfaces and TAB J-2 for discussion of TVA instrument air system.

NOTE: See ASCO letter in TAB E-5.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 8 OF 28
 R 1 R
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 ATM
3/13/89
 VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 7/28/86 JDA
3/13/89

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (Yes/No/NA)? (Note below.)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	Ref (2), p 8 & Ref (1) App. A <u>Sec. 9.4.2.1</u>
(b) Baseline performance measurements taken	<u>Yes</u>	Ref (2), p 8 & Ref (1) App. A <u>Sec. 9.4.2.2</u>
(c) Equipment aged:		Ref (1) App. A, Sec. 9.4.2.3.1 &
Thermal	<u>Yes</u>	<u>Ref (2), p 8</u> Ref (1) App. A Sec. 9.4.2.3.2 &
Radiation	<u>Yes</u>	<u>Ref (2), App. D</u> Ref (1) App. A, Sec. 9.4.2.3.3 &
Wear	<u>Yes</u>	<u>Ref (2), p 12</u> Ref (1) App. A, Sec. 9.4.2.3.4 &
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Ref (2), p 15</u> Ref (1) App. A Sec. 9.4.2.4 &
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>Ref (2), p 19</u> Ref (1) App. A Sec. 9.4.2.4 &
(f) Post-DBE exposure	<u>Yes</u>	<u>Ref (2), p 23</u> Ref (1) App. A Sec. 9.4.3 &
(g) Final inspection and disassembly	<u>Yes</u>	<u>Ref (2), p 24</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (Yes/No/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (Yes/No/NA)? Yes
 (Reference: Ref (1), App. C; Ref (2), App. G).

JUSTIFICATION/COMMENTS

Reference (2) was utilized to qualify the Class H coils. Reference to this report is in regard to coil qualification only unless otherwise noted. |R1

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 9 OF 28
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 R 2 R 7/20/90
 VALVES-MODEL NP8321 SERIES _____ CHECKED FWV DATE 7/28/86 afm
8/7/90

H. AGING

- (1) Was aging considered in the qualification program
 (Yes/No/NA)? Yes (Reference: Ref (1), App. A,
Sec. 9.4.2.3 and Ref (2), App. A, Sec. 9.4).

JUSTIFICATION/COMMENTS See TAB C-3.

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Ref (1), App. A</u> <u>Section</u> <u>9.4.2.3.1</u>
Radiation exposure	<u>Yes</u>	<u>Section</u> <u>9.4.2.3.2</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Section</u> <u>9.4.2.3.4</u>
Operational (electrical/mechanical/ process) stress aging	<u>Yes</u>	<u>Section</u> <u>9.4.2.3.3</u>

JUSTIFICATION/COMMENTS See Reference (2), App. A.

Section 9.4. Also, thermal aging was done using nitrogen
as the process fluid in lieu of instrument air (See TAB C-5).

R2

- (3) Were all known synergistic effects which are believed to have a
 significant effect on equipment performance considered in the
 aging program (Yes/No/NA)? Yes (Reference: NA).

JUSTIFICATION/COMMENTS See discussion, Section P-1.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
 (Yes/No/NA)? Yes (Reference: Ref (1), App. A
Sec. 9.4.2.3.1; Ref (2), App. A, Sec. 9.4.1).

JUSTIFICATION/COMMENTS See TAB C-3 "Thermal Aging"

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 10 OF 28
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 ^{R 2 R}
7/20/90
 VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 7/28/86 ^{AFM}
9/7/90

H. AGING (Continued)

- (b) Were the materials susceptible to thermal degradation identified in the qualification program (yes/no/NA)? Yes
 (Reference: Ref (2), Appendix B & Ref (3), Section 4).

JUSTIFICATION/COMMENTS _____

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference: Ref (3), Sections 5 & 6).

JUSTIFICATION/COMMENTS _____

- ^{CAF}
_{1/20/90}
 (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference: Ref (1), App A, Section 9.4.2.3.1 & Ref (2), App. A, Section 9.4.1).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>*</u>	<u>*</u>	<u>*</u>
Time	<u>_____</u>	<u>_____</u>	<u>_____</u>

JUSTIFICATION/COMMENTS *See TABs C-1 & C-3 "Thermal Aging."

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference: Ref (3), Sections 5 & 6).

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes
 (Reference: Ref (2), Appendix B & Ref (3), Section 4). | R2

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 11 OF 28
R 2 R
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 8/7/86 CRH
7/20/90
VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 8/7/86 AFM
8/7/90

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? NA (Reference _____).

JUSTIFICATION/COMMENTS _____

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference: Ref (1), Section 4.2;
Ref (2), Section 4.1).

JUSTIFICATION/COMMENTS _____

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference Ref (1),
Section 4.3 and 4.6; Ref (2), App. A, Sections 9.4.4
and 9.5.2).

JUSTIFICATION/COMMENTS _____

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? No
(Reference _____).

JUSTIFICATION/COMMENTS Effect on individual materials
not considered. Only effect of radiation on overall
valve performance.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes
(Reference Ref (1), App. A, Sections 9.4.2.3.2 &
9.4.2.4.1; Ref (2), App. A, Sections 9.4.4 & 9.5.2).

| R2

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 12 OF 28
 R 1 R 2
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 AFM CXH
 3/13/89 7/20/90
 VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 7/28/86 JDH QFM
 3/13/89 8/7/90

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: Ref (1), Section 4.3, App. D; Ref (2), App. D).

Plant normal ambient radiation dose (rd) 1.8 x 10³

Test exposure dose (rd) 2.01 x 10³

Test exposure dose rate (rd/hr) 5.1 x 10⁵ for 99 hour
8.0 x 10⁵ for 188.5 hours

Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS _____

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program¹ Yes (Reference: Ref (1), Section 4.5; Ref (2), Section 4.1.5).

JUSTIFICATION/COMMENTS _____

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Ref (1), App. A, Section 8.1.6; Ref (2), App. A, Section 9.4.5).

JUSTIFICATION/COMMENTS _____

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 13 OF 28
R 1 R 2
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 AFM CAF
3/13/89 7/20/90
VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 7/28/86 JDH AFM
3/13/89 8/7/90

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: Ref (1), Section 3.2.4; Ref (2), Section 4.1.2 & 4.1.3).

JUSTIFICATION/COMMENTS _____

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: Ref (1), App. A, Section 7.1; Ref (2), App. A, Sections 9.4.2 & 9.4.3).

JUSTIFICATION/COMMENTS _____

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes (Reference: Ref (1), Section 3.2.2; Ref (2), Appendix C, p C-8, 4.1.1).

Qualified life (Document in QMDS) See TABS C and G

R2

JUSTIFICATION/COMMENTS The qualified life is different from the value given in the test report. TAB C-1 provides rationale.

R2

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes (Reference: Ref (3), Section 8; ref (2), App. C).

R2

JUSTIFICATION/COMMENTS Replacement interval depends upon maximum normal ambient temperature and percentage time solenoid valve is energized.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 14 OF 28
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 R 2 R 7/20/90
 VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 7/28/86 ARM 8/7/90

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>EPDM</u>	<u>NA</u>	<u>NA</u>	<u>0.94</u>	<u>Ref(3)&(2)App.B Sec. 4.1.1</u>
(b) <u>VITON</u>	<u>NA</u>	<u>NA</u>	<u>1.04</u>	<u>Ref(3)&(2)App.B Sec. 4.1.2</u>
(c) <u>NOMEX</u>	<u>NA</u>	<u>NA</u>	<u>0.96</u>	<u>Ref(3)&(2)App.B Sec. 4.1.3</u>
(d) <u>MAGNET-WIRE ENAMEL</u>	<u>NA</u>	<u>NA</u>	<u>1.16</u>	<u>Ref(3)&(2)App.B Sec. 4.2.1</u>
(e) <u>ISO-MICA W/EPOXY</u>	<u>NA</u>	<u>NA</u>	<u>1.00</u>	<u>Ref(30)&(2)App.B Sec. 4.2.6</u>
<u>SILICONE RUBBER LEAD</u>				<u>Ref(3)&(2)App.B</u>
(f) <u>WIRE INSULATION</u>	<u>NA</u>	<u>NA</u>	<u>1.59</u>	<u>Sec. 4.2.5</u>
*(g) <u>DC 550 LUBRICANT</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS The above materials are those with lowest
activation energies listed in Reference (3), Section 4.1 and 4.2.
Radiation threshold values are not required because no analysis was
performed. The devices were qualified by test.

* Although not stated in references (1) or (2), DC 550 lubricant was
used on tested valves as verified by ASCO letter dated
January 5, 1988 (See TAB E-9).

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not yet (yes/no/NA)? Yes
(Reference: Ref (1) & (2), App. A, Sections 6.1 & 6.2). | R2

Identify Acceptance Criteria: Valves must operate from 90-140VDC at minimum and maximum operating pressure differential. Coil insulation resistance must be a minimum of 1.0 megohm at 500VDC. During Hypot test, current leakage must be less than 0.5 milliamp at twice the rated voltage plus 1000 VAC applied for a long period of one minute. Valves must operate at test or low voltage condition (90VDC) at maximum pressure differential under all conditions. Valves are not to have a pressure build-up at a vented cylinder port or a pressure decrease at a cylinder port which is required to be pressurized in excess of 10% the nominal inlet supply pressure under all postulated environmental conditions. | R2

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Ref (1), Section 4.1); (2) TABLE 4.10). | R2

Identify baseline and functional testing: Recording coil excitation, seat leakage, noise test, operational test, external leakage in energized and de-energized state before and after thermal, radiation, wear and vibration aging, and accident radiation and LOCA simulation. Measurement of insulation resistance and coil dielectric tests before thermal aging and after completion of accident radiation and LOCA simulation.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes
(Reference: Ref (1), App. A, Section 7.0, Ref (2), Table 4.10, Fig. 9.2). | R2

- (4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Ref (1), Section 4.8 & Ref (2), Table 4.10). | R2

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 15A OF 28
 BINDER TITLE ASCO SOLENOID COMPUTED R1 AFM DATE 3/13/89 7/20/90
 VALVES-MODEL NP8321 SERIES CHECKED R1 JDH DATE 3/13/89 8/7/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>90-140 VDC</u>	<u>Section J(5)(b) of this TAB</u>
Load	<u>20 Watts</u>	<u>NP-1 Catalog</u>
Frequency	<u>NA</u>	
Accuracy	<u>NA</u>	
Other(s)		

R2

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 16 OF 28
 R 1 R 2
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 AFM CAF
 3/13/89 7/20/90
 VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 7/24/86 JDH CAF
 3/13/89 8/7/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) Parameter	Specific Accident Conditions	Reference	
Voltage	90 VDC Min. (See comment below)		R2
Load	Not Specified		
Frequency	NA	NA	
Accuracy	NA	NA	
Other(s)			

JUSTIFICATION/COMMENTS TVA Calculation WBN EEB-MS-TI11-0004
determines voltage available during accident conditions
(see comment after J.(5)(c)). R2

(c) Parameter	Demonstrated Conditions	Reference	
Voltage	⁹⁰ 65 VDC	Ref (2) <u>Fig. 9.2</u> Table 4.10, <u>p-44 AZ6, App. A</u> p-44	R2
Load	.080 amps	Ref (2) Table 4.10	
Frequency	NA		
Accuracy	NA		
Other(s)			

JUSTIFICATION/COMMENTS: Reference (3), Appendix A, Section 6.1.1, requires 125 VDC valves to operate on demand at any voltage between 90-140 VDC. Per ~~Table 4.10~~ ^{FIGURE 9.2} of reference (2), the test valve was successfully tested at ~~65~~ ⁹⁰ VDC. A primary concern with solenoid valves is that of voltage available at the coil terminals. TVA calculation WBN EEB-MS-TI11-0004 shows that the valves in this binder are supplied voltage within their environmentally qualified minimum ratings as required to perform their safety function during accident conditions.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 17 OF 28
 R 1 R 2
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/18/86 AFM CSH
 3/13/89 7/29/90
 VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 9/18/86 JDH AFM
 3/13/89 8/7/90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-78

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>ATM</u>	(b) Pressure (psig) <u>ATM</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>1.8x10³</u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: The process fluid for valves is oil-free instrument air with a maximum design temperature of 100°F. Therefore, the bounding temperature for these valves is the ambient.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Will occur less than 1 percent of plant life and could exist for up to 8 hours per excursion.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>110</u> ⁽¹⁾	Accident type <u>LOCA</u>
(b) Pressure (psig) <u>NA</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>NA</u>	Accident type <u>LOCA</u>
(d) Radiation (rd) <u>3.3x10⁶ rads</u> ⁽²⁾	Accident type <u>LOCA</u> R2
(e) Spray Type <u>NA</u>	Accident type <u>LOCA</u>

- (1) Returns to maximum normal after 30 days.
 (2) Per Calculation WBNNAL3-031.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 18 OF 28
R 1 R
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 9/18/86 9PM
3/13/89
VALVES-MODEL NP8321 SERIES _____ CHECKED FWV DATE 9/18/86 JDH
3/13/89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): _____

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: _____). | R1
Drawing 47E235-78

- (7) Subject to submergence (Yes/No/NA)? No (Reference: _____). | R1
Drawing 47E235-78

Identify initiation time and duration of submergence: _____

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? No (Reference: See note below). | R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: _____

Note: Beta dose is not applicable to the subject devices as
they are located outside of containment.

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B, Section A for a listing of all calculations used
in this binder.

WBNEQ-SOL-007

Sheet 19 of 28

The information on this page was deleted per Revision 1.

PAGE B-21R1

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 20 OF 28
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 R 2 R 2
 VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 7/28/86 7/20/90 QMM 8/7/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 Days</u>	<u>30 Days</u>	Ref (1) <u>Fig 2</u>
Temperature (°F)	<u>110°F</u>	<u>346°F</u>	Ref (1) <u>Sec. 4.7</u>
Pressure (psig)	<u>ATM</u>	<u>110 psig</u>	Ref (1) <u>Sec. 4.7</u>
Relative Humidity	<u>90%</u>	<u>100 %</u>	Ref (1) <u>Sec. 4.7</u>
*Chemical Spray	<u>NA</u>	<u>3000ppm Boron pH 9.5-10.5</u>	Ref (1) <u>Sec. 4.7</u>
**Radiation (rd)	<u>3.3×10^6 rads gamma</u>	<u>2.01×10^8 rads</u>	Ref (1) <u>App D</u> R2
Submergence	<u>No</u>	<u>No</u>	

*Includes spray concentration, flowrate, density, duration, and pH.
 **Enter 40-year integrated normal dose plus integrated accident dose and specify type.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 21 OF 28
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/24/86 R R
MODEL NP8321 SERIES CHECKED FW DATE 7/28/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified</u>	
	<u>(Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>See (1) above</u>
Pressure	<u>Yes</u>	<u>See (1) above</u>
Relative Humidity	<u>Yes</u>	<u>See (1) above</u>
Chemical Spray	<u>NA</u>	<u> </u>
Submergence	<u>NA</u>	<u> </u>
<u>JUSTIFICATION/COMMENTS</u>		
<u> </u>		

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 22 OF 28
 BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 CRH
7/20/90
 VALVES-MODEL NP8321 SERIES CHECKED FWV DATE 7/28/86 MM
8/7/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323 (74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>	
Temperature: +15 degrees F	>15 °F	Yes	
Pressure: +10% but no more than 10 psig	>10%	Yes	
Radiation: +10% of accident dose	<u>5990</u> <u>5090%</u>	Yes	R2 <u>CRH</u> <u>8/6/90</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	None	Yes*	
**Voltage: ±10% of rated value	+12% to -28%	Yes	R2 <u>CRH</u> <u>8/6/90</u>
Frequency: ±5% of rated value	NA	NA	
Environmental Transient: the initial transient and the peak temperature applied twice	Yes	Yes	
Vibration: +10% added to acceleration (during seismic testing)	Ref (1), Sec. 9.4.2.4.2 Ref (2), Sec. 4.1.6	Yes	

JUSTIFICATION/COMMENTS: *Accident degradation calculation (See TAB C) proves that the 30-day test envelops the 100-day post-accident requirement.

BASELINE
 **The valve was tested at 65 VDC during operability testing, which is better proof of operability than increased coil voltage. ~~During all other tests, either the nominal voltage of 125VDC or the test current of .080 amps was used.~~ DURING LOCA/HELB TESTING THE VALVE WAS ENERGIZED AT 90 VDC (SEE FIGURE 9.2, APPENDIX A, PAGE A26 OF REF. (2)).

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 23 OF 28
R 2 R
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 CAT
7/20/90
VALVES-MODEL NP8321-SERIES CHECKED FWV DATE 7/28/86 JTM
8/7/90

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference See TAB A and TAB C).

JUSTIFICATION/COMMENTS Functions are varied. All are
listed in TAB A and TAB C-1.

- (2) Did the equipment performs its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference: Ref (1), Section 5).

JUSTIFICATION/COMMENTS The test valve is assumed to be
normally energized and required to de-energize on receipt
of accident signal, then to remain operable for 30 days
post-DBA. The specific DBA functions of the TVA valves
are described in TAB C.

R2

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference: Ref (1), Section 5).

JUSTIFICATION/COMMENTS _____

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference Ref (6)).

R2

JUSTIFICATION/COMMENTS See TAB C-1 for the analysis of the
test DBA versus the plant specific DBA. The test valve
demonstrated operability in accordance with the requirements
defined in M(2) above.

R2

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Reference Ref (1), Table 2H; Ref (2), App. J).

JUSTIFICATION/COMMENTS TVA has reviewed test anomalies and
concurs with disposition.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 24 OF 28
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEH DATE 7/24/86 R R
MODEL NP8321 SERIES CHECKED FEW DATE 7/28/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See TABS C and G.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 26 OF 28
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEY DATE 7/27/86
MODEL NP8321 SERIES _____ CHECKED KW DATE 7/28/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>NA</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 27 OF 28
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 R 2 R CSH
VALVES MODEL NP8321 SERIES CHECKED FMV DATE 7/28/86 7/20/90 qtm
8/7/90

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial baseline test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>NA</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u> R2
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 28 OF 28
BINDER TITLE ASCO SOLENOID COMPUTED EEM DATE 7/24/86 R 2 R 7/20/90
VALVES MODEL NP8321 SERIES CHECKED FMV DATE 7/28/86 QJM 8/7/90

P. DISCUSSION

1. Synergism Effects (Sec. H(3))

Ethylene Propylene Terpolymer (EPDM) elastomer is used in the
construction of ASCO solenoid valves as gaskets and diaphragms.
EPDM is the only material having a potential for radiation induced
synergisms based on a review of technical information provided in
NUREG/CR-2157 and NUREG/CR-2553. Data in NUREG/CR-2157 suggests CAJ 7/20/90
that dose rate effects in EPR materials are insignificant up to
doses of 10 to 20 MRADS. A reievew of the location and
environments of ASCO solenoid valves listed in TAB C-1 indicates
that the maximum normal radiation dose will be seen by valves in
subgroup A-2. These valves are qualified for 40 years without
replacement of elastomer parts and will therefore be exposed to a
maximum normal dose of .001 MRADS. Since all elastomer parts are
totally enclosed in metal, the radiation dose to these parts will
be less than .001 MRADS. Synergism effects will be negligible for
normal service aging.
Potential dose rate and test sequence synrgisms will be impact
qualification for accident conditions as demonstrated by Test
Report AOS-21678. The test sequence of thermal aging followed by
radiation aging plus accident radiation at high (0.8 MRAD/HR)
dose rate is a reasonable simulation of actual plant requirements.
Additional assurance is provided by the severity of the radiation
test because the test valve was exposed to 201 MRADs whereas an
actual dose of about 3.3 MRADs (3.3 MRADs accident plus .001 MRADs | R2
normal service) is required.

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

PAGE 1

S NUMBER DESCRIPTION	UNIT DEVICE ID NO.	MODEL NUMBER	LOCATION AZMITH ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-0-SPLC-510-0001 LOW VOLTAGE TUBING	0-SPLC-510-001	WCSF-N	VARIOUS VARIOUS		A A	1000 1000	L HELB	PROVIDE INSULATING PROPERTIES FOR ELECTRICAL CONNECTIONS.
WBN-0-SPLC-510-0002 LOW VOLTAGE MOLDED PARTS	0-SPLC-510-002	END CAPS	VARIOUS VARIOUS		A A	1000 1000	L HELB	PROVIDE INSULATING PROPERTIES FOR ELECTRICAL CONNECTIONS.
WBN-0-SPLC-510-0003 LOW VOLTAGE MOLDED PARTS	0-SPLC-510-003	BREAKOUTS	VARIOUS VARIOUS		A A	1000 1000	L HELB	PROVIDE INSULATING PROPERTIES FOR ELECTRICAL CONNECTIONS.
WBN-0-SPLC-510-0004 LOW VOLTAGE KIT TB REPLACEMENT	0-SPLC-510-004	NPKI	VARIOUS VARIOUS		A A	1000 1000	L HELB	PROVIDE INSULATING PROPERTIES FOR ELECTRICAL CONNECTIONS.
WBN-0-SPLC-510-0005 LOW VOLTAGE KIT CONTROL CABLE SPLICE	0-SPLC-510-005	NPKC	VARIOUS VARIOUS		A A	1000 1000	L HELB	PROVIDE INSULATING PROPERTIES FOR ELECTRICAL CONNECTIONS.

PAGE A-1

R2

PREPARER/DATE HPR/9-23-86

CHECKED/DATE NMB/9-23-86

R 2 R R
8-11-89
8-15-89

100-2745

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	LOCATION	DESCRIPTION	MODEL NUMBER	AZMITH	ELEV(1)	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
								(2)			
WBN-0-SPLC-510-0006	-	0-SPLC-510-006	LOW VOLTAGE KIT POWER CABLE SPLICE	NPKP		VARIOUS	VARIOUS	A	100D	L	PROVIDE INSULATING PROPERTIES
								A	100D	HELB	FOR ELECTRICAL CONNECTIONS.
WBN-0-SPLC-510-0007	-	0-SPLC-510-007	LOW VOLTAGE KIT INSTRUMENT CABLE SPLICE	NPKS		VARIOUS	VARIOUS	A	100D	L	PROVIDE INSULATING PROPERTIES
								A	100D	HELB	FOR ELECTRICAL CONNECTIONS.
WBN-0-SPLC-510-0008	-	0-SPLC-510-008	LOW VOLTAGE KIT "V" STUB CONNECTION	NPKV		VARIOUS	VARIOUS	A	100D	L	PROVIDE INSULATING PROPERTIES
								A	100D	HELB	FOR ELECTRICAL CONNECTIONS.
WBN-0-SPLC-510-0009	-	0-SPLC-510-009	LOW VOLTAGE KIT MOTOR CONNECTION	NMCK		VARIOUS	VARIOUS	A	100D	L	PROVIDE INSULATING PROPERTIES
								A	100D	HELB	FOR ELECTRICAL CONNECTIONS.
WBN-0-SPLC-510-0010	-	0-SPLC-510-010	LOW VOLTAGE KIT CABLE BREAKOUT	NCBK		VARIOUS	VARIOUS	A	100D	L	PROVIDE INSULATING PROPERTIES
								A	100D	HELB	FOR ELECTRICAL CONNECTIONS.

PAGE A-2

R2

PREPARER/DATE R2 2-11-89

CHECKED/DATE R2 8-15-89

R R R

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER	UNIT DEVICE ID NO.	MODEL NUMBER	LOCATION	AZMITH	ELEV(1)	RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
DESCRIPTION							(2)			
WBN-0-SPLC-510-0011 LOW VOLTAGE KIT END SEALING KIT	- 0-SPLC-510-011	NESK	VARIOUS				A	100D	L	PROVIDE INSULATING PROPERTI
			VARIOUS				A	100D	HELB	FOR ELECTRICAL CONNECTIONS.

PAGE A-3

R3

PREPARER/DATE IR2 CAGT 8-11-89

CHECKED/DATE IR2 JFW 8-15-89

R 3 R R

1/2/64/10

1/0.R.26-90

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 7/20/86 DATE 9/20/86
CATION OF RAYCHEM HEAT SHRINK CHECKED B DATE 9/21/86
CABLE SPLICES

A. DOCUMENTATION

Equipment Description Heat Shrink Cable Sleeve
(for applications of 600 VAC or less)
Vendor/Manufacturer Raychem Corporation
Equipment Model No.(s) Raychem's complete line of nuclear grade cable
connection heat shrink splices and terminations
(600 volts or less) (Raychem material Type-52
and/or WCSF).

QUALIFICATION REPORTS

Report No. 1 Title/Number/Revision See title below/ RIMS B70 851119 101
Wyle Labs Report 58722-2/Revision 0 DATE Nov. 18, 1982
Report No. 2 Title/Number/Revision See title below/ RIMS B70 851112 102
Raychem Report EDR 5046 DATE March 4, 1982
Report No. 3 Title/Number/Revision See title below/ RIMS B70 851112 101
Raychem Report EDR 5040 DATE Oct. 15, 1981

OTHER (ANALYSIS, VENDOR DATA, ETC.) Report Titles:

1. "Environmental Qualification Test Report of Raychem WCSF-N In-Line Bolted Splice Assemblies."
 2. Analysis of Heat Aging Data on WCSF Material to Determine Pre-Aging Conditions for Nuclear Qualification Testing."
 3. Analysis of Heat Aging Data on -52 Molding Material to Determine Pre-Aging Conditions for Nuclear Qualification Testing.
- See TAB E for additional qualification documentation. (Listed on pages
2 and 3).

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 2 OF 40
R 1 R _____
BINDER TITLE Environmental COMPUTED HDR DATE 9/22/86 WJH
Qualification of Raychem Heat 12-1-88
Shrink Cable Splices CHECKED NMB DATE 9/22/86 WJH
12-2-88

ADDITIONAL DOCUMENTATION

1. Environmental Qualification Test Report RIMS EEB 830228 035
of Raychem NRPKV Nuclear Plant Stub DATE August 24, 1982
Connection Kit for Raychem Corporation
Report 58722-1 Rev. 0.
2. Environmental Qualification Test Report RIMS B70 851119 102
of Raychem Nuclear Cable Breakout and DATE April 3, 1981
End Sealing Kits Report 58442-2 Rev. 0.
3. Qualification Report Supplement for RIMS B70 851119 104
Raychem Nuclear Grade Adhesive S119 DATE April 23, 1980
Report EDR 5021 Rev. 0.
4. Wyle Laboratories Report "Environmental RIMS B70 851112 105
Qualification Test Report on Raychem DATE Dec. 21, 1982
Nuclear Plant Kit (NPK) Report 58722-6
Rev. 0.
5. Raychem Palo Verde I Test Report RIMS B70 851015 102
EDR 5019 DATE March 4, 1982

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

R1

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 2a OF 40
R 2 R 3
BINDER TITLE Environmental COMPUTED HDR DATE 9/22/86 CAG 7/14/89
Qualification of Raychem Heat
Shrink Cable Splices CHECKED NMB DATE 9/22/86 JFW 8/1/89

ADDITIONAL DOCUMENTATION

6. Environmental Qualification Test Report RIMS B70 851112 104
of Raychem N-MCK Nuclear Motor DATE July 28, 1980
Connection Kits Report 58442-3 Rev. 0.
7. Environmental Qualification Test Report RIMS B36 900604 001
of Raychem WCSF-050-N Shim Stock DATE December 21, 1982
Report 58722-5, Revision 0.
8. Cable inside conduit temperature trans- RIMS B45 850912 235
ient during a MSLB in the Valve Vault. DATE September 12, 1985
Calculation WBNNAL6001.
9. Safety evaluation of superheated steam RIMS B45 851112 218
in the valve vaults caused by a main DATE November 12, 1985
steam line break. Calculation No.
WBNOSG4-003, Rev 2.
10. Environmental Drawings TVA Dwgs RIMS NA
47E235-42 Rev. 2, and 47E235-76 Rev. 3. DATE NA
11. Qualification Test Report for RIMS L33 870318 801
Commonwealth Edison Co. DATE March 18, 1987
Wyle Lab Report No. 17859-02B
12. WBPEVAR 8904055 R0, Class IE Splice RIMS B26 890511 501
List - Unit 1, Common, and Unit 2 DATE March 26, 1989
Required for Unit 1 Safe Shutdown

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 3 OF 40
 R 3 R
 BINDER TITLE Environmental COMPUTED HDR DATE 9/22/86 HAR
Qualification of Raychem Heat 6/4/90
Shrink Cable Splices CHECKED NMB DATE 9/22/86 HAR
7-26-90

The reports on page 2 will help substantiate the qualification of the different configurations of heat shrink cable connections used at Watts Bar (see TAB B).

Report 1 - Covers NPKV kits (Stub Connection Kit)

Report 2 - Covers the nuclear cable breakout (-52 material) and end caps.

Report 3 - Qualification report for new adhesive (S1119) which replaced S1024. This report demonstrates that the new adhesive is equivalent or superior to the S1024.

Report 4 - Covers NPK kits nuclear cable break-out (-52 material).

Report 5 - Covers in-line splices using both the S1119 and S1024 adhesives.

Report 6 - Covers N-MCK Kits Motor connect connection kits.

Report 7 - Covers WCSF-050-N shim stock.

R3

The DBE profiles for these tests encompass the Watts Bar profile and are qualified for 40 years at 90°C, one DBE and 100 days post-accident time. Some of the test items failed to hold the 1,000 volts AC test voltage during the test. In all cases the failures were shown to be caused by overaging of the test cable that the splices were used on. All splices passed the voltage withstand test and had acceptable IR measurements in a water bath when tested with the damaged portion of the leads out of the water during the test. The remainder of the test item held the test voltage (1000 AC) during the complete DBE test.

The above reports (located in TAB E) along with the binder test report 58722-2 qualifies all Raychem splices 600 volts and below at Watts Bar Nuclear Plant.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 4 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED for DATE 7/29/86 R R
CATION OF RAYCHEM HEAT SHRINK CHECKED B DATE 9/2/86
CABLE SPLICES

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

COMMENTS/RECOMMENDATIONS The nuclear grade Raychem cable connection
heat shrink splices are environmentally qualified for 40 years at
90°C including a DBA and 100 day post-accident operation for the
accident and normal conditions at the Watts Bar Nuclear Plant.

Note: Qualification contingent on resolution of all open items.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 5 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED WDR DATE 9/22/86 R R
CATION OF RAYCHEM HEAT SHRINK CHECKED 15 DATE 9/22/86
CABLE SPLICES

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 383-1974

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 6 OF 40
R R
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 2/9/86 DATE 9/24/86
CATION OF RAYCHEM HEAT SHRINK CHECKED 10 DATE 9/24/86
CABLE SPLICES

D. QUALIFICATION METHODOLOGY (Check only one block)

 Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

 X Test of Similar Items with Supporting Analysis

 Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

 Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS This binder qualifies the different con-
figurations of the Raychem cable connection heat shrink splices
using WCSF and/or -52 type nuclear grade heat shrink materials.
The test reports used in TAB B for qualification are for the WCSF-N
sleeve configuration. Additional test reports have been included in
TAB E detailing other configurations that have been tested. All the
profiles encompass the Watts Bar environmental accident conditions
and all tested samples were aged (heat and radiation) to levels well
above those required for Watts Bar. All anomalies were addressed in
each test report and no failures of the Raychem materials were noted
in any of the test. All apparent failures were not Raychem failures
but were attributed to excessive heat aging (causing cracks in cable
insulation) of the cable used in the tests.

All cable connections must be made using TVA Standard Construction
Specification G-38 which requires nuclear grade Raychem heat shrink
be used on all safety-related equipment located in a harsh environ-
ment that are spliced. This specification details the sizes of heat
shrink sleeves and breakouts to use for each cable size and configu-

PAGE 3-6

BINDER NO. <u>WBNEQ-SPLC-001</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>7</u> OF <u>40</u>
			R <u>3</u> R
BINDER TITLE <u>Environmental</u>	COMPUTED <u>HDR</u>	DATE <u>9/22/86</u>	<u>7/25/90</u>
<u>Qualification of Raychem Heat</u>			
<u>Shrink Cable Splices</u>	CHECKED <u>NMB</u>	DATE <u>9/22/86</u>	<u>7/26/90</u>

ratio. This specification is used in conjunction with the installation instructions supplied with the heat shrink material (see TAB H).

This binder covers all nuclear grade Raychem splices 600 volts or less. No safety-related equipment, located in a harsh environment, requiring a nuclear-grade Raychem splice is rated more than 600 volts. The splice loading during the DBE test is less than the 90°C cable rating per National Electric Code 1990. For the purpose of the qualification, the additional heat rise resulting from the difference between these current values is calculated and added to the accident profiles (see TAB C).

R3

The IR measurements taken during the DBE test of the test specimens (Raychem splice and connecting cable) were much greater than comparable readings taken during the qualification testing for TVA Type MS cable (signal cable) used in instrumentation circuits. The splices are required to maintain its required performance during all postulated service conditions. Thus, assurance is provided that the presence of splices in these cables will not result in degraded signal levels caused by current leakage resulting from the use of the Raychem splices.

All Raychem splice material and applications covered in this binder are consistent with Watts Bar applications.

The above information gives reasonable assurance that the nuclear grade Raychem heat shrink splices and terminations at Watts Bar Nuclear Plant are environmentally qualified for 40 years at 90°C and one DBA with 100 days post-accident operation.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 8 OF 40
R 2 R 3
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 CAG 122
Qualification of Raychem Heat 8/11/89 61410
Shrink Cable Splices CHECKED NMB DATE 9/21/86 JFW 482
8/15/89 7-26-90

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification.

(Yes/No/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Cable Sleeve</u>	<u>Cable Sleeve</u>	Report 1 <u>Sec. 2.1.1</u>
(2) Manufacturer	<u>Raychem</u>	<u>Raychem</u>	Report 1 <u>Sec. 2.1.1</u>
(3) Model Number(s)	<u>See Comments</u>	<u>See Comments</u>	<u>NA</u>
(4) Serial Number(s)	<u>NA</u>	<u>NA</u>	<u>NA</u>
(5) Identify Component-	<u>None</u>		
Unique checksheet attached:			

JUSTIFICATION/COMMENTS This binder qualifies the complete line of LOCA-qualified Raychem nuclear grade products consisting of -52 molding material and/or WCSF sleeves. The following products are covered: WCSF-N, NPKC (control cable), NPKS (instrumentation cables); NPKV (V stub connection); NPKP (power cable); NMCK (motor connection); NCBK (cable breakout kit); NESK (end sealing kit); low voltage molded parts (end caps and breakouts); and NPK I (terminal block replacement kit).

R3

BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 *7-14-87*Qualification of Raychem HeatShrink Cable Splices CHECKED NMB DATE 9/21/86 *8-28-87*F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification | R2
documentation and/or evaluation and reference the source. Is the
interface a requirement for our application (Yes/No)? (Note below.)
If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u> </u>	<u> </u>
External Process Connections	<u>NA</u>	<u> </u>	<u> </u>
Electrical Connections	<u>NA</u>	<u> </u>	<u> </u>
Conduit Seals	<u>NA</u>	<u> </u>	<u> </u>
Connector Seals	<u>NA</u>	<u> </u>	<u> </u>
Orientation	<u>NA</u>	<u> </u>	<u> </u>
Physical Configuration	<u>NA</u>	<u> </u>	<u> </u>
Other	<u>NA</u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS 1) Raychem nuclear grade splices are
designed to provide an environmental seal to smooth non-woven
surfaces including polyolefin, most synthetic cable jackets and
to many metals (TAB H Product Features). The qualification
status of the Raychem splice is conditional upon the capability
of the substrate materials maintaining physical integrity
under the same conditions under which the Raychem materials
are qualified. All safety related cables at WBN are qualified
and are expected to maintain their physical integrity under
the normal and DBE conditions at WBN (Ref. all cable quali-
fication binders).

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 10 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 7/22/86 DATE 9/22/86 R R
CATION OF RAYCHEM HEAT SHRINK CHECKED B DATE 9/22/86
CABLE SPLICES

F. INSTALLATION INTERFACES (Continued)

JUSTIFICATION/COMMENTS (1)

The test reports included in this binder do not include all sizes of Raychem splices used at WBN or all cable jacket/insulation material to which the splices must seal. As stated above, the Raychem will seal most cable material. Also during qualification testing of safety related cables used at WBN, Raychem splices were required to connect the cable being tested to the test leads. These splices used during qualification of the cable show that the cable sizes and material types at WBN are compatible with and provide a qualified seal on the cable installations at WBN.

2) Splice installation is to be done in accordance with the latest revision of TVA Standard Drawings (SD)-E12.5.6, E12.5.7-1, E12.5.7-2, and E12.5.8 and Raychem installation instructions taking into account the two-inch minimum seal length after shrinking for in-containment applications. The test set-up utilized Raychem's installation instructions which also require a two-inch minimum seal length. (See TAB H for vendor installation/inspection guides and TAB G installation).

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 11 OF 40
 BINDER TITLE ENVIRONMENTAL QUALIFICATION OF RAYCHEM HEAT SHRINK CABLE SPLICES COMPUTED 7/20/86 DATE 7/20/86 R R
 CHECKED B DATE 9/2/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2. (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	(1) <u>See Comments</u>	<u>See Comments</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>58722-2, Sec. 3.2</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>58722-2, Sec. 3.3.1</u>
Radiation	<u>Yes</u>	<u>58722-2, Sec. 3.3.2</u>
Wear	(2) <u>NA*</u>	<u> </u>
(d) Vibration/seismic testing conducted	(2) <u>NA*</u>	<u> </u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>58722-2, Sec. 3.4</u>
(f) Post-DBE exposure	<u>Yes (Total of 30 days)</u>	<u>58722-2, Sec. 3.4</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>58722-2, Sec. 4.3</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes (Reference 58722-2, Appendix B).

JUSTIFICATION/COMMENTS 1) The report did not describe test specimen inspection; however Raychem has conducted many test programs and we have no reason to believe that inspection was not done.

2) See TAB B, Section P.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 12 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED WBR DATE 9/20/86 R R
CATION OF RAYCHEM HEAT SHRINK
CABLE SPLICES CHECKED B DATE 9/21/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference 58722-2, Sec. 3.3).

JUSTIFICATION/COMMENTS

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	58722-2, <u>Sec. 3.3.1</u>
Radiation exposure	<u>Yes</u>	58722-2, <u>Sec. 3.3.2</u>
Vibration (non-seismic) aging	<u>No*</u>	
Operational (electrical/mechanical/process) stress aging	<u>Yes*</u>	

JUSTIFICATION/COMMENTS See TAB B, Section P.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? Yes (Reference None)

JUSTIFICATION/COMMENTS See TAB B, Section P.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference 58722-2, Sec. 3.3.1).

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 13 OF 40
 R 3 R
 BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 APL
Qualification of Raychem Heat 7/25/90
Shrink Cable Splices CHECKED NMB DATE 9/21/86 AKK
7-26-90

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
 (Reference: IEEE 383-1974 & Raychem Reports EDR 5046 and EDR 5040).

JUSTIFICATION/COMMENTS All insulation materials are considered
susceptible to aging degradation.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference 58722-2, Section 3.3.1)

JUSTIFICATION/COMMENTS Analysis of heat aging data found in
Raychem Reports EDR 5046 and EDR 5040 (see TAB D).

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes
 (Reference 58722-2, Section 3.3.1)

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
<u>Temperature</u>	<u>90°C</u>	<u>150°C</u>	<u>90°C</u>
<u>Time</u>	<u>40 years</u>	<u>916.75 HRs</u>	<u>>40 years</u>

R3

JUSTIFICATION/COMMENTS For analysis see Raychem Reports
EDR 5046 (TAB D) and EDR 5040 (TAB D). Also see TAB C.

- (e) Was the Arrhenius methodology used for accelerated aging (Yes/no/NA)? Yes
 (Reference 58722-2, Section 3.3.1)

JUSTIFICATION/COMMENTS Also see Raychem Reports EDR 5046 and 5040.

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (Yes/no/NA)? No Reference NA.

JUSTIFICATION/COMMENTS See H(4)(g).

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 14 OF 40
R 1 R _____
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86
Qualification of Raychem Heat 12/1/86
Shrink Cable Splices CHECKED NMB DATE 9/20/86 WBN 2-2-88

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? Yes
(Reference: See below).

JUSTIFICATION/COMMENTS Rychem Reports EDR 5046 and EDR 5040. A failure mode of retaining 30% of initial elongation was used, since this resulted in the lowest activation energy and is considered the most conservative case.

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? No (Reference: NA).

JUSTIFICATION/COMMENTS Thermal aging calculation based on 90°C maximum conductor temperature.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (Yes/No/NA)? Yes (Reference: 58722-2, Section 3.3.2).

JUSTIFICATION/COMMENTS _____

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? No
(Reference: NA).

JUSTIFICATION/COMMENTS Splices were subjected to a total dose of 2.2×10^8 rads and passed all functional tests.

This dose exceeds the worst case dose at WBN. (See page R1 B-35).

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? Yes
(Reference: 58722-2, Section 3.3.2).

JUSTIFICATION/COMMENTS Aging and accident dose done at the same time at $5.7\text{E}+5$ rads/hour for 386 hours yielding TID of $2.2\text{E}+8$ rads.

BINDER NO. WBNEO-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 15 OF 40
R 1 R 3
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 CAG SPL
Qualification of Raychem Heat 12/5/88 6/4/90
Shrink Cable Splices CHECKED NMB DATE 9/21/86 WCG 202
12/6/88 7-26-90

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: 58722-2).

Section 3.2.2 and Table I).

Plant normal ambient radiation dose (rd) 1x10⁸ (See Section K)

Test exposure dose (rd) 2.2E+8 (accident included)

Test exposure dose rate (rd/hr) 5.7E+5

Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS Radiation dose and rate are acceptable in accordance with IEEE 383-1974.

(6) Vibration (nonseismic) Aging:

- (a) Were the effects of nonseismic vibration induced during normal and abnormal operation addressed in the qualification program* NA (Reference: NA).

JUSTIFICATION/COMMENTS Seismic concerns are not applicable to cable splicing systems which have inherently high damping and for which vibration is not a principal failure mode.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? NA (Reference: _____).

JUSTIFICATION/COMMENTS _____

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the binder.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 16 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 7/20/86 DATE 9/24/86 R R
CATION OF RAYCHEM HEAT SHRINK CHECKED B DATE 9/24/86
CABLE SPLICES

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes
(Reference _____)

JUSTIFICATION/COMMENTS See TAB B, Section P.

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference _____)

JUSTIFICATION/COMMENTS See TAB B, Section P.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes
(Reference 58722-2, Sec. 3.3.1).

Qualified life (Document in QMDS) 40 years at 90°C

JUSTIFICATION/COMMENTS Also see Raychem Reports EDR 5046 and EDR
5040. See TAB C for qualified life calculation.

R 1, R

1-4-54

67-1171
1-4-84

_____).

JUSTIFICATION/COMMENTS See TAB C for aging equivalent.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 40
 R 3 R
 BINDER TITLE Environmental COMPUTED HDR DATE 9/26/86 JKL
Qualification of Raychem Heat
Shrink Cable Splices CHECKED NMB DATE 9/21/86 ADR
 7-26-90

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis)

	Material/Property/Function	Radiation Threshold	Reference	Activation Energy	Reference
a.	<u>Raychem-52 Molding Material</u>			<u>1.30</u>	<u>EDR 5040</u> <u>and TAB C</u> R3
b.	<u>Raychem WCSF-N Sleeving</u>	<u>NA</u>	<u>NA</u>	<u>1.33</u>	<u>EDR 5046</u> <u>and TAB C</u>
c.					
d.					

JUSTIFICATION/COMMENTS The insulation material (polyolefin) and sealant are considered susceptible to thermal and radiation degradation. The test was done in accordance with IEEE 383-1974 and IEEE 323-1974 and the test values exceeded those values expected during a DBE. The test program included tests on all materials used in the splices; therefore, no material analysis is required.

116

BINDER NO. <u>WBNEQ-SPLC-001</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>19</u> OF <u>40</u>
			R <u>3</u> R
BINDER TITLE <u>Environmental</u>	COMPUTED <u>HDR</u>	DATE <u>9/20/86</u>	<u>HEU</u>
<u>Qualification of Raychem Heat</u>			<u>6/14/90</u>
<u>Shrink Cable Splices</u>	CHECKED <u>NMB</u>	DATE <u>9/21/86</u>	<u>20R</u>
			<u>2-26-90</u>

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1.) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference 58722-2, Section 1.0)

Identify Acceptance Criteria: IEEE 383-1974 criteria - Function Continuously during test then pass high-voltage withstand test after conclusion of DBE simulation.

- (2.) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference: See page 18.1.)

Identify baseline and functional testing: Immersed in water for 16 hours then IR measurements at 500 VDC and voltage withstand test with 3600 VAC hi-pot while still immersed in water.

JUSTIFICATION/COMMENTS

- (3.) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes
(Reference 58722-2. Section 3.4). 90A 11/11/90

JUSTIFICATION/COMMENTS 90A

| R3

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 20 OF 40
R 1 R _____
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 *12-2-88*
Qualification of Raychem Heat
Shrink Cable Splices CHECKED NMB DATE 9/21/86 *12-2-88*

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS R1

1) Functional Test Baseline (Ref. 58722-2 Section 3.1 and 3.2)

- Immersed in water for 16 hours
- Insulation resistance in water at 500 VDC
- 3600 VAC voltage withstand test in water

2) Post Thermal and Radiation Aging (Ref. 58722-2 Section 3.3.3) - Same as above (1)

3) DBE Exposure (Ref. 58722-2 Section 3.4; Fig. 4 and Table 3)

- Energized at 1000 volts AC at 90 amps (nominal)

4) Post DBE (Ref. 58722-2 Section 4.3)

- Same as above (1)

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 21 OF 40

R 1 B

BINDER TITLE Environmental COMPUTED HDR DATE 9/22/86 *WCS*

Qualification of Raychem Heat

Shrink Cable Splices CHECKED NMB DATE 9/22/86 *12-6-88*

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: 58722-2 sec 3.4).

JUSTIFICATION/COMMENTS Baseline testing consisted of insulation resistance at 500V DC voltage withstand at 3600 volts AC. The connection splices are qualified to the relevant industry standards and IEEE-383-1974.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>480V</u>	<u> </u>
Load	<u>NA</u>	<u> </u>
Frequency	<u>NA</u>	<u> </u>
Accuracy	<u>NA</u>	<u> </u>
Other(s)	<u> </u>	<u> </u>
	<u> </u>	<u> </u>
	<u> </u>	<u> </u>

R1

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 22 OF 40
 R 1 R 3
 BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 CAG HDR
Qualification of Raychem Heat 12/6/88 6/4/90
Shrink Cable Splices CHECKED NMB DATE 9/21/86 WCC HDR
 12/6/88 7-26-90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>MFG STD (600 volts or less)</u>	<u>See comments</u>
Load	<u>See Comments</u>	<u>See comments</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)		

JUSTIFICATION/COMMENTS The splice loading during
the DBE test is less than 90°C cable rating per National
Electric Code 1990. For the purpose of the qualification,
additional heat rise resulting from the difference between
these current values is calculated and added to the accident
profiles (see TAB C).

R3

(c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>1000 VAC</u>	<u>58722-2</u> <u>Sec. 3.4</u>
Load	<u>90 amps</u>	<u>58722-2</u> <u>Sec. 3.4</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	
Other(s)		

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 23 OF 40
R 1 R 3
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 CAG WCG
Qualification of Raychem Heat 12/1/88 WCG
Shrink Cable Splices CHECKED NMB DATE 9/21/86 WCG WCG
12/6/88 7-26-90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Worst case 47E235-42
and 47E235-76

(1) Normal Max

(a) Temperature (°F) 130

(b) Pressure (psig) 0.3

(c) Humidity (%) 80

(d) Radiation (rd) 1.0×10^8

(2) Abnormal Max

(a) Temperature (°F) 140

(b) Pressure (psig) 0.3

(c) Humidity (%) 100

(d) Radiation (rd) NA

(3) Process Interfaces: None.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal service conditions duration is less than eight hours per occurrence and total time is less than 1 percent of plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 327* Accident type LOCA/HELB

(b) Pressure (psig) 11.2 Accident type LOCA/HELB

(c) Humidity (%) 100 Accident type LOCA/HELB

(d) Radiation (rd) 4×10^7 gamma Accident type LOCA/HELB

(d) Radiation (rd) 4.7×10^8 beta Accident type LOCA/HELB

(e) Spray Type Yes (See L(2)) Accident type LOCA/HELB

* See TAB B, Section P for discussion on temperature for the MSLB in the steam valve rooms.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 24 OF 40
 R 1 R 1
 BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86
Qualification of Raychem Heat
Shrink Cable Splices CHECKED NMB DATE 9/21/86 12-2-88

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Refer to Watts Bar Environmental Data Drawing Series 47E235 and discussions in TAB B on Radiation and Temperature.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? No (Reference: NA).

- (7) Subject to submergence (Yes/No/NA)? Yes (Reference: See TAB B. Discussion page).

Identify initiation time and duration of submergence: NA

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes (Reference: GENNAL3-002 & 47E235-42).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: Splices are located in junction boxes which are conservatively assumed to be fabricated of 16 ga sheet steel which provides a beta reduction factor of $9.98E-2$. Therefore, the maximum beta dose the splices will be exposed to is $4.7E+07$ rads ($4.7E+8 \times 9.98E-2$). R1

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 25 OF 40
 R 3 R
 BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 11/5/90
Qualification of Raychem Heat
Shrink Cable Splices CHECKED NMB DATE 9/21/86 10/26/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time (days)	<u>100</u>	<u>31.3 days</u> <u>(See TAB C)</u>	<u>58722-2,</u> <u>Sec. 4.2</u> <u>(c), Fig. 6</u>
Temperature (°F)	<u>373***</u>	<u>442</u>	<u>58722-2,</u> <u>Fig. 6, (p10)</u>
Pressure	<u>25.6 psia</u>	<u>132 psig</u>	<u>58722-2,</u> <u>Fig. 6, (p10)</u>
Relative Humidity (%)	<u>100</u>	<u>100</u> <u>IEEE 323-1974</u> <u>(See L(2) for</u>	<u>58722-2,</u> <u>Sec. 5.0</u>
*Chemical Spray	<u>Yes</u>	<u>Justification</u>	<u>58722-2,</u> <u>Sec. 3.4</u>
**Radiation (rd)	<u>1.4 x 10⁸gamma</u> <u>4.7 x 10⁸beta</u>	<u>2.2E+8</u> <u>gamma</u>	<u>58722-2,</u> <u>Table 1,</u> <u>p 17</u>
Submergence	<u>No</u>	<u>No</u>	<u>TAB B, Sec. P,</u> <u>"Submergence"</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type. See discussion TAB B, Section P "Radiation."

***327°F + 46°F heat rise = 373°F

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile</u> <u>Envelopes Specified</u> <u>(Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>(Reference</u> <u>discussion</u> <u>Yes in Sect. P.)</u>	<u>58722-2,</u> <u>Fig. 6,</u> <u>(p 10)</u>
Pressure	<u>Yes</u>	<u>58722-2,</u> <u>Fig. 6,</u> <u>(p 10)</u>
Relative Humidity	<u>Yes (saturated steam)</u>	<u>58722-2,</u> <u>Sec. 5.0</u>
Chemical Spray	<u>Yes (see below)</u>	<u>58722-2,</u> <u>Sec. 3.4</u>
Submergence	<u>NA</u>	<u>TAB B, Sec. P,</u> <u>"Submergence"</u>

JUSTIFICATION/COMMENTS - All cables in containment at WBN are enclosed in conduit; therefore, the splices are not subject to direct impingement of chemical spray. Test chemical spray encompasses requirements for WBN composition. (See TAB B Discussion.)

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 26 OF 40
 BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 7/5/86 DATE 9/24/86 R R
CATION OF RAYCHEM HEAT SHRINK CHECKED 0 DATE 9/24/86
CABLE SPLICES

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>15°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>10%</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>10%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>10%</u> (equivalent)	<u>Yes*</u>
Voltage: +10% of rated value	<u>10%</u>	<u>Yes</u>
Frequency: +5% of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>2</u> <u>Transients</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS: Note: Margins noted are the difference between the required WBN values and the values of the test.

*Refer to TAB C for operating time evaluation.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 27 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 7/9/86 DATE 9/24/86 R R
CATION OF RAYCHEM HEAT SHRINK CHECKED 0 DATE 9/24/86
CABLE SPLICES

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference None).

JUSTIFICATION/COMMENTS To maintain mechanical and electrical
integrity and insulation characteristics during and following a
DBE to allow the cable to which the splice is attached to maintain
its required performance during all postulated service conditions.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference 58722-2, Section 5.0).

JUSTIFICATION/COMMENTS Ten of twelve test assemblies maintained
rated current and voltage during test. All sleeves passed voltage
withstand test and had high IR measurements. (See TAB B, Section P).

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference 58722-2, Section 5.0).

JUSTIFICATION/COMMENTS See M(2) above.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? No (Reference NA).

JUSTIFICATION/COMMENTS Time required is 100 days. Test included
31.3-day LOCA test only (See TAB C).

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 28 OF 40
R R
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED hsp DATE 9/20/86
CATION OF RAYCHEM HEAT SHRINK CHECKED B DATE 9/21/86
CABLE SPLICES

M. OPERABILITY TEST RESULTS (Continued)

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes
(Reference 58722-2, Section 5.0).

JUSTIFICATION/COMMENTS See TAB B, Discussion.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 29 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 7/09 DATE 9/20/86
CATION OF RAYCHEM HEAT SHRINK CHECKED 13 DATE 9/21/86
CABLE SPLICES

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See TAB G. There were no surveillance or
maintenance requirements identified from the vendor or test documentation;
however, TVA does have a maintenance and surveillance program at the
plant.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 30 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 7/24/86 DATE 7/24/86
CATION OF RAYCHEM HEAT SHRINK CHECKED 12 DATE 9/21/86
CABLE SPLICES

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>None taken</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>NA</u> <u>(type test)</u>
(b) Were specific features and failure modes and effects analyzed?	<u>NA</u> <u>(type test)</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u> <u>(type test)</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>NA</u> <u>(Type test)</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>NA</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA (aging)</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 31 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 2/2/86 DATE 9/24/86
CATION OF RAYCHEM HEAT SHRINK CHECKED B DATE 9/21/86
CABLE SPLICES

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 32 OF 40
BINDER TITLE ENVIRONMENTAL QUALIFI- COMPUTED 7/2/86 DATE 9/23/86
CATION OF RAYCHEM HEAT SHRINK CHECKED 10 DATE 9/21/86
CABLE SPLICES

O. SUMMARY OF REVIEW (Continued)

Yes/No/NA

- (15) Criteria regarding functional testing satisfied? Yes
- (a) Does the test plan/report specify an acceptance criteria for equipment performed? Yes
- (b) Was an initial base line test done to establish required performance characteristics? Yes
- (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? Yes
- (16) Criteria regarding instrument accuracy satisfied? Yes
- (17) Test duration margin (1 hour + function time) satisfied? Yes
- (a) Is the minimum specified operating time at least 1 hour? Yes
- (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? NA
- (18) Criteria regarding synergistic effects satisfied? Yes
- (19) Criteria regarding margins satisfied? Yes
- (20) Maintenance and surveillance requirements adequately identified? Yes

P. DISCUSSION

See continuation page.

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 33 OF 40
R 1 R _____
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 *12/5/84*
Qualification of Raychem Heat
Shrink Cable Splices CHECKED NMB DATE 9/21/86 *12/6/88*

THIS PAGE INTENTIONALLY LEFT BLANK

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 34 OF 40
R 1 R _____
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 12-5-88
Qualification of Raychem Heat
Shrink Cable Splices CHECKED NMB DATE 9/21/86 12-5-88

THIS PAGE INTENTIONALLY LEFT BLANK

BINDER NO. <u>WBNEQ-SPLC-001</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>35</u> OF <u>40</u>
			R <u>1</u> R <u>3</u>
BINDER TITLE <u>Environmental</u>	COMPUTED <u>HDR</u>	DATE <u>9/20/86</u>	CAG <u>THL</u>
<u>Qualification of Raychem Heat</u>			12/1/88 <u>8/16/90</u>
<u>Shrink Cable Splices</u>	CHECKED <u>NMB</u>	DATE <u>9/21/86</u>	WCG <u>THL</u>
			12/6/88 <u>8-17-90</u>

P. DISCUSSION (Continued)

A. Radiation

In their worst-case installed environment (inside containment), the total radiation exposure is 14×10^7 rads gamma (including 40-year dose of 1×10^8 rads) and a beta dose of 4.7×10^8 rads. The cables are routed in either rigid steel conduit or American Boa flexible conduit and are terminated in 16-gauge (minimum) sheet steel enclosures. The rigid steel conduit effectively blocks beta radiation completely. Per calculation GENAPS3-023 R0, all radiosensitive material contained in an enclosure formed of 26 gauge or thicker iron will receive a beta dose of no more than one percent of the free-field beta dose. Per calculation is WBNTSR-015, the minimum wall thickness of the American Boa Supra flex conduit is 5.9 mils. This type of conduit is made up of corrugated steel sections that are welded together. The sections are overlapped so that the outermost layers of the conduit are double thickness (11.8 mils). From Figure 1 of WBNTSR-015, it can be seen that the axial distance of each convex or concave section is so small (0.0492") that a typical 6" long flexible conduit (minimum length of Raychem WGSF sleeve is 6") is covered by approximately 50 convex portions (11.8 mils thick) and 50 concave portions (5.9 mils thick) along the length of the conduit. Therefore, it is reasonable to determine the beta reduction afforded by this conduit based on the average thickness of these two portions. For an average thickness of 8.8 mils ($5.9 \text{ mils} + 11.8 \text{ mils} / 2 = 8.8 \text{ mils}$), the corresponding beta dose reduction factor is 14 (See Figure 1 of GENAPS3-023). To conservatively calculate beta radiation transmitted through American Boa flexible conduit, only 70 percent of this factor is utilized. Applying a fraction of 0.102 ($1/9.8$) to the beta dose of 4.7×10^8 yields a dose of 4.8×10^7 . This dose added to the total gamma yields a worst case total 100 day radiation dose to the conductor insulation of 1.88×10^8 rads.

The worst-case radiation dose for inside containment installation is shown below:

40-year normal gamma dose	= 1.0×10^8 rads (reference TVA drawing 47E235-42)	R3
Accident gamma dose	= 4.0×10^7 rads (reference TVA drawing 47E235-42)	
Accident beta dose	= 4.8×10^7 rads (see above)	R3

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 35a OF 40
 R 1 R 3
 BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 CAG HFL
Qualification of Raychem Heat 12/6/88 2/4/90
Shrink Cable Splices CHECKED NMB DATE 9/21/86 WCG HDR
 12/6/88 7-26-90

P. DISCUSSION (Continued)

The 40-year dose plus accident dose with margin is calculated as:

40-year normal gamma dose = 10.0×10^7 rads
 Accident gamma dose = 4.0×10^7 rads
 Accident beta dose = 4.8×10^7 rads
 10-percent accident margin = 8.8×10^6 rads

| R3

| R3

1.968×10^8 rads = Total worst-case
 dose for a 40-year
 qualified life

| R3

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 36 OF 40
R 1 R
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 12/28/86
Qualification of Raychem Heat
Shrink Cable Splices CHECKED NMB DATE 9/21/86 12/28/86

P. DISCUSSION (Continued)

B. Submergence

|R1

The only safety related cables which have cable splices that are
subjected to submergence are connected to the following devices:

1-FSV-62-72	1-FSV-1-147
1-FSV-62-73	1-FSV-3-185
1-FSV-62-74	1-FSV-3-186
1-FSV-62-76	1-FSV-3-187
1-FSV-87-7	
1-FSV-87-8	

The required operating time for the above devices is one hour or
less. The cables become de-energized and failure of the splice
after this time would not be a safety concern (see EQ Binders
WBNEQ-SOL-006 and WBNEQ-SOL-003 for operating time justification).
No splices are required for submergence longer than the 1 hour
given above.

The splices are located in conduit and/or steel junction boxes and
therefore not exposed to the direct chemical spray solution. When
the conduit or junction box becomes submerged, the solution may
submerge the splice. The splices were subjected to the direct
chemical spray at a much higher pressure and temperature (than
plant accident conditions) for 31.3 days. Also the splices were
subjected to a 16 hour water bath prior to the performance of each
functional test cycle. The 31.3 day exposure to direct chemical
spray and the 42 hour water bath (3 at 16 hours) ensure that the
splices will not fail during the required 1 hour of submergence.

BINDER NO. <u>WBNEO-SPLC-001</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>37</u> OF <u>40</u>
			R <u>1</u> R <u>3</u>
BINDER TITLE <u>Environmental</u>	COMPUTED <u>HDR</u>	DATE <u>9/20/86</u>	CAG <u>12/5/88</u>
<u>Qualification of Raychem Heat</u>			<u>12/5/88</u>
<u>Shrink Cable Splices</u>	CHECKED <u>NMB</u>	DATE <u>9/21/86</u>	WCG <u>12/6/88</u>
			<u>7-26-90</u>

P. DISCUSSION (Continued)

C. Temperature

The maximum accident temperature the splices will be subjected to is 453°F (MSLB in steam valve rooms, see QIR NUMWBN90032, (B26 900226 251), but per QIR MNMWBN90057 (B26 900515 250), Raychem splices are only exposed to a peak accident ambient of 349° F. This peak temperature is enveloped by the peak temperature of the test profile with a margin of 93°F (see TAB B, Sect. L.(1)). In addition, the duration of the MSLB is short, i.e., the temperature reaches the peak of 349°F in about 580 seconds and then drops rapidly to 140°F in 40 seconds, while the accident temperature inside containment remains above 150°F for approximately 147,000 seconds after attaining a peak of 324.2°F (see WBN Generic Curve #4, B44 900222 803). Since the splices have been demonstrated to be qualified for use inside containment, they are qualified for the MSLB.

R3

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 38 OF 40
R 1 R _____
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 12-5-86
Qualification of Raychem Heat
Shrink Cable Splices CHECKED NMB DATE 9/21/86 12-6-86

THIS PAGE INTENTIONALLY LEFT BLANK

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 39 OF 40
R 1 R _____
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 RTA
Qualification of Raychem Heat 12-9-85
Shrink Cable Splices CHECKED NMB DATE 9/21/86 WCD
12-6-88

THIS PAGE INTENTIONALLY LEFT BLANK

BINDER NO. WBNEQ-SPLC-001 PLANT WBN UNIT(S) 1 SHEET 40 OF 40
R 1 R _____
BINDER TITLE Environmental COMPUTED HDR DATE 9/20/86 WCH
Qualification of Raychem Heat 12-1-88
Shrink Cable Splices CHECKED NMB DATE 9/21/86 WCH
12-6-88

THIS PAGE INTENTIONALLY LEFT BLANK

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R 3 R 5
DER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 JDH JDH
3/7/90 9/14/90
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86 WCG
3/21/90

DISCUSSION FOR TAB A

1. This binder addresses the qualification of General Electric
CR151B terminal blocks which have been installed in category A/B
Class 1E harsh environment junction boxes at WBN. Field verification
for the terminal blocks is provided in TAB F. The qualification
on any General Electric terminal blocks supplied by a manufacturer
with his equipment package is addressed in the binder(s) for that
equipment. |R5
2. Since the terminal blocks are in many safety-related circuits, some
of which are required to operate for 100 days following an accident,
the category and operating times for all terminal blocks are
designated as "a" and "100 days", respectively, for all accidents. |R5
3. The terminal block EQIS and unit device identification nos. are
synonymous with the junction box EQIS and unit device identification
nos. except for the component function code (TBLK). There are
multiple terminal blocks in some junction boxes; however, each
individual terminal block within a junction box is not identified. |R5

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 1 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-276-L182A TERMINAL BLOCK	-D	1-TBLK-276-L182A CR151B	-D 183	721' 6" VARIOUS	FN2	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-276-L182B TERMINAL BLOCK	-D	1-TBLK-276-L182B CR151B	-D 181	721' 6" VARIOUS	FN2	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-276-L183A TERMINAL BLOCK	-E	1-TBLK-276-L183A CR151B	-E 005	721' 6" VARIOUS	FN1	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-276-L183B TERMINAL BLOCK	-E	1-TBLK-276-L183B CR151B	-E 002	721' 6" VARIOUS	FN1	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-276-L183C TERMINAL BLOCK	-B	1-TBLK-276-L183C CR151B	-B 359	721' 6" VARIOUS	FN1	A	100D	ALL	DISTRIBUTE POWER

PAGE A-2

RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JPH
10/16/90
10-31-91

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 2 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-276-L196 TERMINAL BLOCK	-D 1-TBLK-276-L196 CR151B	-D	713' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-276-L197 TERMINAL BLOCK	-E 1-TBLK-276-L197 CR151B	-E	713' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-276-L216 TERMINAL BLOCK	-A 1-TBLK-276-L216 CR151B	-A	713' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-276-L217 TERMINAL BLOCK	-A 1-TBLK-276-L217 CR151B	-A	737' VARIOUS	A05	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-0004 TERMINAL BLOCK	-A 1-TBLK-292-0004 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER

PAGE

A-3

RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDL
7/26/90
HDL
11-30-91

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 3 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION	
				ELEV(1) CONTRACT	RM/RAD					
WBN-2-TBLK-292-0006 TERMINAL BLOCK	-B	2-TBLK-292-0006 CR151B	-B	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER	RS
WBN-0-TBLK-292-0228 TERMINAL BLOCK	-A	0-TBLK-292-0228 CR151B	-A	729' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER	
WBN-0-TBLK-292-0229 TERMINAL BLOCK	-B	0-TBLK-292-0229 CR151B	-B	729' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER	
WBN-1-TBLK-292-0358 TERMINAL BLOCK	-B	1-TBLK-292-0358 CR151B	-B	692' VARIOUS	A12	A	100D	ALL	DISTRIBUTE POWER	
WBN-1-TBLK-292-0359 TERMINAL BLOCK	-B	1-TBLK-292-0359 CR151B	-B	692' VARIOUS	A13	A	100D	ALL	DISTRIBUTE POWER	

PAGE

A-4

RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDL
10/16/90
NDR
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 4 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT</u>	<u>DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u> <u>(2)</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-TBLK-292-0530 TERMINAL BLOCK	-B	1-TBLK-292-0530 CR151B	-B	729' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-0540 TERMINAL BLOCK	-A	1-TBLK-292-0540 CR151B	-A	729' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-0567 TERMINAL BLOCK	-A	1-TBLK-292-0567 CR151B	-A	676' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-0569 TERMINAL BLOCK	-B	1-TBLK-292-0569 CR151B	-B	676' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-0593 TERMINAL BLOCK	-A	1-TBLK-292-0593 CR151B	-A	737' VARIOUS	A05	A	100D	ALL	DISTRIBUTE POWER

PAGE

A-5

RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5

R

R

JOH
10/16/90
HCVL
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 5 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-TBLK-292-0748 TERMINAL BLOCK	-B	1-TBLK-292-0748 CR151B	-B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-0772 TERMINAL BLOCK	-B	1-TBLK-292-0772 CR151B	-B	676' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-0773 TERMINAL BLOCK	-A	1-TBLK-292-0773 CR151B	-A	676' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-0846 TERMINAL BLOCK	-B	1-TBLK-292-0846 CR151B	-B	692' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-0847 TERMINAL BLOCK	-A	1-TBLK-292-0847 CR151B	-A	692' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER

PAGE A-6 R5

PREPARER/DATE J.L.H 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDL
10/16/90
MSR
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 6 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-292-1005 TERMINAL BLOCK	-A	1-TBLK-292-1005 CR151B	-A	737' VARIOUS	A05	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1006 TERMINAL BLOCK	-B	1-TBLK-292-1006 CR151B	-B	737' VARIOUS	A05	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-1008 TERMINAL BLOCK	-B	2-TBLK-292-1008 CR151B	-B	737' VARIOUS	A09	A	100D	ALL	DISTRIBUTE POWER
WBN-0-TBLK-292-1163 TERMINAL BLOCK	-B	0-TBLK-292-1163 CR151B	-B	757' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER
WBN-0-TBLK-292-1164 TERMINAL BLOCK	-A	0-TBLK-292-1164 CR151B	-A	757' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER

PAGE A-7 K5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDH
10/16/90
7/26/86
10-30-80

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 7 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
WBN-1-TBLK-292-1189 TERMINAL BLOCK	-A	1-TBLK-292-1189 CR151B	-A	692' VARIOUS	A09	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1190 TERMINAL BLOCK	-B	1-TBLK-292-1190 CR151B	-B	692' VARIOUS	A10	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1195 TERMINAL BLOCK	-A	1-TBLK-292-1195 CR151B	-A	692' VARIOUS	A13	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1196 TERMINAL BLOCK	-B	1-TBLK-292-1196 CR151B	-B	692' VARIOUS	A12	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1235 TERMINAL BLOCK	-A	1-TBLK-292-1235 CR151B	-A	713' VARIOUS	A13	A	100D	ALL	DISTRIBUTE POWER

R5

PAGE A-8 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.O. 7/26/86

R 5 R R
JDA
10/16/90
NDR
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 8 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-TBLK-292-1246 TERMINAL BLOCK	-A	1-TBLK-292-1246 CR151B	-A	713' VARIOUS	A13	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1352 TERMINAL BLOCK	-A	1-TBLK-292-1352 CR151B	-A	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1353 TERMINAL BLOCK	-A	1-TBLK-292-1353 CR151B	-A	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1354 TERMINAL BLOCK	-B	1-TBLK-292-1354 CR151B	-B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1355 TERMINAL BLOCK	-B	1-TBLK-292-1355 CR151B	-B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER

PAGE A - 9 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JLH
10/16/90
HOR
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 9 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION		UNIT DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
WBN-1-TBLK-292-1356 TERMINAL BLOCK	-A	1-TBLK-292-1356	-A CR151B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1357 TERMINAL BLOCK	-A	1-TBLK-292-1357	-A CR151B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1358 TERMINAL BLOCK	-B	1-TBLK-292-1358	-B CR151B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1367 TERMINAL BLOCK	-A	1-TBLK-292-1367	-A CR151B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1368 TERMINAL BLOCK	-B	1-TBLK-292-1368	-B CR151B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER

PAGE A - 10 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JAH
10/16/90
7/26/86
10-30-80

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 10 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-292-1369 TERMINAL BLOCK	-A	1-TBLK-292-1369 CR151B	-A	713' VARIOUS	A28	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-1370 TERMINAL BLOCK	-A	1-TBLK-292-1370 CR151B	-A	713' VARIOUS	A28	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-1371 TERMINAL BLOCK	-B	1-TBLK-292-1371 CR151B	-B	713' VARIOUS	A28	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-1391 TERMINAL BLOCK	-S	1-TBLK-292-1391 CR151B	-S	692' VARIOUS	A01	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-1421 TERMINAL BLOCK	-A	1-TBLK-292-1421 CR151B	-A	713' VARIOUS	A12	A	100D	ALL DISTRIBUTE POWER

PAGE A-11 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.O. 7/26/86

R 5 R R
JCH
10/16/90
AKV
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 11 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMUTH	ELEV(1) CONTRACT				
WBN-1-TBLK-292-1422 TERMINAL BLOCK	-B	1-TBLK-292-1422	-B CR151B		713' VARIOUS	A11	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-1425 TERMINAL BLOCK	-A	1-TBLK-292-1425	-A CR151B		713' VARIOUS	A07	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-1426 TERMINAL BLOCK	-B	1-TBLK-292-1426	-B CR151B		713' VARIOUS	A07	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-1446 TERMINAL BLOCK	-B	1-TBLK-292-1446	-B CR151B		713' VARIOUS	A06	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-1447 TERMINAL BLOCK	-A	1-TBLK-292-1447	-A CR151B		713' VARIOUS	A06	A	100D	ALL DISTRIBUTE POWER

PAGE A - 12 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDH
10/10/90
HCR
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 12 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMUTH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-2-TBLK-292-1448 TERMINAL BLOCK	-B	2-TBLK-292-1448	-B CR151B	713' VARIOUS	A19	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-1449 TERMINAL BLOCK	-A	2-TBLK-292-1449	-A CR151B	713' VARIOUS	A19	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1502 TERMINAL BLOCK	-A	1-TBLK-292-1502	-A CR151B	713' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-1503 TERMINAL BLOCK	-A	2-TBLK-292-1503	-A CR151B	713' VARIOUS	A19	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1504 TERMINAL BLOCK	-B	1-TBLK-292-1504	-B CR151B	713' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER

PAGE A - 13 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JLH
10/16/90
2/10/92
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 13 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT						
WBN-2-TBLK-292-1505 TERMINAL BLOCK	-B	2-TBLK-292-1505 CR151B	-B	713' VARIOUS		A19	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1512 TERMINAL BLOCK	-A	1-TBLK-292-1512 CR151B	-A	729' VARIOUS		A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1514 TERMINAL BLOCK	-A	1-TBLK-292-1514 CR151B	-A	729' VARIOUS		A02	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1516 TERMINAL BLOCK	-B	1-TBLK-292-1516 CR151B	-B	729' VARIOUS		A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1518 TERMINAL BLOCK	-B	1-TBLK-292-1518 CR151B	-B	729' VARIOUS		A02	A	100D	ALL	DISTRIBUTE POWER

R5

PAGE A - 14 R5

PREPARER/DATE J.L.H. 7/26/86
CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JLH
10/16/90
10-31-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 14 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION		UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
WBN-1-TBLK-292-1543 TERMINAL BLOCK	-A	1-TBLK-292-1543 CR151B	-A	692' VARIOUS	A07	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1544 TERMINAL BLOCK	-B	1-TBLK-292-1544 CR151B	-B	692' VARIOUS	A07	A	100D	ALL	DISTRIBUTE POWER
WBN-0-TBLK-292-1547 TERMINAL BLOCK	-A	0-TBLK-292-1547 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-0-TBLK-292-1548 TERMINAL BLOCK	-B	0-TBLK-292-1548 CR151B	-B	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1549 TERMINAL BLOCK	-A	1-TBLK-292-1549 CR151B	-A	737' VARIOUS	A05	A	100D	ALL	DISTRIBUTE POWER

PAGE A-15 25

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JCH
10/16/90
RCH
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 15 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-2-TBLK-292-1550 TERMINAL BLOCK	-A	2-TBLK-292-1550 CR151B	-A	737' VARIOUS	A09	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-1551 TERMINAL BLOCK	-B	1-TBLK-292-1551 CR151B	-B	737' VARIOUS	A05	A	100D	ALL DISTRIBUTE POWER
WBN-2-TBLK-292-1552 TERMINAL BLOCK	-B	2-TBLK-292-1552 CR151B	-B	737' VARIOUS	A09	A	100D	ALL DISTRIBUTE POWER
WBN-2-TBLK-292-1553 TERMINAL BLOCK	-A	2-TBLK-292-1553 CR151B	-A	692' VARIOUS	A25	A	100D	ALL DISTRIBUTE POWER
WBN-2-TBLK-292-1554 TERMINAL BLOCK	-B	2-TBLK-292-1554 CR151B	-B	692' VARIOUS	A25	A	100D	ALL DISTRIBUTE POWER

PAGE A - 16 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDL
10/16/90
HSE
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 16 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
				CONTRACT		(2)			
WBN-2-TBLK-292-1555 TERMINAL BLOCK	-A	2-TBLK-292-1555 CR151B	-A	692' VARIOUS	A25	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-1556 TERMINAL BLOCK	-B	2-TBLK-292-1556 CR151B	-B	692' VARIOUS	A25	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1564 TERMINAL BLOCK	-A	1-TBLK-292-1564 CR151B	-A	692' VARIOUS	A08	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1565 TERMINAL BLOCK	-B	1-TBLK-292-1565 CR151B	-B	692' VARIOUS	A08	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1566 TERMINAL BLOCK	-B	1-TBLK-292-1566 CR151B	-B	692' VARIOUS	A08	A	100D	ALL	DISTRIBUTE POWER

PAGE A-17 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDL
10/16/90
HAK
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 17 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-292-1567 TERMINAL BLOCK	-A	1-TBLK-292-1567 CR151B	-A	692' VARIOUS	A08	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1598 TERMINAL BLOCK	-A	1-TBLK-292-1598 CR151B	-A	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1599 TERMINAL BLOCK	-B	1-TBLK-292-1599 CR151B	-B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1933 TERMINAL BLOCK	-S	1-TBLK-292-1933 CR151B	-S	692' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-0-TBLK-292-1942 TERMINAL BLOCK	-A	0-TBLK-292-1942 CR151B	-A	757' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER

PAGE A-18 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.O. 7/26/86

R 5 R R
JLH
10/16/90
E.T.O.
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 18 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-0-TBLK-292-1943 TERMINAL BLOCK	-B	0-TBLK-292-1943 CR151B	-B	757' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1964 TERMINAL BLOCK	-B	1-TBLK-292-1964 CR151B	-B	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1966 TERMINAL BLOCK	-A	1-TBLK-292-1966 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1968 TERMINAL BLOCK	-A	1-TBLK-292-1968 CR151B	-A	737' VARIOUS	A05	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1970 TERMINAL BLOCK	-B	1-TBLK-292-1970 CR151B	-B	737' VARIOUS	A05	A	100D	ALL	DISTRIBUTE POWER

PAGE A - 19 *RS*

PREPARER/DATE *J.L.H. 7/26/86*
CHECKED/DATE *E.T.D. 7/26/86*

R 5 R R
JDA
10/16/90
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 19 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-TBLK-292-1972 TERMINAL BLOCK	-B	1-TBLK-292-1972 CR151B	-B	729' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1974 TERMINAL BLOCK	-A	1-TBLK-292-1974 CR151B	-A	729' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1985 TERMINAL BLOCK	-A	1-TBLK-292-1985 CR151B	-A	729' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1986 TERMINAL BLOCK	-B	1-TBLK-292-1986 CR151B	-B	729' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-1987 TERMINAL BLOCK	-B	1-TBLK-292-1987 CR151B	-B	729' VARIOUS	A02	A	100D	ALL	DISTRIBUTE POWER

PAGE A-20 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDA
10/16/90
HCR
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 20 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
WBN-1-TBLK-292-1988 TERMINAL BLOCK	-A	1-TBLK-292-1988 CR151B	-A	729' VARIOUS	A02	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2007 TERMINAL BLOCK	-B	1-TBLK-292-2007 CR151B	-B	692' VARIOUS	A07	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2008 TERMINAL BLOCK	-A	1-TBLK-292-2008 CR151B	-A	692' VARIOUS	A07	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2012 TERMINAL BLOCK	-B	1-TBLK-292-2012 CR151B	-B	713' VARIOUS	A13	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2013 TERMINAL BLOCK	-A	1-TBLK-292-2013 CR151B	-A	713' VARIOUS	A13	A	100D	ALL	DISTRIBUTE POWER

PAGE A-21 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDA
10/16/90
HDC
10-30-90

R5

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 21 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMITH	ELEV(1) CONTRACT				
WBN-1-TBLK-292-2063 TERMINAL BLOCK	-A	1-TBLK-292-2063	-A CR151B		692' VARIOUS	A07	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-2064 TERMINAL BLOCK	-B	1-TBLK-292-2064	-B CR151B		692' VARIOUS	A07	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-2065 TERMINAL BLOCK	-A	1-TBLK-292-2065	-A CR151B		692' VARIOUS	A07	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-2066 TERMINAL BLOCK	-B	1-TBLK-292-2066	-B CR151B		692' VARIOUS	A07	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-2070 TERMINAL BLOCK	-	1-TBLK-292-2070	CR151B		737' VARIOUS	A05	A	100D	ALL DISTRIBUTE POWER

PAGE A-22

RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.O. 7/26/86

R 5 R R
JCH
10/16/90
10/30/90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 22 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	LOCATION		RM/RAD	CAT	OPER TIME	EVENT	SAFETY FUNCTION
			AZMITH	ELEV(1) CONTRACT					
WBN-1-TBLK-292-2071 TERMINAL BLOCK	-A	1-TBLK-292-2071 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2122 TERMINAL BLOCK	-A	1-TBLK-292-2122 CR151B	-A	713' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2140 TERMINAL BLOCK	-A	1-TBLK-292-2140 CR151B	-A	729' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2141 TERMINAL BLOCK	-B	1-TBLK-292-2141 CR151B	-B	729' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2202 TERMINAL BLOCK	-A	1-TBLK-292-2202 CR151B	-A	737' VARIOUS	A05	A	100D	ALL	DISTRIBUTE POWER

PAGE A - 23 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.O. 7/26/86

R 5 R R
JDL
10/16/90
HON
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 23 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-TBLK-292-2204 TERMINAL BLOCK	-A	1-TBLK-292-2204 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2205 TERMINAL BLOCK	-A	1-TBLK-292-2205 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2206 TERMINAL BLOCK	-A	1-TBLK-292-2206 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2207 TERMINAL BLOCK	-A	1-TBLK-292-2207 CR151B	-A	692' VARIOUS	A07	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2208 TERMINAL BLOCK	-B	1-TBLK-292-2208 CR151B	-B	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER

PAGE A-24 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.O. 7/26/86

R 5 R R
JDA
10/16/90
HGL
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 24 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	LOCATION		RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			AZMITH	ELEV(1) CONTRACT					
WBN-1-TBLK-292-2209 TERMINAL BLOCK	-B	1-TBLK-292-2209 CR151B	-B	737' VARIOUS	A05	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2211 TERMINAL BLOCK	-B	1-TBLK-292-2211 CR151B	-B	692' VARIOUS	A07	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2212 TERMINAL BLOCK	-B	1-TBLK-292-2212 CR151B	-B	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-2215 TERMINAL BLOCK	-	2-TBLK-292-2215 CR151B		737' VARIOUS	A09	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2234 TERMINAL BLOCK	-S	1-TBLK-292-2234 CR151B	-S	692' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER

PAGE A - 25 RS

PREPARER/DATE J.L.H. 7/26/86
CHECKED/DATE E.T.D. 7/26/86

R 5 R _____ R _____
JDL
10/16/90
HDL
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 25 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-TBLK-292-2236 TERMINAL BLOCK	-S	1-TBLK-292-2236 CR151B	-S	692' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2238 TERMINAL BLOCK	-S	1-TBLK-292-2238 CR151B	-S	692' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2242 TERMINAL BLOCK	-S	1-TBLK-292-2242 CR151B	-S	692' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2252 TERMINAL BLOCK	-A	1-TBLK-292-2252 CR151B	-A	757' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2257 TERMINAL BLOCK	-A	1-TBLK-292-2257 CR151B	-A	713' VARIOUS	A06	A	100D	ALL	DISTRIBUTE POWER

PAGE A-26 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
IDH
10/16/90
NON
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 26 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMITH	ELEV(1) CONTRACT				
WBN-1-TBLK-292-2260 TERMINAL BLOCK	-B	1-TBLK-292-2260	-B CR151B		713' VARIOUS	A06	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-2262 TERMINAL BLOCK	-B	1-TBLK-292-2262	-B CR151B		757' VARIOUS	A16	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-2265 TERMINAL BLOCK	-B	1-TBLK-292-2265	-B CR151B		737' VARIOUS	A01	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-2386 TERMINAL BLOCK	-B	1-TBLK-292-2386	-B CR151B		737' VARIOUS	A01	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-2387 TERMINAL BLOCK	-A	1-TBLK-292-2387	-A CR151B		737' VARIOUS	A01	A	100D	ALL DISTRIBUTE POWER

PAGE A-27 ^{RS}

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JAH
10/16/90
HGR
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 27 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION		UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
				CONTRACT		(2)			
WBN-1-TBLK-292-2388 TERMINAL BLOCK	-A	1-TBLK-292-2388 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-2389 TERMINAL BLOCK	-A	2-TBLK-292-2389 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-2390 TERMINAL BLOCK	-B	2-TBLK-292-2390 CR151B	-B	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-2391 TERMINAL BLOCK	-A	2-TBLK-292-2391 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2503 TERMINAL BLOCK	-B	1-TBLK-292-2503 CR151B	-B	676' VARIOUS	A08	A	100D	ALL	DISTRIBUTE POWER

PREPARER/DATE J.L.H. 7/26/86 JDH R 5 R
CHECKED/DATE E.T.D. 7/26/86 10/16/90 R
THSR R
10-30-90

PAGE A-28 RS

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 28 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
WBN-1-TBLK-292-2504 TERMINAL BLOCK	-A	1-TBLK-292-2504 CR151B	-A	676' VARIOUS	A09	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2507 TERMINAL BLOCK	-B	1-TBLK-292-2507 CR151B	-B	676' VARIOUS	A10	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-2508 TERMINAL BLOCK	-A	1-TBLK-292-2508 CR151B	-A	676' VARIOUS	A11	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-2761 TERMINAL BLOCK	-B	2-TBLK-292-2761 CR151B	-B	757' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER
WBN-2-TBLK-292-2762 TERMINAL BLOCK	-A	2-TBLK-292-2762 CR151B	-A	757' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER

PAGE A-29 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JPH
10/16/90
HCH
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 29 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			AZMITH CONTRACT	ELEV(1) RM/RAD				
WBN-0-TBLK-292-2765 TERMINAL BLOCK	-A	0-TBLK-292-2765 CR151B	-A	692' VARIOUS	A01	A	100D	ALL DISTRIBUTE POWER
WBN-0-TBLK-292-2766 TERMINAL BLOCK	-B	0-TBLK-292-2766 CR151B	-B	692' VARIOUS	A01	A	100D	ALL DISTRIBUTE POWER
WBN-0-TBLK-292-2856 TERMINAL BLOCK	-A	0-TBLK-292-2856 CR151B	-A	737' VARIOUS	A01	A	100D	ALL DISTRIBUTE POWER
WBN-0-TBLK-292-2894 TERMINAL BLOCK	-B	0-TBLK-292-2894 CR151B	-B	737' VARIOUS	A01	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-3032 TERMINAL BLOCK	-B	1-TBLK-292-3032 CR151B	-B	713' VARIOUS	A28	A	100D	ALL DISTRIBUTE POWER

PAGE A-30

R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDL
10/16/90
HOC
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 30 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-292-3033 TERMINAL BLOCK	-A	1-TBLK-292-3033 CR151B	-A	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-3208 TERMINAL BLOCK	-A	1-TBLK-292-3208 CR151B	-A	692' VARIOUS	A07	A	100D	ALL	DISTRIBUTE POWER
WBN-0-TBLK-292-3213 TERMINAL BLOCK	-B	0-TBLK-292-3213 CR151B	-B	692' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-3214 TERMINAL BLOCK	-B	1-TBLK-292-3214 CR151B	-B	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-0-TBLK-292-3215 TERMINAL BLOCK	-A	0-TBLK-292-3215 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER

PAGE A-31 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDH
10/16/90
KOR
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 31 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-0-TBLK-292-3341 TERMINAL BLOCK	-B	0-TBLK-292-3341 CR151B	-B	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-0-TBLK-292-3342 TERMINAL BLOCK	-A	0-TBLK-292-3342 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-3422 TERMINAL BLOCK	-A	1-TBLK-292-3422 CR151B	-A	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-3423 TERMINAL BLOCK	-B	1-TBLK-292-3423 CR151B	-B	713' VARIOUS	A28	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-3870 TERMINAL BLOCK	-A	1-TBLK-292-3870 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER

PAGE A-32 R5

PREPARER/DATE J.L.H. 7/26/86
CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDA
10/16/90
HON
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 32 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-292-4011 TERMINAL BLOCK	-A	1-TBLK-292-4011 CR151B	-A	729' VARIOUS	A01	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-4013 TERMINAL BLOCK	-A	1-TBLK-292-4013 CR151B	-A	737' VARIOUS	A05	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-4015 TERMINAL BLOCK	-B	1-TBLK-292-4015 CR151B	-B	737' VARIOUS	A05	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-4026 TERMINAL BLOCK	-B	1-TBLK-292-4026 CR151B	-B	737' VARIOUS	A05	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-292-4027 TERMINAL BLOCK	-A	1-TBLK-292-4027 CR151B	-A	737' VARIOUS	A05	A	100D	ALL DISTRIBUTE POWER

PAGE A - 33 15

PREPARER/DATE J.L.H. 7/26/86
CHECKED/DATE E.T.D. 7/26/86
R 5 R R
10/16/90
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 33 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-TBLK-292-4166 TERMINAL BLOCK	-A	1-TBLK-292-4166 CR151B	-A	729' VARIOUS	A04	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-4167 TERMINAL BLOCK	-B	1-TBLK-292-4167 CR151B	-B	729' VARIOUS	A04	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-4275 TERMINAL BLOCK	-A	1-TBLK-292-4275 CR151B	-A	737' VARIOUS	A01	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-4984 TERMINAL BLOCK	-A	1-TBLK-292-4984 CR151B	-A	757' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-292-4985 TERMINAL BLOCK	-B	1-TBLK-292-4985 CR151B	-B	757' VARIOUS	A16	A	100D	ALL	DISTRIBUTE POWER

R5

PAGE A - 34 R5

PREPARER/DATE J.L.H. 7/26/86
CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDL
10/16/90
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 34 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-293-0159 TERMINAL BLOCK	-B	1-TBLK-293-0159 CR151B	-B	804' 3" VARIOUS	UC	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-293-0368 TERMINAL BLOCK	-B	1-TBLK-293-0368 CR151B	-B	806' VARIOUS	UC	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-293-0394 TERMINAL BLOCK	-A	1-TBLK-293-0394 CR151B	-A 045	706' VARIOUS	RW	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-293-0542 TERMINAL BLOCK	-A	1-TBLK-293-0542 CR151B	-A 234	736' 4" VARIOUS	AC3	A	100D	ALL DISTRIBUTE POWER
WBN-1-TBLK-293-0544 TERMINAL BLOCK	-A	1-TBLK-293-0544 CR151B	-A 248	754' VARIOUS	LC	A	100D	ALL DISTRIBUTE POWER

PAGE A -35 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDA
10/16/90
ADL
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 35 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	CONTRACT					
WBN-1-TBLK-293-0546 TERMINAL BLOCK	-B	1-TBLK-293-0546 CR151B	-B 300	724' 5"	ANN	A	100D		ALL	DISTRIBUTE POWER
				VARIOUS						
WBN-1-TBLK-293-0548 TERMINAL BLOCK	-B	1-TBLK-293-0548 CR151B	-B 248	753' 10"	ANN	A	100D		ALL	DISTRIBUTE POWER
				VARIOUS						
WBN-1-TBLK-293-0550 TERMINAL BLOCK	-A	1-TBLK-293-0550 CR151B	-A 287	792'	ANN	A	100D		ALL	DISTRIBUTE POWER
				VARIOUS						
WBN-1-TBLK-293-0553 TERMINAL BLOCK	-A	1-TBLK-293-0553 CR151B	-A 294	744' 6"	ANN	A	100D		ALL	DISTRIBUTE POWER
				VARIOUS						
WBN-1-TBLK-293-0574 TERMINAL BLOCK	-A	1-TBLK-293-0574 CR151B	-A 013	734' 9"	FN1	A	100D		ALL	DISTRIBUTE POWER
				VARIOUS						

PAGE A - 36 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JON
10/16/90
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 36 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-TBLK-293-0578 TERMINAL BLOCK	-B	1-TBLK-293-0578 CR151B	-B 349	730' 5" VARIOUS	FN1	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0596 TERMINAL BLOCK	-B	1-TBLK-293-0596 CR151B	-B 346	706' 7" VARIOUS	LC	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0656 TERMINAL BLOCK	-A	1-TBLK-293-0656 CR151B	-A 132	731' 7" VARIOUS	AC2	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0691 TERMINAL BLOCK	-A	1-TBLK-293-0691 CR151B	-A 213	706' VARIOUS	RW	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0724 TERMINAL BLOCK	-B	1-TBLK-293-0724 CR151B	-B 059	748' 6" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER

PAGE A-37 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDN
10/18/90
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 37 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-293-0745 TERMINAL BLOCK	-A	1-TBLK-293-0745 CR151B	-A 199	805' 8" VARIOUS	UC	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0760 TERMINAL BLOCK	-B	1-TBLK-293-0760 CR151B	-B 115	731' 4" VARIOUS	IIR	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0762 TERMINAL BLOCK	-A	1-TBLK-293-0762 CR151B	-A 105	751' 6" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0764 TERMINAL BLOCK	-A	1-TBLK-293-0764 CR151B	-A 060	740' 2" VARIOUS	IIR	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0766 TERMINAL BLOCK	-B	1-TBLK-293-0766 CR151B	-B 291	745' VARIOUS	AC4	A	100D	ALL	DISTRIBUTE POWER

PAGE A-38 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDL
10/16/90
2/20
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 38 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION		UNIT DEVICE ID NO. MODEL NUMBER	AZMITH MODEL NUMBER	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-TBLK-293-0768 TERMINAL BLOCK	-A	1-TBLK-293-0768 CR151B	-A 297	731' 4" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0775 TERMINAL BLOCK	-A	1-TBLK-293-0775 CR151B	-A 035	720' 4" VARIOUS	AC1	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0788 TERMINAL BLOCK	-A	1-TBLK-293-0788 CR151B	-A 287	727' 9" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0792 TERMINAL BLOCK	-B	1-TBLK-293-0792 CR151B	-B 285	722' VARIOUS	AC4	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-0795 TERMINAL BLOCK	-A	1-TBLK-293-0795 CR151B	-A 283	728' 9" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER

PAGE A - 39 RS

PREPARER/DATE J.L.H. 7/26/86 JDA R 5
CHECKED/DATE E.T.D. 7/26/86 10/16/90 R _____
10-30-90 R _____

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 39 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION		UNIT DEVICE ID NO. MODEL NUMBER		AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
WBN-1-TBLK-293-1034 TERMINAL BLOCK	-A	1-TBLK-293-1034 CR151B	-A	006	835' 9" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1036 TERMINAL BLOCK	-B	1-TBLK-293-1036 CR151B	-B	357	835' 9" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1255 TERMINAL BLOCK	-A	1-TBLK-293-1255 CR151B	-A	028	727' 10" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1277 TERMINAL BLOCK	-A	1-TBLK-293-1277 CR151B	-A	311	804' 10" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1283 TERMINAL BLOCK	-B	1-TBLK-293-1283 CR151B	-B	317	804' 10" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDH
10/16/90
10/30/90

PAGE A - 40 R5

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 40 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
					ELEV(1)	RM/RAD				
					CONTRACT		(2)			
WBN-1-TBLK-293-1285 TERMINAL BLOCK	-B	1-TBLK-293-1285	-B CR151B	319	804'10"	ANN	A	100D	ALL	DISTRIBUTE POWER
					VARIOUS					
WBN-1-TBLK-293-1287 TERMINAL BLOCK	-A	1-TBLK-293-1287	-A CR151B	313	804'10"	ANN	A	100D	ALL	DISTRIBUTE POWER
					VARIOUS					
WBN-1-TBLK-293-1576 TERMINAL BLOCK	-A	1-TBLK-293-1576	-A CR151B	100	787'	PRS	A	100D	ALL	DISTRIBUTE POWER
					VARIOUS					
WBN-1-TBLK-293-1736 TERMINAL BLOCK	-B	1-TBLK-293-1736	-B CR151B	304	738' 6"	AC4	A	100D	ALL	DISTRIBUTE POWER
					VARIOUS					
WBN-1-TBLK-293-1738 TERMINAL BLOCK	-B	1-TBLK-293-1738	-B CR151B	285	720'	AC4	A	100D	ALL	DISTRIBUTE POWER
					VARIOUS					

PAGE A - 41 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.O. 7/26/86

R 5 R R
JPH
10/16/90
10-30-80

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 41 OF 45

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-TBLK-293-1750 TERMINAL BLOCK	-A	1-TBLK-293-1750 CR151B	-A 308	724'10" VARIOUS	AC4	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1758 TERMINAL BLOCK	-B	1-TBLK-293-1758 CR151B	-B 280	719'10" VARIOUS	AC4	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1764 TERMINAL BLOCK	-B	1-TBLK-293-1764 CR151B	-B 285	719'11" VARIOUS	AC4	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1883 TERMINAL BLOCK	-B	1-TBLK-293-1883 CR151B	-B 165	727'11" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1885 TERMINAL BLOCK	-A	1-TBLK-293-1885 CR151B	-A 191	727'11" VARIOUS	ANN	A	100D	ALL	DISTRIBUTE POWER

PAGE A-42 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JDL
10/16/90
HDL
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 42 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1)	RM/RAD				
WBN-1-TBLK-293-1887 TERMINAL BLOCK	-A	1-TBLK-293-1887 CR151B	-A 007	725' 3"	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1889 TERMINAL BLOCK	-B	1-TBLK-293-1889 CR151B	-B 350	728' 2"	ANN	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-1921 TERMINAL BLOCK	-A	1-TBLK-293-1921 CR151B	-A 297	718' 1"	AC4	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-2649 TERMINAL BLOCK	-A	1-TBLK-293-2649 CR151B	-A	805' 7"	UC	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-3193 TERMINAL BLOCK	-B	1-TBLK-293-3193 CR151B	-B	784' 10"	UC	A	100D	ALL	DISTRIBUTE POWER

PAGE A-43 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JCH
10/16/90
HOK
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 43 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT</u>	<u>DEVICE ID NO.</u> <u>MODEL NUMBER</u>	<u>AZMITH</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u> <u>(2)</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-TBLK-293-3201 TERMINAL BLOCK	-B	1-TBLK-293-3201 CR151B	-B 285	720' 3" VARIOUS	AC4	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-3203 TERMINAL BLOCK	-A	1-TBLK-293-3203 CR151B	-A 235	721' 2" VARIOUS	AC3	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-3317 TERMINAL BLOCK	-B	1-TBLK-293-3317 CR151B	-B 280	732' 11" VARIOUS	AC4	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-4326 TERMINAL BLOCK	-D	1-TBLK-293-4326 CR151B	-D 30	720' 5" VARIOUS	LC	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-4328 TERMINAL BLOCK	-D	1-TBLK-293-4328 CR151B	-D 050	721' 11" VARIOUS	LC	A	100D	ALL	DISTRIBUTE POWER

PAGE A - 44 RS

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
JCH
10/16/90
7/26/86
10-20-80

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 44 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION		UNIT DEVICE ID NO. MODEL NUMBER	AZMITH NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-TBLK-293-4330 TERMINAL BLOCK	-E	1-TBLK-293-4330 CR151B	-E 150	721' 721' VARIOUS	LC	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-4332 TERMINAL BLOCK	-E	1-TBLK-293-4332 CR151B	-E 135	721' 3" 721' VARIOUS	LC	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-4334 TERMINAL BLOCK	-F	1-TBLK-293-4334 CR151B	-F 224	723' 7" 723' VARIOUS	LC	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-4336 TERMINAL BLOCK	-F	1-TBLK-293-4336 CR151B	-F 229	720' 8" 720' VARIOUS	LC	A	100D	ALL	DISTRIBUTE POWER
WBN-1-TBLK-293-4338 TERMINAL BLOCK	-G	1-TBLK-293-4338 CR151B	-G 333	720' 9" 720' VARIOUS	LC	A	100D	ALL	DISTRIBUTE POWER

PREPARER/DATE J.L.H. 7/26/86
CHECKED/DATE E.T.O. 7/26/86

R 5 R R
JOH
10/16/90
7/26/86
10-30-90

PRINT DATE: 10/10/90

BINDER NO. : WBNEQ-TB -001
MANUFACTURER : GENERAL ELECTRIC
PAGE 45 OF 45

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u> <u>DESCRIPTION</u>	<u>UNIT DEVICE ID NO.</u>	<u>AZMITH</u> <u>MODEL NUMBER</u>	<u>LOCATION</u> <u>ELEV(1)</u> <u>CONTRACT</u>	<u>RM/RAD</u>	<u>CAT</u> <u>(2)</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
WBN-1-TBLK-293-4340 TERMINAL BLOCK	-G 1-TBLK-293-4340	-G 315 CR151B	717' 1" VARIOUS	LC	A	100D	ALL	DISTRIBUTE POWER

PAGE A-46 R5

PREPARER/DATE J.L.H. 7/26/86

CHECKED/DATE E.T.D. 7/26/86

R 5 R R
J.D.H.
10/16/90
10-30-90

THIS PAGE INTENTIONALLY LEFT BLANK.

Page A-47 was deleted per revision 5.

THIS PAGE INTENTIONALLY LEFT BLANK

Pages A-48 thru A-50 were deleted per revision 3.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B1 OF B39
R 2 R 3
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/30/86 CAG JDH
9/18/89 3/7/90
TERMINAL BLOCKS CHECKED ETD DATE 7/30/86 WCG WCG
9/20/89 3-21-95

A. DOCUMENTATION

Equipment Description Terminal Block
Vendor/Manufacturer General Electric Company
Equipment Model No.(s) CR151B

QUALIFICATION REPORTS

- *(1) Title/Number/Revision "Nuclear Environ- RIMS B43 860514 501
mental Qualification Test Program on Terminal
Blocks and Cables for Tennessee Valley
Authority," Wyle Test Report
No. 17733-1, Revision B DATE 3/19/86
- (2) Title/Number/Revision _____ RIMS _____

DATE _____
- (3) Title/Number/Revision _____ RIMS _____

DATE _____

OTHER (ANALYSIS, VENDOR DATA, ETC.)

*The report addresses the qualification of terminal blocks
(coated and uncoated) and certain cables. Only the data on the
terminal blocks (specimens 1 through 20) is used in this binder.

|R3

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B1a OF B39
 R 3 R 5
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 JDH JDH
 3/7/90 10/16/90
 TERMINAL BLOCKS CHECKED ETD DATE 7/18/86 WCG HOK
 3/21/90 10-31-90

ADDITIONAL DOCUMENTATION

Other (Analysis, Vendor Data, etc) (Continued)

4. WBN-OSG4-048 R4 (B26 890510 504), "Equipment Submergence Requirements in Reactor Building."
5. WBNTSR-057R0 (B26 891221 201), "Beta Dose Reduction From Finite Volume."
6. TVA Environmental Drawing 47E235-Series (specifically 47E235-42 R2 and DCA P-04104-02-1 and DCA P-04104-03-0).
7. TVA Central Laboratories Technical Report M86-86-0032, dated November 13, 1985 (E13 851113 251), "TB Terminals From Sequoyah Nuclear Plant Environmental Qualification."
8. John A. Raulston memorandum, with attachments, to R. A. Sessoms dated November 20, 1985 (B45 851120 263).
9. WBNTSR-051R0 (B26 891129 202), Reduction of Beta by Sheet Steel.
10. TVA Central Laboratories Technical Report C186-86-1186, dated August 8, 1986 (E13 860808 251), "Examination of Electrical Terminal Blocks Manufactured by General Electric Company."
11. General Electric Company letter dated July 16, 1986 (B70 860721 100).
12. General Electric Company letter dated February 24, 1978. | R5

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B2 OF B39
R 1 R 2
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 CAG 1/17/89
1/18/89
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86 JFW 1/23/89
1/23/89

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified *
- ☐ Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES *The conclusion of equipment qualified is conditional depending upon resolution of the technical issues listed (see front of binder).

R2

COMMENTS/RECOMMENDATIONS The General Electric terminal blocks are qualified for inside and outside containment service for 40 years. The blocks are qualified for power and control applications in any area of the plant. TVA supplied and installed terminal blocks in local junction boxes inside containment and the main steam valve vault rooms are coated with Dow Corning RTV 3140 coating.

R2

R2

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE GENERAL ELECTRIC COMPUTED /R1 *CAH* DATE 1-23-84
TERMINAL BLOCKS CHECKED /R1 *AW* DATE 1-23-89

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-4 was deleted per revision 1 .

PAGE B-4

R1

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B3 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED J.H. DATE 7/26/86 R R
TERMINAL BLOCKS CHECKED E.T.D. DATE 7/26/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

 X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

 Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS NA

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE Standard 344-1975

10CFR50/Appendix B

ANSI N45.2

NEMA ICS4

UL 1059

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B4 OF B39
R 2 R _____
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 RLH _____
7-18-86
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86 WCR _____
9-20-89

D. QUALIFICATION METHODOLOGY (Check only one block)

_____ Test of Identical Item Under Identical Conditions or Under
Similar Conditions with Supporting Analysis

X Test of Similar Items with Supporting Analysis

Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

_____ Experience with Identical or Similar Equipment Under Similar
Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS	R2
------------------------	----

This image shows a single page of white paper with horizontal blue or grey ruling lines. The lines are evenly spaced and run across the width of the page, leaving small margins at the top and bottom. There is no handwriting or printed text on the page.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B5 OF B39
 R 5 R
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/26/86 JDH
10/16/90
 TERMINAL BLOCKS CHECKED ETD DATE 7/26/86 HEK
10-31-90

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? Yes

R5

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Terminal Block</u>	<u>Terminal Block</u>	<u>Page I-2, Par. 2.1</u>
(2) Manufacturer	<u>General Electric</u>	<u>General Electric</u>	<u>Page I-2, Par. 2.1</u>
(3) Model Number(s)	<u>CR151B Series</u>	<u>CR151B6</u>	<u>Page I-2, Par. 2.1</u>
(4) Serial Number(s)	<u>NA</u>	<u>NA</u>	<u>NA</u>
(5) Identify Component-	<u>NA</u>		
Unique checksheet attached:	<u></u>		

JUSTIFICATION/COMMENTS New CR151B6 blocks were tested in the Wyle Test Report No. 17733-1 Revision B, dated March 19, 1986. TVA concludes that the tested blocks' base material was mineral filled phenolic, rather than cellulose-filled phenolic, as Wyle concluded in the test program, since General Electric states in their letter to B. Hooper dated July 16, 1986 (See TAB E), that the block material was changed from cellulose-filled phenolic mineral-filled phenolic in May of 1983, approximately. This conclusion has been proven to be valid based upon a material analysis performed by TVA's Central Laboratories and documented in Report No. C186-86-1186 (see TAB C-3).

R5

The CR151B terminal blocks in TAB A are composed of a phenolic material, either cellulose-filled or mineral-filled. These two types of phenolic materials are similar in appearance, texture, and resistance to the effects of high temperatures.

R5

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-8 was deleted per revision 2.

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-9 was deleted per revision 5.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B8 OF B39
 BINDER TITLE GENERAL ELECTRIC COMPUTED JH DATE 7/16/86 R R
 TERMINAL BLOCKS CHECKED ERD DATE 7/18/86

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>Terminal Block</u>		<u>Page X-11,</u>
	<u>Mounting Screws</u>	<u>(3) Yes</u>	<u>Par. 3.2.1</u>
External Process Connections	<u>None</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>Terminal Lugs</u>		<u>Page I-2,</u>
	<u>(1) See Comment</u>	<u>(3) Yes</u>	<u>Par. 2.2.1</u>
Conduit Seals	<u>None</u>	<u>NA</u>	<u>NA</u>
Connector Seals	<u>None</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>Horizontal or Vertical</u>	<u>(2)(3) No</u>	<u>Page X-10,</u> <u>Par. 3.2.1</u>
Physical Configuration	<u>Mounted Inside Enclosures</u>	<u>(3) Yes</u>	<u>Page VIII-3,</u> <u>Par. 2.1.1</u>
			<u>Page I-2,</u> <u>Par. 2.2.1;</u> <u>Page VIII-3,</u> <u>Par. 2.1.1</u>
Other	<u>Junction Boxes and Jumper Wiring</u>	<u>(3)(4) Yes</u>	

JUSTIFICATION/COMMENTS (1) All terminations on terminal blocks at Watts Bar are made using prescribed materials and procedures per TVA General Construction Specification G-38. Included in G-38 are crimp type insulated and uninsulated terminals (tin coated for oxidation/corrosion inhibition and compatibility with terminal block materials) which are installed by using the appropriate terminal manufacturer's calibrated crimping tools. Sources for these terminals are the AMP Products Corp., Burndy Corp., and Thomas and Betts Company.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B9 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED JPH DATE 7/16/86 R R
TERMINAL BLOCKS CHECKED ESD DATE 7/18/86

F. INSTALLATION INTERFACES (Continued)

The performance of the terminals in the test confirms the suitability of these materials. Terminal blocks screws are tightened to provide a snug connection with terminals, unless otherwise instructed by terminal block or terminal vendors. These procedures are required by TVA General Construction Specification G-38, "Installing Insulated Cables Rated Up to 15,000 Volts," and Watts Bar Nuclear Plant Modifications and Additions Instruction M&AI-4, "Installation and Inspection of Cable Terminations."

(2) Terminal block orientation in test was vertical with open conduit entering top of box. This allowed the chemical spray entering junction box to flow or drip down terminal block across adjacent circuits, thus increasing chances of leakage currents and subsequent failure of the safety-related circuits. Although the blocks were not located directly under the conduit entry in the test, the possibility exists that some blocks may be located directly under top entry conduits at Watts Bar. But in the high accident pressure areas where steam/chemical spray might be forced into the boxes (i.e., containment and the main steam valve vault rooms), the conduit systems are closed to minimize this possibility and the terminal blocks are coated inside containment and the main steam valve vault rooms to help protect them. Also see note (3).

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B10 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED JPH DATE 7/16/86 R R
TERMINAL BLOCKS CHECKED SPD DATE 7/18/86

F. INSTALLATION INTERFACES (Continued)

(3) The standard physical configuration is to install terminal blocks in enclosures per the National Electrical Code Article 110-17 and the NEMA Standard Publication 250. The attachment of the terminal blocks to the enclosure internal panels by mounting screws, the attachment of wiring to the terminal blocks by terminal lugs, and the orientation of the terminal blocks within the enclosures are all standard considerations in all terminal block applications/installations and do not require any special considerations for QMDS. Terminal blocks in WBN safety-related circuits are installed in gasketed and ungasketed sheet steel enclosures (see Binder WBNEQ-JBOX-001). The enclosures provide a degree of physical protection but are not relied upon for environmental qualification other than for direct spray impingement. The Wyle test program, 17733-1, qualified terminal blocks installed in NEMA 12 (gasketed) enclosures. However, since the enclosures had weepholes drilled in them and they had open conduits entering them, the test essentially applied to ungasketed enclosures, also.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B11 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED 2PH DATE 7/16/86
TERMINAL BLOCKS CHECKED STL DATE 7/18/86

F. INSTALLATION INTERFACES (Continued)

(4) The environmental qualification of junction boxes and jumper wire interfaces of the terminal blocks is addressed in the following binders:

[illegible]

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B12 OF B39
 R 5 R
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/26/86 JDH
10/16/90
TERMINAL BLOCKS CHECKED ETD DATE 7/26/86 HMK
10-31-90

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	Page I-1, Par. 2.1
(b) Baseline performance measurements taken	<u>Yes</u>	Page I-3, Par. 2.3
(c) Equipment aged:		
Thermal	<u>Yes*</u>	Page IV-1, Par. 2.0
Radiation	<u>Yes</u>	Page II-1, Par. 2.0
Wear	<u>Yes</u>	See Page B-15 R5
(d) Vibration/seismic testing conducted	<u>Yes</u>	Page VI-2, Par. 2.0
(e) Design basis event (DBE) exposure	<u>Yes</u>	Page VIII-4, Par. 2.4
(f) Post-DBE exposure	<u>Yes</u>	Page VIII-4, Par. 2.4
(g) Final inspection and disassembly	<u>Yes</u>	Page IX-1, Par. 3.0

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes
 (Reference Page vii, paragraph 8.0).

JUSTIFICATION/COMMENTS *Only coated terminal blocks were thermally aged, since the Dow Corning RTV 3140 was considered to be sensitive to thermal aging. The uncoated blocks in the test were not thermally aged, since the thermal bock materials were deemed not age-sensitive to time-temperature effects (see 17733-1, page X-19, paragraph 3.6.5- and Page B-15). | R5

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B13 OF B39
R 5 R
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 JOK
12/16/90
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86 7/18/86
10-31-90

G.(1)(c) Thermal - The basis for evaluating the thermal sensitivity of each non-metallic material is to determine the expected life in its service environment. Per Wyle Test Report No. 17733-1, Page X-52, if the expected life is greater than 1,000 years for materials located in a mild environment, and 10,000 years for materials located in a harsh environment, the material is considered age insensitive for the application. Page X-32, Table II, gives the expected life of phenolic as 6×10^6 years at 49°C (120°F) and page X-30, Table I, states that phenolic is age insensitive.

A test report by R. M. Schuster of General Electric Company dated November 6, 1973, "Terminal Block LOCA Test for Electrical Penetration Assemblies" showed that terminal block performance was not significantly affected by high temperatures (260°F minimum and 340°F maximum during a 10-day test). See TAB E.

Sandia Laboratories Report No. NUREG/CR3691 dated September 1984, "An Assessment of Terminal Blocks in the Nuclear Power Industry," concluded that the terminal block phenolic material is not a significant factor to terminal block failures, but rather leakage currents caused by conductive film formation on the terminal block insulating surfaces. Several sources exist which contribute to the film formation: contaminants (dust, manufacturing residues, body salts from handling, etc.) in the block crevices and on its surfaces; corrosion of the block metallics (conductive strips, screws) and condensation formed from both normal and accident conditions.

G.(1)(c) Wear - The terminal blocks contain no moving parts and thus, wear aging is not appropriate for this equipment. The blocks are passive electrical devices that are energized at levels below the manufacturer's ratings (30A, 600V). Thus there are no electrical, mechanical, or process stresses induced in them.

R5

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B15 OF B39
R 3 R _____
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 JDH
3/7/90
TERMINAL BLOCKS _____ CHECKED ETD DATE 7/18/86 WCR
3-21-90

TEST SEQUENCE AND SYNERGISTIC EFFECTS, SECTIONS G AND H (3)

A review of NUREG/CR-2157 and 2932 determined that there are no known synergistic effects on the RTV coating material that would cause unsatisfactory performance of the terminal blocks. The terminal block materials were assumed to be insensitive to thermal aging effects, and the test program proved that they are not sensitive to radiation effects of the levels exposed. As shown in Sections I, III, and V of Wyle Test Report 17733-1 (see TAB D), the result of sequential radiation and thermal aging on the thermal block coating material was increased insulation resistance after each exposure from initial baseline measurements. No visible damage or degradation to the terminal blocks or coating had occurred. Because each exposure (thermal aging and radiation exposure) on its own increased the insulation resistance of the blocks, it is reasonable to conclude that the reverse sequence of exposure or simultaneous exposure to these parameters would have the same effect. It is concluded that sequence has no effect on these materials.

No dose rate synergisms are known to apply to the RTV or terminal block materials. Moisture is the only other environmental parameter that could have a potential synergistic effect on the terminal blocks. EPRI Report No. NP-2129, "Radiation Effects on Organic Materials in Nuclear Plants," states that cellulose-filled phenolics become more susceptible to moisture damage after irradiation. However, this phenomenon was not observed in Wyle Test Report 17733-1. Also, any moisture induced cracking of the phenolic insulating material would be minimized as the entire block is held intact and rigid by the mounting screws. In addition, changes in relative humidity could cause condensation to form on the terminals, thus increasing the chances of corrosion; however, terminal blocks in areas that experience periods of 100 percent relative humidity during nonaccident conditions (i.e., containment and the main steam valve vault rooms are coated with Dow Corning RTV 3140 coating.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B16 OF B39
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 JDH JDH
3-7-90 10/31/90
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86 WCG WCG
3-21-90 10-31-90

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
 (Reference: Section X, paragraph 3.6 through 3.6.4.1: Tables I and II; Appendix IV).

JUSTIFICATION/COMMENTS Phenolics were shown not to be
age-sensitive. (Refer to Justification/Comments, Section I). | R5

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Page X-15, paragraph 3.6).

JUSTIFICATION/COMMENTS _____

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Page X-16, paragraph 3.6.4.1: Page X-19, paragraph 3.6.5).

Parameter	Plant Maximum Normal	Test	Equivalent
Temperature	<u>130°F (54.4°C)</u>	<u>90°C</u>	<u>130°F (54.4°C)</u>
Time	<u>40-years</u>	<u>498 hrs</u>	<u>40-years</u>

 | R5

JUSTIFICATION/COMMENTS See Page B-19A

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Page X-49, Appendix IV).

JUSTIFICATION/COMMENTS _____

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes
 (Reference Page X-16, paragraph 3.6.4.1).

JUSTIFICATION/COMMENTS The RTV activation energy was used as the basis for the aging program because phenolics are not age-sensitive. Resultant age-conditioning was comparable to 40 years on the RTV coating. | R5

~~EQP127.31~~

BINDER NO. <u>WBNEQ-TB-001</u>	PLANT <u>WBN</u>	UNIT(S) <u>1</u>	SHEET <u>B17a</u> OF <u>B39</u>
			R <u>3</u> R <u>5</u>
BINDER TITLE <u>GENERAL ELECTRIC</u>	COMPUTED <u>R2/CAG</u>	DATE <u>9/18/89</u>	<u>JDH</u> <u>JDH</u>
			3/7/90 10/16/90
TERMINAL BLOCKS	CHECKED <u>R2/WCG</u>	DATE <u>9/20/89</u>	<u>WCG</u> <u>HCR</u>
			3/21/90 10-31-90

H. AGING (Continued)

4. (d) JUSTIFICATION/COMMENTS (continued)

Thermal aging performed in the Wyle 17733-1 test program equates to a qualified life of 40 years at 120°F and 14.2 R5 years at 130°F (maximum normal temperature in the MSVV rooms). Based on the following, however, the qualified life is extended to 40 years at 130°F.

The thermal aging program was performed to assess time-temperature effects on the RTV coating, since the terminal block phenolic material was determined to be insensitive to thermal aging effects over a 40-year lifetime for temperatures present at Watts Bar. Since the coating has a U.L. rating of 365°F (180°C) (per page X-17, Section 3.6.4.1.2 of 17733-1), it is reasonable to expect it to be qualified for 40 years at 130°F. The results of the 17733-1 test program revealed that there is little difference, if any, on terminal block performance during an accident whether or not they are coated. Therefore, for DBE qualification, the presence of RTV coating on the blocks is not required. However, as an added measure of conservatism, TVA applies the coating to blocks inside containment and the MSVV rooms to help protect the terminal block conducting materials (terminal screws and connector plates) from corrosion and potential leakage currents if the block is exposed to moisture.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B18 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED JPH DATE 7/16/86 R R
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86

H.(4)(h) JUSTIFICATION/COMMENTS - The terminal blocks were not energized during thermal aging sequence of Wyle test program 17733-1 for the following reasons:

1. The terminal blocks are passive devices. Thus, there is no need to monitor their performance during thermal aging.
2. Any temperature rise in the blocks' enclosures due to energization is negligible due to the following:
 - a. The results of the 17733-1 test program revealed that there is little difference, if any, on terminal block performance during an accident whether or not they are coated. Thus, the effect of temperature on the coating material is irrelevant. Wyle had concluded that the terminal block materials were not sensitive to time-temperature effects over a 40-year lifetime (page X-19, paragraph 3.6.5).
 - b. There is minimal thermal contribution from terminal blocks inside enclosures because: (1) instrumentation circuits operate with low current, thus there is no heat rise and (2) safety-related control circuits are operated only periodically.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B19 OF B39
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 R 1 R 2
TERMINAL BLOCKS CHECKED ETD DATE 7/16/86 CAG 16-64
 1/6/89 4-16-89
 JFW WCS
 1/6/89 9-20-89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: Page II-1

Para. 2.0).

Plant normal ambient radiation dose (rd) 2.0×10^7 gamma

Test exposure dose (rd) 2.534×10^8 gamma

Test exposure dose rate (rd/hr) $<1.0 \times 10^6$

Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS _____

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program* No (Reference: NA

_____).

JUSTIFICATION/COMMENTS Equipment installed in enclosures

which are rigidly mounted. See TAB C (pg C2). | R2

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? NA (Reference: NA).

JUSTIFICATION/COMMENTS _____

* Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the binder.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET ^{B20} OF ^{B39}
BINDER TITLE GENERAL ELECTRIC COMPUTED JPH DATE 7/16/86
TERMINAL BLOCKS CHECKED ETD DATE 7/13/86

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? No
(Reference NA).

JUSTIFICATION/COMMENTS See sheet B13.

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS See sheet B13.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes
(Reference Page v, paragraph 4.0).

Qualified life (Document in QMDS) 40-years

JUSTIFICATION/ COMMENTS

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B21 OF B39
R 1 R 1
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 1-17-84
TERMINAL BLOCKS CHECKED ETD DATE 7/16/86 1-23-84

H. AGING (Continued)

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? No
(Reference: See below

_____. R1

JUSTIFICATION/COMMENTS No replacement intervals; Terminal
blocks qualified for 40 years.

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

	<u>Radiation</u>	<u>Activation</u>		
<u>Material/Property/Function</u>	<u>Threshold</u>	<u>Reference</u>		
		<u>Energy</u>	<u>Reference</u>	
(a) <u>DOW Corning RTV 3140</u>	<u>unknown</u>	<u>Page X-30</u>	<u>1.61</u>	<u>Page X-30</u>
Coating				
(b)				
(c)				
(d)				
(e)				

JUSTIFICATION/COMMENTS The phenolic material forms the base of the terminal block and is used as the insulating material between circuits on the block. The RTV coating is used to help protect the terminal block conducting materials (terminal screws and connector plates) from corrosion and potential leakage currents if the block is exposed to moisture. The RTV activation energy was used as the basis for the thermal aging program because phenolics are not age-sensitive. The resultant age-conditioning was equivalent to 37 years on the terminal blocks that had the coating, the coating was aged to the equivalent of 40 years (activation energy 1.61). A detailed analysis for the phenolic and coating is presented in Wyle Test Report No. 17733-1, Section X, paragraphs 3.4 and 3.6.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B23 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED JZH DATE 7/16/86
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Page VIII-2, paragraph 1.5).

Identify Acceptance Criteria: The terminal blocks shall distribute sufficient power for proper operability of end devices during the LOCA test. Proper operability of (see sheet B24).

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Page VIII-2.

paragraph 1.5).

Identify baseline and functional testing: Insulation resistance
measurements after thermal aging, radiation exposure, seismic testing,
load current monitoring during accident simulation, and periodic
leakage current measurements during accident simulation.

JUSTIFICATION/ COMMENTS

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes
(Reference Page VIII-2, paragraph 1.5.1).

JUSTIFICATION/ COMMENTS

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B24 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED JPH DATE 7/16/86 R R
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86

J.(1)(Continued): end devices is defined as follows:

1. RTD End Devices - The output resistance shall be within ± 20 percent of the values recorded during the pre-LOCA operability checks.
2. Transmitter End Devices - The output currents shall be within ± 20 percent of the values recorded during the pre-LOCA operability checks.
3. Solenoid Valve End Devices - The solenoid valves shall remain energized during the LOCA test and not change state.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B25 OF B39
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 9/15/86 1-6-89
1-6-89
 TERMINAL BLOCKS CHECKED ETD DATE 9/15/86 1-6-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? No (Reference: NA).

JUSTIFICATION/COMMENTS See Page B-29. | R1

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) Parameter	Plant Normal Conditions	Reference
Voltage	<u>120 VAC, 125 VDC</u>	<u>NA</u>
Load	<u>NA (1)</u>	<u>NA (1)</u>
Frequency	<u>NA (1)</u>	<u>NA (1)</u>
Accuracy	<u>NA (2)</u>	<u>NA (2)</u>
Other(s)		

R1

JUSTIFICATION/COMMENTS (1) Electrical parameters
for terminal blocks, under specified accident conditions,
are the same as under plant normal conditions. The Watts
Bar terminal blocks are used in control applications
where control circuit loads range up to 1 amp (typically
these loads are less than 1 amp).

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B26 OF B39
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 9/15/86 R 1 R 1
1-17-89
TERMINAL BLOCKS CHECKED ETD DATE 9/15/86 QW
1-13-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(5)(b) Parameter	Specific Accident Conditions	Reference	R1
Voltage	<u>120 VAC, 125 VDC</u>	<u>NA</u>	
Load	<u>NA (1)</u>	<u>NA (1)</u>	
Frequency	<u>NA (1)</u>	<u>NA (1)</u>	
Accuracy	<u>NA (2)</u>	<u>NA (2)</u>	
Other(s)	<u></u>	<u></u>	

JUSTIFICATION/COMMENTS

(5)(c) Parameter	Demonstrated Conditions	Reference	R1
Voltage	<u>120 VAC, 125 VDC (3)</u>	<u>pV111-20</u>	
Load	<u>432ma, 108ma</u>	<u>pV111-20</u>	
Frequency	<u>NA</u>	<u>NA</u>	
Accuracy	<u>(2)</u>	<u>(2)</u>	
Other(s)	<u>NA</u>	<u>NA</u>	

JUSTIFICATION/COMMENTS (2) The test program was designed to determine the ability of the terminal blocks to provide sufficient power for proper operability of end devices during an accident at loads typical of those at Watts Bar. There are no 10CFR50.49 instrumentation transmitter and RTD circuits terminated on terminal blocks at Watts Bar. Therefore, accuracy is not a consideration. The demonstrated values of voltage and load throughout the test compared

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B26a OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED /R1 *Red* DATE 1-23-89 R R
TERMINAL BLOCKS CHECKED /R1 *gpc* DATE 1-23-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

(5)(c)

JUSTIFICATION/COMMENTS (continued)

close to values which were predetermined by pre-LOCA opera-
bility checks of the end devices.

(3) See TAB C, sheet C-9, for discussion of qualification of
terminal blocks for 480 VAC applications.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B27 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED JSH DATE 7/16/86 R R
TERMINAL BLOCKS CHECKED ETA DATE 7/18/86

J.(4) JUSTIFICATION/COMMENTS

Only insulation resistance measurements were performed for baseline testing. Testing for operability with test loads was considered unnecessary because terminal blocks are not complex equipment, and insulation resistance measurements and visual inspection did not provide indication to the contrary that the terminal blocks would not carry the load. Pre-accident simulation load conditions were established. See J.(5).

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B28 OF B39
 R 1 R 5
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 9/15/86 CAG JDH
 1/17/89 9/14/90
 TERMINAL BLOCKS CHECKED ETD DATE 9/15/86 JPW JDH
 1/23/89 10-31-90

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Worst case 47E235-42 and 47E235-76

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 130

(a) Temperature (°F) 140

(b) Pressure (psig) 0.3

(b) Pressure (psig) 0.3

(c) Humidity (%) 80

(c) Humidity (%) 100

(d) Radiation (rd) 2x10⁷

(d) Radiation (rd) NA

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Up to 8 hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) *340

Accident type HELB

(b) Pressure (psig) 11.2

Accident type LOCA/HELB

(c) Humidity (%) 100

Accident type LOCA/HELB

(d) Radiation (rd)** 4.7x10⁸ Beta
4.0x10⁷ Gamma

Accident type LOCA

(e) Spray Type Chemical

Accident type LOCA/HELB

*See page B-32 for discussion of this temperature.

**See TAB C, page C-105, for explanation of beta dose radiation and gamma equivalent calculation.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B29 OF B39
R 3 R 5
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 9/15/86 JDH JDH
3/7/90 9/14/90
TERMINAL BLOCKS CHECKED ETD DATE 9/15/86 WCG WCG
3/21/90 10-31-90

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): Spray duration is 30 days and flow rate is 0.92 gpm/ft². Spray composition is an alkaline borate solution (pH 8.3) produced by mixing boric acid with sodium tetraborate.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: Section P, Discussion). R5

- (7) Subject to submergence (Yes/No/NA)? No (Reference:). R5

Identify initiation time and duration of submergence:

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes
(Reference: WBNTSR-051, TVA DWG 47E235-42).

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: Terminal blocks are located in junction boxes which are conservatively assumed to be fabricated of 16 GA sheet steel which provides a beta reduction factor of 9.98E-02. Therefore, the max Beta dose the TB's will be exposed to is 4.7E+07 rads.

See page C-105.

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B, Section A

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET 5 OF 5
BINDER TITLE GENERAL ELECTRIC COMPUTED /R1 CAG DATE 1-23-89 JDK
10/16/90
TERMINAL BLOCKS CHECKED /R1 JPW DATE 1-23-89 JPW
10-31-90

K. REQUIRED OPERATING ENVIRONMENT (continued)

(5)(a)

Accident temperature: A peak temperature of 535°F occurs in the main steam valve rooms in the event of a main steam line break (MSLB) per TVA environmental drawing 47E235-76. However, QIR MNMWBN90057 documents a peak temperature exposure to the terminal block after the MSLB of 340°F for qualification purposes. This value will be revised after WBN specific thermal lag analysis is completed in 1991.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B30 OF B39
 R 3 R 5
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 9/15/86 JDH JDH
 3/7/90 9/14/90
TERMINAL BLOCKS CHECKED ETD DATE 9/15/86 WCG WCG
 3/21/90 10/31/90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>83 hours</u>	PP VIII-28, 29, 30 P X-26, Par. 3.10.7
Temperature (°F)	<u>340</u>	<u>350</u>	P VIII-28 R5
Pressure (psig)	<u>NA</u>	<u>NA</u>	<u>NA</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	P X-25, Par. 3.10.7 P VIII-28
*Chemical Spray	2000ppm boron <u>pH 8.3</u>	2000ppm boron <u>pH 8.3 + 1</u>	P VIII-4 Par. 2.4
Radiation (rd)	2.31E+08gamma and beta	2.53E+08gamma	p II-1 Par. 2.0
Submergence	<u>NA</u>	<u>NA</u>	<u>NA</u>

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

***See TAB C, page C-105, for Beta Radiation Dose Reduction Calculation

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	P VIII-28
Pressure	<u>Yes</u>	P VIII-28
Relative Humidity	<u>Yes</u>	P VIII-28
Chemical Spray	<u>Yes</u>	P VIII-4
Submergence	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B31 OF B39
 R 3 R 5
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/26/86 JDH JDH
 3/7/90 10/16/90
TERMINAL BLOCKS CHECKED ETD DATE 7/26/86 WCG WCG
 3/21/90 12/1-90

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	See Page B-32 10°F	Yes R5
Pressure: +10% but no more than 10 psig	(4) NA	NA
Radiation: +10% of accident dose	+ 10%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	None	Yes
Voltage: ±10% of rated value	(1) None	NA
Frequency: ±5% of rated value	(1) None	NA
Environmental Transient: the initial transient and the peak temperature applied twice	(2) NA	NA
Vibration: +10% added to acceleration	(3) NA	NA

JUSTIFICATION/COMMENTS (1) Only the necessary levels of voltage and frequency to operate the end devices were applied.

(2) Although required by IEEE-323(74), the twice applied environmental transient is generally recognized to not be needed if sufficient margin is added to the temperature and pressure parameters. This is consistent with the option provided in IEEE-323(83).

(3) The terminal blocks were qualified seismically as devices in the test program, which is more stringent than qualification as assemblies, which they are, as actually installed (mounted inside enclosures which are affixed to some rigid structure).

(4) Pressure is not a failure mode for terminal blocks.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B32 OF B39
R 5 R
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 JDH
9/14/90
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86 2/24/90
10-31-90

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference: Page X-9, paragraph 2.2).

JUSTIFICATION/COMMENTS The terminal blocks distribute sufficient power for proper operability of safety-related devices before, during, and after design basis accidents.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (Yes/No/NA)? Yes
(Reference: Page VIII-5, paragraph 3.0).

JUSTIFICATION/COMMENTS _____

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure
(Yes/No/NA)? Yes (Reference: Page VIII-5, paragraph 3.0).

JUSTIFICATION/COMMENTS _____

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (Yes/No/NA)? Yes (Reference: Page VIII-5, paragraph 3.0; TAB C, Page C-54).

| R5

JUSTIFICATION/COMMENTS _____

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (Yes/No/NA)? Yes
(Reference: Pages ii, iii, iv, v; paragraph 4.0).

JUSTIFICATION/COMMENTS Only Anomalies 1 and 2 are applicable to the terminal blocks being addressed in this binder. Anomalies 3-5 apply to cables which are addressed in other binders. See Section P for discussion of anomalies.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B33 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED JPH DATE 7/16/86 R R
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEETB34 OFB39
 R 3 R
 BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 JDN
3/7/90
 TERMINAL BLOCKS CHECKED ETD DATE 7/18/86 WCP
3-21-90

0. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|--|------------------|
| (1) Documented evidence of qualification adequate
(Have all assumptions, mathematical models, and all
extrapolations of test data used in an analysis been
justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary)
taken to the specified qualification level
adequately justified? | <u>NA</u> |
| (3) Choice of qualification methodology adequately
justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements
identified? | <u>Yes</u> |
| (b) Were specific features and failure modes and
effects analyzed? | <u>Yes</u> |
| (c) Were assumptions and mathematical models used
together with appropriate justification for
their use? | <u>Yes</u> |
| (d) Were environmental parameters which affect
equipment performance identified? | <u>Yes</u> |
| (5) Adequate similarity between equipment and test
specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u> |
| (b) Equipment aged to end of life condition prior
to application of DBE conditions? | <u>Yes</u> |
| (c) Absence of preaging in test/analysis justified? | <u>Yes</u> |
| (d) Materials susceptible to thermal/radiation
aging identified? | <u>Yes</u> |

R3

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B35 OF B39
 BINDER TITLE GENERAL ELECTRIC COMPUTED JTH DATE 7/16/86
 TERMINAL BLOCKS CHECKED EDD DATE 7/18/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B36 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED EPH DATE 7/16/86 R R
TERMINAL BLOCKS CHECKED ETD DATE 7/16/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>NA</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

See sheet B37.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B37 OF B39
R 2 R 3
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 9/18/86 CAG JDN
9/18/89 3/22/90
TERMINAL BLOCKS CHECKED ETD DATE 9/18/86 WGG WGT
9/20/89 3/22/90

P. DISCUSSION (Continued)

1. The terminal blocks are used to terminate circuits of safety-
related equipment inside and outside containment and applications
are in the 120 VAC and 125 VDC range. All 10CFR50-49
instrumentation transmitter and RTD circuits have been spliced out
at Watts Bar. This action was taken to relieve uncertainties due
to leakage currents which are inherent in low voltage instru-
mentation circuit/terminal block applications under accident
conditions and which degrade instrumentation signal levels/loop
accuracies. Wyle test program 17733-1 showed that leakage
currents are a potential problem for terminal blocks in accident
conditions, and corrosion is a contributing factor to the
leakage current. The test program also showed that coating of
terminations can reduce the levels of leakage currents. Coating
will also reduce corrosion effects during normal, nonaccident
conditions. TVA-supplied and installed terminal blocks used in
local junction boxes inside containment and the main steam
valve vault rooms at Watts Bar in safety-related circuits are
coated with Dow Corning RTV 3140.

R3

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B38 OF B39
R 3 R 3
BINDER TITLE GENERAL ELECTRIC COMPUTED JLH DATE 7/16/86 JDH
3/22/90
TERMINAL BLOCKS CHECKED ETD DATE 7/18/86 WCP
3/22/90

P. DISCUSSION (Continued)

The blocks are constructed of a phenolic material and are rated for
30 amps and 600 volts. They utilize screw terminals for circuit
wire connections. The terminal blocks are mounted in enclosures
to provide a degree of protection from the environment. All
10CFR50.49 terminal blocks are located above the maximum
postulated flood levels. Terminal block enclosures in areas
susceptible to high accident pressures (containment and the main
steam vault rooms) and areas subject to moisture intrusion (see
environmental drawings) have weep holes drilled in them. R3

Wyle Laboratories test program 17733-1 proved that the terminal R3
blocks are qualified for 40 years and will perform adequately
before, during, and after design basis accidents.

2. Anomalies that occurred during the Wyle Laboratories 17733-1
test program that could affect the terminal blocks' ability to
perform their safety functions are addressed below:

A. Anomaly No. 1: Terminal barriers on terminal block
specimens 2, 4, and 15 were broken during shipment from the
radiation facility. Since the functional operability of
the terminal blocks was demonstrated in subsequent
functional tests and accident testing, the damage does not
affect the qualification of the terminal blocks.

BINDER NO. WBNEQ-TB-001 PLANT WBN UNIT(S) 1 SHEET B39 OF B39
BINDER TITLE GENERAL ELECTRIC COMPUTED JPH DATE 7/16/86 R R
TERMINAL BLOCKS CHECKED E.T.D. DATE 7/18/86

P. DISCUSSION (Continued)

B. Anomaly No. 2: The output of the RTD end device for terminal block
specimens 4 and 9 was less than the required 1.04 mA (approximately
0.9 mA) after 15 hours into the LOCA test. Measurements taken on
the blocks revealed that specimen 4 was the problem. Testing was
continued successfully with specimen 9 only in the circuit. A
post-LOCA inspection of specimen 4 revealed a loose terminal screw.
The screw was tightened and the voltage was applied to specimen 4
only with the RTD end device. The output was normal, indicating
that the cause of the anomaly was probably the loose screw, and the
terminal block would have performed adequately in the test with the
tightened screw.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE BARTON 764 COMPUTED AT NR DATE 5/22/86
LOT 7 AND 4 CHECKED comple DATE 5/22/86

TAB A - Identification of Equipment
Comprising the Equipment Type

100-001

PRINT DATE: 14/90

BINDER NO. : WBNEQ-XMTR-C
MANUFACTURER : BARTON
PAGE 1 OF 7

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH CONTRACT	LOCATION		CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
WBN-1-FT -001-0003A -D 1-FT SG1 MAIN STEAM HDR FLOW CHAN 1	-001-0003A -D 764 LOT 7		(3) 71C62-54114-1	A A	5MIN 5MIN	MS/C FW/C	INITIATE SI & MS ISOLATION ON HIGH STM FLOW, INITIATE REAC TRIP ON LOW FW FLOW	
WBN-1-FT -001-0003B -E 1-FT SG1 MAIN STEAM HDR FLOW CHAN 2	-001-0003B -E 764 LOT 7		(3) 71C62-54114-1	A A	5MIN 5MIN	MS/C FW/C	INITIATE SI & MS ISOLATION ON HIGH STM FLOW, INITIATE REAC TRIP ON LOW FW FLOW	
WBN-1-FT -001-0010A -D 1-FT SG2 MAIN STEAM HDR FLOW CHAN 1	-001-0010A -D 764 LOT 7		(3) 71C62-54114-1	A A	5MIN 5MIN	MS/C FW/C	INITIATE SI & MS ISOLATION ON HIGH STM FLOW, INITIATE REAC TRIP ON LOW FW FLOW	
WBN-1-FT -001-0010B -E 1-FT SG2 MAIN STEAM HDR FLOW CHAN 2	-001-0010B -E 764 LOT 7		(3) 71C62-54114-1	A A	5MIN 5MIN	MS/C FW/C	INITIATE SI & MS ISOLATION ON HIGH STM FLOW, INITIATE REAC TRIP ON LOW FW FLOW	
WBN-1-FT -001-0021A -D 1-FT SG 3 MAIN STEAM HDR FLOW CHAN 1	-001-0021A -D 764 LOT 7		(3) 71C62-54114-1	A A	5MIN 5MIN	MS/C FW/C	INITIATE SI & MS ISOLATION ON HIGH STM FLOW, INITIATE REAC TRIP ON LOW FW FLOW	

PAGE A-2

R2

PREPARER/DATE A.W. Lewis 9/23/86

CHECKED/DATE D.D. Meyer 9/23/86

R 1	R 2	R
<u>WCG</u>	<u>WC97</u>	
<u>2-24-89</u>	<u>3-11-90</u>	
<u>HDR</u>	<u>HDR</u>	
<u>3-3-89</u>	<u>3-21-90</u>	

PRINT DATE: 07/06/90

BINDER NO. : WBNEQ-XMTR-001
MANUFACTURER : BARTON
PAGE 2 OF 7

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	AZMITH	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
			ELEV(1)	RM/RAD				
					(2)			
WBN-1-FT -001-0021B -E 1-FT -001-0021B -E SG 3 MAIN STEAM HDR FLOW CHAN 2 764 LOT 7			(3) 71C62-54114-1	A A	5MIN 5MIN	MS/C FW/C	INITIATE SI & MS ISOLATION ON HIGH STM FLOW, INITIATE REAC TRIP ON LOW FW FLOW	
WBN-1-FT -001-0028A -D 1-FT -001-0028A -D SG 4 MAIN STEAM HDR FLOW CHAN 1 764 LOT 7			(3) 71C62-54114-1	A A	5MIN 5MIN	MS/C FW/C	INITIATE SI & MS ISOLATION ON HIGH STM FLOW, INITIATE REAC TRIP ON LOW FW FLOW	
WBN-1-FT -001-0028B -E 1-FT -001-0028B -E SG 4 MAIN STEAM HDR FLOW CHAN 1 764 LOT 7			(3) 71C62-54114-1	A A	5MIN 5MIN	MS/C FW/C	INITIATE SI & MS ISOLATION ON HIGH STM FLOW, INITIATE REAC TRIP ON LOW FW FLOW	
WBN-1-LT -003-0038 -E 1-LT -003-0038 -E SG 1 LEVEL XMTR (NR) 764 LOT 7			(3) 71C62-54114-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MEASURES SG WATER LVL TO DETER MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI	
WBN-1-LT -003-0039 -F 1-LT -003-0039 -F SG 1 LEVEL XMTR (NR) 764 LOT 7			(3) 71C62-54114-1	A A A A A	100D 100D 100D 1MO 1MO	L MS/C FW/C RH/C CV/C	MEASURES SG WATER LVL TO DETER MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM	

PAGE A-3

PREPARER/DATE A.W. Lewis 9/23/86
CHECKED/DATE B.D. Meyer 9/23/86

R 1	R 2	R 4
WCG 3-24-89	WCG 3-21-90	WCG 5-30-90
HDR 3-3-89	HDR 3-21-90	HDR 8/3/90

PRINT DATE: 07/06/90

BINDER NO. : WBNEQ-XMTR-001
MANUFACTURER : BARTON
PAGE 3 OF 7

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMITH MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				ELEV(1) CONTRACT	RM/RAD				
WBN-1-LT -003-0042 SG 1 LEVEL XMTR (NR)	-G	1-LT -003-0042	-G 764 LOT 7	(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER	MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI
						100D	FW/C		
						100D	MS/C		
						1MO	RH/C		
						1MO	CV/C		
WBN-1-LT -003-0043 STM GEN 1 LEVEL WIDE RANGE	-F	1-LT -003-0043	-F 764 LOT 7	(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER	MINE IF A SG HAS BLOWN DRY. ALSO USED FOLLOWING RX TRIP WHEN THE NR LVL IS TEMPORARILY OFF SCALE. PAM
						100D	FW/C		
						100D	MS/C		
						1MO	RH/C		
						1MO	CV/C		
WBN-1-LT -003-0051 SG 2 LEVEL XMTR (NR)	-D	1-LT -003-0051	-D 764 LOT 7	(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER	MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI
						100D	MS/C		
						100D	FW/C		
						1MO	RH/C		
						1MO	CV/C		
WBN-1-LT -003-0052 SG 2 LEVEL XMTR (NR)	-F	1-LT -003-0052	-F 764 LOT 7	(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER	MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI
						100D	FW/C		
						100D	MS/C		
						1MO	CV/C		
						1MO	RH/C		
WBN-1-LT -003-0055 SG 2 LEVEL XMTR (NR)	-G	1-LT -003-0055	-G 764 LOT 7	(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER	MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI
						100D	MS/C		
						100D	FW/C		
						1MO	RH/C		
						1MO	CV/C		

PREPARER/DATE	A.W. Lewis 9/23/86	R 1	R 2	R 4
CHECKED/DATE	B.D. Meyer 9/23/86	WCG 2-24-89	WCG 3-21-90	WCG 8-30-90
		HDR 3-3-89	HDR 3-21-90	HDR 8-30-90

PAGE A-4

R4

PRINT DATE: 07/06/90

BINDER NO. : HBNEQ-XMTR-001
MANUFACTURER : BARTON
PAGE 4 OF 7

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	MODEL NUMBER	LOCATION		CAT	OPER TIME	EVENT	SAFETY FUNCTION
				AZMUTH	ELEV(1) RM/RAD				
					CONTRACT	(2)			
WBN-1-LT -003-0056 STM GEN 2 LEVEL WIDE RANGE	-G	1-LT -003-0056	-G 764 LOT 7		(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER MINE IF A SG HAS BLOWN DRY. ALSO USED FOLLOWING RX TRIP WHEN THE NR LVL IS TEMPORARILY OFF SCALE. PAM
						A	100D	FW/C	
						A	100D	MS/C	
						A	1MO	RH/C	
						A	1MO	CV/C	
WBN-1-LT -003-0093 SG 3 LEVEL XMTR (NR)	-D	1-LT -003-0093	-D 764 LOT 7		(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
						A	1MO	CV/C	
WBN-1-LT -003-0094 SG 3 LEVEL XMTR (NR)	-F	1-LT -003-0094	-F 764 LOT 7		(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
						A	1MO	CV/C	
WBN-1-LT -003-0097 SG 3 LEVEL XMTR (NR)	-G	1-LT -003-0097	-G 764 LOT 7		(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI
						A	100D	MS/C	
						A	100D	FW/C	
						A	1MO	RH/C	
						A	1MO	CV/C	
WBN-1-LT -003-0098 SG 3 LEVEL XMTR (NR)	-G	1-LT -003-0098	-G 764 LOT 7		(3) 71C62-54114-1	A	100D	L	MEASURES SG WATER LVL TO DETER MINE IF A SG HAS BLOWN DRY. ALSO USED FOLLOWING RX TRIP WHEN THE NR LVL IS TEMPORARILY OFF SCALE. PAM
						A	100D	FW/C	
						A	100D	MS/C	
						A	1MO	RH/C	
						A	1MO	CV/C	

PREPARER/DATE A.W. Lewis 9/23/86
CHECKED/DATE B.D. Meyer 9/23/86

R 1	R 2	R 4
WCG	WCG	WCG
2-24-89	5-21-90	8-21-90
HDR	HDR	ELM
3-3-89	3-21-90	8/21/90

PAGE A-5

R4

PRINT DATE: 07/06/90

BINDER NO. : WBNEQ-XMTR-001
MANUFACTURER : BARTON
PAGE 5 OF 7

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO. MODEL NUMBER	AZMUTH	LOCATION ELEV(1) CONTRACT	RM/RAD	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-LT -003-0106 SG 4 LEVEL XMTR (NR)	-E	1-LT -003-0106 764 LOT 7		(3) 71C62-54114-1		A A A A	100D 100D 100D 1MO	L MS/C FW/C RH/C CV/C	MEASURES SG WATER LVL TO DETER MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI
WBN-1-LT -003-0107 SG 4 LEVEL XMTR (NR)	-F	1-LT -003-0107 764 LOT 7		(3) 71C62-54114-1		A A A A	100D 100D 100D 1MO	L MS/C FW/C RH/C CV/C	MEASURES SG WATER LVL TO DETER MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM
WBN-1-LT -003-0110 SG 4 LEVEL XMTR (NR)	-G	1-LT -003-0110 764 LOT 7		(3) 71C62-54114-1		A A A A	100D 100D 100D 1MO	L MS/C FW/C RH/C CV/C	MEASURES SG WATER LVL TO DETER MINE IF SI CAN BE TERMINATED, CONTROL SG LVL AND DETECT A BREACH OF CONTAINMENT THRU THE SG. PAM/TMI
WBN-1-LT -003-0111 SG 4 LEVEL XMTR (NR)	-F	1-LT -003-0111 764 LOT 4		(3) 71C62-54114-1		A A A A	100D 100D 100D 1MO	L FW/C MS/C RH/C CV/C	MEASURES SG WATER LVL TO DETER MINE IF A SG HAS BLOWN DRY. ALSO USED FOLLOWING RX TRIP WHEN THE NR LVL IS TEMPORARILY OFF SCALE. PAM
WBN-1-PDT -030-0042 CNTMT PRESS DIFF XMTR	-G	1-PDT -030-0042 764 LOT 7	301	728' 7" ANN 71C62-54114-1		A A A A	100D 100D 100D 1MO	L MS/C FW/C RH/C CV/C	PROVIDES A SIGNAL FOR PHASE B ISOLATION, PAM

PAGE A - 6

R 1	R 2	R 4
WCG 2-24-89	WCG 3-21-90	WCG 8-30-90
HDR 3-3-89	HDR 3-21-90	HDR 8-3-90

PREPARER/DATE A.W. Lewis 9/23/86
CHECKED/DATE B.D. Meyer 9/23/86

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

<u>EQIS NUMBER</u>		<u>UNIT DEVICE ID NO.</u>		<u>AZMITH</u>	<u>LOCATION</u>	<u>ELEV(1)</u>	<u>RM/RAD</u>	<u>CAT</u>	<u>OPER TIME</u>	<u>EVENT</u>	<u>SAFETY FUNCTION</u>
<u>DESCRIPTION</u>				<u>MODEL NUMBER</u>		<u>CONTRACT</u>		<u>(2)</u>			
WBN-1-PDT -030-0043	-F	1-PDT -030-0043	-F	296	729' 1" ANN	71C62-54114-1		A	100D	L	PROVIDES A SIGNAL FOR
CNTMT PRESS DIFF XMTR				764 LOT 7				A	100D	MS/C	PHASE B ISOLATION, PAM
								A	100D	FW/C	
								A	1MO	RH/C	
								A	1MO	CV/C	
WBN-1-PDT -030-0044	-E	1-PDT -030-0044	-E	285	746' 1" ANN	71C62-54114-1		A	100D	L	PROVIDES A SIGNAL FOR
CNTMT PRESS DIFF XMTR				764 LOT 7				A	100D	MS/C	PHASE B ISOLATION, PAM
								A	100D	FW/C	
								A	1MO	RH/C	
								A	1MO	CV/C	
WBN-1-PDT -030-0045	-D	1-PDT -030-0045	-D	307	728' 7" ANN	71C62-54114-1		A	100D	L	PROVIDES A SIGNAL FOR
CNTMT PRESS DIFF XMTR				764 LOT 7				A	100D	MS/C	PHASE B ISOLATION, PAM
								A	100D	FW/C	
								A	1MO	RH/C	
								A	1MO	CV/C	
WBN-1-LT -063-0180	-D	1-LT -063-0180	-D	169	720' 3" FN2	71C62-54114-1		A	100D	L	DETECT HIGH SUMP WATER LVL
CNTMT LEVEL MIN LEVEL RHR RECIR				764 LOT 7				A	100D	MS/C	INITIATE SWITCHOVER ON LOW
								A	100D	FW/C	RWST, PAM
								A	1MO	RH/C	
								A	1MO	CV/C	
WBN-1-LT -063-0181	-E	1-LT -063-0181	-E	359	720' 2" FN1	71C62-54114-1		A	100D	L	DETECT HIGH SUMP WATER LVL
CNTMT LEVEL MIN LEVEL RHR RECIR				764 LOT 7				A	100D	MS/C	INITIATE SWITCHOVER ON LOW
								A	100D	FW/C	RWST, PAM
								A	1MO	RH/C	
								A	1MO	CV/C	

PAGE A-7

R2

PREPARER/DATE A.W. Lewis 9/23/86 WCG 2-24-89 WCG 3-21-90
CHECKED/DATE B.D. Meyer 9/23/86 HDR 3-7-89 HDR 3-21-90

PRINT DATE: 09/26/90

BINDER NO. : WBNEQ-XMTR-001
MANUFACTURER : BARTON
PAGE 7 OF 7

WATTS BAR NUCLEAR PLANT
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT	DEVICE ID NO.	AZMUTH MODEL NUMBER	LOCATION ELEV(1) RM/RAD CONTRACT	CAT (2)	OPER TIME	EVENT	SAFETY FUNCTION
WBN-1-LT -063-0182 CNTMT LEVEL MIN LEVEL RHR RECIR	-F	1-LT -063-0182	-F 277 764 LOT 7	720' 2" AC4 71C62-54114-1	A A A A	1WK 1WK 1WK 1WK	L MS/C FW/C RH/C CV/C	DETECT HIGH SUMP WATER LVL INITIATE SWITCHOVER ON LOW RWST
WBN-1-LT -063-0183 CNTMT LEVEL MIN LEVEL RHR RECIR	-G	1-LT -063-0183	-G 072 764 LOT 7	720' 2" IIR 71C62-54114-1	A A A A	1WK 1WK 1WK 1WK	L MS/C FW/C RH/C CV/C	DETECT HIGH SUMP WATER LVL INITIATE SWITCHOVER ON LOW RWST
WBN-1-LT -068-0320 RCS PRZR LEVEL	-F	1-LT -068-0320	-F 120 764 LOT 7	730' 10" IIR 71C62-54114-1	A A A A	100D 100D 100D 1MO	L MS/C FW/C CV/C RH/C	ISOLATE RCS LETDOWN, CONTROL RCP SEAL WATER INJECTION, PAM- MUST BE MONITORED TO ENSURE PROPER RCS PRESS AND INVENTORY CONTROL DURING EACH EVENT.
WBN-1-LT -068-0335 RCS PRZR LEVEL	-E	1-LT -068-0335	-E 085 764 LOT 7	732' 4" IIR 71C62-54114-1	A A A A	100D 100D 100D 1MO	L MS/C FW/C CV/C RH/C	ISOLATE RCS LETDOWN, CONTROL RCP SEAL WATER INJECTION, PAM- MUST BE MONITORED TO ENSURE PROPER RCS PRESS AND INVENTORY CONTROL DURING EACH EVENT.
WBN-1-LT -068-0339 RCS PRZR LEVEL	-D	1-LT -068-0339	-D 103 764 LOT 7	732' 8" IIR 71C62-54114-1	A A A A	100D 100D 100D 1MO	L MS/C FW/C CV/C RH/C	ISOLATE RCS LETDOWN, CONTROL RCP SEAL WATER INJECTION, PAM- MUST BE MONITORED TO ENSURE PROPER RCS PRESS AND INVENTORY CONTROL DURING EACH EVENT.

PAGE A-8

PREPARER/DATE A.W. Lewis 9/23/86 R 1 R 2 R 5
CHECKED/DATE B.D. Meyer 9/23/86 WCG 2-24-89 WCG 3-21-90 WCP 10-15-90
HDR 3-3-89 HDR 3-21-90 ELM 10/16/90

R5

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET OF
R R
BINDER TITLE BARTON 764 COMPUTED /R1 wgs DATE 2-24-79
LOT 7 AND 4 CHECKED /R1 JDR DATE 3-3-89

TAB A

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-3 for source of Category and Operating Time assignments.
3. ECN 5974 is relocating these transmitters. See Open Item No. 1.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE BARTON 764 COMPUTED AYL DATE 5-22-86 R R
LOT 7 AND 4 CHECKED W. Miller DATE 5/24/86

TAB B - CHECKLIST FOR EVALUATION OF
ENVIRONMENTAL QUALIFICATION
INCLUDING SUMMARY AND CONCLUSION

PAGE B-1

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 24
R 1 R
BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 2-24-87
LOT 7 AND 4 CHECKED BDM DATE 9-23-86 3-3-89

A. DOCUMENTATION

Equipment Description Refer to TAB A
Vendor/Manufacturer Westinghouse/Barton
Equipment Model No.(s) 764 Lot 7
764 Lot 4

QUALIFICATION REPORTS

- (1) Title/Number/Revision WCAP-8687, Supp. RIMS NEB 840807 362 |R1
2-EQTR-E03A, Revision 2* DATE 3/83
(2) Title/Number/Revision WCAP-8587, Supp. RIMS NEB 840807 361 |R1
1-EODP-ESE-3A, Revision 4 DATE 11/83
(3) Title/Number/Revision WCAP-8587 - NEB 840724 354
RIMS NEB 840724 353
Methodology Revision 6 DATE 3/83

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (4) QRN 67142
(5) QRN 68859
(6) QRN 68872
(7) QRN 68188
(8) QRN 68284
(9) QRN 68873

*All references in TAB B are to this test report unless otherwise noted.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 1A OF 24
 R 5 R
 BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 WLT
10-15-90
 LOT 7 AND 4 CHECKED BDM DATE 9-23-86 6:07
12/16/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (10) QRN 67149
- (11) QRN 74904
- (12) QRN 67151
- (13) QRN 67150
- (14) QRN 68857
- (15) QRN 56177
- (16) Auditable Link Document (B45 860521 351)
- (17) Calculation EQP-02 (B71 860402 200)
- (18) WBNNAL3-004 (B45 860205 235)
- (19) WBNTSR-051 (B26 891129 202)
- (20) Deleted
- (21) Cat. and Oper. Time WBNOSG4-004 R11-System 1 (B18 900612 253)
- (22) Cat. and Oper. Time WBNOSG4-005 R12-System 3 (B26 900824 201)
- (23) Cat. and Oper. Time WBNOSG4-008 R16-System 30 (B26 900717 201)
- (24) Cat. and Oper. Time WBNOSG4-014 R12-System 63 (B26 900713 212)
- (25) Cat. and Oper. Time WBNOSG4-017 R11-System 68 (B18 900612 252)
- (26) 1-LT-3-038 (B26 900809 405)
- (27) 1-LT-63-180 (B18 900723 251)
- (28) 1-LT-3-43 (B18 900825 255)
- (29) Setpoint Methodology (B26 890515 928)**
- (30) 1-LT-68-335 (B18 900918 254)
- (31) WAC-310
- (31a) L-LS-63-180 (B26 900823 413)

R5

**See Open Item No. 4

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 1B OF 24
R 3 R
BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 WCD
6-15-90
LOT 7 AND 4 CHECKED BDM DATE 9-23-86 66.77
6/15/90

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (32) WAC-311
- (32) WAC- 16
- (34) WAC-21
- (35) Demonstrated Accuracy Calculation 1-PDT-30-42 (B18 900 613 251)
- (36) WAC-23
- (37) WAC-28
- (38) WAC-26
- (39) WAC-29
- (40) WAC-27
- (41) WAC-95
- (42) WAC-72
- (43) Spec. Sheets 01410 - (NEB 840302 352 and NEB 840302 353)
- (44) Spec. 955270 Rev 2 - (B45 850423 359)
- (45) Spec. 953328 Rev 3 - (B45 850508 351)
- (46) TVA-85-176 - (B70 850925 006)
- (47) WAT-D-6354 (NEB 850201 609)
- (48) WAT-EQ-001 (B71 860225 001)
- (49) WAT-EQ-010 (B71 860516 003)
- (50) Manual No. 86A2 (B26 881208 351)
- (51) Dwg. 8765D45, R3
- (52) WCAP-8687, Supp. 2-E03A Addendum 1 (B45 851105 356)

R3

R3

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 1C OF 24
R 2 R 5
BINDER TITLE BARTON 764 COMPUTED/R1 WCG DATE 3/3/89 WCG WCG
3/21/90 WCG
LOT 7 AND 4 CHECKED/R1 HDR DATE 3/3/89 HDR 8E-7
3/21/90 WCG

A. DOCUMENTATION

OTHER (ANALYSIS, VENDOR DATA, ETC.) (Continued)

- (53) Environmental Data Drawing 47E235-42 R2
(including DCA-P04104-05-0, -P04104-02-1, and -P04104-03-0)
- (54) Environmental Data Drawing 47E235-44 R1
- (55) Environmental Data Drawing 47E235-45 R1
(including DCA-P04104-06-0)
- (56) WCAP-8687 - Supp 2 - E21A R2 (B25 880812 006)
- (57) Deleted.

|R5

Note: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 2 OF 24
R 1 R _____
BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 WCL
2-24-89
LOT 7 AND 4 CHECKED BDM DATE 9-23-86 WCL
3-3-89

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified
- ☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
- ☐ Equipment Qualification Not Established by Documentation
- ☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES _____

1. Relocate Transmitter (NCR WBNEEB6172)
2. SCR WBNEEB8575
3. Deleted
4. Demonstrated and Required Accuracy
5. NCR 6224

R1

COMMENTS/RECOMMENDATIONS _____

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 3 OF 24
BINDER TITLE BARTON 764 COMPUTED AME DATE 5/22/86
LOT 7 AND 4 CHECKED W. H. H. DATE 5/22/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

X Components are Qualified to the Criteria of 10CFR50.49
and/or NUREG-0588 Category I (IEEE323-1974)

Components are Qualified to the Criteria of NUREG-0588
Category II or the DOR Guidelines of IE Bulletin No. 79-
01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS _____

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 323-1974

IEEE 344-1975

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 4 OF 24
BINDER TITLE BARTON 764 COMPUTED AKL DATE 5/22/86 R R
LOT 7 AND 4 CHECKED WJH DATE 5/24/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- ☒ Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- ☐ Test of Similar Items with Supporting Analysis
- ☐ Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- ☐ Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 5 OF 24
 R 1 R _____
 BINDER TITLE BARTON 764 COMPUTED AWL DATE 5/22/86 awc
2-24-89
 LOT 7 AND 4 CHECKED WBK DATE 5/22/86 WBN
3-3-89

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification documentation identical to the plant equipment which requires qualification (Yes/No/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Transmitter</u>	<u>Transmitter</u>	<u>See</u>
(2) Manufacturer	<u>Barton</u>	<u>Barton</u>	<u>Comments</u>
(3) Model Number(s)	<u>764</u>	<u>764</u>	<u>_____</u>
	<u>Lot 7</u>	<u>Lot 7</u>	<u>_____</u>
	<u>Lot 4</u>	<u>Lot 4</u>	<u>_____</u>
(4) Serial Number(s)	<u>See</u>	<u>550</u>	<u>Table 1</u>
	<u>TAB C</u>	<u>853</u>	<u>Page 22</u>
	<u>Section A</u>	<u>854</u>	<u>_____</u>
(5) Identify Component- Unique checksheet attached:	<u>NA</u>	<u>_____</u>	<u>_____</u>

JUSTIFICATION/COMMENTS Section 2, page 2 of the test report
(TAB D) identifies the tested units and to what baseline configuration they were built. Table 9, page 33 of the test report identifies that the Auditable Link Document formally compares the plant specific purchased units and their baseline configuration to the qualification test units. The Auditable Link Document is contained in TAB C, Section A (Traceability) along with Table 1, which shows the link from the equipment in the field to the test report. Other supporting documents are also included in this section. Transmitters 1-LT-63-180, -181, -182, and -183 are Barton Model 764 transmitters with Model 351 remote sensors. TAB C, Section J addresses the qualification of the sensors.

R1

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 6 OF 24
 R 5 R
 BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 WLF
10/15/90
 LOT 7 AND 4 CHECKED BDM DATE 9-23-86 EBM
10/16/90

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>	
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>	R5
External Process Connections	<u>1/2" NPT/Female</u>	<u>Yes</u>	<u>Spec. 953328 Sec. 4.3.3, TAB E, Sec C</u>	
Electrical Connections	<u>Per Dwg. 8765D45</u>	<u>Yes</u>	<u>TAB I</u>	
Conduit Seals	<u>Per Dwg. 8765D45</u>	<u>NA</u>	<u>Note 2 of Dwg TAB I - See Comments**</u>	
Connector Seals	<u>Per Dwg. 8765D45</u>	<u>NA</u>	<u>See Comments**</u>	
Orientation	<u>See comments***</u>	<u>Yes</u>		
Physical Configuration	<u>Per Dwg. 8765D45</u>	<u>Yes</u>	<u>TAB I</u>	
Other	<u>See Comments*</u>			

JUSTIFICATION/COMMENTS *Raychem splices are being qualified in binder WBNEQ-SPLC-001. **The Barton transmitters are supplied with a manufacturers seal (potting compound) which was tested and exposed to total LOCA/HELB environments as described in the test report. This information is contained in Westinghouse letter WAT-EQ-010 (WAT-D-6985) (B71 860516 003) which is in TAB E, Section H.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 7 OF 24
BINDER TITLE BARTON 764 COMPUTED ANL DATE 5/29/86 R R
LOT 7 AND 4 CHECKED WBR DATE 5/29/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>3.2 p.4</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>3.2 p.4</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>3.1.1 p.3</u>
Radiation	<u>Yes</u>	<u>3.1.2 & .3, p.3</u>
Wear	<u>Yes</u>	<u>3.1.1, p.3</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>4.2.3, p.7</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>5.4, p.14</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>5.4, p.14</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>3.2, p.4</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes*
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes**
(Reference Table 2, 3, 4, and pages 23, 24, 25, and 26).

JUSTIFICATION/COMMENTS *O-rings and fill oil were replaced; see
Sections 5.1 and 7.1.

**Calibration data and test equipment accuracies available for audit
at Westinghouse.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 8 OF 24
BINDER TITLE BARTON 764 COMPUTED ANL DATE 5/22/86 R R
LOT 7 AND 4. CHECKED WPH DATE 5/24/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference 3.1.1, p. 3).

JUSTIFICATION/COMMENTS _____

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>3.1.1, p.3</u>
Radiation exposure	<u>Yes</u>	<u>3.1.2&3, p.3</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>5.3.5, p.14*</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>5.1, p.9</u>

JUSTIFICATION/COMMENTS *See WCAP-8587, Appendix B, Item 17 P.B-7 in Tab E, Section D for further justification.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS This is addressed in Appendix B of WCAP-8587 (#21, P.B-8), Tab E, Section D.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference 3.1.1, p. 3).

JUSTIFICATION/COMMENTS _____

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes
(Reference: See Comments*).

JUSTIFICATION/COMMENTS *See Appendix D, Section 3, page D-5
of WCAP-8587 in Tab E, Sect. D. This is not for transmitters
only - applies to all Westinghouse NSSS.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS See App. B, Section 7, p. B-2 and
App. D, Sect. 3, p. D-5 of WCAP-8587 in Tab E, Section D.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference 5.1, p. 9).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
	Fan RM 1 - 101°F		
	Fan RM 2 - 100°F		
	Acc RM 3 - 92°F		
	Acc RM 4 - 95°F		
Temperature	<u>IIR = 75°F, Ann. = 110°F</u>	<u>125° C</u>	<u>104°F</u>
Time	40 Years	1673 Hrs	10 Years

JUSTIFICATION/COMMENTS *See Tab C, Section B for plant
temperature calculation (EQP-02) supporting these temperatures.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference 5.1, p. 9).

JUSTIFICATION/COMMENTS

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes* (Reference 5.1, p. 9).

JUSTIFICATION/COMMENTS *Test report used a conservative
activation energy of .5eV; see Appendix D, Sect. 3, p. D-5 of
WCAP-8587 in Tab E, Section D.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 10 CF 24
BINDER TITLE BARTON 764 COMPUTED AKL DATE 5/23/86
LOT 7 AND 4 CHECKED [Signature] DATE 5/29/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? NA (Reference _____).

JUSTIFICATION/COMMENTS

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference 7.1, p. 17).

JUSTIFICATION/COMMENTS

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference 5.2, p. 10).

JUSTIFICATION/COMMENTS

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? No
(Reference See Comments).

JUSTIFICATION/COMMENTS App. C of WCAP-8587 in Tab E, Sec. D

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes*
(Reference 3.1.2, p. 3 and 5.2, p. 10).

JUSTIFICATION/COMMENTS *The basis was further identified in
Section 6.7.1 (p. 6-3) and 6.7.4 (pages 6-6 through 6-9) of
WCAP-8587 in Tab E, Section D.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 11 OF 24
R 1 R _____
BINDER TITLE BARTON 764 COMPUTED AWL DATE 5-22-86 WCR
2-24-89
LOT 7 AND 4 CHECKED BDM DATE 5-22-86 WCR
3-3-89

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (Yes/No/NA)? Yes (Reference: 5.2, p. 10 and 3.1.3, p. 3).

Plant normal ambient radiation dose (rd) 2×10^7 (40 years-Gamma)

Test exposure dose (rd) 6.8×10^7

Test exposure dose rate (rd/hr) 2.0 to 3.0 M Rd/hr

Test exposure source type (e.g., Co-60 gamma) Co-60 Gamma

JUSTIFICATION/COMMENTS _____

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program? Yes* (Reference: _____) | R1
See Comments

JUSTIFICATION/COMMENTS *See App. B Item 17, p. B-7 of WCAP-8587 in TAB E, Section D.

- (b) Was the basis for vibration aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: See Comments).

JUSTIFICATION/COMMENTS *See App. B Item 20, p. B8 of WCAP-8587 in TAB E, Section D.

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (Yes/No/NA)? Yes (Reference: See Comments).

JUSTIFICATION/COMMENTS Section 5.0 - Test procedure addresses the fact that operational stresses were induced in the qualification program, page 9.

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the Binder. | R1

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 12 OF 24
R 1 R _____
BINDER TITLE BARTON 764 COMPUTED AWL DATE 5-22-86 wcr
2-24-89
LOT 7 AND 4 CHECKED BDM DATE 5-22-86 hkl
3-3-89

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: _____).
See Comments

JUSTIFICATION/COMMENTS See App. B - Subprogram A, Section 13-15, page B-6 of WCAP-8587 in TAB E, Section D.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: 7.5, page 20 _____).

Qualified life (Document in QMDS)

IIR=26.4 yrs.; Ann.=8.2 yrs.;
Fan Rm. 1=10.9 yrs.; Fan Rm. 2=11.2 yrs.
Acc Rm. 3=14.6 yrs.; Acc Rm. 4=12.8 yrs.

JUSTIFICATION/COMMENTS See TAB C, Section B for Qualified Life Calculations.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: 7.5, page 20 _____).

|R1

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 13 OF 24
 R 1 R
 BINDER TITLE BARTON 764 COMPUTED AWL DATE 5-22-86 WCR
2-24-89
 LOT 7 AND 4 CHECKED WBK DATE 5-22-86 WCR
3-3-89

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis).

<u>Material/Property/Function</u>	<u>Radiation</u>		<u>Activation</u>	
	<u>Threshold</u>	<u>Reference</u>	<u>Energy</u>	<u>Reference</u>
(a) <u>EPT/O-rings</u>			<u>.92eV</u>	<u>5.1, p.10</u>
(b) <u>Silicone 550/Fill Oil</u>			<u>.92eV</u>	<u>5.1, p.10</u>
(c) <u>Silicone 702/Fill Oil (Capillary)</u>			<u>.92eV</u>	<u>TAB D, 5.1</u> R1 <u>p.D-146</u>
(d) _____				
(e) _____				

JUSTIFICATION/COMMENTS At the conclusion of the aging testing, it
was determined that the internal O-rings failed because the aging
temperature selected was too high for the internal O-rings material
to survive the aging time. The O-rings and fill oil were replaced
and aged for 350 hours at 125°C based on an activation energy of
.92eV based on the O-ring manufacturer. The aging calculation is in
TAB C, Section B.

BINDER NO. WBNEQ-XMTR-001 PLANT WRN UNIT(S) 1 SHEET 14 OF 24
BINDER TITLE BARTON 764 COMPUTED AMZ DATE 9/23/86 R R
LOT 7 AND 4 CHECKED Bdn DATE 9-23-86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference 3.2, page 4).

Identify Acceptance Criteria: Refer to Section 3.2 of the report,
pages 4 and 5.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference 3.2, p. 4, Tbls. 5,6,7,8,&11).

Identify baseline and functional testing: See Section 6.0, page 6-1
and Section 6.8, page 6-9 on WCAP-8587 in Tab E, Section D.

JUSTIFICATION/COMMENTS

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference 5.0, pages 10-14).

JUSTIFICATION/COMMENTS

BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 WCP8-30-90LOT 7 AND 4 CHECKED BDM DATE 9-23-86 BBM8/30/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
(Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____).

JUSTIFICATION/COMMENTS See Comments on 5c

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Plant Normal Conditions</u>	<u>Reference</u>
Voltage	<u>See Comments 5(b)</u>	_____
Load	<u>See Comments 5(b)</u>	_____
Frequency	<u>NA</u>	_____
Accuracy	<u>See TAB C, Section F</u>	<u>TAB C, Pgs. C-462 & C-463</u>
Other(s)	_____	_____

R4

JUSTIFICATION/COMMENTS _____

(b) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>See Comments</u>	_____
Load	<u>See Comments</u>	_____
Frequency	<u>NA</u>	_____
Accuracy	<u>See TAB C, Section F</u>	<u>TAB C, Pgs. C-462 & C-463</u>
Other(s)	_____	_____

R4

JUSTIFICATION/COMMENTS Voltage and load are accounted for in the design process and will not vary during accident conditions since they are powered from regulated power.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 15A OF 24
 R 1 R 4
 BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 WCG WCG
 2/24/89 8-20-90
 LOT 7 AND 4 CHECKED BDM DATE 9-23-86 HDR EBM
 3/3/89 8/20/90

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE
PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(5) (c) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>15-52V DC 1V</u>	<u>1.1.1 of ESE-3A</u>
Load	<u>10-50 MA</u>	<u>1.1.3 of ESE-3A</u>
Frequency	<u>NA</u>	<u>1.1.2 of ESE-3A</u>
Accuracy	<u>See TAB C, Section F</u>	<u>TAB C, Pgs. C-462 & C-463</u>
Other(s)		

R4

JUSTIFICATION/COMMENTS Electrical characteristics are con-
tained in EQDP-ESE-3A and Specification 953328. Vendor sub-
mits to Westinghouse for approval the verification of
electrical characteristics to Spec. 953328. Verification of
electrical characteristics on file at Westinghouse to be
audited. Spec. 953328 contained in TAB E, Section C;
EQDP-ESE-3A is contained in TAB D, Section D-1.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 16 OF 24
R 1 R
BINDER TITLE BARTON 764 COMPUTED AWL DATE 5-22-86 WCJ
2-24-89
LOT 7 AND 4 CHECKED WBK DATE 5-22-86 WDR
3-3-89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. See Sheet 16A for Transmitters
Operating Environment - Normal
& Abnormal

- (1) Normal Max (2) Abnormal Max
- (a) Temperature (°F) Sheet 16A (a) Temperature (°F) Sheet 16A
- (b) Pressure (psig) Sheet 16A (b) Pressure (psig) Sheet 16A
- (c) Humidity (%) Sheet 16A (c) Humidity (%) Sheet 16A
- (d) Radiation (rd) Sheet 16A (d) Radiation (rd) Sheet 16A
- (3) Process Interfaces: The transmitters are connected by impulse
lines to the process systems which they are monitoring and are
located in instrument racks away from the process system so
that they should not see any significant effect due to the
process.
- (4) State anticipated occurrence frequency and duration of abnormal
conditions: These conditions could exist for up to eight
hours per excursion and will occur less than 1% of the plant
life.
- (5) Accident (worst case for any combination of specified accident
parameter including peak, duration, and profile):
- (a) Temperature (°F) 327 Accident type L, HELB
- (b) Pressure (psig) 11.2 Accident type L | R1
- (c) Humidity (%) 100 Accident type L, HELB
 4.7×10^8 (beta)**
- (d) Radiation (rd) 3.3×10^7 (gamma)* Accident type L
- (e) Spray Type 2000 ppm
Boron pH 8.3 Accident type L, HELB | R1

*Radiation level based on OE Calculation WBNNAL3-004 contained | R1
in TAB C, Section C, Subsection A. Page 3 of Calculation.

**Radiation level based on Environmental Data Drawing 47E235-42 | R1
and -45.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 16A OF 24
R 1 R 2
BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 WCG WCG
2-24-89 3-21-90
LOT 7 AND 4 CHECKED BDM DATE 9-23-86 HDR HDR
3-3-89 3-21-90

K. REQUIRED OPERATING ENVIRONMENT (reference also to TAB.C, section B) | R2

Reference Environmental Drawing No. 47E235-42, Lower Containment

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>120</u>	(a) Temperature (°F) <u>130</u>
(b) Pressure (psig) <u>0.3</u>	(b) Pressure (psig) <u>0.3</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>100</u>
(d) Radiation (rd) <u>2×10^7</u>	(d) Radiation (rd) <u>NA</u>

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-45, IIR-Incore
Instrument Room

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>75</u>	(a) Temperature (°F) <u>120</u>
(b) Pressure (psig) <u>0.3</u>	(b) Pressure (psig) <u>0.3</u>
(c) Humidity (%) <u>60</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>3.5×10^5</u>	(d) Radiation (rd) <u>NA</u>

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-44, Annulus

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) <u>110</u>	(a) Temperature (°F) <u>120</u>
(b) Pressure (psig) <u>ATM(-)</u>	(b) Pressure (psig) <u>ATM(-)</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>1×10^6</u>	(d) Radiation (rd) <u>NA</u>

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 17 OF 24
R 1 R
BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 WCR
2-24-89
LOT 7 AND 4 CHECKED BDM DATE 9-23-86 WCR
3-3-89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): See page 17B and the Environmental Drawings
listed in Section A of this TAB

R1

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: Environmental Drawings 47E235-42, -44 and -45). R1

- (7) Subject to submergence (Yes/No/NA)? No (Reference: (See TAB A for elevation and Sheet 17A) *See Open Item No. 1). R1

Identify initiation time and duration of submergence: Na

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes
(Reference: 47E235-42, -44, -45). R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify:

R1

1.87 x 10⁶ rads

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See TAB B, Section A

R1

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 17A OF 24 | R1
R 1 R
BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 2-24-89
LOT 7 AND 4 CHECKED BDM DATE 9-23-86 3-3-89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

(7) Comments: TAB A contains the exact elevation of the transmitters
(from the field verification sheets contained in TAB F)
which can then be compared to the following flood level:

1. IIR - elevation 717.7 ft. (47E235-45)
2. FAN ROOM 1 - 717.7 ft. (47E235-42)
3. FAN ROOM 2 - 717.7 ft. (47E235-42)
4. ACC. ROOM 3 - 717.7 ft. (47E235-42)
5. ACC. ROOM 4 - 717.7 ft. (47E235-42)
6. ANNULUS - NA

R1

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE BARTON 764 COMPUTED /R1 wcv DATE 2-24-89 R____ R____
LOT 7 AND 4 CHECKED /R1 HOR DATE 3-3-89

THIS PAGE INTENTIONALLY LEFT BLANK

Pages B-24 thru B-26 were deleted per revision 1 .

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 17B OF 24 | R1
R 1 R
BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 AWC
2-24-89
LOT 7 AND 4 CHECKED BDM DATE 9-23-86 24K
3-3-89

LOWER CONTAINMENT AND INSTRUMENT ROOM (IIR)

Chemical Spray: The chemical composition of the containment spray was based on the following solutions which result in the most severe conditions:

1. Ice Condenser - Quantity of Ice - 2.7195×10^6 - Boron Concentration 1800 PPM B added as $\text{Na}_2\text{B}_4\text{O}_7 \cdot 10\text{H}_2\text{O}$.
2. Boron Injection Tank - Volume - 900 GAL - Boron Concentration 2100 PPM B in the form of H_3BO_3 .
3. Cold Leg Injection Accumulators (4 Tanks) - Volume - 10,098 FT^3 - Boron Concentration: 2000 PPM B in the form of H_3BO_3 .
4. Upper Head Injection - Volume - 1800 FT^3 - Boron Concentration: 2100 PPM B in the form of H_3BO_3 .
5. Refueling Water Storage Tank - Volume - 375,000 GAL - Boron Concentration: 2100 PPM B in the form of H_3BO_3 .
6. Reactor Coolant System - Volume - 12,145 FT^3 - Maximum Boron Concentration: 2100 PPM B in the form of H_3BO_3 .

Results: The solutions stated above yield a resulting concentration of .19 Molar H_3BO_3 resulting in a pH of 8.3 at 25°C.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 24
 R 1 R _____
 BINDER TITLE BARTON 764 COMPUTED AWL DATE 5-22-86 WCA
2-24-89
 LOT 7 AND 4 CHECKED WBK DATE 5-22-86 WCA
3-3-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

Parameter	Specified	Demonstrated	Reference	
Operating Time	100 Days	15 Days	Fig 2, p 38 See TAB C, Sect G for Comparison	R1
Temperature (°F)	327	420	Fig 2, p 38 Fig 2, p 38 Table 1 of	
Pressure (psig)	11.2	57.6	EQDP-3A Fig 2, p 38 Table 1 of	R1
Relative Humidity (%)	100	100	EQDP-3A	
Chemical Spray*	See TAB C Section I	See Table 1 of EQDP-ESE-3A	p 15, TAB D 6.2, p 15 TAB E, Section G	R1
Radiation (rd)**	5.49 x 10 ⁷ (gamma + beta)***	6.8 x 10 ⁷ (gamma + beta)	Spec. 955270, p 6 See Section K(7), p 17 and 17A1	R1
Submergence	NA	NA		R1

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

***See TAB C, Section C.

(2) Comparison of worst-case profiles and margin assessment:

Parameter	Test Profile Envelopes Specified (Yes/No/NA)	Reference
Temperature	Yes	See TAB C Section H
Pressure	Yes	Fig 2, p 38 TAB D, Table 1 EQDP-ESE-3A, p 15
Relative Humidity	Yes	TAB C, Section H
Chemical Spray	Yes	
Submergence	NA	

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 19 OF 24
 R 1 R _____
 BINDER TITLE BARTON 764 COMPUTED AWL DATE 5-22-86 war
2-24-89
 LOT 7 AND 4 CHECKED WBK DATE 5-22-86 war
3-3-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	+ 15°F	Yes
Pressure: +10% but no more than 10 psig	+ 10%	Yes
Radiation: +10% of accident dose	+ 10%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	+ 10%	Yes
Voltage: ±10% of rated value	*	No R1
Frequency: ±5% of rated value		NA R1
Environmental Transient: the initial transient and the peak temperature applied twice	Same	Yes
Vibration: +10% added to acceleration	** + 10%	Yes R1

JUSTIFICATION/COMMENTS

* Voltage must not exceed 52VDC ± 1VDC - See Note 4 of drawing | R1

8765D45 in TAB I.

**See Seismic Section 5.3.5. | R1

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 20 OF 24
BINDER TITLE BARTON 764 COMPUTED ASL DATE 5/22/86
LOT 7 AND 4, CHECKED WBN DATE 5/22/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference Refer to Tab A).

JUSTIFICATION/ COMMENTS

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference 7.4, p.18, Table 8, p. 32).

JUSTIFICATION/ COMMENTS

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference 7.4, p. 18).

JUSTIFICATION/COMMENTS

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS See Tab C, Section B which demonstrates
that the transmitter operates for the required time interval.

- (5) **Abnormal Conditions:** Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS See Sheet 20A.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 20A OF 24
R 1 R _____
BINDER TITLE BARTON 764 COMPUTED AWL DATE 5-22-86 ways
2-24-89
LOT 7 AND 4 CHECKED WBK DATE 5-22-86 2/88
3-3-89

M. OPERABILITY TEST RESULTS (Continued)

(5) JUSTIFICATION/COMMENTS

See Appendix A and Sections 7.1 thru 7.4 on pages 17 thru 21 of test report (TAB D) for a discussion of the anomalies and their resolution. We concur with the resolution for the O-rings and erratic behavior during HELB because:

1. The cover O-rings are beings replaced per Westinghouse recommendation as noted in the QMDS in TAB G.
2. The erratic behavior observed during HELB testing has been corrected in the Lot 7 and 4 model by a manufacturing change to build the transmitters with the soldered connection.

R1

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 21 OF 24
BINDER TITLE BARTON 764 COMPUTED AMR DATE 5/22/86
LOT 7 AND 4. CHECKED WBR DATE 5/22/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

[illegible]

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 22 OF 24
BINDER TITLE BARTON 764 COMPUTED ASVZ DATE 5/22/86 R R
LOT 7 AND 4 CHECKED WJH DATE 5/22/86

0. SUMMARY OF REVIEW

- | | <u>Yes/No/NA</u> |
|---|------------------|
| (1) Documented evidence of qualification adequate
(Have all assumptions, mathematical models, and
all extrapolations of test data used in an-
analysis been justified and documented)? | <u>Yes</u> |
| (2) Any exceptions (i.e., sound reasons to the contrary)
taken to the specified qualification level
adequately justified? | <u>No</u> |
| (3) Choice of qualification methodology adequately
justified? | <u>Yes</u> |
| (4) If analysis was performed, complete the following: | |
| (a) Were equipment performance requirements
identified? | <u>NA</u> |
| (b) Were specific features and failure modes and
effects analyzed? | <u>NA</u> |
| (c) Were assumptions and mathematical models used
together with appropriate justification for
their use? | <u>NA</u> |
| (d) Were environmental parameters which affect
equipment performance identified? | <u>NA</u> |
| (5) Adequate similarity between equipment and test
specimen established? | <u>Yes</u> |
| (6) Aging degradation evaluated adequately? | <u>Yes</u> |
| (a) Mechanical and/or cycle aging addressed? | <u>Yes</u> |
| (b) Equipment aged to end of life condition prior to
application of DBE conditions? | <u>Yes</u> |
| (c) Absence of preaging in test/analysis justified? | <u>NA</u> |
| (d) Materials susceptible to thermal/radiation
aging identified? | <u>No*</u> |

*See Section H (5b)

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 23 OF 24
BINDER TITLE BARTON 764 COMPUTED 8/8/82 DATE 5/22/86 R R
LOT 7 AND 4 CHECKED WJH DATE 5/22/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes**</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

**See Tab C, Section H.

BINDER NO. WBNEQ-XMTR-001 PLANT WBN UNIT(S) 1 SHEET 24 OF 24
R 1 R
BINDER TITLE BARTON 764 COMPUTED AWL DATE 9-23-86 WCA
3-3-89
LOT 7 AND 4 CHECKED BDM DATE 9-23-86 WCA
3-3-89

O. SUMMARY OF REVIEW (Continued)

- Yes/No/NA
- (15) Criteria regarding functional testing satisfied? Yes
- (a) Does the test plan/report specify an acceptance criteria for equipment performed? Yes
- (b) Was an initial base line test done to establish required performance characteristics? Yes
- (c) Has the test analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? Yes
- (16) Criteria regarding instrument accuracy satisfied? Open Item No. 4 | R1
- (17) Test duration margin (1 hour + function time) satisfied? Yes
- (a) Is the minimum specified operating time at least 1 hour? Yes*
- (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? Yes ** | R1
- (18) Criteria regarding synergistic effects satisfied? Yes
- (19) Criteria regarding margins satisfied? Yes
- (20) Maintenance and surveillance requirements adequately identified? Yes

P. DISCUSSION

- * A few of the transmitters have a minimum specified operating time of five minutes.
- ** See Section 7.1.6 of WCAP-8587 in TAB E, Section D for justification.

ORDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1

BINDER TITLE BARTON 763

COMPUTED AWL DATE 4/23/86

LOT 7

CHECKED CSB DATE 4/23/86

Tab A - Identification of Equipment
Comprising the Equipment Type

XMTR-004

PRINT DATE: 01/11/89

BINDER NO. : WBNEQ-XMTR-
MANUFACTURER : BARTON
PAGE 1 OF 2

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

[illegible]

WEN-1-PT -001-0009A -D 1-PT -001-0009A -D
SG2 MAIN STEAM HDR PRESS 763 LOT 7

729*	AG2	A	100D
71C62-54114-1		A	100D

MS/V INITIATES FEEDWATER ISOL
FW/V AND SAFETY INJECTION; PAM

W8N-1-PT -001-00098 -E 1-PT -001-00098 -E
SG2 MAIN STEAM HDR PRESS 763 LOT 7

729	A02	A	1000
71C63-54114-1		A	1000

MS/V INITIATES FEEDWATER ISOL
FW/V AND SAFETY INJECTION; PAM

WBN-1-PT -001-0020A -D 1-PT -001-0020A -D
SG3 MAIN STEAM HDR PRESS 763 LOT 7

729	A02	A	100D
71C02-54114-1		A	100D

MS/V INITIATES FEEDWATER ISOL
FW/V AND SAFETY INJECTION; PAM

WBN-1-PT -001-00208 -E 1-PT -001-00208 -E
SG3 MAIN STEAM HDR PRESS 763 LOT 7

729 ⁸	A02	A	100D
71C62-54114-1		A	100D

MS/V INITIATES FEEDWATER ISOL
FW/V AND SAFETY INJECTION; PAM

WBN-1-PT -068-0063 -0 1-PT -068-0063 -0
LOOP 1 HOT LEG PRESS 763 LOT 7

713*	A05	A	1000
71062-54114-1		A	1MO
		A	1MO
		A	1MO
		A	1MO

L PAM
AF
AB
RH/A
CV/A

PAGE A-2

PREPARED/DATE__AWL 9/23/86

CHECKED/DATE BDM 9/24/86

R 1	R	R
1-2-87		
1-2-87		
2/8/87		
1-20-87		

PRINT DATE: 01/11/89

BINDER NO. : WBNEQ-XMTR-004
MANUFACTURER : BARTON
PAGE 2 OF 2

W A T T S B A R N U C L E A R P L A N T
TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NUMBER DESCRIPTION	UNIT DEVICE ID NO. MODEL NUMBER	LOCATION ELEV(1) RM/RAD CONTRACT	CAI OPER TIME (2)	EVENT	SAFETY FUNCTION
WBN-1-PT -068-0322 RCS PRZR PRESS	-G 1-PT -068-0322 763 LOT 7	731' 8" IIR 71C62-54114-1	A 5MIN A 5MIN A 5MIN A 5MIN C -NA-	L MS/C FW/C CV/C RH/C	TRIP FUNCTION FOR BOTH HIGH AND LOW PRESSURIZER PRESSURE
WBN-1-PT -068-0323 RCS PRZR PRESS	-F 1-PT -063-0323 763 LOT 7	732' 10" IIR 71C62-54114-1	A 5MIN A 5MIN A 5MIN A 5MIN C -NA-	L MS/C FW/C CV/C RH/C	TRIP FUNCTION FOR BOTH HIGH AND LOW PRESSURIZER PRESSURE
WBN-1-PT -068-0334 RCS PRZR PRESS	-E 1-PT -068-0334 763 LOT 7	734' 10" IIR 71C62-54114-1	A 5MIN A 5MIN A 5MIN A 5MIN C -NA-	L MS/C FW/C CV/C RH/C	TRIP FUNCTION FOR BOTH HIGH AND LOW PRESSURIZER PRESSURE
WBN-1-PT -068-0340 RCS PRZR PRESS	-D 1-PT -068-0340 763 LOT 7	735' IIR 71C62-54114-1	A 5MIN A 5MIN A 5MIN A 5MIN C -NA-	L MS/C FW/C CV/C RH/C	TRIP FUNCTION FOR BOTH HIGH AND LOW PRESSURIZER PRESSURE

PAGE A-3

R1

PREPARER/DATE AWL 9/23/86

CHECKED/DATE BDM 9/24/86

R /
1-20-89
R
R
2/20/89
1-20-89

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
R R
BINDER TITLE BARTON 763 LOT 7 COMPUTED /RI 100% DATE 1-20-89
CHECKED /RI 100% DATE 1-20-89

NOTES

1. Elevations shown are Actual elevations for equipment located in the Reactor Building and Floor elevations for equipment located outside the Reactor Building. Actual elevations for all equipment are documented in TAB F.
2. See Page B-1 for source of Category and Operating Time assignments.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1
BINDER TITLE BARTON 763 COMPUTED ASL DATE 4/23/88 R R
LOT 7 CHECKED SL DATE 4/23/88

Tab B - Checklist for Evaluation of
Environmental Qualification
Including Summary and Conclusion

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 24
R 1 R
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86
CHECKED BDM DATE 9/24/86
1-20-89

A. DOCUMENTATION

Equipment Description Pressure Transmitter

Vendor/Manufacturer Westinghouse/Barton

Equipment Model No.(s) 763 Lot 7

763 Lot 2 Upgrade

QUALIFICATION REPORTS

(1) Title/Number/Revision WCAP-8687, Supp. RIMS NEB 840807 359

2-EQTR-E01A, Revision 2 * DATE March, 1983

(2) Title/Number/Revision WCAP-8587, Supp. RIMS NEB 840807 355

1-EQDP-ESE-1A, Revision 4. DATE March, 1983

NEB 840724 353

(3) Title/Number/Revision WCAP-8587 Revision 6 RIMS NEB 840724 354

"Methodology". DATE March, 1983

OTHER (ANALYSIS, VENDOR DATA, ETC.)

(4) ORN 74911

(5) ORN 74962

(6) ORN 68872

(7) ORN 43423

(8) Auditable Link Document (B45 860521 351)

(9) WAC-33

(10) WAC-32

(11) WAC-34

* All references referred to in TAB B are to this test report
(TAB D) unless otherwise noted. Page numbers referenced are
page numbers of the test report and not of the binder.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 1A OF 24
R 4 R
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86 WEN
9-26-90
CHECKED BDM DATE 9/24/86 EE M
8/27/90

A. DOCUMENTATION (Continued)

OTHER (ANALYSIS, VENDOR DATA, ETC.)

(12) Deleted

(13) Deleted

(14) Deleted

(15) Deleted

(16) Category and Operating Time WBNOSG4-017 - System 68 R11
(B18 900612 252)

(17) Category and Operating Time WBNOSG4-004 - System 1 R11
(B18 900612 253)

(18) ESI Calculation (1-PT-1-2A) - B18 900830 254

R4

(19) OE Calculation (1-PT-68-70) - (B18 900801 251)

(20) Deleted

(21) Setpoint Methodology Study (B26 890515 928)

(22) Barton Upgrade Package (B70 851024 001)

(23) WAC-354

R4

(24) WAC-312

(25) WAC-35

(26) TI-ANL-198 (B45 851001 236)

(27) Deleted

(28) Deleted

(29) Spec. Sheet No. 01010

(30) Spec. 955270 (B45 850423 359)

(31) Spec. 953328 (B45 850508 351)

(32) WAT-D-6467 (B45 850321 600)

R4

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 1B OF 24
R 1 R _____
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86 1-20-89
CHECKED BDM DATE 9/24/86 1-20-89

A. DOCUMENTATION (Continued)

OTHER (ANALYSIS, VENDOR DATA, ETC.)

(33) WAT (EQ)-001 (B71 860225 001)

(34) TVA-86-620 (B45 860804 612)

(35) Manual No. 87F1 (B45 850426 352)

(36) Dwg. 8765D46 Revision 5

| R1

(37) Deleted

| R1

(38) WAT (EQ)-010 (B71 860516 003)

(39) Environmental Drawing No. 47E235-45 R1

(40) Environmental Drawing No. 47E235-56 R1

| R1

(41) Environmental Drawing No. 47E235-76 R3

| R1

NOTE: Documents listed above are used throughout this binder for equipment qualification. The revision levels and Records & Information Management System (RIMS) numbers, as listed above, need not be repeated in other sections of the binder. This listing includes only those documents which are essential to qualification and accordingly should not be considered a complete listing of binder references.

| R1

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 2 OF 24
R 4 R _____
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWR DATE 9/23/86 AWC
9-26-90
CHECKED BDM DATE 9/24/86 BE
9/27/90

B. CONCLUSION OF REVIEW (Check only one block)

- ☒ X Equipment Qualified (Pending Resolution of Open Item)
☐ Equipment Satisfies All Requirements Except Qualified
Life or Justification of Replacement Schedule
☐ Equipment Qualification Not Established by Documentation
☐ Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES _____

1. SCR WBNEEB 8575 & ECN 6119 and 5974

2. Deleted

3. Deleted

4. Deleted

5. Valve Vault Flooding (SCR WBNEEB 8584)

6. Deleted

| R4

COMMENTS/RECOMMENDATIONS _____

THIS PAGE INTENTIONALLY LEFT BLANK

Page B-6 was delcted per revision 2.

DATE: 4/23/86

TVA EQP055.27

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 4 OF 24
BINDER TITLE BARTON 763 COMPUTED ASB DATE 5/15/86 R R
LOT 7 CHECKED CSR DATE 5/15/86

D. QUALIFICATION METHODOLOGY (Check only one block)

X Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

X ** Test of Similar Items with Supporting Analysis

 Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

 Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS ** The lot 2 baseline configuration has been compared with the lot 4 and lot 7 baseline configuration and differences noted. The baseline comparison showed only revision level differences (not affecting qualification) of some piece parts and a solder modification. The Barton upgrade package is contained in TAB C, Section G.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 5 OF 24
 BINDER TITLE BARTON 763 COMPUTED AWL DATE 4/23/86 R R
LOT 7 CHECKED SN DATE 4/23/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Transmitter</u>	<u>Transmitter</u>	<u> </u>
(2) Manufacturer	<u>Barton</u>	<u>Barton</u>	<u>2.0 pg. 2</u>
(3) Model Number(s)	<u>763 Lot 7</u>	<u>763 Lot 7</u>	<u>See Tab C</u>
	<u>763 Lot 2</u>	<u> </u>	<u>See Tab C</u>
	<u>Upgrade</u>	<u> </u>	<u>Sect. G</u>
(4) Serial Number(s)	<u>See Tab C</u>	<u>001</u>	<u>Table 1</u>
	<u>Section A</u>	<u>485</u>	<u>Page 23</u>
	<u> </u>	<u>471</u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
(5) Identify Component- Unique checksheet attached:	<u> </u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS Lot 2 and Lot 7 transmitters can be
differentiated by the Baseline Design Document to which they were
built as shown in Tab C, Section G.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 6 OF 24
 R 1 R 4
 BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86 WCG WCG
 1/20/89 4-26-89
 CHECKED SP DATE 9/24/86 HDR SP
 1/20/89 4/27/89

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the qualification documentation and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if no, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>	
Mounting Bolts	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	R4
External Process Connections	<u>1/2" NPT FEMALE</u>	<u>Yes</u>	<u>SPEC 953328 Sect. 4.3.3 TAB E</u>	
Electrical Connections	<u>PER DWG 8765 D46</u>	<u>Yes</u>	<u>TAB I</u>	
Conduit Seals	<u>PER DWG 8765 D46</u>	<u>N/A</u>	<u>Note 2 of DWG ** 8765 D46 - TAB I See Comments</u>	
Connector Seals	<u>PER DWG 8765 D46</u>	<u>N/A</u>	<u>See Comments**</u>	
Orientation	<u>Horizontal</u>	<u>Yes</u>	<u>Instr. Manual Sect. 3 TAB H</u>	
Physical Configuration	<u>DWG 8765 D46</u>	<u>Yes</u>	<u>TAB I</u>	
Other	<u>See Comments*</u>			

JUSTIFICATION/COMMENTS - *The panels each transmitter is installed in are tabulated in TAB C, Section D. Raychem splices will be qualified by binder WBNEQ-SPLC-001. **The Barton transmitters are supplied with a manufacturer seal (potting compound) which was tested and exposed to total HELB environment as described in test report. This information is contained in Westinghouse letter WAT-EQ-010 (WAT-D-6985) (B71 860516 003) which is in TAB E, Section H. R4

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 7 OF 24
 BINDER TITLE BARTON 763 COMPUTED AVL DATE 4/23/86 R R
LOT 7 CHECKED SP DATE 4/23/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>3.2 Pg. 4</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>3.2 Pg. 4</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>3.1.1 Pg.3</u> <u>3.1.2 and</u>
Radiation	<u>Yes</u>	<u>3.1.3 Pg. 3</u>
Wear	<u>Yes</u>	<u>3.1.1 Pg. 3</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>3.1.4 Pg. 4</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>3.1.5 Pg. 4</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>3.1.5 Pg. 4</u> <u>2.8 & 2.9 Pg.11</u>
(g) Final inspection and disassembly	<u>Yes</u>	of <u>*** EQDP-ESE-1A</u> <u>(Tab D)</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes*
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes**
 (Reference Tables 2, 3, and 4).

JUSTIFICATION/COMMENTS *O-rings were replaced, see Sections 5.1 and 7.1 Page 10 and 18. **Calibration data and test equipment accuracies available for audit at Westinghouse. *** This section identifies the test sequences which the transmitters were subjected to. Test sequences are as specified in IEEE 323-1974. Since no exceptions were taken it is assumed that final inspection and disassembly were performed.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 8 OF 24
BINDER TITLE BARTON 763 COMPUTED ANL DATE 4/23/86 R — R —
LOT 7 CHECKED SD DATE 4/27/86

H. AGING

- (1) Was aging considered in the qualification program
(Yes/no/NA)? Yes (Reference 3.1.1 Page 3).

JUSTIFICATION/COMMENTS _____

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>3.1.1 Pg.3</u>
Radiation exposure	<u>Yes</u>	<u>3.1.2 & 3 Pg.3</u>
Vibration (non-seismic) aging	<u>Yes*</u>	<u>5.3.5 Pg.14</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>3.1.1 Pg. 3</u>

JUSTIFICATION/COMMENTS *See WCAP-8587 - App. B Item 17 P. B-7 in
Tab E, Section D for further justification.

- (3) Were all known synergistic effects which are believed to have a
significant effect on equipment performance considered in the aging
program (yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS Section 21 (P. B8) - Appendix B of
WCAP-8587 in Tab E Section D

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program
(yes/no/NA)? Yes (Reference 5.1 Page 9).

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 9 OF 24
BINDER TITLE BARTON 763 COMPUTED AWL DATE 5/15/86 R R
LOT 7 CHECKED GP DATE 5/15/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes* (Reference: 5.1, page 9*).

JUSTIFICATION/COMMENTS *See Appendix D, Section 3, pg D-5 of WCAP-8587 in Tab E, Section D. This is for generic Westing-house NSSS equipment.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference).

JUSTIFICATION/COMMENTS See WCAP-8587, Appendix B, Section 7, page B-2 in Tab E, Section D.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference 5.1, page 9).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
	<u>IIR=75°F, PENT. RM (A6)=</u>		
<u>Temperature</u>	<u>104°F NSVVR(A2)=130°F</u>	<u>125°C</u>	<u>104°F</u>
<u>Time</u>	<u>40 years</u>	<u>1673hrs</u>	<u>10 yrs</u>

JUSTIFICATION/COMMENTS See Tab C, Section B.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference 5.1, page 9).

JUSTIFICATION/COMMENTS

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes * (Reference 5.1, page 9).

JUSTIFICATION/COMMENTS * Test report used a conservative activation energy of .5eV (see Appendix D, Section 3, page D-5 of WCAP-8587 in Tab E, Section D).

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 10 OF 24
R 1 R _____
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86 1-20-89
CHECKED BDM DATE 9/24/86 1-20-89

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (Yes/No/NA)? NA
(Reference: _____).

JUSTIFICATION/COMMENTS Regression lines were not used.

- (h) Was the equipment operated during the thermal aging (Yes/No/NA)? Yes (Reference: 5.1, page 9)
_____).

JUSTIFICATION/COMMENTS _____

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program¹ (Yes/No/NA)? Yes (Reference: 5.2, page 11) | R1
_____).

JUSTIFICATION/COMMENTS _____

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (Yes/No/NA)? No
(Reference: NA) _____).

JUSTIFICATION/COMMENTS Not required. Assembled device
irradiated to required dose.

- (c) Was the basis for radiation aging exposure identified in the qualification program (Yes/No/NA)? Yes
(Reference: 5.2, page 11) _____).

JUSTIFICATION/COMMENTS See WCAP-8587 for further basis
(Sections 6.7.1, pg 6-3, and 6.7.4, pg 6-4) in TAB E,
Section D.

¹ Qualification program refers to the test report and any supplemental documentation including TVA analyses in TAB C of the binder.

| R1

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference 5.2, pg 11/3.1.3, pg 3).

Plant normal ambient radiation
dose (rd)
$$2 \times 10^7 \text{ (40 years)}$$

Test exposure dose (rd)

$$6.8 \times 10^7$$

Test exposure dose rate (rd/hr)

2.0 to 3.0 M

Test exposure source type
(e.g., Co-60 gamma)

Co-60 gamma

JUSTIFICATION/COMMENTS

- (6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference See Comments).

JUSTIFICATION/COMMENTS See Appendix B, item 17, pg B-7 of

WCAP-8587, Tab E. Also see 5.3.5, pg 14.

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes*
(Reference 5.3.5, pg 14).

JUSTIFICATION/COMMENTS *See Appendix B, items 17 and 20.

pgs B-7 and B-8 of WCAP-8587, Tab E, Section D.

- (7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes
(Reference See Comments).

JUSTIFICATION/COMMENTS Section 5.1, pg 9. Test Procedure

addresses the fact that operational stresses were induced in
the qualification program.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 12 OF 24
R 1 R 1
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 5/9/86
CHECKED BDM DATE 5/15/86 2/92
1-20-89

H. AGING (Continued)

- (7) (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (Yes/No/NA)? Yes (Reference: See Comments)
_____).

JUSTIFICATION/COMMENTS See Appendix B, Subprogram A,
Section 13-15, pg B-6 of WCAP-8587, TAB E, Section D.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (Yes/No/NA)? Yes
(Reference: 7.5, pg 21)
_____).

IIR-26.4 yrs,
PENT. Rm(A6)=9.9 yrs.
Qualified life (Document in QMDS) NSVVR(A2) = 4.4 yrs.
JUSTIFICATION/COMMENTS See TAB C, Section B, and TAB G.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (Yes/No/NA)? Yes
(Reference: 7.5, pg 22)
_____).

|R1

JUSTIFICATION/COMMENTS Although not a replacement part, the
potentiometer (Lot 2) is recommended to be exercised at all
calibration cycles. - See QMDS in TAB G.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 13 OF 24
 BINDER TITLE BARTON 763 COMPUTED ANR DATE 5/9/86 R R
LOT 7 CHECKED CS DATE 5/15/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>EPT/O-rings</u>	<u> </u>	<u> </u>	<u>.92eV</u>	<u>5.1, p 10</u>
(b) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(c) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(d) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(e) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>

JUSTIFICATION/COMMENTS At the conclusion of the aging testing, it was
determined that the O-rings failed due to high aging temperature. The
O-rings were replaced and aged for 14 hours at 125°C based on an activa-
tion energy of .92eV. This 14 hours simulated 2 years of service for the
O-rings. See Section 7.1 on page 18 of test report in Tab D, Section A.
All other components were conservatively assigned an activation energy of
.5eV.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 14 OF 24
BINDER TITLE BARTON 763 COMPUTED SPN DATE 9/23/86 R R
LOT 7 CHECKED BDM DATE 9-24-86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference 3.2, pg 4).

Identify Acceptance Criteria: Refer to Section 3.2 of the test report.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference 3.2, pg 4/ Table 5, 6, 7, 8, and 11.).

Identify baseline and functional testing: See Section 6.0, pg 6-1 and Section 6.8, pg 6.9 on WCAP-8587 in Tab E, Section D.

JUSTIFICATION/COMMENTS

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Section 5.0, pgs 9-15).

JUSTIFICATION/COMMENTS

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 15 OF 24
 R 1 R _____
 BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 4/23/86 1000
1-20-89
 _____ CHECKED BDM DATE 4/23/86 1000
1-20-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (Yes/No/NA)? Yes (Reference: _____)

JUSTIFICATION/COMMENTS See comment under Section 5(b).

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a)	Parameter	Plant Normal Conditions	Reference
	Voltage	<u>15-30.5VDC</u>	<u>See Comments for 5(b)</u>
	Load	<u>10-50 MA</u>	<u>See Comments for 5(b)</u>
	Frequency	<u>NA</u>	<u>See Comments for 5(b)</u>
	Accuracy	<u>See TAB C, Section F</u> <u>See Open Item #6</u>	<u>See Comments for 5(b)</u>
	Other(s)		

JUSTIFICATION/COMMENTS _____

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 15A OF 24
 R 1 R 1
 BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86
 1-2-84
 CHECKED BDM DATE 9/24/86 Hon
 1-20-89

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS
 (Continued)

(b) Parameter	Specific Accident Conditions	Reference R1
Voltage	NA	See Comment
Load	NA	
Frequency	NA	
	See TAB C, Section F	
Accuracy	See Open Item 6	
Other(s)		

JUSTIFICATION/COMMENTS

Voltage, load, and frequency are accounted for in the design process and will not vary during accident conditions since these transmitters are powered from regulated power supplies with fixed loads, and connected with qualified cable. The only electrical characteristics on which qualification is based is accuracy. Variations in the power supply are accounted for in the loop accuracy calculations.

(c) Parameter	Demonstrated Conditions	Reference R1
Voltage	15-52 VDC	Sect. 1.1.1 of ESE-1A
Load	10-50 MA	Sect. 1.1.3 of ESE-1A
Frequency	NA	Sect. 1.1.2 of ESE-1A
	See TAB C, Section F	
Accuracy	See Open Item 6	
Other(s)		

JUSTIFICATION/COMMENTS

Electrical characteristics are contained in EQDP-ESE-1A and specification 953328. Vendor submits to Westinghouse for approval the verification of electrical characteristics to specification 953328. Verification of electrical characteristics is on file at Westinghouse and can be audited. Specification 953328 is contained in TAB E, Section C, and EQDP-ESE-1A is contained in TAB D, Section B.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 16 OF 24
 BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 4/23/86 R 1 R 1
 CHECKED BDM DATE 4/23/86 VER
1-20-89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Normal & Abnormal: See Sheet A
Accident: 47E235-45 Instru- | R1
ment Room

- | | |
|---------------------------------------|---------------------------------------|
| (1) Normal Max | (2) Abnormal Max |
| | See |
| (a) Temperature (°F) <u>Sheet 16A</u> | (a) Temperature (°F) <u>Sheet 16A</u> |
| | See |
| (b) Pressure (psig) <u>Sheet 16A</u> | (b) Pressure (psig) <u>Sheet 16A</u> |
| | See |
| (c) Humidity (%) <u>Sheet 16A</u> | (c) Humidity (%) <u>Sheet 16A</u> |
| | See |
| (d) Radiation (rd) <u>Sheet 16A</u> | (d) Radiation (rd) <u>Sheet 16A</u> |
- (3) Process Interfaces: The transmitters are connected by impluse lines to the process systems which they are monitoring and are located in instrument racks away from the process system so that they should not see any significant effect due to process temperature.
- (4) State anticipated occurrence frequency and duration of abnormal conditions: 1% of the plant life and could exist up to 8 hours per excursion.
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- | | |
|---|-----------------------------------|
| (a) Temperature (°F) <u>327</u> | Accident type <u>L</u> |
| (b) Pressure (psig) <u>11.2</u> | Accident type <u>L</u> R1 |
| (c) Humidity (%) <u>100</u> | Accident type <u>L</u> |
| | <u>1 x 10⁷ (Gamma)</u> |
| (d) Radiation (rd) <u>4.7x10⁸ (Beta)</u> | Accident type <u>L</u> R1 |
| | <u>2000 ppm</u> |
| (e) Spray Type <u>Boron pH 8.2</u> | Accident type <u>L</u> |

R1

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 16A OF 24
R 1 R _____
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86 sub
1-2-89
CHECKED BDM DATE 9/24/86 WDR
1-25-89

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-56, 713-RM-A6 | R1
Penetration Room

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104

(a) Temperature (°F) 110

(b) Pressure (psig) ATM(-)

(b) Pressure (psig) ATM(-) | R1

(c) Humidity (%) 80

(c) Humidity (%) 90

(d) Radiation (rd) 2.2 x 10⁶

(d) Radiation (rd) NA | R1

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-45 Instrument Room | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 75

(a) Temperature (°F) 120

(b) Pressure (psig) 0.3

(b) Pressure (psig) 0.3 | R1

(c) Humidity (%) 60

(c) Humidity (%) 90

(d) Radiation (rd) 3.5 x 10⁵

(d) Radiation (rd) NA

| R1

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-76, 729-RM A2 NSVVR | R1

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 130

(a) Temperature (°F) 140

(b) Pressure (psig) ATM(-)

(b) Pressure (psig) ATM(-) | R1

(c) Humidity (%) 50

(c) Humidity (%) 100

(d) Radiation (rd) 1.8 x 10³

(d) Radiation (rd) NA

| R1

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 17 OF 24
R 1 R
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86
CHECKED BDM DATE 9/24/86
1-20-89

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.): See pages 17A, B, C, D, E, F and G.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (Yes/No/NA)? Yes (Reference: _____)

Environmental drawings 47E235-45, -56 and -76; notes 5, 16 and 16 respectively.

R1

- (7) Subject to submergence (Yes/No/NA)? Yes (Reference: Sheet 17A and Open Item).

R1

Identify initiation time and duration of submergence: NA -
See Sheet 17A and Open Item

- (8) Is the equipment subject to a beta radiation contribution to the total accident dose (Yes/No/NA)? Yes
(Reference: 47E235-45).

R1

If yes, identify the fraction of the unattenuated free field beta dose to be added to the total dose and justify: See

TAB C, Section C

- (9) Special environmental calculations (temp., rad., etc.)

Type

RIMS No.

See Section A this TAB

R1

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 17A OF 24 RI
 R 1 R 3
 BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/24/86 WCG WCG
1-20-89 4-10-90
 CHECKED BDM DATE 9/24/86 HDR ELM
1-20-89 4-11-90

WCG
4/9/90

K. REQUIRED OPERATING ENVIRONMENT (Continued)

(7) Comments: TAB F contains the exact elevation of the transmitters (field verification) which can then be compared to the following flood level:

1. IIR - elevation - 717.7 ft. (47E235-45, note 5)
2. North Steam Valve Vault Room (A2) - 731.5 ft. (47E235-76, note 62)
3. Penetration Room (A6) - 713 ft. 1 inch (47E235-56, Table 1).

3
R2
WCG
4/11/90

Transmitters 1-PT-1-9A and 1-PT-1-20A presently will be flooded, but SCRWBNEEB 8584 has been written against the flooding in the Valve Vault Room. Corrective action will be assigned to the SCR to resolve the problem (i.e., ECN issued to move transmitters above the flood level).

<u>ID#</u>	<u>ACTUAL ELEV</u>	<u>FLOOD ELEV</u>
1-PT-1-9A	731'2"	731.5' *
1-PT-1-9B	733'5"	731.5'
1-PT-1-20A	731'4"	731.5' *
1-PT-1-20B	733'5"	731.5'
1-PT-68-63	717'6"	713.1'
1-PT-68-322	731'8"	717.7'
1-PT-68-323	732'10"	717.7'
1-PT-68-334	734'11"	717.7'
1-PT-68-340	735	717.7'

* See open item #5

WBNEQ-XMTR-004

THIS PAGE INTENTIONALLY LEFT BLANK

Pages B-25 thru B-31 were deleted per revision 1.

PAGEBLNK

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 18 OF 24
 R 1 R
 BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86
 CHECKED BDM DATE 9/24/86
 1-20-89

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 Days</u>	<u>15 Days</u>	See TAB C Sect. H for Comp 3.1.5 pg. 4
Temperature (°F)	<u>327, 535****</u>	<u>420</u>	Figure 2 Page 38 R1
Pressure (psig)	<u>11.2</u>	<u>57.6</u>	Tbl 1, Pg. 16 EQDP-TAB D
Relative Humidity (%)	<u>100</u>	<u>100</u>	Sect. B Tbl 1, Pg. 16
Chemical Spray*	<u>2000 ppm</u> <u>pH 8.2</u>	<u>2500 ppm</u> <u>pH 10.7</u>	EQDP-TAB D Sect. B 6.2, R1
	<u>1.035x10⁷***</u>	<u>6.8x10⁷</u>	Pg. 16
Radiation (rd)**	<u>4.7x10⁸ (BETA)****</u>	<u>9x10⁸</u>	TAB C, Sect. C
Submergence	<u>See Sheet 17A</u>	<u>See Sheet 17A</u>	

*Includes spray concentration, flowrate, density, duration, and pH.

**Enter 40-year integrated normal dose plus integrated accident dose and specify type.

***Based on information contained in section K; accident -
1 x 10⁷, normal - 3.5 x 10⁵.

****The temperature resulting from a Main Steam Line Break in the
Steam Valve Vault Room is 535°F.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile</u> <u>Envelopes Specified</u> <u>(Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u> ¹	Fig. 2 Pg. 38
Pressure	<u>Yes</u>	Fig. 2 Pg. 38
Relative Humidity	<u>Yes</u>	Tbl 1, Pg. 2 EQDP-ESE-1A
Chemical Spray	<u>Yes</u>	TAB C
Submergence	<u>See Sheet 17A</u>	Section K R1

JUSTIFICATION/COMMENTS ¹ OE Calculation TI-ANL-198 (TAB C, Section I) establishes that the peak temperature the insulated transmitter will see is 258.6°F. | R1

PAGE B-32 R1

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 19 OF 24
 BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 4/23/86 ^{R 1} _{R 1-23-89}
 CHECKED BDM DATE 4/23/86 ¹⁻²³⁻⁸⁹

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS
 (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, Yes/No/NA).

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>	
Temperature: +15 degrees F	> +15°F	Yes	
Pressure: +10% but no more than 10 psig	> +10%	Yes	
Radiation: +10% of accident dose	> +10%	Yes	
Time: +10% (or 1 hour + operating time per NUREG-0588)	> +10%	Yes	
Voltage: ±10% of rated value		No*	R1
Frequency: ±5% of rated value	NA	NA	R1
Environmental Transient: the initial transient and the peak temperature applied twice	Same	Yes	
Vibration: +10% added to acceleration	> +10%	Yes*	

JUSTIFICATION/COMMENTS * Voltage must not exceed 30.5VDC + R1

1VDC - See Note 4 on Dwg. 8765 D46 in TAB I.

* See Section 5.3.5 on page 14.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 20 OF 24
BINDER TITLE BARTON 763 COMPUTED AFK DATE 5/9/86 R R
LOT 7 CHECKED SP DATE 5/15/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:
(Reference See Tab A).

JUSTIFICATION/COMMENTS NA

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes
(Reference Section 7.4 Page 20).

JUSTIFICATION/COMMENTS NA

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes
(Reference Section 7.4 Page 20).

JUSTIFICATION/COMMENTS NA

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference 7.4 Page 20).

JUSTIFICATION/COMMENTS See Tab C Section H

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes
(Reference See Comments).

JUSTIFICATION/COMMENTS See Sheet 20A.

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 20A OF 24
R 2 R _____
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 5/26/86 LCB
8-25-87
CHECKED SRP/DLK DATE 5/20/86 KBP
8/29/89

M. OPERABILITY TEST RESULTS (Continued)

(5) JUSTIFICATION/COMMENTS See Appendix A and Sections 7.1 thru
7.4 on pages 18 thru 21 of test report (TAB D) for a
discussion of the anomalies and their resolution. We concur
with the resolution for the O-rings and erratic behavior
during HELB because:

1. The cover O-rings are being replaced per Westinghouse
recommendation as noted in the OMDS in TAB G.
2. The erratic behavior has been corrected in the Lot 7
model by a manufacturing change to build the
transmitters with the soldered connection.

R2

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 22 OF 24
BINDER TITLE BARTON 763 COMPUTED AVL DATE 4/23/86 R R
LOT 7 CHECKED SP DATE 4/23/86

O. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>No</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>NA</u>
(b) Were specific features and failure modes and effects analyzed?	<u>NA</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>NA</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>No*</u>

*See Section H (5b)

BINDER NO. WBNEQ-XMTR-004 PLANT WBN UNIT(S) 1 SHEET 23 OF 24
BINDER TITLE BARTON 763 COMPUTED ANR DATE 9/23/86 R R
LOT 7 CHECKED BDM DATE 9-24-86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes**</u>
(11) Criteria regarding submergence satisfied?	<u>Open Item Sheet 5</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes*</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

*See specification 955270 (Tab E, Section B) section 6.0 page 6 and Westinghouse letter WAT(EQ)-001 (Tab E, Section F). See Also TAB C, Section C.

**Due to the test chamber configuration being small, the flow rate is considered adequate in regard to the plant's requirements.

BINDER NO. WBNEQ-XMTR-QQ4 PLANT WBN UNIT(S) 1 SHEET 24 OF 24
R 1 R _____
BINDER TITLE BARTON 763 LOT 7 COMPUTED AWL DATE 9/23/86 1-26-89
CHECKED BDM DATE 9/24/86 1-26-89

O. SUMMARY OF REVIEW (Continued)

- | | <u>Yes/No/NA</u> |
|--|-------------------|
| (15) Criteria regarding functional testing satisfied? | <u>Yes</u> |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed? | <u>Yes</u> |
| (b) Was an initial base line test done to establish required performance characteristics? | <u>Yes</u> |
| (c) Has the test analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u> |
| (16) Criteria regarding instrument accuracy satisfied? | Open Item #6 R1 |
| (17) Test duration margin (1 hour + function time) satisfied? | <u>Yes</u> |
| (a) Is the minimum specified operating time at least 1 hour? | <u>No</u> |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? | <u>Yes *</u> |
| (18) Criteria regarding synergistic effects satisfied? | <u>Yes</u> |
| (19) Criteria regarding margins satisfied? | <u>Yes</u> |
| (20) Maintenance and surveillance requirements adequately identified? | <u>Yes</u> |

P. DISCUSSION

* See Section 7.1.6 of WCAP-8587 contained in TAB E, Section D.
