



**LEGEND**

- Axial Tests ◆
- Radial Tests ■

Results of Laboratory UCS Tests on Rock Samples from Borehole BPA-47 ▲

Note:

- 1) Test results shown for axial and radial point load tests are based on a site-specific correlation factor between point, load index and laboratory UCS of 21.3.
- 2) See legend of Figure 2.5.4-204A for descriptions of graphical log symbols.

Progress Energy Carolinas  
**Shearon Harris Nuclear Power Plant  
 Units 2 and 3**  
**Part 2, Final Safety Analysis Report**  
 New Hill, North Carolina

---

Point Load Index Results at BPA-47

---

FIGURE 2.5.4-207A Rev. 0