

1 DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
2
3 TOPICAL REPORT WCAP-16168-NP, REVISION 2, "RISK-INFORMED EXTENSION OF THE
4
5 REACTOR VESSEL IN-SERVICE INSPECTION INTERVAL"
6
7 PRESSURIZED WATER REACTOR OWNERS GROUP
8
9 PROJECT NO. 694

10
11
12 1.0 INTRODUCTION AND BACKGROUND
13

14 By letter dated January 26, 2006, as supplemented by letter dated June 8, 2006, the
15 Westinghouse Owners Group (WOG), currently known as the Pressurized Water Reactor
16 Owners Group (PWROG), submitted topical report WCAP-16168-NP, Revision 1, "Risk-
17 Informed Extension of the Reactor Vessel In-Service Inspection Interval" (Reference 1 and
18 Reference 2), for U.S. Nuclear Regulatory Commission (NRC) staff review. By letter dated
19 October 16, 2007, the PWROG submitted responses to the NRC staff's request for additional
20 information (RAI) on WCAP-16168-NP, Revision 1, and provided WCAP-16168-NP, Revision 2
21 (Reference 3), but did not expand its scope as originally submitted for NRC staff review.
22

23 In WCAP-16168-NP, Revision 2, (hereafter referred to as the TR) the PWROG provided the
24 technical and regulatory basis for decreasing the frequency of inspections by extending the
25 *American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code)*
26 Section XI inservice inspection (ISI) from the current 10 years to 20 years for ASME Code
27 Section XI, Category B-A and B-D reactor vessel (RV) welds.
28

29 The TR described risk-informed pilot studies based, for the most part, on the results of the
30 NRC's recently-completed pressurized thermal shock (PTS) research program. The NRC's
31 Office of Nuclear Regulatory Research (RES) completed this research program to update the
32 PTS regulations. In an October 3, 2007, Federal Register Notice (72 FR 56275) (Reference 4),
33 the NRC proposed to amend its regulations to provide updated fracture toughness requirements
34 for protection against PTS events for PWR RVs. NUREG-1806, "Technical Basis for Revision
35 of the Pressurized Thermal Shock (PTS) Screening Limit in the PTS Rule (10 CFR 50.61)" (the
36 PTS Risk Study) (Reference 5 and Reference 6) and (2) NUREG-1874, "Recommended
37 Screening Limits for Pressurized Thermal Shock (PTS)" (Reference 7), provided the technical
38 basis for the rulemaking. These reports summarized and referenced several additional reports
39 on the same topic.
40

41 2.0 REGULATORY EVALUATION
42

43 ISI of ASME Code Class 1, 2, and 3 components is performed in accordance with Section XI of
44 the ASME Code and applicable addenda as required by Title 10 of the *Code of Federal*
45 *Regulation* (10 CFR) 50.55a(g), except where specific relief has been granted by the NRC

1 pursuant to 10 CFR 50.55a(g)(6)(i). The regulation at 10 CFR 50.55a(a)(3) states that
2 alternatives to the requirements of paragraph (g) may be used, when authorized by the NRC, if:
3 (i) the proposed alternatives would provide an acceptable level of quality and safety or
4 (ii) compliance with the specified requirements would result in hardship or unusual difficulty
5 without a compensating increase in the level of quality and safety.
6

7 The regulations require that ISI of components and system pressure tests conducted during the
8 first 10-year interval and subsequent intervals comply with the requirements in the latest edition
9 and addenda of Section XI of the ASME Code incorporated by reference in 10 CFR 50.55a(b)
10 12 months prior to the start of the 120-month interval, subject to the limitations and modifications
11 listed therein.
12

13 The current requirements for the inspection of RV pressure retaining welds have been in effect
14 since the 1989 Edition of ASME Code, Section XI. Article IWB-2000 of the ASME Code,
15 Section XI establishes an inspection interval of 10 years. The TR proposed a methodology that
16 can be used by individual licensees to demonstrate that extending the inspection interval on their
17 Category B-A pressure retaining RV welds and Category B-D full penetration RV nozzle welds
18 from 10 to 20 years would provide an acceptable level of quality and safety.
19

20 The NRC staff based its review of the risk information on NUREG-0800, "Standard Review Plan
21 [(SRP)] for the Review of Safety Analysis Reports for Nuclear Power Plants," Chapter 19.2,
22 "Review of Risk Information Used to Support Permanent Plant-Specific Changes to the
23 Licensing Basis: General Guidance" (Reference 8). SRP Chapter 19.2 directs the NRC staff to
24 review each of the four elements suggested in Regulatory Guide (RG) 1.174, "An Approach for
25 Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to
26 the Licensing Basis," Section 2 (Reference 9). These elements are: (1) Define the Proposed
27 Changes, (2) Conduct Engineering Evaluations, (3) Develop Implementation and Monitoring
28 Strategies, and (4) Document the Evaluations and Submit the Request.
29

30 The NRC staff also used further guidance in RG 1.174. RG 1.174 describes a risk-informed
31 approach, acceptable to the NRC, for assessing the nature and impact of proposed licensing-
32 basis changes by considering engineering issues and applying risk insights.
33

34 One acceptable approach to making risk-informed decisions about the proposed change is to
35 show that the proposed changes meet five key principles stated in RG 1.174, Section 2:
36

- 37 1. The proposed change meets the current regulations unless it is explicitly related to a
38 requested exemption or rule change.
- 39 2. The proposed change is consistent with the defense-in-depth philosophy.
- 40 3. The proposed change maintains sufficient safety margins.
- 41 4. When proposed changes result in an increase in core-damage frequency or risk, the
42 increases should be small and consistent with the intent of the Commission's Safety
43 Goal Policy Statement.
- 44 5. The impact of the proposed change should be monitored using performance
45 measurement strategies.

1 RG 1.174 provides numerical risk acceptance guidelines that are helpful in determining whether
2 or not the fourth key principle has been satisfied. These guidelines are not to be applied in an
3 overly prescriptive manner; rather, they provide an indication, in numerical terms, of what is
4 considered acceptable. The intent in comparing risk results with the risk acceptance guidelines
5 is to demonstrate with reasonable assurance that the fourth key principle has been satisfied.
6

7 3.0 TECHNICAL EVALUATION

8

9 The objective of ISI is to identify conditions, such as flaw indications, that are precursors to leaks
10 and ruptures and which violate pressure boundary integrity principles for plant safety. The TR
11 includes a detailed analysis of the potential effects of extending the RV weld ISI interval for three
12 pilot plants: Beaver Valley, Unit 1 (BV1), Palisades, and Oconee, Unit 1 (OC1). These three
13 units include one unit from each of the PWR vendors and are the same plants that were
14 evaluated in detail in the NRC PTS Risk Study. The TR proposed a method that each licensee
15 could use to apply the results from the three pilot plant applications to its plant.
16

17 The TR used the estimated through wall cracking frequency (TWCF) as a measure of the risk of
18 RV failure. The correlation for determining plant-specific TWCF was based on plant-specific
19 data and can be found in NUREG-1874 (Reference 7). This correlation took into consideration
20 the contribution to TWCF from each of the most limiting plate, axial weld, and circumferential
21 welds. These individual TWCF contributions were then weighted based on pilot plant data and
22 summed to determine a total RV TWCF.
23

24 3.1 Define the Proposed Change

25

26 The TR proposed to extend the inspection interval for ASME Code, Section XI, Category B-A
27 and B-D RV welds from 10 years to a maximum of 20 years. The change will be accomplished
28 through plant-specific requests for an alternative pursuant to 10 CFR 50.55a(a)(3)(i) on the basis
29 that the alternative inspection interval provides an acceptable level of quality and safety.
30

31 The 20 year inspection interval is a maximum interval and the PWROG did not request, and the
32 NRC staff does not endorse, that all RV inspections be discontinued for the 10 years following
33 approval of this methodology (as would occur if every licensee were granted an extension from
34 10 to 20 years). In response to RAI 11b from Reference 3, the PWROG explained how a
35 sampling of plants performing reactor inspections over the next 10 years can be achieved. In its
36 request for an alternative, each licensee shall identify the years in which future inspections will
37 be performed. The dates provided must be within plus or minus one refueling cycle of the dates
38 identified in the implementation plan provided to the NRC in PWROG letter OG-06-356, "Plan for
39 Plant Specific Implementation of Extended Inservice Inspection Interval per WCAP 16168-NP,
40 Revision 1, "Risk Informed Extension of the Reactor Vessel In-Service Inspection Interval,"
41 MUHP 5097-99, Task 2059," dated October 31, 2006 (Reference 10).
42

43 The inspection method, the acceptance criteria, and reporting requirements for inspection
44 results that will modify from ASME Code requirements are discussed in section 3.3 of this safety
45 evaluation (SE).

1 3.2 Conduct Engineering Evaluations
2

3 According to the guidelines in RG 1.174 and SRP Chapter 19.2, the second element associated
4 with a risk-informed application is an analysis of the proposed change using a combination of
5 traditional engineering analysis with supporting insights from a risk assessment.
6

7 The objective of this study was to verify that a reduction in the frequency of volumetric
8 examination of the RV full-penetration welds could be accomplished with an acceptably small
9 change in risk. The methodology used to justify this reduction involved estimating the potential
10 increase in risk caused by extending the RV inspection interval from 10 to 20 years. The
11 increase in risk was evaluated against RG 1.174 criteria to determine if the values met the
12 specified regulatory guidelines. The other key principles in RG 1.174 were also addressed in the
13 evaluation. The intent was that licensees can then use the results of this bounding assessment
14 to demonstrate that their RV and plant are bounded by the generic analysis, thereby justifying an
15 extension of their plant-specific RV weld inspection interval.
16

17 The engineering evaluations in the TR were based on the NRC staff's PTS Risk Study that is the
18 technical basis for the proposed alternative fracture toughness requirements for pressurized
19 thermal shock in 10 CFR 50.61a (Reference 4).
20

21 3.2.1 Engineering Evaluation
22

23 The ISI interval extension methodology was primarily based on a risk analysis, including a
24 probabilistic fracture mechanics (PFM) analysis of the effect of different inspection intervals on
25 the frequency of RV failure due to postulated PTS transients. RV failure is defined for the
26 purposes of this study as through-wall cracking of the RV wall. The likelihood of RV failure was
27 postulated to increase with increasing time of operation due to the growth of pre-existing
28 fabrication flaws by fatigue in combination with a decrease in RV fracture resistance due to
29 irradiation. Credible, postulated PTS transients that could potentially lead to RV failure were
30 considered to occur at the worst time in the life of the plant (as defined by flaw size and level of
31 RV embrittlement). The PFM methodology allowed for the consideration of distributions and
32 uncertainties in flaw number and size, material properties, crack growth resulting from fatigue,
33 accident transients, stresses, and the effectiveness of inspections. The PFM approach led to a
34 conditional RV failure frequency due to a given loading condition and a prescribed inspection
35 interval. The PFM analyses documented in the TR evaluated the impact of different inspection
36 intervals on the three, previously-identified pilot plants.
37

38 Limiting Location for RV Failure
39

40 To determine the limiting location in the RV, the PWROG evaluated the impact of flaws in each
41 RV region. The PWROG used deterministic fracture mechanics analyses, which utilized a 10
42 percent through-wall flaw, assumed 40 effective full power years (EFPY) of embrittlement for the
43 flaws in the RV beltline and included fatigue crack growth due to normal plant operating
44 transients for all flaws. Each crack length was evaluated at the end of a 10 year interval to
45 determine the maximum applied stress intensity factor ($K_{I,applied}$). The ratio of the maximum
46 allowable stress intensity factor ($K_{I,allowable}$), per the ASME Code, Section XI, Appendix A criteria,
47 to $K_{I,applied}$ was used as a measure of the margins to failure. The lower the ratio of $K_{I,allowable}/K_{I,applied}$,
48 the lower the margin to failure and the more limiting the location. Figures 3-1 and 3-2 in

1 the TR indicated that the beltline welds have the lowest ratio of ASME Code allowable stress
2 intensity values ($K_{I \text{ allowable}}/K_{I \text{ applied}}$). These figures do not include the full penetration nozzle-to-
3 vessel welds. The NRC staff requested that the PWROG provide the ratio of ASME Code
4 allowable stress intensity value for full penetration nozzle-to-vessel welds to demonstrate that
5 the beltline welds were the limiting locations. In the response to RAI 5 from Reference 3, the
6 PWROG provided the requested information. The PWROG analyses indicated that the beltline
7 is more limiting than the full penetration nozzle-to-vessel welds.
8

9 The results from the PWROG deterministic analyses were consistent with assumptions utilized
10 in the NRC PTS Risk Study which concluded that the limiting RV region was the beltline region.
11 Since the RV beltline region has the lowest margin to failure, the NRC staff also concluded that
12 the beltline region is the most limiting location and the beltline location can be used to determine
13 the impact of different inspection intervals on the frequency of RV failure.
14

15 Distributions and Uncertainties in Flaw Number and Size

16
17 Section 3.2 of the TR indicated that surface-breaking and embedded flaws were used in the
18 PFM analysis. Since embedded flaws do not grow significantly due to fatigue, they were not
19 evaluated as part of the fatigue growth analysis. To simulate embedded flaws in welds and
20 plates, the PWROG pilot plant studies for the RV ISI interval extension used the embedded flaw
21 distribution for welds and plates from the NRC PTS Risk Study.
22

23 Surface-breaking flaws were assumed to grow by fatigue as a result of normal operating
24 conditions. A discussion of the initial size and distribution of the assumed surface-breaking
25 flaws was provided by the PWROG in response to RAI 1 from Reference 3. The PWROG
26 indicated that the initial size and distribution of the surface flaws were consistent with the size
27 and distribution developed by Pacific Northwest National Laboratory (PNNL) for use in the NRC
28 PTS Risk Study. The initial size and distribution of surface-breaking flaws utilized the computer
29 code VFLA W03, which was developed by PNNL and is described in NUREG/CR-6817,
30 Revision 1, "A Generalized Procedure for Generating Flaw-Related Inputs for the FAVOR Code"
31 (Reference 11). The initial surface-breaking flaw size and distribution were input into a fatigue
32 crack growth and ISI analysis to determine a surface flaw density file after any ISI. Surface flaw
33 density files were created to simulate two inspection routines. The first case simulated
34 inspections performed on a 10 year interval as currently required by the ASME Code. The
35 second case simulated a single inspection performed after the first 10 years of operation with no
36 subsequent inspection. These surface-breaking flaw density files are then input into the PFM
37 analysis as surface-breaking flaw density files. Since the characterization of embedded flaws in
38 plates and welds and the initial surface-breaking flaw size for the fatigue analysis used
39 distributions that were used in the NRC PTS Risk Study, they are applicable for use in RV ISI
40 interval extension analyses.
41

42 In Attachment 1 to the June 8, 2006 letter (Reference 2), the PWROG indicated that underclad
43 cracks in forgings are so shallow that the probability of them growing through-wall during a
44 severe PTS transient would be fairly small. NUREG-1874 indicated that for severe PTS
45 transients, the TWCF for forgings with underclad cracks can be greater than those for axial
46 welds, plates and forgings without underclad cracks. In its response to RAI 2 from Reference 3,
47 the PWROG provided an analysis of the TWCF for axial welds, plates, forgings without
48 underclad cracks, and forgings with underclad cracks. The analysis, which used correlations

1 from NUREG-1874, indicated forgings with underclad cracks have a higher TWCF than welds,
2 plates and forgings without underclad cracks when the RT_{MAX-FO} ¹ is greater than 240 °F.
3 Table 3.4 in NUREG-1874 indicated that the highest RT_{MAX-FO} for a PWR RV ring forging is
4 187.3 °F at 32 EFPY and 198.6 °F at 48 EFPY. Therefore, it is unlikely that the RT_{MAX-FO} value
5 for any domestic PWR will ever exceed 240 °F and the TWCF value for all such forgings will
6 remain below that for axial welds with equivalent reference temperatures. The PWROG
7 indicated that the analyses performed in the TR would not be applicable without further
8 evaluation for RVs with RT_{MAX-FO} values exceeding 240 °F.

9 Fatigue Crack Growth Analysis

10 Section 3.2 of the TR indicated that the pilot plant studies included a probabilistic representation
11 of the fatigue crack growth correlation for ferritic materials in water consistent with the previous
12 and current models contained in ASME Code, Section XI, Appendix A. The probabilistic
13 representation was consistent with those used in the pc-PRAISE computer code and
14 NRC-approved structural reliability and risk assessment (SRRA) tool for piping risk-informed ISI.
15 In Appendix A of the NRC staff SE on WCAP-14572, Revision 1, "Westinghouse Owners Group
16 Application of Risk-Informed Methods to Piping Inservice Inspection Topical Report"
17 (Reference 13), the NRC staff concluded that the SRRA tool addresses fatigue crack growth in
18 an acceptable manner since it is consistent with the technical approach used by other state-of-
19 the-art PFM computer codes. The NRC staff noted that realistic predictions of failure
20 probabilities require that the user define input parameters which accurately represent all sources
21 of fatigue stress and the probability for preexisting fabrication defects in welds. As discussed in
22 the preceding section of this SE, the size and distribution of preexisting surface-breaking
23 fabrication flaws was consistent with the size and distribution developed by PNNL for use in the
24 NRC PTS Risk Study.

25 Design basis transients for the pilot plants were reviewed and the PWROG determined that the
26 greatest contributor to fatigue crack growth for surface-breaking flaws initiating from the inside
27 surface of the RV for the pilot plants is the RV heat-up and cool-down transient. Each transient
28 represents a full heat-up and cool-down cycle between atmospheric pressure at room
29 temperature and full-system pressure at 100-percent power operating temperature. This
30 transient envelopes many transients with smaller ranges of conditions. For the pilot plant
31 evaluations, seven heat-up and cool-down cycles per year were used for the Westinghouse-
32 designed plant, BV1, 13 heat-up and cool-down cycles were used for the Combustion
33 Engineering (CE)-designed plant, Palisades, and 12 heat-up and cool-down cycles were used
34 for the Babcock and Wilcox (B&W)-designed plant, OC1, to bound all the design basis
35 transients for the respective PWR plant designs in each fleet.

1 RT_{MAX-FO} means the material property which characterizes the RV's resistance to fracture
2 initiation from flaws in forgings that are not associated with welds in the forgings. RT_{MAX-FO} value
3 is calculated under the provisions of Sections (f) and (g) of 10 CFR 50.61a, Alternative fracture
4 toughness requirements for protection against pressurized thermal shock, in Enclosure 1 to the
5 Proposed Rulemaking in SECY-07-0104 (Reference 12).

1 In response to RAI 1 from Reference 3, the PWROG provided a description of the analyses
2 performed to determine whether the seven heat-up and cool-down cycles per year for
3 Westinghouse plants and the 13 heat-up and cool-down cycles per year for CE plants bound all
4 the design basis transients for the respective PWR Nuclear Steam Supply System (NSSS)
5 designs in each fleet. For Westinghouse plants, previous fatigue crack growth analyses of flaws
6 on the inside surface of the RV had shown that only four transients result in measurable crack
7 growth. Sensitivity studies for the four contributing transients were performed. These analyses
8 indicated that the only design transient that resulted in significant crack growth was the cool-
9 down transient. The design basis for the Westinghouse plant was based on five cool-down
10 cycles per year. An additional two cycles per year were added to the analysis to envelope the
11 contribution of the other three transients which contributed to measurable fatigue crack growth.
12

13 Previous fatigue growth studies were not available for CE-designed plants. Therefore, all design
14 transients were evaluated in the CE transient fatigue crack growth sensitivity study. This study
15 indicated that the cool-down transient produced the largest amount of fatigue growth for a RV
16 inside surface flaw. The loss of secondary pressure transient also produced measurable
17 growth. Assuming 12 cool-down cycles per year was considered to be conservative in
18 comparison to the actual number of cool-downs a plant might experience in a given year based
19 on plant operating experience. One additional cool-down cycle was added to the analysis to
20 envelope the contribution to fatigue crack growth of the loss of secondary pressure transient.
21

22 Based on the results of the fatigue crack growth sensitivity studies, the number of cool-down
23 transients assumed for the Westinghouse and CE-designed pilot plants will envelope the fatigue
24 crack growth from all Westinghouse and CE NSSS design transients. All RVs are inspected
25 before operation providing confidence that there are no large flaws throughout the RV that have
26 a high likelihood of failure given a PTS event. Only surface-breaking flaws are assumed to grow
27 from fatigue crack growth.
28

29 Fatigue crack growth sensitivity studies were not performed to determine the effect of B&W
30 design transients for fatigue crack growth in B&W designed plants. Therefore, any B&W plant
31 licensee using the results of the TR to extend the RV ISI interval from 10 to 20 years, including
32 the pilot plant, must demonstrate that the assumption of 12 heat-up/cool-down transients per
33 year in the TR analysis bounds the fatigue crack growth for all design basis transients for that
34 unit.
35

36 For the purpose of the pilot plant studies in the TR, an 80-year life for fatigue crack growth was
37 used. This 80-year life envelopes plants seeking to obtain license extensions to 60 years and
38 provides an additional margin of conservatism. This result in a total of 560 heat-up/cool-down
39 transients for the Westinghouse-designed unit, 1040 heat-up/cool-down transients for the
40 CE-designed unit, and 960 heat-up/cool-down transients for the B&W-designed unit. The
41 PWROG indicated that most plants operational histories indicate that they will not reach this
42 number of design transients by end of 80 years of operation. Hence, this calculation was
43 performed as a bounding analysis based on actual plant operating histories.
44

45 In response to RAI 1 from Reference 3, the PWROG indicated that the fatigue crack growth
46 rates that are used in the fatigue crack growth analysis are taken from Section 4.2.2 of the
47 Theoretical and Users Manual for PC-PRAISE (Reference 14). As noted in this report, these
48 "equations provide a probabilistic representation of the fatigue growth relationship for ferritic
49 materials in water contained in Appendix A of Section XI of the ASME Boiler and Pressure

1 Vessel Code.” Figure A-4300-2, “Reference Fatigue Crack Growth Curves for Carbon and Low
2 Alloy Ferritic Steels Exposed to Water Environments,” from Appendix A to Section XI in the
3 current edition of the ASME Code, provides a graphical representation of these equations. It
4 should be noted that the fatigue crack growth curves in Appendix A of Section XI of the ASME
5 Code have not changed since they were originally included in the 1978 Edition of Section XI.
6 Since the crack growth rate code used in the PWROG analysis was taken directly from a code
7 that was previously reviewed and approved by the NRC staff in Reference 13 and is based on
8 the ASME Code crack growth rate curves, the crack growth rate code used in the PWROG
9 analysis is acceptable.

10 Effectiveness of ISI

11
12
13 To determine the impact of different inspection intervals on the frequency of RV failure, the
14 effectiveness of the ISI must be considered. The PWROG considered the impact of the
15 probability of detection (POD) of flaws when ultrasonic inspection is performed on the RV welds
16 and adjacent base metal. The basis for the POD used in the pilot plant studies for the RV ISI
17 interval extension was taken from studies performed at the Electric Power Research Institute
18 (EPRI) Nondestructive Examination (NDE) Center on the detection and sizing qualification of
19 ISIs of the RV beltline welds (Reference 15). Figure 3-4 in the TR illustrates the POD as a
20 function of flaw size. The POD ranges from 0.5 for very small flaws up to 0.9 and greater for
21 flaws with through-wall depths greater than 0.25 inches.

22
23 For the pilot plant evaluations, ultrasonic examinations were assumed to be conducted in
24 accordance with ASME Code, Section XI, Appendix VIII. Flaws that were detected were
25 assumed to be repaired with the repaired area returned to a flaw-free condition. If the quality of
26 inspection is not as good as assumed or the quality of the repair is less than 100 percent, then
27 the result would be fewer flaws found and fewer flaws removed during repair, resulting in less
28 difference in risk from one inspection interval to another. The POD values used in the analysis
29 were relatively high and, therefore, the pilot plant studies conservatively calculated a larger
30 potential difference in risk by maximizing the benefits of inspection.

31 Material Fracture Toughness and Neutron Embrittlement

32
33
34 The RV material properties for each of the pilot plant studies used plant-specific properties that
35 are identified in Appendices B, F, and J in the TR. These material properties are input to the
36 Fracture Analysis of Vessels – Oak Ridge (FAVOR) Code (Reference 16). The FAVOR Code,
37 which was developed by Oak Ridge National Laboratory (ORNL) to perform PFM analyses for
38 the NRC PTS Risk Studies, includes fracture toughness models which are based on extended
39 databases of empirically obtained plane strain fracture toughness (K_{Ic}) and crack arrest fracture
40 toughness (K_{Ia}) data points and include the effects of statistical bias for direct measurement of
41 fracture toughness.

42
43 The input to the FAVOR Code includes plant-specific neutron fluence maps for each of the pilot
44 plants. For the pilot plant evaluations in the TR, the input neutron fluence distributions were
45 taken directly from the NRC PTS Risk Study. A series of neutron transport calculations were
46 performed for the NRC PTS Risk Study to determine the neutron fluence on the inner wall of the
47 pilot plant RVs. The modeling procedures were based on the guidance contained in RG 1.190,
48 “Calculational and Dosimetry Methods for Determining Pressure Vessel Neutron Fluence”
49 (Reference 17). The models incorporated pilot plant-specific geometry and operating data. The

1 neutron fluence for energies greater than one million electron volts ($E > 1\text{MeV}$) was calculated
2 as a function of the azimuthal and axial location on the inner wall of the RV. The neutron
3 fluence was extrapolated from the current state point to various EFPY of operation assuming a
4 linear extrapolation of the most recent operating cycles.

5
6 The neutron fluence values used in the RV ISI interval extension evaluations were for 60 EFPY
7 for BV1 and Palisades and were for 500 EFPY for OC1. 500 EFPY were used for OC1 rather
8 than 60 EFPY to envelope license extension consideration and because it is recognized that
9 OC1 is not the most radiation sensitive RV in the B&W fleet. The use of 500 EFPY for OC1
10 should bound the embrittlement of the most highly embrittled RV in the B&W fleet.

11 Accident Transients

12
13
14 PTS events are viewed as providing the greatest challenge to PWR RV structural integrity. If a
15 RV had an existing flaw of critical size and certain PTS transients were to occur, this flaw could
16 rapidly propagate through the RV wall, resulting in a through-wall crack and challenging the
17 integrity of the RV. The PTS Risk Study utilized plant-specific probabilistic risk assessment
18 (PRA) models to determine the possible sequences which could result in a PTS event for each
19 of the pilot plants. Due to the large number of sequences which were identified, it was
20 necessary to group (i.e., bin) sequences with like characteristics into representative transients
21 (PTS transients) that are analyzed using thermal-hydraulic (TH) codes.

22
23 TH analyses were performed for each PTS transient to develop time histories of temperature,
24 pressure, and heat transfer coefficients. These histories were then input into the FAVOR code
25 where they were used during the calculation of the conditional probability of RV failure for each
26 PTS transient. From this analysis, it was determined that only a portion of the PTS transients
27 contribute to the total risk of RV failure, while the remaining transients have an insignificant or
28 zero contribution. The transients which were identified to be contributors to PTS risk were then
29 used for the PFM analysis in the PTS study and for the pilot plant studies in the TR.

30 Stresses Resulting from PTS Transients, Cladding and Welding

31
32
33 For each PTS transient, deterministic calculations were performed to produce a load definition
34 input file that includes time-dependent, through-wall temperature profiles, through-wall
35 circumferential and axial stress profiles, and stress intensity factors for a range of axially and
36 circumferentially-oriented embedded and inner surface-breaking flaw geometries. This load
37 definition file was input into the FAVOR code to produce the conditional probability of failure
38 (CPF) (i.e., the conditional probability of a through-wall crack) for each PTS transient. These
39 probabilities estimated by the FAVOR code (complete with uncertainties) are conditional in the
40 sense that, within the FAVOR code probabilistic fracture mechanics module (FAVPFM), the TH
41 transients are assumed to occur.

42
43 In addition to the stress resulting from PTS transients, the PWROG analysis included the impact
44 of cladding and residual stresses on the probability of failure. The pilot plant studies for RV ISI
45 interval extension used a residual weld stress distribution through the wall that was taken from
46 the NRC PTS Risk Study and is described in the FAVOR Code Theory Manual (Reference 16).
47 The cladding stress used in the pilot plant studies was taken from the NRC PTS Risk Study.
48 The cladding temperature dependence due to differential thermal expansion was based on a
49 stress free temperature of $488\text{ }^{\circ}\text{F}$, which is consistent with that used in the NRC PTS Risk Study.

1 Staff Evaluation of Engineering Considerations in PFM Analysis

2
3 The material fracture toughness, neutron embrittlement, distribution and uncertainties in
4 embedded and surface-breaking flaws, accident transients, frequency of transients, and stress
5 resulting from PTS transients, cladding, and welding used in the PWROG ISI interval extension
6 study are acceptable because the values and methodologies were derived from the NRC PTS
7 Risk Studies. The fatigue crack growth analysis used in the PWROG ISI interval extension
8 study is acceptable because it was performed using a code approved by the NRC and has
9 considered all sources of fatigue stress and the probability for preexisting fabrication flaws. The
10 effectiveness of ISI has been adequately determined because it used data from studies
11 performed at the EPRI NDE Center on the detection and sizing qualification of ISIs of RV beltline
12 welds. Based on the above conclusions, the NRC staff considers that the PWROG has
13 adequately considered the engineering variables in determining the risk of RV failure in its ISI
14 interval extension study.

15
16 The PWROG has identified two items that must be further evaluated. They are:

- 17
18 1) Licensees for B&W plants using the results of TR WCAP-16168-NP, Revision 2 to
19 extend the RV ISI interval from 10 to 20 years (including the pilot plant) must
20 demonstrate that the assumption of 12 heat-up/cool-down transients per year in the
21 TR analysis bounds the fatigue crack growth for all design basis transients for that
22 unit.
23
24 2) RVs with RT_{MAX-FO} values exceeding 240 °F require further evaluation because the
25 analyses performed in TR WCAP-16168-NP, Revision 2 are not applicable.
26

27 3.2.2 Probabilistic Risk Assessment

28
29 PTS events were viewed as providing the greatest challenge to PWR RV structural integrity and,
30 therefore, the PRA had to estimate the frequency and severity of PTS transients. PTS transients
31 are not normally modeled in PRAs and the analyses of the pilot plants in the TR used the PTS
32 transients and frequencies from the NRC PTS Risk Study. As part of the NRC PTS Risk Study,
33 PRA models were developed by the NRC staff for each of the three pilot plants using
34 plant-specific information (References 18, 19, and 20). These three units included one unit from
35 each of the PWR vendors. These PRA models included an event tree analysis that defined the
36 sequences of events that are likely to produce a PTS challenge to RV structural integrity for
37 each of the pilot plants. As discussed above, individual event tree sequences with like
38 characteristics were binned into representative PTS transients.
39

40 The results of the PRA in the PTS Risk Study included descriptions of each PTS transient from
41 which the TH characteristics of each transient can be developed, and estimates of the frequency
42 with which each transient was expected to occur. The final transient frequency estimates were
43 distributions (histograms) which represented the combined frequency, including uncertainties, of
44 all the event tree sequences incorporated into each bin. Appendices D, H, and L in the TR
45 briefly described the failures and the mean estimated frequency for each bin for each of the
46 three pilot plants.
47

48 The transient frequencies were input into the FAVPOST module, the final module in the FAVOR
49 Code. This module combined the conditional initiation and through-wall cracking probabilities

1 through a matrix multiplication with the frequency histograms for each PTS transient provided by
2 the PRA analyses.

3
4 3.2.2.1 Estimating the Risk Associated with Extending the RV Weld Inspection Interval from
5 10 to 20 Years

6
7 The likelihood of RV failure was postulated to increase with increasing time of operation due to
8 the growth of pre-existing fabrication flaws by fatigue in combination with a decrease in RV
9 toughness due to irradiation. The PFM approach in the TR simulated the growth of flaws over
10 time and the repair of flaws that are detected during a periodic ISI. The largest cracks were
11 expected to exist at the end of the plant's operating life because, even with periodic inspection,
12 flaws may be missed during an inspection. These flaws would remain in service and grow until
13 eventually detected by ISI, causing RV failure during a PTS event, or the end of plant life is
14 reached. The end of operating life is also the time when the RV will be most embrittled and most
15 subject to failure for any size crack.

16
17 Therefore, instead of assuming that PTS transients can occur randomly during the operating life,
18 the PWROG's response to RAI 9 from Reference 3 explained that the TR conservatively
19 estimated the CPF for each PTS transient by applying the PTS loadings to the material
20 properties and the distribution of flaws sizes expected to exist on the first day of full power
21 operation following the refueling outage after the last operating year of the extended license of
22 the plant. The NRC staff concurred that this process approximates the greatest CPF expected
23 to exist during the life of the plant. The PTS transients' frequencies were not expected to
24 change over the plant life so the product of these frequencies with the maximum CPF is
25 acceptable because it results in a bounding estimate for the TWCF and associated increase in
26 risk.

27
28 The current inspection interval is 10 years and the base case scenario for the change in risk
29 analysis is one inspection every 10 years. Rather than evaluate each plants' specific inspection
30 cycle, the TR bounded the impact of extending the interval by estimating the risk increase as the
31 difference between the base case risk (assuming that the RV was inspected every ten years)
32 and the risk assuming that a plant only had one inspection after the first 10 years and then was
33 never inspected again for the remaining life of the plant. Plant life was assumed to be 80 years,
34 for both the base case (every 10 year inspection) and the bounding case (only one inspection).
35 The NRC staff concurred that this evaluation is applicable to all plants and the change in risk
36 estimated for this scenario will bound the change expected by extending the 10 year interval to a
37 20 year interval.

38
39 The TR assumed that a through-wall crack will lead to core damage and that core damage will
40 lead to a large early release. The RG 1.174 guideline addressing an acceptable increase in
41 large early release frequency (LERF) is the smallest guideline value. Requiring that the TWCF
42 is less than the LERF guideline ensured that both the core damage frequency (CDF) and LERF
43 guidelines are met. The equation in FAVPOST that was used to estimate risk with and without
44 periodic inspection for plant j is;

45
46
$$\text{LERF}_j = \text{CDF}_j = \text{TWCF}_j = \sum \text{IE}_{ji} * \text{CPF}_{ji}$$

47
48 where,

1 IE_{ji} is the initiating event frequency (events per year) for each of the i representative PTS
2 transients for plant j developed during the PTS Risk Study. The PTS Risk Study developed
3 full distributions for the frequency of each PTS transient bin and the TR used the full
4 distribution.² IE_{ji} does not change when the inspection period changes.
5

6 CPF_{ji} is the conditional probability of RV vessel failure (conservatively assumed to occur if a
7 through-wall crack develops) given the thermal-hydraulic characteristics of each of the i
8 representative PTS transients for plant j . As described above, the RV material properties
9 and the distribution of flaw sizes are those expected to exist at the end of plant j 's operating
10 life. The distribution of flaw sizes is the parameter that changes when the inspection period
11 changes and, therefore, CPF_{ji} changes when the inspection period changes.
12

13 The NRC staff concurs that the PRA models of PTS transient frequency, the IE_{ji} and CPF_{ji}
14 parameters, and the above equation appropriately capture the significant contributors to risk
15 from RV failure and, therefore, fulfill the RG 1.174 guidance that the analysis is capable of
16 modeling the impact of the proposed change. The NRC staff also concurs that the bounding
17 estimates from only one inspection versus an inspection every ten years appropriately envelops
18 the impact of the proposed change for any facility regardless of its inspections schedule and
19 history.
20

21 ISI is directed toward identifying surface-breaking and embedded flaws that have grown large
22 enough to require repair. In the response to RAI 12a from Reference 3, the PWROG noted that
23 the frequency of surface-breaking flaws should be very small because none had ever been
24 discovered during either pre-service or in-service examinations of beltline welds. With few such
25 flaws, few failures were observed from the simulations even when fatigue crack growth was
26 included. With few failures, it was difficult to obtain a converged solution using Monte Carlo
27 simulation in the FAVOR Code because its precision is based upon the number of failures in the
28 total number of simulations. In order to obtain a converged solution, the dominant contribution to
29 TWCF from embedded flaws was included³ in the simulations. The result of including the
30 dominant contribution from embedded flaws in the simulation was that direct comparison of the
31 mean TWCF with only one inspection and the mean TWCF with inspections every ten years did
32 not produce a stable metric. This is illustrated by, for example, the results in Table 4-1 in the TR
33 which reported that the estimated TWCF for BV1 with only one inspection ($5.04E-9$ /year) was
34 smaller than the TWCF with one inspection every ten years ($5.23E-9$ /year) although the more
35 frequent inspection program should result in a smaller TWCF.
36

37 In the response to RAI 12b from Reference 3, the PWROG, reported on a sensitivity study that
38 was performed by running the Monte Carlo simulation without the embedded flaws. The
39 PWROG reported that the number of FAVOR simulations was increased from 70,000 to 500,000
40 but that no failures were obtained for both the only one inspection and the inspection every ten

2 Appendices D, H, and L include only the mean frequency estimates from the PTS transient bins, but the calculations illustrated in Appendices E, I, and M are performed using the full initiating event frequency distributions.

3 The NRC staff concluded during the PTS Risk Study, that embedded flaws do not grow over time and therefore their contribution to TWCF is driven by the initial flaw distribution and is unaffected by the ISI interval.

1 years simulations. The PWROG noted that excluding embedded flaws results in a zero TWCF
2 for both inspection intervals and, therefore, a zero increase in TWCF given the proposed interval
3 extension.
4

5 Because of the uncertainty in how accurately an insignificant (null) effect can be calculated using
6 standard Monte Carlo simulation, the PWROG included embedded flaws and estimated the
7 change in risk by subtracting the lower bound mean estimate for one inspection every ten years
8 from the upper bound mean estimate for only one inspection. The PWROG argued that this
9 difference represents the maximum statistically calculated value for the potential change in risk
10 at a number of RV simulations for which the Monte Carlo statistical analysis has reached a
11 stable solution. In its response to RAI 12c from Reference 3, the PWROG described the
12 derivation of the standard error on the mean which was used to calculate the upper and lower
13 bound estimates. The standard error is a statistical estimate reflecting how much sampling
14 fluctuation was observed which can be used to estimate confidence intervals about the mean
15 estimate. The PWROG chose to use two times the standard error to develop its confidence
16 bounds. Therefore, if repetitive simulations (each with 70,000 trials) were performed, it is expect
17 that in only 2.5% of the mean estimates would exceed the upper bound value and 2.5% would
18 be less than the lower bound value.
19

20 The NRC staff concluded that the analyses described in the TR provided a reasonable or
21 bounding estimate of the increase in risk associated with extending the inspection interval for RV
22 welds from 10 to 20 years. As discussed above, the NRC staff based this conclusion on:
23

- 24 • the PRA models of PTS transient frequency, the IE_{ji} and CPF_{ji} parameters, and the
25 equation used to calculate the risk from PTS events appropriately capturing the
26 significant contributors to risk from RV failure,
27
- 28 • the bounding estimates from only one inspection versus an inspection every ten years
29 appropriately modeling the impact of the proposed change for any facility regardless of
30 its RV inspections schedule and history,
31
- 32 • the TWCF from surface-breaking flaws being so small that the Monte Carlo estimation
33 techniques in the FAVOR code do not converge to a stable solution indicating that the
34 TWCF from surface-breaking flaws is small regardless of the inspection program interval,
35 and
36
- 37 • the subtraction of the lower bound mean estimate for one inspection every ten years from
38 the upper bound mean estimate for only one inspection being consistent with the
39 guidance in RG 1.174 that the difference in the means (in this case confidence estimates
40 on the means) is the risk metric that should be compared with the acceptance guidelines.
41

42 3.2.2.2 Evaluation of PRA Technical Adequacy 43

44 Technically adequate is defined, at the highest level, as an analysis that is performed correctly,
45 in a manner consistent with accepted practices, commensurate with the scope and level of detail
46 required to support the proposed change. The PWROG used the PTS transient frequencies
47 developed in the NRC PTS Risk Study in its analysis. The TR conservatively assumed that core
48 damage and large early release will inevitably follow a PTS transient that results in a

1 through-wall crack. Therefore, there is no PRA event and sequence modeling needed beyond
2 the determination of the PTS transient frequencies.

3
4 The NRC staff developed plant-specific PRA analyses to estimate the PTS transient frequencies
5 for each of the three pilot plants using a process described in detail in NUREG/CR-6859, "PRA
6 Procedures and Uncertainty for PTS Analysis" (Reference 21). The analyses were described in
7 detail in the plant-specific PRA reports (References 18, 19, and 20) and summarized in Chapter
8 5 of the PTS Risk Study. The process included a review of the PRA analyses performed during
9 the 1980s in support of the first PTS rule and a search of licensee event reports for the years
10 1980 through 2000 to gain an understanding of the frequency and severity of observed
11 overcooling events. The PRA analyses used realistic input values and models and an explicit
12 treatment of uncertainties. Best estimate equipment failure values were used throughout based
13 on generic nuclear industry data or, in cases where it was available, on plant-specific data.
14 Parameters related to human performance were based on review of plant-specific procedures
15 and training, observation of plant personnel responding to PTS-related sequences on their
16 simulator, and performance data from actual plant operations. The scope of the study covered
17 all event sequences in the range from zero power hot stand-by up to 100% power

18
19 As discussed in the individual pilot plants' PRA reports, all analyses were conducted through
20 plant visits and by numerous interactions (vocal, written, and e-mail exchanges) with each
21 licensee as the analysis evolved. During a first site visit, the PTS study team collected
22 information. After preliminary results were completed, reviews were performed both by licensee
23 and NRC project staff during a second site visit. The OC1 and BV1 models used system level
24 fault trees and system level failure data. The Palisades model used detailed system level fault
25 trees from the licensee's PRA. Formal reviews were carried out for OC1 and BV1. Palisades'
26 models were developed by the licensee and reviewed by the NRC staff.

27
28 A final peer review was carried out by a panel of six experts to provide an independent review of
29 the technical basis developed for the PTS Rulemaking (Reference 6). The objective of the peer
30 review was to assess the adequacy and reasonableness of the technical basis to support the
31 proposed revision of the PTS rule. The peer reviewers focused on different parts of the PTS
32 analysis. Comments related to the PRA aspects generally concluded that the work was well
33 founded and reasonable and no serious weaknesses were identified.

34
35 Based on the PTS Risk Study's detailed review of past studies and operating experience,
36 extensive interactions between the analysis team and the plant personnel at all units, and the
37 opportunity for the same team to benefit from the multiple plant study insights while performing
38 all the analyses, the NRC has confidence that the PTS transient frequency results from the PRA
39 analyses in the PTS Risk Study are sufficiently well developed to be able to demonstrate that the
40 change in risk estimates as developed in the TR does not exceed the acceptance guidelines in
41 RG 1.174.

42 43 3.2.2.3 Generic Applicability and External Events

44
45 During the development of the PTS Risk Study, the NRC staff investigated the applicability of the
46 results from the three pilot plants to the operating fleet of PWRs. These three units included one
47 unit from each of the three PWR vendors. This investigation examined plant design and
48 operational characteristics of five additional plants as described in Letter Report, "Generalization
49 of Plant-Specific Pressurized Thermal Shock (PTS) Risk Results to Additional Plants,"

1 (Reference 22). The overall approach was to compare potentially important design and
2 operational features (as related to PTS) of the other PWRs to the same features of the pilot
3 plants to determine the extent these features are similar or different.
4

5 In 72 FR 56275 (Reference 4), the NRC staff reported its conclusion that the TWCF results from
6 the PTS Risk Study can be applied to the entire fleet of operating PWRs. This conclusion was
7 based on an understanding of characteristics of the dominant transients that drive their risk
8 significance. The generic evaluation revealed no design, operational, training, or procedural
9 factors that could credibly increase the severity of these transients or the frequency of their
10 occurrence in the general PWR population above the severity/frequency characteristics of the
11 three plants that were modeled in detail. As applied to the analyses included in the TR, this
12 conclusion indicated that the PTS transient frequencies and TH characteristics used to estimate
13 the change in risk are dependent only on the reactor vendor and are generally applicable to all
14 PWRs from that vendor.
15

16 The detailed plant-specific PRAs in the PTS Risk Study evaluated the contribution of internal
17 initiating events to TWCF. The study group also evaluated the potential contribution of external
18 initiating events to PTS risk as described in Reference 23 and summarized in Section 9.4 of the
19 PTS Risk Study. The external events included in the evaluation were fires, floods, high winds
20 and tornados, and seismic events. This analysis was structured by identifying three broad types
21 of overcooling scenarios and making conservative judgments with regard to the type and
22 frequency of external events that could directly contribute to causing each overcooling scenario.

23 The conservative judgments were directed toward bounding the PTS TWCF contributions
24 attributable to external events for the worst situation that might arise at virtually any plant. The
25 study's results indicated that the bounding total external event TWCF is approximately
26 $2E-8/\text{year}$, quantitatively comparable to the highest internal events contribution of $2E-8/\text{year}$.
27 The study concluded that there was considerable assurance that the external event contribution
28 to the overall TWCF as a result of external event initiated PTS events is at least no greater than
29 the highest best estimate contribution from internal events.
30

31 Based on the results of the PTS Generalization Study, the NRC staff has concluded that the
32 PTS transient characteristics (both frequency and TH characteristics) are generically applicable
33 for all similar plants (i.e., plants from the same vendor) in the fleet. Based on the results of the
34 external events analyses, the NRC staff has also concluded that the contribution of external
35 events to the change in risk has been adequately evaluated and that the contribution to risk from
36 external events is equal or less than the contribution for internal events.
37

38 3.2.2.4 Comparison with RG 1.174 Acceptance Guidelines

39
40 The results of the change in risk analyses were summarized in Table 4-1 in the TR where the
41 bounding increases in risk were reported as $9.43E-10/\text{year}$, $1.81E-8/\text{year}$, and $1.26E-8/\text{year}$ for
42 BV1 (Westinghouse-designed plant), Palisades (CE-designed plant), and OC1 (B&W-designed
43 plant), respectively. These increases are well below the guideline for a very small increase in
44 LERF of $1E-7/\text{year}$ in RG 1.174.
45

46 The TR only incorporated the internal events PTS sequence frequency results from the PTS
47 rulemaking into its change in risk analysis. The largest increase in LERF was estimated as
48 $1.8E-8/\text{year}$ for the Palisades plant. The NRC staff's evaluation of external event contributions
49 to PTS risk determined that the total PTS risk would, at most, double compared to the risk from

1 internal events when the risk from external events are included. Since the total risk for the base
2 case and the only one inspection case would both double, the total change in risk would also
3 double. The NRC staff concluded that the greatest change in risk associated with extending the
4 inspection interval at any PWR using the methods and guidelines described in the TR and
5 endorsed in this SE is less than $5E-8$ /year. The NRC staff finds that this increase is small and
6 consistent with the intent of the Commission's safety goals.

7 8 3.3 Implementation and Monitoring 9

10 The third element in the RG 1.174 approach is to develop an implementation and monitoring
11 program to ensure that no adverse safety degradation occurs because of the proposed changes.
12 Therefore, an implementation and monitoring plan should be developed to ensure that the
13 engineering evaluation conducted to examine the impact of the proposed changes continues to
14 be valid after the change has been implemented. This will ensure that the conclusions that have
15 been drawn from the evaluation remain valid.

16
17 RV integrity depends upon licensees ensuring that the critical elements of the PFM analysis
18 described in the TR are valid. Licensees must monitor the number of cycles of transients that
19 could effect the fatigue crack growth analysis, the change in fracture toughness of the limiting
20 RV material due to exposure to radiation, and the flaw distribution in the RV welds and adjacent
21 base metal.

22
23 The number of transient cycles that were utilized in the fatigue crack growth analysis was
24 discussed in Section 3.2.1 of this SE. The PWROG used 7 heat-up and cooldown cycles per
25 year for Westinghouse-designed plants, 13 heat-up and cooldown cycles per year for CE-
26 designed plants, and 12 heat-up and cooldown cycles per year for B&W-designed plants. The
27 design basis for the Westinghouse plant was 5 cooldown cycles per year. Although it was
28 determined that three other transients did not significantly contribute to fatigue crack growth in
29 RV welds, an additional 2 cycles were conservatively added to envelope the contribution of
30 these three transients. Since the PWROG fatigue crack growth analysis for Westinghouse
31 NSSS designed plants determined that the only design basis transient that resulted in significant
32 crack growth was the cool-down transient, it is the only design basis transient that needs to be
33 monitored. Since the PWROG fatigue crack growth analysis of CE NSSS designed plants
34 determined that the amount of crack growth from 13 cool-down transients bounds the expected
35 crack growth from both cool-down and loss of secondary pressure transients, CE plants should
36 monitor the number of cool-down transients. Fatigue crack growth sensitivity studies were not
37 performed to determine the effect of B&W design transient for fatigue crack growth in B&W
38 designed plants. Therefore, any B&W plant using the results of the TR to extend the RV ISI
39 interval from 10 to 20 years (including the pilot plants), must determine the design basis
40 transients that contribute to significant crack growth in RV welds. These transients must be
41 monitored by the licensee.

42
43 Material fracture toughness was discussed in Section 3.2.1 of this SE and must be monitored by
44 determining whether the 95th percentile $TWCF_{TOTAL}$ ⁴ for the plant requesting to implement the
45 pilot plant study is less than the 95th percentile $TWCF_{TOTAL}$ from the pilot plant study. The 95th

4 The 95 percentile $TWCF_{TOTAL}$ is the sum of the 95 percentile $TWCF$ for all beltline materials. It is calculated in accordance with NUREG-1874.

1 percentile $TWCF_{TOTAL}$ was calculated based on the material property indexing parameter
2 RT_{MAX-X} .⁵ Appendix A in the TR identifies the 95th percentile $TWCF_{TOTAL}$ from the pilot plant
3 studies for BV1, Palisades, and OC1. The 95th percentile $TWCF_{TOTAL}$ value calculated for BV1
4 at 60 EFPY was 1.76E-08 events per year. The 95th percentile $TWCF_{TOTAL}$ value calculated for
5 Palisades at 60 EFPY was 3.16E-07 events per year. The 95th percentile $TWCF_{TOTAL}$ value
6 calculated for OC1 at 500 EFPY was 4.42E-07 events per year.

7
8 The flaw distributions used in the PWROG PFM analyses are described in Section 3.2.1 of this
9 SE. The PWROG utilized the flaw sizes and distributions in the NRC PTS Risk Study to
10 simulate embedded flaws in welds, forgings, and plates and to simulate the initial size and
11 distribution of surface-breaking flaws. Section (e) of the proposed 10 CFR 50.61a, Alternative
12 fracture toughness requirements for protection against pressurized thermal shock, in Enclosure
13 1 to the proposed rulemaking in SECY-07-0104 described the allowable flaw distribution for
14 embedded flaws and surface-breaking flaws that would be permitted for RVs that are at the PTS
15 screening limits described in the proposed 10 CFR 50.61a. By monitoring flaw sizes in
16 accordance with the criteria described in Section (e) of the proposed rulemaking in SECY-07-
17 0104, licensees will ensure that their RVs do not have flaws that invalidate the results of the
18 PWROG PFM analyses.

19
20 The NRC staff concludes that the implementation and monitoring described above will ensure
21 that the conclusions that have been drawn from the evaluation remain valid.

22 23 3.4 Submit Proposed Change

24
25 The fourth and final element in RG 1.174 approach is the development and submittal of the
26 proposed change to the NRC. Since the 10 year ISI interval is required by Section XI, IWB-
27 2412, as codified in 10 CFR 50.55a, a relief for an alternative, in accordance 10 CFR
28 50.55a(a)(3)(i), must be submitted and approved by the NRC to extend the ISI interval.
29 Licensees that submit a request for an alternative based on the TR need to submit the following
30 plant-specific information:

- 31
- 32 1) Licensees must demonstrate that the embrittlement of their RV is within the envelope
33 used in the supporting analyses. Licensees must provide the 95th percentile $TWCF_{TOTAL}$
34 and its supporting material properties at the end of the period in which the relief is
35 requested to extend the inspection interval from 10 to 20 years. The 95th percentile
36 $TWCF_{TOTAL}$ must be calculated using the methodology in NUREG-1874. The RT_{MAX-X}
37 and the shift in the Charpy transition temperature produced by irradiation defined at the
38 30 ft-lb energy level, ΔT_{30} , must be calculated using the latest approved methodology
39 documented in Regulatory Guide 1.99, "Radiation Embrittlement of Reactor Vessel
40 Materials," or other NRC-approved methodology. The PWROG response to RAI 3 from
41 Reference 3 and Appendix A in the TR identifies the information that is to be submitted.

5 RT_{MAX-X} values are determined for each beltline material. RT_{MAX-X} is a material property which characterizes the RVs resistance to fracture initiating from flaws in welds, plates, and forgings. The method of determining RT_{MAX-X} is described in Sections (f) and (g) of 10 CFR 50.61a, Alternative fracture toughness requirements for protection against pressurized thermal shock, in Enclosure 1 to the Proposed Rulemaking in SECY-07-0104.

- 1 2) Licensees must report whether the frequency of the limiting design basis transients
2 during prior plant operation are less than the frequency of the design basis transients
3 identified in the PWROG fatigue analysis that are considered to significantly contribute to
4 fatigue crack growth.
5
- 6 3) Licensees must report the results of prior ISI of RV welds and the proposed schedule for
7 the next 20 year ISI interval. The 20 year inspection interval is a maximum interval. In
8 its request for an alternative, each licensee shall identify the years in which future
9 inspections will be performed. The dates provided must be within plus or minus one
10 refueling cycle of the dates identified in the implementation plan provided to the NRC in
11 PWROG letter OG-06-356, "Plan for Plant Specific Implementation of Extended Inservice
12 Inspection Interval per WCAP 16168-NP, Revision 1, "Risk Informed Extension of the
13 Reactor Vessel In-Service Inspection Interval," MUHP 5097-99, Task 2059," dated
14 October 31, 2006 (Reference 10).
15
- 16 4) Licensees with B&W plants must (a) verify that the fatigue crack growth of 12 heat-
17 up/cool-down transients per year that was used in the PWROG fatigue analysis bound
18 the fatigue crack growth for all of its design basis transients and (b) identify the design
19 bases transients that contribute to significant fatigue crack growth.
20
- 21 5) Licensees with RVs having forgings that are susceptible to underclad cracking and with
22 RT_{MAX-FO} values exceeding 240 °F must submit a plant-specific evaluation to extend the
23 inspection interval for ASME Code, Section XI, Category B-A and B-D RV welds from 10
24 to a maximum of 20 years because the analyses performed in the TR are not be
25 applicable.
26

27 Within one year of completing each of the ASME Code, Section XI, Category B-A and B-D RV
28 weld inspections required in the proposed ISI interval, the licensee must provide the information
29 and analyses requested in Section (e) of the proposed 10 CFR 50.61a, Alternative fracture
30 toughness requirements for protection against pressurized thermal shock, in Enclosure 1 to the
31 proposed rulemaking in SECY-07-0104, Reference 12. Licensees that do not implement the
32 proposed 10 CFR 50.61a must amend their licenses to require that the information and analyses
33 requested in Section (e) of the proposed rulemaking in SECY-07-0104 will be submitted for NRC
34 staff review and approval. The amendment to the license shall be submitted at the same time
35 as the request for alternative.
36

37 Licensees that also implement the proposed 10 CFR 50.61a must perform the ISI inspections
38 required in Section (e) of the rule and must submit the required information for review and
39 approval to the Director, Office of Nuclear Reactor Regulation, in accordance with Section (c) of
40 the rule, at least three years before the limiting RT_{PTS} value calculated under 10 CFR 50.61 is
41 projected to exceed the PTS screening criteria in 10 CFR 50.61. Licensees also implementing
42 Section (c) of the proposed 10 CFR 50.61a must perform the inspections and analyses required
43 by Section (e) of the proposed 10 CFR 50.61a and may not defer the ISI inspection of the RV
44 beltline welds.
45

46 3.5 Conformance to RG 1.174 47

48 In addition to the four element approach discussed above, RG 1.174 states that risk-informed
49 plant changes are expected to meet a set of key principles. This section summarizes these

1 principles and the NRC staff findings related to the conformance of the TR methodology with
2 these principles.

3
4 Principle 1 states that the proposed change must meet the current regulations unless it is
5 explicitly related to a requested exemption or rule change. ISI of ASME Code Class 1, 2, and 3
6 components is performed in accordance with Section XI of the ASME Code and applicable
7 addenda as required by 10 CFR 50.55a(g), except where specific relief has been granted by the
8 NRC pursuant to 10 CFR 50.55a(g)(6)(i). This risk-informed application requires a request for
9 an alternative under CFR 50.55a(a)(3)(i) which meets the current regulations and, therefore,
10 satisfies Principle 1.

11
12 Principle 2 states that the proposed change shall be consistent with the defense-in-depth
13 philosophy. In the response to RAI 11a from Reference 3, the PWROG argued that the
14 proposed change is consistent with the defense-in-depth philosophy because there is no change
15 in RV design and no change in the robustness of the RV or other systems at the plant. The
16 NRC staff believes that ISI is an integral part of defense-in-depth and extending the interval may
17 change the robustness of the RV, albeit very slightly. However, the extension of the inspection
18 interval is accompanied by various evaluations and a monitoring program and the NRC staff
19 concludes that, in total, the proposed ISI program provides reasonable assurance that RV
20 integrity will be maintained consistent with the philosophy of defense-in-depth. Therefore,
21 Principle 2 is met.

22
23 Principle 3 states that the proposed change shall maintain sufficient safety margins. Section 12
24 in PTS Risk Study concluded that the calculations demonstrate that PTS events are associated
25 with an extremely small risk of RV failure, suggesting the existence of considerable safety
26 margin. Section 4.3 in the TR clarified that no safety analysis margins are changed and, aside
27 from extending the inspection interval, no portions of the current inspection requirements are
28 eliminated. The NRC staff concurred that the proposed change maintains sufficient safety
29 margins because the change simply extends the inspection interval and does not change, for
30 example, the acceptance criteria used to determine whether any identified flaws are acceptable
31 or need to be repaired. Therefore, Principle 3 is met.

32
33 Principle 4 states that when proposed changes result in an increase in CDF or risk, the
34 increases should be small and consistent with the intent of the Commission's Safety Goals. The
35 NRC staff concluded that the greatest increase in LERF associated with extending the
36 inspection interval at any PWR using the methods and guidelines described in the TR and
37 endorsed in this SE is less than $5E-8$ /year. The NRC staff found that this increase is small and
38 consistent with the intent of the Commission's Safety Goals. Therefore, Principle 4 is met.

39
40 Principle 5 states that the impact of the proposed change should be monitored using
41 performance measurement strategies. As described in Section 3.3 of this SE, licensees must
42 monitor the number of cycles of transients that could effect the fatigue crack growth analysis, the
43 fracture toughness of the limiting RV material, and the flaw distribution in the RV welds and
44 adjacent base metal. The NRC staff found that the planned monitoring program provides
45 confidence that no adverse safety degradation will occur because of the proposed changes and
46 that the engineering evaluation conducted to examine the impact of the proposed changes will
47 continue to be valid after the change has been implemented. Therefore, Principle 5 is met.

1 3.6 NRC Staff Findings

2
3 The NRC recently proposed a new rulemaking (72 FR 56275) which would change the
4 regulations regarding the requirements for protection against PTS events. In support of this
5 rulemaking, the NRC staff concluded that the risk of through-wall cracking caused by PTS
6 events is much lower than previously estimated. The proposed rule provided new PTS
7 screening criteria that are selected based on an evaluation that indicated that, after applying
8 these new, relaxed criteria, the risk of through-wall cracking due to a PTS event at any PWR
9 would be less than 1E-6/year. Most PWRs are not expected to need the new screening criteria
10 and, therefore, would have a TWCF less than, or substantially less than, 1E-6/year.

11
12 The analysis developed to support this TR uses mostly the same inputs and models used in the
13 PTS Risk Study. The PTS Risk Study concluded that embedded flaws do not grow and,
14 therefore, after the first inspection, periodic ISIs do not affect the risk from embedded cracks.
15 Surface cracks that penetrate through the cladding and into the ferritic alloy steel were not part
16 of the PTS Risk Study because these types of flaws have not been observed in the beltline of
17 operating PWR reactors. PFM analyses indicate, however, that surface cracks can grow over
18 time when subject to fatigue. The TR has analyzed the growth of postulated surface cracks
19 because extending the RV inspection interval could increase the risk of RV failure from such
20 cracks. The NRC staff has concluded that the TR has appropriately postulated and modeled the
21 potential change in risk that could be caused by fatigue crack growth over the life of operating
22 facilities.

23
24 Based on the results of the PTS Generalization Study, the NRC staff has concluded that the
25 PTS transient characteristics (both frequency and TH characteristics) are generically applicable
26 for plants from the same reactor vendor. RV embrittlement is, however, RV material, operating
27 history, and age specific. Therefore, the NRC staff found that, while the PTS transient work
28 need not be repeated by each plant seeking to extend its interval, the analyses and monitoring
29 to demonstrate that the RV embrittlement is within the envelope used in the supporting analyses
30 and must be performed by each plant as described.

31
32 The NRC staff found that licensees implementing the ISI interval extension program
33 documented in the TR and endorsed in the SE will have a program that meets the five key
34 principles stated in RG 1.174 and, therefore, the proposed alternatives would provide an
35 acceptable level of quality and safety, in accordance with 10 CFR 50.55a(a)(3)(i).

36
37 Based on the above conclusions, the ASME Code Section XI ISI interval for examination
38 categories B-A and B-D welds in PWR RVs can be extended from 10 years to a maximum of 20
39 years. Since the 10 year ISI interval is required by Section XI, IWB-2412, as codified in 10 CFR
40 50.55a, a request for an alternative, in accordance 10 CFR 50.55a(g)(6)(i), must be submitted
41 and approved by the NRC to extend any facility's ISI interval. In addition, licensees that do not
42 implement the proposed 10 CFR 50.61a must amend their licenses to require that the
43 information and analyses requested in Section (e) of the proposed 10 CFR 50.61a will be
44 submitted for NRC staff review and approval. The amendment to the license shall be submitted
45 at the same time as the request for an alternative. The request for an alternative will be for the
46 remainder of the licensed period for the plant.

47
48 The methodology in the TR is applicable to all operating PWR plants by confirming the
49 applicability of the parameters in Appendix A of the TR on a plant-specific basis. Licensees

1 must submit a request for an alternative that contains all the information in Section 3.4 of this
2 SE. However, since the analysis documented in the TR used plant-specific data for BV1,
3 Palisades, and OC1, these plants need not confirm the applicability of the parameters in
4 Appendix A of the TR for the current license term.
5

6 The staff will not repeat its review of the matters described in WCAP-16168-NP, Revision 2, as
7 modified by this SE, when the report appears as a reference in a request for an alternative,
8 except to ensure that the material presented applies to the specific plant involved and the
9 licensee has submitted all the information requested in Section 3.4 of this SE.
10

11 4.0 CONDITIONS AND LIMITATIONS

12
13 The 20 year inspection interval is a maximum interval. In its request for an alternative, each
14 licensee shall identify the years in which future inspections will be performed. The dates
15 provided must be within plus or minus one refueling cycle of the dates identified in the
16 implementation plan provided to the NRC in PWR Owners Group letter OG-06-356, "Plan for
17 Plant Specific Implementation of Extended Inservice Inspection Interval per WCAP 16168-NP,
18 Revision 1, "Risk Informed Extension of the Reactor Vessel In-Service Inspection Interval,"
19 MUHP 5097-99, Task 2059," dated October 31, 2006 (Reference 10).
20

21 Within one year of completing each of the ASME Code Section XI Category B-A and B-D RV
22 welds inspections required in the proposed ISI interval, the licensee must provide the information
23 and analyses requested in Section (e) of the proposed 10 CFR 50.61a, Alternative fracture
24 toughness requirements for protection against pressurized thermal shock, in Enclosure 1 to the
25 proposed rulemaking in SECY-07-0104, Reference 12. Licensees that do not implement the
26 proposed 10 CFR 50.61a must amend their licenses to require that the information and analyses
27 requested in Section (e) of the proposed rulemaking in SECY-07-0104 will be submitted for NRC
28 staff review and approval. The amendment to the license shall be submitted at the same time
29 as the relief request.
30

31 Licensees that also implement the proposed 10 CFR 50.61a must perform the ISI inspections
32 required in Section (e) of the rule and must submit the required information for review and
33 approval to the Director, Office of Nuclear Reactor Regulation, in accordance with Section (c) of
34 the rule, at least three years before the limiting RT_{PTS} value calculated under 10 CFR 50.61 is
35 projected to exceed the PTS screening criteria in 10 CFR 50.61. Licensees also implementing
36 Section (c) of the proposed 10CFR 50.61a must perform the inspections and analyses required
37 by Section (e) of the proposed 10 CFR 50.61a and may not defer the ISI inspection of the RV
38 beltline welds.
39

40 The methodology in the TR is applicable to all operating PWR plants by confirming the
41 applicability of the parameters in Appendix A of the TR on a plant-specific basis. Licensees
42 must submit a request for an alternative that contains all the information in Section 3.4 of this
43 SE. However, since the analysis documented in the TR used plant-specific data for BV1,
44 Palisades, and OC1, these plants need not confirm the applicability of the parameters in
45 Appendix A of the TR for the current license term.

1 The NRC staff has accepted TR WCAP-16168-NP, Revision 2, based on the imposition of a
2 condition related to the augmented evaluation of in-service inspection (ISI) results taken from
3 Section (e) of the proposed Title 10 of the *Code of Federal Regulations* 50.61a, published in the
4 Federal Register on October 3, 2007 (72 FR 56275). The NRC staff is in the process of
5 reviewing public comments on the proposed rule and preparing the final rule. If the final
6 10 CFR 50.61a differs from the proposed 10 CFR 50.61a with regard to the augmented ISI
7 evaluation requirements, the PWROG will be expected to review the requirements in the final
8 10 CFR 50.61a and determine whether a revision to the accepted TR WCAP-16168-NP,
9 Revision 2, is required. The PWROG will be expected to notify the NRC staff, in writing, of the
10 results of its determination within six months of the publication date of the final 10 CFR 50.61a.
11 If, on this basis, a revision to the accepted TR WCAP-16168-NP, Revision 2, is required, the
12 PWROG will be expected to submit the revised TR for NRC staff review within one year of the
13 publication date of the final 10 CFR 50.61a.

14 5.0 CONCLUSION

15
16 The NRC staff has found that the methodology presented in WCAP-16168-NP, Revision 2, in
17 concert with the guidance provided by RG 1.174, is acceptable for referencing in license
18 amendment requests for PWR plants in accordance with the limitations and conditions in
19 Section 4.0 of this SE. The NRC staff will consider extending the RV weld inspection interval
20 beyond 10 years based on plant-specific requests for an alternative that reference WCAP-
21 16168-NP, Revision 2.

22 6.0 REFERENCES

- 23
24 1. Letter from F. P. Schiffley, Westinghouse Owners' Group, "Transmittal of
25 WCAP-16168-NP, Revision 1, 'Risk-Informed Extension of Reactor Vessel In-Service
26 Inspection Interval', MUHP-5097/5098/5099, Tasks 2008/2059," January 26, 2006
27 (ADAMS Accession No. ML060330504)
- 28
29 2. Letter from F. P. Schiffley, PWR Owners Group, "Evaluation of NRC Questions on the
30 Technical Bases for Revision of the PTS Rule Relative to Their Effects on the Risk
31 Results in WCAP-16168-NP, Revision 1, "Risk-Informed Extension of the Reactor Vessel
32 In-Service Inspection Interval," June 8, 2006 (ADAMS Accession No. ML0616004311)
- 33
34 3. Letter from F. P. Schiffley, PWR Owners Group, "Responses to the NRC Request for
35 Additional Information (RAI) on PWR Owners' Group (PWROG) WCAP-16168-NP,
36 Revision 1, 'Risk-Informed Extension of Reactor vessel In-Service Inspection Interval',
37 MUHP-5097/5098/5099, Tasks 2008/2059," October 16, 2007, and Enclosure 1, RAI
38 responses (ADAMS Accession No. ML0729204120). Enclosure 2, WCAP-16168-NP,
39 Revision 2, 'Risk-Informed Extension of Reactor vessel In-Service Inspection Interval',
40 October 2007 (ADAMS Accession No. ML072920413).
- 41
42 4. Federal Register Notice, (72 FR 56275) "Alternative Fracture Toughness Requirements
43 for Protection against Pressurized Thermal Shock Events," October 3, 2007 (ADAMS
44 Accession No. ML072780354)

- 1 5. NUREG-1806, "Technical Basis for Revision of the Pressurized Thermal Shock (PTS)
2 Screening Limit in the PTS Rule (10 CFR 50.61): Summary Report," August 2007
3 (ADAMS Accession Nos. ML072830076 and ML072830081)
4
- 5 6. NUREG-1806, "Technical Basis for Revision of the Pressurized Thermal Shock (PTS)
6 Screening Limit in the PTS Rule (10 CFR 50.61): Appendices," August 2007 (ADAMS
7 Accession No. ML07282069)
8
- 9 7. NUREG-1874, "Recommended Screening Limits for Pressurized Thermal Shock (PTS),
10 2007 (ADAMS Accession No. ML070860156)
11
- 12 8. U.S. NRC, NUREG-0800, Standard Review Plan for the Review of Safety Analysis
13 Reports for Nuclear Power Plants," Section 19.2, "Review of Risk Information Used to
14 Support Permanent Plant-Specific Changes to the Licensing Basis: General Guidance,"
15 June, 2007 (ADAMS Accession No. ML071700658)
16
- 17 9. U.S. NRC, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed
18 Decisions on Plant-Specific Changes to the Licensing Basis," Regulatory Guide 1.174,
19 Revision 1, November 2002 (Adams Accession No. ML023240437)
20
- 21 10. PWR Owners Group letter OG-06-356, "Plan for Plant Specific Implementation of
22 Extended Inservice Inspection Interval per WCAP 16168-NP, Revision 1, "Risk Informed
23 Extension of the Reactor Vessel In-Service Inspection Interval," MUHP 5097-99, Task
24 2059," dated October 31, 2006
25
- 26 11. NUREG/CR-6817, Revision 1, "A Generalized Procedure for Generating Flaw-Related
27 Inputs for the FAVOR Code," March 1, 2004 (ADAMS Accession No. ML040830499)
28
- 29 12. SEC-07-0104, "Proposed Rulemaking-Alternate Fracture Toughness Requirements For
30 Protection Against Pressurized Thermal Shock Events," June 25, 2007,
31 (ADAMS Accession No. ML070570525)
32
- 33 13. WCAP-14572, Revision 1-NP-A, *Westinghouse Owners Group Application of Risk-
34 Informed Methods to Piping Inservice Inspection Topical Report*, February 1999
35 (ADAMS Accession Nos. ML012630327, ML012630349, and ML012630333)
36
- 37 14. Theoretical and Users Manual for PC-PRAISE, NUREG/CR-5864, July 1992
38
- 39 15. Electric Power Research Institute (EPRI) Nondestructive Examination (NDE) Center on
40 the detection and sizing qualification of ISIs on the RV beltline welds
41
- 42 16. Fracture Analysis of Vessels - Oak Ridge (FAVOR) Code
43
- 44 17. Regulatory Guide 1.190, "Calculational and Dosimetry Methods for Determining Pressure
45 Vessel Neutron Fluence," (ADAMS Accession No. ML010890301)
46
- 47 18. Letter Report, "Beaver Valley Pressurized Thermal Shock (PTS) Probabilistic Risk
48 Assessment (PRA)," March 3, 2005 (ADAMS Accession No. ML042880454)

- 1 19. Letter Report, "Palisades Pressurized Thermal Shock (PTS) Probabilistic Risk
2 Assessment (PRA)", March 3, 2005 (ADAMS Accession No. ML042880473)
3
 - 4 20. Letter Report, "Oconee Pressurized Thermal Shock (PTS) Probabilistic Risk Assessment
5 (PRA)," March 3, 2005 (ADAMS Accession No. ML042880452)
6
 - 7 21. NUREG/CR-6859, "PRA Procedures and Uncertainty for PTS Analysis," October 6, 2004
8 (ADAMS Accession No. ML061580379)
9
 - 10 22. Letter Report, "Generalization of Plant-Specific Pressurized Thermal Shock (PTS) Risk
11 Results to Additional Plants," December 14, 2004
12
- 13 Principle Contributors: Barry Elliott
14 Stephen Dinsmore
15
16 Date:
17