

**ATTACHMENT 2**

**Peach Bottom Atomic Power Station  
Units 2 and 3  
Docket Nos. 50-277 and 50-278**




**License Amendment Request  
Response to Request for Additional Information**

**Alternative Source Term (AST)**

**PBAPS Calculation 1-1, Revision 1, "Stress Analysis for Main  
Steam Outside Containment"**

**ATTACHMENT 1**  
**Design Analysis Cover Sheet**

**Page 1**

<b>Design Analysis (Major Revision)</b>		<b>Last Page No.<sup>6</sup> App. 2, Page 126</b>		
<b>Analysis No.:<sup>1</sup></b>	1-1	<b>Revision:<sup>2</sup></b> 1		
<b>Title:<sup>3</sup></b>	Stress Analysis for Main Steam Outside Containment			
<b>EC/ECR No.:<sup>4</sup></b>	03-00525	<b>Revision:<sup>5</sup></b> 0		
<b>Station(s):<sup>7</sup></b>	PBAPS	<b>Component(s):<sup>14</sup></b>		
<b>Unit No.:<sup>8</sup></b>	2 & 3	AO-2-01A-086A		
<b>Discipline:<sup>9</sup></b>	PEDM	AO-3-01A-086A		
<b>Descrip. Code/Keyword:<sup>10</sup></b>	Pipe Stress Analysis	AO-2-01A-086B		
<b>Safety/QA Class:<sup>11</sup></b>	Q	AO-3-01A-086B		
<b>System Code:<sup>12</sup></b>	01, 904	AO-2-01A-086C		
<b>Structure:<sup>13</sup></b>	Reactor/Turbine Bldg	AO-3-01A-086D		
<b>CONTROLLED DOCUMENT REFERENCES<sup>15</sup></b>				
<b>Document No.:</b>	<b>From/To</b>	<b>Document No.:</b>	<b>From/To</b>	
PM-789	From	PM-810	From	
PM-815	To			
<b>Is this Design Analysis Safeguards Information?<sup>16</sup></b>		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	If yes, see SY-AA-101-106
<b>Does this Design Analysis contain Unverified Assumptions?<sup>17</sup></b>		Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	If yes, ATI/AR#:
<b>This Design Analysis SUPERCEDES:<sup>18</sup></b>		calculation PM-786 in its entirety.		
<b>Description of Revision (list affected pages for partials):<sup>19</sup></b>				
This revision is a complete reanalysis to document the main steam piping analysis and the evaluation of unit 3 as-found spring hanger loads per 3R14 ISI inspection. This revision incorporates and supersedes analysis performed in calculation PM-786, since the referenced calculation duplicates the evaluation of the main steam piping.				
<b>Preparer:<sup>20</sup></b>	M. Kazoun		12/28/04	
Print Name	Sign Name	Date		
<b>Method of Review:<sup>21</sup></b>	Detailed Review <input checked="" type="checkbox"/>	Alternate Calculations (attached) <input type="checkbox"/>	Testing <input type="checkbox"/>	
<b>Reviewer:<sup>22</sup></b>	J. Boyer		2-2-05	
Print Name	Sign Name	Date		
<b>Review Notes:<sup>23</sup></b>	Independent review <input checked="" type="checkbox"/>	Peer review <input type="checkbox"/>		
Print Name	Sign Name	Date		
(For External Analyses Only)				
<b>External Approver:<sup>24</sup></b>	Print Name	Sign Name	Date	
Exelon Reviewer: <sup>25</sup>	Print Name	Sign Name	Date	
<b>Is a Supplemental Review Required?<sup>26</sup></b>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	If yes, complete Attachment 3	
<b>Exelon Approver:<sup>27</sup></b>	JAMES JONES		3/1/05	
Print Name	Sign Name	Date		

**ATTACHMENT 1**  
**General Review Questions**  
**Page 1 of 1**

DESIGN ANALYSIS NO. 1 - 1 REV: 1 Page 2

	Yes	No	N/A
1. Does the Design Analysis conform to design requirements?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Does the Design Analysis conform to applicable codes, standards, and regulatory requirements?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Have applicable design and safety limits been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Is the analysis method appropriate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Are the methods used and recommendations given conservative relative to the design and safety limits?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Are assumptions/Engineering Judgments explained and appropriate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. Have appropriately verified Computer Program and versions been identified, when applicable?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Does the Computer Program conform with the NRC SER or similar document when applicable?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Has the input been correctly incorporated into the Design Analysis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Has the input been reviewed by all cognizant design authorities?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11. Are the analysis outputs and conclusions reasonable compared to the inputs and assumptions?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12. Are the recommendations/results/conclusions reasonable based on previous experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13. Has a verification of the Design Analysis been performed by alternate methods? (L <sub>1</sub> , L <sub>2</sub> , P <sub>1</sub> , P <sub>2</sub> , V <sub>1</sub> , V <sub>2</sub> , V <sub>3</sub> , V <sub>4</sub> )	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
14. Has all input data been used correctly and is it traceable?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15. Has the effect on plant drawings, procedures, databases, and/or plant simulator been addressed?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16. Has the effect on other systems been addressed?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17. Have any changes in other controlled documents (e.g. UFSAR, Technical Specifications, COLR, etc.) been identified and tracked?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
18. When applicable, are the analysis results consistent with the proposed license amendment?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
19. Have other documents that have used the calculation as input been reviewed and revised as appropriate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20. Have all affected design analyses been documented on the Affected Documents List (ADL) for the associated Configuration Change?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21. Do the sources of inputs and analysis methodology used meet current technical requirements and regulatory commitments? (If the input sources or analysis methodology are based on an out-of-date methodology or code, additional reconciliation may be required if the site has since committed to a more recent code)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
22. Have supporting technical documents and references been reviewed when necessary?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**Table of contents**

	<u>Page No.</u>
1. Cover Sheet	1
2. DA Review Sheet	2
3. Table of Contents	3
4. Purpose	4
5. Assumptions/Notes	4
6. References	5
7. Inputs	5
8. Identification of Computer Programs	5
9. Method of Analysis/Results	6
10. Conclusion	7

**Attachments:**

**Appendix 1. Analysis of Main Steam Outside Containment including Power Re-rate  
(104 pages)**

**Appendix 2. Evaluation of Unit 3 Main Steam Outside Containment to address As-Found spring  
hangers setting changes  
(126 pages)**

This calculation revision documents the stress analysis of units 2 and 3 Main Steam (MS) piping outside containment in accordance with the requirements of PBAPS specification NE-104 and ANSI B31.1 code, 1973 Edition including S73.

This calculation will determine and verify acceptability of:

1. Piping stresses
2. Valve accelerations
3. Support and penetration loads

**Background:**

Documentation of revision 0 of this calculation (stored in Microfilm Roll No. 81-107) could not be found and no replacement could be obtained from Bechtel Corporation. Later analysis (PM-786) and evaluation (E2 of A/R A1435406) were performed for MS piping outside containment and will be incorporated in this calculation revision.

**Assumptions/Notes:**

No assumptions require further confirmation.

1. Unit 2 MS line "D" was fully analyzed for weight, thermal, earthquake, and fluid transient, representing all MS lines in both units, for station power re-rate modification No. 8565 under stress calculation No. PM-786. During 3R14 refueling outage (September 2003), Unit 3 spring hanger settings were found out of tolerance. An engineering evaluation was performed for the acceptance of the as-found condition.

This calculation revision will include PM-786 analysis as Appendix 1 and unit 3 as-found spring settings evaluation as Appendix 2. These piping analysis and evaluation were performed in accordance with the requirements of ANSI B31.1 code, 1973 Edition including S73.

2. Appendix 1 analysis modeled the MSIV operator in downward direction, while as-built direction is upward. This error will not have adverse effect on evaluation results or support loads since the valve is located close to the containment penetration anchor.

3. There are some input parameters differences between Appendix 1 and Appendix 2 analyses, such as using support stiffness, support component weights, piping data, analysis boundary, and valve modeling. The Appendix 1 analysis is the final complete analysis and applies to both units. However, unit 3 evaluation in Appendix 2 is used to evaluate the effect of spring setting changes and determine piping stress and support load changes only. The changes in the stress and support load results between two dead weight load cases (one includes as-designed spring settings from support detail drawings, WT01 case, and the second is for as-found spring settings during 3R14 refueling outage, WT02 case), were reviewed and accepted in the following pages.

4. Note 9 on page 14 of Appendix 1 justifies the decoupling of the 14" line to main steam Bypass valve from the 26" main steam line analysis by stating that their moment of inertia ratio is about 15 while the actual ratio is about 10. However, since the connection is located close to the main steam stop and control valves block (considered an anchor for the MS analysis), it is judged acceptable to decouple the 14" line from the 26" main steam line analysis with no adverse effect on the qualifications of each.

5. Note 14 on page 15B of Appendix 1 evaluated additional 550 pounds for main steam isolation valve Poppet Assembly. However, this assembly is not installed for outside containment isolation valves (per system manager J. Kozakowski). This evaluation is considered for information only until the assembly is installed.

**References**

(Also see Appendices 1 and 2 for references)

1. Specification NE-104, Rev. 0
2. ANSI B31.1 code, 1973, including summer 73 addenda
3. ANSI B31.1.0, 1967 code
4. ECR 03-00525, Rev. 0
5. Specification M-300, Rev. 16
6. Specification M-301, Rev. 12
7. Specification, G-14, Rev. 0
8. Calculations PM-810 Rev. 0
9. Calculation Pm-789, Rev. 0
10. E2 OF A/R A1435406
11. ME101 computer program for stress analysis, version N2
12. Unit 2 Piping Hanger drawings # HSO-121 R 3, HSO-122 R 2, HSO-123 R 1, HSO-124 R 1
13. Unit 3 Piping Hanger drawings # HSO-171 R 2, HSO-172 R 1, HSO-173 R 1, HSO-174 R 1

**Inputs:**

Design inputs are as shown in Appendices 1 and 2

**Identification of Computer Programs:**

1. NUPIPE-Stone & Webster, ME-110, Version 06, Level 03 for Stress analysis.
2. ME101, Bechtel Piping Stress Analysis program, Version N2

**Method of Analysis//Results**

Analysis description, methodology, and output, provided by the reference stress analysis programs, are shown in Appendices 1 and 2. Appendix 1 includes a complete stress analysis for "D" line (was documented in calculation PM-786) and Appendix 2 documents the evaluation of unit 3 as-found spring settings during 3R14 ISI inspection. Appendix 2 changes affect only weight loads and piping stress for unit 3. Therefore, Units 2 and 3 overall piping qualifications are per appendix 1 except unit 3 weight analysis is per appendix 2 (i.e. unit 3 dynamic and thermal loads are per Appendix 1). Appendix 2 includes two weight analyses for unit 3 configuration, one with as-designed spring cold loads and the second is for as-found spring cold loads.

**Piping Stress:**

See Appendix 1 for Unit 2 results.

For unit 3, the maximum piping dead weight stress (see appendix 2), incorporating as-found spring cold loads, is less than the maximum stress for the original as-designed spring cold loads. Therefore, no change to piping stresses of Appendix 1, due to unit 3 spring setting changes, is required.

**Support loads:**

See Appendix 1 for Unit 2 results.

Since the analyzed Unit 2 line "D", in App. 1, corresponds to Unit 3 line "A" (analyzed in App. 2), the following is the unit 3 rigid support load change comparison and acceptance (Snubbers and valve accelerations are not affected):

<u>Support No. (NP, In App. 2)</u>	<u>WT. Load change (App. 2)</u>	<u>FLTD LD (Att 2. App. 1)</u>	<u>Percentage Load Change</u>	<u>Remarks</u>
X-7A (A05)	Reduced	Not Affected	Reduced	Anchor Loads generally reduced, Acceptable
3-1DB-H3 (A35)	+295	32921	0.9%	Minor change, acceptable
3-1DB-H4 (A40)	-28	19953	Reduced	Load reduced, Acceptable
3-1DB-H5 (A45)	-210	16484	Reduced	Load reduced, Acceptable
3-1DB-H6 (A50)	+535	16868	3.2%	Minor change, acceptable (Strut capacity is 20250#)
3-1DB-H7 (A55)	-1842	19686	Reduced	Load reduced, Acceptable
3-1DB-H9 (A70)	+3242	18219	17.8%	See Note 1 below
Restr-5 (AR-5)	+295	53499	<1%	Insignificant change, acceptable

**Note 1:**

Per page 2 of attachment 4 of Appendix 1, the original faulted load of this support is +34382, -49945#. While the Re-rate analysis load is +983, -18219#. If the change in support load, due to spring hangers as-found settings in App. 2 (3242#) is added, the faulted support load would be +983, -21461# which is less than original loads and therefore, acceptable.

**Valve Accelerations/Nozzle and penetration anchor loads/pipe movements:**

See Appendix 1 for evaluation and acceptance.

**Conclusion**

Main Steam piping outside the containments for both unit 2 and 3, from penetrations X-7A, B, C, and D to MS stop valves, were analyzed including station power re-rate. In addition, as-found spring cold loads (for unit 3) were reviewed and found acceptable. All piping stresses, valve accelerations, penetration and support loads for both units meet the requirements of PB specification NE-104 and their corresponding design code and capacities.



**NUCLEAR  
GROUP**  
**M-20599 Rev. 3/83**  
**DOCTYPE 081**

## **CALCULATION COVER SHEET**

3. MOD/NCR/ECR No: Other:	MOD 8565	4. Responsible Branch:	SECP	5. Total No. of Pages:	117	6. Last Page No:	ATTACH 5 pg1	7. <input checked="" type="checkbox"/> Safety Related <input type="checkbox"/> Non-Safety Related
8. Description: QUALIFICATION OF MAIN STEAM PIPING FROM CONTAINMENT TO STOP VALVE FOR POWER RERATE CONDITIONS				9. System/Topic No.:		1		
				Structure:		N/A		
				Component:		PEN N-70, MSJ-4		

## **RECORD OF REVISIONS**

Calc. 1-1 2.1 app. 1 page 1 of 10

15. Related Calc. Numbers	Provides Info to:	Pm-815					16.
	Receives Info from:	Pm 789, 810	.	.	.	.	<input type="checkbox"/> Manual
	Supersedes:		.	.	.	.	<input checked="" type="checkbox"/> Computer

Effective Date: 8/6/93

Calc. 1-1 R.  
APP-A Page 2

## CALCULATION REVIEW CHECKLIST

CALCULATION No.: Pm 786  
Calc. Rev. No.: 0

Page 2

Initiating Document (e.g., ECR, NCR, Mod No.): M00 8565

<u>MANUAL COMPUTER</u>	<u>REVIEW CRITERIA</u>	<u>YES or N/A</u>
X X	SOURCES OF DATA & FORMULAE WERE REVIEWED AND VERIFIED TO BE CORRECT & COMPLETE	Yes
X X	INPUT DATA FROM SOURCES IN ITEM 1 ABOVE IS CORRECT AND PROPERLY USED IN THE CALCULATION	Yes
X	THE ANALYTICAL METHOD USED IN THE CALCULATION HAS BEEN CONSIDERED AND IS PROPER FOR THE INTENDED USE	N/A
X	MATHEMATICAL ACCURACY HAS BEEN CHECKED AND IS CORRECT (INDICATE METHOD USED)	
a)	COMPLETE CHECK OF EACH COMPUTATION	N/A
b)	SPOT-CHECK OF SELECTED COMPUTATIONS WHICH ARE INITIALED IN THE CALCULATION	N/A
c)	PERFORMANCE OF ALTERNATE OR APPROXIMATION CALCULATION (ATTACHED)	N/A
X X	CALCULATION RESULTS WERE CHECKED AGAINST APPLICABLE DOCUMENTED DESIGN CRITERIA AND FOUND IN CONFORMANCE	Yes
X X	EXISTING CALCULATIONS REQUIRING REVISION AS A RESULT OF THIS CALCULATION HAVE BEEN IDENTIFIED	Yes
X	THE ANALYTICAL METHOD DESCRIBED IN THE COMPUTER CALCULATION SUMMARY IS PROPER FOR THE INTENDED USE	Yes
X X	ALL SYSTEMS AND TOPIC NUMBERS ASSOCIATED WITH THE CALCULATION HAVE BEEN LISTED	Yes
X	COMPUTATIONAL ACCURACY HAS BEEN CHECKED AND FOUND CORRECT (INDICATE THE METHOD USED)	
a)	CHECK SAMPLE CALCULATION USING DATA OTHER THAN THAT USED IN THE SAMPLE	N/A
b)	PERFORMANCE OF ALTERNATE OR APPROXIMATE CALCULATION (ATTACHED)	N/A
c)	DESCRIBE OTHER METHOD USED	
	QA VERIFIED PROGRAM	Yes
X	PROGRAM USED IS APPROPRIATE, INPUT IS VALID, AND OUTPUT IS REASONABLE CONSIDERING THE INPUT	Yes
X X	PIMS CODE OF CALCULATION BRANCH OWNER HAS BEEN LISTED IN BLOCK 4	Yes
X X	ASSUMPTIONS REQUIRING CONFIRMATION HAVE BEEN IDENTIFIED AND TRACKING A/R'S HAVE BEEN INITIATED	Yes

THE CRITERIA LISTED ABOVE ARE MINIMUM CRITERIA TO BE CONSIDERED AND ARE NOT INTENDED TO LIMIT THE INITIATIVE OF THE REVIEWER TO CONSIDER OTHER CRITERIA.

ATTRIBUTES APPLICABLE TO MANUAL AND COMPUTER CALCULATIONS ARE NOTED BY A "X" IN THE APPROPRIATE COLUMN. FOR CHECKING OF REVISIONS TO MANUAL CALCULATIONS, THE ATTRIBUTES MAY BE LIMITED TO ONLY REVISED PORTIONS OF THE CALCULATION.

LIST THE DOCUMENTS USED TO SUPPORT THE REVIEW:

REVIEWED R.F. DOCUMENTS LISTED ON PGS 9, 10, 10A

REVIEWED BY: J.S. Boyer

DATE: 10/21/93

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION TITLE PAGE

5010.64(FRONT)

CALC. 1-1 R. 1  
APP. 1 PAGE 3

CLIENT & PROJECT PECo - PEACH BOTTOM ATOMIC POWER STATION UNITS 2,3			PAGE 3		
CALCULATION TITLE (Indicative of Objective)  QUALIFICATION OF MAINSTEAM PIPING FROM CONTAINMENT TO STOP VALVE FOR POWER RERATE CONDITIONS			QA CATEGORY (X) <input checked="" type="checkbox"/> I - NUCLEAR <input type="checkbox"/> II - SAFETY RELATED <input type="checkbox"/> III - OTHER		
CALCULATION IDENTIFICATION NUMBER			OPTIONAL WORK PACKAGE NO.  N/A		
J.O. OR W.O. NO.	DIVISION & GROUP	CURRENT CALC. NO.			
03040	NP(C)	PM-786	N/A		
APPROVALS - SIGNATURE & DATE			REV. NO. OR NEW CALC NO.	SUPERSEDES CALC NO. OR REV NO.	CONFIRMATION REQUIRED (x)
PREPARER(S) / DATE(S)	REVIEWER(S) / DATE(S)	INDEPENDENT REVIEWER(S) / DATE(S)		YES	NO
F. CAPUANO <i>F. Capuano</i> 4/5/93	J. S. BOYER <i>Jn A Boyer</i> 4.6.93	J. S. BOYER <i>Jn A Boyer</i> 4.6.93	A	N/A	X
F. Capuano 10/21/93	J. S. BOYER <i>Jn A Boyer</i> (10/21/93)	J. S. BOYER <i>Jn A Boyer</i> (10/21/93)	B	A	X
DISTRIBUTION					
GROUP	NAME & LOCATION	COPY SENT (x)	GROUP	NAME & LOCATION	COPY SENT (x)
PROJECT FILE	JOB BOOK R4.3.1	X			

**STONE & WEBSTER ENGINEERING CORPORATION**  
**CALCULATION SHEET**

▲5010.65P

CALCULATION IDENTIFICATION NUMBER				PAGE
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
03040	NP(C)	PM-786 : -1	N/A	A P P . 1 P . 4

Rev 1

## **REVISION STATUS TABLE**

REV. NO.	PAGE NO.	DESCRIPTION / REASON
A	ALL	ORIGINAL ISSUE
B	see below	<p>Evaluation of the additional weight (550 lb) of the new MSIV Poppet Assembly addressed in reference 25.</p> <p>Pages revised: 3, 4, 10A, 15B, 25, 30, 31, 34</p> <p>Pages added: None</p> <p>Pages deleted: None</p>

**NOTE:** UNDER DESCRIPTION / REASON DESCRIBE THE CHANGES MADE AND THE REASON FOR THE REVISION.

**STONE & WEBSTER ENGINEERING CORPORATION**  
**CALCULATION SHEET**

▲5010.65

APP. I

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
03040	NP (C)	PM - 786 1-1 A.1	N/A	5
<b>TABLE OF CONTENTS</b>				
<b>SECTION</b> <span style="float: right;"><b>PAGE</b></span>				
CALCULATION COVER SHEET ..... 1				
ATTRIBUTE PAGE ..... 2				
CALCULATION TITLE PAGE ..... 3				
REVISION STATUS TABLE ..... 4				
TABLE OF CONTENTS ..... 5				
OBJECTIVE ..... 6				
METHOD ..... 6				
ASSUMPTIONS ..... 7				
CONCLUSIONS ..... 7				
REFERENCES ..... 8-10, 10A				
NOTES ..... 11-15, 15A, B				
DESIGN INPUT:				
WORKSKETCH ..... 16				
FLUID TRANSIENT LOADING ..... 17				
AMPLIFIED RESPONSE SPECTRA ..... 18				
CROSS-SECTIONAL PROPERTIES ..... 20				
BASIC ANALYTICAL DATA ..... 21				
SYSTEM RESTRAINTS ..... 22				
COLD LOAD FORCE APPLIED AT SPRING HANGERS ..... 23				
HAND INPUT SIFs ..... 24				
CONCENTRATED WEIGHTS ..... 25				
LOADING CONDITIONS ANALYZED ..... 27				
RESULTS SUMMARY:				
MAXIMUM STRESS LEVELS ..... 28				
SYSTEM ACCELERATIONS ..... 32				
PIPING DISPLACEMENTS ..... 33				
PENETRATION LOAD EVALUATION ..... 34				
STOP VALVE LOAD EVALUATION ..... 35				
PIPE SUPPORT LOAD SUMMARY ..... 36				
COMPUTER LOG ..... 72				
ATTACHMENTS:				
1. INPUT DATA ECHO ..... 22 PAGES				
2. GRINNELL SNUBBER LOAD RATINGS ..... 3 PAGES				
3. POWER RERATE OPEN ITEM PB-OI-024 ..... 1 PAGE				
4. SUPPORT LOAD COMPARISON ..... 15 PAGES (PM-786 vs. PREVIOUS ANALYSES)				
5. MICROFICHE ..... 1 PAGE				

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65

APP. I

CALCULATION IDENTIFICATION NUMBER				OPTIONAL TASK CODE	PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.			
03040	NP (C)	PM - 786 1-1 R. 1		N/A	6

1

OBJECTIVE:

2

To analyze a representative Unit 2 or 3 Main Steam line from the penetration flued head anchor, outside the containment, to the inlet of the stop valve for the operating conditions resulting from power rerate and qualify this piping in accordance with references 1, 2. As addressed in the Notes section, Main Steam line D (from Penenrtation N-7D to MSV-4) for Unit 2 is selected as the representative piping.

3

Determine pipe support loads to be used for pipe support design evaluation.

4

Verify that valve accelerations/equipment loads are within allowable limits (as applicable).

5

Determine pipe support loads for selected supports on other main steam lines to be used for the pipe support design evaluation required for the resolution of Power Rerate Project Open Item No. OI-PB-024. The specific supports are as follows: Line C supports H17 and H26, Line B supports H27, H28, H29, and H30, Line A supports H41 and H42.

6

NOTE:

Utilization of this calculation by persons without access to the pertinent factors and without proper regard for its purpose could lead to erroneous conclusions. Should it become desirable to use this calculation to support design or station activities other than those explicitly specified in this Section, the responsible engineering branch (as noted in Block 4 of PECo cover sheet) shall be contacted to ensure that the purposes, assumptions, judgements and limitations are thoroughly understood.

7

METHOD:

8

A mathematical model of the piping system is prepared from piping drawings and other design inputs. Geometrically determined boundary conditions are defined by equipment/piping penetrations or are established by six-way pipe supports (anchors). The model is then analyzed by utilizing the NUPIPE-SW (ME-110) Computer Program applying the coding methods established in Section II of the NUPIPE-SW Users' Manual (ref 21). The results are then evaluated for conformance to the objective of the calculation.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65

APP. 1

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
03040	NP (C)	PM - 786 1-1 R 1	N/A	7

ASSUMPTIONS: (further verification not required)

1. Based on reference 16, the distribution of weight for  
AO-086D is conservatively assumed as follows:

CG of valve body is located at the end of the valve body  
casing, estimated to be 3.9' from the centerline of the  
valve with a lumped weight of 80% of the total weight (i.e.  
.80\*10075 = 8060).

CG of operator is located at the end of the operator, 9.5'  
from the centerline of the valve with a lumped weight of 20%  
of the total weight (i.e. .20\*10075 = 2015).

CONCLUSIONS:

The completed analysis shows that piping is qualified in  
accordance with Reference 1, 2.

Pipe support loads have been determined and transmitted to  
the pipe support group for evaluation.

Valve accelerations and/or equipment loads are within  
allowable limits (as applicable).

Pipe support loads for selected supports on other main  
steam lines have been determined and transmitted to the  
pipe support group for evaluation.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A 5010.65

APP. I

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
03040	NP(C)	PM 786 1-1 R.1	N/A	8
<b>1 REFERENCES:</b>				
2				
3				
4    1. Piping Codes				
5        a. ANSI B31.1 Power Piping Code, 1967 Edition				
6				
7        b. ANSI B31.1 Power Piping Code, 1973 Edition, including				
8              Summer 1973 Addenda.				
9				
10        c. ANSI B31.1 Power Piping Code, 1980 Edition, including				
11              Winter 1982 Addenda. (for allow. stress of A-672 GR.B70 only)				
12				
13    2. UFSAR for the Peach Bottom Atomic Power Station,				
14              Section 4.11, Appendix A, and Appendix C.				
15				
16    3. Specification 6280-G-14 Revision 1, General Project				
17              Requirements for Seismic Design and Analysis of				
18              Equipment and Equipment Supports for PBAPS Units 2 & 3.				
19				
20    4. Specification 6280-M-300 Revision 13 (including addenda),				
21              Specification for Piping Materials, Instrument Piping Standards				
22              and Valve Classifications.				
23				
24    5. Calculation PM-789 Rev. 0, System Piping Conditions Evaluation				
25              for Power Rerate.				
26				
27    6. Grinnell Handbooks				
28        a. ITT Grinnell Piping Design And Engineering, 5th Edition.				
29        b. Pipe Hanger Design and Engineering, Grinnell, Revised 1979				
30				
31    7. Calculation PM-810 Rev. 0, Fluid Transient Load on Main Steam				
32              Lines due to Stop Valve Closure for 5% Power Rerate.				
33				
34    8. Specification NE-111 Revision 0, Thermal Insulation Outside				
35              the Drywell.				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65

A.P.A. 1

CALCULATION IDENTIFICATION NUMBER				OPTIONAL TASK CODE	PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.			
03040	NP (C)	PM - 786	1 - 1 R. 1	N/A	9

REFERENCES:

9. P&IDs

- a. 6280-M-351 sht 2, Rev 51, Unit 2 Nuclear Boiler
- b. 6280-M-303 sht 1, Rev 46, Unit 2 MS Bypass and Crossaround

10. QADs

- a. 6280-M-851 sht 2, Rev 26, Unit 2 Nuclear Boiler
- b. 6280-M-803 sht 1, Rev 22, Unit 2 MS Bypass and Crossaround

11. Piping and Hanger Location drawings (Line D)

- a. ISO-2-1-1, Rev 7, Unit 2 Main Steam Line D
- b. HIS0-121, Rev 2, Unit 2 Main Steam to MSV-4
- c. 6280-M-175, Rev 7, Unit 2 Main Steam Piping System

12. Pipe Support Detail drawings (Line D)

- a. M-1813-0 sht 1 for hanger 1DB-H1
- b. M-1813-0 sht 2 for hanger 1DB-H2
- c. M-1813-0 sht 3 for hanger 1DB-H3
- d. M-1813-0 sht 4 for hanger 1DB-H4
- e. M-1813-0 sht 5 for hanger 1DB-H5
- f. M-1813-0 sht 6 for hanger 1DB-H6
- g. M-1813-0 sht 7 for hanger 1DB-H7
- h. M-1813-0 sht 8 for hanger 1DB-H9B
- i. M-1813-0 sht 9 for hanger 1DB-H10
- j. M-1813-0 sht 10 for hanger 1DB-H11
- k. M-1813-0 sht 11 for hanger 1DB-H12
- l. M-1813-0 sht 12 for hanger 1DB-H13
- m. M-1813-0 sht 13 for restraint no. 5
- n. M-1813-0 sht 14 for hanger 1DB-S7A
- o. M-1813-0 sht 15 for hanger 1DB-S7A
- p. S-257, Rev 7 for hanger 1DB-S2A

13. Piping and Hanger Location drawings for other Unit 2 and 3 MS lines

- a. HIS0-122 Rev 1
- b. HIS0-123 Rev 1
- c. HIS0-124 Rev 1
- d. 6280-M-190, Rev 2, Unit 3 Main Steam Piping System
- e. HIS0-171 Rev 2
- f. HIS0-172 Rev 1
- g. HIS0-173 Rev 1
- h. HIS0-174 Rev 1

**STONE & WEBSTER ENGINEERING CORPORATION**  
**CALCULATION SHEET**

5010.65

App-1

CALCULATION IDENTIFICATION NUMBER					PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE		
03040	NP (C)	PM - 786	1-1 R-1	N/A	10

## REFERENCES:

14. Pipe Whip Restraint drawings
    - a. S-397, Rev 7
    - b. S-398, Rev 3
    - c. S-399, Rev 6
  15. Penetration drawings
    - a. M-205, Rev 2
    - b. M-206, Rev 4
    - c. M-207, Rev 4
  16. MSIV AO-086D vendor print - M-1-R-12, Rev 5, shts 1 and 2
  17. Main Steam Stop Valve and Restraint drawings
    - a. M2-76D-13, Rev 11 (vendor dwg)
    - b. M2-408D-4, Sh 2, Rev 11 (vendor dwg for restraint capacities)
    - c. S-256, Rev 6 (stop valve restraints)
  18. Pipe Hanger Vendor Catalogs
    - a. Grinnell Pipe Hangers Catalog PH-90, dated 1989
  19. Main Steam Bypass Calculations on Bechtel Microfilm Cartridge  
M.S.O. No. 128275, Job No. 11187, Dated 1-22-81, Roll No.  
SFPD-81-117
    - a. 7-1S dated 02/14/72
    - b. 7-10T dated 01/07/75
    - c. 7-11T dated 01/07/75
    - d. 7-12T dated 01/07/75
    - e. 7-13T dated 01/07/75
  20. Main Steam Calculations on Bechtel Microfilm Cartridge M.S.O. No  
128273, Job No. 11187-047, Dated 1-21-81, Roll No. SFPD-81-0107
    - a. 1-1T dated 01/30/73
    - b. BP-TOP-2 dated 12/12/78
    - c. 1-1W dated 02/27/73
    - d. 1-1S date/rev not available
  21. NUPIPE-SW, ME-110, Version 06, Level 03
  22. Main Steam Line D Calculation D-007, dated 4/24/75 on Bechtel  
Microfilm Cartridge M.S.O. No. 456, Job No. 6280, Dated 3-16-76,  
Roll No. 76-134
  23. Bechtel PBAPS Stress Group Technical Files, Binder 19, Main  
Steam Miscellaneous Calculations and Modifications, Microfilmed  
on Cartridge No. 86-0435. Dated 7-28-86

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65

APP. I

CALCULATION IDENTIFICATION NUMBER					PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE		
03040	NP (C)	PM - 786 1-1 R.1	N/A		10A
1					
2 REFERENCES:					
3					
4 24. Pipe Stress Calculation PM-777 Rev. 0, Pipe Stress Margin					
5 Screening Evaluation due to Power Rerate - Main Steam and					
6 Feedwater Systems					
7					
8 25. GE-NE-123-E169-0992, Main Steam Piping System Stress and					
9 Support Load Evaluation for Installation of MSIV					
10 nose-Guided Poppet Assembly, dated September 1992,					
11 Transmittal No. EOC-92-046 dated October 15, 1992					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					

B

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲5010.65

APP. 1

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
03040	NP (C)	PM - 786 1-1 R.1	N/A	11

1

2

3 NOTES:

4

- 5 1. Forces and moments on restraints, supports and equipment  
6 are those imposed by the piping system (i.e. Actions not  
7 Reactions).
- 8 2. Unless otherwise noted forces and moments reported at  
9 inline anchors represent the total forces and moments  
10 acting upon that anchor, considering contributions from  
11 piping on all sides of the anchor. Reactions reported on  
12 terminal anchors are due to piping shown in this report  
13 only.
- 14 3. The supports in the scope of this calculation are located  
15 in the reactor building and turbine building.
  - 16 a. Relative seismic displacements between reactor building  
17 supports are insignificant (< 1/32") per reference 2 and  
18 therefore are not analyzed.
  - 19 b. The differential elevation between turbine building  
20 support attachments is insignificant since the piping is  
21 routed at one elevation (excluding pipe slope).  
22 Therefore relative seismic displacements are not  
23 applicable within the turbine building.
  - 24 c. Considering the small magnitude of the reactor building  
25 seismic displacement, the out of phase displacement  
26 between the reactor and turbine buildings is also  
27 insignificant. Furthermore, there is approximately 50  
28 feet of piping flexibility between the closest same  
29 direction seismic restraints in the two buildings.
  - 30 4. For lines requiring seismic analysis, the reactions  
31 reported are cyclic in character, and reactions must be  
32 considered as acting in either the positive or negative  
33 direction.
  - 34 5. Main Steam line D is analyzed as the representative main  
35 steam line since Line D has the longest total length of  
36 piping and all four lines in both units are routed and  
37 supported similarly except as noted (see references 11 and  
38 13). Line D is also the line for which the fluid transient  
39 loading of reference 7 was generated. The difference  
40 between the four loops, as it impacts the scope of work

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65

APP. 1

CALCULATION IDENTIFICATION NUMBER					PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE		
03040	NP (C)	PM 786 1 - 1 R. 1	N/A		12

NOTES:

in this calculation, is the arrangement of rigid vertical supports near the elbow adjacent to snubber S7A for lines C and D and snubber S42A for lines A and B. Details are specified below.

Lines C and D have at least one rigid support close to the elbow. This is the first rigid support upstream of the MSV. Lines A and B have a spring hanger on each side of the elbow. The first rigid support upstream of the MSV is approximately an additional 40' upstream of the elbow. This difference is addressed in note 12.

6. The inlet to stop valve 4 (node 390) is the boundary for the qualification of piping in this analysis. This is based on reference 17 which indicates that the 4 stop valves/control valves (for lines A,B,C,D) are welded together forming one large assembly. Note that the control valves are mounted to the outlet of the stop valves. This assembly is:
- a) rigidly supported in the vertical direction by a pair of 250 kip struts which also restrain rotation about the global X axis.
  - b) dynamically supported in the global X direction by a pair of 200 kip snubbers (skewed approximately 20 degrees down from global X) which also restrain dynamic rotation about the global Y axis. These snubbers are offset from the centerline of the main steam line by approximately 3.5' and as a result contribute some dynamic rotational restraint about the global Z direction.
  - c) dynamically supported in the global Z direction by a single 72 kip snubber which does not contribute to rotational restraint.

In summary, the assembly is dynamically restrained in the X, Y, and Z translational direction and the X and Y rotational directions. The massive nature of the 4 stop valve/control valve assembly, in conjunction with the contribution from the pair of "global X" snubbers, is considered to provide the Z rotational direction restraint. These restraints effectively anchor the stop valve inlet for dynamic loading.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲5010.65

App. 1

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
03040	NP (C)	PM 786 1-1 R.1	N/A	13
1				
2				
<b>NOTES:</b>				
3				
4				
5      7. Statically, node 390 is only restrained in the vertical and				
6      rotational X directions. Therefore, the piping model is				
7      extended up to the H.P. turbine inlet (node 480) to obtain				
8      the proper restraining effect at node 390 for the static				
9      cases (i.e. thermal and deadweight). This portion of the				
10     model is based on reference 20a, modeled as weightless,				
11     and is excluded from the scope of this calculation.				
12				
13				
14     8. The main steam piping in this calculation is qualified to				
15     the criteria specified in Appendix C, Table C.5.7 of the				
16     UFSAR (ref 2) which is consistent with or more conservative				
17     than the requirements of reference 1b. Using the equation				
18     notation of reference 1b, the criteria is summarized below.				
19				
20 <u>Condition</u> <u>Equation</u> <u>Allowable</u>				
21     Sustained      11      Sh				
22     Occasional      12U      1.2Sh				
23     (Upset)				
24				
25     Occasional      12F      1.8Sh				
26     (Faulted)				
27				
28     Expansion      13 $Sa = 1.25Sc + .25Sh$				
29				
30     Sustained      14 $Sh + Sa$				
31     + Expansion				
32				
33     Occasional      12U + 13 $1.2*(Sh + Sa)$				
34     (Upset) +				
35     Expansion				
36				
37     Load combinations addressing dynamic loads due to fluid				
38     transients are not specifically discussed in reference 2 or				
39     in the original piping code, reference 1a. Therefore,				
40     consistent with previous analysis, calculation BP-TOP-2 (ref				
41     20b), the fluid transient loading (upset condition) is				
42     considered independently of seismic loading. Accordingly,				
43     equation 12U will evaluate the maximum of either fluid				
44     transient or seismic loading.				
45				
46				
47				

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.65

APP. I

CALCULATION IDENTIFICATION NUMBER					PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE		
03040	NP (C)	PM 786 1-1 R.1	N/A		14

NOTES:

9. Node 355 is the intersection of the 26" main steam line with the 14" bypass line. Even though the diameter ratio is only approximately 2 to 1, the moment of inertia ratio is approximately 15 to 1. Therefore the 14" bypass line is decoupled from the 26" main steam line consistent with the analyses of the bypass lines (reference 19) which considered the 14" bypass line to be anchored at the 26" mainsteam line. Qualification of the 14" bypass line is not within the scope of this calculation. Only the weight contribution of the 14" bypass line to the 26" line is considered in this analysis.
10. Vertical restraint no. 5 is located on the 26" long radius elbow from nodes 20 to 45 directly under the riser from nodes 45 to 65. The pipe attachment is modeled at node 40 to provide restraint along the axis of the riser. However the actual piping attachment is at the horizontal centerline of the elbow from nodes 20 to 45. This results in a differential elevation of 2.75' between the actual attachment of the support and the coded location. This difference would yield fictitious vertical thermal loads between node 5 and 40. To negate this effect, a dummy vertical member is coded from node 40 to 41 (-2.75') with the same properties as the attached piping. Restraint no. 5 is modeled at node 41.
11. The four pipe whip restraints, 1 to 4 (ref 11b and 14), are conservatively not included in the piping analysis. They are gapped to accommodate the thermal displacements but would provide some seismic and dynamic restraint. Accordingly, the seisimic and dynamic results of the analysis are conservative.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65

A1P-1

CALCULATION IDENTIFICATION NUMBER					PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.		OPTIONAL TASK CODE	
03040	NP (C)	PM - 786	1-1 R.1	N/A	15
1					
2					
<u>NOTES:</u>					
3					
4					
5      12. Summary of Analyses					
6					
7      a. <u>Job 3762, Run 001, dated 2/23/93</u>					
8      Evaluates all loading conditions with all supports functioning.					
9					
10     Results - Pipe stresses acceptable for all loading conditions.					
11     Restraint no. 5 (node 41) uplifts due to dynamic loading.					
12     SSE load on support S2A (node 105, 72kip, Grinnell, 6" bore,					
13     Fig. 200, hydraulic snubber) exceeds snubber capacity by					
14     only 1.5%.					
15     Load = 114.3 kips > 112.6 kips per Attachment 2. Note that					
16     upset condition load of 61 kips is < the capacity.					
17					
18     This small SSE overload can be attributed to the					
19     conservatism in the ARS envelope. The piping in the Turbine					
20     Building (TB) is located at approximate elevation 154' which					
21     is very near the ARS elevation of 150'. Significantly					
22     higher accelerations exist at the next ARS elevation of 165'					
23     which was enveloped in this analysis. The significant					
24     effect of the 165' TB ARS, on snubber S2A, is demonstrated					
25     in study analysis JOB 7541 discussed below. Note that with					
26     the exception of snubber S2A which is addressed by Job 7541					
27     all piping, supports and components are qualified using the					
28     TB ARS at elevation 165'.					
29					
30					
31     b. <u>Job 3823, Run 002, dated 2/23/93</u>					
32     Same as Job 3762 except Restraint no. 5 (node 41) is					
33     conservatively considered non-functioning for all loading					
34     conditions due to uplift.					
35					
36     Results - Pipe stresses acceptable for all loading conditions.					
37     Loads on snubber support S2A (node 105) are within capacity.					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.68

APP. 1

CALCULATION IDENTIFICATION NUMBER					OPTIONAL TASK CODE	PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	PM - 786	I - 1		
03040	NP(C)		R . 1		N/A	15A

1  
2  
NOTES:

3  
4  
5 12. Summary of Analyses (cont'd)

6  
7 c. Job 7541, Run 008, dated 3/24/93 (study analysis)

8 Only evaluates the faulted condition using the piping model  
9 from Job 3762 and excluding TB ARS at elevation 165'. The  
10 purpose of this study analysis is to demonstrate the  
11 significant effect the TB ARS at elevation 165, has on  
12 snubber S2A.

13 Results - The load on snubber S2A was reduced from 114.3  
14 kips to 86 kips. It is based on this significant load  
15 reduction and the discussion included with Job 3762 that the  
16 load on snubber S2A is considered not to be overloaded by  
17 1.5% but rather loaded to its capacity of 112.6 kips.

18  
19 d. Job 6343, Run 023, dated 3/30/93

20 The piping model for Line D (Job 3821) is modified to  
21 reflect the vertical support arrangement on Lines A and B as  
22 discussed in note 5. The purpose of this analysis is to  
23 generate seismic and dynamic loadings for Line A supports  
24 H41 and H42 and Line B supports H27, H28, H29, and H30 for  
25 evaluation as required for the resolution of OI-PB-024 (See  
26 Objective). Note that thermal and deadweight loads from  
27 the previous analyses can be used (see Attachment 4). A  
28 piping model representative of lines A and B is obtained by  
29 coding Line D rigid hangers H7 and H9B as "spring hangers"  
30 with stiffness = 1.0 lb/in and with an applied force equal  
31 to the deadload on the rigid hangers from Job 3823.

32  
33 Results - Seismic and dynamic loads representative of those  
34 on hangers H27, H28, H29, H30, H41, and H42 have been  
35 generated. Due to the similarity between the 4 main steam  
36 lines addressed in note 5, the loads on the subject supports  
37 can be obtained from the corresponding Line D supports as  
38 follows:

39 H27 see H3

40 H28 see H4

41 H29, H41 see H5

42 H30, H42 see H6

43  
44 Detailed information is provided in Attachment 4.

45

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65

APP. 1

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
03040	NP(C)	PM - 786 1 - 1 R. 1	N/A	15B

NOTES:

13. This calculation fulfills the requirement of screening calculation PM-777 (ref. 24) to do further evaluation of the impact of rerated conditions on the Main Steam piping.

14. Evaluation of Additional 550 lb for New MSIV Poppet Asembly

Due to the close proximity of the MSIV to the penetration anchor (node 5), the additional poppet assembly weight will only impact the span from the anchor to the valve. The additional 550 lb represents approximately a 5% increase over the weight of the MSIV and piping to the anchor.

$$\begin{aligned} \text{MSIV} &= 10075 \text{ lb} & 2.583' \text{ of piping} &= 746 \text{ lb} \\ 550/(10075+746) &= .05 \end{aligned}$$

The critical location impacted by this change would be the anchor at node 5. The impact on this node is addressed below. Note that this small additional weight will not significantly impact the valve accelerations on page 32.

Increase deadweight stress by 5%, and using a safety factor of 1.5, increase dynamic stress by 7.5%.

The stresses at node 5 for Job 3762 are more than 7.5% less than the maximum stresses shown on pages 28 and 29. Therefore there is no impact.

The stresses at node 5 for Job 3823 are evaluated as follows and documented on pages 30 and 31.

Design press. stress = 6674 psi, Peak press. stress = 8003 psi  
 $8003 - 6674 = 1329 \text{ psi}$

$$\text{EQ11} = (10033 - 6674) * 1.05 + 6674 = 10,201$$


$$\text{EQ12U} = (19268 - 10033) * 1.075 + 10201 + 1329 = 21457 < \text{max on p30}$$

$$\text{EQ14} = 11546 + (10201 - 10033) = 11,714$$

$$\text{EQ12F} = (24701 - 10033) * 1.075 + 10201 + 1329 = 27,298$$


The conclusions of the penetration load evaluation on page 34 are not impacted, even with an additional 550 lb, given the large magnitude of the existing loads.

Peach Bottom Atomic Power Station  
Records Management



The following oversized page(s) were here ..  
to view, please move forward to the end of  
this document

11 x 17 Pg 16 + App 2 pg 12-17 of  
Calc 1-1



RADIOGRAPHS

If you need assistance, please contact PBAPS  
Records Management

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.85

APP. I

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
03040	NP(C)	PM 786 1-1 R.1	N/A	17

1           **DESIGN INPUT**

2           **FLUID TRANSIENT LOADING (REF 7)**

5           THTAPE = 019576

6           THFILE = 3

7           Total Integration Time = 3.0 sec

8           Integration Time Step = .001 sec

9           Damping = .5 %

10          Cutoff Frequency = 200 HZ

12         **Pipe**

<u>Segment</u>	<u>Curve</u>	<u>Node</u>	<u>Direction</u>
No.	No.		
1-7	7	10	-Z*
1-8	8	15	-Z
1-9	9	65	-Y
1-10	10	110	-Z
1-11	11	260	+X
1-12	12	345	-Z
1-13	13	360	-X

23          \* A scaler of .25 is applied to the load from segment  
 24          1-7 to address the ratio of the segment length  
 25          included in this model vs. the total segment length.

28          Segment length from node 5 to 15 =                   6.166 '  
 29          Total segment length considered in reference 7 = 24.67 '

31          6.166/24.67 = 0.25

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSVUNIFORM SUPPORT MOTION SEISMIC RESPONSE SPECTRA SET 1 (REF3)  
AMPLIFIED RESPONSE SPECTRA (ARS) - RB EL.135'-165', TB EL.150'-165'.5% DAMPING

X-EARTHQUAKE		Y-EARTHQUAKE		Z-EARTHQUAKE	
PERIOD (SEC)	ACCELERATION (G)	PERIOD (SEC)	ACCELERATION (G)	PERIOD (SEC)	ACCELERATION (G)
0.010	0.120			0.010	0.100
0.033	0.120			0.033	0.100
0.037	0.150			0.037	0.150
0.045	0.200			0.045	0.230
0.077	0.330			0.071	0.360
0.100	0.600 (.45)			0.091	0.840
0.111	1.920 (.42)			0.095	1.890
0.125	1.920 (.42)			0.111	1.890
0.133	2.270			0.118	0.930
0.164	2.270			0.122	1.090
0.167	2.090			0.133	2.270
0.196	0.640			0.164	2.270
0.244	0.360			0.167	2.090
0.435	0.290			0.196	0.640
0.833	0.290			0.238	0.390
1.220	0.130			0.500	0.390
10.000	0.000			0.769	0.360 (.22)
				1.250	0.120
				10.000	0.000

VALUES IN ( ) ARE ACCELERATIONS USED IN STUDY ANALYSIS JOB 7591 AND REPRESENT THE  
REDUCTION IN ARS WHEN TB EL 165 IS EXCLUDED. SEE NOTE 12 a/c

APP. 1 - 1 Rev. 1  
APR. 1 , 2018

NUPIPE-SW ME-110  
VER 06 LEV 03

STONE & WEBSTER ENGINEERING CORPORATION

2/23/93 PAGE 11  
JOB 3762 R0170001

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

UNIFORM SUPPORT MOTION SEISMIC RESPONSE SPECTRA SET 2 (REF. 3.)  
AMPLIFIED RESPONSE SPECTRA (ARS) - (2/3) GROUND SPECTRA .5% DAMPING

X-EARTHQUAKE		Y-EARTHQUAKE		Z-EARTHQUAKE	
PERIOD (SEC)	ACCELERATION (G)	PERIOD (SEC)	ACCELERATION (G)	PERIOD (SEC)	ACCELERATION (G)
0.000	0.043				
0.025	0.043				
0.033	0.060				
0.050	0.087				
0.100	0.113				
0.111	0.122				
0.125	0.133				
0.143	0.153				
0.167	0.167				
0.182	0.173				
0.222	0.173				
0.250	0.167				
0.333	0.153				
0.500	0.113				
1.000	0.057				
10.000	0.057				

Calc. 1-1 Rev. 1  
AEP 1 / P19

CALCULATION IDENTIFICATION NUMBER										PAGE
JOB NUMBER	DIVISION & GROUP		CALCULATION NO.			OPTIONAL TASK CODE				20
03040	NP (C)		PM - 786 1-1 R. 1			N/A				

DESIGN INPUTCROSS SECTIONAL PROPERTIES (REFERENCE 2, 5, 6)

ITEM NO.	SYSTEM NO.	PIPE CLASS	NOM. DIA. (IN)	SCH.	OD (IN)	WALL THK. (IN)	PIPE WT. (#/FT)	CONTENTS		INSULATION			TOTAL WT. (#/FT)
								TYPE	WT. (#/FT)	TYPE	THK. (IN)	WT.(1) (#/FT)	
1	1	DB/DBN	26	N/A	26.00	1.086 (4)	289	STEAM	N/A	I	3.5	28	317
2	1	DB	6	80	6.625	.432	28.6	WATER	11.3	I	3.5	10.6	50.5
3 (2)	1	DB	26	N/A	26.00	1.086 (4)	N/A	N/A	N/A	N/A	N/A	N/A	0
4	1	DB	14	80	14.00	.750	106	STEAM	N/A	I	3.5	17	123
5	1	N/A	28	N/A	28.00	1.375	N/A	STEAM	N/A	N/A	N/A	N/A	0
(3)	1	DB	4	80	4.50	.337	15	STEAM	N/A	II	2.5	5.3	20.3

## Notes:

1. Insulation weight includes:
  - 2 lb for aluminum jacket on 26" pipe.
  - 1.2 lb for aluminum jacket on 14" pipe.
  - 0.8 lb for aluminum jack
  - 0.6 lb for aluminum jacket on 4" pipe.
2. Item 3 is a dummy cross section for modeling of the AOV stem.
3. This item is not modeled in the analysis. It is only used to calculate the weight contribution of the decoupled 4" branch pipe.
4.  $t_{nom} = t_{min}/.875 = .950/.875 = 1.086$  accounting for manufacturers tolerance of 12.5%.

5010.65

APP - 1

CALCULATION IDENTIFICATION NUMBER								PAGE	
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	PM <del>786</del>			1 - 1	R - 1		
03040	NP (C)							N/A	21

1

2

3

4

DESIGN INPUT

5

BASIC ANALYTICAL DATA (REFERENCE 1b, c, 4, 5)

6

7

LOAD CASE NO.	MODE/ NOP (2)	MATERIAL	E(C) *E6 (PSI)	E(H) *E6 (PSI)	S(C) *E3 (PSI)	S(H) *E3 (PSI)	OPER. TEMP. (F)	THERMAL GROWTH (IN/FT)	DESIGN PRESSURE (PSI) (1)	DESIGN TEMP. (F)
2	1 / 1	A-672 GR.B-70 Class 22 (3)	29.90	27.04	17.5	17.5	551	.04120	1115	583
2	1 / 2	A-106GR.B	27.90	26.04	15.0	15.0	551	.04120	1115	583
3	2 / 1	A-672 GR.B-70 Class 22 (3)	29.90	26.82	17.5	17.5	583	.04433	1115	583
3	2 / 2	A-106GR.B	27.90	25.82	15.0	15.0	583	.04433	1115	583

24

25

26

27

28

29

30

31

32

33

34

- (1) 1337 is the maximum operating pressure.
- (2) Mode 1 is normal operating, Mode 2 is maximum operating.
- (3) Note that previous main steam stress calculations 1-1T and BP-TOP-2 (ref 20) identify the pipe material as A155 KC70. The material shown above is per reference 4. This difference is of no consequence since both materials have the same properties and allowable stress.
- (4) Reference 1c is used for the allowable stresses for material A-672 GR. B-70 Class 22 since this is the first year of the ANSI code in which this material appears.

NUPPIPE-SW ME-110  
VER 06 LEV 03

STONE & WEBSTER ENGINEERING CORPORATION

2/23/93 PAGE 24  
JOB 3762 R0170001

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

SYSTEM RESTRAINTS

ORTHOGONAL RESTRAINTS

NODE	GROUP	TYPE	TRANSLATIONAL (LBF/IN)			ROTATIONAL (IN-LBF/RAD)			MARK NO.
			X	Y	Z	X	Y	Z	
5	1	ANCHOR	1.E+08	1.E+08	1.E+08	1.E+10	1.E+10	1.E+10	FLUED HEAD PEN N-7D
75	1	RESTRAINT		1500.					1DB-H1
100	1	RESTRAINT		2160.					1DB-H2
105	1	SNUBBER	1.E+08						1DB-S2A
125	1	RESTRAINT		1.E+08					1DB-H3
140	1	RESTRAINT		1.E+08					1DB-H4
170	1	RESTRAINT		1.E+08					1DB-H5
210	1	RESTRAINT		1.E+08					1DB-H6
240	1	RESTRAINT		1.E+08					1DB-H7
250	1	SNUBBER			1.E+08				1DB-S7A
275	1	RESTRAINT		1.E+08					1DB-H9B
305	1	RESTRAINT		3000.					1DB-H10
325	1	RESTRAINT		2160.					1DB-H11
340	1	RESTRAINT		3000.					1DB-H12
370	1	RESTRAINT		2400.					1DB-H13
390	1	RESTRAINT		1.E+08					MSV-4 (INLET)
390	1	SNUBBER	1.E+08		1.E+08	1.E+10			MSV-4 (INLET)
41	1	RESTRAINT		1.E+08			1.E+10	1.E+10	RESTRAINT #5
480	1	ANCHOR	1.E+08	1.E+08	1.E+08	1.E+10	1.E+10	1.E+10	H.P.TURBINE (INLET)

STIFFNESS AT SPRING HANGERS IS PER REF 12 § 18. ALL OTHER SUPPORTS ARE RIGID

SYSTEM RESTRAINTS FOR OTHER ANALYSES DIFFER FROM THAT SHOWN ABOVE AS FOLLOWS:

JOB  
3823

DESCRIPTION  
Node 41 (Rest. #5) NOT MODELED

2/23/93 - 1-1-X-1  
C:\D\1-1-X-1

PECO PBAPS UNIT#2 03040-NP(c)-PM-786 (RERATE) MS "D" CONTMT TO TSV

## NODAL LOADS

STATIC FORCES (REF 12)

NODE	THERMAL MODE	FORCES (LBF)			MOMENTS (FT-LBF)		
		X	Y	Z	X	Y	Z
75 (H1) 1		0.	8887.	0.	0.	0.	0.
100 (H2) 1		0.	6125.	0.	0.	0.	0.
305 (H10) 1		0.	8697.	0.	0.	0.	0.
325 (H11) 1		0.	6434.	0.	0.	0.	0.
340 (H12) 1		0.	8571.	0.	0.	0.	0.
370 (H13) 1		0.	7200.	0.	0.	0.	0.

COLD LOAD INPUT AT SPRING HANGERS

5.0 App. 2 for Unit 3  
Spring Settings

APP. 1  
P23

1-1 R.1

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲5010.65

A.P.P. 1

CALCULATION IDENTIFICATION NUMBER					OPTIONAL TASK COD N/A	PAGE 24
JOB NUMBER 03040	DIVISION & GROUP NP (C)	CALCULATION NO. PM - 786	1-1	R. 1		

1  
2     DESIGN INPUT

3     STRESS INTENSIFICATION FACTORS

COMPONENT		SIF	NOTES								
1 TAPER TRANSITION		1.9	5, 10, 390 20(3)								
2 ANSI TEE		$i = .9/(4.4t/r)^{(2/3)}$ $r =$ mean radius of run pipe									
OD      t A)      26    1.086		1.70	355								
3 BRANCH CONNECTIONS $R_m/Tr \leq 50$ , $r'm/R_m \leq 0.5$		$i = 1.5(R_m/Tr)^{(2/3)} (r'm/R_m)^{(1/2)} (T'b/Tr) (r'm/rp)$ $R_m =$ mean radius of run pipe $r'm =$ mean radius of branch pipe $rp =$ outer radius of branch pipe									
RUN                  BRANCH		LIMITS									
OD	Tr	OD	T'b	Rm	r'm	rp	Rm/Tr	r'm/Rm	LIMITS		
A)      26"    N/A    6"    SCH80		$i = 1.41$		385 (2)							
26.000    1.086    6.625    0.432    12.457    3.0965    3.313    11.47    0.25    OK											
B)      26"    N/A    4"    SCH80		$i = 0.90$ USE 1.3		380							
26.000    1.086    4.500    0.337    12.457    2.0815    2.250    11.47    0.17    OK											
C) miscellaneous small bore instrumentation connections		$i =$ USE 1.3		360, 365, 370							

21 REFERENCES: 1b (ANSI 1973)

22     NOTES:

- 23     1) SIFs FOR BUTT WELDED ELBOWS, ARE CALCULATED IN NUPIPE PER REF ABOVE.  
24  
25     2) THE SIF FOR THE 6" DRIP LEG ATTACHED TO THE 26" ELBOW AT NODE 35 IS CONSIDERED TO  
26       BE THE PRODUCT OF THE INDIVIDUAL SIFs.

27     ELBOW SIF =  $.9/(Tr/r^2)^{(2/3)} =$       2.14

28     BRANCH SIF =                                    1.41

29     SIF PRODUCT =    3.02 \*     \* THIS SIF IS CODED ON MEMBER 35-40. THEREFORE AN  
30       SIF OF 3.02 IS ALSO CONSIDERED AT TRUNNION FOR RESTRAINT NO. 5

- 31  
32     3) ELBOW SIF, PER NOTE 1 ABOVE, OF 2.14 EXCEEDS TAPER SIF.

33

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

45010.65

App. 1

CALCULATION IDENTIFICATION NUMBER					PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK COD		
03040	NP (C)	PM - <del>786</del> 1-1 R.1	N/A		25

1

2 DESIGN INPUT

3 CONCENTRATED WEIGHTS (lbs)

4

5 Weight of AOV 086D is 10,075 lb per reference 16. Weight  
 6 distribution is per assumption 1. SEE NOTE 14 FOR ADDITIONAL  
 7 WEIGHT OF 550 lb

(B)

8 Weight contribution of a decoupled branch line is  
 9 approximated as the weight of 1/2 of a standard deadweight  
 10 span per ref 6. Weights are rounded to the nearest 10 lb.

11

Line OD (in)	Std Stm Span (ft)	Weight (lb/ft)	1/2 Span Weight (lb)
4	17	20.3	170
14	32	123	1970

16

17 Approximate weights of pipe whip restraint attachments to the piping  
 18 are based on pipe restraint detail drawings (ref. 14). These weights  
 19 are summarized below.

21

restraint/node	weight	description	
2, 3, 4 (54, 56, 76)	1080	clamp =	380
		(4) 3" lugs =	475
		(4) 6-1/2" lugs =	220
		misc. hardware =	5
1 (82)	170	clamp =	102
		lug =	68

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.85

APP. 1

CALCULATION IDENTIFICATION NUMBER				PAGE 26
JOB NUMBER 03040	DIVISION & GROUP NP (C)	CALCULATION NO. PM - 786	1 - 1 R. 1	

DESIGN INPUT

CONCENTRATED WEIGHTS (lbs)

Approximate weights of pipe support attachments to the piping are based on pipe support detail drawings (ref. 12), and support vendor catalog (ref. 18). These weights are summarized below.

support/(node)	weight	description	
R5 (40)	580	20" SCH 80 trunnion 2.78' long	
H1, H2, H11, H12 (75, 100, 325, 340)	109	clamp	
S2A (105)	620	plate box around pipe = 467 1/2 72K snubber = 146 misc. hardware = 7	
H3 (125)	330	2 channels @ 11.5#/ft, 4 ft long = 93 plate steel = 115 1 strut = 86 u-bolt = 28 misc. hardware = 8	
H4, H5, H6, H7, H9B (140, 170, 210, 240, 275)	300	clamp = 272 1/2 strut = 27 misc. hardware = 1	
S7A (250)	1450	plate box around pipe = 836 1/2 200K snubber = 515 * 4 rods = 50 misc. hardware = 49	
H10 (305)	162	clamp	
H13 (370)	220	steel = 108 saddle = 45 rod = 27 u-bolt = 28 misc. hardware = 12	

\* Weight of a 200K snubber was unavailable from reference 18 therefore 1/2 the weight of a 200K snubber is considered equal to the weight of a 100K snubber.

Weights are shown in the Input Data Echo section (Attachment 1) on lines beginning with "CWE".

STONE & WEBSTER ENGINEERING CORPORATION

PAGE OF

COMPUTER RUN DATE SUBMITTER  
R0170001 2/23/93 F.CAPUANO

CLIENT

AX STRESS SUMMARY

J.O. 03040.24.54.0 PROB.

PIPING SYSTEM

MS "D" (CONTMT TO TSV)

REPORT OR AX

03040-NP(C)-PM-786

REF. DRAWINGS

ISS/REV

DATE

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (R  
ERATE) MS "D" CONTMT TO TSV

LOADING CONDITIONS ANALYZED

LOAD CASE NUMBER	DESCRIPTION
1	DEADWEIGHT
2	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
10	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS

Rev. 1-1 R. 1  
P27

STONE &amp; WEBSTER ENGINEERING CORPORATION

PAGE OF

COMPUTER RUN  
R0170001 DATE 2/23/93 SUBMITTER  
F.CAPUANO

## AX STRESS SUMMARY

J.O. 03040.24.54.0 PROB.

CLIENT

PIPING SYSTEM MS "D" (CONTMT TO TSV)

REPORT OR AX 03040-NP(C)-PM-786

REF. DRAWINGS

ISS/REV

DATE

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (R  
ERATE) MS "D" CONTMT TO TSVJOB 3762 ALL SUPPORTS FUNCTIONING

SEE NOTE 8

CLASS 2, 3, OR 4 MAXIMUM STRESS LEVELS (PSI) - NORMAL/UPSET CONDITIONS  
 $E(\text{COLD}) = 29,900$        $S(C) = 17,500 \text{ (PSI)}$   
 $P\text{-NO.} = 1$                    $S(H) = 17,500 \text{ (PSI)}$       583 DEG-F

EQUATION	POINT NO.	MEMBER TYPE	MAX. CALC. STRESS	ALLOWABLE STRESS
SUSTAINED STRESS (EQUATION 8T11)	170	RUN	7621.	$< 17,500 = (S_h)$
OCCASIONAL STRESS (EQUATION 8T12)	40	ELBOW	17756.	$< 21,000 = (1.2 S_h)$ , $17756 + 1329 = 19085 < 21,000$
EXPANSION STRESS (EQUATION 10T13)	260	ELBOW	3709.	$< 26,250 = (1.25 S_c + .25 S_h) = S_a$
SUSTAINED PLUS EXPANSION STRESS (EQUATION 12T14)	260	ELBOW	10611.	$< 43,750 = (S_h + S_a)$

$S(C)$  = BASIC MATERIAL ALLOWABLE STRESS AT MINIMUM (COLD) TEMPERATURE  
 $S(H)$  = BASIC MATERIAL ALLOWABLE STRESS AT MAXIMUM (HOT) TEMPERATURE

OCCASIONAL + EXPANSION

EQ 12T13      40      ELBOW  $19042 + 1329 < 52,500 = 1.2(S_h + S_a)$   
 $= 20,371$

NOTE: STRESS LEVELS FOR THE 6" CARBON STEEL Drip LEGS ( $E=27.9E6$ )

ARE INSIGNIFICANT WHEN COMPARED TO THE STRESSES  
 IN THE BALANCE OF THE PIPING. THEREFORE A  
 SEPARATE TABULATION IS NOT PROVIDED.

\* ADDITIONAL PRESSURE STRESS DUE TO maximum pressure of 1337psi  
 $(1337 - 1115) * 26.00 / 4 * 1.086 = 1329 \text{ psi}$

Calc. 1-1 R.  
App. 1 P28

STONE &amp; WEBSTER ENGINEERING CORPORATION

PAGE OF

COMPUTER RUN DATE SUBMITTER  
R0170001 2/23/93 F.CAPUANO

CLIENT

## AX STRESS SUMMARY

J.O. 03040.24.54.0 PROB.

PIPING SYSTEM MS "D" (CONTMT TO TSV)

REPORT OR AX 03040-NP(C)-PM-786

REF. DRAWINGS

ISS/REV

DATE

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (R  
ERATE) MS "D" CONTMT TO TSVJOB 3762

CLASS 2, 3, OR 4 MAXIMUM STRESS LEVELS (PSI) - FAULTED CONDITION  
 $E(\text{COLD}) = 29,900$        $S(C) = 17,500 \text{ (PSI)}$   
 $P-\text{NO.} = 1$                    $S(H) = 17,500 \text{ (PSI)}$        $583 \text{ DEG-F}$

EQUATION	POINT NO.	MEMBER TYPE	MAX. CALC. STRESS	ALLOWABLE STRESS
SUSTAINED STRESS (EQUATION 8)	170	RUN	7621.	
OCCASIONAL STRESS (EQUATION 9T/2F)	390	RUN	21945. $< 31,500 = 1.8(S_h)$ , $21945 + 1329 = 23,274 < 31,500$	

$S(C)$  = BASIC MATERIAL ALLOWABLE STRESS AT MINIMUM (COLD) TEMPERATURE  
 $S(H)$  = BASIC MATERIAL ALLOWABLE STRESS AT MAXIMUM (HOT) TEMPERATURE

CAC. 1-1 R.1  
APP. 1, P29

STONE &amp; WEBSTER ENGINEERING CORPORATION

PAGE \_\_\_\_ OF \_\_\_\_

COMPUTER RUN  
R0170002 DATE 2/23/93 SUBMITTER  
F.CAPUANO

CLIENT

## AX STRESS SUMMARY

J.O. 03040.24.54.0 PROB.

PIPING SYSTEM MS "D" (CONTMT TO TSV)

REPORT OR AX 03040-NP(C)-PM-786

REF. DRAWINGS

ISS/REV

DATE

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (R  
ERATE) MS "D" CONTMT TO TSV

JOB 3823 REST. NO. 5 NOT FUNCTIONING

CLASS 2, 3, OR 4 MAXIMUM STRESS LEVELS (PSI) - NORMAL/UPSET CONDITIONS

E(COLD)= 29,900

S(C)=17,500 (PSI)

P-NO. = 1

S(H)=17,500 (PSI)

583 DEG-F

EQUATION	POINT NO.	MEMBER TYPE	MAX. CALC. STRESS	ALLOWABLE STRESS
SUSTAINED STRESS (EQUATION 8) //	5	RUN	10,201 * 10053.	< 17,500
OCCASIONAL STRESS (EQUATION 8+12)	35	ELBOW	20132.	< 21,500
EXPANSION STRESS (EQUATION 20+13)	260	ELBOW	3716.	< 26,250
SUSTAINED PLUS EXPANSION STRESS (EQUATION 22+14)	5	RUN	11,714 * 11546.	< 43,750

A

$$20132 + 1329 = 21,461 < 21,500$$

A

EQ12+13 35 ELBOW  $21668 + 1329 < 52,500$ 

22797

S(C) = BASIC MATERIAL ALLOWABLE STRESS AT MINIMUM (COLD) TEMPERATURE

S(H) = BASIC MATERIAL ALLOWABLE STRESS AT MAXIMUM (HOT) TEMPERATURE

\* SEE NOTE 14 ON PG 15B

B

Calc. 1 - 1 R.  
App. 1, P30

STONE &amp; WEBSTER ENGINEERING CORPORATION

PAGE OF  
---COMPUTER RUN DATE SUBMITTER  
R0170002 2/23/93 F.CAPUANO

## AX STRESS SUMMARY

J.O. 03040.24.54.0 PROB.

CLIENT

PIPING SYSTEM MS "D" (CONTMT TO TSV)

REPORT OR AX 03040-NP(C)-PM-786

REF. DRAWINGS

ISS/REV

DATE

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (R  
ERATE) MS "D" CONTMT TO TSVJAB 3823

CLASS 2, 3, OR 4 MAXIMUM STRESS LEVELS (PSI) - FAULTED CONDITION  
 $E(\text{COLD}) = 29,900$        $S(C) = 17,500 \text{ (PSI)}$   
 $P\text{-NO.} = 1$                    $S(H) = 17,500 \text{ (PSI)}$       583 DEG-F

EQUATION	POINT NO.	MEMBER TYPE	MAX. CALC. STRESS	ALLOWABLE STRESS
----------	-----------	-------------	-------------------	------------------

SUSTAINED STRESS      6      RUN      10033.

OCCASIONAL STRESS      5      RUN      24701. < 31,500       $24701 + 1329 = 26030 < 31,500$

$S(C)$  = BASIC MATERIAL ALLOWABLE STRESS AT MINIMUM (COLD) TEMPERATURE  
 $S(H)$  = BASIC MATERIAL ALLOWABLE STRESS AT MAXIMUM (HOT) TEMPERATURE

\* SEE NOTE 14 ON PG 15B

27298\*

(A)

C-3  
APP. 1  
P31

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲5010.65

APP. I

CALCULATION IDENTIFICATION NUMBER					PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE		
03040	NP (C)	PM 786	1-1 R.1	N/A	32

1

2 SYSTEM ACCELERATIONS:

3

4 The accelerations at the body (node 25) and the operator  
5 (node 30) of AO 086D are less than 0.5 g in each of the  
6 global directions for the following independent UPSET  
7 loading conditions: OBE and Fluid Transient

8

9 Note that SSE accelerations = 2.4\*OBE accelerations

10

11 These accelerations are judged acceptable based on  
12 their very small magnitude (i.e. resultant  
13 acceleration is less than 1g for the upset condition.)

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65

APP-1

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
03040	NP(C)	PM - 786	1-1 R.1	N/A

1

**PIPING DISPLACEMENTS:**

2

3 Displacements in excess of 2" are highlighted below for  
4 information. Only the maximum displacement and node in a  
5 given vicinity of piping are identified. Detailed displacement  
6 data at non support locations can be obtained from the computer  
7 run microfiche, Attachment 5. Detailed displacements at support  
8 locations can be obtained from the pipe support summary section,  
9 beginning on page 36.

10

11

12 Range of nodes with  
13 displacements

14

<u>Loading Condition</u>	<u>Range of nodes with displacements exceeding 2" in vicinity of maximum</u>	<u>Maximum Displacement (Node)</u>		
		x	y	z
OBE	160-205			2.4"(185)
SSE	135-230			5.8"(185)
Thermal (583F)	100-140 160-390 315-390		-6.7"(265)	2.5"(115) 3.2"(345)

15

16 Note that displacements due to fluid transient are less than 2"  
17 in each global direction at all locations.

18

19 The above displacements are judged acceptable since adequate  
20 clearance exists between main steam lines A, B, C, and D and  
21 between the lines and structural components based on main steam  
22 piping drawing M-175 (ref. 11C).

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A 5010.65

APP. I

CALCULATION IDENTIFICATION NUMBER						PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE			
03040	NP (C)	PM - 786 /-1 R.1	N/A			34

(SEE NOTE 14 FOR EVALUATION)

OF ADDITIONAL LOAD WE167T

**PENETRATION N-7D EVALUATION:**

LOADS FROM PM-786 (Pipe Support Summary Section)

LOAD	NODE	FORCE (LB)			MOMENT (FT-LB)		
		FX	FY	FZ	MX	MY	MZ
DW (5)	14	-19374	-11	99833	330	-1491	
THERM 583 (5)	926	-1622	-792	31136	7523	-10636	
FT+ (5)	13806	43697	30473	221335	123683	166921	
FT- (5)	-14907	-31634	-21755	-169844	-129237	-159087	
OBE (5)	10317	15399	13144	122936	84908	106246	
SSE (5)	24761	36956	31547	295047	203779	254990	
UPSET+	14746	24323	30462	352304	131536	165430	
UPSET-	-14893	-52630	-22558	-70011	-128907	-171214	
FAULTED+	25701	17582	31536	426016	211632	253499	
FAULTED-	24775	-57952	-32350	-195214	-203449	-267117	

LOADS FROM PREVIOUS ANALYSES 1-1W,S,T, D-007 (ref 20, 22)

LOAD	NODE	FORCE (LB)			MOMENT (FT-LB)		
		FX	FY	FZ	MX	MY	MZ
DW (5)	26	-15543	-17	115971	735	-1735	
THERM 583 (5)	868	-698	-730	19015	7998	-9767	
FT+ (110)	76482	19479	10029	1107900	683604	406132	
FT- (110)	-76482	-19479	-10029	-1107900	-683604	-406132	
OBE (133)	3987	8460	13132	97319	37999	44608	
SSE (133)	9569	20304	31517	233566	91198	107059	
UPSET+	77376	3936	13115	1242886	692337	404397	
UPSET-	-76456	-35720	-13879	-991929	-682869	-417634	
FAULTED+	10463	4761	31500	368552	99931	105324	
FAULTED-	-9543	-36545	-32264	-117595	-90463	-118561	

**RATIO OF UPSET LOADS (PREVIOUS ANALYSES/PM-786)**

UPSET+	5.2	0.2	0.4	3.5	5.3	2.4
UPSET-	5.1	0.7	0.6	14.2	5.3	2.4

Notes:

1. FT loads from calc D-007 are only tabulated/summarized in one direction. Therefore they are considered to be +/- in this evaluation.
2. The upset condition loading from the previous analyses is the dominant loading condition.
3. The impact of power rerate on the penetration loading is negligible as seen by the significant fluid transient loading from the previous analyses for the Fx, Mx, My, and Mz components. The significant load for these components is considered to offset the increase in the Fy, and Fz components.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.65

APP. 1

CALCULATION IDENTIFICATION NUMBER						
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.			OPTIONAL TASK CODE	PAGE
03040	NP(C)	PM - 786 1-1 A.1			N/A	35

**MAIN STEAM STOP VALVE NO. 4 EVALUATION:**

1-1  
**LOADS FROM PM-786 (Pipe Support Summary Section)**

LOAD	NODE	FORCE (LB)			MOMENT (FT-LB)		
		FX	FY	FZ	MX	MY	MZ
FT+	(390)	13806	847	30473	3420	123683	166921
FT-	(390)	-13471	-1046	-21755	-3742	-129237	-159087
OBE	(390)	7181	3488	8904	9790	160197	59496
SSE	(390)	17234	8371	21370	23496	384473	142790

**LOADS FROM PREVIOUS ANALYSES 1-1S, D-007 (ref 20, 22)**

LOAD	NODE	FORCE (LB)			MOMENT (FT-LB)		
		FX	FY	FZ	MX	MY	MZ
FT+	(2)	18616	123	19518	5079	3591361	19520
FT-	(2)	-18616	-123	-19518	-5079	-3591361	-19520
OBE	(29)	3002	8586	7133	20970	188440	222040
SSE	(29)	7205	20608	17119	50328	452256	532896

1-1  
**RATIO OF LOADS (PREVIOUS ANALYSES/PM-786)**

UPSET+	1.3	2.5	0.6	2.1	22.4	1.3
UPSET-	1.4	2.5	0.9	2.1	22.4	1.4
SSE	0.4	2.5	0.8	2.1	1.2	3.7

Notes:

1. FT loads from calc D-007 are only tabulated/summarized in one direction. Therefore they are considered to be +/- in this evaluation.
2. Only dynamic loads are addressed in this evaluation since maximum temperature is unchanged at 583F and the differences in deadweight loading would only be due to modeling techniques and not due to power rerate conditions.
3. Calc 1-1S models all four main steam loops together and therefore does not have the MSV inlet directly restrained as is done in PM-786. 1-1 Therefore member loads at node 29 from member 29 to 34 are used in this evaluation.
4. The impact of power rerate on the MSV-4 loading is negligible as seen by the significant FT or seismic loading from the previous analyses for the Fx, Fy, Mx, My, and Mz components. The load for these components is considered to offset the increase in the Fz component.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65

APP. 1

CALCULATION IDENTIFICATION NUMBER				OPTIONAL TASK CODE	PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.			
03040	NP(C)	PM - 786	1-1 R-1	N/A	36

PIPE SUPPORT LOAD SUMMARY:

JOB	Description	Pages
3762	All supports functioning	37-54
3823	Restraint no.5 non-functioning (uplift)	55-71

NOTES:

1. Cold loads, applied at spring hangers for deadweight analysis, are shown on page 23 of this calculation.
2. Pipe support evaluation shall use the maximum loading from JOBS 3762 and 3823.
3. Load combination LC#2 is erroneously identified as using the maximum value of DWT or (DWT + TH NORMAL). Actually, load combination LC#2 only uses the algebraic sum of DWT + TH NORMAL. If another load combination is desired the individual loads (i.e. DWT, THERMAL, FT, OBE) must be recombined manually.
4. 200 kip Grinnell snubber S7A (node 250) restrains both lines C and D. Therefore the load must be doubled for evaluation of the support. This is noted on pages 47, 64. Note that twice the maximum faulted load ( $2 \times 108.4 = 216.8$  kips) is within the capacity of the snubber ( $1.33 \times 200 = 266$  kips). The 1.33 factor applied to the normal capacity of the snubber is conservatively based on the smallest ratio of faulted to normal snubber capacities specified in Attachment 2 (Grinnell load data sheet).

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 1 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 5 \*  
\* FUNCTION: ANCHOR \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* FLUED HEAD PEN N-7D \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI)	FORCES (LBF)			MINIMUM CLASS 2 STRESSES (PSI)			DEFLECTIONS (IN)			ROTATIONS (RAD)		
			FX	FY	FZ	EQ.8 7027.	EQ.9 14378.	EQ.10 769.	EQ.11 7796.	MX	MY	MZ	DX	DY
DWT	1	353.	11.	-9727.	-6.	10411.	330.	-1265.	0.00	0.00	0.00	0.000	0.000	0.000
OBEI	10	4967.	-10317.	-15399.	-11849.	-57456.	-84908.	-106246.	0.00	0.00	0.00	0.000	0.000	0.000
OBEA NOT SPECIFIED														
SSEI	11	11921.	-24761.	-36956.	-28438.	-137894.	-203779.	-254990.	0.00	0.00	0.00	0.000	0.000	0.000
NORM	2	715.	859.	2743.	-734.	-10457.	6992.	-9786.	0.00	0.00	0.00	0.000	0.000	0.000
THERANC	3	769.	924.	2951.	-790.	-11251.	7523.	-10529.	0.00	0.00	0.00	0.000	0.000	0.000
OCCMAX	4	7351.	-14907.	43697.	30473.	-167789.	-129237.	166921.	0.00	0.00	0.00	0.000	0.000	0.000
OCCMIN														
MODFLEX	15	567.	870.	-9727.	-741.	10411.	7322.	-11051.	0.00	0.00	0.00	0.000	0.000	0.000
MODFLEX	17	7782.	-15777.	-50681.	-31214.	-167835.	-136559.	-177972.	0.00	0.00	0.00	0.000	0.000	0.000
MODFLEX	18	12496.	-25696.	-46683.	-29235.	-148304.	-211632.	-266785.	0.00	0.00	0.00	0.000	0.000	0.000

CASE DESCRIPTION TITLE

- |                              |  |
|------------------------------|--|
| 1 DEADWEIGHT                 | DEADWEIGHT   |
| 10 1/2 SSE INERTIA           | OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS |
| 11 SSE INERTIA               | SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS |
| 2 NORMAL OPERATING           | THERMAL ANALYSIS (NORMAL) 551 DEG F                          |
| 3 THERMAL EXPAN + ANC MVMTS  | THERMAL ANALYSIS (MAXIMUM) 583 DEG F                         |
| 4 TIME HISTORY DYNAMIC FORCE | FT = FLUID TRANSIENT DUE TO TURBINE TRIP                     |
| 15 MODFLEX                   | LC#1 MAX. VALUE (DWT, (DWT+TH NORM))                         |
| 17 MODFLEX                   | LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))             |
| 18 MODFLEX                   | LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)                      |

44-1-237  
1/18/93

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 18 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 41 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* RESTRAINT #5 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	MINIMUM CLASS 2 STRESSES (PSI)			DEFLECTIONS (IN)			ROTATIONS (RAD)			
			EQ.8 6674.	EQ.9 6674.	EQ.10 0.	EQ.11 6674.	DX	DY	DZ	RX	RY	RZ
DWT	1	0.	0.	-10837.	0.	0.	0.00	0.00	0.00	0.000	0.000	0.000
OBEI	10	0.	0.	-15807.	0.	0.	0.03	0.00	0.02	0.001	0.001	0.001
OBEA NOT SPECIFIED												
SSEI	11	0.	0.	-37938.	0.	0.	0.06	0.00	0.04	0.003	0.002	0.004
NORM	2	0.	0.	-4390.	0.	0.	0.00	0.00	0.42	0.000	0.000	0.000
THERANC	3	0.	0.	-4724.	0.	0.	0.00	0.00	0.46	0.000	0.000	0.000
OCCMAX	4	0.	0.	-40395.	0.	0.	-0.04	0.00	-0.05	0.004	-0.001	0.002
OCCMIN				32565.	0.	0.	0.03	0.00	0.04	-0.003	0.001	-0.002
MODFLEX	15	0.	0.	-15227.	0.	0.	0.00	0.00	0.42	0.000	0.000	0.000
MODFLEX	17	0.	0.	-55622.	0.	0.	0.04	0.00	0.47	0.004	0.001	0.003
MODFLEX	18	0.	0.	-53498.	0.	0.	0.06	0.00	0.49	0.003	0.002	0.004

CASE DESCRIPTION

TITLE

- 1 DEADWEIGHT  
10 1/2 SSE INERTIA  
11 SSE INERTIA  
2 NORMAL OPERATING  
3 THERMAL EXPAN + ANC MVMTS  
4 TIME HISTORY DYNAMIC FORCE  
15 MODFLEX  
17 MODFLEX  
18 MODFLEX
- DEADWEIGHT  
OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
THERMAL ANALYSIS (NORMAL) 551 DEG F  
THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
LC#1 MAX. VALUE (DWT, (DWT+TH NORM))  
LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))  
LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R. 1  
AP. 1, P38

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 2 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 75 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-M1 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				GLOBAL COORDINATES (FT)		
			EQ.8 6997.	EQ.9 10589.	EQ.10 543.	EQ.11 7540.	X COORD -11.00	Y COORD 153.83	Z COORD 61.25			
			FORCES (LBF)	MOMENTS (FT-LBF)		DEFLECTIONS (IN)			ROTATIONS (RAD)			
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ	RX
DWT	1	324.	0.	-19.	0.	0.	0.	0.	0.01	-0.01	0.01	0.000
OBEI	10	1952.	0.	-93.	0.	0.	0.	0.	0.34	0.06	0.25	0.001
OBEA	NOT SPECIFIED											0.001
SSEI	11	4684.	0.	-224.	0.	0.	0.	0.	0.81	0.15	0.60	0.002
NORM	2	504.	0.	865.	0.	0.	0.	0.	0.03	0.58	0.75	0.001
TERHANC	3	543.	0.	931.	0.	0.	0.	0.	0.04	0.62	0.81	0.001
OCCMAX	4	3592.	0.	-233.	0.	0.	0.	0.	-0.56	-0.16	0.73	0.001
OCCMIN			0.	176.	0.	0.	0.	0.	0.37	0.12	-0.53	-0.001
MODFLEX	15	810.	0.	846.	0.	0.	0.	0.	0.04	0.56	0.76	0.001
MODFLEX	17	4387.	0.	-1079.	0.	0.	0.	0.	0.60	0.72	1.49	0.003
MODFLEX	18	5378.	0.	-1136.	0.	0.	0.	0.	0.86	0.76	1.41	0.003

CASE DESCRIPTION

TITLE

- |    |                            |  |
|----|----------------------------|--|
| 1  | DEADWEIGHT                 | DEADWEIGHT   |
| 10 | 1/2 SSE INERTIA            | OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS |
| 11 | SSE INERTIA                | SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS |
| 2  | NORMAL OPERATING           | THERMAL ANALYSIS (NORMAL) 551 DEG F                          |
| 3  | THERMAL EXPAN + ANC MVMTS  | THERMAL ANALYSIS (MAXIMUM) 583 DEG F                         |
| 4  | TIME HISTORY DYNAMIC FORCE | FT = FLUID TRANSIENT DUE TO TURBINE TRIP                     |
| 15 | MODFLEX                    | LC#1 MAX. VALUE (DWT, (DWT+TH NORM))                         |
| 17 | MODFLEX                    | LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))             |
| 18 | MODFLEX                    | LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)                      |

Case 1-1 R. 1  
Modflex P39

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 3 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 100 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H2 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	MINIMUM CLASS 2 STRESSES (PSI)			DEFLECTIONS (IN)			ROTATIONS (RAD)		
			EQ.8 6706.	EQ.9 11156.	EQ.10 845.	EQ.11 7551.	DX	DY	DZ	RX	RY
DWT	1	33.	0.	-56.	0.	0.	0.02	-0.03	0.01	0.000	0.000
OBEI	10	3965.	0.	-169.	0.	0.	0.03	0.08	0.25	0.001	0.001
OBEA	NOT SPECIFIED										
SSEI	11	9516.	0.	-405.	0.	0.	0.08	0.19	0.60	0.001	0.003
NORM	2	786.	0.	258.	0.	0.	-0.04	0.12	1.99	0.001	0.000
THERANC	3	845.	0.	277.	0.	0.	-0.04	0.13	2.14	0.001	0.000
OCCMAX	4	4449.	0.	-264.	0.	0.	-0.06	-0.12	0.74	-0.001	0.002
OCCMIN			0.	208.	0.	0.	0.05	0.10	-0.54	0.001	-0.002
MODFLEX	15	790.	0.	202.	0.	0.	-0.02	0.09	2.00	0.001	0.000
MODFLEX	17	5239.	0.	-466.	0.	0.	0.08	0.22	2.73	0.002	0.003
MODFLEX	18	10364.	0.	-626.	0.	0.	0.11	0.29	2.75	0.003	0.004

CASE DESCRIPTION

TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 p 40  
A/P. 1, P. 1

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 4 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 105 \*  
\* FUNCTION: SNUBBER \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-S2A \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				GLOBAL COORDINATES (FT)		
			FX	FY	FZ	EQ.8 6755.	EQ.9 11393.	EQ.10 890.	EQ.11 7646.	X COORD -11.00	Y COORD 153.83	Z COORD 93.33
DWT	1	82.	0.	0.	0.							
OBEI	10	4347.	-47626.	0.	0.	0.	0.	0.	0.02	-0.02	0.01	0.000
OBEA	NOT SPECIFIED								0.00	0.06	0.25	0.001
SSEI	11	10433.	-114303.	*	0.	0.	0.	0.	0.00	0.15	0.60	0.002
NORM	2	827.	0.	0.	0.					-0.05	0.09	2.07
THERANC	3	890.	0.	0.	0.					-0.05	0.10	2.23
OCCMAX	4	4637.	-58659.	0.	0.	0.	0.	0.	0.00	-0.10	0.74	-0.001
OCCMIN	34779.								0.00	0.08	-0.54	0.001
MODFLEX	15	844.	0.	0.	0.					-0.03	0.07	2.08
MODFLEX	17	5475.	-58659.	0.	0.	0.	0.	0.	0.03	0.17	2.82	0.002
MODFLEX	18	11328.	-114303.	*	0.	0.	0.	0.	0.04	0.23	2.83	0.003
												0.004
												0.001

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	Thermal Analysis (Normal) 551 deg F
3	THERMAL EXPAN + ANC MVMTS	Thermal Analysis (Maximum) 583 deg F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

\* SEE NOTES 12 a AND 12 c. LOAD = 112,600 lb

Calc. 1-1 R. 1  
A11-1, P49

NUPIPE-SW ME-110  
VER 06 REV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 5 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 125 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H3 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL FORCES (LBF)			MINIMUM CLASS 2 STRESSES (PSI)			GLOBAL COORDINATES (FT)			
			FX	FY	FZ	EQ.8 6957.	EQ.9 9738.	EQ.10 902.	EQ.11 7860.	X COORD -17.65	Y COORD 153.83	Z COORD 99.17
DWT	1	284.	0.	-4579.	0.	0.	0.	0.	0.02	0.00	0.01	0.000
OBEI	10	1874.	0.	-9091.	0.	0.	0.	0.	0.15	0.00	0.44	0.001
OBEA	NOT SPECIFIED											0.004
SSEI	11	4499.	0.	-21818.	0.	0.	0.	0.	0.35	0.00	1.07	0.002
NORM	2	839.	0.	510.	0.	0.	0.	0.	-0.37	0.00	2.21	0.001
THERANC	3	902.	0.	549.	0.	0.	0.	0.	-0.40	0.00	2.38	0.001
OCCMAX	4	2781.	0.	-9279.	0.	0.	0.	0.	0.19	0.00	0.62	-0.001
OCCMIN				7504.	0.	0.	0.	0.	-0.18	0.00	-0.49	0.001
MODFLEX	15	887.	0.	-4579.	0.	0.	0.	0.	-0.36	0.00	2.22	0.001
MODFLEX	17	3659.	0.	-13348.	0.	0.	0.	0.	0.55	0.00	2.84	0.002
MODFLEX	18	5424.	0.	-26397.	0.	0.	0.	0.	0.73	0.00	3.45	0.003

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R. 1  
APP-1, P42

## STONE &amp; WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 6 OF 19

DATE 2/23/93

JOB NO. 3762

RUN NO. R0170001

\*\*\*  
\*  
NT \*  
\*\*\*\*\*

## PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H4 \*  
\*\*\*\*\*

AL

	MINIMUM CLASS 2 STRESSES (PSI)					(FT)		
	EQ.8 7282.	EQ.9 10768.	EQ.10 662.	EQ.11 7943.		X COORD -31.00	Y COORD 153.83	Z COORD 99.17

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF)	FX	FY	FZ	MOMENTS (FT-LBF)	MX	MY	MZ	DEFLECTIONS (IN)	DX	DY	DZ	ROTATIONS (RAD)	RX	RY	RZ
DWT	1	608.		0.	-9053.	0.		0.	0.	0.	0.02	0.00	0.01	0.000	0.000	0.000	0.000	
OBEI	10	2108.		0.	-3830.	0.		0.	0.	0.	0.15	0.00	1.05	0.001	0.004	0.000	0.000	
OBEA	NOT SPECIFIED																	
SSEI	11	5059.		0.	-9192.	0.		0.	0.	0.	0.35	0.00	2.53	0.002	0.010	0.000	0.000	
NORM	2	615.		0.	11.	0.		0.	0.	0.	-0.92	0.00	1.94	0.001	-0.002	0.000	0.000	
THERANC	3	662.		0.	12.	0.		0.	0.	0.	-0.99	0.00	2.09	0.001	-0.002	0.000	0.000	
OCCMAX	4	3486.		0.	-4370.	0.		0.	0.	0.	0.19	0.00	0.59	-0.001	-0.004	0.000	0.000	
OCCMIN					4073.	0.		0.	0.	0.	-0.19	0.00	-0.44	0.001	0.002	0.000	0.000	
MODFLEX	15	862.		0.	-9053.	0.		0.	0.	0.	-0.91	0.00	1.95	0.001	-0.002	0.000	0.000	
MODFLEX	17	4142.		0.	-13411.	0.		0.	0.	0.	1.10	0.00	3.00	0.002	0.006	0.000	0.000	
MODFLEX	18	5771.		0.	-18245.	0.		0.	0.	0.	1.33	0.00	4.62	0.003	0.012	0.000	0.000	

CASE DESCRIPTION

TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc 1-1 R.1  
Att. 1, p 43

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

## STONE &amp; WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" COMTMT TO TSV

PAGE 7 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 170 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

## PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H5 \*  
\*\*\*\*\*

## GLOBAL

MINIMUM CLASS 2 STRESSES (PSI)

EQ.8 EQ.9 EQ.10 EQ.11  
7621. 11299. 211. 7833.

(FT)  
GLOBAL COORDINATES  
X COORD Y COORD Z COORD  
-68.77 153.83 99.17

LOAD TYPE	CASE	MNS (PSI)	FORCES (LBF)	FX	FY	FZ	MX	MY	MZ	DEFLECTIONS (IN)	ROTATIONS (RAD)				
										DX	DY	DZ	RX	RY	RZ
DWT	1	948.	0.	-12797.	0.	0.	0.	0.	0.	0.02	0.00	0.02	0.000	0.000	0.000
OBEI	10	3677.	0.	-1458.	0.	0.	0.	0.	0.	0.15	0.00	2.30	0.001	0.002	0.000
OBEA	NOT SPECIFIED														
SSEI	11	8826.	0.	-3499.	0.	0.	0.	0.	0.	0.35	0.00	5.51	0.001	0.005	0.000
NORM	2	197.	0.	16.	0.	0.	0.	0.	0.	-2.48	0.00	1.03	0.001	-0.002	0.000
THERANC	3	211.	0.	17.	0.	0.	0.	0.	0.	-2.67	0.00	1.10	0.001	-0.002	0.000
OCCMAX	4	3527.	0.	-474.	0.	0.	0.	0.	0.	0.20	0.00	-1.20	-0.001	0.002	0.000
OCCMIN				413.	0.	0.	0.	0.	0.	-0.20	0.00	0.76	0.001	-0.002	0.000
MODFLEX	15	963.	0.	-12797.	0.	0.	0.	0.	0.	-2.46	0.00	1.04	0.001	-0.002	0.000
MODFLEX	17	3907.	0.	-14240.	0.	0.	0.	0.	0.	2.66	0.00	3.34	0.001	0.005	0.000
MODFLEX	18	8994.	0.	-16297.	0.	0.	0.	0.	0.	3.00	0.00	6.63	0.002	0.007	0.000

## CASE DESCRIPTION

## TITLE

1 DEADWEIGHT  
10 1/2 SSE INERTIA  
11 SSE INERTIA  
2 NORMAL OPERATING  
3 THERMAL EXPAN + ANC MVMTS  
4 TIME HISTORY DYNAMIC FORCE  
15 MODFLEX  
17 MODFLEX  
18 MODFLEX

DEADWEIGHT  
OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
THERMAL ANALYSIS (NORMAL) 551 DEG F  
THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
LC#1 MAX. VALUE (DWT,(DWT+TH NORM))  
LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT)  
LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)

C&c. 1-1 R. 1  
APR. 1, 1994

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 8 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 210 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H6 \*  
\*\*\*\*\*

GLOBAL	MINIMUM CLASS 2 STRESSES (PSI)				GLOBAL COORDINATES (FT)		
	EQ.8 7549.	EQ.9 11646.	EQ.10 810.	EQ.11 8359.	X COORD -106.94	Y COORD 153.83	Z COORD 99.17

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF)	FX	FY	FZ	MOMENTS (FT-LBF)	MX	MY	MZ	DEFLECTIONS (IN)	DX	DY	DZ	ROTATIONS (RAD)	RX	RY	RZ
DWT	1	875.		0.	-12306.	0.		0.	0.	0.	0.02	0.00	0.02	0.000	0.000	0.000	0.000	
OBEI	10	3453.		0.	-1823.	0.		0.	0.	0.	0.15	0.00	1.90	0.000	0.003	0.000		
OBEA NOT SPECIFIED																		
SSEI	11	8286.		0.	-4376.	0.		0.	0.	0.	0.35	0.00	4.56	0.001	0.007	0.000		
NORM	2	753.		0.	-63.	0.		0.	0.	0.	-4.05	0.00	0.14	0.001	-0.002	0.000		
ATHERANC	3	810.		0.	-68.	0.		0.	0.	0.	-4.36	0.00	0.15	0.001	-0.002	0.000		
OCCMAX	4	4097.		0.	429.	0.		0.	0.	0.	-0.21	0.00	-1.04	0.000	0.002	0.000		
OCCMIN				0.	-321.	0.		0.	0.	0.	0.20	0.00	0.72	0.000	-0.002	0.000		
MODFLEX	15	1163.		0.	-12369.	0.		0.	0.	0.	-4.03	0.00	0.16	0.000	-0.002	0.000		
MODFLEX	17	4920.		0.	-14192.	0.		0.	0.	0.	4.24	0.00	2.06	0.001	0.005	0.000		
MODFLEX	18	9175.		0.	-16749.	0.		0.	0.	0.	4.70	0.00	4.74	0.001	0.009	0.000		

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R-1  
APP. 1, p45

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 9 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 240 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1D8-H7 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL FORCES (LBF)			MINIMUM CLASS 2 STRESSES (PSI)			GLOBAL COORDINATES (FT)					
			FX	FY	FZ	EQ.8 7537.	EQ.9 12681.	EQ.10 1508.	EQ.11 9045.	X COORD -144.93	Y COORD 153.83	Z COORD 99.17		
DWT	1	863.	0.	-12440.	0.	0.	0.	0.	0.02	0.00	0.04	0.000	0.000	0.000
OBEI	10	5144.	0.	-2980.	0.	0.	0.	0.	0.15	0.00	0.27	0.000	0.004	0.000
OBEA NOT SPECIFIED														
SSEI	11	12345.	0.	-7152.	0.	0.	0.	0.	0.36	0.00	0.65	0.001	0.009	0.000
NORM	2	1402.	0.	2.	0.	0.	0.	0.	-5.62	0.00	-0.35	0.000	0.000	0.000
THERANC	3	1508.	0.	2.	0.	0.	0.	0.	-6.04	0.00	-0.38	0.000	0.000	0.000
OCCMAX	4	3964.	0.	-624.	0.	0.	0.	0.	-0.21	0.00	0.22	0.000	-0.003	0.000
OCCMIN				601.	0.	0.	0.	0.	0.20	0.00	-0.18	0.000	0.002	0.000
MODFLEX	15	1655.	0.	-12440.	0.	0.	0.	0.	-5.60	0.00	-0.32	0.000	0.000	0.000
MODFLEX	17	6665.	0.	-15418.	0.	0.	0.	0.	5.81	0.00	0.59	0.000	0.004	0.000
MODFLEX	18	13958.	0.	-19593.	0.	0.	0.	0.	6.38	0.00	0.99	0.001	0.009	0.000

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS{X+Y} OR ABS{Y+Z} SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)

Calc. 1-1 R. 1  
APP 1, p 46

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 10 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 250 \*  
\* FUNCTION: SNUBBER \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-S7A \*  
\*\*\*\*\*

GLOBAL

			MINIMUM CLASS 2 STRESSES (PSI)						GLOBAL COORDINATES (FT)		
	EQ.8 6786.	EQ.9 12944.	EQ.10 1623.	EQ.11 8409.		X COORD -151.14	Y COORD 153.83	Z COORD 99.17			

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF) FX	FY	FZ	MOMENTS (FT-LBF) MX	MY	MZ	DEFLECTIONS (IN) DX	DY	DZ	ROTATIONS (RAD) RX	RY	RZ
DWT	1	112.	0.	0.	0.	0.	0.	0.	0.02	0.00	0.04	0.000	0.000	0.000
OBEI	10	6158.	0.	0.	-45159.	0.	0.	0.	0.15	0.02	0.00	0.000	0.004	0.000
OBEA NOT SPECIFIED														
SSEI	11	14780.	0.	0.	-108382.	0.	0.	0.	0.36	0.04	0.00	0.001	0.009	0.001
NORM	2	1508.	0.	0.	0.	0.	0.	0.	-5.87	0.00	-0.37	0.000	0.000	0.000
THERANC	3	1623.	0.	0.	0.	0.	0.	0.	-6.32	0.00	-0.40	0.000	0.000	0.000
OCCMAX	4	4532.	0.	0.	41710.	0.	0.	0.	-0.21	0.00	0.00	0.000	-0.003	0.000
OCCMIN														
MODFLEX	15	1523.	0.	0.	0.	0.	0.	0.	0.20	0.00	0.00	0.000	0.003	0.000
MODFLEX	17	7675.	0.	0.	-45159.	0.	0.	0.	-5.86	0.00	-0.33	0.000	0.000	0.000
MODFLEX	18	16412.	0.	0.	-108382.	0.	0.	0.	6.07	0.02	0.33	0.000	0.004	0.000

CASE DESCRIPTION

TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

SEE NOTE 4 ON PAGE 36, USE LOAD FACTOR OF 2.0

Calc. 1-1 Rev. 1  
App. 1, p47

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 11 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 275 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H9B \*  
\*\*\*\*\*

GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				(FT)			GLOBAL COORDINATES					
	CASE	(PSI) MNS	FORCES (LBF)	FX	FY	FZ	EQ.8 7133.	EQ.9 10047.	EQ.10 1545.	EQ.11 8677.	X COORD -160.33	Y COORD 153.83	Z COORD 110.75		
DWT	1	459.		0.	-8687.	0.	0.	0.	0.	0.02	0.00	0.04	0.000	0.000	0.000
OBEI	10	2741.		0.	-3972.	0.	0.	0.	0.	0.17	0.00	0.38	0.000	0.001	0.000
OBEA NOT SPECIFIED															
SSEI	11	6579.		0.	-9532.	0.	0.	0.	0.	0.41	0.00	0.90	0.001	0.002	0.000
NORM	2	1436.		0.	115.	0.	0.	0.	0.	-6.02	0.00	0.13	0.000	0.002	0.000
THERANC	3	1545.		0.	124.	0.	0.	0.	0.	-6.47	0.00	0.14	0.000	0.002	0.000
OCCMAX	4	2914.		0.	-840.	0.	0.	0.	0.	0.33	0.00	-0.33	0.000	-0.003	0.000
OCCMIN					755.	0.	0.	0.	0.	-0.30	0.00	0.32	0.000	0.003	0.000
MODFLEX	15	1511.		0.	-8687.	0.	0.	0.	0.	-5.99	0.00	0.18	0.000	0.002	0.000
MODFLEX	17	4360.		0.	-12543.	0.	0.	0.	0.	6.32	0.00	0.55	0.000	0.005	0.000
MODFLEX	18	8187.		0.	-18219.	0.	0.	0.	0.	6.86	0.00	1.09	0.001	0.005	0.001

CASE DESCRIPTION

TITLE

- |    |                            |  |
|----|----------------------------|--|
| 1  | DEADWEIGHT                 | DEADWEIGHT   |
| 10 | 1/2 SSE INERTIA            | OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS |
| 11 | SSE INERTIA                | SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS |
| 2  | NORMAL OPERATING           | THERMAL ANALYSIS (NORMAL) 551 DEG F                          |
| 3  | THERMAL EXPAN + ANC MVMTS  | THERMAL ANALYSIS (MAXIMUM) 583 DEG F                         |
| 4  | TIME HISTORY DYNAMIC FORCE | FT = FLUID TRANSIENT DUE TO TURBINE TRIP                     |
| 15 | MODFLEX                    | LC#1 MAX. VALUE (DWT, (DWT+TH NORM))                         |
| 17 | MODFLEX                    | LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))             |
| 18 | MODFLEX                    | LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)                      |

Calc. 1-1 R.1  
APP. I p 48

NUPPIPE-SW ME-110  
VER 06 REV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 12 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 305 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H10 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)			GLOBAL COORDINATES (FT)		
			EQ.8 7065.	EQ.9 12056.	EQ.10 877.	EQ.11 7941.	X COORD -160.33	Y COORD 153.83	Z COORD 141.40		
DWT	1	391.	0.	136.	0.	0.	0.	0.	0.05	0.05	0.04
OBEI	10	1594.	0.	-463.	0.	0.	0.	0.	0.27	0.15	0.38
OBEA	NOT SPECIFIED										
SSEI	11	3825.	0.	-1111.	0.	0.	0.	0.	0.65	0.37	0.91
NORM	2	815.	0.	108.	0.	0.	0.	0.	-5.03	0.04	1.40
THERANC	3	877.	0.	116.	0.	0.	0.	0.	-5.42	0.04	1.50
OCCMAX	4	4991.	0.	-77.	0.	0.	0.	0.	-0.94	-0.03	-0.34
OCCMIN			0.	75.	0.	0.	0.	0.	0.88	0.03	0.33
MODFLEX	15	904.	0.	243.	0.	0.	0.	0.	-4.99	0.08	1.44
MODFLEX	17	5808.	0.	-707.	0.	0.	0.	0.	5.92	0.24	1.82
MODFLEX	18	4779.	0.	-1363.	0.	0.	0.	0.	6.02	0.45	2.46

CASE DESCRIPTION

TITLE

- |                              |  |
|------------------------------|--|
| 1 DEADWEIGHT                 | DEADWEIGHT   |
| 10 1/2 SSE INERTIA           | OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS |
| 11 SSE INERTIA               | SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS |
| 2 NORMAL OPERATING           | THERMAL ANALYSIS (NORMAL) 551 DEG F                          |
| 3 THERMAL EXPAN + ANC MVMTS  | THERMAL ANALYSIS (MAXIMUM) 583 DEG F                         |
| 4 TIME HISTORY DYNAMIC FORCE | FT = FLUID TRANSIENT DUE TO TURBINE TRIP                     |
| 15 MODFLEX                   | LC#1 MAX. VALUE (DWT, (DWT+TH NORM))                         |
| 17 MODFLEX                   | LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))             |
| 18 MODFLEX                   | LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)                      |

Calc. 1-1  
APP. 1, P49

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 13 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 325 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H11 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL FORCES (LBF)			MINIMUM CLASS 2 STRESSES (PSI)			DEFLECTIONS (IN)			ROTATIONS (RAD)			GLOBAL COORDINATES (FT)			
			FX	FY	FZ	EQ.8 7169.	EQ.9 9980.	EQ.10 341.	EQ.11 7510.	DX	DY	DZ	RX	RY	RZ	X COORD -160.33	Y COORD 153.83	Z COORD 165.59
DWT	1	495.	0.	215.	0.	0.	0.	0.	0.	0.07	0.10	0.04	0.000	0.000	0.000			
OBEI	10	1684.	0.	-354.	0.	0.	0.	0.	0.	0.20	0.16	0.38	0.000	0.001	0.000			
OBEA	NOT SPECIFIED																	
SSEI	11	4043.	0.	-849.	0.	0.	0.	0.	0.	0.47	0.39	0.91	0.001	0.002	0.001			
NORM	2	317.	0.	215.	0.	0.	0.	0.	0.	-4.05	0.10	2.39	0.000	0.004	0.000			
THERANC	3	341.	0.	231.	0.	0.	0.	0.	0.	-4.36	0.11	2.58	0.000	0.004	0.000			
OCCMAX	4	2811.	0.	-48.	0.	0.	0.	0.	0.	-0.60	-0.02	-0.34	0.000	0.003	0.000			
OCCMIN				45.	0.	0.	0.	0.	0.	0.51	0.02	0.33	0.000	-0.002	0.000			
MODFLEX	15	598.	0.	430.	0.	0.	0.	0.	0.	-3.99	0.20	2.44	0.000	0.004	-0.001			
MODFLEX	17	3154.	0.	-784.	0.	0.	0.	0.	0.	4.59	0.36	2.82	0.001	0.006	0.001			
MODFLEX	18	4511.	0.	-1295.	0.	0.	0.	0.	0.	4.77	0.60	3.53	0.001	0.006	0.002			

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R. 1  
APP. 1, P50

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 Q3040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 14 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 340 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 108-H12 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)			(FT) GLOBAL COORDINATES					
			FX	FY	FZ	EQ.8 7161.	EQ.9 8587.	EQ.10 107.	EQ.11 7268.	X COORD -160.33	Y COORD 153.83	Z COORD 178.56		
DWT	1	487.	0.	335.	0.	0.	0.	0.	0.08	0.11	0.04	0.000	0.000	0.000
OBEI	10	1190.	0.	-499.	0.	0.	0.	0.	0.06	0.17	0.38	0.000	0.001	0.001
OBEA NOT SPECIFIED														
SSEI	11	2855.	0.	-1197.	0.	0.	0.	0.	0.14	0.40	0.91	0.001	0.002	0.001
NORM	2	99.	0.	416.	0.	0.	0.	0.	-3.49	0.14	2.93	0.000	0.004	0.000
THERANC	3	107.	0.	448.	0.	0.	0.	0.	-3.76	0.15	3.15	0.000	0.004	0.000
OCCMAX	4	1426.	0.	-79.	0.	0.	0.	0.	-0.13	-0.03	-0.34	0.000	0.003	0.000
OCCMIN														
MODFLEX	15	572.	0.	750.	0.	0.	0.	0.	0.12	0.03	0.33	0.000	-0.003	0.000
MODFLEX	17	1593.	0.	-1249.	0.	0.	0.	0.	3.55	0.42	3.35	0.001	0.007	0.001
MODFLEX	18	3067.	0.	-1979.	0.	0.	0.	0.	3.82	0.66	4.10	0.001	0.006	0.002

CASE DESCRIPTION TITLE

- 1 DEADWEIGHT  
10 1/2 SSE INERTIA  
11 SSE INERTIA  
2 NORMAL OPERATING  
3 THERMAL EXPAN + ANC MVMTS  
4 TIME HISTORY DYNAMIC FORCE  
15 MODFLEX  
17 MODFLEX  
18 MODFLEX
- DEADWEIGHT  
OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
THERMAL ANALYSIS (NORMAL) 551 DEG F  
THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
LC#1 MAX. VALUE (DWT, (DWT+TH NORM))  
LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))  
LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R.  
All 1, P51

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 15 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 370 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H13 \*  
\*\*\*\*\*

GLOBAL	MINIMUM CLASS 2 STRESSES (PSI)				(FT) GLOBAL COORDINATES		
	EQ.8 6752.	EQ.9 9198.	EQ.10 651.	EQ.11 7402.	X COORD -140.31	Y COORD 153.83	Z COORD 183.00

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF) FX	FY	FZ	MOMENTS (FT-LBF) MX	MY	MZ	DEFLECTIONS (IN) DX	DY	DZ	ROTATIONS (RAD) RX	RY	RZ
DWT	1	78.	0.	60.	0.	0.	0.	0.	0.08	0.02	0.03	0.000	0.000	0.000
OBEI	10	2447.	0.	-67.	0.	0.	0.	0.	0.00	0.03	0.07	0.000	0.001	0.000
OBEA	NOT SPECIFIED													
SSEI	11	5872.	0.	-160.	0.	0.	0.	0.	0.00	0.07	0.16	0.000	0.002	0.001
NORM	2	605.	0.	137.	0.	0.	0.	0.	-2.47	0.06	2.26	0.000	0.003	0.000
THERANC	3	651.	0.	148.	0.	0.	0.	0.	-2.66	0.06	2.43	0.000	0.004	-0.001
OCCMAX	4	1961.	0.	12.	0.	0.	0.	0.	0.00	0.00	0.06	0.000	0.001	0.000
OCCMIN			0.	-11.	0.	0.	0.	0.	0.00	0.00	-0.04	0.000	-0.001	0.000
MODFLEX	15	604.	0.	197.	0.	0.	0.	0.	-2.39	0.08	2.29	0.000	0.004	-0.001
MODFLEX	17	3009.	0.	-263.	0.	0.	0.	0.	2.40	0.11	2.36	0.000	0.005	0.001
MODFLEX	18	6471.	0.	-367.	0.	0.	0.	0.	2.58	0.15	2.62	0.000	0.006	0.002

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R. 1  
App. 1, p52

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 16 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\*\*\*\*\*  
\* POINT NO. 390 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* MSU-4 INLET \*  
\*\*\*\*\*

GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				(FT)			GLOBAL COORDINATES			
	CASE	(PSI)	FORCES (LBF)	FX	FY	FZ	EQ.8 7247.	EQ.9 13371.	EQ.10 1720.	EQ.11 8966.	X COORD -131.70	Y COORD 153.83	Z COORD 183.00
DWT	1	275.		0.	809.	0.	3412.	0.	0.	0.08	0.00	0.02	
OBEI	10	216.		0.	-3488.	0.	-9356.	0.	0.	0.00	0.00	0.00	
OBEA NOT SPECIFIED													
SSEI	11	519.		0.	-8372.	0.	-22454.	0.	0.	0.00	0.00	0.00	
NORM	2	600.		0.	-2523.	0.	3766.	0.	0.	-2.12	0.00	1.91	
THERANC	3	646.		0.	-2714.	0.	4053.	0.	0.	-2.28	0.00	2.05	
OCCMAX	4	119.		0.	658.	0.	2702.	0.	0.	0.00	0.00	0.00	
OCCMIN													
MODFLEX	15	502.		0.	-1714.	0.	7178.	0.	0.	-2.04	0.00	1.93	
MODFLEX	17	623.		0.	-5202.	0.	-16534.	0.	0.	2.04	0.00	1.93	
MODFLEX	18	996.		0.	-10277.	0.	-29918.	0.	0.	2.20	0.00	2.08	

CASE DESCRIPTION TITLE

- |    |                            |  |
|----|----------------------------|--|
| 1  | DEADWEIGHT                 | DEADWEIGHT   |
| 10 | 1/2 SSE INERTIA            | OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS |
| 11 | SSE INERTIA                | SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS |
| 2  | NORMAL OPERATING           | THERMAL ANALYSIS (NORMAL) 551 DEG F                          |
| 3  | THERMAL EXPAN + ANC MVMTS  | THERMAL ANALYSIS (MAXIMUM) 583 DEG F                         |
| 4  | TIME HISTORY DYNAMIC FORCE | FT = FLUID TRANSIENT DUE TO TURBINE TRIP                     |
| 15 | MODFLEX                    | LC#1 MAX. VALUE (DWT,(DWT+TH NORM))                          |
| 17 | MODFLEX                    | LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT)              |
| 18 | MODFLEX                    | LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)                       |

Calc. 1-1 R. 1  
APP. 1, PS3

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 17 OF 19  
DATE 2/23/93  
JOB NO. 3762  
RUN NO. R0170001

\* POINT NO. 390 \*  
\* FUNCTION: SNUBBER \*

PIPE SUPPORT SUMMARY

\* SUPPORT MARK NO. \*  
\* MSV-4 (INLET) \*

GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				(FT) GLOBAL COORDINATES						
	CASE	(PSI) MNS	FORCES (LBF)	FX	FY	FZ	EQ.8 7247.	EQ.9 13371.	EQ.10 1720.	EQ.11 8966.	X COORD -131.70	Y COORD 153.83	Z COORD 183.00
DWT	1	275.	0.	0.	0.	0.							
OBEI	10	216.	-7070.	0.	-8904.	0.	-160197.		-59496.	0.08	0.00	0.02	0.000
OBEA	NOT SPECIFIED												
SSEI	11	519.	-16967.	0.	-21369.	0.	-384472.	-142791.		0.00	0.00	0.00	0.000
NORM	2	600.	0.	0.	0.	0.	0.	0.	0.	-2.12	0.00	1.91	0.000
THERANC	3	646.	0.	0.	0.	0.	0.	0.	0.	-2.28	0.00	2.05	0.000
OCCMAX	4	119.	21099.	0.	9056.	0.	145276.	-10567.	0.00	0.00	0.00	0.000	0.000
OCCMIN			-15658.	0.	-6323.	0.	-101216.	9890.	0.00	0.00	0.00	0.000	0.000
MODFLEX	15	502.	0.	0.	0.	0.	0.	0.	0.	-2.04	0.00	1.93	0.000
MODFLEX	17	623.	-21099.	0.	-9056.	0.	-160197.	-59496.	2.04	0.00	1.93	0.000	0.004
MODFLEX	18	996.	-16967.	0.	-21369.	0.	-384472.	-142791.	2.20	0.00	2.08	0.000	0.004

CASE DESCRIPTION TITLE

- 1 DEADWEIGHT  
 10 1/2 SSE INERTIA  
 11 SSE INERTIA  
 2 NORMAL OPERATING  
 3 THERMAL EXPAN + ANC MVMTS  
 4 TIME HISTORY DYNAMIC FORCE  
 15 MODFLEX  
 17 MODFLEX  
 18 MODFLEX
- DEADWEIGHT  
 OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
 SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
 THERMAL ANALYSIS (NORMAL) 551 DEG F  
 THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
 FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
 LC#1 MAX. VALUE (DWT, (DWT+TH NORM))  
 LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))  
 LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc - 1-1 r. 1  
APP-1 p54

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 1 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 5 \*  
\* FUNCTION: ANCHOR \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* FLUED HEAD PEN N-7D \*  
\*\*\*\*\*

GLOBAL	MINIMUM CLASS 2 STRESSES (PSI)				(FT)			GLOBAL COORDINATES		
	EQ.8 10033.	EQ.9 19268.	EQ.10 1513.	EQ.11 11546.	X COORD -11.00	Y COORD 138.15	Z COORD 45.00			

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF) FX	FY	FZ	MOMENTS (FT-LBF) MX	MY	MZ	DEFLECTIONS (IN) DX	DY	DZ	ROTATIONS (RAD) RX	RY	RZ
DWT	1	3359.	14.	-19374.	-11.	99833.	190.	-1491.	0.00	0.00	0.00	0.000	0.000	0.000
OBEI	10	6112.	-10042.	-13731.	-13144.	-122936.	-82962.	-104916.	0.00	0.00	0.00	0.000	0.000	0.000
OBEA NOT SPECIFIED														
SSEI	11	14668.	-24102.	-32953.	-31547.	-295047.	-199110.	-251797.	0.00	0.00	0.00	0.000	0.000	0.000
NORM	2	1407.	860.	-1507.	-737.	28938.	6930.	-9885.	0.00	0.00	0.00	0.000	0.000	0.000
THERANC	3	1513.	926.	-1622.	-792.	31136.	7457.	-10636.	0.00	0.00	0.00	0.000	0.000	0.000
OCCMAX	4	9235.	13806.	14991.	23713.	221335.	123683.	-159087.	0.00	0.00	0.00	0.000	0.000	0.000
OCCMIN														
MODFLEX	15	4356.	875.	-20881.	-747.	-169844.	-113924.	149699.	0.00	0.00	0.00	0.000	0.000	0.000
MODFLEX	17	12845.	-14681.	-35872.	-24460.	-350106.	-130803.	-170463.	0.00	0.00	0.00	0.000	0.000	0.000
MODFLEX	18	18239.	-25042.	-53949.	-32350.	-426016.	-206756.	-263924.	0.00	0.00	0.00	0.001	0.000	0.000

CASE DESCRIPTION

TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1 - 1 R. 1  
APP. 1 P55

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

## STONE &amp; WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 2 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 75 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

## PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H1 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	MINIMUM CLASS 2 STRESSES (PSI)			EQ.8 6793.	EQ.9 10950.	EQ.10 453.	EQ.11 7246.	GLOBAL COORDINATES (FT)								
			FX	FY	FZ					MX	MY	MZ	DX	DY	DZ	RX	RY	RZ
DWT	1	119.	0.	-80.	0.	0.	0.	0.	0.	0.01	-0.05	0.06	0.000	0.000	0.000	0.000	0.000	0.000
OBEI	10	2133.	0.	-197.	0.	0.	0.	0.	0.	0.34	0.13	0.32	0.001	0.001	0.001	0.001	0.001	0.001
QBEA NOT SPECIFIED																		
SSEI	11	5120.	0.	-472.	0.	0.	0.	0.	0.	0.81	0.31	0.76	0.002	0.002	0.003			
NORM	2	421.	0.	838.	0.	0.	0.	0.	0.	0.03	0.56	0.77	0.001	0.000	0.000			
THERANC	3	453.	0.	901.	0.	0.	0.	0.	0.	0.04	0.60	0.83	0.001	0.000	0.000			
OCCMAX	4	4157.	0.	-441.	0.	0.	0.	0.	0.	0.58	-0.29	0.79	0.001	0.000	-0.002			
OCCMIN																		
MODFLEX	15	524.	0.	757.	0.	0.	0.	0.	0.	0.04	0.50	0.83	0.001	0.000	0.000			
MODFLEX	17	4671.	0.	-1199.	0.	0.	0.	0.	0.	0.62	0.80	1.61	0.003	0.001	0.002			
MODFLEX	18	5630.	0.	-1294.	0.	0.	0.	0.	0.	0.85	0.86	1.65	0.003	0.002	0.003			

CASE DESCRIPTION TITLE

1 DEADWEIGHT  
10 1/2 SSE INERTIA  
11 SSE INERTIA  
2 NORMAL OPERATING  
3 THERMAL EXPAN + ANC MVMTS  
4 TIME HISTORY DYNAMIC FORCE  
15 MODFLEX  
17 MODFLEX  
18 MODFLEX

DEADWEIGHT  
OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
THERMAL ANALYSIS (NORMAL) 551 DEG F  
THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
LC#1 MAX. VALUE (DWT, (DWT+TH NORM))  
LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))  
LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 Rev 1  
AP 1/1993

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 3 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\* POINT NO. 100 \*  
\* FUNCTION: RESTRAINT \*

PIPE SUPPORT SUMMARY

\* SUPPORT MARK NO. \*  
\* 1DB-H2 \*

GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				(FT) GLOBAL COORDINATES					
	CASE	(PSI) MNS	EQ.8 6728.	EQ.9 11850.	EQ.10 850.	EQ.11 7578.	X COORD -11.00	Y COORD 153.83	Z COORD 91.39			
LOAD TYPE	CASE	(PSI) MNS	FX	FORCES (LBF) FY	FZ	MX MY MZ	DEFLECTIONS (IN) DX DY DZ	ROTATIONS (RAD) RX RY RZ				
DWT	1	55.	0.	-82.	0.	0. 0. 0.	0.01 -0.04 0.11	-0.04 0.11 0.32	0.06 0.76 0.32	0.000 0.002 0.001	0.000 0.003 0.001	0.000 0.001 0.001
OBEI	10	3910.	0.	-234.	0.	0. 0. 0.	0.04 0.11 0.32	0.04 0.11 0.32	0.001 0.001 0.001	0.001 0.001 0.001	0.000 0.000 0.000	
OBEA NOT SPECIFIED												
SSEI	11	9384.	0.	-563.	0.	0. 0. 0.	0.08 -0.04 0.04	0.26 0.11 0.11	0.76 2.01 2.17	0.002 0.001 0.001	0.003 0.000 -0.001	0.001 0.000 0.000
NORM	2	790.	0.	246.	0.	0. 0. 0.	0. -0.04 0.04	0.11 0.12 0.14	2.01 2.17 0.79	0.001 0.001 -0.001	0.000 0.000 0.000	0.000 0.000 0.000
THERANC	3	850.	0.	265.	0.	0. 0. 0.	0. -0.04 0.08	0.12 0.19 -0.19	2.17 0.79 0.79	0.001 0.001 -0.001	-0.001 0.003 -0.001	0.000 0.000 0.000
OCCMAX	4	5122.	0.	-407.	0.	0. 0. 0.	0. -0.06 0.08	0.14 0.08 -0.19	0.001 0.001 0.001	0.003 0.003 0.003	0.000 0.000 0.000	0.000 0.000 0.000
OCCMIN												
MODFLEX	15	804.	0.	165.	0.	0. 0. 0.	0. -0.02 0.10	0.08 0.08 0.26	2.07 2.07 2.86	0.001 0.001 0.002	0.000 0.000 0.004	0.000 0.000 0.001
MODFLEX	17	5925.	0.	-572.	0.	0. 0. 0.	0. 0.10 0.11	0.14 0.26 0.35	0.57 2.86 2.99	0.001 0.002 0.003	0.000 0.002 0.004	0.000 0.000 0.002
MODFLEX	18	10245.	0.	-746.	0.	0. 0. 0.	0. 0.11 0.11	0.14 0.26 0.35	0.57 2.86 2.99	0.001 0.002 0.003	0.000 0.002 0.004	0.000 0.000 0.002

CASE DESCRIPTION TITLE

- 1 DEADWEIGHT
- 10 1/2 SSE INERTIA OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
- 11 SSE INERTIA SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
- 2 NORMAL OPERATING THERMAL ANALYSIS (NORMAL) 551 DEG F
- 3 THERMAL EXPAN + ANC MVMTS THERMAL ANALYSIS (MAXIMUM) 583 DEG F
- 4 TIME HISTORY DYNAMIC FORCE FT = FLUID TRANSIENT DUE TO TURBINE TRIP
- 15 MODFLEX LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
- 17 MODFLEX LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
- 18 MODFLEX LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R-1  
Att. 1, P57

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 ~~03040-NP(C)-PM-786~~ (RERATE) MS "D" CONTMT TO TSV

PAGE 4 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 105 \*  
\* FUNCTION: SNUBBER \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-S2A \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL FORCES (LBF)			MINIMUM CLASS 2 STRESSES (PSI)			GLOBAL COORDINATES (FT)					
			FX	FY	FZ	EQ.8 6771.	EQ.9 12030.	EQ.10 894.	EQ.11 7666.	X COORD -11.00	Y COORD 153.83	Z COORD 93.33		
DWT	1	98.	0.	0.	0.	0.	0.	0.	0.01	-0.03	0.06	0.000	0.000	0.000
OBEI	10	4283.	-46797.	0.	0.	0.	0.	0.	0.00	0.09	0.32	0.001	0.002	0.001
OBEA	NOT SPECIFIED													
SSEI	11	10279.	-112312.	0.	0.	0.	0.	0.	0.00	0.21	0.76	0.002	0.004	0.001
NORM	2	831.	0.	0.	0.	0.	0.	0.	-0.05	0.08	2.09	0.001	-0.001	0.000
THERANC	3	894.	0.	0.	0.	0.	0.	0.	-0.05	0.09	2.25	0.001	-0.001	0.000
OCCMAX	4	5259.	-61204.	0.	0.	0.	0.	0.	0.00	-0.15	0.79	-0.002	-0.003	-0.001
OCCMIN	39393.													
MODFLEX	15	858.	0.	0.	0.	0.	0.	0.	-0.04	0.05	2.15	0.001	-0.001	0.000
MODFLEX	17	6115.	-61204.	0.	0.	0.	0.	0.	0.04	0.21	2.94	0.002	0.004	0.001
MODFLEX	18	11186.	-112312.	0.	0.	0.	0.	0.	0.04	0.27	3.07	0.003	0.004	0.001

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	Thermal Analysis (Normal) 551 DEG F
3	Thermal Expan + ANC MVMTS	Thermal Analysis (Maximum) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R. 1  
APP. 1, P58

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 5 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 125 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-M3 \*  
\*\*\*\*\*

GLOBAL

MINIMUM CLASS 2 STRESSES (PSI)  
EQ.8 EQ.9 EQ.10 EQ.11  
6991. 9864. 904. 7895.

(FT)  
GLOBAL COORDINATES  
X COORD Y COORD Z COORD  
-17.65 153.83 99.17

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF)			MOMENTS (FT-LBF)			DEFLECTIONS (IN)			ROTATIONS (RAD)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ	RX	RY	RZ
DWT	1	317.	0.	-4924.	0.	0.	0.	0.	0.01	0.00	0.06	0.000	0.000	0.000
OBEI	10	2029.	0.	-11665.	0.	0.	0.	0.	0.15	0.00	0.53	0.001	0.004	0.000
OBEA	NOT SPECIFIED													
SSEI	11	4870.	0.	-27997.	0.	0.	0.	0.	0.35	0.00	1.27	0.003	0.009	0.000
NORM	2	840.	0.	358.	0.	0.	0.	0.	-0.37	0.00	2.23	0.001	-0.002	0.000
THERANC	3	904.	0.	385.	0.	0.	0.	0.	-0.40	0.00	2.40	0.001	-0.002	0.000
OCCMAX	4	2872.	0.	-15083.	0.	0.	0.	0.	-0.28	0.00	0.59	-0.001	-0.004	0.000
OCCMIN				10842.	0.	0.	0.	0.	0.20	0.00	-0.46	0.001	0.003	0.000
MODFLEX	15	907.	0.	-4924.	0.	0.	0.	0.	-0.36	0.00	2.29	0.001	-0.002	0.000
MODFLEX	17	3771.	0.	-19649.	0.	0.	0.	0.	0.64	0.00	2.87	0.002	0.006	0.000
MODFLEX	18	5812.	0.	-32921.	0.	0.	0.	0.	0.74	0.00	3.72	0.003	0.011	0.000

CASE DESCRIPTION

TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R. 1  
APP. 1, P59

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 6 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 140 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H4 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	MINIMUM CLASS 2 STRESSES (PSI)			EQ.8 7278.	EQ.9 10444.	EQ.10 662.	EQ.11 7940.	GLOBAL COORDINATES (FT)		
			FX	FY	FZ					MX	MY	MZ
										DEFLECTIONS (IN)	ROTATIONS (RAD)	
										DX	DY	DZ
										RX	RY	RZ
DWT	1	605.	0.	-8931.	0.	0.	0.	0.	0.	0.01	0.00	0.06
OBEI	10	2166.	0.	-4542.	0.	0.	0.	0.	0.	0.15	0.00	1.13
OBEA	NOT SPECIFIED											
SSEI	11	5197.	0.	-10900.	0.	0.	0.	0.	0.	0.35	0.00	2.71
NORM	2	615.	0.	65.	0.	0.	0.	0.	0.	-0.92	0.00	1.96
THERANC	3	662.	0.	70.	0.	0.	0.	0.	0.	-0.99	0.00	2.11
OCCMAX	4	3166.	0.	6474.	0.	0.	0.	0.	0.	-0.28	0.00	0.60
OCCMIN												
MODFLEX	15	860.	0.	-8931.	0.	0.	0.	0.	0.	0.21	0.00	-0.48
MODFLEX	17	3842.	0.	-15339.	0.	0.	0.	0.	0.	1.19	0.00	3.15
MODFLEX	18	5919.	0.	-19831.	0.	0.	0.	0.	0.	1.33	0.00	4.88

CASE DESCRIPTION

TITLE

- |    |                            |  |
|----|----------------------------|--|
| 1  | DEADWEIGHT                 | DEADWEIGHT   |
| 10 | 1/2 SSE INERTIA            | OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS |
| 11 | SSE INERTIA                | SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS |
| 2  | NORMAL OPERATING           | THERMAL ANALYSIS (NORMAL) 551 DEG F                          |
| 3  | THERMAL EXPAN + ANC MVMTS  | THERMAL ANALYSIS (MAXIMUM) 583 DEG F                         |
| 4  | TIME HISTORY DYNAMIC FORCE | FT = FLUID TRANSIENT DUE TO TURBINE TRIP                     |
| 15 | MODFLEX                    | LC#1 MAX. VALUE (DWT, (DWT+TH NORM))                         |
| 17 | MODFLEX                    | LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))             |
| 18 | MODFLEX                    | LC#3 ABS.SUM(DWT OR (DWT+TH MAX)), SSEI)                     |

Calc. 1 - 1 R. 1  
App. 1, P60

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 7 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 170 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H5 \*  
\*\*\*\*\*

GLOBAL

MINIMUM CLASS 2 STRESSES (PSI)

(FT)  
GLOBAL COORDINATES  
X COORD Y COORD Z COORD  
-68.77 153.83 99.17

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF)	FX	FY	FZ	MX	MY	MZ	DEFLECTIONS (IN)	ROTATIONS (RAD)				
										DX	DY	DZ	RX	RY	RZ
DWT	1	950.		0.	-12810.	0.	0.	0.	0.	0.01	0.00	0.05	0.000	0.000	0.000
OBEI	10	3730.		0.	-1531.	0.	0.	0.	0.	0.15	0.00	2.35	0.001	0.002	0.000
OBEA	NOT SPECIFIED														
SSEI	11	8952.		0.	-3674.	0.	0.	0.	0.	0.36	0.00	5.65	0.002	0.005	0.000
NORM	2	189.		0.	10.	0.	0.	0.	0.	-2.48	0.00	1.04	0.001	-0.002	0.000
THERANC	3	204.		0.	11.	0.	0.	0.	0.	-2.67	0.00	1.12	0.001	-0.002	0.000
OCCMAX	4	4327.		0.	737.	0.	0.	0.	0.	-0.29	0.00	-1.19	-0.001	0.002	0.000
OCCMIN				0.	-695.	0.	0.	0.	0.	0.21	0.00	0.94	0.001	-0.002	0.000
MODFLEX	15	961.		0.	-12810.	0.	0.	0.	0.	-2.47	0.00	1.09	0.001	-0.002	0.000
MODFLEX	17	4506.		0.	-14330.	0.	0.	0.	0.	2.75	0.00	3.45	0.002	0.004	0.000
MODFLEX	18	9120.		0.	-16483.	0.	0.	0.	0.	3.01	0.00	6.82	0.002	0.007	0.000

CASE DESCRIPTION

TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT,(DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT)
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)

Calc. 1-1 R-1  
APP. 1, p61

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 8 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 210 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H6 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL FORCES (LBF)			MINIMUM CLASS 2 STRESSES (PSI)			GLOBAL COORDINATES (FT)					
			FX	FY	FZ	EQ.8 7547.	EQ.9 11880.	EQ.10 810.	EQ.11 8356.	X COORD -106.94	Y COORD 153.83	Z COORD 99.17		
DWT	1	873.	0.	-12285.	0.	0.	0.	0.	0.01	0.00	0.05	0.000	0.000	0.000
OBEI	10	3434.	0.	-1873.	0.	0.	0.	0.	0.15	0.00	1.94	0.001	0.003	0.000
OBEA NOT SPECIFIED														
SSEI	11	8241.	0.	-4494.	0.	0.	0.	0.	0.36	0.00	4.66	0.001	0.007	0.000
NORM	2	753.	0.	-54.	0.	0.	0.	0.	-4.05	0.00	0.15	0.001	-0.002	0.000
THERANC	3	810.	0.	-58.	0.	0.	0.	0.	-4.36	0.00	0.16	0.001	-0.002	0.000
OCCMAX	4	4334.	0.	-961.	0.	0.	0.	0.	-0.29	0.00	-1.06	-0.001	-0.002	0.000
OCCMIN				829.	0.	0.	0.	0.	0.21	0.00	1.01	0.001	0.002	0.000
MODFLEX	15	1159.	0.	-12339.	0.	0.	0.	0.	-4.04	0.00	0.20	0.000	-0.002	0.000
MODFLEX	17	5157.	0.	-14211.	0.	0.	0.	0.	4.33	0.00	2.14	0.001	0.005	0.000
MODFLEX	18	9135.	0.	-16837.	0.	0.	0.	0.	4.71	0.00	4.87	0.002	0.009	0.000

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT,(DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)

Cals. 1-1 R.  
APP. 1, P62

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 9 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 240 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H7 \*  
\*\*\*\*\*

GLOBAL

MINIMUM CLASS 2 STRESSES (PSI)

EQ.8 EQ.9 EQ.10 EQ.11  
7548. 12457. 1510. 9059.

(FT)  
GLOBAL COORDINATES  
X COORD Y COORD Z COORD  
-144.93 153.83 99.17

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF) FX	FY	FZ	MOMENTS (FT-LBF) MX	MY	MZ	DEFLECTIONS (IN) DX	DY	DZ	ROTATIONS (RAD) RX	RY	RZ
DWT	1	875.	0.	-12492.	0.	0.	0.	0.	0.01	0.00	0.05	0.000	0.000	0.000
OBEI	10	4909.	0.	-2988.	0.	0.	0.	0.	0.15	0.00	0.27	0.000	0.004	0.000
OBEA NOT SPECIFIED														
SSEI	11	11781.	0.	-7172.	0.	0.	0.	0.	0.36	0.00	0.66	0.001	0.009	0.000
NORM	2	1404.	0.	-20.	0.	0.	0.	0.	-5.52	0.00	-0.35	0.000	0.000	0.000
THERANC	3	1510.	0.	-22.	0.	0.	0.	0.	-6.05	0.00	-0.37	0.000	0.000	0.000
OCCMAX	4	3955.	0.	-1141.	0.	0.	0.	0.	-0.30	0.00	0.24	0.000	-0.003	0.000
OCCMIN														
MODFLEX	15	1667.	0.	-12512.	0.	0.	0.	0.	0.21	0.00	-0.21	0.000	0.003	0.000
MODFLEX	17	6447.	0.	-15500.	0.	0.	0.	0.	-5.60	0.00	-0.30	0.000	0.000	0.000
MODFLEX	18	13410.	0.	-19686.	0.	0.	0.	0.	5.90	0.00	0.57	0.000	0.004	0.000
									6.39	0.00	0.98	0.001	0.009	0.000

CASE DESCRIPTION

TITLE

- 1 DEADWEIGHT  
 10 1/2 SSE INERTIA  
 11 SSE INERTIA  
 2 NORMAL OPERATING  
 3 THERMAL EXPAN + ANC MVMTS  
 4 TIME HISTORY DYNAMIC FORCE  
 15 MODFLEX  
 17 MODFLEX  
 18 MODFLEX
- DEADWEIGHT  
 OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
 SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
 THERMAL ANALYSIS (NORMAL) 551 DEG F  
 THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
 FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
 LC#1 MAX. VALUE (DWT,(DWT+TH NORM))  
 LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))  
 LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)

Calc. 1-1 K-1  
APP. 1, P63

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 10 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 250 \*  
\* FUNCTION: SNUBBER \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-S7A \*  
\*\*\*\*\*

GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				(FT) GLOBAL COORDINATES			
	CASE	(PSI) MNS	FORCES (LBF)	EQ.8 6797.	EQ.9 12663.	EQ.10 1626.	EQ.11 8423.	X COORD -151.14	Y COORD 153.83	Z COORD 99.17
DWT	1	123.	0.	0.	0.	0.	0.	0.01	-0.01	0.05
OBEI	10	5866.	0.	0.	-42514.	0.	0.	0.15	0.02	0.00
OBEA	NOT SPECIFIED									
SSEI	11	14079.	0.	0.	-102034.	0.	0.	0.36	0.04	0.00
NORM	2	1511.	0.	0.	0.	0.	0.	-5.87	0.00	-0.37
TERHANC	3	1626.	0.	0.	0.	0.	0.	-6.32	0.00	-0.39
OCCMAX	4	4586.	0.	0.	41265.	0.	0.	-0.30	0.01	0.00
OCCMIN			0.	0.	-34971.	0.	0.	0.21	0.00	0.00
MODFLEX	15	1533.	0.	0.	0.	0.	0.	-5.86	-0.01	-0.31
MODFLEX	17	7395.	0.	0.	-42514.	0.	0.	6.16	0.02	0.32
MODFLEX	18	15723.	0.	0.	-102034.	0.	0.	6.67	0.05	0.34

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

SEE NOTE 4 IN PAGE 36, USE LOAD FACTOR OF 2.0

Calc. 1-1 R. 1  
APP. 1, p64

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 11 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 275 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H9B \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL FORCES (LBF)			MINIMUM CLASS 2 STRESSES (PSI)			GLOBAL COORDINATES (FT)					
			FX	FY	FZ	EQ.8 7141.	EQ.9 9974.	EQ.10 1548.	EQ.11 8689.	X COORD -160.33	Y COORD 153.83	Z COORD 110.75		
DWT	1	468.	0.	-8657.	0.	0.	0.	0.	0.02	0.00	0.05	0.000	0.000	0.000
OBEI	10	2686.	0.	-3960.	0.	0.	0.	0.	0.18	0.00	0.38	0.000	0.001	0.000
OBEA NOT SPECIFIED														
SSEI	11	6446.	0.	-9503.	0.	0.	0.	0.	0.44	0.00	0.91	0.001	0.002	0.000
NORM	2	1439.	0.	128.	0.	0.	0.	0.	-6.02	0.00	0.14	0.000	0.002	0.000
THERANC	3	1548.	0.	138.	0.	0.	0.	0.	-6.47	0.00	0.15	0.000	0.002	0.000
OCCMAX	4	2833.	0.	1110.	0.	0.	0.	0.	0.43	0.00	-0.34	0.000	0.004	0.000
OCCMIN														
MODFLEX	15	1525.	0.	-8657.	0.	0.	0.	0.	-6.00	0.00	0.19	0.000	0.002	0.000
MODFLEX	17	4293.	0.	-12489.	0.	0.	0.	0.	6.43	0.00	0.57	0.000	0.006	0.000
MODFLEX	18	8068.	0.	-18160.	0.	0.	0.	0.	6.90	0.00	1.11	0.001	0.004	0.001

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R.1  
Ann. 1 p65

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C) PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 12 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\* POINT NO. 305 \*  
\* FUNCTION: RESTRAINT \*

PIPE SUPPORT SUMMARY

\* SUPPORT MARK NO. \*  
\* 1DB-H10 \*

LOAD TYPE	CASE	(PSI) MNS	MINIMUM CLASS 2 STRESSES (PSI)			DEFLECTIONS (IN)			ROTATIONS (RAD)		
			EQ.8 7068.	EQ.9 13235.	EQ.10 879.	EQ.11 7948.	DX	DY	DZ	RX	RY
DWT	1	395.	0.	138.	0.	0.	0.04	0.05	0.05	0.000	0.000
OBEI	10	1595.	0.	-455.	0.	0.	0.31	0.15	0.38	0.000	0.001
OBEA	NOT SPECIFIED										
SSEI	11	3828.	0.	-1092.	0.	0.	0.74	0.36	0.91	0.001	0.002
NORM	2	817.	0.	108.	0.	0.	-5.04	0.04	1.40	0.000	0.003
THERANC	3	879.	0.	117.	0.	0.	-5.42	0.04	1.51	0.000	0.003
OCCMAX	4	6167.	0.	83.	0.	0.	-1.22	0.03	-0.34	0.000	0.001
OCCMIN			0.	-73.	0.	0.	0.	1.21	-0.02	0.33	0.000
MODFLEX	15	914.	0.	246.	0.	0.	0.	-4.99	0.08	1.46	0.000
MODFLEX	17	6992.	0.	-701.	0.	0.	0.	6.22	0.23	1.84	0.001
MODFLEX	18	4792.	0.	-1346.	0.	0.	0.	6.11	0.45	2.47	0.001

CASE DESCRIPTION

TITLE

- 1 DEADWEIGHT
- 10 1/2 SSE INERTIA
- 11 SSE INERTIA
- 2 NORMAL OPERATING
- 3 THERMAL EXPAN + ANC MVMTS
- 4 TIME HISTORY DYNAMIC FORCE
- 15 MODFLEX
- 17 MODFLEX
- 18 MODFLEX
- DEADWEIGHT
- OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
- SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
- Thermal Analysis (Normal) 551 DEG F
- Thermal Analysis (Maximum) 583 DEG F
- FT = Fluid Transient Due to Turbine Trip
- LC#1 Max. Value (DWT, (DWT+TH NORM))
- LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
- LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R-1  
APL-1 P66

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 13 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 325 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H11 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				(FT) GLOBAL COORDINATES		
			FX	FY	FZ	EQ.8 7170.	EQ.9 9956.	EQ.10 343.	EQ.11 7513.	X COORD -160.33	Y COORD 153.83	Z COORD 165.59
DWT	1	496.	0.	216.	0.	0.	0.	0.	0.06	0.10	0.05	0.000
OBEI	10	1628.	0.	-308.	0.	0.	0.	0.	0.19	0.14	0.38	0.000
OBEA NOT SPECIFIED												
SSEI	11	3907.	0.	-740.	0.	0.	0.	0.	0.47	0.34	0.91	0.001
NORM	2	319.	0.	215.	0.	0.	0.	0.	-4.05	0.10	2.40	0.000
THERANC	3	343.	0.	231.	0.	0.	0.	0.	-4.36	0.11	2.58	0.000
OCCMAX	4	2786.	0.	42.	0.	0.	0.	0.	-0.72	0.02	-0.34	0.000
OCCMIN												
MODFLEX	15	603.	0.	431.	0.	0.	0.	0.	-3.99	0.20	2.45	0.000
MODFLEX	17	3145.	0.	-739.	0.	0.	0.	0.	4.71	0.34	2.83	0.001
MODFLEX	18	4383.	0.	-1187.	0.	0.	0.	0.	4.77	0.55	3.55	0.001
												0.006
												0.002

CASE DESCRIPTION TITLE

- |    |                            |  |
|----|----------------------------|--|
| 1  | DEADWEIGHT                 | DEADWEIGHT   |
| 10 | 1/2 SSE INERTIA            | OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS |
| 11 | SSE INERTIA                | SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS |
| 2  | NORMAL OPERATING           | THERMAL ANALYSIS (NORMAL) 551 DEG F                          |
| 3  | THERMAL EXPAN + ANC MVMTS  | THERMAL ANALYSIS (MAXIMUM) 583 DEG F                         |
| 4  | TIME HISTORY DYNAMIC FORCE | FT = FLUID TRANSIENT DUE TO TURBINE TRIP                     |
| 15 | MODFLEX                    | LC#1 MAX. VALUE (DWT, (DWT+TH NORM))                         |
| 17 | MODFLEX                    | LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))             |
| 18 | MODFLEX                    | LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)                       |

Calc. 1-1 R-1  
AP-1, p67

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

## STONE &amp; WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 14 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\* POINT NO. 340 \*  
\* FUNCTION: RESTRAINT \*

## PIPE SUPPORT SUMMARY

\* SUPPORT MARK NO. \*  
\* 1DB-H12 \*

LOAD TYPE	CASE	(PSI) MNS	MINIMUM CLASS 2 STRESSES (PSI)			(FT) GLOBAL COORDINATES					
			EQ.8 7161.	EQ.9 9437.	EQ.10 108.	EQ.11 7268.	X COORD -160.33	Y COORD 153.83	Z COORD 178.56	DEFLECTIONS (IN)	ROTATIONS (RAD)
FX	FY	FZ	MX	MY	MZ	DX	DY	DZ	RX	RY	RZ
DWT	1	487.	0.	334.	0.	0.	0.	0.08	0.11	0.05	0.000
OBEI	10	1190.	0.	-488.	0.	0.	0.	0.05	0.16	0.38	0.000
OBEA NOT SPECIFIED											0.001
SSEI	11	2856.	0.	-1170.	0.	0.	0.	0.13	0.39	0.91	0.001
NORM	2	100.	0.	416.	0.	0.	0.	-3.49	0.14	2.93	0.000
THERANC	3	108.	0.	447.	0.	0.	0.	-3.76	0.15	3.16	0.000
OCCMAX	4	2276.	0.	-88.	0.	0.	0.	-0.15	-0.03	-0.34	0.004
OCCMIN				73.	0.	0.	0.	0.14	0.02	0.33	0.000
MODFLEX	15	572.	0.	750.	0.	0.	0.	-3.42	0.25	2.99	0.000
MODFLEX	17	2404.	0.	-1237.	0.	0.	0.	3.57	0.41	3.37	0.001
MODFLEX	18	3067.	0.	-1952.	0.	0.	0.	3.81	0.65	4.12	0.001
											0.006
											0.002

CASE DESCRIPTION TITLE

1 DEADWEIGHT  
10 1/2 SSE INERTIA  
11 SSE INERTIA  
2 NORMAL OPERATING  
3 THERMAL EXPAN + ANC MVMTS  
4 TIME HISTORY DYNAMIC FORCE  
15 MODFLEX  
17 MODFLEX  
18 MODFLEX

DEADWEIGHT  
OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
THERMAL ANALYSIS (NORMAL) 551 DEG F  
THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
LC#1 MAX. VALUE (DWT, (DWT+TH NORM))  
LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))  
LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R.  
App. 1, p 68

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 15 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 370 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H13 \*  
\*\*\*\*\*

LOAD TYPE	CASE	(PSI) MNS	GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)			GLOBAL COORDINATES (FT)					
			FX	FY	FZ	EQ.8 6753.	EQ.9 9200.	EQ.10 650.	EQ.11 7403.	X COORD -140.31	Y COORD 153.83	Z COORD 183.00		
DWT	1	79.	0.	59.	0.	0.	0.	0.	0.08	0.02	0.04	0.000	0.000	0.000
OBEI	10	2447.	0.	-66.	0.	0.	0.	0.	0.00	0.03	0.07	0.000	0.001	0.000
OBEA NOT SPECIFIED														
SSEI	11	5872.	0.	-157.	0.	0.	0.	0.	0.00	0.07	0.16	0.000	0.002	0.001
NORM	2	604.	0.	137.	0.	0.	0.	0.	-2.48	0.06	2.26	0.000	0.003	0.000
THERANC	3	650.	0.	147.	0.	0.	0.	0.	-2.66	0.06	2.43	0.000	0.004	-0.001
OCCMAX	4	1977.	0.	-15.	0.	0.	0.	0.	0.00	-0.01	0.06	0.000	0.001	0.000
OCCMIN														
MODFLEX	15	603.	0.	196.	0.	0.	0.	0.	-2.40	0.08	2.30	0.000	0.004	-0.001
MODFLEX	17	3006.	0.	-262.	0.	0.	0.	0.	2.40	0.11	2.37	0.000	0.005	0.001
MODFLEX	18	6468.	0.	-364.	0.	0.	0.	0.	2.58	0.15	2.64	0.000	0.006	0.002

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT,(DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)

Calc. 1-1 R.  
A#1, pg9

NUPIPE-SW ME-110  
VER 06 REV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 16 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 390 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* M3V-4 INLET \*  
\*\*\*\*\*

GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)			(FT)			GLOBAL COORDINATES		
	EQ.8	EQ.9	EQ.10	EQ.11		X COORD	Y COORD	Z COORD			
	7249.	13354.	1719.	8967.		-131.70	153.83	183.00			
LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF) FX FY	FZ	MOMENTS (FT-LBF) MX MY MZ	DEFLECTIONS (IN) DX DY DZ	ROTATIONS (RAD) RX RY RZ				
DWT	1	276.	0. 814.	0.	3541. 0. 0.	0.08 0.00 0.03	0.000 0.000 0.000				
OBEI	10	214.	0. -3453.	0.	-9790. 0. 0.	0.00 0.00 0.00	0.000 0.000 0.000				
OBEA	NOT SPECIFIED										
SSEI	11	513.	0. -8286.	0.	-23495. 0. 0.	0.00 0.00 0.00	0.000 0.000 0.000				
NORM	2	600.	0. -2521.	0.	3823. 0. 0.	-2.12 0.00 1.91	0.000 0.003 0.003				
THERANC	3	646.	0. -2712.	0.	4114. 0. 0.	-2.28 0.00 2.06	0.000 0.004 0.004				
OCCMAX	4	119.	0. -1046.	0.	-3742. 0. 0.	0.00 0.00 0.00	0.000 0.000 0.000				
OCCMIN			0. 847.	0.	3420. 0. 0.	0.00 0.00 0.00	0.000 0.000 0.000				
MODFLEX	15	504.	0. -1707.	0.	7364. 0. 0.	-2.04 0.00 1.94	0.000 0.003 0.003				
MODFLEX	17	622.	0. -5159.	0.	-17154. 0. 0.	2.04 0.00 1.94	0.000 0.004 0.004				
MODFLEX	18	992.	0. -10185.	0.	-31150. 0. 0.	2.20 0.00 2.09	0.000 0.004 0.004				

CASE DESCRIPTION TITLE

1 DEADWEIGHT DEADWEIGHT  
10 1/2 SSE INERTIA OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
11 SSE INERTIA SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
2 NORMAL OPERATING THERMAL ANALYSIS (NORMAL) 551 DEG F  
3 THERMAL EXPAN + ANC MVMTS THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
4 TIME HISTORY DYNAMIC FORCE FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
15 MODFLEX LC#1 MAX. VALUE (DWT, (DWT+TH NORM))  
17 MODFLEX LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))  
18 MODFLEX LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

Calc. 1-1 R. 1  
APP. 1, p70

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

PAGE 17 OF 18  
DATE 2/23/93  
JOB NO. 3823  
RUN NO. R0170002

\*\*\*\*\*  
\* POINT NO. 390 \*  
\* FUNCTION: SNUBBER \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* MSV-4 (INLET) \*  
\*\*\*\*\*

GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				GLOBAL COORDINATES (FT)						
	CASE	(PSI) MNS	FORCES (LBF)	FX	FY	FZ	EQ.8 7249.	EQ.9 13354.	EQ.10 1719.	EQ.11 8967.	X COORD -131.70	Y COORD 153.83	Z COORD 183.00
DWT	1	276.	0.	0.	0.	0.	0.	0.	0.	0.	0.08	0.00	0.03
OBEI	10	214.	-7181.	0.	-8805.	0.	0.	-159991.	-58664.	0.00	0.00	0.00	0.000
OBEA	NOT SPECIFIED												
SSEI	11	513.	-17234.	0.	-21132.	0.	0.	-383979.	-140794.	0.00	0.00	0.00	0.000
NORM	2	600.	0.	0.	0.	0.	0.	0.	0.	-2.12	0.00	1.91	0.000
THERANC	3	646.	0.	0.	0.	0.	0.	0.	0.	-2.28	0.00	2.06	0.000
OCCMAX	4	119.	21112.	0.	10543.	0.	0.	146139.	14081.	0.00	0.00	0.00	0.000
OCCMIN			-17488.	0.	-7220.	0.	0.	-128094.	-11119.	0.00	0.00	0.00	0.000
MODFLEX	15	504.	0.	0.	0.	0.	0.	0.	0.	-2.04	0.00	1.94	0.000
MODFLEX	17	622.	-21112.	0.	-10543.	0.	0.	-159991.	-58664.	2.04	0.00	1.94	0.000
MODFLEX	18	992.	-17234.	0.	-21132.	0.	0.	-383979.	-140794.	2.20	0.00	2.09	0.000

CASE DESCRIPTION

TITLE

- |    |                            |  |
|----|----------------------------|--|
| 1  | DEADWEIGHT                 | DEADWEIGHT   |
| 10 | 1/2 SSE INERTIA            | OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS |
| 11 | SSE INERTIA                | SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS |
| 2  | NORMAL OPERATING           | Thermal Analysis (Normal) 551 deg F                          |
| 3  | THERMAL EXPAN + ANC MVMTS  | Thermal Analysis (Maximum) 583 deg F                         |
| 4  | TIME HISTORY DYNAMIC FORCE | FT = FLUID TRANSIENT DUE TO TURBINE TRIP                     |
| 15 | MODFLEX                    | LC#1 MAX. VALUE (DWT, (DWT+TH NORM))                         |
| 17 | MODFLEX                    | LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))             |
| 18 | MODFLEX                    | LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)                      |

C&C - 1-1 R. 1  
16/1/91 P71

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

A5010.65P

CALCULATION IDENTIFICATION NUMBER					PAGE
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	A PP. 1	
03040	NP (C)	PM 786 / - /		72	

R - 1

COMPUTER LOG

S&W COMPUTER AUTH. NO. 0170

PROGRAM NAME	VERSION /LEVEL	RUN NO.	JOB NO.	FICHE LOC	PREPARED BY	COMMENTS
LIBRARY REF. NO.				SECT	DATE	
NUPIPE	V06/L03	001	3762	Att. 5	F.CAPUANO	RJE STORAGE: FCC.PM786:072
ME-110				A	02/23/93	
NUPIPE	V06/L03	002	3823	Att. 5	F.CAPUANO	RJE STORAGE: FCC.PM786.WO41:072
ME-110				B	02/23/93	
NUPIPE	V06/L03	008	7541	Att. 5	F.CAPUANO	RJE STORAGE: FCC.PM786.TB165:072
ME-110				C	03/24/93	
NUPIPE	V06/L03	023	6343	Att. 5	F.CAPUANO	RJE STORAGE: FCC.PM786.WO9B7:072
ME-110				D	03/30/93	

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

## INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
1	0	0	0	0	0	0	0	0
2	PECO PBAPS UNIT#2	03040-NP(C)-PM-786 (RERATE)	MS "D"	CONTMT	TO TSV			
3	CONTROL	5	2.	1.	.001			
4	CONTROL	1.						
5	FLEXAN	1	1	3.				
6	DEADWEIGHT							
7	FLEXAN	2	1	2.				
8	THERMAL ANALYSIS (NORMAL)	551	DEG F					
9	FLEXAN	3	2	2.				
10	THERMAL ANALYSIS (MAXIMUM)	583	DEG F					
11	FLEXAN	4	1	18.	300.	200.	3.	
12	FT = FLUID TRANSIENT DUE TO TURBINE TRIP							
13	FFLEXAN	5	1	5.	20.	20.	1.	
14	FFLEXAN	-1						
15	X DIRECTION OBE EARTHQUAKE							
16	FFLEXAN	6	1	6.	20.	20.	2.	
17	Y DIRECTION OBE EARTHQUAKE							
18	FFLEXAN	7	1	7.	20.	20.	1.	
19	FFLEXAN	-1						
20	Z DIRECTION OBE EARTHQUAKE							
21	MODFLEX	8	5	6	1.	1.	1.	
22	ABS(X+Y) OBE EARTHQUAKE							
23	MODFLEX	9	6	7	1.	1.	1.	
24	ABS(Y+Z) OBE EARTHQUAKE							
25	MODFLEX	10	8	9	1.	1.	4.	
26	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS							
27	MODFLEX	11	10	2.4				
28	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS							
29	MODFLEX	12	410	1.	1.	4.		
30	UPSET MAX OF (OBEI OR FT)							
31	MOD	13	1	2	1.	1.		
32	ALG.SUM (DWT, TH NORM)							
33	MOD	14	1	3	1.	1.		
34	ALG.SUM (DWT, TH MAX)							
35	MOD	15	113	1.	1.	3.		
36	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))							
37	MOD	16	114	1.	1.	3.		
38	MAX. VALUE (DWT, (DWT+TH MAX))							
39	MOD	17	1213	1.	1.	1.		
40	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))							
41	MOD	18	1116	1.	1.	1.		
42	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)							
43	TITLE	1						
44	AMPLIFIED RESPONSE SPECTRA (ARS) - RB EL.135'-165', TB EL.150'- 165'.5% DAMPING							
45	SPEC	1	1	0.010	.12	.033	.12	.037 .15
46	SPEC	1	1	.045	.20	.077	.33	.100 .60
47	SPEC	1	1	.111	1.92	.125	1.92	.133 2.27
48	SPEC	1	1	.164	2.27	.167	2.09	.196 .64
49	SPEC	1	1	.244	.36	.435	.29	.833 .29
50	SPEC	1	1	1.220	.13	10.000	.00	

ATTACHMENT NO. | P 10412

Calc. 1 - 1 R. 1

APP. 1

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

## INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
51	SPEC	1	3	0.010	.10	.033	.10	.037 .15
52	SPEC	1	3	.045	.23	.071	.36	.091 .84
53	SPEC	1	3	.095	1.89	.111	1.89	.118 .93
54	SPEC	1	3	.122	1.09	.133	2.27	.164 2.27
55	SPEC	1	3	.167	2.09	.196	.64	.238 .39
56	SPEC	1	3	.500	.39	.769	.36	1.250 .12
57	SPEC	1	3	10.00	.00			
58	TITLE	2						
59	AMPLIFIED RESPONSE	SPECTRA (ARS)	- (2/3)	GROUND SPECTRA	.5% DAMPING			
60	SPEC	2	2	.000	.043	.025	.043	.033 .06
61	SPEC	2	2	.050	.087	.100	.113	.111 .122
62	SPEC	2	2	.125	.133	.143	.153	.167 .167
63	SPEC	2	2	.182	.173	.222	.173	.250 .167
64	SPEC	2	2	.333	.153	.500	.113	1.000 .057
65	SPEC	2	2	10.000	.057			
66	XSE26STM	1		26.00	1.086	317.0	29.9	1115. 1.
67	XSE6" WTR	2		6.625	.432	50.5	27.9	1115. 2.
68	XSEA0DVUM	3		26.00	1.086	.001	29.9	0. 3.
69	XSE14STM	4		14.00	.750	123.0	27.9	1115. 3.
70	XSE28STM	5		28.00	1.375	.001	29.9	1115. 3.
71	OPV551	1	1	27.04	.04120			
72	OPV551	1	2	26.04	.04120			
73	OPV583	2	1	26.82	.04433			
74	OPV583	2	2	25.82	.04433			
75	ANCHOR	5		-11.00	138.15	45.00		
76	MARKNO	FLUED	HEAD	PEN N-7D				
77	RUN	5	10			2.583	1.	1. 1.9
78	VALVE	10	15			3.583		
79	VALVE	15	20			1.250		
80	ELBOW	20	35					
81	DUMMY				.1521	.9884		
82	ELBOW	35	40			3.02		
83	DUMMY				.9884	.1521		
84	ELBOW	40	45					
85	RUN	45	54		.521			
86	RUN	54	56			4.161		
87	RUN	56	60			2.926		
88	RUN	60	65			5.074		
89	ELBOW	65	70					
90	RUN	70	75					
91	RESTRAINT					5.833		
92	MARKNO	1DB-H1			1500			
93	RUN	75	76			3.292		
94	RUN	76	80			5.403		
95	RUN	80	82			3.847		
96	RUN	82	90			5.542		
97	RUN	90	95			6.028		
98	RUN	95	100			6.028		
99	RESTRAINT			100		2160		
100	MARKNO	1DB-H2						

ATTACHMENT NO. | P2

Calc. 1 - 1 R - 1

App. 1

See App. 2. For unit 3 spring settings ▲

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

## INPUT DATA ECHO

STMT NUMBER		1	2	3	4	5	6	7	8
101	RUN	100	105	0	0	0	0	0	0
102	SNUBBER		105		1.0E8				
103	MARKNO	1DB-S2A							
104	RUN	105	110			5.833			
105	ELBOW	110	115						
106	RUN	115	125	-6.646					
107	RESTRAINT	125			1.0E8				
108	MARKNO	1DB-H3							
109	RUN	125	130	-4.451					
110	RUN	130	135	-4.451					
111	RUN	135	140	-4.451					
112	RESTRAINT	140			1.0E8				
113	MARKNO	1DB-H4							
114	RUN	140	145	-6.295					
115	RUN	145	150	-6.295					
116	RUN	150	155	-6.295					
117	RUN	155	160	-6.295					
118	RUN	160	165	-6.295					
119	RUN	165	170	-6.295					
120	RESTRAINT	170			1.0E8				
121	MARKNO	1DB-H5							
122	RUN	170	175	-4.771					
123	RUN	175	180	-4.771					
124	RUN	180	185	-4.771					
125	RUN	185	190	-4.771					
126	RUN	190	195	-4.771					
127	RUN	195	200	-4.771					
128	RUN	200	205	-4.771					
129	RUN	205	210	-4.771					
130	RESTRAINT	210			1.0E8				
131	MARKNO	1DB-H6							
132	RUN	210	215	-6.333					
133	RUN	215	220	-6.333					
134	RUN	220	225	-6.333					
135	RUN	225	230	-6.333					
136	RUN	230	235	-6.333					
137	RUN	235	240	-6.333					
138	RESTRAINT	240			1.0E8				
139	MARKNO	1DB-H7							
140	RUN	240	245	-3.104					
141	RUN	245	250	-3.104					
142	SNUBBER		250			1.0E8			
143	MARKNO	1DB-S7A							
144	RUN	250	255	-4.594					
145	RUN	255	260	-4.594					
146	ELBOW	260	265						
147	RUN	265	270			5.792			
148	RUN	270	275			5.792			
149	RESTRAINT	275			1.0E8				
150	MARKNO	1DB-H9B							
		0	0	0	0	0	0	0	0

ATTACHMENT NO. |

P3

Calc. 1-1 R-1  
APP. I

## PECO PBAPS UNIT#2 03040-NP(C) PM-786 (RERATE) MS "D" CONTMT TO TSV

INPUT DATA ECHO

STMT NUMBER		1	2	3	4	5	6	7	8
		0	0	0	0	0	0	0	0
151	RUN	275	280			5.108			
152	RUN	280	285			5.108			
153	RUN	285	290			5.108			
154	RUN	290	295			5.108			
155	RUN	295	300			5.108			
156	RUN	300	305			5.108			
157	RESTRAINT		305		3000				
158	MARKNO	1DB-H10							
159	RUN	305	310			6.047			
160	RUN	310	315			6.047			
161	RUN	315	320			6.047			
162	RUN	320	325			6.047			
163	RESTRAINT		325		2160				
164	MARKNO	1DB-H11							
165	RUN	325	330			4.325			
166	RUN	330	335			4.325			
167	RUN	335	340			4.325			
168	RESTRAINT		340		3000				
169	MARKNO	1DB-H12							
170	RUN	340	345			4.443			
171	ELBOW	345	350						
172	RUN	350	355	4.875					
173	RUN	355	360	5.049					
174	RUN	360	365	5.049					
175	RUN	365	370	5.049					
176	RESTRAINT		370		2400				
177	MARKNO	1DB-H13							
178	RUN	370	375	3.302					
179	RUN	375	380	3.302					
180	RUN	380	385	1.000					
181	RUN	385	390	1.000					
182	RESTRAINT		390		1.0E8	1.0E10			
183	SNUBBER		390	1.0E8		1.0E8	1.0E10	1.0E10	
184	MARKNO	MSV-4 (INLET)							
185	VALVE	15	25		-2.758	-2.758	3.		
186	MVALVE	25	30		-3.960	-3.960			
187	RUN	35	36		-2.29		2.		
188	RUN	40	41		-2.75		1.		
189	RESTRAINT		41		1.0E8				
190	MARKNO	RESTRAINT #5							
191	RUN	355	356		2.583		4.		
192	TEE	355	356	1.7					
193	RUN	385	386		-2.29		2.		
194	TEE	385	386	1.41			2.		
195	VALVE	390	400	11.083	-12.646		5.		
196	RUN	400	405		-11.927		1.		
197	RUN	405	410		-11.927				
198	ELBOW	410	415	11.000					
199	RUN	415	425	17.958					
200	RUN	425	435	17.958					

ATTACHMENT NO. 1

P4

C:\C\1-1.R1

App. 1

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

## INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
201	ELBOW	435	440	11.000				
202	RUN	440	450		12.950			
203	RUN	450	455		12.950			
204	RUN	455	460		12.950			
205	RUN	460	470		12.950			
206	ELBOW	470	475					
207	RUN	475	480		-4.08			
208	ANCHOR		480					
209	LMASS	10	54	56	76	82	105	125
210	LMASS	275	305	325	340	370		140
211	LMASS	15	25	30	35	36	40	60
212	LMASS	90	95	100	110	130	135	145
213	LMASS	175	180	185	190	195	200	205
214	LMASS	245	255	260	270	280	285	290
215	LMASS	320	330	335	345	355	356	360
216	CWEVLVBODY		25			8060.		
217	CWEVLVOPER		30			2015.		
218	CWEHGR R5		40			580.		
219	CWEREST 4		54			1080.		
220	CWEREST 3		56			1080.		
221	CWEREST 2		76			1080.		
222	CWEREST 1		82			170.		
223	CWEHGR H1		75			109.		
224	CWEHGR H2		100			109.		
225	CWEHGR H11		325			109.		
226	CWEHGR H12		340			109.		
227	CWEHGR S2A		105			620.		
228	CWEHGR H3		125			330.		
229	CWEHGR H4		140			300.		
230	CWEHGR H5		170			300.		
231	CWEHGR H6		210			300.		
232	CWEHGR H7		240			300.		
233	CWEHGR H9B		275			300.		
234	CWEHGR S7A		250			1450.		
235	CWEHGR H10		305			162.		
236	CWEHGR H13		370			220.		
237	CWE14"PIPE		356			1970.		
238	CWE4"PIPE		380			170.		
239	FORCE	1	75			8887.		
240	FORCE	1	100			6125.		
241	FORCE	1	305			8697.		
242	FORCE	1	325			6434.		
243	FORCE	1	340			8571.		
244	FORCE	1	370			7200.		
245	TFORCE	7	10			-.25		
246	TFORCE	8	15			-1.00		
247	TFORCE	9	65			-1.00		
248	TFORCE	10	110			-1.00		
249	TFORCE	11	260			1.00		
250	TFORCE	12	345			-1.00		

ATTACHMENT NO. 1

P5

Calc. 1-1 R. 1

APP. 1

NUPIPE-SW ME-110  
VER 06 LEV 03

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

2/23/93 PAGE 6  
JOB 3762 R0170001

INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
251	0	0	0	0	0	0	0	0
252	TFORCE	13	360		-1.00			
253	9CN	1	12					
254	9CF	1	11					
255	10CASES	2	3					
256	SUMMARY	1	2	3	4	10	11	
257	SUPPORT	1	10	11	2	3	4	15
258	STITLE	MS "D"	(CONTMT TO TSV)					
259	STITLE	03040-NP(C)-PM-786						
260	ALLDONE							
261	STORED AS:	FCC.PM786:072						
262	ALLDONE							

Calc - 1-1 R - 1  
App. 1  
ATTACHMENT NO. 1

P6

## PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
1	0	0	0	0	0	0	0	0
2	PECO PBAPS UNIT#2	03040-NP(C)-PM-786 (RERATE)	MS "D" CONTMT TO TSV					
2	CONTROL	5	2.	1.	.001			
3	CONTROL		1.					
4	FLEXAN	1	1	3.				
5	DEADWEIGHT							
6	FLEXAN	2	1	2.				
7	THERMAL ANALYSIS (NORMAL)	551	DEG F					
8	FLEXAN	3	2	2.				
9	THERMAL ANALYSIS (MAXIMUM)	583	DEG F					
10	FLEXAN	4	1	18.	300.	200.	3.	
11	FT = FLUID TRANSIENT DUE TO TURBINE TRIP							
12	FFLEXAN	5	1	5.	20.	20.	1.	
13	FFLEXAN	-1						
14	X DIRECTION OBE EARTHQUAKE							
15	FFLEXAN	6	1	6.	20.	20.	2.	
16	FFLEXAN	-1						
17	Y DIRECTION OBE EARTHQUAKE							
18	FFLEXAN	7	1	7.	20.	20.	1.	
19	FFLEXAN	-1						
20	Z DIRECTION OBE EARTHQUAKE							
21	MODFLEX	8	5	6	1.	1.	1.	
22	ABS(X-Y) OBE EARTHQUAKE							
23	MODFLEX	9	6	7	1.	1.	1.	
24	ABS(Y+Z) OBE EARTHQUAKE							
25	MODFLEX	10	8	9	1.	1.	4.	
26	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS							
27	MODFLEX	11	10	2.4				
28	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS							
29	MODFLEX	12	410	1.	1.	4.		
30	UPSET MAX OF (OBEI OR FT)							
31	MOD	13	1	2	1.	1.		
32	ALG.SUM (DWT,TH NORM)							
33	MOD	14	1	3	1.	1.		
34	ALG.SUM (DWT,TH MAX)							
35	MOD	15	113	1.	1.	3.		
36	LC#1 MAX. VALUE (DWT,(DWT+TH NORM))							
37	MOD	16	114	1.	1.	3.		
38	MAX. VALUE (DWT,(DWT+TH MAX))							
39	MOD	17	1213	1.	1.	1.		
40	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))							
41	MOD	18	1116	1.	1.	1.		
42	LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)							
43	TITLE	1						
44	AMPLIFIED RESPONSE SPECTRA (ARS) - RB EL.135'-165', TB EL.150'- 165' 5% DAMPING							
45	SPEC	1	1	0.010	.12	.033	.12	.037 .15
46	SPEC	1	1	.045	.20	.077	.33	.100 .60
47	SPEC	1	1	.111	1.92	.125	1.92	.133 2.27
48	SPEC	1	1	.164	2.27	.167	2.09	.196 .64
49	SPEC	1	1	.244	.36	.435	.29	.833 .29
50	SPEC	1	1	1.220	.13	10.000	.00	

ATTACHMENT NO. | p7

Calc. 1-1 R. 1  
APP. 1

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

## INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
51	SPEC	1 3	0.010	.10	.033	.10	.037	.15
52	SPEC	1 3	.045	.23	.071	.36	.091	.84
53	SPEC	1 3	.095	1.89	.111	1.89	.118	.93
54	SPEC	1 3	.122	1.09	.133	2.27	.164	2.27
55	SPEC	1 3	.167	2.09	.196	.64	.238	.39
56	SPEC	1 3	.500	.39	.769	.36	1.250	.12
57	SPEC	1 3	10.00	.00				
58	TITLE	2						
59	AMPLIFIED RESPONSE	SPECTRA (ARS)	- (2/3)	GROUND SPECTRA	.5% DAMPING			
60	SPEC	2 2	.000	.043	.025	.043	.033	.06
61	SPEC	2 2	.050	.087	.100	.113	.111	.122
62	SPEC	2 2	.125	.133	.143	.153	.167	.167
63	SPEC	2 2	.182	.173	.222	.173	.250	.167
64	SPEC	2 2	.333	.153	.500	.113	1.000	.057
65	SPEC	2 2	10.000	.057				
66	XSE26STM	1	26.00	1.086	317.0	29.9	1115.	1.
67	XSE6" WTR	2	6.625	.432	50.5	27.9	1115.	2.
68	XSEA0VDUM	3	26.00	1.086	.001	29.9	0.	3.
69	XSE14STM	4	14.00	.750	123.0	27.9	1115.	3.
70	XSE28STM	5	28.00	1.375	.001	29.9	1115.	3.
71	OPV551	1 1	27.04	.04120				
72	OPV551	1 2	26.04	.04120				
73	OPV583	2 1	26.82	.04433				
74	OPV583	2 2	25.82	.04433				
75	ANCHOR	5	-11.00	138.15	45.00			
76	MARKNO	FLUED HEAD PEN N-7D						
77	RUN	5 10		2.583	1.	1.	1.9	
78	VALVE	10 15		3.583				
79	VALVE	15 20		1.250				
80	ELBOW	20 35						
81	DUMMY			.1521	.9884			
82	ELBOW	35 40			3.02			
83	DUMMY			.9884	.1521			
84	ELBOW	40 45						
85	RUN	45 54		.521				
86	RUN	54 56			4.161			
87	RUN	56 60			2.926			
88	RUN	60 65			5.074			
89	ELBOW	65 70						
90	RUN	70 75			5.833			
91	RESTRAINT	75		1500				
92	MARKNO	1DB-H1						
93	RUN	75 76			3.292			
94	RUN	76 80			5.403			
95	RUN	80 82			3.847			
96	RUN	82 90			5.542			
97	RUN	90 95			6.028			
98	RUN	95 100			6.028			
99	RESTRAINT	100		2160				
100	MARKNO	1DB-H2						

Calc. 1-1 R. 1  
App. 1  
ATTACHMENT NO. 1 P8

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

## INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
101 RUN	0	0	0	0	0	0	0	0
102 SNUBBER	100	105			1.943			
103 MARKNO	105			1.0E8				
104 RUN	1DB-S2A							
105 ELBOW	105	110				5.833		
106 RUN	110	115						
107 RESTRAINT	115	125	-6.646					
108 MARKNO	125			1.0E8				
109 RUN	1DB-H3							
110 RUN	125	130	-4.451					
111 RUN	130	135	-4.451					
112 RESTRAINT	135	140	-4.451					
113 MARKNO	140			1.0E8				
114 RUN	1DB-H4							
115 RUN	140	145	-6.295					
116 RUN	145	150	-6.295					
117 RUN	150	155	-6.295					
118 RUN	155	160	-6.295					
119 RUN	160	165	-6.295					
120 RESTRAINT	165	170	-6.295					
121 MARKNO	170			1.0E8				
122 RUN	1DB-H5							
123 RUN	170	175	-4.771					
124 RUN	175	180	-4.771					
125 RUN	180	185	-4.771					
126 RUN	185	190	-4.771					
127 RUN	190	195	-4.771					
128 RUN	195	200	-4.771					
129 RUN	200	205	-4.771					
130 RESTRAINT	205	210	-4.771					
131 MARKNO	210			1.0E8				
132 RUN	1DB-H6							
133 RUN	210	215	-6.333					
134 RUN	215	220	-6.333					
135 RUN	220	225	-6.333					
136 RUN	225	230	-6.333					
137 RUN	230	235	-6.333					
138 RESTRAINT	235	240	-6.333					
139 MARKNO	240			1.0E8				
140 RUN	1DB-H7							
141 RUN	240	245	-3.104					
142 SNUBBER	245	250	-3.104					
143 MARKNO	250			1.0E8				
144 RUN	1DB-S7A							
145 RUN	250	255	-4.594					
146 ELBOW	255	260	-4.594					
147 RUN	260	265						
148 RUN	265	270						
149 RESTRAINT	270	275						
150 MARKNO	275			1.0E8				
	1DB-H9B							
	0	0	0	0	0	0	0	0

ATTACHMENT NO. 1 P9

Calc - 1 - 1 R. 1  
App. 1

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

## INPUT DATA ECHO

STMT NUMBER		1	2	3	4	5	6	7	8
151	RUN	275	280			5.108			
152	RUN	280	285			5.108			
153	RUN	285	290			5.108			
154	RUN	290	295			5.108			
155	RUN	295	300			5.108			
156	RUN	300	305			5.108			
157	RESTRAINT		305		3000				
158	MARKNO	1DB-H10							
159	RUN	305	310			6.047			
160	RUN	310	315			6.047			
161	RUN	315	320			6.047			
162	RUN	320	325			6.047			
163	RESTRAINT		325		2160				
164	MARKNO	1DB-H11							
165	RUN	325	330			4.325			
166	RUN	330	335			4.325			
167	RUN	335	340			4.325			
168	RESTRAINT		340		3000				
169	MARKNO	1DB-H12							
170	RUN	340	345			4.443			
171	ELBOW	345	350						
172	RUN	350	355	4.875					
173	RUN	355	360	5.049					
174	RUN	360	365	5.049			1.3		
175	RUN	365	370	5.049			1.3		
176	RESTRAINT		370		2400				
177	MARKNO	1DB-H13							
178	RUN	370	375	3.302					
179	RUN	375	380	3.302			1.3		
180	RUN	380	385	1.000					
181	RUN	385	390	1.000			1.9		
182	RESTRAINT		390		1.0E8	1.0E10	1.0E10	1.0E10	
183	SNUBBER		390	1.0E8	1.0E8				
184	MARKNO	MSV-4 (INLET)							
185	VALVE	15	25		-2.758	-2.758	3.		
186	MVALVE	25	30		-3.960	-3.960			
187	RUN	35	36		-2.29		2.	2.	3.02
188	RUN	355	356	1.7	2.583		4.	2.	
189	TEE	355	356						
190	RUN	385	386		-2.29		2.	2.	
191	TEE	385	386	1.41					
192	VALVE	390	400	11.083	-12.646		5.	1.	
193	RUN	400	405		-11.927				
194	RUN	405	410		-11.927				
195	ELBOW	410	415	11.000					
196	RUN	415	425	17.958					
197	RUN	425	435	17.958					
198	ELBOW	435	440	11.000					
199	RUN	440	450		12.950				
200	RUN	450	455		12.950				

ATTACHMENT NO. 1 P 10

Calc. 1-1 R. 1

APP. 1

NUPIPE-SW ME-110  
VER 06 LEV 03

STONE & WEBSTER ENGINEERING CORPORATION

2/23/93 PAGE 5  
JOB 3823 R0170002

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" CONTMT TO TSV

INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
201	0	0	0	0	0	0	0	0
201 RUN	455	460		12.950				
202 RUN	460	470		12.950				
203 ELBOW	470	475						
204 RUN	475	480		-4.08				
205 ANCHOR	480							
206 LMASS	10	54	56	76	82	105	125	140
207 LMASS	275	305	325	340	370			
208 LMASS	15	25	30	35	36	40	60	65
209 LMASS	90	95	100	110	130	135	145	150
210 LMASS	175	180	185	190	195	200	205	215
211 LMASS	245	255	260	270	280	285	290	295
212 LMASS	320	330	335	345	355	360	365	375
213 CWEVLVBODY	25			8060.				
214 CWEVLVOPER	30			2015.				
215 CWEHGR R5	40			580.				
216 CWEREST 4	54			1080.				
217 CWEREST 3	56			1080.				
218 CWEREST 2	76			1080.				
219 CWEREST 1	82			170.				
220 CWEHGR H1	75			109.				
221 CWEHGR H2	100			109.				
222 CWEHGR H11	325			109.				
223 CWEHGR H12	340			109.				
224 CWEHGR S2A	105			620.				
225 CWEHGR H3	125			330.				
226 CWEHGR H4	140			300.				
227 CWEHGR H5	170			300.				
228 CWEHGR H6	210			300.				
229 CWEHGR H7	240			300.				
230 CWEHGR H9B	275			300.				
231 CWEHGR S7A	250			1450.				
232 CWEHGR H10	305			162.				
233 CWEHGR H13	370			220.				
234 CWE14"PIPE	356			1970.				
235 CWE4"PIPE	380			170.				
236 FORCE	1	75		8887.				
237 FORCE	1	100		6125.				
238 FORCE	1	305		8697.				
239 FORCE	1	325		6434.				
240 FORCE	1	340		8571.				
241 FORCE	1	370		7200.				
242 TFORCE	7	10			.25			
243 TFORCE	8	15			-1.00			
244 TFORCE	9	65			-1.00			
245 TFORCE	10	110			-1.00			
246 TFORCE	11	260		1.00				
247 TFORCE	12	345			-1.00			
248 TFORCE	13	360		-1.00				
249 9CN	1		12					
250 9CF	1		11					

Calc. 1-1 R. 1  
App. 1  
ATTACHMENT NO. 1 P 11

NUPPIPE-SW ME-110  
VER 06 LEV 03

STONE & WEBSTER ENGINEERING CORPORATION

2/23/93 PAGE 6  
JOB 3823 R0170002

PECO PBAPS UNIT#2 ~~03040-NP(C)-PM-786 (RERATE)~~ MS "D" CONTMT TO TSV

INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
251	0	0	0	0	0	0	0	0
252	LOCASES	2	3					
252	SUMMARY	1	2	3	4	10	11	
253	SUPPORT	1	10	11	2	3	4	15
254	STITLE							17
255	STITLE	MS "D"	(CONTMT TO TSV)					
256	STITLE	03040-NP(C)-PM-786						
257	ALLDONE							
258	STORED AS:	FCC.PM786.W041:072						
259	ALLDONE							

Calc. 1-1 Rev. 1  
App. 1  
ATTACHMENT NO. 1 p12

MAR-23-93 TUE 8:39

GRINNELL CRANSTON RI

FAX NO. 14017817150

P.01

Calc. 1-1 R.1 APP. 1

03040-Netf-Pm 786, ATTACHMENT 2 p1of3



**Grinnell**  
CORPORATION

1341 Elmwood Avenue  
Cranston, RI 02910 USA  
Tel: 401-941-8000  
Fax: 401-781-7150

Fax: 401-781-7150

**FAX TRANSMISSION**

**DATE:** 3/23/93

**TO:** NAME: Y.C. JEN  
FIRM: STONE & WEBSTER ENGR. COOP.  
FAX NO: 609-482-3283

**FROM:** NAME: JEAN P. GOULET

NUMBER OF PAGES TO FOLLOW (EXCLUDING COVER PAGE): 8

SUBJECT: Design Report Summary for ECP 206N & ECP 201N  
is enclosed for your information.

---

---

---

MAR-23-93 TUE 8:39

GRINNELL CRANSTON RI

FAX NO. 14017817150

P.02

Calc. I-I. R-1 App-1

03040-NP(1)-PM786, ATTACHMENT 2 p2Page 1 of 8  
DRS 200

## GRINNELL CORPORATION

DESIGN REPORT SUMMARY  
FOR  
FIG. 200N & FIG. 201N  
HYDRAULIC SNUBBERS1. GENERAL INFORMATION


CODE CLASS: 1, 2, 3, MC  
 MATERIAL DATA: See Page 2 & 3  
 LOAD RATINGS: See Page 4  
 DESIGN BY: Analysis

SERVICE LIMITS: Levels A, B, C, D  
 DESIGN TEMPERATURE: 200°F\*  
 650°F(Clamps)  
 DIMENSIONAL DATA: See Page 5-8

2. CERTIFICATION

I CERTIFY THAT THE LOAD CAPACITY  
 OF THIS COMPONENT STANDARD SUPPORT  
 IS RATED IN ACCORDANCE WITH THE  
 REQUIREMENTS OF THE A.S.M.E. B&PV  
 CODE, SECTION III, SUBSECTIONS NCA  
 & NF AND GRINNELL'S DESIGN  
 SPECIFICATION PE188-1 Rev.7.

THE SUBSTANTIATING DESIGN REPORT  
 DR200, DESIGN REPORT  
 CERTIFICATION, AND GRINNELL'S  
 DESIGN SPECIFICATION ARE LOCATED  
 AT THE PIPE SUPPORT DIVISION -  
 CRANSTON, RI.

3. REVISIONS

DRS Rev.	Report Rev.	Code** Edition	Code** Addenda	P.E.	Date
0	5	1989	1991	7/6	8/6/92

\* 340°F for 3 hours maximum

\*\* When sizes 3 1/4 thru 8 are used to support components other than piping (such as valves &amp; pumps) the applicable Code Year is up to and including 1980, S-82.

(21885)

MAR-23-93 TUE 8:40

GRINNELL CRANSTON RI

FAX NO. 14017817150

Calc. 1-1 R-1 App. 1

P. 05

03040-NP(c) AM786, ATTACHMENT 2 p3

Page 4 of 8  
DRS 200  
Rev.0

GRINNELL CORPORATION

DESIGN REPORT SUMMARY  
FOR

FIG. 200N/201N HYDRAULIC SNUBBERS

LOAD RATINGS (LBS)

<u>Bore Size</u>	<u>Design &amp; Levels A&amp;B</u>	<u>Level C</u>	<u>Level D</u>
1 1/2*	3000/1250	3600/1650	4000/1950
2 1/2	10350	13750	19100
3 1/4	17600	23450	30800
4	27300	37300	45000
5	45500	62000	75000
6	68200	92900	112600
8	110000	132000	165000

\* Lesser load rating is for 10" stroke.

Calc. 1-1 R.1 APP.1

03040-NP(1)-PM-786 ATTACHMENT 3 P10F1

Page 1 of 2  
J.O. 030402411

## PECO PBAPS 2&3 POWER RERATE PROJECT

SWEC OPEN ITEMS NOTIFICATION/RESOLUTION REPORT JAN 14 1993

OPEN ITEM NO: 01-PB-024

c.c. TMadden  
Job book 245/R2.4.1  
LJCorsi  
CSLai

SWEC INITIATOR: X. G. Jen T.M.  
PHONE: (609)482-9121

INITIATION DATE: 12/24/92

RESPONSE REQUIRED BY 01/15/93

SUBJECT: Restraint Supports of Main Steam Piping for power rerate review

### POTENTIAL CONCERNS/QUESTIONS

There is no official document to address the qualification of these supports, the only reference document is based on the 'BECHTEL' Main Steam 6280 Binder # 19 for initial review. Due to the 1.76 % thermal load increase and approximately 17% fluid transient load increase in the Main Steam Piping, an average screening criteria 16 % for MSS pipe support is calculated. No calculation for the support structure qualification is included in the referenced document. The following supports exceed allowables in the component part of sway strut for upset condition (see pg.2 for component part evaluation) at the rerate condition:

1DB-H4, H5, H6, H26, H17, H27, H28, H29, H30, H41 & H42.

It is recommended that these loads be re-reviewed based on the main steam piping reanalysis being performed using the new detailed fluid transient loads. Component acceptability will be based on the revised loads. Until then, these items will be "open" relative to acceptability for rerate.

Please provide PECO's concurrence with this approach, or alternate direction by 1/15/93.

### PECO RESPONSE/CLOSEOUT:

The SWEC recommendation seems appropriate.  
Please prepare a task stoping change notice and description  
of your proposed action

RESPONSE BY:  
PHONE:

D. J. Cloney  
(215)640-6374

RESPONSE DATE:

1-19-93

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

APP. 1

ATTACHMENT 4

▲5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE 1 of
JOB NUMBER 03040	DIVISION & GROUP NP (C)	CALCULATION NO. <del>PM</del> 786 1-1 R-1	OPTIONAL TASK CODE N/A	
<u>SUPPORT LOAD COMPARISON (PM-786 vs. PREVIOUS ANALYSES)</u>				15
In order to facilitate a) the evaluation of the support loads generated in this calculation and b) the resolution of Power Rerate Open Item PB-OI-024, the support load comparisons and computer analysis addressed below are provided in this attachment.				
<u>Description</u>			<u>page</u>	
Tabulation and comparison of rigid hanger loads and snubber loads for Unit 2 main steam line D. The loads from this calculation (Jobs 3762, 3823) are compared to the loads from previous analyses (ref. 20, 22, 23).			2	
Tabulation and comparison of rigid hanger loads for Unit 2 main steam line A, B, C in support of the resolution of PB-OI-024. The loads from this calculation (Jobs 3762, 3823) are used for the Line C supports and the loads from Job 6343 are used for the Line A and B supports. See notes 5 and 12d for detailed explanation of the differences between lines A/B and C/D and Job 6343. These loads are compared to the loads from previous analyses (ref. 20, 22, 23).			3	
Support load summary from Job 6343			4-7	
System restraints from Job 6343			8	
Cold loads at "spring hangers" from Job 6343			9	
Input data echo from Job 6343			10-15	
<u>Load combinations used for support comparisons on pages 2 and 3</u>				
UPSET = Max of (DWT or DWT+THERMAL) + Max of (OBE or FT)				
FAULTED = Max of (DWT or DWT+THERMAL) + SSE				
Note that this approach conservatively excludes the thermal load if it will decrease the total loading.				

LOAD COMPARISON (MAIN STEAM LINE D) RIGID HANGER AND SNUBBER LOADS

## LOADS FROM PM-786 1-1

LOAD (lb)	HANGER (NODE)								
	R5 (41)	H3 (125)	H4 (140)	H5 (170)	H6 (210)	H7 (240)	H9B (275)	S2A (105)	S7A (250)
DWT	-10837	-4924	-9053	-12810	-12306	-12492	-8687	0	0
THERMAL (583F)	-4724	549	70	17	-68	-22	138	0	0
FT+	0	10842	6474	737	829	1122	1110	39393	83420
FT-	-40395	-15083	-6224	-695	-961	-1141	-1036	-61204	-72204
OBE	-15807	11665	4542	1531	1873	2988	3972	47626	90318
SSE	-37938	27997	10900	3674	4494	7172	9532	112600	216764
UPSET+	0	7290	0	0	0	0	0	47626	90318
UPSET-	-55956	-20007	-15277	-14341	-14247	-15502	-12659	-61204	-90318
FAULTED+	0	23622	1917	0	0	0	983	112600	216764
FAULTED-	-53499	-32921	-19953	-16484	-16868	-19686	-18219	-112600	-216764

## LOADS FROM PREVIOUS ANALYSES 1-1W,S,T, D-007, BINDER 19 (REF 20,22,23)

LOAD (lb)	REF.	HANGER (NODE)								
		H3 (125)	H4 (140)	H5 (170)	H6 (210)	H7 (240)	H9B (275)	S2A (105)	S7A (250)	
DWT	1-1W	-4726	-9236	-12785	-12501	-10429	-8507	0	0	
THERMAL (583F)	1-1W,T	784	-91	9	-17	431	1451	0	0	
FT+	D007,BR19	13936	8329	1615	1310	2005	1261	82248	190000	
FT-	D007,BR19	-21153	-4329	-1623	-1276	-2572	-994	-82248	-190000	
OBE	1-1S,BR19	11209	4109	269	185	4697	17266	4364	20000	
SSE	1-1S,BR19	26902	9862	646	444	11273	41438	10474	48000	
UPSET+		9994	0	0	0	0	10210	82248	190000	
UPSET-		-25879	-13656	-14408	-13794	-15126	-25773	-82248	-190000	
FAULTED+		22960	626	0	0	1275	34382	10474	48000	
FAULTED-		-31628	-19189	-13431	-12962	-21702	-49945	-10474	-48000	

1-1

## IDENTIFICATION OF LOAD RATIOS GREATER THAN 1.0 (PM-786 LOADS / PREVIOUS LOADS)

		HANGER (NODE)								
		H3 (125)	H4 (140)	H5 (170)	H6 (210)	H7 (240)	H9B (275)	S2A (105)	S7A (250)	
UPSET+										
UPSET-			1.12		1.03	1.02				
FAULTED+		1.03	3.06					10.75	4.52	
FAULTED-		1.04	1.04	1.23	1.30			10.75	4.52	

LOAD COMPARISON (MAIN STEAM LINES A, B, C) RIGID HANGER LOADS

LOADS FROM PREVIOUS ANALYSES 1-1W,S,T, D-007, BINDER 19 (REF 20,22,23)

LOAD (lb)	HANGER (LOOP)							
	H17	H26	H27	H28	H29	H30	H41	H42
	(C)	(C)	(B)	(B)	(B)	(B)	(A)	(A)
SIMILAR "D" HGR	H5	H3	H3	H4	H5	H6	H5	H6
DW	-12911	-5152	-7918	-10261	-13722	-14146	-13128	-13790
THERMAL (583F)	61	503	422	242	-368	473	-421	568
FT+	1600	14000	14000	8500	1600	1300	1600	2000
FT-	-1600	-22000	-22000	-4500	-1600	-1300	-1600	-1800
OBE	1807	3975	3450	2339	4706	6966	7889	12390
SSE	4337	9540	8280	5614	11294	16718	18934	29736
UPSET+	0	9351	6504	0	0	0	0	0
UPSET-	-14718	-27152	-29918	-14761	-18796	-21112	-21438	-26180
FAULTED+	0	4891	784	0	0	3045	5806	16514
FAULTED-	-17248	-14692	-16198	-15875	-25384	-30864	-32483	-43526

LOADS FROM PM-786 (SEE NOTES 5 AND 12D ADDRESSING DIFFERENCES BETWEEN LOOPS)

LOAD (lb)	HANGER (LOOP)							
	H17	H26	H27	H28	H29	H30	H41	H42
	(C)	(C)	(B)	(B)	(B)	(B)	(A)	(A)
SIMILAR "D" HGR	H5	H3	H3	H4	H5	H6	H5	H6
COMPUTER JOB	3762,3823	3762,3823	6343	6343	6343	6343	6343	6343
NODE	(170)	(125)	(125)	(140)	(170)	(210)	(170)	(210)
DW	refer to loads from previous analyses above							
THERMAL (583F)	refer to loads from previous analyses above							
FT+	737	10842	10326	7457	831	1790	831	1790
FT-	-695	-15083	-14902	-6026	-843	-2104	-843	-2104
OBE	1531	11665	11757	5299	3665	4876	3665	4876
SSE	3674	27997	28218	12718	8796	11702	8796	11702
UPSET+	0	7016	4261	0	0	0	0	0
UPSET-	-14442	-20235	-22820	-16287	-17755	-19022	-17214	-18666
FAULTED+	0	23348	20722	2699	0	0	0	0
FAULTED-	-16585	-33149	-36136	-22979	-22886	-25848	-22345	-25492

IDENTIFICATION OF LOAD RATIOS GREATER THAN 1.0 (PM-786 LOADS / PREVIOUS LOADS)

LOAD (lb)	HANGER (LOOP)							
	H17	H26	H27	H28	H29	H30	H41	H42
	(C)	(C)	(B)	(B)	(B)	(B)	(A)	(A)
SIMILAR "D" HGR	H5	H3	H3	H4	H5	H6	H5	H6
UPSET+								
UPSET-				1.10				
FAULTED+		4.77	26.43	2699.00				
FAULTED-		2.26	2.23	1.45				

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

PAGE 5 OF 18  
DATE 3/30/93  
JOB NO. 6343  
RUN NO. R0170023

\*\*\*\*\*  
\* POINT NO. 125 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H3 \*  
\*\*\*\*\*

GLOBAL			MINIMUM CLASS 2 STRESSES (PSI)				(FT) GLOBAL COORDINATES							
	EQ.8 6991.	EQ.9 9861.	EQ.10 903.	EQ.11 7894.		X COORD -17.65	Y COORD 153.83	Z COORD 99.17						
LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF) FX	FY	FZ	MX	MOMENTS (FT-LBF) MY	MZ	DEFLECTIONS (IN) DX	DY	DZ	ROTATIONS (RAD) RX	RY	RZ
DWT	1	317.	0.	-4924.	0.	0.	0.	0.	0.01	0.00	0.06	0.000	0.000	0.000
OBEI	10	2033.	0.	-11757.	0.	0.	0.	0.	0.15	0.00	0.53	0.001	0.004	0.000
OBEA	NOT SPECIFIED													
SSEI	11	4878.	0.	-28218.	0.	0.	0.	0.	0.35	0.00	1.26	0.003	0.009	0.000
NORM	2	839.	0.	333.	0.	0.	0.	0.	-0.37	0.00	2.23	0.001	-0.002	0.000
THERANC	3	903.	0.	358.	0.	0.	0.	0.	-0.40	0.00	2.40	0.001	-0.002	0.000
OCCMAX	4	2870.	0.	-14902.	0.	0.	0.	0.	-0.28	0.00	0.59	-0.001	-0.004	0.000
OCCMIN				10326.	0.	0.	0.	0.	0.20	0.00	-0.47	0.001	0.003	0.000
MODFLEX	15	907.	0.	-4924.	0.	0.	0.	0.	-0.36	0.00	2.29	0.001	-0.002	0.000
MODFLEX	17	3768.	0.	-19493.	0.	0.	0.	0.	0.64	0.00	2.87	0.002	0.006	0.000
MODFLEX	18	5822.	0.	-33142.	0.	0.	0.	0.	0.74	0.00	3.72	0.004	0.011	0.000

CASE DESCRIPTION

TITLE

- 1 DEADWEIGHT  
10 1/2 SSE INERTIA  
11 SSE INERTIA  
2 NORMAL OPERATING  
3 THERMAL EXPAN + ANC MVMTS  
4 TIME HISTORY DYNAMIC FORCE  
15 MODFLEX  
17 MODFLEX  
18 MODFLEX
- DEADWEIGHT  
OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
THERMAL ANALYSIS (NORMAL) 551 DEG F  
THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
LC#1 MAX. VALUE (DWT,(DWT+TH NORM))  
LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT)  
LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)

ATTACHMENT NO. 4 P4

NUPPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

PAGE 6 OF 18  
DATE 3/30/93  
JOB NO. 6343  
RUN NO. R0170023

\*\*\*\*\*  
\* POINT NO. 140 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H4 \*  
\*\*\*\*\*

GLOBAL

MINIMUM CLASS 2 STRESSES (PSI)

	EQ.8	EQ.9	EQ.10	EQ.11
7278.	10444.	661.	7939.	

(FT)  
GLOBAL COORDINATES  
X COORD Y COORD Z COORD  
-31.00 153.83 99.17

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF)			MOMENTS (FT-LBF)			DEFLECTIONS (IN)			ROTATIONS (RAD)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ	RX	RY	RZ
DWT	1	605.	0.	-8931.	0.	0.	0.	0.	0.01	0.00	0.06	0.000	0.000	0.000
OBEI	10	2181.	0.	-5299.	0.	0.	0.	0.	0.15	0.00	1.13	0.001	0.004	0.000
OBEA NOT SPECIFIED														
SSEI	11	5235.	0.	-12718.	0.	0.	0.	0.	0.36	0.00	2.71	0.003	0.010	0.000
NORM	2	614.	0.	112.	0.	0.	0.	0.	-0.92	0.00	1.96	0.001	-0.002	0.000
THERANC	3	661.	0.	121.	0.	0.	0.	0.	-0.99	0.00	2.11	0.001	-0.002	0.000
OCCMAX	4	3166.	0.	7457.	0.	0.	0.	0.	-0.28	0.00	0.60	-0.001	-0.004	0.000
OCCMIN														
MODFLEX	15	859.	0.	-8931.	0.	0.	0.	0.	0.21	0.00	-0.48	0.001	0.003	0.000
MODFLEX	17	3864.	0.	-16276.	0.	0.	0.	0.	-0.91	0.00	2.02	0.001	-0.002	0.000
MODFLEX	18	5985.	0.	-21649.	0.	0.	0.	0.	1.19	0.00	3.15	0.002	0.006	0.000
									1.34	0.00	4.87	0.003	0.012	0.000

CASE DESCRIPTION

TITLE

- |    |                            |  |
|----|----------------------------|--|
| 1  | DEADWEIGHT                 | DEADWEIGHT   |
| 10 | 1/2 SSE INERTIA            | OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS |
| 11 | SSE INERTIA                | SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS |
| 2  | NORMAL OPERATING           | THERMAL ANALYSIS (NORMAL) 551 DEG F                          |
| 3  | THERMAL EXPAN + ANC MVMTS  | THERMAL ANALYSIS (MAXIMUM) 583 DEG F                         |
| 4  | TIME HISTORY DYNAMIC FORCE | FT = FLUID TRANSIENT DUE TO TURBINE TRIP                     |
| 15 | MODFLEX                    | LC#1 MAX. VALUE (DWT,(DWT+TH NORM))                          |
| 17 | MODFLEX                    | LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))             |
| 18 | MODFLEX                    | LC#3 ABS.SUM(DWT OR (DWT+TH MAX),SSEI)                       |

ATTACHMENT NO. 4 PS

Calc. 1 - 1  
A/P. 1

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

PAGE 7 OF 18  
DATE 3/30/93  
JOB NO. 6343  
RUN NO. R0170023

\*\*\*\*\*  
\* POINT NO. 170 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H5 \*  
\*\*\*\*\*

GLOBAL

MINIMUM CLASS 2 STRESSES (PSI)

EQ.8 EQ.9 EQ.10 EQ.11

7624. 11967. 201. 7824.

(FT)  
GLOBAL COORDINATES  
X COORD Y COORD Z COORD  
-68.77 153.83 99.17

LOAD TYPE	CASE	MNS (PSI)	FX	FORCES (LBF)	FY	FZ	MX	MOMENTS (FT-LBF)	MY	MZ	DEFLECTIONS (IN)	DX	DY	DZ	ROTATIONS (RAD)	RX	RY	RZ
DWT	1	950.	0.	-12810.	0.	0.	0.	0.	0.	0.	0.01	0.00	0.05	0.000	0.000	0.000	0.000	
OBEI	10	3776.	0.	-3665.	0.	0.	0.	0.	0.	0.	0.15	0.00	2.37	0.001	0.002	0.000	0.000	
OBEA NOT SPECIFIED																		
SSEI	11	9061.	0.	-8796.	0.	0.	0.	0.	0.	0.	0.36	0.00	5.68	0.002	0.005	0.000	0.000	
NORM	2	187.	0.	-105.	0.	0.	0.	0.	0.	0.	-2.48	0.00	1.04	0.001	-0.002	0.000	0.000	
THERANC	3	201.	0.	-113.	0.	0.	0.	0.	0.	0.	-2.67	0.00	1.12	0.001	-0.002	0.000	0.000	
OCCMAX	4	4344.	0.	-843.	0.	0.	0.	0.	0.	0.	-0.29	0.00	-1.19	-0.001	0.002	0.000	0.000	
OCCMIN																		
MODFLEX	15	976.	0.	-12915.	0.	0.	0.	0.	0.	0.	0.21	0.00	0.94	0.001	-0.002	0.000	0.000	
MODFLEX	17	4527.	0.	-16580.	0.	0.	0.	0.	0.	0.	-2.47	0.00	1.09	0.001	-0.002	0.000	0.000	
MODFLEX	18	9322.	0.	-21719.	0.	0.	0.	0.	0.	0.	2.75	0.00	3.46	0.002	0.004	0.000	0.000	
											3.01	0.00	6.85	0.003	0.007	0.000	0.000	

CASE DESCRIPTION

TITLE

- 1 DEADWEIGHT  
10 1/2 SSE INERTIA  
11 SSE INERTIA  
2 NORMAL OPERATING  
3 THERMAL EXPAN + ANC MVMTS  
4 TIME HISTORY DYNAMIC FORCE  
15 MODFLEX  
17 MODFLEX  
18 MODFLEX
- DEADWEIGHT  
OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS  
SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS  
THERMAL ANALYSIS (NORMAL) 551 DEG F  
THERMAL ANALYSIS (MAXIMUM) 583 DEG F  
FT = FLUID TRANSIENT DUE TO TURBINE TRIP  
LC#1 MAX. VALUE (DWT, (DWT+TH NORM))  
LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))  
LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

ATTACHMENT NO. 4  
P6

Calc. 1 - 1 k.  
APP. 1

NUPIPE-SW ME-110  
VER 06 LEV 03  
91.350 17.12.52

STONE & WEBSTER ENGINEERING CORPORATION  
PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

PAGE 8 OF 18  
DATE 3/30/93  
JOB NO. 6343  
RUN NO. R0170023

\*\*\*\*\*  
\* POINT NO. 210 \*  
\* FUNCTION: RESTRAINT \*  
\*\*\*\*\*

PIPE SUPPORT SUMMARY

\*\*\*\*\*  
\* SUPPORT MARK NO. \*  
\* 1DB-H6 \*  
\*\*\*\*\*

GLOBAL		MINIMUM CLASS 2 STRESSES (PSI)				(FT) GLOBAL COORDINATES		
		EQ.8 7546.	EQ.9 11887.	EQ.10 811.	EQ.11 8357.	X COORD -106.94	Y COORD 153.83	Z COORD 99.17

LOAD TYPE	CASE	(PSI) MNS	FORCES (LBF) FX	FY	FZ	MOMENTS (FT-LBF) MX	MY	MZ	DEFLECTIONS (IN) DX	DY	DZ	ROTATIONS (RAD) RX	RY	RZ
DWT	1	873.	0.	-12284.	0.	0.	0.	0.	0.01	0.00	0.05	0.000	0.000	0.000
OBEI	10	3799.	0.	-4876.	0.	0.	0.	0.	0.15	0.00	1.95	0.001	0.003	0.001
OBEA NOT SPECIFIED														
SSEI	11	9117.	0.	-11702.	0.	0.	0.	0.	0.36	0.00	4.68	0.002	0.007	0.001
NORM	2	754.	0.	91.	0.	0.	0.	0.	-4.05	0.00	0.15	0.001	-0.002	0.000
THERANC	3	811.	0.	97.	0.	0.	0.	0.	-4.36	0.00	0.16	0.001	-0.002	0.000
OCCMAX	4	4341.	0.	-2104.	0.	0.	0.	0.	-0.29	0.00	-1.06	-0.001	-0.002	0.000
OCCMIN				1790.	0.	0.	0.	0.	0.21	0.00	1.02	0.001	0.002	0.000
MODFLEX	15	1153.	0.	-12284.	0.	0.	0.	0.	-4.04	0.00	0.20	0.000	-0.002	0.000
MODFLEX	17	5160.	0.	-17069.	0.	0.	0.	0.	4.33	0.00	2.15	0.001	0.005	0.001
MODFLEX	18	10231.	0.	-23986.	0.	0.	0.	0.	4.71	0.00	4.89	0.003	0.009	0.001

CASE DESCRIPTION TITLE

1	DEADWEIGHT	DEADWEIGHT
10	1/2 SSE INERTIA	OBEI MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS
11	SSE INERTIA	SSEI MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS
2	NORMAL OPERATING	THERMAL ANALYSIS (NORMAL) 551 DEG F
3	THERMAL EXPAN + ANC MVMTS	THERMAL ANALYSIS (MAXIMUM) 583 DEG F
4	TIME HISTORY DYNAMIC FORCE	FT = FLUID TRANSIENT DUE TO TURBINE TRIP
15	MODFLEX	LC#1 MAX. VALUE (DWT, (DWT+TH NORM))
17	MODFLEX	LC#2 ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))
18	MODFLEX	LC#3 ABS.SUM(DWT OR (DWT+TH MAX), SSEI)

ATTACHMENT NO. 4 p7  
Calc. 1-1 R.1  
APP. 1

PECO PBAPS UNIT#2 D3040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

## SYSTEM RESTRAINTS

## ORTHOGONAL RESTRAINTS

NODE	GROUP	TYPE	TRANSLATIONAL (LBF/IN)			ROTATIONAL (IN-LBF/RAD)			MARK NO.
			X	Y	Z	X	Y	Z	
5	1	ANCHOR	1.E+08	1.E+08	1.E+08				
75	1	RESTRAINT		1500.		1.E+10	1.E+10	1.E+10	1DB-H1
100	1	RESTRAINT		2160.					1DB-H2
105	1	SNUBBER	1.E+08						1DB-S2A
125	1	RESTRAINT		1.E+08					1DB-H3
140	1	RESTRAINT		1.E+08					1DB-H4
170	1	RESTRAINT		1.E+08					1DB-H5
210	1	RESTRAINT		1.E+08					1DB-H6
240*	1	RESTRAINT		1.					1DB-H7
250	1	SNUBBER			1.E+08				1DB-S7A
275*	1	RESTRAINT		1.					1DB-H9B
305	1	RESTRAINT		3000.					1DB-H10
325	1	RESTRAINT		2160.					1DB-H11
340	1	RESTRAINT		3000.					1DB-H12
370	1	RESTRAINT		2400.					1DB-H13
390	1	RESTRAINT		1.E+08		1.E+10			
390	1	SNUBBER	1.E+08		1.E+08		1.E+10	1.E+10	MSV-4 (INLET)
480	1	ANCHOR	1.E+08	1.E+08	1.E+08	1.E+10	1.E+10	1.E+10	

\* H7 AND H9B MODELED AS "SPRINGS" TO SIMULATE LOOPS A AND B

SEE NOTES 5 AND 12D IN MAIN BODY OF CALL FOR DETAILS

STIFFNESS OF 1.0 IS CONSERVATIVELY USED

ATTACHMENT NO. 4  
P8Calc. 1-1 P. 1  
APP. 1

NUPPIPE-SW ME-110  
VER 06 LEV 03

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C) PM-786 (RERATE) MS "D" MODELED AS "A/B"

3/30/93 PAGE 25  
JOB 6343 R0170023

NODAL LOADS

STATIC FORCES

NODE	THERMAL MODE	FORCES (LBF)			MOMENTS (FT-LBF)		
		X	Y	Z	X	Y	Z
75	1	0.	8887.	0.	0.	0.	0.
100	1	0.	6125.	0.	0.	0.	0.
305	1	0.	8697.	0.	0.	0.	0.
325	1	0.	6434.	0.	0.	0.	0.
340	1	0.	8571.	0.	0.	0.	0.
370	1	0.	7200.	0.	0.	0.	0.
275	1	0.	8657.*	0.	0.	0.	0.
240	1	0.	12492.*	0.	0.	0.	0.

\*BASED ON DWT LOAD FROM JOB 3823

Calc. 1-1 Rev. 1  
A 18.1  
ATTACHMENT NO. 4 p 9

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

## INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
1	0	0	0	0	0	0	0	0
2	PECO PBAPS UNIT#2	03040-NP(C)-PM-786	(RERATE)	MS "D"	MODELED AS "A/B"			
2	CONTROL	5	2.	1.	.001			
3	CONTROL		1.			1.		
4	FLEXAN	1	1	3.				
5	DEADWEIGHT							
6	FLEXAN	2	1	2.				
7	THERMAL ANALYSIS (NORMAL)	551	DEG F					
8	FLEXAN	3	2	2.				
9	THERMAL ANALYSIS (MAXIMUM)	583	DEG F					
10	FLEXAN	4	1	18.	300.	200.	3.	
11	FT = FLUID TRANSIENT DUE TO TURBINE TRIP							
12	FFLEXAN	5	1	5.	20.	20.	1.	
13	FFLEXAN	-1						
14	X DIRECTION OBE EARTHQUAKE							
15	FFLEXAN	6	1	6.	20.	20.	2.	
16	FFLEXAN	-1						
17	Y DIRECTION OBE EARTHQUAKE							
18	FFLEXAN	7	1	7.	20.	20.	1.	
19	FFLEXAN	-1						
20	Z DIRECTION OBE EARTHQUAKE							
21	MODFLEX	8	5	6	1.	1.	1.	
22	ABS(X+Y) OBE EARTHQUAKE							
23	MODFLEX	9	6	7	1.	1.	1.	
24	ABS(Y+Z) OBE EARTHQUAKE							
25	MODFLEX	10	8	9	1.	1.	4.	
26	OBEI	MAX OF ABS(X+Y) OR ABS(Y+Z) OBE EARTHQUAKE COMBINATIONS						
27	MODFLEX	11	10	2.4				
28	SSEI	MAX OF ABS(X+Y) OR ABS(Y+Z) SSE EARTHQUAKE COMBINATIONS						
29	MODFLEX	12	410	1.	1.	4.		
30	UPSET	MAX OF (OBEI OR FT)						
31	MOD	13	1	2	1.	1.		
32	ALG.SUM (DWT,TH NORM)							
33	MOD	14	1	3	1.	1.		
34	ALG.SUM (DWT,TH MAX)							
35	MOD	15	113	1.	1.	3.		
36	LC#1	MAX. VALUE (DWT,(DWT+TH NORM))						
37	MOD	16	114	1.	1.	3.		
38	MAX. VALUE (DWT,(DWT+TH MAX))							
39	MOD	17	1213	1.	1.	1.		
40	LC#2	ABS.SUM(DWT OR (DWT+TH NORM), (OBEI OR FT))						
41	MOD	18	1116	1.	1.	1.		
42	LC#3	ABS.SUM(DWT OR (DWT+TH MAX),SSEI)						
43	TITLE	1						
44	AMPLIFIED RESPONSE SPECTRA (ARS) - RB EL.135'-165',TB EL.150'- 165'.5% DAMPING							
45	SPEC	1	1	0.010	.12	.033	.12	.037 .15
46	SPEC	1	1	.045	.20	.077	.33	.100 .60
47	SPEC	1	1	.111	1.92	.125	1.92	.133 2.27
48	SPEC	1	1	.164	2.27	.167	2.09	.196 .64
49	SPEC	1	1	.244	.36	.435	.29	.833 .29
50	SPEC	1	1	1.220	.13	10.000	.00	

ATTACHMENT NO. 4 P/0

C L C . 1 - 1 R . 1  
A P . 1

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

## INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
51	0	0	0	0	0	0	0	0
52	SPEC	1	3	0.010	.10	.033	.10	.037 .15
53	SPEC	1	3	.045	.23	.071	.36	.091 .84
54	SPEC	1	3	.095	1.89	.111	1.89	.118 .93
55	SPEC	1	3	.122	1.09	.133	2.27	.164 2.27
56	SPEC	1	3	.167	2.09	.196	.64	.238 .39
57	SPEC	1	3	.500	.39	.769	.36	1.250 .12
58	TITLE	2		10.00	.00			
59	AMPLIFIED RESPONSE	SPECTRA (ARS)	- (2/3)	GROUND SPECTRA	.5%	DAMPING		
60	SPEC	2	2	.000	.043	.025	.043	.033 .06
61	SPEC	2	2	.050	.087	.100	.113	.111 .122
62	SPEC	2	2	.125	.133	.143	.153	.167 .167
63	SPEC	2	2	.182	.173	.222	.173	.250 .167
64	SPEC	2	2	.333	.153	.500	.113	1.000 .057
65	SPEC	2	2	10.000	.057			
66	XSE26STM	1		26.00	1.086	317.0	29.9	1115. 1.
67	XSE6"WT	2		6.625	.432	50.5	27.9	1115. 2.
68	XSEAOVDUM	3		26.00	1.086	.001	29.9	0. 3.
69	XSE14STM	4		14.00	.750	123.0	27.9	1115. 3.
70	XSE28STM	5		28.00	1.375	.001	29.9	1115. 3.
71	OPV551	1	1	27.04	.04120			
72	OPV551	1	2	26.04	.04120			
73	OPV583	2	1	26.82	.04433			
74	OPV583	2	2	25.82	.04433			
75	ANCHOR	5		-11.00	138.15	45.00		
76	MARKNO	FLUED	HEAD	PEN N-7D				
77	RUN	5	10			2.583	1.	1. 1.9
78	VALVE	10	15			3.583		
79	VALVE	15	20			1.250		
80	ELBOW	20	35					
81	DUMMY				.1521	.9884		
82	ELBOW	35	40			3.02		
83	DUMMY				.9884	.1521		
84	ELBOW	40	45					
85	RUN	45	54		.521			
86	RUN	54	56			4.161		
87	RUN	56	60			2.926		
88	RUN	60	65			5.074		
89	ELBOW	65	70					
90	RUN	70	75			5.833		
91	RESTRAINT		75		1500			
92	MARKNO	1DB-H1						
93	RUN	75	76			3.292		
94	RUN	76	80			5.403		
95	RUN	80	82			3.847		
96	RUN	82	90			5.542		
97	RUN	90	95			6.028		
98	RUN	95	100			6.028		
99	RESTRAINT		100		2160			
100	MARKNO	1DB-H2						

ATTACHMENT NO. 4 PII

Calc 1-1 R 1

NUPIPE-SW ME-110  
VER 06 LEV 03

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

3/30/93 PAGE 3  
JOB 6343 R0170023

INPUT DATA ECHO

STMT NUMBER		1	2	3	4	5	6	7	8
101	RUN	0	0	0	0	0	0	0	0
102	SNUBBER	100	105						
103	MARKNO	105		1.0E8					
104	RUN	105	110						
105	ELBOW	110	115						
106	RUN	115	125	-6.646					
107	RESTRAINT	125			1.0E8				
108	MARKNO	1DB-S2A							
109	RUN	125	130	-4.451					
110	RUN	130	135	-4.451					
111	RUN	135	140	-4.451					
112	RESTRAINT	140			1.0E8				
113	MARKNO	1DB-H4							
114	RUN	140	145	-6.295					
115	RUN	145	150	-6.295					
116	RUN	150	155	-6.295					
117	RUN	155	160	-6.295					
118	RUN	160	165	-6.295					
119	RUN	165	170	-6.295					
120	RESTRAINT	170			1.0E8				
121	MARKNO	1DB-H5							
122	RUN	170	175	-4.771					
123	RUN	175	180	-4.771					
124	RUN	180	185	-4.771					
125	RUN	185	190	-4.771					
126	RUN	190	195	-4.771					
127	RUN	195	200	-4.771					
128	RUN	200	205	-4.771					
129	RUN	205	210	-4.771					
130	RESTRAINT	210			1.0E8				
131	MARKNO	1DB-H6							
132	RUN	210	215	-6.333					
133	RUN	215	220	-6.333					
134	RUN	220	225	-6.333					
135	RUN	225	230	-6.333					
136	RUN	230	235	-6.333					
137	RUN	235	240	-6.333					
138	RESTRAINT	240			1.000				
139	MARKNO	1DB-H7							
140	RUN	240	245	-3.104					
141	RUN	245	250	-3.104					
142	SNUBBER	250							
143	MARKNO	1DB-S7A							
144	RUN	250	255	-4.594					
145	RUN	255	260	-4.594					
146	ELBOW	260	265						
147	RUN	265	270						
148	RUN	270	275						
149	RESTRAINT	275			1.000				
150	MARKNO	1DB-H9B							

ATTACHMENT NO. 4

P 12

Calc. 1-1 R. 1  
A/P.

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

## INPUT DATA ECHO

STMT NUMBER		1	2	3	4	5	6	7	8
151	RUN	275	280			5.108			
152	RUN	280	285			5.108			
153	RUN	285	290			5.108			
154	RUN	290	295			5.108			
155	RUN	295	300			5.108			
156	RUN	300	305			5.108			
157	RESTRAINT	305		3000					
158	MARKNO	1DB-H10							
159	RUN	305	310			6.047			
160	RUN	310	315			6.047			
161	RUN	315	320			6.047			
162	RUN	320	325			6.047			
163	RESTRAINT	325		2160					
164	MARKNO	1DB-H11							
165	RUN	325	330			4.325			
166	RUN	330	335			4.325			
167	RUN	335	340			4.325			
168	RESTRAINT	340		3000					
169	MARKNO	1DB-H12							
170	RUN	340	345			4.443			
171	ELBOW	345	350						
172	RUN	350	355			4.875			
173	RUN	355	360			5.049			
174	RUN	360	365			5.049			
175	RUN	365	370			5.049			
176	RESTRAINT	370		2400					
177	MARKNO	1DB-H13							
178	RUN	370	375			3.302			
179	RUN	375	380			3.302			
180	RUN	380	385			1.000			
181	RUN	385	390			1.000			
182	RESTRAINT	390							
183	SNUBBER	390		1.0E8		1.0E8		1.0E10	
184	MARKNO	MSV-4 (INLET)							
185	VALVE	15	25			-2.758		-2.758	
186	MVALVE	25	30			-3.960		-3.960	
187	RUN	35	36			-2.29		2.	
188	RUN	355	356			2.583		4.	
189	TEE	355	356			1.7			
190	RUN	385	386			-2.29		2.	
191	TEE	385	386			1.41			
192	VALVE	390	400			11.083		-12.646	
193	RUN	400	405			-11.927		5.	
194	RUN	405	410			-11.927		1.	
195	ELBOW	410	415			11.000			
196	RUN	415	425			17.958			
197	RUN	425	435			17.958			
198	ELBOW	435	440			11.000			
199	RUN	440	450			12.950			
200	RUN	450	455			12.950			

ATTACHMENT NO. 4 p 13  
 Calc. 1 - 1 R. 1  
 A pp. 1

NUPIPE-SW ME-110  
VER 06 LEV 03

STONE & WEBSTER ENGINEERING CORPORATION

3/30/93 PAGE 5  
JOB 6343 R0170023

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
201	0	0	0	12.950	0	0	0	0
202	RUN	455	460					
202	RUN	460	470					
203	ELBOW	470	475					
204	RUN	475	480					
205	ANCHOR	480		-4.08				
206	LMASS	10	54	56	76	82	105	125
207	LMASS	275	305	325	340	370		
208	LMASS	15	25	30	35	36	40	60
209	LMASS	90	95	100	110	130	135	145
210	LMASS	175	180	185	190	195	200	205
211	LMASS	245	255	260	270	280	285	290
212	LMASS	320	330	335	345	355	356	360
213	CWEVLVBODY		25		8060.			
214	CWEVLVOPER		30		2015.			
215	CWEHGR R5		40		580.			
216	CWEREST 4		54		1080.			
217	CWEREST 3		56		1080.			
218	CWEREST 2		76		1080.			
219	CWEREST 1		82		170.			
220	CWEHGR H1		75		109.			
221	CWEHGR H2		100		109.			
222	CWEHGR H11		325		109.			
223	CWEHGR H12		340		109.			
224	CWEHGR S2A		105		620.			
225	CWEHGR H3		125		330.			
226	CWEHGR H4		140		300.			
227	CWEHGR H5		170		300.			
228	CWEHGR H6		210		300.			
229	CWEHGR H7		240		300.			
230	CWEHGR H98		275		300.			
231	CWEHGR S7A		250		1450.			
232	CWEHGR H10		305		162.			
233	CWEHGR H13		370		220.			
234	CWE14"PIPE		356		1970.			
235	CWE4"PIPE		380		170.			
236	FORCE	1	75		8887.			
237	FORCE	1	100		6125.			
238	FORCE	1	305		8697.			
239	FORCE	1	325		6434.			
240	FORCE	1	340		8571.			
241	FORCE	1	370		7200.			
242	FORCE	1	275		8657.			
243	FORCE	1	240		12492.			
244	TFORCE	7	10			-.25		
245	TFORCE	8	15			-1.00		
246	TFORCE	9	65		-1.00			
247	TFORCE	10	110			-1.00		
248	TFORCE	11	260	1.00				
249	TFORCE	12	345			-1.00		
250	TFORCE	13	360	-1.00				

Calc. 1-1 k-1  
ATTACHMENT NO. 4 p14

NPIPE-SW ME-110  
VER 06 LEV 03

STONE & WEBSTER ENGINEERING CORPORATION

PECO PBAPS UNIT#2 03040-NP(C)-PM-786 (RERATE) MS "D" MODELED AS "A/B"

3/30/93 PAGE 6  
JOB 6343 R0170023

INPUT DATA ECHO

STMT NUMBER	1	2	3	4	5	6	7	8
251	9CN	0	0	0	0	0	0	0
252	9CF	1	12					
253	10CASES	2	3					
254	SUMMARY	1	2	3	4	10	11	
255	SUPPORT	1	10	11	2	3	4	15
256	STITLE						17	18
257	STITLE	MS "D" MODELED AS "A/B"						
258	STITLE	03040-NP(C)-PM-786						
259	ALLDONE							
260	STORED AS:	FCC.PM786.W09B7:072						
261	ALLDONE							

Calc 1 - 1 R - 1  
ATTACHMENT NO. 4 p 15

Calc. 1-1 Rev. 1  
APP 2 Computer run  
for V3 spring setting changes

E  
D  
C  
B  
A

Calc. 1-1 R.1  
03090-NP(c)-PM786  
ATTACHMENT 5 plot/

Calc. 1-1 REV. 1

APP. 1 Computer Run  
page 107 of 107

Boorum™

212-40 T

MADE IN U.S.A. PATENT NO. 3,643,360

\*\*\* ACTION REQUEST \*\*\*

Calc. 1-1 R-1  
APP. 2 page 1 of 126 PAGE: 01  
 A/R NUMBER : A1435406  
 A/R STATUS : ASIGND  
 STATUS DATE: 25SEP03  
 LAST UPDATE: 06OCT03  
 PRINT DATE : 12FEB04

A/R TYPE : EC ECR  
 REQUEST ORG : SMS  
 REQUEST DATE: 22SEP03  
 REQUESTED BY: WRIGHT, RM

EVALUATION NBR: 02  
 EVALUATING ORG: PEDM  
 EVAL ASIGND TO: KAZOUN, M MS OC  
 EVAL REQUEST ORG: PEX  
 EVAL REQUESTOR: KARASEK, M  
 EVAL RETURNED BY: JORDAN

ORIG DATE ASSIGNED: \_\_\_\_\_  
 EVAL DUE DATE: 30SEP03  
 DATE ASSIGNED: 23SEP03  
 EVAL STATUS : COMPLT

IMPORTANCE CODE: O OEAP: \_\_\_\_\_ SCHEDULE CODE: 3R14 DATE FIXED: \_\_\_\_\_

EVAL DESC: EVALUATE THE AS-FOUND CONDITIONS OF MAIN STEAM SUPPORTS  
 PLEASE PERFORM AN ENGINEERING EVALUATION OF THE AS-FOUND MACO 23SEP03  
 CONDITION OF THE MAIN STEAM SPRING HANGERS (1DB-H32, MACO 23SEP03  
 1DB-H34, 1DB-H43, 1DB-H44, AND 1DB-H46) AS DESCRIBED IN MACO 23SEP03  
 AR A1435400, A1435401, A1435403, A1435404, AND A1435406. MACO 23SEP03  
 THE RESULTS OF THE EVALUATION WILL BE USED TO DETERMINE MACO 23SEP03  
 IF ADDITIONAL SUPPORTS SHOULD BE INSPECTED TO MEET THE MACO 23SEP03  
 REQUIREMENTS FOR ASME SECTION XI INSPECTIONS FOR 3R14. MACO 23SEP03  
 IF REQUIRED, ADDITIONAL SUPPORTS WILL BE SELECTED IN MACO 23SEP03  
 ACCORDANCE WITH CODE CASE N-491-1 REQUIREMENTS. MACO 23SEP03  
 . MACO 23SEP03  
 . JSB2 26SEP03  
 . JSB2 26SEP03  
 . JSB2 26SEP03  
 . JSB2 26SEP03

ENGINEERING TECHNICAL EVALUATION

JSB2 26SEP03  
 JSB2 26SEP03  
 JSB2 26SEP03  
 JSB2 26SEP03  
 JSB2 26SEP03

REASON FOR EVALUATION / SCOPE JSB2 26SEP03  
 . JSB2 26SEP03  
 . JSB2 26SEP03  
 . JSB2 26SEP03  
 THE ISI PROGRAM MANAGER HAS REQUESTED ENGINEERING TO JSB2 26SEP03  
 EVALUATE THE AS-FOUND SPRING SETTINGS FOR MAIN STEAM JSB2 26SEP03  
 SUPPORTS 1DB-H32, 1DB-H34, 1DB-H43, 1DB-H44, AND 1DB-H46. JSB2 26SEP03  
 THE SUBJECT SUPPORTS WERE FOUND TO BE BEYOND THE 10% JSB2 26SEP03  
 ACCEPTANCE TOLERANCE BASED ON THE ISI INSPECTION PROGRAM. JSB2 26SEP03  
 INFORMATION FOR THESE SUPPORTS IS PROVIDED IN A/R'S JSB2 26SEP03  
 A1435400, A1435401, A1435403, A1435404, AND A1435406. JSB2 26SEP03  
 . JSB2 26SEP03  
 . JSB2 26SEP03

JSB2 26SEP03

DETAILED EVALUATION

JSB2 26SEP03

JSB2 26SEP03

JSB2 26SEP03

THE ABOVE-IDENTIFIED SUPPORTS ARE PART OF THE (4) MAIN JSB2 26SEP03  
 STEAM SYSTEM PIPING, OUTSIDE PRIMARY CONTAINMENT, WHICH JSB2 26SEP03  
 RUNS FROM THE CONTAINMENT PENETRATION (N-7A,B,C,D), JSB2 26SEP03  
 THROUGH THE MSIV VALVES (AO-86A,B,C,D) TO THE TURBINE JSB2 26SEP03  
 STOP VALVES AND CONTROL VALVES, TO THE HIGH-PRESSURE JSB2 26SEP03  
 TURBINE INLET. BASED ON INFORMATION PROVIDED TO JSB2 26SEP03  
 ENGINEERING A NUMBER OF TASKS WERE PERFORMED TO ADDRESS JSB2 26SEP03  
 THIS ISSUE: JSB2 26SEP03

JSB2 26SEP03

JSB2 26SEP03

JSB2 26SEP03

i. A WALKDOWN WAS REQUESTED AND PERFORMED (BY NDE) TO

JSB2 26SEP03

## \*\*\* ACTION REQUEST \*\*\*

PAGE: 02

A/R TYPE : EC ECR  
 REQUEST ORG : SMS  
 REQUEST DATE: 22SEP03  
 REQUESTED BY: WRIGHT, RM

A/R NUMBER : A1435406  
 A/R STATUS : ASIGND  
 STATUS DATE: 25SEP03  
 LAST UPDATE: 06OCT03  
 PRINT DATE : 12FEB04

VERIFY COLD SETTINGS ON ALL SPRING CANS ON THE MAIN STEAM JSB2 26SEP03  
 PIPING OUTSIDE CONTAINMENT. JSB2 26SEP03

2. A PIPING ANALYSIS CALCULATION IS PRESENTLY NOT JSB2 26SEP03  
 AVAILABLE. THEREFORE, A NEW ME-101 ANALYSIS WAS JSB2 26SEP03  
 RECREATED, OR RECONSTITUTED, MODELING THE MAIN STEAM JSB2 26SEP03  
 PIPING, INCLUDING THE STOP VALVES, CONTROL VALVES AND JSB2 26SEP03  
 BYPASS VALVES. THE MODELING WAS BASED ON THE HISQ (HSQ) JSB2 26SEP03  
 DRAWINGS, SUPPORT DETAIL DRAWINGS, AND GE DRAWINGS FOR JSB2 26SEP03  
 THE STOP AND CONTROL VALVES, AND PIPE ROUTING BETWEEN THE JSB2 26SEP03  
 STOP AND CONTROL VALVES TO THE HP TURBINE INLETS. JSB2 26SEP03

3. TWO ANALYSES WERE PERFORMED: JSB2 26SEP03  
 - FIRST ANALYSIS IS PERFORMED USING DESIGN JSB2 26SEP03  
 SETTINGS FOR ALL SPRING HANGERS IN THE JSB2 26SEP03  
 MAIN STEAM SYSTEM OUTSIDE CONTAINMENT, BASED JSB2 26SEP03  
 ON DESIGN DETAIL DRAWINGS. JSB2 26SEP03  
 - SECOND ANALYSIS IS PERFORMED USING JSB2 26SEP03  
 AS-FOUND SETTINGS FOR THE SPRINGS, BASED ON JSB2 26SEP03  
 INFORMATION OBTAINED FROM THE NDE WALKDOWN. JSB2 26SEP03  
 - IT SHOULD BE NOTED THAT (2) SUPPORTS WERE NOT JSB2 26SEP03  
 ACCESSIBLE DURING THE WALKDOWN PERFORMED BECAUSE JSB2 26SEP03  
 OF SCAFFOLDING (7DB-H74 AND 7DBH77). FOR THESE JSB2 26SEP03  
 TWO SUPPORTS, THE DESIGN VALUES WERE USED FOR COLD JSB2 26SEP03  
 SETTINGS. IT WAS JUDGED THAT THE USE OF DESIGN JSB2 26SEP03  
 VALUES VERSUS AS-FOUND VALUES WILL NOT ADVERSELY JSB2 26SEP03  
 AFFECT THE RESULTS OF THE ANALYSIS. JSB2 26SEP03

4. FOR THE IDENTIFIED CONDITION, THE ISSUE OF CONCERN IS JSB2 26SEP03  
 NORMAL OPERATING CONDITIONS, SINCE SPRING HANGERS HAVE JSB2 26SEP03  
 RELATIVELY LOW STIFFNESS, AND PROVIDE LITTLE RESISTANCE JSB2 26SEP03  
 DURING A SEISMIC EVENT. THEREFORE, THE ME-101 ANALYSIS JSB2 26SEP03  
 PERFORMED EVALUATES THE SUPPORTS FOR DEADWEIGHT AND JSB2 26SEP03  
 THERMAL LOADS ONLY. JSB2 26SEP03

5. DESIGN ATTRIBUTES (CC-AA-102) CONSIDERED FOR THIS JSB2 26SEP03  
 TECHNICAL EVALUATION ARE: JSB2 26SEP03

BASIS FUNCTION JSB2 26SEP03  
 ----- JSB2 26SEP03

THE MAIN STEAM SYSTEM IS DESIGNED: JSB2 26SEP03  
 ----- JSB2 26SEP03

- TO DELIVER STEAM FROM THE NUCLEAR BOILER TO THE MAIN JSB2 26SEP03  
 TURBINE AT RATED FLOW, TEMPERATURE, AND PRESSURE FROM JSB2 26SEP03  
 TURBINE WARM-UP TO VALVES WIDE OPEN. JSB2 26SEP03

- TO PROVIDE STEAM TO THE STEAM JET AIR EJECTORS JSB2 26SEP03  
 (SJAES), STEAM SEAL REGULATOR, REACTOR FEED PUMP JSB2 26SEP03  
 TURBINES (RFPT'S), OFF GAS RECOMBINER PREHEATER, AND JSB2 26SEP03  
 CONDENSER HOTWELL DEAERATING STEAM COILS. JSB2 26SEP03

- TO BYPASS STEAM TO THE CONDENSERS DURING STARTUP AND JSB2 26SEP03

## \*\*\* ACTION REQUEST \*\*\*

PAGE: 03

A/R TYPE : EC ECR  
 REQUEST ORG : SMS  
 REQUEST DATE: 22SEP03  
 REQUESTED BY: WRIGHT, RM

A/R NUMBER : A1435406  
 A/R STATUS : ASIGND  
 STATUS DATE: 25SEP03  
 LAST UPDATE: 06OCT03  
 PRINT DATE : 12FEB04

WHEN REACTOR STEAM PRODUCTION IS GREATER THAN REQUIRED BY JSB2 26SEP03  
 THE TURBINE-GENERATOR. JSB2 26SEP03  
 JSB2 26SEP03

THE MAIN STEAM SYSTEM CONSISTS OF FOUR 26-INCH CARBON JSB2 26SEP03  
 STEEL LINES FROM THE OUTBOARD MAIN STEAM ISOLATION VALVES JSB2 26SEP03  
 (MSIV'S) TO THE TURBINE STOP VALVES. FOUR MAIN STEAM JSB2 26SEP03  
 LINES ARE USED TO SUPPLY STEAM TO THE MAIN TURBINE. THIS JSB2 26SEP03  
 ALSO PERMITS TESTING OF INDIVIDUAL TURBINE STOP VALVES JSB2 26SEP03  
 AND MSIVS WITH ONLY A MINIMUM LOAD REDUCTION. EACH MAIN JSB2 26SEP03  
 STEAM LINE ALSO HAS A 14-INCH PRESSURE EQUALIZING LINE JSB2 26SEP03  
 THAT CONNECTS TO A BYPASS VALVE CHEST VIA TWO 18-INCH JSB2 26SEP03  
 HEADERS. THE BYPASS VALVES DIRECT STEAM TO THE MAIN JSB2 26SEP03  
 CONDENSER IN ORDER TO PREVENT AN OVERPRESSURE CONDITION JSB2 26SEP03  
 AND SUBSEQUENT OPENING OF THE SAFETY RELIEF VALVES JSB2 26SEP03  
 (SRV'S) AT ANY TIME WHEN REACTOR STEAM PRODUCTION EXCEEDS JSB2 26SEP03  
 TURBINE-GENERATOR REQUIREMENTS SUCH AS TURBINE STARTUP, JSB2 26SEP03  
 SHUTDOWN, ELECTRIC LOAD REJECTION, OR TURBINE TRIP. JSB2 26SEP03  
 JSB2 26SEP03

THE ABOVE PIPING IS THE PART OF THE MAIN STEAM SYSTEM JSB2 26SEP03  
 AFFECTED BY THIS TECHNICAL EVAL. QUALIFICATION OF PIPING JSB2 26SEP03  
 AND SUPPORT STRESSES TO WITHIN APPLICABLE CODE JSB2 26SEP03  
 REQUIREMENTS ENSURES PRESSURE BOUNDARY FUNCTION, AND THAT JSB2 26SEP03  
 THE SYSTEM WILL PERFORM ITS DESIGN FUNCTION. JSB2 26SEP03  
 JSB2 26SEP03

SEISMIC/SAFETY/ISI CLASSIFICATION JSB2 26SEP03  
 JSB2 26SEP03

THE Affected PORTION OF THE MAIN STEAM PIPING IS JSB2 26SEP03  
 CLASSIFIED AS SAFETY RELATED, ISI, AND SEISMIC. FOR JSB2 26SEP03  
 PURPOSES OF THIS TECHNICAL EVALUATION THE Affected JSB2 26SEP03  
 SUPPORTS ARE SAFETY RELATED AND ISI, BUT ARE NOT JSB2 26SEP03  
 TYPICALLY DESIGNED TO PROVIDE SEISMIC RESTRAINT SINCE JSB2 26SEP03  
 SPRING HANGERS HAVE RELATIVELY LOW STIFFNESS AS COMPARED JSB2 26SEP03  
 TO RIGID SUPPORTS. SPRING HANGERS ARE GENERALLY DESIGNED JSB2 26SEP03  
 IN A SYSTEM TO ALLOW FREEDOM OF MOVEMENT OF THE PIPING JSB2 26SEP03  
 FOR HIGH TEMPERATURE SYSTEMS, SUCH AS MAIN STEAM. JSB2 26SEP03  
 SNUBBERS, OR DYNAMIC LOCKING RESTRAINTS ARE TYPICALLY JSB2 26SEP03  
 DESIGNED WITHIN A SYSTEM TO COMPLIMENT SPRING HANGERS. JSB2 26SEP03  
 THE Affected PORTION OF THE MS SYSTEM IS ALSO PROVIDED JSB2 26SEP03  
 WITH SNUBBERS TO PROVIDE RESTRAINT FOR THE PIPING AGAINST JSB2 26SEP03  
 DYNAMIC EVENTS. RIGID SUPPORTS ARE EVALUATED TO ENSURE JSB2 26SEP03  
 NO SIGNIFICANT EFFECT AS A RESULT OF THE IDENTIFIED JSB2 26SEP03  
 CONDITION. THEREFORE, THE DYNAMIC CONFIGURATION (AND JSB2 26SEP03  
 CONSEQUENTLY B31.1 CODE EQ'S 12U AND 12F) IS NOT CHANGED JSB2 26SEP03  
 BY THIS ACTIVITY. JSB2 26SEP03

SPECIFICATIONS JSB2 26SEP03  
 JSB2 26SEP03

PER SPECIFICATION M-300, THE FOLLOWING ARE DESIGN JSB2 26SEP03  
 CONDITIONS FOR THE MAIN STEAM PIPING: JSB2 26SEP03

MS & TURBINE: JSB2 26SEP03  
 JSB2 26SEP03

JSB2 26SEP03

**\*\*\* ACTION REQUEST \*\*\***

PAGE: 04

A/R TYPE : EC ECR  
REQUEST ORG : SMS  
REQUEST DATE: 22SEP03  
REQUESTED BY: WRIGHT, RM

A/R NUMBER : A1435406  
A/R STATUS : ASIGND  
STATUS DATE: 25SEP03  
LAST UPDATE: 06OCT03  
PRINT DATE : 12FEB04

## \*\*\* ACTION REQUEST \*\*\*

PAGE: 05

A/R TYPE : EC ECR  
 REQUEST ORG : SMS  
 REQUEST DATE: 22SEP03  
 REQUESTED BY: WRIGHT, RM

A/R NUMBER : A1435406  
 A/R STATUS : ASIGND  
 STATUS DATE: 25SEP03  
 LAST UPDATE: 06OCT03  
 PRINT DATE : 12FEB04

- SUPPORT LOADS ARE WITHIN DESIGN LOADS PROVIDED IN JSB2 26SEP03  
 THE ASSOCIATED SUPPORT DETAIL DRAWING. JSB2 26SEP03

- IF THE ABOVE ARE NOT MET REVIEW SUPPORTS TO VERIFY JSB2 26SEP03  
 QUALIFICATION TO THE APPLICABLE CODES AND JSB2 26SEP03  
 STANDARDS. JSB2 26SEP03

D. IT SHOULD BE NOTED THAT (2) EVALUATIONS WERE RUN. JSB2 26SEP03  
 THE FIRST WAS TO INPUT THE AS-FOUND SPRING COLD LOADS, JSB2 26SEP03  
 AND COMPARE THOSE LOADS WITH A LOAD CASE WHICH INPUTS THE JSB2 26SEP03  
 AS DESIGN COLD LOADS. THE SECOND ANALYSIS TOOK THE JSB2 26SEP03  
 AS-FOUND COLD LOADS, AND COMPUTATED NEW HOT LOADS, BASED JSB2 26SEP03  
 ON THE DIFFERENCES BETWEEN HOT AND COLD LOADS AS PROVIDED JSB2 26SEP03  
 IN THE DESIGN DRAWINGS. THE NEW HOT LOADS ARE EVALUATED JSB2 26SEP03  
 FOR CONFORMANCE AS DESCRIBED ABOVE. JSB2 26SEP03

. JSB2 26SEP03  
 THE ABOVE CONDITIONS WILL BE DOCUMENTED IN THIS TECH JSB2 26SEP03  
 EVAL, AND THE RECONSTITUTED STRESS ANALYSIS FOR CALC 1-1 JSB2 26SEP03  
 WHICH WILL CONSIDER THE AS-FOUND SPRING SETTINGS. JSB2 26SEP03

. JSB2 26SEP03  
 WALKDOWNS JSB2 26SEP03

WALKDOWNS ARE PERFORMED TO VERIFY THE FIELD COLD LOAD JSB2 26SEP03  
 SETTINGS ON ALL SPRINGS WITHIN THE AFFECTED PORTION OF JSB2 26SEP03  
 THE MAIN STEAM SYSTEM TO BE USED FOR INPUT TO THE ME-101 JSB2 26SEP03  
 COMPUTER ANALYSIS. JSB2 26SEP03

. JSB2 26SEP03  
 6. ME-101 RESULTS: JSB2 26SEP03  
 THE RESULTS OF THE ANALYSES WERE COMPARED TO IDENTIFY ANY JSB2 26SEP03  
 SIGNIFICANT CHANGES IN THE PIPING SYSTEM OR STRESSES. IN JSB2 26SEP03  
 ADDITION, RESULTS OF THE AS FOUND ANALYSIS WERE EVALUATED JSB2 26SEP03  
 FOR CODE ACCEPTABILITY, AND AGAINST DESIGN SUPPORT JSB2 26SEP03  
 LOADINGS BASED ON SUPPORT DRAWINGS. THE FOLLOWING ARE JSB2 26SEP03  
 RESULTS OF THE EVALUATION: JSB2 26SEP03

. JSB2 26SEP03  
 A. PIPING STRESSES ARE WELL WITHIN B31.1 CODE JSB2 26SEP03  
 REQUIREMENTS FOR EQUATION 11. THE MAXIMUM STRESS WAS JSB2 26SEP03  
 IDENTIFIED TO BE AT THE INLET NOZZLE TO THE "B" MSV (NODE JSB2 26SEP03  
 BSV), AND IS 8365 PSI, WHICH IS LESS THAN THE CODE JSB2 26SEP03  
 ALLOWABLE OF 15,000 PSI. THE RESULTING MARGIN IS 0.44. JSB2 26SEP03  
 THIS ANALYSIS WAS FOR EVALUATION OF HOT LOAD SETTINGS. JSB2 26SEP03  
 THE COLD LOADS RESULTS ARE ENVELOPED BY THE HOT LOADS, JSB2 26SEP03  
 AND NEED NO FURTHER EVALUATION. JSB2 26SEP03

. JSB2 26SEP03  
 B. PIPING WEIGHT MOVEMENTS WERE REVIEWED AND FOUND TO BE JSB2 26SEP03  
 SMALL AND ACCEPTABLE. MOST PIPE MOVEMENTS ARE LESS THAN JSB2 26SEP03  
 0.1". THE MOVEMENTS IN THE VICINITY OF HANGERS H10 TO JSB2 26SEP03  
 H12 (A LOOP), AND H22 (B LOOP) ARE SLIGHTLY GREATER THAN JSB2 26SEP03  
 0.10", BUT ARE LESS THAN 0.150", AND ARE CONSIDERED TO BE JSB2 26SEP03  
 ACCEPTABLE GIVEN THE PIPE SIZE, THE LENGTH OF RUN OF THE JSB2 26SEP03  
 PIPING, AND CONSIDERING THAT THE PIPING IS ALREADY IN ITS JSB2 26SEP03  
 AS-INSTALLED STATE. JSB2 26SEP03

. JSB2 26SEP03  
 C. REVIEW OF SUPPORT LOADS FOUND MINIMAL EFFECT ON THE JSB2 26SEP03

## \*\*\* ACTION REQUEST \*\*\*

PAGE: 06

A/R TYPE : EC ECR  
 REQUEST ORG : SMS  
 REQUEST DATE: 22SEP03  
 REQUESTED BY: WRIGHT, RM

A/R NUMBER : A1435406  
 A/R STATUS : ASIGNRD  
 STATUS DATE: 25SEP03  
 LAST UPDATE: 06OCT03  
 PRINT DATE : 12FEB04

SPRING SUPPORTS, AND THAT MOST RIGID SUPPORTS HAD NO OR JSB2 26SEP03  
 INSIGNIFICANT CHANGES (< 10%). ALL SUPPORT LOADINGS WERE JSB2 26SEP03  
 REVIEWED AGAINST DESIGN LOADS PROVIDED ON THE ASSOCIATED JSB2 26SEP03  
 SUPPORT DETAILS (SEE REFERENCE SUPPORT DRAWINGS). MOST JSB2 26SEP03  
 SUPPORTS WERE IDENTIFIED TO HAVE LOADS LESS THAN OR JSB2 26SEP03  
 WITHIN 10% OF THE APPROXIMATED LOADING ON THE SUPPORT JSB2 26SEP03  
 DETAIL DRAWINGS. NO SUPPORTS WERE IDENTIFIED TO HAVE JSB2 26SEP03  
 LOADS THAT EXCEEDED THE MAXIMUM LOADING ON THE SUPPORT JSB2 26SEP03  
 DETAILS. BASED ON THESE RESULTS, THE AS-FOUND CONDITIONS JSB2 26SEP03  
 ARE CONCLUDED TO BE ACCEPTABLE. FOLLOW UP ACTIONS ARE JSB2 26SEP03  
 DISCUSSED IN THE CONCLUSIONS OF THIS TECH EVAL. JSB2 26SEP03

.

.

**CONCLUSIONS / FINDINGS** JSB2 26SEP03  
 ----- JSB2 26SEP03  
 . JSB2 26SEP03

BASED ON THE EVALUATION PERFORMED, THE AS FOUND CONDITION JSB2 26SEP03  
 OF SUPPORTS 1DB-H32, 1DB-H34, 1DB-H43, 1DB-H44, AND JSB2 26SEP03  
 1DB-H46 ARE FOUND TO BE ACCEPTABLE WITH NO CORRECTIVE JSB2 26SEP03  
 ACTIONS REQUIRED. IN ADDITION, THE AS-FOUND SETTINGS FOR JSB2 26SEP03  
 ALL MAIN STEAM SUPPORTS ARE CONCLUDED TO BE ACCEPTABLE JSB2 26SEP03  
 BASED ON THE ME-101 RESULTS. PIPING STRESSES ARE WITHIN JSB2 26SEP03  
 CODE REQUIREMENTS, AND HANGER LOADS ARE CONCLUDED TO BE JSB2 26SEP03  
 WITHIN DESIGN LOADINGS PROVIDED ON THE HANGER DETAIL JSB2 26SEP03  
 DRAWINGS. THE FOLLOWING FOLLOW-UP ACTIONS NEED TO BE JSB2 26SEP03  
 PERFORMED AS A RESULT OF THIS THE IDENTIFIED CONDITION, JSB2 26SEP03  
 AND THIS TECHNICAL EVALUATION: JSB2 26SEP03

.

1. PROVIDE RECONSTITUTED STRESS CALCULATION FOR 1-1. JSB2 26SEP03  
 THE CALCULATION SHOULD DOCUMENT THE AS-FOUND SETTINGS, JSB2 26SEP03  
 AND THE SEISMIC EVALUATION. JSB2 26SEP03

.

2. PROVIDE DOCUMENTATION OF EVALUATION OF MAIN STEAM JSB2 26SEP03  
 SUPPORTS. JSB2 26SEP03

.

3. AFTER PERFORMING STRESS AND SUPPORT ANALYSIS, UPDATE JSB2 26SEP03  
 DRAWINGS WITH THE AS-FOUND SETTINGS. THE DRAWING UPDATE JSB2 26SEP03  
 SHOULD INCLUDE THE SETTINGS PROVIDED AS FOLLOW UP JSB2 26SEP03  
 WALKDOWN OF ALL SUPPORTS ON THE MAIN STEAM PIPING TO JSB2 26SEP03  
 TURBINE. JSB2 26SEP03

.

4. ECR 03-00525 HAS BEEN GENERATED TO PERFORM THE ABOVE JSB2 26SEP03  
 FOLLOW UP ACTIONS. THE ECR IS ASSIGNED TO PEDM. JSB2 26SEP03

.

.

**REFERENCES** JSB2 26SEP03

----- JSB2 26SEP03

.

1. ME-101 VERSION N2, MAY, 1993 JSB2 26SEP03

2. ANSI B31.1 POWER PIPING CODE, 1973 INCLUDING S73 JSB2 26SEP03

ADDENDA JSB2 26SEP03

3. ISO DRAWINGS: JSB2 26SEP03

## \*\*\* ACTION REQUEST \*\*\*

PAGE: 07

A/R TYPE : EC ECR  
 REQUEST ORG : SMS  
 REQUEST DATE: 22SEP03  
 REQUESTED BY: WRIGHT, RM

A/R NUMBER : A1435406  
 A/R STATUS : ASIGND  
 STATUS DATE: 25SEP03  
 LAST UPDATE: 06OCT03  
 PRINT DATE : 12FEB04

A. HSO 171 REV. 2	JSB2 26SEP03
B. HSO 172 REV. 1	JSB2 26SEP03
C. HSO 173 REV. 1	JSB2 26SEP03
D. HSO 174 REV. 1	JSB2 26SEP03
E. HSO 760 REV. 2	JSB2 26SEP03
4. HANGER DRAWINGS: (A LOOP)	JSB2 26SEP03
A. M-2012 SHEET 1 REV. 2	JSB2 26SEP03
B. M-2012 SHEET 2 REV. 0	JSB2 26SEP03
C. M-2012 SHEET 3 REV. 0	JSB2 26SEP03
D. M-2012 SHEET 4 REV. 0	JSB2 26SEP03
E. M-2012 SHEET 5 REV. 0	JSB2 26SEP03
F. M-2012 SHEET 6 REV. 0	JSB2 26SEP03
G. M-2012 SHEET 7 REV. 0	JSB2 26SEP03
H. M-2012 SHEET 9 REV. 1	JSB2 26SEP03
I. M-2012 SHEET 10 REV. 0	JSB2 26SEP03
J. M-2012 SHEET 11 REV. 0	JSB2 26SEP03
K. M-2012 SHEET 12 REV. 0	JSB2 26SEP03
L. M-2012 SHEET 13 REV. 0	JSB2 26SEP03
M. M-2012 SHEET 14 REV. 0	JSB2 26SEP03
N. M-2012 SHEET 15 REV. 1	JSB2 26SEP03
O. M-2012 SHEET 16 REV. 1	JSB2 26SEP03
P. M-2012 SHEET 17 REV. 1	JSB2 26SEP03
5. HANGER DRAWINGS: (B LOOP)	JSB2 26SEP03
A. M-2013 SHEET 1 REV. 1	JSB2 26SEP03
B. M-2013 SHEET 2 REV. 0	JSB2 26SEP03
C. M-2013 SHEET 3 REV. 0	JSB2 26SEP03
D. M-2013 SHEET 4 REV. 0	JSB2 26SEP03
E. M-2013 SHEET 5 REV. 0	JSB2 26SEP03
F. M-2013 SHEET 6 REV. 0	JSB2 26SEP03
G. M-2013 SHEET 7 REV. 0	JSB2 26SEP03
H. M-2013 SHEET 8 REV. 0	JSB2 26SEP03
I. M-2013 SHEET 9 REV. 0	JSB2 26SEP03
J. M-2013 SHEET 10 REV 0	JSB2 26SEP03
K. M-2013 SHEET 11 REV 0	JSB2 26SEP03
L. M-2013 SHEET 12 REV 0	JSB2 26SEP03
M. M-2013 SHEET 13 REV 0	JSB2 26SEP03
N. M-2013 SHEET 14 REV 0	JSB2 26SEP03
6. HANGER DRAWINGS: (C LOOP)	JSB2 26SEP03
A. M-2014 SHEET 1 REV. 1	JSB2 26SEP03
B. M-2014 SHEET 2 REV. 0	JSB2 26SEP03
C. M-2014 SHEET 3 REV. 0	JSB2 26SEP03
D. M-2014 SHEET 4 REV. 0	JSB2 26SEP03
E. M-2014 SHEET 5 REV. 0	JSB2 26SEP03
F. M-2014 SHEET 6 REV. 0	JSB2 26SEP03
G. M-2014 SHEET 7 REV. 0	JSB2 26SEP03
H. M-2014 SHEET 8 REV. 0	JSB2 26SEP03
I. M-2014 SHEET 9 REV. 0	JSB2 26SEP03
J. M-2014 SHEET 10 REV 0	JSB2 26SEP03
K. M-2014 SHEET 11 REV 0	JSB2 26SEP03
L. M-2014 SHEET 12 REV 0	JSB2 26SEP03
M. M-2014 SHEET 13 REV 0	JSB2 26SEP03
N. M-2014 SHEET 14 REV 0	JSB2 26SEP03

## \*\*\* ACTION REQUEST \*\*\*

PAGE: 08

A/R TYPE : EC ECR  
 REQUEST ORG : SMS  
 REQUEST DATE: 22SEP03  
 REQUESTED BY: WRIGHT, RM

A/R NUMBER : A1435406  
 A/R STATUS : ASIGND  
 STATUS DATE: 25SEP03  
 LAST UPDATE: 06OCT03  
 PRINT DATE : 12FEB04

## O. M-2014 SHEET 15 REV 0

JSB2 26SEP03

JSB2 26SEP03

## A. M-2014 SHEET 1 REV. 1

JSB2 26SEP03

## B. M-2014 SHEET 2 REV. 0

JSB2 26SEP03

## C. M-2014 SHEET 3 REV. 0

JSB2 26SEP03

## D. M-2014 SHEET 4 REV. 0

JSB2 26SEP03

## E. M-2014 SHEET 5 REV. 0

JSB2 26SEP03

## F. M-2014 SHEET 6 REV. 0

JSB2 26SEP03

## G. M-2014 SHEET 7 REV. 0

JSB2 26SEP03

## H. M-2014 SHEET 8 REV. 0

JSB2 26SEP03

## I. M-2014 SHEET 9 REV. 0

JSB2 26SEP03

## J. M-2014 SHEET 10 REV 0

JSB2 26SEP03

## K. M-2014 SHEET 11 REV 0

JSB2 26SEP03

## L. M-2014 SHEET 12 REV 0

JSB2 26SEP03

## M. M-2014 SHEET 13 REV 0

JSB2 26SEP03

## N. M-2014 SHEET 14 REV 0

JSB2 26SEP03

## O. M-2014 SHEET 15 REV 0

JSB2 26SEP03

## 8. HANGER DRAWINGS: (C LOOP)

JSB2 26SEP03

## A. M-2014 SHEET 1 REV. 1

JSB2 26SEP03

## B. M-2014 SHEET 2 REV. 0

JSB2 26SEP03

## C. M-2014 SHEET 3 REV. 0

JSB2 26SEP03

## D. M-2014 SHEET 4 REV. 0

JSB2 26SEP03

## E. M-2014 SHEET 5 REV. 0

JSB2 26SEP03

## F. M-2014 SHEET 6 REV. 0

JSB2 26SEP03

## G. M-2014 SHEET 7 REV. 0

JSB2 26SEP03

## H. M-2014 SHEET 8 REV. 0

JSB2 26SEP03

## I. M-2014 SHEET 9 REV. 0

JSB2 26SEP03

## J. M-2014 SHEET 10 REV 0

JSB2 26SEP03

## K. M-2014 SHEET 11 REV 0

JSB2 26SEP03

## L. M-2014 SHEET 12 REV 0

JSB2 26SEP03

## M. M-2014 SHEET 13 REV 0

JSB2 26SEP03

## N. M-2014 SHEET 14 REV 0

JSB2 26SEP03

## O. M-2014 SHEET 15 REV 0

JSB2 26SEP03

## P. M-2014 SHEET 16 REV 0

JSB2 26SEP03

## Q. M-2014 SHEET 17 REV 0

JSB2 26SEP03

## R. M-2014 SHEET 18 REV 0

JSB2 26SEP03

## S. M-2014 SHEET 19 REV 0

JSB2 26SEP03

## T. M-2014 SHEET 20 REV 0

JSB2 26SEP03

## 8. SYSTEM 7 HANGER DRAWINGS:

JSB2 26SEP03

## A. M-2019 SHEET 1 REV. 0

JSB2 26SEP03

## B. M-2019 SHEET 2 REV. 0

JSB2 26SEP03

## C. M-2019 SHEET 3 REV. 0

JSB2 26SEP03

## D. M-2019 SHEET 4 REV. 0

JSB2 26SEP03

## E. M-2019 SHEET 5 REV. 0

JSB2 26SEP03

## F. M-2019 SHEET 6 REV. 0

JSB2 26SEP03

## 9. OTHER DRAWINGS:

JSB2 26SEP03

## A. M-2-B31-1 SHEET 1

JSB2 26SEP03

## B. M-2-B31-1 SHEET 2

JSB2 26SEP03

## C. M-190 REV. 2

JSB2 26SEP03

## D. S-256 REV. 6

JSB2 26SEP03

## E. S-258 REV. 4

JSB2 26SEP03

## F. M-1-R-12 REV. 6 SHEETS 1 &amp; 2

JSB2 26SEP03

## \*\*\* ACTION REQUEST \*\*\*

PAGE: 09

A/R TYPE : EC ECR  
 REQUEST ORG : SMS  
 REQUEST DATE: 22SEP03  
 REQUESTED BY: WRIGHT, RM

A/R NUMBER : A1435406  
 A/R STATUS : ASIGND  
 STATUS DATE: 25SEP03  
 LAST UPDATE: 06OCT03  
 PRINT DATE : 12FEB04

G. M-1-R-12 SHEET 3 REV. 0	JSB2 26SEP03
H. M-2-B31-1 SHEET 1	JSB2 26SEP03
I. M-2-B31-1 SHEET 1	JSB2 26SEP03
J. M-2-76-D-13 SHEETS 1 & 2	JSB2 26SEP03
10. GRINNELL PIPE HANGER, CATALOG PH-90	JSB2 26SEP03
11. SPEC M-300 REV. 16	JSB2 26SEP03
12. DBD PS-45 REV. 15	JSB2 26SEP03
13. PIPING DESIGN AND ENGINEERING BY ITT GRINNELL, 5TH EDITION	JSB2 26SEP03
.	JSB2 26SEP03
PREPARED BY: J.S. BOYER	JSB2 26SEP03
.	MLK1 26SEP03
IR BY: M. KAZOUN	MLK1 26SEP03
I REVIEWED THE EVAL AND AGREE WITH THE CONCLUSIONS. THE AS-FOUND CONDITIONS OF MAIN STEAM PIPING AND SPRINGS ARE ACCEPTABLE. NO FIELD WORK IS REQUIRED. ECR 03-00525 WAS CREATED TO DOCUMENT THE MS ANALYSIS AND REVISE AFFECTED DOCUMENTS AS REQUIRED. ALSO, BASED ON THIS EVALUATION, NO ADDITIONAL SUPPORT INSPECTION, PER N-491-1, IS REQUIRED. THIS TECH EVAL SHALL BE SENT TO RECORDS MANAGEMENT UNDER DOCTYPE 3015 SINCE IT IS RELATED TO AN ISI SSC.	MLK1 26SEP03
.	MLK1 26SEP03
APPROVED: JORDAN	JAJ1 26SEP03
.	MACO 28SEP03
THIS EVAL IS ACCEPTABLE. NO ADDITIONAL SCOPE IS REQUIRED. NO SUCCESSIVE EXAMINATIONS ARE REQUIRED. EVAL COMPLETE.	MACO 28SEP03
.	MACO 28SEP03
	MACO 28SEP03

=====END OF ACTION REQUEST=====

Date: September 25, 2003

W.D. # C 0 2 0 6 8 3 8

To: Dave Branciaroli (Exelon)  
 From: Philip Gainer (GE)

Subject: Per Exelon engineering, General Electric Visual technicians inspected 28 mainstream spring can hangers for cold settings only. Here is a summary of the results.

<u>Component ID</u>	<u>Detail Cold Setting</u>	<u>Tolerance</u>		<u>As - Found Setting</u>	<u>Acc / Rej.</u>	<u>Tech</u>	<u>Remarks</u>
		<u>Plus 10%</u>	<u>Minus 10%</u>				
1DB-H10	8697	9566	7828	7200	Reject	L. Eller	Calculated per MAG-CG-407
1DB-H12	8571	9428	7713	5200	Reject	L. Eller	
1DB-H13	3600	3960	3240	2750 Both	Reject	L. Eller	
1DB-H14	8687	9555	7818	8250	Acceptable	J. Mizak	
1DB-H15	8754	9629	7879	8250	Acceptable	J. Mizak	
1DB-H2	6125	6737	5513	5940	Acceptable	L. Eller	
1DB-H20	8941	9836	8047	8600	Acceptable	L. Eller	
1DB-H21	11,758	12,933	10,583	9900	Reject	L. Eller	
1DB-H1	8887	9776	7999	8250	Acceptable	J. Mizak	
1DB-H22	9000	9900	8100	5700	Reject	L. Eller	Calculated per MAG-CG-407
1DB-H23	3434	3778	3081	a=2640 b=2950	Reject	L. Eller	
1DB-H24	8887	9776	7999	8250	Acceptable	J. Mizak	
1DB-H25	1800	1980	1620	4500	Reject	J. Price	
1DB-H31	8751	9627	7876	7900	Acceptable	J. Price	
1DB-H33	9000	9900	8100	7500	Reject	J. Price	
1DB-H35	3253	3579	2928	a=2300 b=2400	Reject	J. Price	
1DB-H11	6434	7077	5780	4050	Reject	L. Eller	Calculated per MAG-CG-407
1DB-H36	8387	9226	7549	8250	Acceptable	J. Mizak	
1DB-H37	8126	8938	7313	7800	Acceptable	S. Woodyard	

CPLC-1-1  
APP-2-1  
P-1-1  
G-1-1  
R-1-1

<u>Component ID</u>	<u>Detail Cold Setting</u>	<u>Tolerance</u>		<u>As - Found Setting</u>	<u>Acc / Rej</u>	<u>Tech</u>	<u>Remarks</u>
		<u>Plus 10%</u>	<u>Minus 10%</u>				
1DB-H38 /	2966	3263	2670	2950	Acceptable	S. Woodyard	
1DB-H45 /	6337	6971	5704	4860	Reject	S. Woodyard	
1DB-H47 /	3225	3548	2903	2550	Reject	S. Woodyard	
7DB-H74 /	3975	4373	3578			S. Woodyard	Need Scaffolding
7DB-H75 /	3710	4081	3339	3150	Reject	S. Woodyard	
7DB-H76 /	3519	3871	3168	3300	Acceptable	L. Eller	
7DB-H77 /	5928	6521	5336			L. Eller	Need Scaffolding
7DB-H78 /	3372	3710	3035	2650	Reject	J. Price	
7DB-H79 /	3906	4296	3616	3155	Reject	L. Eller	

Code. 1-1 R1  
APP. 2 P. 11

MMM	MMM	EEEEEEEEE	11	0000000	11
		EE      E	111	00      00	111
MM	MM	EE	11	00      00	11
MM	MM	EEE	11	00      00	11
MM	M	EE	11	00      00	11
MM	MM	EE      E	11	00      00	11
MMMM	MMMM	EEEEEEEEE	1111	0000000	1111

VERSION : N2  
 RELEASED : MAY, 1993  
 USER MANUAL VERSION : N2  
 THEORETICAL MANUAL VERSION : 9  
 VALIDATION MANUAL VERSION : N2  
 SUPPLEMENTAL MANUAL VERSION : 6

\*

FOR COMPLETE ME101 OUTPUT,  
 SEE PAGE 107 OF APP. I MICROFICHE  
 (JOB 24236, DATED 02/11/84)

\* \* \* \* \*  
 \* IN CASE OF PROBLEMS WITH ME101, CONTACT THE  
 \* PIPE STRESS USER REPRESENTATIVES :  
 \*

CHICAGO	-	NAME	LOCATION EXTENSION
GAITHERSBURG	-	B. MCCALL	CAO 2400
HOUSTON	-	R. LEE	GRO 5549
NORWALK	-	D. RAVAD	HRO 2234
SAN FRANCISCO	-	K. MORGAN	LARO 2464
	-	L. T. NICHOLSON	SFR0 973-9965
* * * * *			
PROGRAM SPONSOR	-	M. KHALAFALLAH	SF 45/30 768-2261
TECHNICAL SPECIALIST	-	M. Y. DONG	SF 45/30 768-8482
* * * * *			

COPYRIGHT 1979, 1993      BECHTEL CORP.      ALL RIGHTS RESERVED.

CDL. 1-1 R-1  
APR. 2, P. 18

ME101

## INPUT CARD IMAGES

INPUT CARD IMAGES  
 SEQ     1       11       21       31       41       51       61       71       80       LOAD CASE(S)  
 1 .+      +      +      +      +      +      +      +  
 2 .RUN     \*\*\*\*\* SPRING COLD SETTING LOADS USED      LDCASE=WT01(1),  
 3 .RUN     \*\*\*\*\* WT01(1) AS DESIGNED SPRING SETTINGS      LDCASE=WT02(2),  
 4 .RUN     \*\*\*\*\* WT02(2) AS FOUND SPRING SETTINGS      LDCASE=THRMO1,  
 5 .HED  
 6 .  
 7 .  
 8 .  
 9 .  
 10 .  
 11 .  
 12 .\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
 13 .\*\*\*\*\*@\*\*\*\*\* HSO-171  
 14 .ANC    A05  
 15 .  
 16 .  
 17 .  
 18 .  
 19 .  
 20 .  
 21 .  
 22 .  
 23 .  
 24 .A06                          4-8  
 25 .A07                          7-10  
 26 .A10                   15-8              L  
 27 .A15                          5-2.5  
 28 .SPR A15                          1  
 29 .SPR A15                          1                  AA=1500, FORCE=8887, \*1      WT01  
 30 .\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
 31 .SPR A20                          30-9.188      DTI=1DB-H2, SEG=4,  
 32 .SPR A20                          1                  AA=2160, FORCE=6125, \*1      WT01  
 33 .SPR A20                          1                  AA=2160, FORCE=5940, \*2      WT02  
 34 .A25                                  2-1.313  
 35 .SNB A25                          1  
 36 .A30                                  5-9            L  
 37 .A35                                  6-7.375      DTI=1DB-H3,  
 38 .RAD A35                                  1  
 39 .RAD A40                                  13-3.625      DTI=1DB-H4, SEG=3,  
 40 .RAD A40                                  1  
 41 .RAD A45                                  37-10      DTI=1DB-H5, SEG=6,  
 42 .RAD A45                                  1  
 43 .RAD A50                                  37-11      DTI=1GB-H6, SEG=6,  
 44 .RAD A50                                  1  
 45 .\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
 46 .RAD A55                                  37-10.75     DTI=1DB-H7, SEG=6,  
 47 .RAD A55                                  1  
 48 .A60    6-6.75      DTI=1DB-S7A,  
 49 .SNB A60                                  1  
 50 .A65    9-2.25  
 51 .A70    10-11.688     L  
 52 .RAD A70                                  1              DTI=1DB-H9, SEG=2,  
 53 .A75    31-2.063     DTI=1DB-H10, SEG=5,  
 54 .SPR A75                                  1              AA=3000, FORCE=8697, \*1      WT01

 APP. 2, P. 19  
 APP. 1-1 R. 1

## INPUT CARD IMAGES

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 2

55 . SPR A75		1				AA=3000, FORCE=7200, *2 . WT02
56 . SPR A80			24-2.25			DTI=1DB-H11, SEG=4,
57 . SPR A80		1				AA=2160, FORCE=6434, *1 . WT01
58 . SPR A80		1				AA=2160, FORCE=4050, *2 . WT02
59 . SPR A85			12-11.688			DTI=1DB-H12, SEG=2,
60 . SPR A85		1				AA=3000, FORCE=8571, *1 . WT01
61 . SPR A85		1				AA=3000, FORCE=5200, *2 . WT02
62 .						
63 .	A88		4-5.313	L		
64 .	A90	-4-10.5				TEE=WTEE,
65 .	A95	-15-3.813				DTI=1DB-H13, SEG=2,
66 . SPR A95		1				AA=2400, FORCE=7200, *1 . WT01
67 . SPR A95		1				AA=2400, FORCE=5500, *2 . WT02
68 .	ASV	-8-5.188				SEG=2,
69 .	A97	-4-0				DTI=MSV-1, THI=2, OD=48,
70 .						ADDWT=80200,
71 .	MS1		3-7.5			DTI=MS-1,
72 . RAD MS1		1				
73 .	S02		0-6			DTI=1DB-S102,
74 . SNB S02			1			
75 .	*	*	*	*	*	*
76 .	A97GA1	-7-1	-8-7.75			DTI=CV-1, OD=36,
77 .						ADDWT=44700,
78 .	CV1	-2-8.625				DTI=CV1-SPR,
79 . SPD CV1		1				
80 .	GA1GA2		-20-2.25	L		OD=28, THI=1.25, LBS/FT=389,
81 .						SEG=3,
82 .	GA4	-35-11			L	SEG=6,
83 .	GA5	51-1	-1-4			SEG=8,
84 .	GA6				S	DTI=TRBN NOZZLE,
85 . ANC GA6	0.17	0.46	-3-0			
86 .			0.21			
87 .	*	*	*	*	*	*
88 . ANC B05		HSO-172				
89 .						
90 .	B06		4-8			OD=26, THI=0.950, LBS/FT=284,
91 .	B07		7-10			COSAZ=1, COSCX=1,
92 .	B10	15-8		L		DTI=X-7B,
93 .	B15		5-2.688			SIF=1.08,
94 .	SPR B15		1			ADDWT=10075, DTI=AO-86B,
95 .	SPR B15		1			SIF=7.4,
96 .	B20		31-3.063	L		SEG=3,
97 . SPR B20		1			DTI=1DB-H14,	
98 .	SPR B20		1			AA=1500, FORCE=8887, *1 . WT01
99 .						AA=1500, FORCE=8250, *2 . WT02
100 .						DTI=1DB-H15, SEG=4,
101 . SPR B25		1				AA=3000, FORCE=8754, *1 . WT01
102 .						AA=3000, FORCE=8250, *2 . WT02
103 . SNB B25		1	6-2.25			DTI=1DB-S15A,
104 .	B30		5-0	L		
105 .	B35	9-.438				DTI=1DB-H26, SEG=2,
106 .	RAD B35		1			
107 .	B40	13-10.125				DTI=1DB-H16, SEG=2,
108 .	RAD B40		1			
109 .	B45	35-10.875				DTI=1DB-H17, SEG=6,
110 .	RAD B45		1			
111 .	B50	37-10.875				DTI=1GB-H18, SEG=6,
112 .	RAD B50		1			
113 .	*	*	*	*	*	*
114 .	B55	37-10.813				DTI=1DB-H19, SEG=6,

Calc. 1-1 R. 1  
APP. 2. P. 20

115 . RAD B55 1  
116 . B60 12-10.625  
117 . SNB B60 1  
118 . B65 5-2.25 1  
119 . B70 7-7.875 L DTI=1DB-S7A,  
120 . SPR B70 1 AA=3000, FORCE=8941, \*1 WT01  
121 . SPR B70 1 AA=3000, FORCE=8600, \*2 WT02  
122 . B75 30-8.25 DTI=1DB-H21, SEG=5,  
123 . SPR B75 1 AA=4000, FORCE=11758, \*1 WT01  
124 . SPR B75 1 AA=4000, FORCE=9900, \*2 WT02  
125 . B80 30-7.938 DTI=1DB-H22, SEG=4,  
126 . SPR B80 1 AA=3000, FORCE=9000, \*1 WT01  
127 . SPR B80 1 AA=3000, FORCE=5700, \*2 WT02  
128 . B85 4-4.938 L TEE=WTEE,  
129 . B90 -4-10.5 DTI=1DB-H23, SEG=2,  
130 . B95 -11-3.75 AA=2400, FORCE=6868, \*1 WT01  
131 . SPR B95 1 AA=2400, FORCE=5590, \*2 WT02  
132 . SPR B95 1 SEG=2,  
133 . BSV -8-5.25 DTI=MSV-2, THI=2, OD=48,  
134 . B97 -4-0 ADDWT=80200,  
135 . \*\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
136 . GB1 -7-1 -8-7.75 DTI=CV-2, OD=36,  
137 . CV2 -2-8.625 ADDWT=44700,  
138 . SPD CV2 1 DTI=CV2-SPR,  
140 . GB1GB2 -20-2.25 L OD=28, THI=1.25, LBS/FT=389,  
141 . GB4 -35-11 -1-3 L SEG=3,  
142 . GB5 39-2 DTI=TRBN NOZZLE, SEG=8,  
144 . ANC GB5 0.17 -0.03 0.08  
145 . ANC HSO-173  
146 . \*\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
147 . ANC C05 OD=26, THI=0.950, LBS/FT=284,  
149 . C06 4-8 COSAZ=1, COSCX=1  
150 . C07 7-10 DTI=X-7D, X-7C  
151 . C10 15-8 L SIF=1.08,  
152 . C15 5-2.563 ADDWT=10075, DTI=AO-86C,  
153 . SPR C15 1 SIF=7.4,  
154 . SPR C15 1 SEG=3,  
155 . C10 5-2.563 DTI=1DB-H24,  
156 . C15 1 AA=1500, FORCE=8887, \*1 WT01  
157 . SPR C15 1 AA=1500, FORCE=8250, \*2 WT02  
158 . SPR C20 30-9.125 DTI=1DB-H25, SEG=5,  
159 . SPR C20 1 AA=3200, FORCE=9600, \*1 WT01  
160 . SPR C20 1 AA=3200, FORCE=9000, \*2 WT02  
162 . C25 11-7.313 DTI=1DB-S25A,  
163 . SNB C25 1  
164 . C30 3-11 L DTI=1DB-H27,  
165 . C35 8-7.125  
166 . RAD C35 1 DTI=1DB-H28, SEG=4,  
167 . C40 26-.063  
168 . RAD C40 1 DTI=1DB-H29, SEG=6,  
169 . C45 37-10.063  
170 . RAD C45 1 DTI=1GB-H30, SEG=6,  
171 . C50 37-10.875  
172 . RAD C50 1 DTI=1DB-S42A, SEG=6,  
173 . \*\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
174 . C55 33-10.625 DTI=1DB-S42A, SEG=6,

Calc - 1 - 1 R. 1  
AP - 2 - P. 2 1

175 . SNB C55  
 176 . C60 4-.563 1  
 177 . SPR C60 1  
 178 . SPR C60 1  
 179 . C65 7-8.688 L  
 180 . C70 10-8.813  
 181 . SPR C70 1  
 182 . SPR C70 1  
 183 . C75 23-8.188  
 184 . SPR C75 1  
 185 . SPR C75 1  
 186 . C80 24-2  
 187 . SPR C80 1  
 188 . SPR C80 1  
 189 . C85 4-6 L  
 190 . C90 -4-10.5  
 191 . C95 -7-4.563  
 192 . SPR C95 1  
 193 . SPR C95 1  
 194 . C96 -7-6  
 195 . CSV -1-3  
 196 . C97 -4-0  
 197 . \*\*\*\*\*@\*\*\*\*\*  
 198 . GCL -7-1 -8-7.75 @\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
 199 . CV3 -2-8.625  
 200 .  
 201 . SPD CV3 1  
 202 . GC1GC2 -20-2.25 L  
 203 .  
 204 . GC4 -35-11 1-3 L  
 205 . GCS 39-2  
 206 . ANC GCS 0.17 1-3  
 207 . ANC GCS -0.03 -0.08 DTI=TRBN NOZZLE,SEG=8,  
 208 . \*\*\*\*\*  
 209 . \*\*\* HSO-174  
 210 . ANC D05  
 211 .  
 212 . D06 4-8  
 213 . D07 7-10  
 214 . D10 15-8 L  
 215 . D15 5-2.563  
 216 . SPR D15 1  
 217 . SPR D15 1  
 218 . D20 30-9.125  
 219 . SPR D20 1  
 220 . SPR D20 1  
 221 . SPR D22 15-4.125  
 222 . SPR D22 1  
 223 . SPR D22 1  
 224 . D25 0-1.188  
 225 . SPR D25 1  
 226 . SPR D30 3-11 L  
 227 . D33 11-7.75  
 228 . D35 4-11.5  
 229 . RAD D35 1  
 230 . D40 25-2.125  
 231 . RAD D40 1

Calc. 1-1  
AII-2, P-22

AA=3000, FORCE=8751, \*1 WT01  
 AA=3000, FORCE=7900, \*2 WT02  
 DTI=1DB-H31,  
 AA=2160, FORCE=6480, \*1 WT01  
 AA=2160, FORCE=5750, \*2 WT02  
 DTI=1DB-H32, SEG=2,  
 AA=3000, FORCE=9000, \*1 WT01  
 AA=3000, FORCE=7500, \*2 WT02  
 DTI=1DB-H33, SEG=4,  
 AA=2160, FORCE=6480, \*1 WT01  
 AA=2160, FORCE=4500, \*2 WT02  
 TEE=WTEE,  
 DTI=1DB-H35,  
 AA=2400, FORCE=6506, \*1 WT01  
 AA=2400, FORCE=4700, \*2 WT02  
 DTI=4" CONN,  
 DTI=MSV-3, THI=2, OD=48,  
 ADDWT=80200,  
 DTI=CV-3, OD=36,  
 ADDWT=44700,  
 DTI=CV3-SPR,  
 OD=28, THI=1.25, LBS/FT=389,  
 SEG=3,  
 SEG=6,  
 DTI=TRBN NOZZLE,SEG=8,  
 OD=26, THI=0.950, LBS/FT=284,  
 COSAZ=1, COSCX=1,  
 DTI=~~X-7C~~, ~~X-7D~~  
 SIF=1.08,  
 ADDWT=10075, DTI=AO-86D,  
 SIF=7.4,  
 SEG=3,  
 DTI=1DB-H36,  
 AA=1500, FORCE=8887, \*1 WT01  
 AA=1500, FORCE=8250, \*2 WT02  
 DTI=1DB-H37, SEG=4,  
 AA=3000, FORCE=8126, \*1 WT01  
 AA=3000, FORCE=7800, \*2 WT02  
 DTI=1DB-H38, SEG=2,  
 AA=2400, FORCE=5932, \*1 WT01  
 AA=2400, FORCE=5900, \*2 WT02  
 DTI=1DB-S38A,  
 DTI=6" CONN, SEG=2,  
 DTI=1DB-H39,  
 DTI=1DB-H40, SEG=4,

235 .	RAD	D45	37-11.813	1		DTI=1DB-H41, SEG=6,	.	.
236 .	RAD	D45				DTI=1GB-H42, SEG=6,	.	.
237 .	RAD	D50	37-10.938	1			.	.
238 .	RAD	D50					.	.
239 .	*	*	*	*	*	*	*	*
240 .	SNB	D55	33-10.5	1		DTI=1DB-S42A, SEG=6,	.	.
241 .	SPR	D60	4-.438	1		DTI=1DB-H43,	.	.
242 .	SPR	D60		1		AA=3000, FORCE=7681, *1	WT01	.
243 .	SPR	D60		1		AA=3000, FORCE=6750, *2	WT02	.
244 .					L		.	.
245 .		D65	3-8.813			DTI=1DB-H44, SEG=2,	.	.
246 .		D70		7-6		AA=2160, FORCE=5148, *1	WT01	.
247 .	SPR	D70		1		AA=2160, FORCE=4300, *2	WT02	.
248 .	SPR	D70		1		DTI=1DB-H45, SEG=4,	.	.
249 .		D75		20-8.938		AA=2160, FORCE=6337, *1	WT01	.
250 .	SPR	D75		1		AA=2160, FORCE=4860, *2	WT02	.
251 .	SPR	D75		1		DTI=1DB-H46, SEG=3,	.	.
252 .		D80		18-4.813		AA=1600, FORCE=4237, *1	WT01	.
253 .	SPR	D80		1		AA=1600, FORCE=3000, *2	WT02	.
254 .	SPR	D80		1			.	.
255 .		D85		6-1.25	L		.	.
256 .		D90	-4-10.5			TEE=WTEE,	.	.
257 .		D95	-3-4.313			DTI=1DB-H47,	.	.
258 .	SPR	D95		1		AA=2400, FORCE=6450, *1	WT01	.
259 .	SPR	D95		1		AA=2400, FORCE=5100, *2	WT02	.
260 .		D96	-7-4.688			DTI=CONN,	.	.
261 .		DSV	-1-0				.	.
262 .		D97	-4-0				.	.
263 .		MS4		-3-7.5		DTI=MSV-4, THI=2, OD=48,	.	.
264 .	RAD	MS4		1		ADDWT=80200,	.	.
265 .	*	*	*	*	*	DTI=MS-4,	.	.
266 .	*	*	*	*	*		.	.
267 .	D97GD1	-7-1	-8-7.75			DTI=CV-4, OD=36,	.	.
268 .		CV4	-2-8.625			ADDWT=44700,	.	.
269 .	SPD	CV4		1		DTI=CV4-SPR,	.	.
270 .		GD1GD2		-20-2.25	L	OD=28, THI=1.25, LBS/FT=389,	.	.
271 .		GD4	-35-11			SEG=3,	.	.
272 .		GD5	51-1	1-4		SEG=6,	.	.
273 .		GD6		3-0	S	SEG=8,	.	.
274 .	ANC	GD6	0.17	0.46		DTI=TRBN NOZZLE,	.	.
275 .				-0.21			.	.
276 .	*	*	*	*	*	*	*	*
277 .	*	*	*	*	*	*	*	*
278 .		HSO-760					.	.
279 .		A90105		2-7	L	OD=14, THI=.75,	.	.
280 .			110	-8-7.5		LBS/FT=124,	.	.
281 .	SPR	110		1		SEG=2, DTI=7DB-H79,	.	.
282 .	SPR	110		1		AA=1600, FORCE=3906, *1	WT01	.
283 .		115	-10-5.75			AA=1600, FORCE=3155, *2	WT02	.
284 .		120			16-3	SEG=2, TEE=WTEE,	.	.
285 .						DTI=7DB-H77, SEG=3,	.	.
286 .						OD=18, THI=0.937,	.	.
287 .						LBS/FT=193,	.	.
288 .	SPR	120		1		AA=2160, FORCE=5928, *1	WT01	.
289 .	SPR	120		1		AA=2160, FORCE=5928, *2	WT02	.
290 .		125		20-6		DTI=7DB-H76, SEG=4, SIF=6,	.	.
291 .	SPR	125		1		AA=1200, FORCE=3519, *1	WT01	.
292 .	SPR	125		1		AA=1200, FORCE=3300, *2	WT02	.
293 .		130		5-4	L		.	.
294 .		133	-4-6		S		.	.

Calc. 1-1 R.1  
App. 2 P.23

295 . 135 -1-7  
 296 . SNB 135 -.707 0.707 DTI=7DB-S11,  
 297 . 140 -0-2 DTI=7DB-S12,  
 298 . SNB 140 0.707 0.707  
 299 . 144 -0-9  
 300 . 145 -2-5 DTI=BYPS VV SPPT,  
 301 . LBS/FT=3621,  
 302 . RAD 145 1  
 303 . 146 -10-6 DTI=BYPS VV SPPT,  
 304 . RAD 146 1  
 305 . 147 -2-5  
 306 \*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
 307 . 150 -0-2 DTI=7DB-S10,LBS/FT=193,  
 308 . SNB 150 0.956 0.292  
 309 . 155 -0-9 S  
 310 . 160 3-0 2-1 -3-8 L  
 311 . 165 -3-8 DTI=7DB-H74,  
 312 . SPR 165 1 AA=1600, FORCE=3975, \*1 WT01  
 313 . SPR 165 1 AA=1600, FORCE=3975, \*2 WT02  
 314 . 170 -22-9 TEE=WTEE, SEG=4,  
 315 . 175 -2-0 JOINT=RED,  
 316 . 180 -5-8 DTI=7DB-H75,  
 317 . OD=14, THI=.75,  
 318 . LBS/FT=124,  
 319 . SPR 180 1 AA=1600, FORCE=3710, \*1 WT01  
 320 . SPR 180 1 AA=1600, FORCE=3150, \*2 WT02  
 321 . 230 -5-4 L  
 322 . 235 8-7.75 -4-6 L  
 323 . D90 -4-6 DTI=26"MS D,  
 324 . 115240 -2-0 JOINT=RED,  
 325 . OD=18, THI=0.937,  
 326 . 245 -11-0 L  
 327 . 250 3-8 OD=14, THI=.75,  
 328 . LBS/FT=124, SEG=2,  
 329 . 250 3-8 DTI=7DB-H78,  
 330 . SPR 250 1 AA=1200, FORCE=3372, \*1 WT01  
 331 . SPR 250 1 AA=1200, FORCE=2650, \*2 WT02  
 332 . 255 7-5.75 L  
 333 . C90 -2-7  
 334 . 170260 16-7.75 -2-7 L  
 335 . B90 -4-6 SEG=3,  
 336 \*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
 337 . B97S01 3-3 DTI=1DB-S101,  
 338 . OD=48, THI=2, LBS/FT=0,  
 339 . SNB S01 0.932 -0.363 3-3  
 340 . A97 3-3  
 341 . C97MS2 3-3  
 342 . SPD MS2 1 DTI=MS2-MS3 SPR,  
 343 . B97 3-3  
 344 . D97S00 3-3  
 345 . SNB S00 0.932 -0.363 DTI=1DB-S100,  
 346 . C97 3-3  
 347 \*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*@\*\*\*\*\*  
 348 . A07AR5 -3-0 DTI=REST-5, OD=20, THI=1,  
 349 . LBS/FT=209,  
 350 . RAD AR5 1  
 351 . B07BR5 -3-0 DTI=REST-5,  
 352 . RAD BR5 1  
 353 . C07CR5 -3-0 DTI=REST-5,  
 354 . RAD CR5 1

Calc. / - / R. 1  
A 88.2 / P. 24

## INPUT CARD IMAGES

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE

7

355 . D07DR5 -3-0  
356 . RAD DR5 1  
357 . \*\*\*\*\*  
358 . SLA DTI=REST-5,  
359 . TEA INCLUD=WT02,  
360 . RLS INCLUD=WT02,  
361 . END LIST=WT01+WT02+THRM01,  
+ + + + + + + + + +

361 CARDS IN INPUT DECK  
328 CARDS IN LOAD CASE WT01  
328 CARDS IN LOAD CASE WT02  
295 CARDS IN LOAD CASE THRM01

0 WARNINGS  
0 ERRORS  
0 FATAL ERRORS

ME101DK Version N2 stop on 09/26/03 at 02:24:22  
ME101DK Version N2 run time .67 seconds  
ME101I Version N2 start on 09/26/03 at 02:24:23

Cold C. 1 - 1  
APP. 2 , P. 25

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1 Rev. 1  
 USER : KAZOUN  
 LOAD CASE : WT01

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
A05	TNGT	3	-10243	6	-420	-377	-27806	713.	1.080	1.000	1.000	B31S73
A06		-3	8918	-6	420	347	-16904	433.	1.000	1.000	1.000	
A06	TNGT	3	1157	6	-420	-347	16904	433.	1.000	1.000	1.000	B31S73
A07		-3	-3381	-6	420	297	868	144.	7.400	1.000	1.000	
A07	TNGT	1352	3	6	297	-420	-868	144.	7.400	1.000	1.000	B31S73
A07A		-177	-3	-6	-297	393	881	26.	1.000	1.000	1.000	
A07A	TNGT	177	3	6	297	-393	-881	26.	1.000	1.000	1.000	B31S73
A07B		998	-3	-6	-297	367	894	26.	1.000	1.000	1.000	
A07B	TNGT	-998	3	6	297	-367	-894	26.	1.000	1.000	1.000	B31S73
A10 B		2173	-3	-6	-297	340	907	26.	1.000	1.000	1.000	
A10 B	BEND	-2173	3	6	297	-340	-907	46.	2.356	6.986	6.986	B31S73
A10 M		2047	-2051	-6	25	436	3438	157.	2.356	6.986	6.986	
A10 M	BEND	-2047	2051	6	-25	-436	-3438	157.	2.356	6.986	6.986	B31S73
A10 E		-3	-3623	-6	319	276	10980	498.	2.356	6.986	6.986	
A10 E	TNGT	3	3623	6	-319	-276	-10980	282.	1.000	1.000	1.000	B31S73
A15		-3	-4179	-6	319	264	18619	477.	1.000	1.000	1.000	
A15	TNGT	3	-4713	6	-319	-264	-18619	477.	1.000	1.000	1.000	B31S73
A15A		-3	2529	-6	319	214	-9234	237.	1.000	1.000	1.000	
A15A	TNGT	3	-2529	6	-319	-214	9234	237.	1.000	1.000	1.000	B31S73
A15B		-3	346	-6	319	165	-20291	520.	1.000	1.000	1.000	
A15B	TNGT	3	-346	6	-319	-165	20291	520.	1.000	1.000	1.000	B31S73
A15C		-3	-1838	-6	319	116	-14553	373.	1.000	1.000	1.000	
A15C	TNGT	3	1838	6	-319	-116	14553	373.	1.000	1.000	1.000	B31S73
A20		-3	-4022	-6	319	66	7981	205.	1.000	1.000	1.000	
A20	TNGT	3	-2133	6	-319	-66	-7981	205.	1.000	1.000	1.000	B31S73
A25		-3	1534	-6	319	53	4113	106.	1.000	1.000	1.000	
A25	TNGT	3	-1534	6	-319	-53	-4113	106.	1.000	1.000	1.000	B31S73
A30 B		-3	825	-6	319	37	1165	31.	1.000	1.000	1.000	
A30 B	TNGT	-3	825	-6	319	-1165	37	55.	2.356	6.986	6.986	B31S73
A30 M		-7	-2	-100	-319	499	-419	30.	2.356	6.986	6.986	
A30 M	BEND	3	6	825	-319	-1165	-25					

Calc - 1-1  
Page 26  
Rev. 2

1-1 WT01 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 157

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE CLASS
		FA	FB	FC	MA	MB	MC				
A30 M	BEND	7	2	100	-499	419	25	30.	2.356	6.986	6.986 B31S73
A30 E		-6	3	625	197	0	-26	9.	2.356	6.986	6.986
A30 E	TNGT	6	-625	3	-197	26	0	5.	1.000	1.000	1.000 B31S73
A35		-6	1580	-3	197	-37	-3709	95.	1.000	1.000	1.000
A35	TNGT	6	285	3	-197	37	3709	95.	1.000	1.000	1.000 B31S73
A35A		-6	974	-3	197	-51	-5237	134.	1.000	1.000	1.000
A35A	TNGT	6	-974	3	-197	51	5237	134.	1.000	1.000	1.000 B31S73
A35B		-6	2233	-3	197	-65	-12347	317.	1.000	1.000	1.000
A35B	TNGT	6	-2233	3	-197	65	12347	317.	1.000	1.000	1.000 B31S73
A40		-6	3492	-3	197	-78	-25039	642.	1.000	1.000	1.000
A40	TNGT	6	5069	3	-197	78	25039	642.	1.000	1.000	1.000 B31S73
A40A		-6	-3279	-3	197	-98	1283	33.	1.000	1.000	1.000
A40A	TNGT	6	3279	3	-197	98	-1283	33.	1.000	1.000	1.000 B31S73
A40B		-6	-1489	-3	197	-118	16315	418.	1.000	1.000	1.000
A40B	TNGT	6	1489	3	-197	118	-16315	418.	1.000	1.000	1.000 B31S73
A40C		-6	301	-3	197	-138	20060	514.	1.000	1.000	1.000
A40C	TNGT	6	-301	3	-197	138	-20060	514.	1.000	1.000	1.000 B31S73
A40D		-6	2091	-3	197	-157	12516	321.	1.000	1.000	1.000
A40D	TNGT	6	-2091	3	-197	157	-12516	321.	1.000	1.000	1.000 B31S73
A40E		-6	3882	-3	197	-177	-6315	162.	1.000	1.000	1.000
A40E	TNGT	6	-3882	3	-197	177	-12516	162.	1.000	1.000	1.000 B31S73
A45		-6	5672	-3	197	-197	-36436	934.	1.000	1.000	1.000
A45	TNGT	6	-3882	3	-197	177	6315	162.	1.000	1.000	1.000 B31S73
A45A		-6	5482	3	-197	197	36436	934.	1.000	1.000	1.000 B31S73
A45A	TNGT	6	-3688	-3	197	-217	-7463	191.	1.000	1.000	1.000
A45B		-6	3688	3	-197	217	7463	191.	1.000	1.000	1.000 B31S73
A45B	TNGT	6	-1894	-3	197	-236	10173	261.	1.000	1.000	1.000
A45C		-6	1894	3	-197	236	-10173	261.	1.000	1.000	1.000 B31S73
A45C	TNGT	6	-99	-3	197	-256	16470	422.	1.000	1.000	1.000
A45C		-6	1695	-3	197	-276	-16470	422.	1.000	1.000	1.000 B31S73
A45D		-6	99	3	-197	256	-11428	293.	1.000	1.000	1.000
A45D	TNGT	6	1695	-3	197	-296	11428	293.	1.000	1.000	1.000 B31S73
A45E		-6	-1695	3	-197	276	-4951	127.	1.000	1.000	1.000
A45E	TNGT	6	3489	-3	197	-296	4951	127.	1.000	1.000	1.000 B31S73
A50		-6	-3489	3	-197	296	-32668	837.	1.000	1.000	1.000
A50	TNGT	6	5283	-3	197	-316					

APP. 2  
P  
R  
T

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 158

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS .75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
A50 A50A	TNGT	6 -6	5266 -3473	3 -3	-197 197	316 -335	32668 -5069	837. 130.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A50A A50B	TNGT	6 -6	3473 -1680	3 -3	-197 197	335 -355	5069 11203	130. 287.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A50B A50C	TNGT	6 -6	1680 113	3 -3	-197 197	355 -375	-11203 16151	287. 414.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A50C A50D	TNGT	6 -6	-113 1906	3 -3	-197 197	375 -395	-16151 9772	414. 251.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A50D A50E	TNGT	6 -6	-1906 3700	3 -3	-197 197	395 -414	-9772 -7931	251. 204.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A50E A55	TNGT	6 -6	-3700 5493	3 -3	-197 197	414 -434	7931 -36961	204. 947.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A55 A60	TNGT	6 -6	5324 -3461	3 -3	-197 197	434 -455	36961 -8136	947. 209.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A60 A65_B	TNGT	6 -6	3461 -1775	3 -3	-197 197	455 -473	8136 7407	209. 190.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A65_B A65_M	BEND	6 -7	3 2	-1775 1050	-197 6832	-7407 8299	-473 474	336. 487.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
A65_M A65_E	BEND	7 -3	-2 6	-1050 326	-6832 11464	-8299 2573	-474 463	487. 532.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
A65_E A65A	TNGT	3 -3	-326 -771	6 -6	-11464 11464	-463 438	2573 -1714	301. 297.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A65A A70	TNGT	3 -3	771 -1867	6 -6	-11464 11464	-438 413	1714 3381	297. 307.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A70 A70A	TNGT	3 -3	-3866 2096	6 -6	-11464 11464	-413 373	-3381 -15203	307. 488.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A70A A70B	TNGT	3 -3	-2096 326	6 -6	-11464 11464	-373 333	15203 -22752	488. 653.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A70B A70C	TNGT	3 -3	-326 -1444	6 -6	-11464 11464	-333 293	22752 -19266	653. 575.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A70C A70D	TNGT	3 -3	1444 -3214	6 -6	-11464 11464	-293 253	19266 -4746	575. 318.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A70D A75	TNGT	3 -3	3214 -4984	6 -6	-11464 11464	-253 213	4746 20810	318. 609.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73

A  
B  
C  
D  
E  
F  
G  
H  
I  
J  
K  
L  
M  
N  
O  
P  
Q  
R  
S  
T  
U  
V  
W  
X  
Y  
Z

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (.75IN/Z) INT.FAC. (I))	STRESS INT.FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
A75	TNGT	3	-3256	6	-11464	-213	-20810	609.	1.000	1.000	1.000	B31S73
A75A		-3	1539	-6	11464	175	6315	335.	1.000	1.000	1.000	
A75A	TNGT	3	-1539	6	-11464	-175	-6315	335.	1.000	1.000	1.000	B31S73
A75B		-3	-178	-6	11464	136	2201	299.	1.000	1.000	1.000	
A75B	TNGT	3	178	6	-11464	-136	-2201	299.	1.000	1.000	1.000	B31S73
A75C		-3	-1895	-6	11464	97	8467	365.	1.000	1.000	1.000	
A75C	TNGT	3	1895	6	-11464	-97	-8467	365.	1.000	1.000	1.000	B31S73
A80		-3	-3612	-6	11464	58	25116	708.	1.000	1.000	1.000	
A80	TNGT	3	-2225	6	-11464	-58	-25116	708.	1.000	1.000	1.000	B31S73
A80A		-3	383	-6	11464	17	16656	518.	1.000	1.000	1.000	
A80A	TNGT	3	-383	6	-11464	-17	-16656	518.	1.000	1.000	1.000	B31S73
A85		-3	-1459	-6	11464	-25	20145	594.	1.000	1.000	1.000	
A85	TNGT	3	6191	6	-11464	25	-20145	594.	1.000	1.000	1.000	B31S73
A88 B		-3	5853	-6	11464	-32	12962	444.	1.000	1.000	1.000	
A88 B	BEND	3	-6	-5853	-11464	12962	32	784.	2.356	6.986	6.986	B31S73
A88 M		2	7	5128	4277	-4701	-50	288.	2.356	6.986	6.986	
A88 M	BEND	-2	-7	-5128	-4277	4701	50	288.	2.356	6.986	6.986	B31S73
A88 E		6	3	4403	4347	4557	-63	285.	2.356	6.986	6.986	
A88 E	TNGT	-6	-4403	3	-4347	63	4557	161.	1.000	1.000	1.000	B31S73
A90		6	3942	-3	4347	-68	-11338	437.	1.871	1.000	1.000	
A90	TNGT	-144	-4660	113	-3226	-589	7421	292.	1.871	1.000	1.000	B31S73
A90A		144	2486	-113	3226	-278	-34787	895.	1.000	1.000	1.000	
A90A	TNGT	-144	-2486	113	-3226	278	34787	895.	1.000	1.000	1.000	B31S73
A95		144	311	-113	3226	-1146	-45498	1169.	1.000	1.000	1.000	
A95	TNGT	-144	-7390	113	-3226	1146	45498	1169.	1.000	1.000	1.000	B31S73
A95A		144	6193	-113	3226	-1624	-74131	1902.	1.000	1.000	1.000	
A95A	TNGT	-144	-6193	113	-3226	1624	74131	1902.	1.000	1.000	1.000	B31S73
ASV		144	4996	-113	3226	-2102	-97716	2506.	1.000	1.000	1.000	
ASV	TNGT	-144	-4996	113	-3226	2102	97716	353.	1.000	1.000	1.000	B31S73
A97		144	3859	-113	3226	-2555	-115426	417.	1.000	1.000	1.000	
MS1	TNGT	0	60962	0	0	0	222817	804.	1.000	1.000	1.000	B31S73
MS1		0	-61992	0	0	0	36	0.	1.000	1.000	1.000	
S02	TNGT	0	-142	0	0	0	-36	0.	1.000	1.000	1.000	B31S73
		0	0	0	0	0	0	0.	1.000	1.000	1.000	

Calc. 1-1 R.  
Aft. 2, p. 19

1-1 WT01 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 160

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS 75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
A97 GA1	TNGT	-6698 4240	-5301 3287	241 -241	-1227 1227	-9040 6345	81758 -129755	544. 859.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73 1.000
GA1 CV1	TNGT	0 0	53880 -54653	0 0	0 0	0 0	147538 0	975. 0.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA1 GA1A	TNGT	-14544 12379	-241 241	144 -144	-4970 4970	17783 -18586	-4131 2789	323. 332.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA1A GA1B	TNGT	-12379 10214	-241 241	144 -144	-4970 4970	18586 -19390	-2789 1448	332. 343.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA1B GA2 B	TNGT	-10214 8049	-241 241	144 -144	-4970 4970	19390 -20193	-1448 107	343. 355.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA2 B GA2 M	BEND	-8049 5044	-153 -4827	-236 236	-4970 3150	856 -3537	20175 -13026	543. 362.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GA2 M GA2 E	BEND	-5044 153	4827 -5910	-236 236	-3150 -32	3537 -4146	13026 2693	362. 129.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GA2 E GA2A	TNGT	-153 153	-5910 4032	236 -236	32 -32	-4146 3009	2693 -26671	84. 458.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA2A GA2B	TNGT	-153 153	-4032 2155	236 -236	31 -31	-3009 1873	26671 -41594	458. 711.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA2B GA2C	TNGT	-153 153	-2155 278	236 -236	32 -32	-1873 737	41594 -47461	711. 811.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA2C GA2D	TNGT	-153 153	-278 -1600	236 -236	32 -32	-737 -400	47461 -44273	811. 756.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA2D GA2E	TNGT	-153 153	1600 -3477	236 -236	32 -32	400 -1536	44273 -32030	756. 548.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA2E GA4 B	TNGT	-153 153	3477 -5354	236 -236	32 -32	1536 -2672	32030 -10732	548. 189.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA4 B GA4 M	BEND	-153 4651	-5354 4434	-236 236	32 2109	-2672 2495	-10732 -3613	289. 127.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GA4 M GA4 E	BEND	-4651 7494	-4434 -153	-236 236	-2109 3497	-2495 856	3613 -10192	127. 282.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GA4 E GA4 A	TNGT	-7494 9695	241 -241	144 -144	-3497 3497	-10217 9400	-478 1841	185. 174.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GA4 A GA4 B	TNGT	-9695 11896	241 -241	144 -144	-3497 3497	-9400 8583	-1841 3205	174. 168.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73

APP. 2  
P. 11

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI) .75IM/Z	STRESS INT.FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
GA4B	TNGT	-11896	241	144	-3497	-8583	-3205	168.	1.000	1.000	1.000	B31S73
GA4C		14098	-241	-144	3497	7766	4569	165.	1.000	1.000	1.000	
GA4C	TNGT	-14098	241	144	-3497	-7766	-4569	165.	1.000	1.000	1.000	B31S73
GA4D		16299	-241	-144	3497	6949	5932	167.	1.000	1.000	1.000	
GA4D	TNGT	-16299	241	144	-3497	-6949	-5932	167.	1.000	1.000	1.000	B31S73
GA4E		18501	-241	-144	3497	6132	7296	173.	1.000	1.000	1.000	
GA4E	TNGT	-18501	241	144	-3497	-6132	-7296	173.	1.000	1.000	1.000	B31S73
GA4F		20702	-241	-144	3497	5315	8660	184.	1.000	1.000	1.000	
GA4F	TNGT	-20702	241	144	-3497	-5315	-8660	184.	1.000	1.000	1.000	B31S73
GA4G		22903	-241	-144	3497	4497	10023	197.	1.000	1.000	1.000	
GA4G	TNGT	-22903	241	144	-3497	-4497	-10023	197.	1.000	1.000	1.000	B31S73
GA5 B		25105	-241	-144	3497	3680	11387	213.	1.000	1.000	1.000	
GA5 B	BEND	-25105	-241	-144	-3497	3680	11387	427.	2.670	8.433	8.433	B31S73
GA5 M		18426	-18085	144	-31	-4837	5694	256.	2.670	8.433	8.433	
GA5 M	BEND	-18426	18085	-144	31	4837	-5694	256.	2.670	8.433	8.433	B31S73
GA5 E		241	-26531	144	-3343	-3160	48747	1675.	2.670	8.433	8.433	
GA5 E	TNGT	-241	-26531	144	3343	-3160	48747	836.	1.000	1.000	1.000	B31S73
GA6		241	26791	-144	-3343	3063	-66521	1139.	1.000	1.000	1.000	
B05	TNGT	5	-10539	12	274	-643	-28884	741.	1.080	1.000	1.000	B31S73
B06		-5	9214	-12	-274	585	-17206	441.	1.000	1.000	1.000	
B06	TNGT	5	861	12	274	-585	17206	441.	1.000	1.000	1.000	B31S73
B07		-5	-3085	-12	-274	488	-1750	261.	7.400	1.000	1.000	
B07	TNGT	885	5	12	488	274	1750	261.	7.400	1.000	1.000	B31S73
B07A		290	-5	-12	-488	-326	-1731	47.	1.000	1.000	1.000	
B07A	TNGT	-290	5	12	488	326	1731	47.	1.000	1.000	1.000	B31S73
B07B		1465	-5	-12	-488	-377	-1711	47.	1.000	1.000	1.000	
B07B	TNGT	-290	5	12	488	377	1711	47.	1.000	1.000	1.000	B31S73
B10 B		1465	5	12	488	-428	-1691	46.	1.000	1.000	1.000	
B10 B	BEND	2640	-5	-12	-488	428	-1691	46.	1.000	1.000	1.000	B31S73
B10 M		-2640	5	12	488	428	1691	82.	2.356	6.986	6.986	
B10 M	BEND	2376	-2383	-12	-660	14	1288	66.	2.356	6.986	6.986	
B10 M		-2376	2383	12	660	-14	-1288	66.	2.356	6.986	6.986	
B10 E		-5	-4090	-12	-469	448	9904	449.	2.356	6.986	6.986	
B10 E	TNGT	5	4090	12	469	-448	-9904	254.	1.000	1.000	1.000	B31S73
B15		-5	-4650	-12	-469	423	18530	475.	1.000	1.000	1.000	

APR 1 2024

1-1 WT01 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 162

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (.75IN/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
B15 B15A	TNGT	5 -5	-4233 2014	12 -12	469 -469	-423 326	-18530 -5875	475. 151.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73 1.000
B15A B15B	TNGT	5 -5	-2014 -204	12 -12	469 -469	-326 229	5875 -12945	151. 332.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B15B B15C	TNGT	5 -5	204 -2423	12 -12	469 -469	-229 132	12945 -2682	332. 70.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B15C B20	TNGT	5 -5	2423 -4641	12 -12	469 -469	-132 35	2682 24917	70. 639.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B20 B25	TNGT	5 -5	-4091 2334	12 -12	469 -469	-35 -42	-24917 5041	639. 130.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B25 B30 B	TNGT	5 -5	-2334 1837	12 -12	469 -469	42 -64	-5041 1391	130. 38.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B30 B B30 M	BEND	5 -12	12 -5	1837 -1112	469 -862	-1391 -2028	-64 88	67. 100.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
B30 M B30 E	BEND	12 -12	5 5	1112 -388	862 -2867	2028 -2503	-88 89	100. 172.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
B30 E B30 A	TNGT	12 -12	388 434	5 -5	2867 -2867	-89 75	-2503 2436	98. 96.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B30A B35	TNGT	12 -12	-434 1255	5 -5	2867 -2867	-75 61	-2436 -7	96. 74.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B35 B35A	TNGT	12 -12	272 1693	5 -5	2867 -2867	-61 28	7 -4926	74. 146.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B35A B40	TNGT	12 -12	-1693 3659	5 -5	2867 -2867	-28 -5	4926 -23449	146. 605.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B40 B40A	TNGT	12 -12	4885 -3186	5 -5	2867 -2867	5 -33	23449 700	605. 76.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B40A B40B	TNGT	12 -12	3186 -1487	5 -5	2867 -2867	33 -62	-700 14682	76. 383.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B40B B40C	TNGT	12 -12	1487 212	5 -5	2867 -2867	62 -90	-14682 18495	383. 480.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B40C B40D	TNGT	12 -12	-212 1911	5 -5	2867 -2867	90 -119	-18495 12141	480. 320.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B40D B40E	TNGT	12 -12	-1911 3610	5 -5	2867 -2867	119 -147	-12141 -4380	320. 134.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73

C-1-1-1-1-1-1-1

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z )	STRESS INT.FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
B40E B45	TNGT	12 -12	-3610 5309	5 -5	2867 -2867	147 -176	4380 -31069	134. 800.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B45 B45A	TNGT	12 -12	4999 -3206	5 -5	2867 -2867	176 -206	31069 -5150	800. 151.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B45A B45B	TNGT	12 -12	3206 -1412	5 -5	2867 -2867	206 -236	5150 9437	151. 253.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B45B B45C	TNGT	12 -12	1412 382	5 -5	2867 -2867	236 -266	-9437 12692	253. 334.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B45C B45D	TNGT	12 -12	-382 2175	5 -5	2867 -2867	266 -296	-12692 4615	334. 139.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B45D B45E	TNGT	12 -12	-2175 3969	5 -5	2867 -2867	296 -326	-4615 -14793	139. 386.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B45E B50	TNGT	12 -12	-3969 5763	5 -5	2867 -2867	326 -356	14793 -45533	386. 1169.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B50 B50A	TNGT	12 -12	6848 -5054	5 -5	2867 -2867	356 -386	45533 -7941	1169. 217.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B50A B50B	TNGT	12 -12	5054 -3261	5 -5	2867 -2867	386 -416	7941 18323	217. 475.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B50B B50C	TNGT	12 -12	3261 -1468	5 -5	2867 -2867	416 -446	-18323 33258	475. 856.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B50C B50D	TNGT	12 -12	1468 326	5 -5	2867 -2867	446 -476	-33258 36864	856. 948.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B50D B50E	TNGT	12 -12	-326 2119	5 -5	2867 -2867	476 -506	-36864 29141	948. 751.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B50E B55	TNGT	12 -12	-2119 3913	5 -5	2867 -2867	506 -537	-29141 10090	751. 269.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B55 B60	TNGT	12 -12	2060 1598	5 -5	2867 -2867	537 -598	-10090 13065	269. 343.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B60 B65 B	TNGT	12 -12	-1598 2148	5 -5	2867 -2867	598 -607	-13065 9435	343. 253.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B65 B B65 M	BEND	12 -12	5 5	2148 -2873	2867 2364	-9435 2884	-607 606	447. 171.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
B65 M B65 E	BEND	12 -5	-5 12	2873 -3598	-2364 741	-2884 -7114	-606 582	171. 325.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73

Rev 1-1  
 P. 2  
 R. 3

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
B65 E	TNGT	5	3598	12	-741	-582	-7114	184.	1.000	1.000	1.000	B31S73
B70		-5	-4849	-12	741	527	25722	660.	1.000	1.000	1.000	
B70 A	TNGT	5	-3573	12	-741	-527	-25722	660.	1.000	1.000	1.000	B31S73
B70A		-5	1830	-12	741	451	9141	235.	1.000	1.000	1.000	
B70A B70B	TNGT	5	-1830	12	-741	-451	-9141	235.	1.000	1.000	1.000	B31S73
B70B		-5	88	-12	741	375	3254	86.	1.000	1.000	1.000	
B70B B70C	TNGT	5	-88	12	-741	-375	-3254	86.	1.000	1.000	1.000	B31S73
B70C		-5	-1655	-12	741	299	8061	208.	1.000	1.000	1.000	
B70C B70D	TNGT	5	1655	12	-741	-299	-8061	208.	1.000	1.000	1.000	B31S73
B70D		-5	-3397	-12	741	222	23564	604.	1.000	1.000	1.000	
B70D B75	TNGT	5	3397	12	-741	-222	-23564	604.	1.000	1.000	1.000	B31S73
B75		-5	-5140	-12	741	146	49761	1276.	1.000	1.000	1.000	
B75 A	TNGT	5	-5577	12	-741	-146	-49761	1276.	1.000	1.000	1.000	B31S73
B75A		-5	3401	-12	741	51	15350	394.	1.000	1.000	1.000	
B75A B75B	TNGT	5	-3401	12	-741	-51	-15350	394.	1.000	1.000	1.000	B31S73
B75B		-5	1225	-12	741	-44	-2378	64.	1.000	1.000	1.000	
B75B B75C	TNGT	5	-1225	12	-741	44	2378	64.	1.000	1.000	1.000	B31S73
B75C		-5	-952	-12	741	-140	-3425	90.	1.000	1.000	1.000	
B75C B80	TNGT	5	952	12	-741	140	3425	90.	1.000	1.000	1.000	B31S73
B80		-5	-3128	-12	741	-235	12211	314.	1.000	1.000	1.000	
B80 B85 B	TNGT	5	-5385	12	-741	235	-12211	314.	1.000	1.000	1.000	B31S73
B85 B		-5	5056	-12	741	-249	6147	159.	1.000	1.000	1.000	
B85 B B85 M	BEND	5	-12	-5056	-741	6147	249	281.	2.356	6.986	6.986	B31S73
B85 M		5	12	4331	755	5869	-282	268.	2.356	6.986	6.986	
B85 M B85 E	BEND	-5	-12	-4331	-755	-5869	282	268.	2.356	6.986	6.986	B31S73
B85 E		12	5	3606	8571	12690	-305	694.	2.356	6.986	6.986	
B85 E B90	TNGT	-12	-3606	5	-8571	305	12690	393.	1.000	1.000	1.000	B31S73
B90		12	3145	-5	8571	-313	-18175	723.	1.871	1.000	1.000	
B90 B90A	TNGT	-106	-1397	5	-8302	799	21784	839.	1.871	1.000	1.000	B31S73
B90A		106	-209	-5	8302	-826	-25144	679.	1.000	1.000	1.000	
B90A B95	TNGT	-106	209	5	-8302	826	25144	679.	1.000	1.000	1.000	B31S73
B95		106	-1815	-5	8302	-852	-19422	542.	1.000	1.000	1.000	
B95 B95A	TNGT	-106	-4981	5	-8302	852	19422	542.	1.000	1.000	1.000	B31S73
B95A		106	3783	-5	8302	-872	-37907	995.	1.000	1.000	1.000	

Calc.  
11/21/03  
11/21/03  
11/21/03

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 165

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI) .75IN/Z	STRESS INT.FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
B95A BSV	TNGT	-106 106	-3783 2585	5 -5	-8302 8302	872 -892	37907 -51340	995. 1333.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
BSV B97	TNGT	-106 106	-2585 1449	5 -5	-8302 8302	892 -911	51340 -59407	188. 217.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
B97 GB1	TNGT	-8662 6204	-7269 5255	-1 1	-51 51	1225 -1210	48840 -118828	323. 785.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB1 CV2	TNGT	0 0	51064 -51837	0 0	0 0	0 0	139880 0	924. 0.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB1 GB1A	TNGT	-14493 12328	1 -1	-133 133	727 -727	21052 -20311	968 -960	360. 348.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB1A GB1B	TNGT	-12328 10163	1 -1	-133 133	727 -727	20311 -19569	960 -953	348. 335.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB1B GB2 B	TNGT	-10163 7998	1 -1	-133 133	727 -727	19569 -18828	953 -945	335. 322.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB2 B GB2 M	BEND	-7998 4805	133 -4993	-3 3	727 -306	-289 727	18849 -11043	493. 289.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GB2 M GB2 E	BEND	-4805 -133	4993 -5859	-3 3	306 301	-727 738	11043 4844	289. 128.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GB2 E GB2A	TNGT	133 -133	-5859 3981	3 -3	-301 301	738 -754	4844 -28574	84. 488.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB2A GB2B	TNGT	133 -133	-3981 2104	3 -3	-301 301	754 -770	28574 -43250	488. 739.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB2B GB2C	TNGT	133 -133	-2104 227	3 -3	-301 301	770 -785	43250 -48873	739. 835.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB2C GB2D	TNGT	133 -133	-227 -1650	3 -3	-301 301	785 -801	48873 -45442	835. 776.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB2D GB2E	TNGT	133 -133	1650 -3527	3 -3	-301 301	801 -816	45442 -32959	776. 563.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB2E GB4 B	TNGT	133 -133	3527 -5404	3 -3	-301 301	816 -832	32959 -11422	563. 196.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GB4 B GB4 M	BEND	133 4483	-5404 4672	-3 3	-301 804	-832 384	-11422 -3340	299. 90.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GB4 M GB4 E	BEND	-4483 7544	-4672 133	-3 3	-804 843	-384 -289	3340 -10680	90. 280.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73

APP. 1  
 APP. 2  
 APP. 3  
 APP. 4

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z )	STRESS INT.FAC.	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
GB4 E	TNGT	-7544	-1	-133	-843	-10663	661	183.	1.000	1.000	1.000	B31S73
GB4A		9279	1	133	843	11258	-667	193.	1.000	1.000	1.000	
GB4A	TNGT	-9279	-1	-133	-843	-11258	667	193.	1.000	1.000	1.000	B31S73
GB4B		11014	1	133	843	11852	-673	203.	1.000	1.000	1.000	
GB4B	TNGT	-11014	-1	-133	-843	-11852	673	203.	1.000	1.000	1.000	B31S73
GB4C		12749	1	133	843	12446	-679	213.	1.000	1.000	1.000	
GB4C	TNGT	-12749	-1	-133	-843	-12446	679	213.	1.000	1.000	1.000	B31S73
GB4D		14484	1	133	843	13041	-686	224.	1.000	1.000	1.000	
GB4D	TNGT	-14484	-1	-133	-843	-13041	686	224.	1.000	1.000	1.000	B31S73
GB4E		16219	1	133	843	13635	-692	234.	1.000	1.000	1.000	
GB4E	TNGT	-16219	-1	-133	-843	-13635	692	234.	1.000	1.000	1.000	B31S73
GB4F		17954	1	133	843	14229	-698	244.	1.000	1.000	1.000	
GB4F	TNGT	-17954	-1	-133	-843	-14229	698	244.	1.000	1.000	1.000	B31S73
GB4G		19690	1	133	843	14824	-704	254.	1.000	1.000	1.000	
GB4G	TNGT	-19690	-1	-133	-843	-14824	704	254.	1.000	1.000	1.000	B31S73
GB5		21425	1	133	843	15418	-711	264.	1.000	1.000	1.000	
C05	TNGT	6	-10860	16	115	-819	-30056	771.	1.080	1.000	1.000	B31S73
C06		-6	9535	-16	-115	744	-17532	450.	1.000	1.000	1.000	
C06	TNGT	6	540	16	115	-744	17532	450.	1.000	1.000	1.000	B31S73
C07		-6	-2764	-16	-115	617	-4590	659.	7.400	1.000	1.000	
C07	TNGT	434	6	16	617	115	4590	659.	7.400	1.000	1.000	B31S73
C07A		741	-6	-16	-617	-182	-4567	118.	1.000	1.000	1.000	
C07A	TNGT	-741	6	16	617	182	4567	118.	1.000	1.000	1.000	B31S73
C07B		1916	-6	-16	-617	-249	-4544	118.	1.000	1.000	1.000	
C07B	TNGT	-1916	6	16	617	249	4544	118.	1.000	1.000	1.000	B31S73
C10 B		3091	-6	-16	-617	-316	-4521	117.	1.000	1.000	1.000	
C10 B	BEND	-3091	6	16	617	316	4521	207.	2.356	6.986	6.986	B31S73
C10 M		2694	-2702	-16	-675	176	-1111	59.	2.356	6.986	6.986	
C10 M	BEND	-2694	2702	16	675	-176	1111	59.	2.356	6.986	6.986	B31S73
C10 E		-6	-4540	-16	-368	564	8541	388.	2.356	6.986	6.986	
C10 E	TNGT	6	4540	16	368	-564	-8541	220.	1.000	1.000	1.000	B31S73
C15		-6	-5098	-16	-368	533	18003	462.	1.000	1.000	1.000	
C15	TNGT	6	-3775	16	368	-533	-18003	462.	1.000	1.000	1.000	B31S73
C15A		-6	2028	-16	-368	433	153	15.	1.000	1.000	1.000	

A  
B  
C  
D  
E  
F  
G  
H  
I  
J  
K  
L  
M  
N  
O  
P  
Q  
R  
S  
T  
U  
V  
W  
X  
Y  
Z

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 167

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
C15A	TNGT	6	-2028	16	368	-433	-153	15.	1.000	1.000	1.000	B31S73
C15B		-6	282	-16	-368	334	-6953	179.	1.000	1.000	1.000	
C15B	TNGT	6	-282	16	368	-334	6953	179.	1.000	1.000	1.000	B31S73
C15C		-6	-1465	-16	-368	234	-3312	86.	1.000	1.000	1.000	
C15C	TNGT	6	1465	16	368	-234	3312	86.	1.000	1.000	1.000	B31S73
C15D		-6	-3212	-16	-368	134	11074	284.	1.000	1.000	1.000	
C15D	TNGT	6	3212	16	368	-134	-11074	284.	1.000	1.000	1.000	B31S73
C20		-6	-4958	-16	-368	35	36205	928.	1.000	1.000	1.000	
C20	TNGT	6	-4523	16	368	-35	-36205	928.	1.000	1.000	1.000	B31S73
C25		-6	1227	-16	-368	-153	2831	73.	1.000	1.000	1.000	
C25	TNGT	6	-1227	16	368	153	-2831	73.	1.000	1.000	1.000	B31S73
C30 B		-6	1037	-16	-368	-164	2076	54.	1.000	1.000	1.000	
C30 B	BEND	6	16	1037	368	-2076	-164	96.	2.356	6.986	6.986	B31S73
C30 M		-15	-7	-313	455	223	196	25.	2.356	6.986	6.986	
C30 M	BEND	15	7	313	-455	-223	-196	25.	2.356	6.986	6.986	B31S73
C30 E		-16	6	412	416	-5	198	21.	2.356	6.986	6.986	
C30 E	TNGT	16	-412	6	-416	-198	-5	12.	1.000	1.000	1.000	B31S73
C35		-16	1929	-6	416	168	-6250	161.	1.000	1.000	1.000	
C35	TNGT	16	2937	6	-416	-168	6250	161.	1.000	1.000	1.000	B31S73
C35A		-16	-1091	-6	416	132	6845	176.	1.000	1.000	1.000	
C35A	TNGT	16	1091	6	-416	-132	-6845	176.	1.000	1.000	1.000	B31S73
C35B		-16	754	-6	416	96	7941	204.	1.000	1.000	1.000	
C35B	TNGT	16	-754	6	-416	-96	-7941	204.	1.000	1.000	1.000	B31S73
C35C		-16	2600	-6	416	59	-2963	77.	1.000	1.000	1.000	
C35C	TNGT	16	-2600	6	-416	-59	2963	77.	1.000	1.000	1.000	B31S73
C40		-16	4446	-6	416	23	-25868	663.	1.000	1.000	1.000	
C40	TNGT	16	4922	6	-416	-23	25868	663.	1.000	1.000	1.000	B31S73
C40A		-16	-3131	-6	416	-12	-476	16.	1.000	1.000	1.000	
C40A	TNGT	16	3131	6	-416	12	476	16.	1.000	1.000	1.000	B31S73
C40B		-16	-1341	-6	416	-47	13625	349.	1.000	1.000	1.000	
C40B	TNGT	16	1341	6	-416	47	-13625	349.	1.000	1.000	1.000	B31S73
C40C		-16	450	-6	416	-83	16434	421.	1.000	1.000	1.000	
C40C	TNGT	16	-450	6	-416	83	-16434	421.	1.000	1.000	1.000	B31S73
C40D		-16	2240	-6	416	-118	7952	204.	1.000	1.000	1.000	

A112  
C101  
1/17/04

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 168

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE CLASS
		FA	FB	FC	MA	MB	MC				
C40D	TNGT	16	-2240	6	-416	118	-7952	204.	1.000	1.000	1.000 B31S73
C40E		-16	4031	-6	416	-153	-11822	303.	1.000	1.000	1.000
C40E	TNGT	16	-4031	6	-416	153	11822	303.	1.000	1.000	1.000 B31S73
C45		-16	5821	-6	416	-188	-42887	1099.	1.000	1.000	1.000
C45	TNGT	16	6365	6	-416	188	42887	1099.	1.000	1.000	1.000 B31S73
C45A		-16	-4572	-6	416	-223	-8338	214.	1.000	1.000	1.000
C45A	TNGT	16	4572	6	-416	223	8338	214.	1.000	1.000	1.000 B31S73
C45B		-16	-2778	-6	416	-259	14880	382.	1.000	1.000	1.000
C45B	TNGT	16	2778	6	-416	259	-14880	382.	1.000	1.000	1.000 B31S73
C45C		-16	-984	-6	416	-294	26765	686.	1.000	1.000	1.000
C45C	TNGT	16	984	6	-416	294	-26765	686.	1.000	1.000	1.000 B31S73
C45D		-16	809	-6	416	-329	27319	700.	1.000	1.000	1.000
C45D	TNGT	16	-809	6	-416	329	-27319	700.	1.000	1.000	1.000 B31S73
C45E		-16	2603	-6	416	-364	16541	424.	1.000	1.000	1.000
C45E	TNGT	16	-2603	6	-416	364	-16541	424.	1.000	1.000	1.000 B31S73
C50		-16	4397	-6	416	-400	-5570	144.	1.000	1.000	1.000
C50	TNGT	16	5224	6	-416	400	5570	144.	1.000	1.000	1.000 B31S73
C50A		-16	-3620	-6	416	-431	19403	498.	1.000	1.000	1.000
C50A	TNGT	16	3620	6	-416	431	-19403	498.	1.000	1.000	1.000 B31S73
C50B		-16	-2017	-6	416	-463	35320	905.	1.000	1.000	1.000
C50B	TNGT	16	2017	6	-416	463	-35320	905.	1.000	1.000	1.000 B31S73
C50C		-16	-413	-6	416	-494	42182	1081.	1.000	1.000	1.000
C50C	TNGT	16	413	6	-416	494	-42182	1081.	1.000	1.000	1.000 B31S73
C50D		-16	1190	-6	416	-526	39989	1025.	1.000	1.000	1.000
C50D	TNGT	16	-1190	6	-416	526	-39989	1025.	1.000	1.000	1.000 B31S73
C50E		-16	2794	-6	416	-557	28740	737.	1.000	1.000	1.000
C50E	TNGT	16	-2794	6	-416	557	-28740	737.	1.000	1.000	1.000 B31S73
C55		-16	4397	-6	416	-589	8435	217.	1.000	1.000	1.000
C55	TNGT	16	-4397	6	-416	589	-8435	217.	1.000	1.000	1.000 B31S73
C60		-16	5546	-6	416	-611	-11684	300.	1.000	1.000	1.000
C60	TNGT	16	2167	6	-416	611	11684	300.	1.000	1.000	1.000 B31S73
C65 B		-16	-896	-6	416	-636	-4832	125.	1.000	1.000	1.000
C65 B	BEND	16	6	-896	-416	4832	-636	221.	2.356	6.986	6.986 B31S73
C65 M		-15	7	172	-2504	-2529	634	164.	2.356	6.986	6.986

A#-2, p.38  
Rev. 1-1 K!

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 169

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI 75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
C65 M	BEND	15	-7	-172	2504	2529	-634	164.	2.356	6.986	6.986	B31S73
C65 E		-6	16	-553	-3630	-502	602	168.	2.356	6.986	6.986	
C65 E	TNGT	6	553	16	3630	-602	-502	95.	1.000	1.000	1.000	B31S73
C65A		-6	-1615	-16	-3630	541	4560	150.	1.000	1.000	1.000	
C65A	TNGT	6	1615	16	3630	-541	-4560	150.	1.000	1.000	1.000	B31S73
C70		-6	-2678	-16	-3630	481	12593	336.	1.000	1.000	1.000	
C70	TNGT	6	-2921	16	3630	-481	-12593	336.	1.000	1.000	1.000	B31S73
C70A		-6	1240	-16	-3630	385	273	94.	1.000	1.000	1.000	
C70A	TNGT	6	-1240	16	3630	-385	-273	94.	1.000	1.000	1.000	B31S73
C70B		-6	-440	-16	-3630	289	-2096	108.	1.000	1.000	1.000	
C70B	TNGT	6	440	16	3630	-289	2096	108.	1.000	1.000	1.000	B31S73
C70C		-6	-2121	-16	-3630	194	5488	169.	1.000	1.000	1.000	
C70C	TNGT	6	2121	16	3630	-194	-5488	169.	1.000	1.000	1.000	B31S73
C75		-6	-3802	-16	-3630	98	23024	597.	1.000	1.000	1.000	
C75	TNGT	6	-4329	16	3630	-98	-23024	597.	1.000	1.000	1.000	B31S73
C75A		-6	2614	-16	-3630	0	2051	107.	1.000	1.000	1.000	
C75A	TNGT	6	-2614	16	3630	0	-2051	107.	1.000	1.000	1.000	B31S73
C75B		-6	898	-16	-3630	-98	-8558	238.	1.000	1.000	1.000	
C75B	TNGT	6	-898	16	3630	98	8558	238.	1.000	1.000	1.000	B31S73
C75C		-6	-817	-16	-3630	-195	-8804	244.	1.000	1.000	1.000	
C75C	TNGT	6	817	16	3630	195	8804	244.	1.000	1.000	1.000	B31S73
C80		-6	-2532	-16	-3630	-293	1313	99.	1.000	1.000	1.000	
C80	TNGT	6	817	16	3630	195	8804	244.	1.000	1.000	1.000	B31S73
C85 B		-6	3288	-16	-3630	-313	-3018	121.	1.000	1.000	1.000	
C85 B	BEND	6	-16	-3288	3630	-3018	313	214.	2.356	6.986	6.986	B31S73
C85 M		7	15	2563	2462	11379	-356	527.	2.356	6.986	6.986	
C85 M	BEND	-7	-15	-2563	-2462	-11379	356	527.	2.356	6.986	6.986	B31S73
C85 E		16	6	1839	11993	11317	-384	747.	2.356	6.986	6.986	
C85 E	TNGT	-16	-1839	6	-11993	384	11317	423.	1.000	1.000	1.000	B31S73
C90		16	1377	-6	11993	-393	-13930	661.	1.871	1.000	1.000	
C90	TNGT	133	-1838	46	-12037	590	13497	651.	1.871	1.000	1.000	B31S73
C95		-133	-257	-46	12037	-931	-19330	584.	1.000	1.000	1.000	
C95	TNGT	133	-6167	46	-12037	931	19330	584.	1.000	1.000	1.000	B31S73
C96		-133	4038	-46	12037	-1278	-57600	1509.	1.000	1.000	1.000	

Calc. 1-1  
App. 2, P.39

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (.75IN/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
C96 CSV	TNGT	133 -133	-4038 3683	46 -46	-12037 12037	1278 -1335	57600 -62426	1509. 1630.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
CSV C97	TNGT	133 -133	-3683 2547	46 -46	-12037 12037	1335 -1520	62426 -74885	230. 274.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
C97 GC1	TNGT	-8704 6246	-7288 5274	24 -24	1039 -1039	-1016 746	48492 -118694	321. 784.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC1 CV3	TNGT	0 0	51023 -51796	0 0	0 0	0 0	139769 0	924. 0.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC1 GC1A	TNGT	-14497 12332	-24 24	-121 121	331 -331	21075 -20401	-1235 1101	361. 349.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC1A GC1B	TNGT	-12332 10167	-24 24	-121 121	331 -331	20401 -19727	-1101 966	349. 337.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC1B GC2 B	TNGT	-10167 8002	-24 24	-121 121	331 -331	19727 -19053	-966 832	337. 326.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC2 B GC2 M	BEND	-8002 4816	122 -4988	-20 20	331 -333	169 164	19070 -11288	498. 295.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GC2 M GC2 E	BEND	-4816 -122	4988 -5863	-20 20	333 -99	-164 401	11288 4598	295. 121.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GC2 E GC2A	TNGT	122 -122	-5863 3986	20 -20	99 -99	401 -497	4598 -28348	79. 484.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC2A GC2B	TNGT	122 -122	-3986 2109	20 -20	99 -99	497 -593	28348 -43044	484. 735.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC2B GC2C	TNGT	122 -122	-2109 232	20 -20	99 -99	593 -689	43044 -48688	735. 832.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC2C GC2D	TNGT	122 -122	-232 -1646	20 -20	99 -99	689 -785	48688 -45277	832. 774.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC2D GC2E	TNGT	122 -122	1646 -3523	20 -20	99 -99	785 -881	45277 -32814	774. 561.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC2E GC4 B	TNGT	122 -122	3523 -5400	20 -20	99 -99	881 -977	32814 -11297	561. 194.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
GC4 B GC4 M	BEND	122 4488	-5400 4661	-20 20	99 641	-977 810	-11297 -3443	296. 94.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73
GC4 M GC4 E	BEND	-4488 7539	-4661 122	-20 20	-641 1047	-810 169	3443 -10750	94. 282.	2.038 2.038	5.622 5.622	5.622 5.622	B31S73

Calc. 1-1 K  
AM. 2, P. 40

1-1 WT01 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 171

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS .75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
GC4 E	TNGT	-7539	24	-121	-1047	-10738	-543	185.	1.000	1.000	1.000	B31S73
GC4A		9275	-24	121	1047	11278	650	194.	1.000	1.000	1.000	
GC4A	TNGT	-9275	24	-121	-1047	-11278	-650	194.	1.000	1.000	1.000	B31S73
GC4B		11010	-24	121	1047	11818	758	203.	1.000	1.000	1.000	
GC4B	TNGT	-11010	24	-121	-1047	-11818	-758	203.	1.000	1.000	1.000	B31S73
GC4C		12745	-24	121	1047	12359	866	212.	1.000	1.000	1.000	
GC4C	TNGT	-12745	24	-121	-1047	-12359	-866	212.	1.000	1.000	1.000	B31S73
GC4D		14480	-24	121	1047	12899	973	222.	1.000	1.000	1.000	
GC4D	TNGT	-14480	24	-121	-1047	-12899	-973	222.	1.000	1.000	1.000	B31S73
GC4E		16215	-24	121	1047	13439	1081	231.	1.000	1.000	1.000	
GC4E	TNGT	-16215	24	-121	-1047	-13439	-1081	231.	1.000	1.000	1.000	B31S73
GC4F		17950	-24	121	1047	13980	1189	240.	1.000	1.000	1.000	
GC4F	TNGT	-17950	24	-121	-1047	-13980	-1189	240.	1.000	1.000	1.000	B31S73
GC4G		19685	-24	121	1047	14520	1296	250.	1.000	1.000	1.000	
GC4G	TNGT	-19685	24	-121	-1047	-14520	-1296	250.	1.000	1.000	1.000	B31S73
GC5		21421	-24	121	1047	15060	1404	259.	1.000	1.000	1.000	
D05	TNGT	10	-10991	35	3525	-1830	-30542	789.	1.080	1.000	1.000	B31S73
D06		-10	9666	-35	-3525	1666	-17656	463.	1.000	1.000	1.000	
D06	TNGT	10	409	35	3525	-1666	17656	463.	1.000	1.000	1.000	B31S73
D07		-10	-2633	-35	-3525	1390	-5739	978.	7.400	1.000	1.000	
D07	TNGT	584	10	35	1390	3525	5739	978.	7.400	1.000	1.000	B31S73
D07A		591	-10	-35	-1390	-3671	-5699	177.	1.000	1.000	1.000	
D07A	TNGT	-591	10	35	1390	3671	5699	177.	1.000	1.000	1.000	B31S73
D07B		1766	-10	-35	-1390	-3816	-5658	179.	1.000	1.000	1.000	
D07B	TNGT	-1766	10	35	1390	3816	5658	179.	1.000	1.000	1.000	B31S73
D10 B		2941	-10	-35	-1390	-3962	-5617	180.	1.000	1.000	1.000	
D10 B	BEND	-2941	10	35	1390	3962	5617	318.	2.356	6.986	6.986	B31S73
D10 M		2585	-2599	-35	-3818	-1899	-2340	220.	2.356	6.986	6.986	
D10 M	BEND	-2585	2599	35	3818	1899	2340	220.	2.356	6.986	6.986	B31S73
D10 E		-10	-4391	-35	-4076	1276	6973	370.	2.356	6.986	6.986	
D10 E	TNGT	10	4391	35	4076	-1276	-6973	210.	1.000	1.000	1.000	B31S73
D15		-10	-4948	-35	-4076	1207	16141	428.	1.000	1.000	1.000	
D15	TNGT	10	-3920	35	4076	-1207	-16141	428.	1.000	1.000	1.000	B31S73
D15A		-10	1736	-35	-4076	937	-5606	179.	1.000	1.000	1.000	

Code 1-1

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 172

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z )	STRESS INT.FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
D15A	TNGT	10	-1736	35	4076	-937	5606	179.	1.000	1.000	1.000	B31S73
D15B		-10	-447	-35	-4076	667	-10565	291.	1.000	1.000	1.000	
D15B	TNGT	10	447	35	4076	-667	10565	291.	1.000	1.000	1.000	B31S73
D15C		-10	-2630	-35	-4076	396	1267	110.	1.000	1.000	1.000	
D15C	TNGT	10	2630	35	4076	-396	-1267	110.	1.000	1.000	1.000	B31S73
D20		-10	-4814	-35	-4076	126	29889	773.	1.000	1.000	1.000	
D20	TNGT	10	-3069	35	4076	-126	-29889	773.	1.000	1.000	1.000	B31S73
D20A		-10	891	-35	-4076	-144	14697	391.	1.000	1.000	1.000	
D20A	TNGT	10	-891	35	4076	144	-14697	391.	1.000	1.000	1.000	B31S73
D25		-10	-1315	-35	-4076	-417	16345	432.	1.000	1.000	1.000	
D25	TNGT	10	-4424	35	4076	417	-16345	432.	1.000	1.000	1.000	B31S73
D30 B		-10	4235	-35	-4076	-440	13458	361.	1.000	1.000	1.000	
D30 B	BEND	10	35	4235	4076	-13458	-440	637.	2.356	6.986	6.986	B31S73
D30 M		-32	-18	-3510	2838	3545	512	207.	2.356	6.986	6.986	
D30 M	BEND	32	18	3510	-2838	-3545	-512	207.	2.356	6.986	6.986	B31S73
D30 E		-35	10	-2785	1407	-6688	523	310.	2.356	6.986	6.986	
D30 E	TNGT	35	2785	10	-1407	-523	-6688	176.	1.000	1.000	1.000	B31S73
D30A		-35	-1594	-10	1407	482	15879	409.	1.000	1.000	1.000	
D30A	TNGT	35	1594	10	-1407	-482	-15879	409.	1.000	1.000	1.000	B31S73
D33		-35	-402	-10	1407	441	20068	516.	1.000	1.000	1.000	
D33	TNGT	35	402	10	-1407	-441	-20068	516.	1.000	1.000	1.000	B31S73
D35		-35	1006	-10	1407	392	18569	477.	1.000	1.000	1.000	
D35	TNGT	35	1612	10	-1407	-392	-18569	477.	1.000	1.000	1.000	B31S73
D35A		-35	175	-10	1407	330	23090	593.	1.000	1.000	1.000	
D35A	TNGT	35	-175	10	-1407	-330	-23090	593.	1.000	1.000	1.000	B31S73
D35B		-35	1962	-10	1407	269	16363	421.	1.000	1.000	1.000	
D35B	TNGT	35	-1962	10	-1407	-269	-16363	421.	1.000	1.000	1.000	B31S73
D35C		-35	3749	-10	1407	207	-1612	55.	1.000	1.000	1.000	
D35C	TNGT	35	-3749	10	-1407	-207	1612	55.	1.000	1.000	1.000	B31S73
D40		-35	5536	-10	1407	145	-30835	791.	1.000	1.000	1.000	
D40	TNGT	35	5118	10	-1407	-145	30835	791.	1.000	1.000	1.000	B31S73
D40A		-35	-3321	-10	1407	83	-4122	112.	1.000	1.000	1.000	
D40A	TNGT	35	3321	10	-1407	-83	4122	112.	1.000	1.000	1.000	B31S73
D40B		-35	-1524	-10	1407	21	11213	290.	1.000	1.000	1.000	

Cal  
2/24/2024

1-1 WT01 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 173

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS 75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE CLASS
		FA	FB	FC	MA	MB	MC				
D40B	TNGT	35	1524	10	-1407	-21	-11213	290.	1.000	1.000	1.000 B31S73
D40C		-35	274	-10	1407	-41	15169	390.	1.000	1.000	1.000
D40C	TNGT	35	-274	10	-1407	41	-15169	390.	1.000	1.000	1.000 B31S73
D40D		-35	2071	-10	1407	-103	7747	202.	1.000	1.000	1.000
D40D	TNGT	35	-2071	10	-1407	103	-7747	202.	1.000	1.000	1.000 B31S73
D40E		-35	3869	-10	1407	-165	-11054	286.	1.000	1.000	1.000
D40E	TNGT	35	-3869	10	-1407	165	11054	286.	1.000	1.000	1.000 B31S73
D45		-35	5666	-10	1407	-227	-41234	1057.	1.000	1.000	1.000
D45A	TNGT	35	6255	10	-1407	227	41234	1057.	1.000	1.000	1.000 B31S73
D45A		-35	-4461	-10	1407	-289	-7377	193.	1.000	1.000	1.000
D45A	TNGT	35	4461	10	-1407	289	7377	193.	1.000	1.000	1.000 B31S73
D45B		-35	-2668	-10	1407	-351	15146	390.	1.000	1.000	1.000
D45B	TNGT	35	2668	10	-1407	351	-15146	390.	1.000	1.000	1.000 B31S73
D45C		-35	-874	-10	1407	-413	26333	676.	1.000	1.000	1.000
D45C	TNGT	35	874	10	-1407	413	-26333	676.	1.000	1.000	1.000 B31S73
D45D		-35	920	-10	1407	-474	26185	672.	1.000	1.000	1.000
D45D	TNGT	35	-920	10	-1407	474	-26185	672.	1.000	1.000	1.000 B31S73
D45E		-35	2714	-10	1407	-536	14703	379.	1.000	1.000	1.000
D45E	TNGT	35	-2714	10	-1407	536	-14703	379.	1.000	1.000	1.000 B31S73
D50		-35	4508	-10	1407	-598	-8115	212.	1.000	1.000	1.000
D50	TNGT	35	5308	10	-1407	598	8115	212.	1.000	1.000	1.000 B31S73
D50A		-35	-3705	-10	1407	-654	17327	446.	1.000	1.000	1.000
D50A	TNGT	35	3705	10	-1407	654	-17327	446.	1.000	1.000	1.000 B31S73
D50B		-35	-2102	-10	1407	-709	33720	865.	1.000	1.000	1.000
D50B	TNGT	35	2102	10	-1407	709	-33720	865.	1.000	1.000	1.000 B31S73
D50C		-35	-499	-10	1407	-764	41063	1053.	1.000	1.000	1.000
D50C	TNGT	35	499	10	-1407	764	-41063	1053.	1.000	1.000	1.000 B31S73
D50D		-35	1104	-10	1407	-820	39356	1010.	1.000	1.000	1.000
D50D	TNGT	35	-1104	10	-1407	820	-39356	1010.	1.000	1.000	1.000 B31S73
D50E		-35	2707	-10	1407	-875	28600	734.	1.000	1.000	1.000
D50E	TNGT	35	-2707	10	-1407	875	-28600	734.	1.000	1.000	1.000 B31S73
D55		-35	4310	-10	1407	-930	8793	229.	1.000	1.000	1.000
D55	TNGT	35	-4310	10	-1407	930	-8793	229.	1.000	1.000	1.000 B31S73
D60		-35	5456	-10	1407	-970	-10915	283.	1.000	1.000	1.000

A01  
C01  
2  
1  
X

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 174

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS .75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
D60 D65 B	TNGT	35 -35	1252 -1115	10 -10	-1407 1407	970 -974	10915 -10342	283. 269.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D65 B D65 M	BEND	35 -32	10 18	-1115 390	-1407 -5492	10342 -6625	-974 964	475. 392.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
D65 M D65 E	BEND	32 -10	-18 35	-390 -335	5492 -8431	6625 -783	-964 892	392. 386.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
D65 E D65A	TNGT	10 -10	335 -938	35 -35	8431 -8431	-892 817	-783 2136	218. 224.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D65A D70	TNGT	10 -10	938 -1541	35 -35	8431 -8431	-817 743	-2136 4770	224. 249.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D70 D70A	TNGT	10 -10	-2923 1450	35 -35	8431 -8431	-743 560	-4770 -6569	249. 274.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D70A D70B	TNGT	10 -10	-1450 -22	35 -35	8431 -8431	-560 378	-6569 -10272	274. 341.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D70B D70C	TNGT	10 -10	22 -1495	35 -35	8431 -8431	-378 196	10272 -6339	341. 270.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D70C D75	TNGT	10 -10	1495 -2967	35 -35	8431 -8431	-196 13	6339 5231	270. 254.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D75 D75A	TNGT	10 -10	-2998 1256	35 -35	8431 -8431	-13 -202	-5231 -7816	254. 295.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D75A D75B	TNGT	10 -10	-1256 -485	35 -35	8431 -8431	202 -418	7816 -10180	295. 339.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D75B D80	TNGT	10 -10	485 -2227	35 -35	8431 -8431	418 -633	10180 -1864	339. 222.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D80 D85 B	TNGT	10 -10	-1907 1096	35 -35	8431 -8431	633 -734	1864 -6149	222. 268.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
D85 B D85 M	BEND	10 18	-35 32	-1096 372	8431 -805	-6149 11951	734 -824	474. 544.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
D85 M D85 E	BEND	-18 35	-32 10	-372 -353	805 8000	-11951 8995	824 -880	544. 547.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
D85 E D90	TNGT	-35 35	353 -815	10 -10	-8000 8000	880 -896	8995 -8046	309. 409.	1.000 1.871	1.000 1.000	1.000 1.000	B31S73
D90 D95	TNGT	46 -46	2057 -3010	-141 141	-8210 8210	2309 -1836	11829 -3318	524. 232.	1.871 1.000	1.000 1.000	1.000 1.000	B31S73

Calc. 1-1 R.  
Ap. 2, p. 44

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 175

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
D95	TNGT	46	-3408	-141	-8210	1836	3318	232.	1.000	1.000	1.000	B31S73
D96		-46	1310	141	8210	-794	-20751	572.	1.000	1.000	1.000	
D96	TNGT	46	-1310	-141	-8210	794	20751	572.	1.000	1.000	1.000	B31S73
DSV		-46	1026	141	8210	-654	-21919	600.	1.000	1.000	1.000	
DSV	TNGT	46	-1026	-141	-8210	654	21919	85.	1.000	1.000	1.000	B31S73
D97		-46	-111	141	8210	-90	-23749	91.	1.000	1.000	1.000	
D97	TNGT	0	-66417	0	0	0	-242630	876.	1.000	1.000	1.000	B31S73
MS4		0	67447	0	0	0	0	0.	1.000	1.000	1.000	
D97	TNGT	-9951	-7919	-241	2059	9857	41917	285.	1.000	1.000	1.000	B31S73
GD1		7493	5906	241	-2059	-7168	-119178	789.	1.000	1.000	1.000	
GD1	TNGT	0	49678	0	0	0	136112	899.	1.000	1.000	1.000	B31S73
CV4		0	-50451	0	0	0	0	0.	1.000	1.000	1.000	
GD1	TNGT	-14516	241	180	6135	16934	4240	316.	1.000	1.000	1.000	B31S73
GD1A		12352	-241	-180	-6135	-17936	-2901	328.	1.000	1.000	1.000	
GD1A	TNGT	-12352	241	180	6135	17936	2901	328.	1.000	1.000	1.000	B31S73
GD1B		10187	-241	-180	-6135	-18939	-1563	341.	1.000	1.000	1.000	
GD1B	TNGT	-10187	241	180	6135	18939	1563	341.	1.000	1.000	1.000	B31S73
GD2 B		8022	-241	-180	-6135	-19941	-225	356.	1.000	1.000	1.000	
GD2 B	BEND	-8022	-189	234	6135	-965	19919	545.	2.038	5.622	5.622	B31S73
GD2 M		5049	-4782	-234	-3896	4442	-12887	370.	2.038	5.622	5.622	
GD2 M	BEND	-5049	4782	234	3896	-4442	12887	370.	2.038	5.622	5.622	B31S73
GD2 E		189	-5882	-234	147	5317	2728	156.	2.038	5.622	5.622	
GD2 E	TNGT	-189	-5882	-234	-147	5317	2728	102.	1.000	1.000	1.000	B31S73
GD2A		189	4005	234	147	-4190	-26574	460.	1.000	1.000	1.000	
GD2A	TNGT	-189	-4005	-234	-146	4190	26574	460.	1.000	1.000	1.000	B31S73
GD2B		189	2128	234	146	-3062	-41364	709.	1.000	1.000	1.000	
GD2B	TNGT	-189	-2128	-234	-147	3062	41364	709.	1.000	1.000	1.000	B31S73
GD2C		189	250	234	147	-1935	-47099	805.	1.000	1.000	1.000	
GD2C	TNGT	-189	-250	-234	-147	1935	47099	805.	1.000	1.000	1.000	B31S73
GD2D		189	-1627	234	147	-807	-43779	748.	1.000	1.000	1.000	
GD2D	TNGT	-189	1627	-234	-146	807	43779	748.	1.000	1.000	1.000	B31S73
GD2E		189	-3504	234	146	320	-31404	536.	1.000	1.000	1.000	
GD2E	TNGT	-189	3504	-234	-147	-320	31404	536.	1.000	1.000	1.000	B31S73
GD4 B		189	-5382	234	147	1447	-9973	172.	1.000	1.000	1.000	

Calc 1-1 Rev 1

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 176

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z )	STRESS INT.FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
GD4 B	BEND	-189	-5382	234	-147	1447	-9973	263.	2.038	5.622	5.622	B31S73
GD4 M		4695	4428	-234	-1159	-1705	-4403	127.	2.038	5.622	5.622	
GD4 M	BEND	-4695	-4428	234	1159	1705	4403	127.	2.038	5.622	5.622	B31S73
GD4 E		7521	-189	-234	-2265	-965	-10922	292.	2.038	5.622	5.622	
GD4 E	TNGT	-7521	-241	180	2265	-10950	559	191.	1.000	1.000	1.000	B31S73
GD4A		9723	241	-180	-2265	9931	-1920	177.	1.000	1.000	1.000	
GD4A	TNGT	-9723	-241	180	2265	-9931	1920	177.	1.000	1.000	1.000	B31S73
GD4B		11924	241	-180	-2265	8911	-3280	167.	1.000	1.000	1.000	
GD4C	TNGT	-11924	-241	180	2265	-8911	3280	167.	1.000	1.000	1.000	B31S73
GD4C		14125	241	-180	-2265	7892	-4641	161.	1.000	1.000	1.000	
GD4C	TNGT	-14125	-241	180	2265	-7892	4641	161.	1.000	1.000	1.000	B31S73
GD4D		16327	241	-180	-2265	6873	-6002	161.	1.000	1.000	1.000	
GD4D	TNGT	-16327	-241	180	2265	-6873	6002	161.	1.000	1.000	1.000	B31S73
GD4E		18528	241	-180	-2265	5853	-7363	165.	1.000	1.000	1.000	
GD4E	TNGT	-18528	-241	180	2265	-5853	7363	165.	1.000	1.000	1.000	B31S73
GD4F		20729	241	-180	-2265	4834	-8723	175.	1.000	1.000	1.000	
GD4F	TNGT	-20729	-241	180	2265	-4834	8723	175.	1.000	1.000	1.000	B31S73
GD4G		22931	241	-180	-2265	3814	-10084	188.	1.000	1.000	1.000	
GD4G	TNGT	-22931	-241	180	2265	-3814	10084	188.	1.000	1.000	1.000	B31S73
GD5 B		25132	241	-180	-2265	2795	-11445	205.	1.000	1.000	1.000	
GD5 B	BEND	-25132	-241	180	2265	-2795	11445	410.	2.670	8.433	8.433	B31S73
GD5 M		18445	-18105	-180	251	3281	5655	224.	2.670	8.433	8.433	
GD5 M	BEND	-18445	18105	180	-251	-3281	-5655	224.	2.670	8.433	8.433	B31S73
GD5 E		241	-26558	-180	2375	1845	48754	1671.	2.670	8.433	8.433	
GD5 E	TNGT	-241	26558	180	-2375	-1845	-48754	834.	1.000	1.000	1.000	B31S73
GD6		241	-26818	-180	2375	1725	66546	1138.	1.000	1.000	1.000	
A90	TNGT	-718	137	-110	-658	-1121	3916	530.	1.871	1.000	1.000	B31S73
105 B		822	-137	110	658	1213	-3802	469.	1.000	1.000	1.000	
105 B	BEND	-822	137	-110	-658	-1213	3802	627.	1.782	4.598	4.598	B31S73
105 M		605	-799	110	1379	529	-3153	540.	1.782	4.598	4.598	
105 M	BEND	-605	799	-110	-1379	-529	3153	540.	1.782	4.598	4.598	B31S73
105 E		-137	-1163	110	1405	-465	-1743	355.	1.782	4.598	4.598	
105 E	TNGT	137	1163	-110	-1405	465	1743	265.	1.000	1.000	1.000	B31S73
105A		-137	-1589	110	1405	-86	2987	383.	1.000	1.000	1.000	

1  
 2  
 3  
 4  
 5  
 6  
 7  
 8  
 9  
 10

1-1 WT01 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 177

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI 75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
105A 110	TNGT	137	1589	-110	-1405	86	-2987	383.	1.000	1.000	1.000	B31S73
		-137	-2016	110	1405	292	9184	1079.	1.000	1.000	1.000	
110 110A	TNGT	137	-1661	-110	-1405	-292	-9184	1079.	1.000	1.000	1.000	B31S73
		-137	1011	110	1405	870	2186	318.	1.000	1.000	1.000	
110A 115	TNGT	137	-110	1011	-1405	-2186	870	318.	1.000	1.000	1.000	B31S73
		-137	110	-361	1405	-1407	-1447	250.	1.461	1.000	1.000	
115 115A	TNGT	-151	12	-29	-908	8567	155	529.	1.461	1.000	1.000	B31S73
		151	-12	1075	908	-5578	-90	317.	1.000	1.000	1.000	
115A 115B	TNGT	-151	1075	12	-908	-90	5578	317.	1.000	1.000	1.000	B31S73
		151	-2121	-12	908	25	3077	180.	1.000	1.000	1.000	
115B 120	TNGT	-151	2121	12	-908	-25	-3077	180.	1.000	1.000	1.000	B31S73
		151	-3166	-12	908	-39	17396	976.	1.000	1.000	1.000	
120 120A	TNGT	-151	-2622	12	-908	39	-17396	976.	1.000	1.000	1.000	B31S73
		151	1632	-12	908	-100	6495	367.	1.000	1.000	1.000	
120A 120B	TNGT	-151	-1632	12	-908	100	-6495	367.	1.000	1.000	1.000	B31S73
		151	643	-12	908	-162	664	64.	1.000	1.000	1.000	
120B 120C	TNGT	-151	-643	12	-908	162	-664	64.	1.000	1.000	1.000	B31S73
		151	-347	-12	908	-223	-95	53.	1.000	1.000	1.000	
120C 125	TNGT	-151	347	12	-908	223	95	53.	1.000	1.000	1.000	B31S73
		151	-1336	-12	908	-284	4217	1090.	6.000	1.000	1.000	
125 130 B	TNGT	-151	-2083	12	-908	284	-4217	1090.	6.000	1.000	1.000	B31S73
		151	1488	-12	908	-321	-1287	90.	1.000	1.000	1.000	
130 B 130 M	BEND	-151	-12	-1488	-908	-1287	321	123.	1.821	4.747	4.747	B31S73
		115	-98	1146	2456	2348	-240	261.	1.821	4.747	4.747	
130 M 130 E	BEND	-115	98	-1146	-2456	-2348	240	261.	1.821	4.747	4.747	B31S73
		12	-151	805	4076	1461	-8	331.	1.821	4.747	4.747	
130 E 133 B	TNGT	-12	-805	-151	-4076	8	1461	243.	1.000	1.000	1.000	B31S73
		12	660	151	4076	105	-2011	255.	1.000	1.000	1.000	
133 B 133 M	BEND	-12	151	-660	-4076	-2011	-105	456.	2.386	7.121	7.121	B31S73
		-98	-115	433	4560	-887	270	466.	2.386	7.121	7.121	
133 M 135	BEND	98	115	-433	-4560	887	-270	466.	2.386	7.121	7.121	B31S73
		-151	-12	205	2754	-3520	349	449.	2.386	7.121	7.121	
135 140	TNGT	151	205	12	-2754	349	3520	251.	1.000	1.000	1.000	B31S73
		-151	-157	-12	2754	-352	-3475	249.	1.000	1.000	1.000	

Calc. 1-1 R.  
APR 2, 2017

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 178

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
140 144	TNGT	151 -151	157 -12	12 -12	-2754 2754	352 -361	3475 -3411	249. 246.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
144 145	TNGT	151 -151	12 8739	12 -12	-2754 2754	361 -390	3411 -13955	246. 797.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
145 146	TNGT	151 -151	17950 20071	12 -12	-2754 2754	390 -515	13955 -25091	797. 1414.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
146 147	TNGT	151 -151	9952 -1201	12 -12	-2754 2754	515 -544	25091 -11614	1414. 669.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
147 150	TNGT	151 -151	1201 -1144	12 -12	-2754 2754	544 -547	11614 -11266	669. 650.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
150 155 M	BEND	151 -367	662 -495	-933 839	-2753 -1005	9566 -9386	5976 -5633	1163. 1101.	2.386 2.386	7.121 7.121	7.121 7.121	B31S7
155 M 155 E	BEND	367 -483	495 -271	-839 746	1005 -4420	9386 -7837	5633 -5406	1101. 1052.	2.386 2.386	7.121 7.121	7.121 7.121	B31S7
155 E 160 B	TNGT	483 -201	789 -148	-86 86	4420 -4420	-1391 1704	9419 -7719	588. 507.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
160 B 160 M	BEND	201 -153	12 -24	171 -31	4420 -1749	-6174 7307	-4937 4950	693. 688.	1.821 1.821	4.747 4.747	4.747 4.747	B31S7
160 M 160 E	BEND	153 -151	24 -61	31 108	1749 1176	-7307 7456	-4950 4987	688. 692.	1.821 1.821	4.747 4.747	4.747 4.747	B31S7
160 E 165	TNGT	151 -151	-124 652	12 -12	-1176 1176	157 -190	8968 -10030	507. 566.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
165 165A	TNGT	151 -151	3314 -2216	12 -12	-1176 1176	190 -258	10030 5695	566. 326.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
165A 165B	TNGT	151 -151	2216 -1118	12 -12	-1176 1176	258 -326	-5695 15175	326. 853.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
165B 165C	TNGT	151 -151	1118 -20	12 -12	-1176 1176	326 -394	-15175 18409	853. 1033.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
165C 170	TNGT	151 -151	-12 12	20 1079	-1176 1176	18409 -15397	394 -461	1033. 948.	1.000 1.461	1.000 1.000	1.000 1.000	B31S7
170 175	TNGT	151 -151	81 -81	-1861 2247	-1337 1337	15128 -11020	947 -784	934. 935.	1.461 2.000	1.000 1.000	1.000 1.000	B31S7
175 180	TNGT	151 -151	-2247 2950	-81 81	-1337 1337	784 -323	-11020 -3706	1937. 459.	2.000 1.000	1.000 1.000	1.000 1.000	B31S7

4  
 2  
 1  
 3  
 5  
 6  
 7  
 8

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 179

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
180	TNGT	151	864	-81	-1337	323	3706	459.	1.000	1.000	1.000	B31S73
230 B		-151	-420	81	1337	-32	-1406	225.	1.000	1.000	1.000	
230 B	BEND	151	-81	-420	-1337	1406	-32	301.	1.782	4.598	4.598	B31S73
230 M		-49	164	249	137	-1531	-146	240.	1.782	4.598	4.598	
230 M	BEND	49	-164	-249	-137	1531	146	240.	1.782	4.598	4.598	B31S73
230 E		81	151	79	-888	-982	-374	213.	1.782	4.598	4.598	
230 E	TNGT	-81	79	-151	888	-374	982	160.	1.000	1.000	1.000	B31S73
230A		81	241	151	-888	762	-1191	194.	1.000	1.000	1.000	
230A	TNGT	-81	-241	-151	888	-762	1191	194.	1.000	1.000	1.000	B31S73
235 B		81	560	151	-888	1150	-2220	308.	1.000	1.000	1.000	
235 B	BEND	-81	560	151	888	1150	-2220	412.	1.782	4.598	4.598	B31S73
235 M		-459	-574	-151	-1519	-372	3055	532.	1.782	4.598	4.598	
235 M	BEND	459	574	151	1519	372	-3055	532.	1.782	4.598	4.598	B31S73
235 E		-901	-81	-151	-1414	624	3559	602.	1.782	4.598	4.598	
235 E	TNGT	901	-81	-151	1414	624	3559	450.	1.000	1.000	1.000	B31S73
D90		-1242	81	151	-1414	-210	-3783	520.	1.871	1.000	1.000	
115	TNGT	-41	149	390	-2315	7162	1292	469.	1.461	1.000	1.000	B31S73
240		41	-149	-3	2315	-7555	-993	669.	2.000	1.000	1.000	
240	TNGT	-41	3	-149	-2315	993	-7555	1386.	2.000	1.000	1.000	B31S73
240A		41	570	149	2315	-303	6244	774.	1.000	1.000	1.000	
240A	TNGT	-41	-570	-149	-2315	303	-6244	774.	1.000	1.000	1.000	B31S73
245 B		41	1144	149	2315	388	2279	380.	1.000	1.000	1.000	
245 B	BEND	-41	-149	1144	-2315	-2279	388	508.	1.782	4.598	4.598	B31S73
245 M		134	77	-1315	2633	-1552	-552	482.	1.782	4.598	4.598	
245 M	BEND	-134	-77	1315	-2633	1552	552	482.	1.782	4.598	4.598	B31S73
245 E		149	-41	-1485	60	-4697	-579	734.	1.782	4.598	4.598	
245 E	TNGT	-149	-1485	41	-60	-579	4697	549.	1.000	1.000	1.000	B31S73
250		149	1723	-41	60	501	-7771	904.	1.000	1.000	1.000	
250	TNGT	-149	1616	41	-60	-501	7771	904.	1.000	1.000	1.000	B31S73
255 B		149	-905	-41	60	268	-549	71.	1.000	1.000	1.000	
255 B	BEND	-149	-905	-41	-60	-126	-182	95.	1.782	4.598	4.598	B31S73
255 M		625	414	41	-126	-395	-549	70.	1.782	4.598	4.598	
255 M	BEND	-625	-414	-41	126	182	395	70.	1.782	4.598	4.598	B31S73
255 E		564	-149	41	-197	11	-558	92.	1.782	4.598	4.598	

CALC. 1-1 K  
APR. 2, 1992

1-1

WT01

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 180

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI) .75IM/Z	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE CLASS
		FA	FB	FC	MA	MB	MC				
255 C90	E TNGT	-564 461	-149 149	41 -41	197 -197	11 -44	-558 433	69. 61.	1.000 1.871	1.000 1.000	1.000 B31S73 1.000
170 170A	TNGT	93 -93	0 0	783 -167	-269 269	161 -2517	-485 486	59. 299.	1.461 1.000	1.000 1.000	1.000 B31S73 1.000
170A 170B	TNGT	93 -93	167 449	0 0	-269 269	-486 486	-2517 1815	299. 220.	1.000 1.000	1.000 1.000	1.000 B31S73 1.000
170B 260 B	TNGT	93 -93	-449 1065	0 0	-269 269	-486 486	-1815 -1946	220. 235.	1.000 1.000	1.000 1.000	1.000 B31S73 1.000
260 B 260 M	BEND	93 -940	1065 -808	0 0	-269 -153	486 -534	-1946 3317	314. 522.	1.782 1.782	4.598 4.598	4.598 B31S73 4.598
260 M 260 E	BEND	940 -1406	808 93	0 0	153 -486	534 -269	-3317 3865	522. 606.	1.782 1.782	4.598 4.598	4.598 B31S73 4.598
260 E B90	TNGT	1406 -1748	93 -93	0 0	486 -486	-269 270	3865 -3608	453. 469.	1.000 1.871	1.000 1.000	1.000 B31S73 1.000
B97 S01	TNGT	128 -128	-23920 23920	1 -1	-34666 34666	-9242 9240	51893 -129634	228. 486.	1.000 1.000	1.000 1.000	1.000 B31S73 1.000
S01 A97	TNGT	-1010 1010	-23899 23899	2 -2	-36608 36608	-7507 7500	129211 -212960	486. 781.	1.000 1.000	1.000 1.000	1.000 B31S73 1.000
C97 MS2	TNGT	122 -122	115615 -115615	-238 238	-1853 1853	-7879 8654	78404 297343	285. 1074.	1.000 1.000	1.000 1.000	1.000 B31S73 1.000
MS2 B97	TNGT	6363 -6363	113801 -113801	252 -252	-38692 38692	10800 -11563	294750 49905	1074. 232.	1.000 1.000	1.000 1.000	1.000 B31S73 1.000
D97 S00	TNGT	100 -100	26609 -26609	-226 226	-18168 18168	-7749 8485	244521 -158040	886. 575.	1.000 1.000	1.000 1.000	1.000 B31S73 1.000
S00 C97	TNGT	1382 -1382	26574 -26574	-214 214	-35490 35490	-6815 7570	155154 -61494	575. 258.	1.000 1.000	1.000 1.000	1.000 B31S73 1.000
A07 AR5	TNGT	4733 -5360	0 0	0 0	0 0	0 0	0 0	0. 0.	7.400 1.000	1.000 1.000	1.000 B31S73 1.000
B07 BR5	TNGT	3970 -4597	0 0	0 0	0 0	0 0	0 0	0. 0.	7.400 1.000	1.000 1.000	1.000 B31S73 1.000
C07 CR5	TNGT	3199 -3825	0 0	0 0	0 0	0 0	0 0	0. 0.	7.400 1.000	1.000 1.000	1.000 B31S73 1.000
D07 DR5	TNGT	3217 -3844	0 0	0 0	0 0	0 0	0 0	0. 0.	7.400 1.000	1.000 1.000	1.000 B31S73 1.000
*** AT THE MEMBER END ASV		OF ELEMENT FROM A95A TO ASV			, MAX. STRESS (PSI) IS			2506.	Calc. 1-1 P.50 A(1-2)		

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE : WT02

ELEMENT	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (.75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS	
		FROM	TO	FA	FB	FC	MA	MB	MC				
A05	TNGT			4	-10129	9	-653	-433	-27399	703.	1.080	1.000	1.000 B31S73
A06		-4		8804	-9		653	393	-16776	430.	1.000	1.000	1.000
A06	TNGT			4	1271	9	-653	-393	16776	430.	1.000	1.000	1.000 B31S73
A07		-4		-3495	-9		653	326	1894	289.	7.400	1.000	1.000
A07	TNGT			1943	4	9	326	-653	-1894	289.	7.400	1.000	1.000 B31S73
A07A		-768		-4	-9		-326	617	1910	52.	1.000	1.000	1.000
A07A	TNGT			768	4	9	326	-617	-1910	52.	1.000	1.000	1.000 B31S73
A07B		407		-4	-9		-326	582	1926	52.	1.000	1.000	1.000
A07B	TNGT			-407	4	9	326	-582	-1926	52.	1.000	1.000	1.000 B31S73
A10 B		1583		-4	-9		-326	546	1942	52.	1.000	1.000	1.000
A10 B	TNGT			1583	4	9	326	-546	-1942	93.	2.356	6.986	6.986 B31S73
A10 M	BEND			-1583	-4	9	326	-546	-1942	3912	2.356	6.986	6.986
A10 M		1629		-1634	-9		148	597		179.	2.356	6.986	6.986
A10 M	BEND			-1629	1634	9	-148	-597	-3912	179.	2.356	6.986	6.986 B31S73
A10 E		-4		-3032	-9		518	298	10096	458.	2.356	6.986	6.986
A10 E	TNGT			4	3032	9	-518	-298	-10096	259.	1.000	1.000	1.000 B31S73
A15		-4		-3588	-9		518	281	16578	425.	1.000	1.000	1.000
A15	TNGT			4	-4670	9	-518	-281	-16578	425.	1.000	1.000	1.000 B31S73
A15A		-4		2486	-9		518	216	-10941	281.	1.000	1.000	1.000
A15A	TNGT			4	-2486	9	-518	-216	10941	281.	1.000	1.000	1.000 B31S73
A15B		-4		302	-9		518	150	-21665	555.	1.000	1.000	1.000
A15B	TNGT			4	-302	9	-518	-150	21665	555.	1.000	1.000	1.000 B31S73
A15C		-4		-1881	-9		518	84	-15593	400.	1.000	1.000	1.000
A15C	TNGT			4	1881	9	-518	-84	15593	400.	1.000	1.000	1.000 B31S73
A20		-4		-4065	-9		518	18	7275	187.	1.000	1.000	1.000
A20	TNGT			4	-1910	9	-518	-18	-7275	187.	1.000	1.000	1.000 B31S73
A25		-4		1311	-9		518	0	3878	100.	1.000	1.000	1.000
A25	TNGT			4	-1311	9	-518	0	-3878	100.	1.000	1.000	1.000 B31S73
A30 B		-4		601	-9		518	-21	1488	40.	1.000	1.000	1.000
A30 B	BEND	4		9	601		-518	-1488	-21	71.	2.356	6.986	6.986 B31S73
A30 M		-9		-3	124		1081	183	37	50.	2.356	6.986	6.986

CDC-1-1  
APR 2011  
P.1

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 221

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
A30 M	BEND	9	3	-124	-1081	-183	-37	50.	2.356	6.986	6.986	B31S73
A30 E		-9	4	848	1246	527	37	61.	2.356	6.986	6.986	
A30 E	TNGT	9	-848	4	-1246	-37	527	35.	1.000	1.000	1.000	B31S73
A35		-9	1804	-4	1246	24	-4988	132.	1.000	1.000	1.000	
A35	TNGT	9	357	4	-1246	-24	4988	132.	1.000	1.000	1.000	B31S73
A35A		-9	902	-4	1246	7	-6197	162.	1.000	1.000	1.000	
A35A	TNGT	9	-902	4	-1246	-7	6197	162.	1.000	1.000	1.000	B31S73
A35B		-9	2161	-4	1246	-10	-12989	334.	1.000	1.000	1.000	
A35B	TNGT	9	-2161	4	-1246	10	12989	334.	1.000	1.000	1.000	B31S73
A40		-9	3420	-4	1246	-27	-25362	651.	1.000	1.000	1.000	
A40	TNGT	9	5113	4	-1246	27	25362	651.	1.000	1.000	1.000	B31S73
A40A		-9	-3322	-4	1246	-51	1232	45.	1.000	1.000	1.000	
A40A	TNGT	9	3322	4	-1246	51	-1232	45.	1.000	1.000	1.000	B31S73
A40B		-9	-1532	-4	1246	-76	16537	425.	1.000	1.000	1.000	
A40B	TNGT	9	1532	4	-1246	76	-16537	425.	1.000	1.000	1.000	B31S73
A40C		-9	258	-4	1246	-100	20554	528.	1.000	1.000	1.000	
A40C	TNGT	9	-258	4	-1246	100	-20554	528.	1.000	1.000	1.000	B31S73
A40D		-9	2048	-4	1246	-124	13282	342.	1.000	1.000	1.000	
A40D	TNGT	9	-2048	4	-1246	124	-13282	342.	1.000	1.000	1.000	B31S73
A40E		-9	3839	-4	1246	-148	-5277	139.	1.000	1.000	1.000	
A40E	TNGT	9	-3839	4	-1246	148	5277	139.	1.000	1.000	1.000	B31S73
A45		-9	5629	-4	1246	-172	-35126	901.	1.000	1.000	1.000	
A45	TNGT	9	5315	4	-1246	172	35126	901.	1.000	1.000	1.000	B31S73
A45A		-9	-3521	-4	1246	-197	-7205	187.	1.000	1.000	1.000	
A45A	TNGT	9	3521	4	-1246	197	7205	187.	1.000	1.000	1.000	B31S73
A45B		-9	-1727	-4	1246	-221	9377	243.	1.000	1.000	1.000	
A45B	TNGT	9	1727	4	-1246	221	-9377	243.	1.000	1.000	1.000	B31S73
A45C		-9	67	-4	1246	-245	14621	376.	1.000	1.000	1.000	
A45C	TNGT	9	-67	4	-1246	245	-14621	376.	1.000	1.000	1.000	B31S73
A45D		-9	1861	-4	1246	-269	8527	221.	1.000	1.000	1.000	
A45D	TNGT	9	-1861	4	-1246	269	-8527	221.	1.000	1.000	1.000	B31S73
A45E		-9	3656	-4	1246	-294	-8905	231.	1.000	1.000	1.000	
A45E	TNGT	9	-3656	4	-1246	294	8905	231.	1.000	1.000	1.000	B31S73
A50		-9	5450	-4	1246	-318	-37675	966.	1.000	1.000	1.000	

2  
 1  
 0  
 9  
 8  
 7  
 6  
 5  
 4  
 3  
 2  
 1

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 222

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI) .75IN/Z	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE CLASS
		FA	FB	FC	MA	MB	MC				
A50	TNGT	9	5902	4	-1246	318	37675	966.	1.000	1.000	1.000 B31S73
A50A		-9	-4109	-4	1246	-342	-6061	159.	1.000	1.000	1.000
A50A	TNGT	9	4109	4	-1246	342	6061	159.	1.000	1.000	1.000 B31S73
A50B		-9	-2316	-4	1246	-366	14226	366.	1.000	1.000	1.000
A50B	TNGT	9	2316	4	-1246	366	-14226	366.	1.000	1.000	1.000 B31S73
A50C		-9	-522	-4	1246	-391	23188	595.	1.000	1.000	1.000
A50C	TNGT	9	522	4	-1246	391	-23188	595.	1.000	1.000	1.000 B31S73
A50D		-9	1271	-4	1246	-415	20825	535.	1.000	1.000	1.000
A50D	TNGT	9	-1271	4	-1246	415	-20825	535.	1.000	1.000	1.000 B31S73
A50E		-9	3064	-4	1246	-439	7135	186.	1.000	1.000	1.000
A50E	TNGT	9	-3064	4	-1246	439	-7135	186.	1.000	1.000	1.000 B31S73
A55		-9	4857	-4	1246	-463	-17880	460.	1.000	1.000	1.000
A55	TNGT	9	3310	4	-1246	463	17880	460.	1.000	1.000	1.000 B31S73
A60		-9	-1447	-4	1246	-489	-2273	68.	1.000	1.000	1.000
A60	TNGT	9	1447	4	-1246	489	2273	68.	1.000	1.000	1.000 B31S73
A65 B		-9	239	-4	1246	-511	1311	48.	1.000	1.000	1.000
A65 B	BEND	9	4	239	-1246	-1311	-511	85.	2.356	6.986	6.986 B31S73
A65 M		-9	3	-964	1346	-1382	512	90.	2.356	6.986	6.986
A65 M	BEND	9	-3	964	-1346	1382	-512	90.	2.356	6.986	6.986 B31S73
A65 E		-4	9	-1689	-1178	-5022	496	235.	2.356	6.986	6.986
A65 E	TNGT	4	1689	9	1178	-496	-5022	133.	1.000	1.000	1.000 B31S73
A65A		-4	-2785	-9	-1178	463	13661	352.	1.000	1.000	1.000
A65A	TNGT	4	2785	9	1178	-463	-13661	352.	1.000	1.000	1.000 B31S73
A70		-4	-3882	-9	-1178	430	26534	681.	1.000	1.000	1.000
A70	TNGT	4	-5094	9	1178	-430	-26534	681.	1.000	1.000	1.000 B31S73
A70A		-4	3324	-9	-1178	377	294	33.	1.000	1.000	1.000
A70A	TNGT	4	-3324	9	1178	-377	-294	33.	1.000	1.000	1.000 B31S73
A70B		-4	1554	-9	-1178	323	-14911	383.	1.000	1.000	1.000
A70B	TNGT	4	-1554	9	1178	-323	14911	383.	1.000	1.000	1.000 B31S73
A70C		-4	-216	-9	-1178	270	-19080	490.	1.000	1.000	1.000
A70C	TNGT	4	216	9	1178	-270	19080	490.	1.000	1.000	1.000 B31S73
A70D		-4	-1986	-9	-1178	216	-12216	315.	1.000	1.000	1.000
A70D	TNGT	4	1986	9	1178	-216	12216	315.	1.000	1.000	1.000 B31S73
A75		-4	-3756	-9	-1178	163	5685	149.	1.000	1.000	1.000

APP 2  
 P 53  
 CLO. 1-1 R. 1

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 223

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
A75 A75A	TNGT	4 -4	-3690 1973	9 -9	1178 -1178	-163 111	-5685 -11439	149. 295.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A75A A75B	TNGT	4 -4	-1973 257	9 -9	1178 -1178	-111 59	11439 -18181	295. 467.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A75B A75C	TNGT	4 -4	-257 -1460	9 -9	1178 -1178	-59 8	18181 -14542	467. 374.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A75C A80	TNGT	4 -4	1460 -3177	9 -9	1178 -1178	-8 -44	14542 -522	374. 33.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A80 A80A	TNGT	4 -4	-1019 -823	9 -9	1178 -1178	44 -100	522 -1159	33. 42.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A80A A85	TNGT	4 -4	823 -2664	9 -9	1178 -1178	100 -155	1159 10151	42. 262.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A85 A88 B	TNGT	4 -4	-2646 2307	9 -9	1178 -1178	155 -165	-10151 7197	262. 187.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A88 B A88 M	BEND	4 3	-9 9	-2307 1582	1178 -3961	7197 167	165 -189	330. 180.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
A88 M A88 E	BEND	-3 9	-9 4	-1582 858	3961 -1411	-167 5677	189 -206	180. 265.	2.356 2.356	6.986 6.986	6.986 6.986	B31S73
A88 E A90	TNGT	-9 9	-858 396	4 -4	1411 -1411	206 -212	5677 -6695	150. 246.	1.000 1.871	1.000 1.000	1.000 1.000	B31S73
A90 A90A	TNGT	-60 60	-882 -1293	60 -60	2112 -2112	-483 21	5472 -3899	212. 114.	1.871 1.000	1.000 1.000	1.000 1.000	B31S73
A90A A95	TNGT	-60 60	1293 -3467	60 -60	2112 -2112	-21 -441	3899 14328	114. 371.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A95 A95A	TNGT	-60 60	-2056 859	60 -60	2112 -2112	441 -696	-14328 8183	371. 217.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A95A ASV	TNGT	-60 60	-859 -338	60 -60	2112 -2112	696 -950	-8183 7085	217. 191.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
ASV A97	TNGT	-60 60	338 -1475	60 -60	2112 -2112	950 -1191	-7085 10710	27. 40.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
A97 MS1	TNGT	0 0	72364 -73393	0 0	0 0	0 0	264149 36	954. 0.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73
MS1 S02	TNGT	0 0	-142 0	0 0	0 0	0 0	-36 0	0. 0.	1.000 1.000	1.000 1.000	1.000 1.000	B31S73

Calc. 1-1  
App. 2.  
P.S4

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 224

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
A97 GA1	TNGT	-15335 12877	-12378 10364	244 -244	-1164 1164	-9190 6466	-27161 -99933	190. 662.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA1 CV1	TNGT	0 0	42699 -43472	0 0	0 0	0 0	117138 0	774. 0.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA1 GA1A	TNGT	-14528 12363	-244 244	143 -143	-4998 4998	17204 -18002	-4264 2908	315. 323.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA1A GA1B	TNGT	-12363 10198	-244 244	143 -143	-4998 4998	18002 -18801	-2908 1553	323. 333.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA1B GA2 B	TNGT	-10198 8033	-244 244	143 -143	-4998 4998	18801 -19599	-1553 197	333. 346.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA2 B GA2 M	BEND	-8033 5032	-152 -4816	-238 238	-4998 3125	924 -3598	19578 -12443	528. 348.	2.038 2.038	5.622 5.622	5.622 5.622	B31S7.
GA2 M GA2 E	BEND	-5032 152	4816 -5894	-238 238	-3125 -90	3598 -4164	12443 3238	348. 138.	2.038 2.038	5.622 5.622	5.622 5.622	B31S7.
GA2 E GA2A	TNGT	-152 152	-5894 4016	238 -238	90 -90	-4164 3015	3238 -27138	90. 466.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA2A GA2B	TNGT	-152 152	-4016 2139	238 -238	90 -90	-3015 1866	27138 -41983	466. 718.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA2B GA2C	TNGT	-152 152	-2139 262	238 -238	90 -90	-1866 717	41983 -47773	718. 816.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA2C GA2D	TNGT	-152 152	-262 -1616	238 -238	90 -90	-717 -432	47773 -44508	816. 760.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA2D GA2E	TNGT	-152 152	1616 -3493	238 -238	90 -90	432 -1581	44508 -32188	760. 550.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA2E GA4 B	TNGT	-152 152	3493 -5370	238 -238	90 -90	1581 -2731	32188 -10812	550. 190.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA4 B GA4 M	BEND	-152 4662	-5370 4446	-238 238	90 2111	-2731 2584	-10812 -3573	291. 128.	2.038 2.038	5.622 5.622	5.622 5.622	B31S7.
GA4 M GA4 E	BEND	-4662 7510	-4446 -152	-238 238	-2111 3564	-2584 924	3573 -10171	128. 282.	2.038 2.038	5.622 5.622	5.622 5.622	B31S7.
GA4 E GA4 A	TNGT	-7510 9711	244 -244	143 -143	-3564 3564	-10198 9387	-546 1924	185. 175.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.
GA4 A GA4 B	TNGT	-9711 11913	244 -244	143 -143	-3564 3564	-9387 8575	-1924 3303	175. 168.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7.

 Calc. 1-1 R.  
 APP. 2, P. 55

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI 75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
GA4B	TNGT	-11913	244	143	-3564	-8575	-3303	168.	1.000	1.000	1.000	B31S7:
GA4C		14114	-244	-143	3564	7764	4681	166.	1.000	1.000	1.000	
GA4C	TNGT	-14114	244	143	-3564	-7764	-4681	166.	1.000	1.000	1.000	B31S7:
GA4D		16315	-244	-143	3564	6952	6060	169.	1.000	1.000	1.000	
GA4D	TNGT	-16315	244	143	-3564	-6952	-6060	169.	1.000	1.000	1.000	B31S7:
GA4E		18517	-244	-143	3564	6141	7438	176.	1.000	1.000	1.000	
GA4E	TNGT	-18517	244	143	-3564	-6141	-7438	176.	1.000	1.000	1.000	B31S7:
GA4F		20718	-244	-143	3564	5329	8817	186.	1.000	1.000	1.000	
GA4F	TNGT	-20718	244	143	-3564	-5329	-8817	186.	1.000	1.000	1.000	B31S7:
GA4G		22919	-244	-143	3564	4518	10195	200.	1.000	1.000	1.000	
GA4G	TNGT	-22919	244	143	-3564	-4518	-10195	200.	1.000	1.000	1.000	B31S7:
GA5 B		25121	-244	-143	3564	3706	11574	216.	1.000	1.000	1.000	
GA5 B	BEND	-25121	-244	-143	-3564	3706	11574	433.	2.670	8.433	8.433	B31S7:
GA5 M		18440	-18095	-143	-2	-4904	5513	252.	2.670	8.433	8.433	
GA5 M	BEND	-18440	18095	-143	2	4904	-5513	252.	2.670	8.433	8.433	B31S7:
GA5 E		244	-26547	143	-3371	-3230	48591	1670.	2.670	8.433	8.433	
GA5 E	TNGT	-244	26807	-143	-3371	3134	-66376	1137.	1.000	1.000	1.000	B31S7:
B05	TNGT	5	-10371	13	-226	-650	-28283	725.	1.080	1.000	1.000	B31S7:
B06		-5	9046	-13	226	587	-17024	437.	1.000	1.000	1.000	
B06	TNGT	5	1029	13	-226	-587	17024	437.	1.000	1.000	1.000	B31S7:
B07		-5	-3253	-13	226	482	-255	84.	7.400	1.000	1.000	
B07	TNGT	1547	5	13	482	-226	255	84.	7.400	1.000	1.000	B31S7:
B07A		-371	-5	-13	-482	170	-234	14.	1.000	1.000	1.000	
B07A	TNGT	371	5	13	482	-170	234	14.	1.000	1.000	1.000	B31S7:
B07B		804	-5	-13	-482	114	-212	14.	1.000	1.000	1.000	
B07B	TNGT	-804	5	13	482	-114	212	14.	1.000	1.000	1.000	B31S7:
B10 B		1979	-5	-13	-482	58	-191	13.	1.000	1.000	1.000	
B10 B	BEND	-1979	5	13	482	-58	191	14.	1.000	1.000	1.000	B31S7:
B10 M		1908	-1915	-13	-312	351	2160	100.	2.356	6.986	6.986	
B10 M	BEND	-1908	1915	13	312	14	438	100.	2.356	6.986	6.986	B31S7:
B10 E		-5	-3428	-13	14	-351	-2160	420.	2.356	6.986	6.986	
B10 E	TNGT	5	3428	13	-14	-438	-9255	237.	1.000	1.000	1.000	B31S7:
B15		-5	-3988	-13	14	411	16576	425.	1.000	1.000	1.000	

Calc. 1-1 R.1

App. 2,

P. S6

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 226

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
B15	TNGT	5	-4262	13	-14	-411	-16576	425.	1.000	1.000	1.000	B31S7:
B15A		-5	2043	-13	14	306	-8057	207.	1.000	1.000	1.000	
B15A	TNGT	5	-2043	13	-14	-306	8057	207.	1.000	1.000	1.000	B31S7:
B15B		-5	-175	-13	14	200	-15356	394.	1.000	1.000	1.000	
B15B	TNGT	5	175	13	-14	-200	15356	394.	1.000	1.000	1.000	B31S7:
B15C		-5	-2394	-13	14	95	-5320	136.	1.000	1.000	1.000	
B15C	TNGT	5	2394	13	-14	-95	5320	136.	1.000	1.000	1.000	B31S7:
B20		-5	-4612	-13	14	-11	22051	565.	1.000	1.000	1.000	
B20	TNGT	5	-3638	13	-14	11	-22051	565.	1.000	1.000	1.000	B31S7:
B25		-5	1881	-13	14	-94	4978	128.	1.000	1.000	1.000	
B25	TNGT	5	-1881	13	-14	94	-4978	128.	1.000	1.000	1.000	B31S7:
B30 B		-5	1384	-13	14	-118	2121	54.	1.000	1.000	1.000	
B30 B	BEND	5	-1384	13	-14	94	-4978	128.	1.000	1.000	1.000	B31S7:
B30 M		-13	6	1384	-14	-2121	-118	96.	2.356	6.986	6.986	
B30 M	BEND	13	-6	-659	427	-813	144	42.	2.356	6.986	6.986	B31S7:
B30 E		-13	5	659	-427	813	-144	42.	2.356	6.986	6.986	
B30 E	TNGT	13	-65	5	666	-145	-1514	43.	1.000	1.000	1.000	B31S7:
B30A		-13	887	-5	-666	130	137	18.	1.000	1.000	1.000	
B30A	TNGT	13	-887	5	666	-130	-137	18.	1.000	1.000	1.000	B31S7:
B35		-13	1708	-5	-666	115	-3617	94.	1.000	1.000	1.000	
B35	TNGT	13	597	5	666	-115	3617	94.	1.000	1.000	1.000	B31S7:
B35A		-13	1368	-5	-666	79	-6287	162.	1.000	1.000	1.000	
B35A	TNGT	13	-1368	5	666	-79	6287	162.	1.000	1.000	1.000	B31S7:
B40		-13	3333	-5	-666	43	-22559	578.	1.000	1.000	1.000	
B40	TNGT	13	4825	5	666	-43	22559	578.	1.000	1.000	1.000	B31S7:
B40A		-13	-3126	-5	-666	12	1232	36.	1.000	1.000	1.000	
B40A	TNGT	13	3126	5	666	-12	-1232	36.	1.000	1.000	1.000	B31S7:
B40B		-13	-1427	-5	-666	-19	14856	381.	1.000	1.000	1.000	
B40B	TNGT	13	1427	5	666	19	-14856	381.	1.000	1.000	1.000	B31S7:
B40C		-13	272	-5	-666	-50	18312	470.	1.000	1.000	1.000	
B40C	TNGT	13	-272	5	666	50	-18312	470.	1.000	1.000	1.000	B31S7:
B40D		-13	1971	-5	-666	-80	11600	298.	1.000	1.000	1.000	
B40D	TNGT	13	-1971	5	666	80	-11600	298.	1.000	1.000	1.000	B31S7:
B40E		-13	3670	-5	-666	-111	-5279	136.	1.000	1.000	1.000	

Calc. 1-1 R.  
App. 2, P. 1

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI 75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
B40E B45	TNGT	13 -13	-3670 5369	5 -5	666 -666	111 -142	5279 -32327	136. 829.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B45 B45A	TNGT	13 -13	5142 -3348	5 -5	666 -666	142 -175	32327 -5507	829. 142.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B45A B45B	TNGT	13 -13	3348 -1555	5 -5	666 -666	175 -208	5507 9980	142. 256.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B45B B45C	TNGT	13 -13	1555 239	5 -5	666 -666	208 -240	-9980 14136	256. 363.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B45C B45D	TNGT	13 -13	-239 2033	5 -5	666 -666	240 -273	-14136 6959	363. 179.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B45D B45E	TNGT	13 -13	-2033 3826	5 -5	666 -666	273 -306	-6959 -11549	179. 297.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B45E B50	TNGT	13 -13	-3826 5620	5 -5	666 -666	306 -338	11549 -41389	297. 1061.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B50 B50A	TNGT	13 -13	6326 -4533	5 -5	666 -666	338 -371	41389 -7090	1061. 183.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B50A B50B	TNGT	13 -13	4533 -2740	5 -5	666 -666	371 -404	7090 15879	183. 407.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B50B B50C	TNGT	13 -13	2740 -946	5 -5	666 -666	404 -436	-15879 27520	407. 706.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B50C B50D	TNGT	13 -13	946 847	5 -5	666 -666	436 -469	-27520 27832	706. 714.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B50D B50E	TNGT	13 -13	-847 2641	5 -5	666 -666	469 -502	-27832 16816	714. 432.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B50E B55	TNGT	13 -13	-2641 4434	5 -5	666 -666	502 -534	-16816 -5530	432. 143.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B55 B60	TNGT	13 -13	2625 1033	5 -5	666 -666	534 -601	5530 4729	143. 123.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B60 B65 B	TNGT	13 -13	-1033 1583	5 -5	666 -666	601 -611	-4729 2195	123. 61.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7:
B65 B B65 M	BEND	13 -13	5 6	1583 -2308	666 -661	-2195 -2494	-611 610	107. 120.	2.356 2.356	6.986 6.986	6.986 6.986	B31S7:
B65 M B65 E	BEND	13 -5	-6 13	2308 -3032	661 -4662	2494 -7478	-610 584	120. 400.	2.356 2.356	6.986 6.986	6.986 6.986	B31S7:

Calc. 1-1 R.  
Rev. 2, P. 58

1-1 WT02 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 228

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS .75IM/Z )	STRESS INT.FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
B65 E	TNGT	5	3032	13	4662	-584	-7478	226.	1.000	1.000	1.000	B31S7:
B70		-5	-4283	-13	-4662	524	23596	617.	1.000	1.000	1.000	
B70 A	TNGT	5	-4105	13	4662	-524	-23596	617.	1.000	1.000	1.000	B31S7:
B70A		-5	2362	-13	-4662	441	3752	154.	1.000	1.000	1.000	
B70A B	TNGT	5	-2362	13	4662	-441	-3752	154.	1.000	1.000	1.000	B31S7:
B70B		-5	620	-13	-4662	359	-5398	183.	1.000	1.000	1.000	
B70B B70C	TNGT	5	-620	13	4662	-359	5398	183.	1.000	1.000	1.000	B31S7:
B70C		-5	-1123	-13	-4662	276	-3853	155.	1.000	1.000	1.000	
B70C B70D	TNGT	5	1123	13	4662	-276	3853	155.	1.000	1.000	1.000	B31S7:
B70D		-5	-2866	-13	-4662	193	8387	246.	1.000	1.000	1.000	
B70D B75	TNGT	5	2866	13	4662	-193	-8387	246.	1.000	1.000	1.000	B31S7:
B75		-5	-4608	-13	-4662	110	31321	812.	1.000	1.000	1.000	
B75 A	TNGT	5	-5183	13	4662	-110	-31321	812.	1.000	1.000	1.000	B31S7:
B75A		-5	3007	-13	-4662	7	-66	119.	1.000	1.000	1.000	
B75A B75B	TNGT	5	-3007	13	4662	-7	66	119.	1.000	1.000	1.000	B31S7:
B75B		-5	830	-13	-4662	-97	-14771	397.	1.000	1.000	1.000	
B75B B75C	TNGT	5	-830	13	4662	97	14771	397.	1.000	1.000	1.000	B31S7:
B75C		-5	-1346	-13	-4662	-200	-12794	349.	1.000	1.000	1.000	
B75C B80	TNGT	5	1346	13	4662	200	12794	349.	1.000	1.000	1.000	B31S7:
B80		-5	-3522	-13	-4662	-304	5864	192.	1.000	1.000	1.000	
B80 B85 B	TNGT	5	-2342	13	4662	304	-5864	192.	1.000	1.000	1.000	B31S7:
B85		-5	2012	-13	-4662	-319	3336	147.	1.000	1.000	1.000	
B85 B	BEND	5	-13	-2012	4662	3336	319	260.	2.356	6.986	6.986	B31S7:
B85 M		6	13	1287	-3975	4683	-355	279.	2.356	6.986	6.986	
B85 M B85 E	BEND	-6	-13	-1287	3975	-4683	355	279.	2.356	6.986	6.986	B31S7:
B85 E		13	5	562	1491	8202	-380	378.	2.356	6.986	6.986	
B85 E B90	TNGT	-13	-562	5	-1491	380	8202	214.	1.000	1.000	1.000	B31S7:
B90		13	101	-5	1491	-388	-8741	319.	1.871	1.000	1.000	
B90 A	TNGT	25	1647	-34	-1643	576	14283	517.	1.871	1.000	1.000	B31S7:
B90A		-25	-3253	34	1643	-385	-423	45.	1.000	1.000	1.000	
B90A B95	TNGT	25	3253	-34	-1643	385	423	45.	1.000	1.000	1.000	B31S7:
B95		-25	-4859	34	1643	-194	22520	579.	1.000	1.000	1.000	
B95 B95A	TNGT	25	-772	-34	-1643	194	-22520	579.	1.000	1.000	1.000	B31S7:
B95A		-25	-425	34	1643	-51	21787	560.	1.000	1.000	1.000	

4012-1-1 R.  
Calc. 1-1 R.  
P.59

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI 75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
B95A BSV	TNGT	25 -25	425 -1623	-34 34	-1643 1643	51 91	-21787 26108	560. 670.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
BSV B97	TNGT	25 -25	1623 -2759	-34 34	-1643 1643	-91 227	-26108 34873	94. 126.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
B97 GB1	TNGT	-16399 13941	-13614 11600	-2 2	-20 20	1307 -1280	-48908 -91998	323. 608.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB1 CV2	TNGT	0 0	41045 -41818	0 0	0 0	0 0	112642 0	744. 0.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB1 GB1A	TNGT	-14480 12316	2 -2	-138 138	795 -795	20644 -19877	1003 -990	353. 340.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB1A GB1B	TNGT	-12316 10151	2 -2	-138 138	795 -795	19877 -19109	990 -976	340. 327.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB1B GB2 B	TNGT	-10151 7986	2 -2	-138 138	795 -795	19109 -18341	976 -963	327. 314.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB2 B GB2 M	BEND	-7986 4793	138 -4988	-2 2	795 -330	-325 798	18364 -10559	480. 277.	2.038 2.038	5.622 5.622	5.622 5.622	B31S71
GB2 M GB2 E	BEND	-4793 -138	4988 -5846	-2 2	330 333	-798 804	10559 5302	277. 140.	2.038 2.038	5.622 5.622	5.622 5.622	B31S71
GB2 E GB2A	TNGT	138 -138	-5846 3969	2 -2	-333 333	804 -815	5302 -28972	92. 495.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB2A GB2B	TNGT	138 -138	-3969 2092	2 -2	-333 333	815 -827	28972 -43588	495. 745.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB2B GB2C	TNGT	138 -138	-2092 215	2 -2	-333 333	827 -839	43588 -49151	745. 840.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB2C GB2D	TNGT	138 -138	-215 -1662	2 -2	-333 333	839 -850	49151 -45661	840. 780.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB2D GB2E	TNGT	138 -138	1662 -3539	2 -2	-333 333	850 -862	45661 -33118	780. 566.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB2E GB4 B	TNGT	138 -138	3539 -5416	2 -2	-333 333	862 -874	33118 -11521	566. 197.	1.000 1.000	1.000 1.000	1.000 1.000	B31S71
GB4 B GB4 M	BEND	138 4489	-5416 4684	-2 2	-333 856	-874 388	-11521 -3277	302. 89.	2.038 2.038	5.622 5.622	5.622 5.622	B31S71
GB4 M GB4 E	BEND	-4489 7556	-4684 138	-2 2	-856 882	-388 -325	3277 -10641	89. 279.	2.038 2.038	5.622 5.622	5.622 5.622	B31S71

 Calc. 1-1 R.  
 App. 2  
 p. 60

1-1 WT02 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 230

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
GB4 E	TNGT	-7556	-2	-138	-882	-10623	695	182.	1.000	1.000	1.000	B31S7:
GB4A		9291	2	138	882	11238	-705	193.	1.000	1.000	1.000	
GB4A	TNGT	-9291	-2	-138	-882	-11238	705	193.	1.000	1.000	1.000	B31S7:
GB4B		11026	2	138	882	11854	-716	203.	1.000	1.000	1.000	
GB4B	TNGT	-11026	-2	-138	-882	-11854	716	203.	1.000	1.000	1.000	B31S7:
GB4C		12761	2	138	882	12469	-727	214.	1.000	1.000	1.000	
GB4C	TNGT	-12761	-2	-138	-882	-12469	727	214.	1.000	1.000	1.000	B31S7:
GB4D		14497	2	138	882	13084	-737	224.	1.000	1.000	1.000	
GB4D	TNGT	-14497	-2	-138	-882	-13084	737	224.	1.000	1.000	1.000	B31S7:
GB4E		16232	2	138	882	13699	-748	235.	1.000	1.000	1.000	
GB4E	TNGT	-16232	-2	-138	-882	-13699	748	235.	1.000	1.000	1.000	B31S7:
GB4F		17967	2	138	882	14315	-759	245.	1.000	1.000	1.000	
GR4F	TNGT	-17967	-2	-138	-882	-14315	759	245.	1.000	1.000	1.000	B31S7:
GB4G		19702	2	138	882	14930	-769	256.	1.000	1.000	1.000	
GB4G	TNGT	-19702	-2	-138	-882	-14930	769	256.	1.000	1.000	1.000	B31S7:
GB5		21437	2	138	882	15545	-780	266.	1.000	1.000	1.000	
C05	TNGT	6	-10604	16	-296	-788	-29132	747.	1.080	1.000	1.000	B31S7:
C06		-6	9279	-16	296	713	-17261	443.	1.000	1.000	1.000	
C06	TNGT	6	796	16	-296	-713	17261	443.	1.000	1.000	1.000	B31S7:
C07		-6	-3020	-16	296	586	-2315	342.	7.400	1.000	1.000	
C07	TNGT	1208	6	16	586	-296	2315	342.	7.400	1.000	1.000	B31S7:
C07A		-33	-6	-16	-586	229	-2291	61.	1.000	1.000	1.000	
C07A	TNGT	33	6	16	586	-229	2291	61.	1.000	1.000	1.000	B31S7:
C07B		1143	-6	-16	-586	162	-2266	60.	1.000	1.000	1.000	
C07B	TNGT	-1143	6	16	586	-162	2266	60.	1.000	1.000	1.000	B31S7:
C10 B		2318	-6	-16	-586	94	-2242	59.	1.000	1.000	1.000	
C10 B	BEND	-2318	6	16	586	-162	2266	60.	1.000	1.000	1.000	B31S7:
C10 M		2147	-2155	-16	-363	443	2242	105.	2.356	6.986	6.986	B31S7:
C10 M	BEND	-2147	2155	16	363	-443	-432	32.	2.356	6.986	6.986	B31S7:
C10 E		-6	-3767	-16	42	533	8308	377.	2.356	6.986	6.986	
C10 E	TNGT	6	3767	16	-42	-533	-8308	213.	1.000	1.000	1.000	B31S7:
C15		-6	-4325	-16	42	501	16252	417.	1.000	1.000	1.000	
C15	TNGT	6	-3918	16	-42	-501	-16252	417.	1.000	1.000	1.000	B31S7:
C15A		-6	2172	-16	42	401	-2481	64.	1.000	1.000	1.000	

Calc. 1-1 R-1  
Ap. 2, p. 61

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 231

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI) 75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
C15A	TNGT	6	-2172	16	-42	-401	2481	64.	1.000	1.000	1.000	B31S73
C15B		-6	425	-16	42	301	-10469	268.	1.000	1.000	1.000	
C15B	TNGT	6	-425	16	-42	-301	10469	268.	1.000	1.000	1.000	B31S73
C15C		-6	-1322	-16	42	201	-7711	198.	1.000	1.000	1.000	
C15C	TNGT	6	1322	16	-42	-201	7711	198.	1.000	1.000	1.000	B31S73
C15D		-6	-3068	-16	42	101	5792	148.	1.000	1.000	1.000	
C15D	TNGT	6	3068	16	-42	-101	-5792	148.	1.000	1.000	1.000	B31S73
C20		-6	-4815	-16	42	1	30041	770.	1.000	1.000	1.000	
C20	TNGT	6	-4120	16	-42	-1	-30041	770.	1.000	1.000	1.000	B31S73
C25		-6	824	-16	42	-187	1342	35.	1.000	1.000	1.000	
C25	TNGT	6	-824	16	-42	187	-1342	35.	1.000	1.000	1.000	B31S73
C30 B		-6	635	-16	42	-198	856	23.	1.000	1.000	1.000	
C30 B	BEND	6	16	635	-42	-856	-198	40.	2.356	6.986	6.986	B31S73
C30 M		-16	-7	90	265	-5	230	16.	2.356	6.986	6.986	
C30 M	BEND	16	7	-90	-265	5	-230	16.	2.356	6.986	6.986	B31S73
C30 E		-16	6	815	504	894	232	48.	2.356	6.986	6.986	
C30 E	TNGT	16	-815	6	-504	-232	894	27.	1.000	1.000	1.000	B31S73
C35		-16	2332	-6	504	200	-9301	239.	1.000	1.000	1.000	
C35	TNGT	16	3013	6	-504	-200	9301	239.	1.000	1.000	1.000	B31S73
C35A		-16	-1167	-6	504	163	4286	111.	1.000	1.000	1.000	
C35A	TNGT	16	1167	6	-504	-163	-4286	111.	1.000	1.000	1.000	B31S73
C35B		-16	679	-6	504	125	5873	151.	1.000	1.000	1.000	
C35B	TNGT	16	-679	6	-504	-125	-5873	151.	1.000	1.000	1.000	B31S73
C35C		-16	2525	-6	504	87	-4541	117.	1.000	1.000	1.000	
C35C	TNGT	16	-2525	6	-504	-87	4541	117.	1.000	1.000	1.000	B31S73
C40		-16	4370	-6	504	49	-26954	691.	1.000	1.000	1.000	
C40	TNGT	16	5104	6	-504	-49	26954	691.	1.000	1.000	1.000	B31S73
C40A		-16	-3313	-6	504	12	-413	17.	1.000	1.000	1.000	
C40A	TNGT	16	3313	6	-504	-12	413	17.	1.000	1.000	1.000	B31S73
C40B		-16	-1523	-6	504	-25	14837	381.	1.000	1.000	1.000	
C40B	TNGT	16	1523	6	-504	25	-14837	381.	1.000	1.000	1.000	B31S73
C40C		-16	268	-6	504	-62	18796	482.	1.000	1.000	1.000	
C40C	TNGT	16	-268	6	-504	62	-18796	482.	1.000	1.000	1.000	B31S73
C40D		-16	2058	-6	504	-99	11463	294.	1.000	1.000	1.000	

Calc. 1-1 R.1  
Ap 2. A.62

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI 75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
C40D	TNGT	16	-2058	6	-504	99	-11463	294.	1.000	1.000	1.000	B31S7:
C40E		-16	3848	-6	504	-136	-7161	184.	1.000	1.000	1.000	
C40E	TNGT	16	-3848	6	-504	136	7161	184.	1.000	1.000	1.000	B31S7:
C45		-16	5639	-6	504	-172	-37077	950.	1.000	1.000	1.000	
C45	TNGT	16	5617	6	-504	172	37077	950.	1.000	1.000	1.000	B31S7:
C45A		-16	-3824	-6	504	-209	-7255	186.	1.000	1.000	1.000	
C45A	TNGT	16	3824	6	-504	209	7255	186.	1.000	1.000	1.000	B31S7:
C45B		-16	-2030	-6	504	-246	11236	288.	1.000	1.000	1.000	
C45B	TNGT	16	2030	6	-504	246	-11236	288.	1.000	1.000	1.000	B31S7:
C45C		-16	-236	-6	504	-283	18394	472.	1.000	1.000	1.000	
C45C	TNGT	16	236	6	-504	283	-18394	472.	1.000	1.000	1.000	B31S7:
C45D		-16	1557	-6	504	-320	14221	365.	1.000	1.000	1.000	
C45D	TNGT	16	-1557	6	-504	320	-14221	365.	1.000	1.000	1.000	B31S7:
C45E		-16	3351	-6	504	-357	-1284	37.	1.000	1.000	1.000	
C45E	TNGT	16	-3351	6	-504	357	1284	37.	1.000	1.000	1.000	B31S7:
C50		-16	5145	-6	504	-394	-28122	721.	1.000	1.000	1.000	
C50	TNGT	16	5727	6	-504	394	28122	721.	1.000	1.000	1.000	B31S7:
C50A		-16	-4124	-6	504	-427	-305	19.	1.000	1.000	1.000	
C50A	TNGT	16	4124	6	-504	427	305	19.	1.000	1.000	1.000	B31S7:
C50B		-16	-2520	-6	504	-460	18457	473.	1.000	1.000	1.000	
C50B	TNGT	16	2520	6	-504	460	-18457	473.	1.000	1.000	1.000	B31S7:
C50C		-16	-917	-6	504	-493	28163	722.	1.000	1.000	1.000	
C50C	TNGT	16	917	6	-504	493	-28163	722.	1.000	1.000	1.000	B31S7:
C50D		-16	686	-6	504	-526	28814	739.	1.000	1.000	1.000	
C50D	TNGT	16	-686	6	-504	526	-28814	739.	1.000	1.000	1.000	B31S7:
C50E		-16	2290	-6	504	-559	20410	523.	1.000	1.000	1.000	
C50E	TNGT	16	-2290	6	-504	559	-20410	523.	1.000	1.000	1.000	B31S7:
C55		-16	3893	-6	504	-592	2950	78.	1.000	1.000	1.000	
C55	TNGT	16	-3893	6	-504	592	-2950	78.	1.000	1.000	1.000	B31S7:
C60		-16	5042	-6	504	-615	-15131	388.	1.000	1.000	1.000	
C60	TNGT	16	2538	6	-504	615	15131	388.	1.000	1.000	1.000	B31S7:
C65 B		-16	-1268	-6	504	-641	-6619	171.	1.000	1.000	1.000	
C65 B	BEND	16	6	-1268	-504	6619	-641	302.	2.356	6.986	6.986	B31S7:
C65 M		-16	7	543	-3352	-3002	639	206.	2.356	6.986	6.986	

Calc. 1-1  
App. 2  
P. 63

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 233

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
C65 M	BEND	16	-7	-543	3352	3002	-639	206.	2.356	6.986	6.986	B31S7:
C65 E		-6	16	-182	-4211	616	608	195.	2.356	6.986	6.986	
C65 E	TNGT	6	182	16	4211	-608	616	110.	1.000	1.000	1.000	B31S7:
C65A		-6	-1244	-16	-4211	547	2052	121.	1.000	1.000	1.000	
C65A	TNGT	6	1244	16	4211	-547	-2052	121.	1.000	1.000	1.000	B31S7:
C70		-6	-2307	-16	-4211	486	8697	248.	1.000	1.000	1.000	
C70	TNGT	6	-3201	16	4211	-486	-8697	248.	1.000	1.000	1.000	B31S7:
C70A		-6	1520	-16	-4211	390	-5280	173.	1.000	1.000	1.000	
C70A	TNGT	6	-1520	16	4211	-390	5280	173.	1.000	1.000	1.000	B31S7:
C70B		-6	-161	-16	-4211	294	-9305	262.	1.000	1.000	1.000	
C70B	TNGT	6	161	16	4211	-294	9305	262.	1.000	1.000	1.000	B31S7:
C70C		-6	-1842	-16	-4211	198	-3378	138.	1.000	1.000	1.000	
C70C	TNGT	6	1842	16	4211	-198	3378	138.	1.000	1.000	1.000	B31S7:
C75		-6	-3523	-16	-4211	102	12502	338.	1.000	1.000	1.000	
C75	TNGT	6	-3859	16	4211	-102	-12502	338.	1.000	1.000	1.000	B31S7:
C75A		-6	2143	-16	-4211	3	-5630	180.	1.000	1.000	1.000	
C75A	TNGT	6	-2143	16	4211	-3	5630	180.	1.000	1.000	1.000	B31S7:
C75B		-6	428	-16	-4211	-95	-13398	360.	1.000	1.000	1.000	
C75B	TNGT	6	-428	16	4211	95	13398	360.	1.000	1.000	1.000	B31S7:
C75C		-6	-1287	-16	-4211	-193	-10802	297.	1.000	1.000	1.000	
C75C	TNGT	6	1287	16	4211	193	10802	297.	1.000	1.000	1.000	B31S7:
C80		-6	-3003	-16	-4211	-291	2156	297.	1.000	1.000	1.000	
C80	TNGT	6	1287	16	4211	193	10802	121.	1.000	1.000	1.000	B31S7:
C85 B		-6	-1524	16	4211	291	-2156	121.	1.000	1.000	1.000	
C85 B	TNGT	6	1170	-16	-4211	-311	472	109.	1.000	1.000	1.000	B31S7:
C85 M	BEND	6	-16	-1170	4211	472	311	192.	2.356	6.986	6.986	B31S7:
C85 M		7	16	445	-2433	4453	-354	230.	2.356	6.986	6.986	
C85 M	BEND	-7	-16	-445	2433	-4453	354	230.	2.356	6.986	6.986	B31S7:
C85 E		16	6	-280	1617	5013	-383	239.	2.356	6.986	6.986	
C85 E	TNGT	-16	280	6	-1617	383	5013	135.	1.000	1.000	1.000	B31S7:
C90		16	-741	-6	1617	-392	-4184	162.	1.871	1.000	1.000	
C95	TNGT	37	1101	57	-2774	67	7388	284.	1.871	1.000	1.000	B31S7:
C95		-37	-3196	-57	2774	-486	8468	229.	1.000	1.000	1.000	
C95	TNGT	37	-1526	57	-2774	486	-8468	229.	1.000	1.000	1.000	B31S7:
C96		-37	-603	-57	2774	-912	5009	149.	1.000	1.000	1.000	

Calc. / / / /  
Alt. 2 / / / /  
P / / / /  
o / / / /  
4 / / / /

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 234

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS 75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
C96 CSV	TNGT	37 -37	603 -958	57 -57	-2774 2774	912 -983	-5009 5985	149. 171.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
CSV C97	TNGT	37 -37	958 -2095	57 -57	-2774 2774	983 -1211	-5985 12091	24. 45.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
C97 GC1	TNGT	-15975 13517	-13234 11220	26 -26	1080 -1080	-1058 769	-42844 -93819	283. 620.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC1 CV3	TNGT	0 0	41613 -42386	0 0	0 0	0 0	114186 0	755. 0.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC1 GC1A	TNGT	-14479 12315	-26 26	-113 113	348 -348	20367 -19737	-1279 1135	349. 338.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC1A GC1B	TNGT	-12315 10150	-26 26	-113 113	348 -348	19737 -19106	-1135 991	338. 327.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC1B GC2 B	TNGT	-10150 7985	-26 26	-113 113	348 -348	19106 -18476	-991 848	327. 316.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC2 B GC2 M	BEND	-7985 4809	114 -4970	-22 22	348 -368	205 156	18494 -10749	483. 281.	2.038 2.038	5.622 5.622	5.622 5.622	B31S7: 5.622
GC2 M GC2 E	BEND	-4809 -114	4970 -5845	-22 22	368 -128	-156 425	10749 5085	281. 133.	2.038 2.038	5.622 5.622	5.622 5.622	B31S7: 5.622
GC2 E GC2A	TNGT	114 -114	-5845 3968	22 -22	128 -128	425 -530	5085 -28751	87. 491.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC2A GC2B	TNGT	114 -114	-3968 2091	22 -22	128 -128	530 -636	28751 -43362	491. 741.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC2B GC2C	TNGT	114 -114	-2091 214	22 -22	128 -128	636 -741	43362 -48921	741. 836.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC2C GC2D	TNGT	114 -114	-214 -1663	22 -22	128 -128	741 -847	48921 -45426	836. 776.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC2D GC2E	TNGT	114 -114	-1663 -3540	22 -22	128 -128	847 -953	45426 -32878	776. 562.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC2E GC4 B	TNGT	114 -114	3540 -5417	22 -22	128 -128	953 -1058	32878 -11276	562. 193.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7: 1.000
GC4 B GC4 M	BEND	114 4506	-5417 4668	-22 22	128 680	-1058 893	-11276 -3499	296. 96.	2.038 2.038	5.622 5.622	5.622 5.622	B31S7: 5.622
GC4 M GC4 E	BEND	-4506 7557	-4668 114	-22 22	-680 1135	-893 205	3499 -10805	96. 284.	2.038 2.038	5.622 5.622	5.622 5.622	B31S7: 5.622

Calc. 1-1 R.  
App. 2, p. 6

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
GC4 E GC4A	TNGT	-7557 9292	26 -26	-113 113	-1135 1135	-10791 11297	-580 696	186. 194.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
GC4A GC4B	TNGT	-9292 11027	26 -26	-113 113	-1135 1135	-11297 11802	-696 811	194. 203.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
GC4B GC4C	TNGT	-11027 12762	26 -26	-113 113	-1135 1135	-11802 12307	-811 926	203. 212.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
GC4C GC4D	TNGT	-12762 14498	26 -26	-113 113	-1135 1135	-12307 12813	-926 1041	212. 220.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
GC4D GC4E	TNGT	-14498 16233	26 -26	-113 113	-1135 1135	-12813 13318	-1041 1156	220. 229.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
GC4E GC4F	TNGT	-16233 17968	26 -26	-113 113	-1135 1135	-13318 13824	-1156 1272	229. 238.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
GC4F GC4G	TNGT	-17968 19703	26 -26	-113 113	-1135 1135	-13824 14329	-1272 1387	238. 247.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
GC4G GC5	TNGT	-19703 21438	26 -26	-113 113	-1135 1135	-14329 14834	-1387 1502	247. 255.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D05 D06	TNGT	10 -10	-10754 9429	35 -35	3162 -3162	-1775 1614	-29688 -17405	767. 455.	1.080 1.000	1.000 1.000	1.000 1.000	B31S7
D06 D07	TNGT	10 -10	646 -2870	35 -35	3162 -3162	-1614 1344	17405 -3634	455. 711.	1.000 7.400	1.000 1.000	1.000 1.000	B31S7
D07 D07A	TNGT	1299 -124	10 -10	35 -35	1344 -1344	3162 -3305	3634 -3593	711. 130.	7.400 1.000	1.000 1.000	1.000 1.000	B31S7
D07A D07B	TNGT	124 1051	10 -10	35 -35	1344 -1344	3305 -3448	3593 -3552	130. 131.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D07B D10 B	TNGT	-1051 2226	10 -10	35 -35	1344 -1344	3448 -3591	3552 -3512	131. 133.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D10 B D10 M	BEND	-2226 2080	10 -2094	35 -35	1344 -3522	3591 -1669	3512 -915	235. 181.	2.356 2.356	6.986 6.986	6.986 6.986	B31S7
D10 M D10 E	BEND	-2080 -10	2094 -3676	35 -35	3522 -3703	1669 1231	915 6754	181. 353.	2.356 2.356	6.986 6.986	6.986 6.986	B31S7
D10 E D15	TNGT	10 -10	3676 -4233	35 -35	3703 -3703	-1231 1164	-6754 14519	200. 385.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D15 D15A	TNGT	10 -10	-4005 1821	35 -35	3703 -3703	-1164 898	-14519 -7882	385. 224.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7

Calc. / - / R.  
Rev. 2, P. 66

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 236

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS 75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
D15A	TNGT	10	-1821	35	3703	-898	7882	224.	1.000	1.000	1.000	B31S7
D15B		-10	-362	-35	-3703	633	-13494	359.	1.000	1.000	1.000	
D15B	TNGT	10	362	35	3703	-633	13494	359.	1.000	1.000	1.000	B31S7
D15C		-10	-2545	-35	-3703	367	-2315	112.	1.000	1.000	1.000	
D15C	TNGT	10	2545	35	3703	-367	2315	112.	1.000	1.000	1.000	B31S7
D20		-10	-4729	-35	-3703	102	25653	664.	1.000	1.000	1.000	
D20	TNGT	10	-2882	35	3703	-102	-25653	664.	1.000	1.000	1.000	B31S7
D20A		-10	704	-35	-3703	-163	11895	319.	1.000	1.000	1.000	
D20A	TNGT	10	-704	35	3703	163	-11895	319.	1.000	1.000	1.000	B31S7
D25		-10	-1502	-35	-3703	-432	14994	396.	1.000	1.000	1.000	
D25	TNGT	10	-4232	35	3703	432	-14994	396.	1.000	1.000	1.000	B31S7
D30 B		-10	4043	-35	-3703	-455	12236	328.	1.000	1.000	1.000	
D30 B	TNGT	10	35	4043	3703	-12236	-455	579.	2.356	1.000	1.000	B31S7
D30 M	BEND	-31	-17	-3318	2419	2857	525	171.	2.356	6.986	6.986	
D30 M		-35	17	3318	-2419	-2857	-525	171.	2.356	6.986	6.986	
D30 E	BEND	-35	10	-2594	807	-6438	535	295.	2.356	6.986	6.986	
D30 E		-35	2594	10	-807	-535	-6438	167.	1.000	1.000	1.000	
D30 A	TNGT	-35	-1402	-10	807	494	14825	381.	1.000	1.000	1.000	B31S7
D30A		35	1402	10	-807	-494	-14825	381.	1.000	1.000	1.000	
D30A	TNGT	-35	-210	-10	807	452	18208	467.	1.000	1.000	1.000	B31S7
D33		-35	210	10	-807	-452	-18208	467.	1.000	1.000	1.000	
D33	TNGT	-35	1198	-10	807	403	15760	405.	1.000	1.000	1.000	B31S7
D35		-35	1666	10	-807	-403	-15760	405.	1.000	1.000	1.000	
D35	TNGT	-35	121	-10	807	342	20623	529.	1.000	1.000	1.000	B31S7
D35A		-35	-121	10	-807	-342	-20623	529.	1.000	1.000	1.000	
D35A	TNGT	-35	1908	-10	807	280	14238	366.	1.000	1.000	1.000	B31S7
D35B		-35	-1908	10	-807	-280	-14238	366.	1.000	1.000	1.000	
D35B	TNGT	-35	3695	-10	807	218	-3395	90.	1.000	1.000	1.000	B31S7
D35C		-35	3695	10	-807	-218	-3395	90.	1.000	1.000	1.000	
D35C	TNGT	-35	5482	-10	807	156	-32276	828.	1.000	1.000	1.000	B31S7
D40		-35	5333	10	-807	-156	32276	828.	1.000	1.000	1.000	
D40	TNGT	-35	-3536	-10	807	93	-4201	110.	1.000	1.000	1.000	B31S7
D40A		-35	3536	10	-807	-93	4201	110.	1.000	1.000	1.000	
D40A	TNGT	-35	-1739	-10	807	31	12494	321.	1.000	1.000	1.000	B31S7

CALC. 1-1 R. 1  
All. 2 P. 67

1-1 WT02 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 237

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI 75IM/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
D40B	TNGT	35	1739	10	-807	-31	-12494	321.	1.000	1.000	1.000	B31S7
D40C		-35	59	-10	807	-31	17812	457.	1.000	1.000	1.000	
D40C	TNGT	35	-59	10	-807	31	-17812	457.	1.000	1.000	1.000	B31S7
D40D		-35	1856	-10	807	-93	11750	302.	1.000	1.000	1.000	
D40D	TNGT	35	-1856	10	-807	93	-11750	302.	1.000	1.000	1.000	B31S7
D40E		-35	3654	-10	807	-156	-5690	147.	1.000	1.000	1.000	
D40E	TNGT	35	-3654	10	-807	156	5690	147.	1.000	1.000	1.000	B31S7
D45		-35	5451	-10	807	-218	-34509	885.	1.000	1.000	1.000	
D45	TNGT	35	5393	10	-807	218	34509	885.	1.000	1.000	1.000	B31S7
D45A		-35	-3599	-10	807	-280	-6100	158.	1.000	1.000	1.000	
D45A	TNGT	35	3599	10	-807	280	6100	158.	1.000	1.000	1.000	B31S7
D45B		-35	-1805	-10	807	-342	10973	282.	1.000	1.000	1.000	
D45B	TNGT	35	1805	10	-807	342	-10973	282.	1.000	1.000	1.000	B31S7
D45C		-35	-11	-10	807	-404	16712	429.	1.000	1.000	1.000	
D45C	TNGT	35	11	10	-807	404	-16712	429.	1.000	1.000	1.000	B31S7
D45D		-35	1783	-10	807	-467	11115	286.	1.000	1.000	1.000	
D45D	TNGT	35	-1783	10	-807	467	-11115	286.	1.000	1.000	1.000	B31S7
D45E		-35	3577	-10	807	-529	-5817	151.	1.000	1.000	1.000	
D45E	TNGT	35	-3577	10	-807	529	5817	151.	1.000	1.000	1.000	B31S7
D50		-35	5371	-10	807	-591	-34083	874.	1.000	1.000	1.000	
D50	TNGT	35	5987	10	-807	591	34083	874.	1.000	1.000	1.000	B31S7
D50A		-35	-4384	-10	807	-646	-4805	126.	1.000	1.000	1.000	
D50A	TNGT	35	4384	10	-807	646	4805	126.	1.000	1.000	1.000	B31S7
D50B		-35	-2781	-10	807	-702	15423	396.	1.000	1.000	1.000	
D50B	TNGT	35	2781	10	-807	702	-15423	396.	1.000	1.000	1.000	B31S7
D50C		-35	-1178	-10	807	-758	26601	682.	1.000	1.000	1.000	
D50C	TNGT	35	1178	10	-807	758	-26601	682.	1.000	1.000	1.000	B31S7
D50D		-35	424	-10	807	-813	28729	737.	1.000	1.000	1.000	
D50D	TNGT	35	-424	10	-807	813	-28729	737.	1.000	1.000	1.000	B31S7
D50E		-35	2027	-10	807	-869	21808	560.	1.000	1.000	1.000	
D50E	TNGT	35	-2027	10	-807	869	-21808	560.	1.000	1.000	1.000	B31S7
D55		-35	3630	-10	807	-924	5837	153.	1.000	1.000	1.000	
D55	TNGT	35	-3630	10	-807	924	-5837	153.	1.000	1.000	1.000	B31S7
D60		-35	4776	-10	807	-964	-11130	287.	1.000	1.000	1.000	

Calc. 1-1 R.1  
AM. 2, P 58

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 238

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
D60 D65 B	TNGT	35 -35	1797 -1659	10 -10	-807 807	964 -969	11130 -10293	287. 266.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D65 B D65 M	BEND	35 -31	10 17	-1659 934	-807 -5363	10293 -4914	-969 958	470. 332.	2.356 2.356	6.986 6.986	6.986 6.986	B31S7
D65 M D65 E	BEND	31 -10	-17 35	-934 210	5363 -6612	4914 1586	-958 888	332. 311.	2.356 2.356	6.986 6.986	6.986 6.986	B31S7
D65 E D65A	TNGT	10 -10	-210 -394	35 -35	6612 -6612	-888 815	1586 -1391	176. 174.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D65A D70	TNGT	10 -10	394 -997	35 -35	6612 -6612	-815 742	1391 86	174. 171.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D70 D70A	TNGT	10 -10	-3221 1748	35 -35	6612 -6612	-742 563	-86 -12800	171. 370.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D70A D70B	TNGT	10 -10	-1748 276	35 -35	6612 -6612	-563 384	12800 -18049	370. 493.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D70B D70C	TNGT	10 -10	-276 -1196	35 -35	6612 -6612	-384 205	18049 -15663	493. 436.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D70C D75	TNGT	10 -10	1196 -2669	35 -35	6612 -6612	-205 25	15663 -5640	436. 223.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D75 D75A	TNGT	10 -10	-2256 515	35 -35	6612 -6612	-25 -186	5640 -14139	223. 400.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D75A D75B	TNGT	10 -10	-515 -1226	35 -35	6612 -6612	186 -398	14139 -11957	400. 350.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D75B D80	TNGT	10 -10	1226 -2968	35 -35	6612 -6612	398 -610	11957 907	350. 172.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D80 D85 B	TNGT	10 -10	-94 -717	35 -35	6612 -6612	610 -708	-907 1796	172. 177.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D85 B D85 M	BEND	10 17	-35 31	717 -1441	6612 -6863	1796 880	708 -797	312. 315.	2.356 2.356	6.986 6.986	6.986 6.986	B31S7
D85 M D85 E	BEND	-17 35	-31 10	1441 -2166	6863 -5837	-880 1284	797 -853	315. 273.	2.356 2.356	6.986 6.986	6.986 6.986	B31S7
D85 E D90	TNGT	-35 35	2166 -2627	10 -10	5837 -5837	853 -869	1284 2611	155. 232.	1.000 1.871	1.000 1.000	1.000 1.000	B31S7
D90 D95	TNGT	-75 75	4352 -5306	-59 59	3953 -3953	1290 -1093	2597 13625	176. 365.	1.871 1.000	1.000 1.000	1.000 1.000	B31S7

APR 2 1999  
P 69

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 239

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
D95	TNGT	-75	163	-59	3953	1093	-13625	365.	1.000	1.000	1.000	B31S7:
D96		75	-2261	59	-3953	-660	22583	588.	1.000	1.000	1.000	
D96	TNGT	-75	2261	-59	3953	660	-22583	588.	1.000	1.000	1.000	B31S7:
DSV		75	-2545	59	-3953	-601	24986	649.	1.000	1.000	1.000	
DSV	TNGT	-75	2545	-59	3953	601	-24986	91.	1.000	1.000	1.000	B31S7:
D97		75	-3682	59	-3953	-367	37440	136.	1.000	1.000	1.000	
D97	TNGT	0	-76966	0	0	0	-280870	1014.	1.000	1.000	1.000	B31S7:
MS4		0	77996	0	0	0	0	0.	1.000	1.000	1.000	
D97	TNGT	-16145	-12994	-242	2075	10008	-36180	248.	1.000	1.000	1.000	B31S7:
GD1		13687	10980	242	-2075	-7298	-97795	648.	1.000	1.000	1.000	
GD1	TNGT	0	41659	0	0	0	114311	755.	1.000	1.000	1.000	B31S7:
CV4		0	-42432	0	0	0	0	0.	1.000	1.000	1.000	
GD1	TNGT	-14505	242	181	6230	16516	4330	310.	1.000	1.000	1.000	B31S7:
GD1A		12340	-242	-181	-6230	-17521	-2981	322.	1.000	1.000	1.000	
GD1A	TNGT	-12340	242	181	6230	17521	2981	322.	1.000	1.000	1.000	B31S7:
GD1B		10175	-242	-181	-6230	-18526	-1632	335.	1.000	1.000	1.000	
GD1B	TNGT	-10175	242	181	6230	18526	1632	335.	1.000	1.000	1.000	B31S7:
GD2 B		8010	-242	-181	-6230	-19531	-283	350.	1.000	1.000	1.000	
GD2 M	BEND	-8010	-190	236	6230	-1008	19508	535.	2.038	5.622	5.622	B31S7:
GD2 M		5042	-4773	-236	-3934	4535	-12489	362.	2.038	5.622	5.622	
GD2 M	BEND	-5042	4773	236	3934	-4535	12489	362.	2.038	5.622	5.622	B31S7:
GD2 E		190	-5870	-236	183	5405	3097	163.	2.038	5.622	5.622	
GD2 E	TNGT	-190	-5870	-236	-183	5405	3097	106.	1.000	1.000	1.000	B31S7:
GD2A		190	3993	236	183	-4269	-26885	465.	1.000	1.000	1.000	
GD2A	TNGT	-190	-3993	-236	-183	4269	26885	465.	1.000	1.000	1.000	B31S7:
GD2B		190	2116	236	183	-3132	-41619	713.	1.000	1.000	1.000	
GD2B	TNGT	-190	-2116	-236	-183	3132	41619	713.	1.000	1.000	1.000	B31S7:
GD2C		190	239	236	183	-1996	-47297	809.	1.000	1.000	1.000	
GD2C	TNGT	-190	-239	-236	-183	1996	47297	809.	1.000	1.000	1.000	B31S7:
GD2D		190	-1639	236	183	-859	-43920	750.	1.000	1.000	1.000	
GD2D	TNGT	-190	1639	-236	-183	859	43920	750.	1.000	1.000	1.000	B31S7:
GD2E		190	-3516	236	183	277	-31488	538.	1.000	1.000	1.000	
GD2E	TNGT	-190	3516	-236	-183	-277	31488	538.	1.000	1.000	1.000	B31S7:
GD4 B		190	-5393	236	183	1414	-10001	173.	1.000	1.000	1.000	

Calc. 1-1 R-1  
App. 2 P. 70

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 240

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI 75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE CLASS
		FA	FB	FC	MA	MB	MC				
GD4 B	BEND	-190	-5393	236	-183	1414	-10001	264.	2.038	5.622	5.622 B31S7:
GD4 M		4704	4436	-236	-1112	-1712	-4404	127.	2.038	5.622	5.622
GD4 M	BEND	-4704	-4436	236	1112	1712	4404	127.	2.038	5.622	5.622 B31S7:
GD4 E		7533	-190	-236	-2239	-1008	-10933	293.	2.038	5.622	5.622
GD4 E	TNGT	-7533	-242	181	2239	-10963	602	191.	1.000	1.000	1.000 B31S7:
GD4A		9734	242	-181	-2239	9941	-1973	177.	1.000	1.000	1.000
GD4A	TNGT	-9734	-242	181	2239	-9941	1973	177.	1.000	1.000	1.000 B31S7:
GD4B		11936	242	-181	-2239	8919	-3345	167.	1.000	1.000	1.000 B31S7:
GD4C	TNGT	-11936	-242	181	2239	-8919	3345	167.	1.000	1.000	1.000 B31S7:
GD4C		14137	242	-181	-2239	7897	-4716	162.	1.000	1.000	1.000
GD4C	TNGT	-14137	-242	181	2239	-7897	4716	162.	1.000	1.000	1.000 B31S7:
GD4D		16338	242	-181	-2239	6875	-6088	161.	1.000	1.000	1.000
GD4D	TNGT	-16338	-242	181	2239	-6875	6088	161.	1.000	1.000	1.000 B31S7:
GD4E		18540	242	-181	-2239	5853	-7460	161.	1.000	1.000	1.000 B31S7:
GD4F	TNGT	-18540	-242	181	2239	-5853	7460	166.	1.000	1.000	1.000 B31S7:
GD4F		20741	242	-181	-2239	4830	-8831	176.	1.000	1.000	1.000
GD4F	TNGT	-20741	-242	181	2239	-4830	8831	176.	1.000	1.000	1.000 B31S7:
GD4G		22942	242	-181	-2239	3808	-10203	190.	1.000	1.000	1.000 B31S7:
GD4G	TNGT	-22942	-242	181	2239	-3808	10203	190.	1.000	1.000	1.000 B31S7:
GD5 B	BEND	-25144	-243	181	2239	-2786	11574	414.	2.670	8.433	8.433 B31S7:
GD5 M		18455	-18112	-181	264	3255	5531	220.	2.670	8.433	8.433
GD5 M	BEND	-18455	18112	181	-264	-3255	-5531	220.	2.670	8.433	8.433 B31S7:
GD5 E		242	-26570	-181	2364	1817	48648	1667.	2.670	8.433	8.433
GD5 E	TNGT	-242	26570	181	-2364	-1817	-48648	833.	1.000	1.000	1.000 B31S7:
GD6		242	-26830	-181	2364	1697	66448	1136.	1.000	1.000	1.000
A90	TNGT	-486	52	-56	-695	-700	1223	202.	1.871	1.000	1.000 B31S7:
105 B		589	-52	56	695	747	-1180	181.	1.000	1.000	1.000
105 B	BEND	-589	52	-56	-695	-747	1180	242.	1.782	4.598	4.598 B31S7:
105 M		501	-574	56	1049	107	-757	201.	1.782	4.598	4.598
105 M	BEND	-501	574	-56	-1049	-107	757	201.	1.782	4.598	4.598 B31S7:
105 E		-52	-930	56	846	-596	321	168.	1.782	4.598	4.598
105 E	TNGT	52	930	-56	-846	596	-321	126.	1.000	1.000	1.000 B31S7:
105A		-52	-1356	56	846	-402	4251	505.	1.000	1.000	1.000

Calc 1-1 R.  
AP. 2, P. 71

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 241

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IN/Z )	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE CLASS
		FA	FB	FC	MA	MB	MC				
105A 110	TNGT	52 -52	1356 -1783	-56 56	-846 846	402 -208	-4251 9647	505. 1124.	1.000 1.000	1.000 1.000	1.000 B31S7:
110 110A	TNGT	52 -52	-1404 754	-56 56	-846 846	208 88	-9647 3995	1124. 474.	1.000 1.000	1.000 1.000	1.000 B31S7:
110A 115	TNGT	52 -52	-56 56	754 -104	-846 846	-3995 1749	88 -384	474. 202.	1.000 1.461	1.000 1.000	1.000 B31S7:
115 115A	TNGT	-107 107	1 -1	-102 1148	-1141 1141	9309 -5922	-59 66	576. 338.	1.461 1.000	1.000 1.000	1.000 B31S7:
115A 115B	TNGT	-107 107	1148 -2194	1 -1	-1141 1141	66 -73	5922 3130	338. 187.	1.000 1.000	1.000 1.000	1.000 B31S7:
115B 120	TNGT	-107 107	2194 -3240	1 -1	-1141 1141	73 -79	-3130 17847	187. 1002.	1.000 1.000	1.000 1.000	1.000 B31S7:
120 120A	TNGT	-107 107	-2650 1661	1 -1	-1141 1141	79 -86	-17847 6800	1002. 386.	1.000 1.000	1.000 1.000	1.000 B31S7:
120A 120B	TNGT	-107 107	-1661 671	1 -1	-1141 1141	86 -92	-6800 825	386. 79.	1.000 1.000	1.000 1.000	1.000 B31S7:
120B 120C	TNGT	-107 107	-671 -318	1 -1	-1141 1141	92 -98	-825 -79	79. 64.	1.000 1.000	1.000 1.000	1.000 B31S7:
120C 125	TNGT	-107 107	318 -1308	1 -1	-1141 1141	98 -105	79 4088	64. 1070.	1.000 6.000	1.000 1.000	1.000 B31S7:
125 130 B	TNGT	-107 107	-1940 1345	1 -1	-1141 1141	105 -109	-4088 -977	1070. 84.	6.000 1.000	1.000 1.000	1.000 B31S7:
130 B 130 M	BEND	-107 77	-1 -75	-1345 1004	-1141 2308	-977 1737	109 -40	115. 221.	1.821 1.821	4.747 4.747	4.747 B31S7:
130 M 130 E	BEND	-77 1	75 -107	-1004 663	-2308 3445	-1737 908	40 130	221. 273.	1.821 1.821	4.747 4.747	4.747 B31S7:
130 E 133 B	TNGT	-1 1	-663 518	-107 107	-3445 3445	-130 211	908 -1350	200. 208.	1.000 1.000	1.000 1.000	1.000 B31S7:
133 B 133 M	BEND	-1 -75	107 -77	-518 290	-3445 3585	-1350 -1060	-211 325	371. 376.	2.386 2.386	7.121 7.121	7.121 B31S7:
133 M 135	BEND	75 -107	77 -1	-290 63	-3585 1879	1060 -3103	-325 374	376. 365.	2.386 2.386	7.121 7.121	7.121 B31S7:
135 140	TNGT	107 -107	63 -15	1 -1	-1879 1879	374 -374	3103 -3093	204. 204.	1.000 1.000	1.000 1.000	1.000 B31S7:

CALC. /-1 R.  
REV. 2, P. 1  
7.121

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 242

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI 75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE	CODE CLASS
		FA	FB	FC	MA	MB	MC					
140	TNGT	107	15	1	-1879	374	3093	204.	1.000	1.000	1.000	B31S7
144		-107	130	-1	1879	-375	-3137	206.	1.000	1.000	1.000	
144	TNGT	107	-130	1	-1879	375	3137	206.	1.000	1.000	1.000	B31S7
145		-107	8881	-1	1879	-378	-14025	793.	1.000	1.000	1.000	
145	TNGT	107	17928	1	-1879	378	14025	793.	1.000	1.000	1.000	B31S7
146		-107	20093	-1	1879	-391	-25392	1426.	1.000	1.000	1.000	
146	TNGT	107	9945	1	-1879	391	25392	1426.	1.000	1.000	1.000	B31S7
147		-107	-1194	-1	1879	-394	-11933	677.	1.000	1.000	1.000	
147	TNGT	107	1194	1	-1879	394	11933	677.	1.000	1.000	1.000	B31S7
150		-107	-1137	-1	1879	-395	-11586	658.	1.000	1.000	1.000	
150	BEND	107	649	-933	-1879	9742	6285	1177.	2.386	7.121	7.121	B31S7
155 M		-323	-499	840	-1880	-9214	-5943	1115.	2.386	7.121	7.121	
155 M	BEND	323	499	-840	1880	9214	5943	1115.	2.386	7.121	7.121	B31S7
155 E		-443	-293	747	-5164	-7344	-5709	1066.	2.386	7.121	7.121	
155 E	TNGT	443	799	-67	5164	-1880	9110	596.	1.000	1.000	1.000	B31S7
160 B		-161	-158	67	-5164	2124	-7375	518.	1.000	1.000	1.000	
160 B	BEND	161	-10	171	5163	-5680	-5162	707.	1.821	4.747	4.747	B31S7
160 M		-108	-19	-32	-2625	7134	5163	703.	1.821	4.747	4.747	
160 M	BEND	108	19	32	2625	-7134	-5163	703.	1.821	4.747	4.747	B31S7
160 E		-107	-74	108	300	7630	5203	707.	1.821	4.747	4.747	
160 E	TNGT	107	-131	1	-300	79	9235	518.	1.000	1.000	1.000	B31S7
165		-107	659	-1	300	-82	-10316	578.	1.000	1.000	1.000	
165	TNGT	107	3345	1	-300	82	10316	578.	1.000	1.000	1.000	B31S7
165A		-107	-2247	-1	300	-89	5587	313.	1.000	1.000	1.000	
165A	TNGT	107	2247	1	-300	89	-5587	313.	1.000	1.000	1.000	B31S7
165B		-107	-1149	-1	300	-96	15244	854.	1.000	1.000	1.000	
165B	TNGT	107	1149	1	-300	96	-15244	854.	1.000	1.000	1.000	B31S7
165C		-107	-51	-1	300	-103	18656	1045.	1.000	1.000	1.000	
165C	TNGT	107	-1	51	-300	18656	103	1045.	1.000	1.000	1.000	B31S7
170		-107	1	1047	300	-15823	-110	972.	1.461	1.000	1.000	
170	TNGT	68	-40	-1829	864	16151	-351	993.	1.461	1.000	1.000	B31S7
175		-68	40	2215	-864	-12107	270	1020.	2.000	1.000	1.000	
175	TNGT	68	-2215	40	864	-270	-12107	2113.	2.000	1.000	1.000	B31S7
180		-68	2918	-40	-864	43	-2437	300.	1.000	1.000	1.000	

Calc. 1-1 L.1  
App. 2 - P 73

1-1 WT02 STRESSES AND LOCAL FORCES AND MOMENTS ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 243

ELEMENT TYPE/TITLE FROM TO		LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI .75IM/Z)	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT AND PLANE CLASS
		FA	FB	FC	MA	MB	MC				
180	TNGT	68	382	40	864	-43	2437	300.	1.000	1.000	1.000 B31S7
230	B	-68	63	-40	-864	-100	-1866	239.	1.000	1.000	1.000
230	B	TNGT	68	40	63	864	1866	-100	319.	1.782	4.598
230	M	-77	20	-233	-1992	-897	115	339.	1.782	4.598	4.598 B31S7
230	M	TNGT	77	-20	233	1992	897	-115	339.	1.782	4.598
230	E	-40	68	-404	-2193	374	51	345.	1.782	4.598	4.598
230	E	TNGT	40	-404	-68	2193	51	-374	258.	1.000	1.000
230A		-40	723	68	-2193	126	-1076	284.	1.000	1.000	1.000
230A	TNGT	40	-723	-68	2193	-126	1076	284.	1.000	1.000	1.000 B31S7
235	B	-40	1042	68	-2193	302	-3347	466.	1.000	1.000	1.000
235	B	TNGT	886	1042	68	2193	302	-3347	622.	1.782	4.598
235	M	-886	-829	-68	-1799	1252	4716	807.	1.782	4.598	4.598
235	M	TNGT	886	829	68	1799	-1252	-4716	807.	1.782	4.598
235	E	-1383	40	-68	-422	2073	5318	888.	1.782	4.598	4.598 B31S7
235	E	TNGT	1383	40	-68	422	2073	5318	664.	1.000	1.000
D90		-1725	-40	68	-422	-1884	-5207	714.	1.871	1.000	1.000
115	TNGT	-51	53	206	608	8463	444	522.	1.461	1.000	1.000 B31S7
240		51	-53	180	-608	-8488	-338	716.	2.000	1.000	1.000
240	TNGT	-51	-180	-53	608	338	-8488	1482.	2.000	1.000	1.000 B31S7
240A		51	754	53	-608	-94	6328	738.	1.000	1.000	1.000
240A	TNGT	-51	-754	-53	608	94	-6328	738.	1.000	1.000	1.000 B31S7
245	B	51	1328	53	-608	150	1515	190.	1.000	1.000	1.000
245	M	-51	1	-1498	608	-1515	150	254.	1.782	4.598	4.598 B31S7
245	M	73	1	-1498	-69	-253	-190	50.	1.782	4.598	4.598
245	M	TNGT	-73	-1	1498	69	253	190	50.	1.782	4.598
245	E	53	-51	-1669	-1026	-2095	-154	363.	1.782	4.598	4.598 B31S7
245	E	TNGT	-73	-1669	51	1026	-154	2095	271.	1.000	1.000
250		53	1907	-51	-1026	56	-5522	652.	1.000	1.000	1.000
250	TNGT	-53	796	51	1026	-56	5522	652.	1.000	1.000	1.000 B31S7
255	B	53	-85	-51	-1026	-236	-3000	369.	1.000	1.000	1.000
255	B	TNGT	-53	-85	-51	1026	-236	-3000	493.	1.782	4.598
255	M	-23	-98	51	-532	955	3022	498.	1.782	4.598	4.598
255	M	TNGT	23	98	-51	532	-955	-3022	498.	1.782	4.598
255	E	-256	-53	51	325	1115	3161	522.	1.782	4.598	4.598 B31S7

Calc. 1-1 R-1  
A-1 E-1 F-1 H-1

1-1

WT02

## STRESSES AND LOCAL FORCES AND MOMENTS

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 244

ELEMENT FROM TO	TYPE/TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			STRESS (PSI) .75IM/Z	STRESS INT. FAC. (I)	FLEX. IN PLANE	FLEX. OUT PLANE	CODE AND CLASS
		FA	FB	FC	MA	MB	MC					
255 E C90	TNGT	256 -360	-53 53	51 -51	-325 325	1115 -1157	3161 -3205	391. 440.	1.000 1.871	1.000 1.000	1.000 1.000	B31S7
170 170A	TNGT	-39 39	39 -39	782 -166	328 -328	-1164 -1187	461 -267	132. 146.	1.461 1.000	1.000 1.000	1.000 1.000	B31S7
170A 170B	TNGT	-39 39	166 450	-39 39	328 -328	267 -74	-1187 481	146. 68.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
170B 260 B	TNGT	-39 39	-450 1066	-39 39	328 -328	74 119	-481 -3285	68. 383.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
260 B 260 M	BEND	-39 -847	1066 -902	39 -39	328 -336	119 99	-3285 4724	512. 735.	1.782 1.782	4.598 4.598	4.598 4.598	B31S7
260 M 260 E	BEND	847 -1407	902 -39	39 -39	336 -188	-99 260	-4724 5436	735. 845.	1.782 1.782	4.598 4.598	4.598 4.598	B31S7
260 E B90	TNGT	1407 -1749	-39 39	-39 39	188 -188	260 -152	5436 -5543	632. 713.	1.000 1.871	1.000 1.000	1.000 1.000	B31S7
B97 S01	TNGT	183 -183	-29018 29018	83 -83	-17649 17649	-8486 8215	63990 -158297	242. 576.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
S01 A97	TNGT	-1198 1198	-28993 28993	86 -86	-19904 19904	-7276 6977	158075 -259675	576. 941.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
C97 MS2	TNGT	215 -215	130677 -130677	-29 29	19004 -19004	-7182 7277	88238 336464	327. 1217.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
MS2 B97	TNGT	7544 -7544	133076 -133076	56 -56	-23019 23019	8557 -8727	336183 66852	1217. 257.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
D97 S00	TNGT	184 -184	27639 -27639	-106 106	-1260 1260	-7581 7926	270490 -180665	977. 653.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
S00 C97	TNGT	1501 -1501	27598 -27598	-86 86	-21113 21113	-6935 7237	179473 -82201	653. 308.	1.000 1.000	1.000 1.000	1.000 1.000	B31S7
A07 AR5	TNGT	5438 -6065	0 0	0 0	0 0	0 0	0 0	0. 0.	7.400 1.000	1.000 1.000	1.000 1.000	B31S7
B07 BR5	TNGT	4799 -5426	0 0	0 0	0 0	0 0	0 0	0. 0.	7.400 1.000	1.000 1.000	1.000 1.000	B31S7
C07 CR5	TNGT	4228 -4854	0 0	0 0	0 0	0 0	0 0	0. 0.	7.400 1.000	1.000 1.000	1.000 1.000	B31S7
D07 DR5	TNGT	4169 -4796	0 0	0 0	0 0	0 0	0 0	0. 0.	7.400 1.000	1.000 1.000	1.000 1.000	B31S7

\*\*\* AT THE MEMBER END 175 OF ELEMENT FROM 175 TO 180 MAX. STRESS (PSI) IS 2113.

Calc. / - / R. !  
A/P. 2 , P. 75

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
				FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
A05	ANC	WT01 WT02 THRMO1	X-7A	-6.	-10243.	-3.	27806.	-377.	420.	.000	.000	.000
				-9.	-10129.	-4.	27399.	-433.	653.	.000	.000	.000
				-638.	20416.	-528.	-215228.	-8515.	6665.	.000	.000	.000
A15	SPR	WT01 WT02 THRMO1	1DB-H1	0.	-5.	0.	0.	0.	0.	-.003	-.003	-.007
				0.	-8.	0.	0.	0.	0.	-.004	-.005	-.005
										-.031	.725	.614
A20	SPR	WT01 WT02 THRMO1	1DB-H2	0.	-30.	0.	0.	0.	0.	-.011	-.014	-.007
				0.	-35.	0.	0.	0.	0.	-.013	-.016	-.005
										.009	.165	1.881
A35	RAD	WT01 WT02 THRMO1	1DB-H3	0.	-1865.	0.	0.	0.	0.	-.013	.000	-.005
				0.	-2160.	0.	0.	0.	0.	-.015	.000	-.003
				0.	1726.	0.	0.	0.	0.	.332	.000	2.111
A40	RAD	WT01 WT02 THRMO1	1DB-H4	0.	-8561.	0.	0.	0.	0.	-.013	.000	-.001
				0.	-8533.	0.	0.	0.	0.	-.015	.000	.001
				0.	-470.	0.	0.	0.	0.	.880	.000	1.867
A45	RAD	WT01 WT02 THRMO1	1DB-H5	0.	-11154.	0.	0.	0.	0.	-.013	.000	.011
				0.	-10944.	0.	0.	0.	0.	-.015	.000	.013
				0.	51.	0.	0.	0.	0.	2.439	.000	1.033
A50	RAD	WT01 WT02 THRMO1	1GB-H6	0.	-10549.	0.	0.	0.	0.	-.013	.000	.026
				0.	-11352.	0.	0.	0.	0.	-.015	.000	.027
				0.	-95.	0.	0.	0.	0.	4.001	.000	.249
A55	RAD	WT01 WT02 THRMO1	1DB-H7	0.	-10817.	0.	0.	0.	0.	-.013	.000	.046
				0.	-8167.	0.	0.	0.	0.	-.015	.000	.046
				0.	137.	0.	0.	0.	0.	5.562	.000	-.160
A70	RAD	WT01 WT02 THRMO1	1DB-H9	0.	-5733.	0.	0.	0.	0.	-.022	.000	.057
				0.	-8975.	0.	0.	0.	0.	-.025	.000	.057
				0.	73.	0.	0.	0.	0.	5.957	.000	.330

calc. 1-1 R  
AM-2, p. 76

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
				FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
A75	SPR		1DB-H10									
			WT01	0.	457.	0.	0.	0.	0.	-.053	.152	.057
			WT02	0.	-246.	0.	0.	0.	0.	-.055	.082	.057
			THRM01						4.879	.032		1.614
A80	SPR		1DB-H11									
			WT01	0.	598.	0.	0.	0.	0.	-.078	.277	.057
			WT02	0.	-146.	0.	0.	0.	0.	-.080	.068	.057
			THRM01						3.846	.083		2.611
A85	SPR		1DB-H12									
			WT01	0.	921.	0.	0.	0.	0.	-.092	.307	.057
			WT02	0.	-110.	0.	0.	0.	0.	-.094	-.037	.057
			THRM01						3.261	.110		3.145
A95	SPR		1DB-H13									
			WT01	0.	122.	0.	0.	0.	0.	-.096	.051	.036
			WT02	0.	-23.	0.	0.	0.	0.	-.098	-.010	.037
			THRM01						2.227	.048		2.434
MS1	RAD		MS-1									
			WT01	0.	-62134.	0.	0.	0.	0.	-.100	.000	.024
			WT02	0.	-73536.	0.	0.	0.	0.	-.101	.000	.026
			THRM01	0.	-4196.	0.	0.	0.	0.	1.563	.000	2.056
CV1	SPD		CV1-SPR									
			WT01	0.	-54653.	0.	0.	0.	0.	-.095	.000	.019
			WT02	0.	-43472.	0.	0.	0.	0.	-.100	.000	.021
			THRM01						1.352	-.405		1.504
GA6	ANC		TRBN NOZZLE									
			WT01	144.	-26791.	241.	66521.	-3063.	-3343.	.000	.000	.000
			WT02	143.	-26807.	244.	66376.	-3134.	-3371.	.000	.000	.000
			THRM01	-679.	1503.	317.	-15130.	-41279.	563.	.170	.460	.210
B05	ANC		X-7B									
			WT01	-12.	-10539.	-5.	28884.	-643.	-274.	.000	.000	.000
			WT02	-13.	-10371.	-5.	28283.	-650.	226.	.000	.000	.000
			THRM01	-866.	19966.	-601.	-213573.	-18202.	9155.	.000	.000	.000
B15	SPR		1DB-H14									
			WT01	0.	4.	0.	0.	0.	0.	.000	.003	-.013
			WT02	0.	0.	0.	0.	0.	0.	-.003	.000	-.010
			THRM01							-.067	.733	.606

Calc. 1-1  
1-2  
1-3  
1-4

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
				FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
B20	SPR	WT01 WT02 THRM01	1DB-H15	0.	22.	0.	0.	0.	0.	-.010	.007	-.013
				0.	0.	0.	0.	0.	0.	-.013	.000	-.010
										-.168	.220	1.893
B35	RAD	WT01 WT02 THRM01	1DB-H26	0.	-1527.	0.	0.	0.	0.	-.013	.000	-.011
				0.	-2305.	0.	0.	0.	0.	-.017	.000	-.007
				0.	1581.	0.	0.	0.	0.	.231	.000	2.229
B40	RAD	WT01 WT02 THRM01	1DB-H16	0.	-8543.	0.	0.	0.	0.	-.013	.000	-.007
				0.	-8158.	0.	0.	0.	0.	-.017	.000	-.003
				0.	-506.	0.	0.	0.	0.	.801	.000	1.967
B45	RAD	WT01 WT02 THRM01	1DB-H17	0.	-10309.	0.	0.	0.	0.	-.013	.000	.004
				0.	-10511.	0.	0.	0.	0.	-.017	.000	.007
				0.	73.	0.	0.	0.	0.	2.280	.000	1.129
B50	RAD	WT01 WT02 THRM01	1GB-H18	0.	-12610.	0.	0.	0.	0.	-.013	.000	.017
				0.	-11946.	0.	0.	0.	0.	-.017	.000	.020
				0.	-153.	0.	0.	0.	0.	3.842	.000	.274
B55	RAD	WT01 WT02 THRM01	1DB-H19	0.	-5973.	0.	0.	0.	0.	-.013	.000	.037
				0.	-7059.	0.	0.	0.	0.	-.017	.000	.038
				0.	257.	0.	0.	0.	0.	5.403	.000	-.187
B70	SPR	WT01 WT02 THRM01	1DB-H20	0.	519.	0.	0.	0.	0.	-.020	.173	.050
				0.	212.	0.	0.	0.	0.	-.024	.071	.050
										5.956	.010	.178
B75	SPR	WT01 WT02 THRM01	1DB-H21	0.	1041.	0.	0.	0.	0.	-.053	.260	.050
				0.	109.	0.	0.	0.	0.	-.056	.027	.050
										4.802	.042	1.442
B80	SPR	WT01 WT02 THRM01	1DB-H22	0.	487.	0.	0.	0.	0.	-.087	.162	.050
				0.	-164.	0.	0.	0.	0.	-.088	-.055	.050
										3.386	.096	2.705

Calc.  
App. 2, p. 1  
R.

## RESTRAINT LOAD SUMMARY

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 314

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
				FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
B95	SPR		1DB-H23									
		WT01		0.	73.	0.	0.	0.	0.	-.091	.030	.034
		WT02		0.	-42.	0.	0.	0.	0.	-.092	-.017	.036
		THRM01								2.512	.049	2.161
CV2	SPD		CV2-SPR									
		WT01		0.	-51837.	0.	0.	0.	0.	-.089	.000	.014
		WT02		0.	-41818.	0.	0.	0.	0.	-.093	.000	.015
		THRM01								1.629	-.391	1.222
GB5	ANC		TRBN NOZZLE									
		WT01		-133.	-21425.	-1.	711.	-843.	-15418.	.000	.000	.000
		WT02		-138.	-21437.	-2.	780.	-882.	-15545.	.000	.000	.000
		THRM01		1066.	1164.	1065.	-31588.	-58610.	56152.	.170	-.030	.080
C05	ANC		X-7D X-7C									
		WT01		-16.	-10860.	-6.	30056.	-819.	-115.	.000	.000	.000
		WT02		-16.	-10604.	-6.	29132.	-788.	296.	.000	.000	.000
		THRM01		-1151.	19557.	-681.	-212067.	-31505.	12439.	.000	.000	.000
C15	SFR		1DB-H24									
		WT01		0.	14.	0.	0.	0.	0.	-.002	.010	-.020
		WT02		0.	7.	0.	0.	0.	0.	-.003	.005	-.015
		THRM01								.116	.740	.598
C20	SPR		1DB-H25									
		WT01		0.	119.	0.	0.	0.	0.	-.014	.037	-.020
		WT02		0.	65.	0.	0.	0.	0.	-.016	.020	-.015
		THRM01								-.421	.285	1.865
C35	RAD		1DB-H27									
		WT01		0.	-4866.	0.	0.	0.	0.	-.020	.000	-.017
		WT02		0.	-5345.	0.	0.	0.	0.	-.023	.000	-.012
		THRM01		0.	1075.	0.	0.	0.	0.	-.130	.000	2.407
C40	RAD		1DB-H28									
		WT01		0.	-9368.	0.	0.	0.	0.	-.020	.000	-.009
		WT02		0.	-9474.	0.	0.	0.	0.	-.023	.000	-.004
		THRM01		0.	-77.	0.	0.	0.	0.	.941	.000	1.898
C45	RAD		1DB-H29									
		WT01		0.	-12187.	0.	0.	0.	0.	-.020	.000	.003
		WT02		0.	-11256.	0.	0.	0.	0.	-.023	.000	.007
		THRM01		0.	-219.	0.	0.	0.	0.	2.500	.000	.941

Calc. 1-1 R.  
App. 2, p.  
18

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
				FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
C50	RAD	WT01 WT02 THRMO1	1GB-H30	0.	-9620.	0.	0.	0.	0.	-.020	.000	.018
				0.	-10872.	0.	0.	0.	0.	-.023	.000	.021
				0.	309.	0.	0.	0.	0.	4.061	.000	.098
C60	SPR	WT01 WT02 THRMO1	1DB-H31	0.	1039.	0.	0.	0.	0.	-.020	.346	.039
				0.	320.	0.	0.	0.	0.	-.023	.107	.041
										5.623	.061	-.209
C70	SPR	WT01 WT02 THRMO1	1DB-H32	0.	881.	0.	0.	0.	0.	-.030	.408	.045
				0.	242.	0.	0.	0.	0.	-.033	.112	.047
										5.623	.065	.300
C75	SPR	WT01 WT02 THRMO1	1DB-H33	0.	869.	0.	0.	0.	0.	-.056	.290	.045
				0.	119.	0.	0.	0.	0.	-.057	.040	.047
										4.647	.062	1.276
C80	SPR	WT01 WT02 THRMO1	1DB-H34	0.	305.	0.	0.	0.	0.	-.082	.141	.045
				0.	-27.	0.	0.	0.	0.	-.083	-.012	.047
										3.492	.074	2.271
C95	SPR	WT01 WT02 THRMO1	1DB-H35	0.	81.	0.	0.	0.	0.	-.086	.034	.034
				0.	-22.	0.	0.	0.	0.	-.088	-.009	.036
										2.772	.037	1.903
CV3	SPD	WT01 WT02 THRMO1	CV3-SPR	0.	-51796.	0.	0.	0.	0.	-.085	.000	.020
				0.	-42386.	0.	0.	0.	0.	-.089	.000	.021
										1.870	-.393	.948
GC5	ANC	WT01 WT02 THRMO1	TRBN NOZZLE	-121.	-21421.	24.	-1404.	-1047.	-15060.	.000	.000	.000
				-113.	-21438.	26.	-1502.	-1135.	-14834.	.000	.000	.000
				2572.	919.	951.	-26706.	-58842.	99197.	.170	-.030	-.080
D05	ANC	WT01 WT02 THRMO1	X-7C X-7D	-35.	-10991.	-10.	30542.	-1830.	-3525.	.000	.000	.000
				-35.	-10754.	-10.	29688.	-1775.	-3162.	.000	.000	.000
				-1464.	19163.	-756.	-210619.	-47520.	15512.	.000	.000	.000

calc. /-1 k.  
app. 2, p. 80

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
				FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
D15	SPR		1DB-H36									
			WT01	0.	19.	0.	0.	0.	0.	.013	.013	-.023
			WT02	0.	12.	0.	0.	0.	0.	.011	.008	-.018
			THRM01							-.173	.747	.590
D20	SPR		1DB-H37									
			WT01	0.	243.	0.	0.	0.	0.	-.004	.081	-.023
			WT02	0.	189.	0.	0.	0.	0.	-.006	.063	-.018
			THRM01							-.734	.341	1.857
D25	SPR		1DB-H38									
			WT01	0.	193.	0.	0.	0.	0.	-.014	.080	-.023
			WT02	0.	166.	0.	0.	0.	0.	-.016	.069	-.018
			THRM01							-.952	.078	2.493
D35	RAD		1DB-H39									
			WT01	0.	-2618.	0.	0.	0.	0.	-.016	.000	-.017
			WT02	0.	-2864.	0.	0.	0.	0.	-.018	.000	-.012
			THRM01	0.	1153.	0.	0.	0.	0.	-.285	.000	2.474
D40	RAD		1DB-H40									
			WT01	0.	-10655.	0.	0.	0.	0.	-.016	.000	-.009
			WT02	0.	-10815.	0.	0.	0.	0.	-.018	.000	-.005
			THRM01	0.	-295.	0.	0.	0.	0.	.752	.000	1.949
D45	RAD		1DB-H41									
			WT01	0.	-11921.	0.	0.	0.	0.	-.016	.000	.001
			WT02	0.	-10844.	0.	0.	0.	0.	-.018	.000	.005
			THRM01	0.	-199.	0.	0.	0.	0.	2.316	.000	.927
D50	RAD		1GB-H42									
			WT01	0.	-9816.	0.	0.	0.	0.	-.016	.000	.014
			WT02	0.	-11358.	0.	0.	0.	0.	-.018	.000	.017
			THRM01	0.	330.	0.	0.	0.	0.	3.878	.000	.046
D60	SPR		1DB-H43									
			WT01	0.	973.	0.	0.	0.	0.	-.016	.324	.037
			WT02	0.	177.	0.	0.	0.	0.	-.018	.059	.039
			THRM01							5.439	.064	-.230
D70	SPR		1DB-H44									
			WT01	0.	684.	0.	0.	0.	0.	-.024	.317	.040
			WT02	0.	82.	0.	0.	0.	0.	-.026	.038	.043
			THRM01							5.379	.064	.130

A/I. 1-1 R.  
Calc. 1-1 R.  
10/2, P.81

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
				FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
D75	SPR		1DB-H45									
			WT01	0.	372.	0.	0.	0.	0.	-.051	.172	.040
			WT02	0.	-65.	0.	0.	0.	0.	-.052	-.030	.043
			THRM01							4.542	.060	.984
D80	SPR		1DB-H46									
			WT01	0.	104.	0.	0.	0.	0.	-.075	.065	.040
			WT02	0.	-62.	0.	0.	0.	0.	-.075	-.038	.043
			THRM01							3.683	.067	1.742
D95	SPR		1DB-H47									
			WT01	0.	32.	0.	0.	0.	0.	-.082	.013	.033
			WT02	0.	-43.	0.	0.	0.	0.	-.082	-.018	.035
			THRM01							3.056	.042	1.624
MS4	RAD		MS-4									
			WT01	0.	-67447.	0.	0.	0.	0.	-.079	.000	.024
			WT02	0.	-77996.	0.	0.	0.	0.	-.080	.000	.026
			THRM01	0.	-621.	0.	0.	0.	0.	2.698	.000	.946
CV4	SPD		CV4-SPR									
			WT01	0.	-50451.	0.	0.	0.	0.	-.082	.000	.014
			WT02	0.	-42432.	0.	0.	0.	0.	-.084	.000	.015
			THRM01							2.171	-.390	.688
GD6	ANC		TRBN NOZZLE									
			WT01	180.	-26818.	-241.	-66546.	1725.	-2375.	.000	.000	.000
			WT02	181.	-26830.	-242.	-66448.	1697.	-2364.	.000	.000	.000
			THRM01	1160.	493.	235.	-5706.	-39468.	50502.	.170	.460	-.210
110	SPR		7DB-H79									
			WT01	0.	230.	0.	0.	0.	0.	-.130	.143	.045
			WT02	0.	-32.	0.	0.	0.	0.	-.095	-.020	.044
			THRM01							2.493	.164	2.729
120	SPR		7DB-H77									
			WT01	0.	140.	0.	0.	0.	0.	-.158	.065	.033
			WT02	0.	38.	0.	0.	0.	0.	-.102	.018	.040
			THRM01							1.373	.074	2.949
125	SPR		7DB-H76									
			WT01	0.	100.	0.	0.	0.	0.	-.193	.083	.033
			WT02	0.	52.	0.	0.	0.	0.	-.108	.043	.040
			THRM01							.503	.034	3.793

Calc. 1-1 R 1  
A/P. 2, P.82

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
				FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
145	RAD		BYP5 VV SPPT									
				WT01	0.	-26689.	0.	0.	0.	.194	.000	.026
				WT02	0.	-26809.	0.	0.	0.	.108	.000	.039
			THRM01	0.		-314.	0.	0.	0.	.300	.000	3.619
146	RAD		BYP5 VV SPPT									
				WT01	0.	-30023.	0.	0.	0.	.175	.000	.026
				WT02	0.	-30038.	0.	0.	0.	.101	.000	.039
			THRM01	0.		509.	0.	0.	0.	.746	.000	3.186
165	SPR		7DB-H74									
				WT01	0.	9.	0.	0.	0.	.181	.006	.025
				WT02	0.	-29.	0.	0.	0.	.105	-.018	.034
			THRM01	0.			0.	0.	0.	1.308	.119	2.877
180	SPR		7DB-H75									
				WT01	0.	-104.	0.	0.	0.	.113	-.065	.025
				WT02	0.	-150.	0.	0.	0.	.084	-.094	.034
			THRM01	0.			0.	0.	0.	2.598	.190	1.624
250	SPR		7DB-H78									
				WT01	0.	33.	0.	0.	0.	.104	.028	.038
				WT02	0.	-52.	0.	0.	0.	.089	-.043	.042
			THRM01	0.			0.	0.	0.	2.759	.138	1.902
MS2	SPD		MS2-MS3 SPR									
				WT01	0.	-229593.	0.	0.	0.	.089	.000	.024
				WT02	0.	-263967.	0.	0.	0.	.090	.000	.026
			THRM01	0.			0.	0.	0.	2.110	-.006	1.491
AR5	RAD		REST-5									
				WT01	0.	-5360.	0.	0.	0.	.000	.000	.002
				WT02	0.	-6065.	0.	0.	0.	.000	.000	.002
			THRM01	0.		-21700.	0.	0.	0.	-.002	.000	.552
BR5	RAD		REST-5									
				WT01	0.	-4597.	0.	0.	0.	-.001	.000	.002
				WT02	0.	-5426.	0.	0.	0.	.000	.000	.002
			THRM01	0.		-21078.	0.	0.	0.	-.008	.000	.553
CR5	RAD		REST-5									
				WT01	0.	-3825.	0.	0.	0.	-.001	.000	.002
				WT02	0.	-4854.	0.	0.	0.	.000	.000	.002
			THRM01	0.		-20523.	0.	0.	0.	-.017	.000	.553

Calc. 1-1 R.  
APP. 2, p. 33

## RESTRAINT LOAD SUMMARY

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
				FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
DR5	RAD	WT01	REST-5	0.	-3844.	0.	0.	0.	0.	-.003	.000	.003
		WT02		0.	-4796.	0.	0.	0.	0.	-.003	.000	.002
		THRM01		0.	-20013.	0.	0.	0.	0.	-.029	.000	.553

Cde. 1-1 R.1  
 App. 2, p. 84

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
				FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	CC C
A05	ANC	WT01 WT02 THRMO1	X-7A	-3	10243	-6	420	377	27806	.00	.00	1.00	.00	-1.00	.00	1.00	.00	.00 .0
				-4	10129	-9	653	433	27399	.00	.00	1.00	.00	-1.00	.00	1.00	.00	.00 .0
				-528	-20416	-638	6665	8515	-215228	.00	.00	1.00	.00	-1.00	.00	1.00	.00	.00 .0
A15	SPR	WT01 WT02 THRMO1	1DB-H1	-5	0	0	0	0	0	0	.00	1.00	.00					
				-8	0	0	0	0	0	0	.00	1.00	.00					
A20	SPR	WT01 WT02 THRMO1	1DB-H2	-30	0	0	0	0	0	0	.00	1.00	.00					
				-35	0	0	0	0	0	0	.00	1.00	.00					
A35	RAD	WT01 WT02 THRMO1	1DB-H3	-1865	0	0	0	0	0	0	.00	1.00	.00					
				-2160	0	0	0	0	0	0	.00	1.00	.00					
				1726	0	0	0	0	0	0	.00	1.00	.00					
A40	RAD	WT01 WT02 THRMO1	1DB-H4	-8561	0	0	0	0	0	0	.00	1.00	.00					
				-8533	0	0	0	0	0	0	.00	1.00	.00					
				-470	0	0	0	0	0	0	.00	1.00	.00					
A45	RAD	WT01 WT02 THRMO1	1DB-H5	-11154	0	0	0	0	0	0	.00	1.00	.00					
				-10944	0	0	0	0	0	0	.00	1.00	.00					
				51	0	0	0	0	0	0	.00	1.00	.00					
A50	RAD	WT01 WT02 THRMO1	1GB-H6	-10549	0	0	0	0	0	0	.00	1.00	.00					
				-11352	0	0	0	0	0	0	.00	1.00	.00					
				-95	0	0	0	0	0	0	.00	1.00	.00					
A55	RAD	WT01 WT02 THRMO1	1DB-H7	-10817	0	0	0	0	0	0	.00	1.00	.00					
				-8167	0	0	0	0	0	0	.00	1.00	.00					
				137	0	0	0	0	0	0	.00	1.00	.00					
A70	RAD	WT01 WT02 THRMO1	1DB-H9	-5733	0	0	0	0	0	0	.00	1.00	.00					
				-8975	0	0	0	0	0	0	.00	1.00	.00					
				73	0	0	0	0	0	0	.00	1.00	.00					

Calc. 1-1 R.1  
A11.2, P.85

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
				FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	CC
A75	SPR	WT01 WT02 THRM01	1DB-H10	457	0	0	0	0	0	0	.00	1.00	.00					
				-246	0	0	0	0	0	0	.00	1.00	.00					
A80	SPR	WT01 WT02 THRM01	1DB-H11	598	0	0	0	0	0	0	.00	1.00	.00					
				-146	0	0	0	0	0	0	.00	1.00	.00					
A85	SPR	WT01 WT02 THRM01	1DB-H12	921	0	0	0	0	0	0	.00	1.00	.00					
				-110	0	0	0	0	0	0	.00	1.00	.00					
A95	SPR	WT01 WT02 THRM01	1DB-H13	122	0	0	0	0	0	0	.00	1.00	.00					
				-23	0	0	0	0	0	0	.00	1.00	.00					
MS1	RAD	WT01 WT02 THRM01	MS-1	-62134	0	0	0	0	0	0	.00	1.00	.00					
				-73536	0	0	0	0	0	0	.00	1.00	.00					
				-4196	0	0	0	0	0	0	.00	1.00	.00					
CV1	SPD	WT01 WT02 THRM01	CV1-SPR	-54653	0	0	0	0	0	0	.00	1.00	.00					
				-43472	0	0	0	0	0	0	.00	1.00	.00					
GA6	ANC	WT01 WT02 THRM01	TRBN NOZZLE	144	-26791	241	66521	-3063	-3343	1.00	.00	.00	.00	1.00	.00	.00	.00	1.0
				143	-26807	244	66376	-3134	-3371	1.00	.00	.00	.00	1.00	.00	.00	.00	1.0
				-679	1503	317	-15130	-41279	563	1.00	.00	.00	.00	1.00	.00	.00	.00	1.0
B05	ANC	WT01 WT02 THRM01	X-7B	-5	10539	-12	-274	643	28884	.00	.00	1.00	.00	-1.00	.00	1.00	.00	.0
				-5	10371	-13	226	650	28283	.00	.00	1.00	.00	-1.00	.00	1.00	.00	.0
				-601	-19966	-866	9155	18202	-213573	.00	.00	1.00	.00	-1.00	.00	1.00	.00	.0
B15	SPR	WT01 WT02 THRM01	1DB-H14	4	0	0	0	0	0	0	.00	1.00	.00					
				0	0	0	0	0	0	0	.00	1.00	.00					

Calc. 1-1 R.1  
Aft. 2, p 86

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES							
				FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY
B20	SPR		1DB-H15														
			WT01	22	0	0	0	0	0	0	.00	1.00	.00				
			WT02	0	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														
B35	RAD		1DB-H26														
			WT01	-1527	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-2305	0	0	0	0	0	0	.00	1.00	.00				
			THRM01	1581	0	0	0	0	0	0	.00	1.00	.00				
B40	RAD		1DB-H16														
			WT01	-8543	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-8158	0	0	0	0	0	0	.00	1.00	.00				
			THRM01	-506	0	0	0	0	0	0	.00	1.00	.00				
B45	RAD		1DB-H17														
			WT01	-10309	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-10511	0	0	0	0	0	0	.00	1.00	.00				
			THRM01	73	0	0	0	0	0	0	.00	1.00	.00				
B50	RAD		1GB-H18														
			WT01	-12610	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-11946	0	0	0	0	0	0	.00	1.00	.00				
			THRM01	-153	0	0	0	0	0	0	.00	1.00	.00				
B55	RAD		1DB-H19														
			WT01	-5973	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-7059	0	0	0	0	0	0	.00	1.00	.00				
			THRM01	257	0	0	0	0	0	0	.00	1.00	.00				
B70	SPR		1DB-H20														
			WT01	519	0	0	0	0	0	0	.00	1.00	.00				
			WT02	212	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														
B75	SPR		1DB-H21														
			WT01	1041	0	0	0	0	0	0	.00	1.00	.00				
			WT02	109	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														
B80	SPR		1DB-H22														
			WT01	487	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-164	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														

CDR 1-1 R-1  
APR 2, 2004

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES						
				FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX
B95	SPR	1DB-H23		73	0	0	0	0	0	0 .00	1.00	.00				
		WT01		-42	0	0	0	0	0	0 .00	1.00	.00				
		WT02														
		THRM01														
CV2	SPD	CV2-SPR														
		WT01		-51837	0	0	0	0	0	0 .00	1.00	.00				
		WT02		-41818	0	0	0	0	0	0 .00	1.00	.00				
		THRM01														
GB5	ANC	TRBN NOZZLE														
		WT01		-133	-21425	-1	711	-843	-15418	1.00	.00	.00	.00	1.00	.00	.00
		WT02		-138	-21437	-2	780	-882	-15545	1.00	.00	.00	.00	1.00	.00	.00
		THRM01		1066	1164	1065	-31588	-58610	56152	1.00	.00	.00	.00	1.00	.00	.00
C05	ANC	X-7D X-7C														
		WT01		-6	10860	-16	-115	819	30056	.00	.00	1.00	.00	-1.00	.00	1.00
		WT02		-6	10604	-16	296	788	29132	.00	.00	1.00	.00	-1.00	.00	1.00
		THRM01		-681	-19557	-1151	12439	31505	-212067	.00	.00	1.00	.00	-1.00	.00	1.00
C15	SPR	1DB-H24														
		WT01		14	0	0	0	0	0	0 .00	1.00	.00				
		WT02		7	0	0	0	0	0	0 .00	1.00	.00				
		THRM01														
C20	SPR	1DB-H25														
		WT01		119	0	0	0	0	0	0 .00	1.00	.00				
		WT02		65	0	0	0	0	0	0 .00	1.00	.00				
		THRM01														
C35	RAD	1DB-H27														
		WT01		-4866	0	0	0	0	0	0 .00	1.00	.00				
		WT02		-5345	0	0	0	0	0	0 .00	1.00	.00				
		THRM01		1075	0	0	0	0	0	0 .00	1.00	.00				
C40	RAD	1DB-H28														
		WT01		-9368	0	0	0	0	0	0 .00	1.00	.00				
		WT02		-9474	0	0	0	0	0	0 .00	1.00	.00				
		THRM01		-77	0	0	0	0	0	0 .00	1.00	.00				
C45	RAD	1DB-H29														
		WT01		-12187	0	0	0	0	0	0 .00	1.00	.00				
		WT02		-11256	0	0	0	0	0	0 .00	1.00	.00				
		THRM01		-219	0	0	0	0	0	0 .00	1.00	.00				

Calc. 1-1 R.  
App. 2, p. 93

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES							
				FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY
C50	RAD		1GB-H30														
			WT01	-9620	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-10872	0	0	0	0	0	0	.00	1.00	.00				
			THRM01	309	0	0	0	0	0	0	.00	1.00	.00				
C60	SPR		1DB-H31														
			WT01	1039	0	0	0	0	0	0	.00	1.00	.00				
			WT02	320	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														
C70	SPR		1DB-H32														
			WT01	881	0	0	0	0	0	0	.00	1.00	.00				
			WT02	242	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														
C75	SPR		1DB-H33														
			WT01	869	0	0	0	0	0	0	.00	1.00	.00				
			WT02	119	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														
C80	SPR		1DB-H34														
			WT01	305	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-27	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														
C95	SPR		1DB-H35														
			WT01	81	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-22	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														
CV3	SPD		CV3-SPR														
			WT01	-51796	0	0	0	0	0	0	.00	1.00	.00				
			WT02	-42386	0	0	0	0	0	0	.00	1.00	.00				
			THRM01														
GC5	ANC		TRBN NOZZLE														
			WT01	-121	-21421	24	-1404	-1047	-15060	1.00	.00	.00	.00	1.00	.00	.00	.00
			WT02	-113	-21438	26	-1502	-1135	-14834	1.00	.00	.00	.00	1.00	.00	.00	.00
			THRM01	2572	919	951	-26706	-58842	99197	1.00	.00	.00	.00	1.00	.00	.00	.00
D05	ANC		X-7C X-1D														
			WT01	-10	10991	-35	-3525	1830	30542	.00	.00	1.00	.00	-1.00	.00	1.00	.00
			WT02	-10	10754	-35	-3162	1775	29688	.00	.00	1.00	.00	-1.00	.00	1.00	.00
			THRM01	-756	-19163	-1464	15512	47520	-210619	.00	.00	1.00	.00	-1.00	.00	1.00	.00

Calc. 1-12  
App. 2, p. 8

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES							
				FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY
D15	SPR	WT01 WT02 THRM01	1DB-H36	19	0	0	0	0	0	0	.00	1.00	.00				
				12	0	0	0	0	0	0	.00	1.00	.00				
D20	SPR	WT01 WT02 THRM01	1DB-H37	243	0	0	0	0	0	0	.00	1.00	.00				
				189	0	0	0	0	0	0	.00	1.00	.00				
D25	SPR	WT01 WT02 THRM01	1DB-H38	193	0	0	0	0	0	0	.00	1.00	.00				
				166	0	0	0	0	0	0	.00	1.00	.00				
D35	RAD	WT01 WT02 THRM01	1DB-H39	-2618	0	0	0	0	0	0	.00	1.00	.00				
				-2864	0	0	0	0	0	0	.00	1.00	.00				
				1153	0	0	0	0	0	0	.00	1.00	.00				
D40	RAD	WT01 WT02 THRM01	1DB-H40	-10655	0	0	0	0	0	0	.00	1.00	.00				
				-10815	0	0	0	0	0	0	.00	1.00	.00				
				-295	0	0	0	0	0	0	.00	1.00	.00				
D45	RAD	WT01 WT02 THRM01	1DB-H41	-11921	0	0	0	0	0	0	.00	1.00	.00				
				-10844	0	0	0	0	0	0	.00	1.00	.00				
				-199	0	0	0	0	0	0	.00	1.00	.00				
D50	RAD	WT01 WT02 THRM01	1GB-H42	-9816	0	0	0	0	0	0	.00	1.00	.00				
				-11358	0	0	0	0	0	0	.00	1.00	.00				
				330	0	0	0	0	0	0	.00	1.00	.00				
D60	SPR	WT01 WT02 THRM01	1DB-H43	973	0	0	0	0	0	0	.00	1.00	.00				
				177	0	0	0	0	0	0	.00	1.00	.00				
D70	SPR	WT01 WT02 THRM01	1DB-H44	684	0	0	0	0	0	0	.00	1.00	.00				
				82	0	0	0	0	0	0	.00	1.00	.00				

Code. 1-1 R  
App. 2, p. 90

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
				FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	CC
D75	SPR	WT01	1DB-H45	372	0	0	0	0	0	0	.00	1.00	.00					
		WT02		-65	0	0	0	0	0	0	.00	1.00	.00					
		THRM01																
D80	SPR	WT01	1DB-H46	104	0	0	0	0	0	0	.00	1.00	.00					
		WT02		-62	0	0	0	0	0	0	.00	1.00	.00					
		THRM01																
D95	SPR	WT01	1DB-H47	32	0	0	0	0	0	0	.00	1.00	.00					
		WT02		-43	0	0	0	0	0	0	.00	1.00	.00					
		THRM01																
MS4	RAD	WT01	MS-4	-67447	0	0	0	0	0	0	.00	1.00	.00					
		WT02		-77996	0	0	0	0	0	0	.00	1.00	.00					
		THRM01		-621	0	0	0	0	0	0	.00	1.00	.00					
CV4	SPD	WT01	CV4-SPR	-50451	0	0	0	0	0	0	.00	1.00	.00					
		WT02		-42432	0	0	0	0	0	0	.00	1.00	.00					
		THRM01																
GD6	ANC	WT01	TRBN NOZZLE	180	-26818	-241	-66546	1725	-2375	1.00	.00	.00	.00	1.00	.00	.00	.00	1.00
		WT02		181	-26830	-242	-66448	1697	-2364	1.00	.00	.00	.00	1.00	.00	.00	.00	1.00
		THRM01		1160	493	235	-5706	-39468	50502	1.00	.00	.00	.00	1.00	.00	.00	.00	1.00
110	SPR	WT01	7DB-H79	230	0	0	0	0	0	0	.00	1.00	.00					
		WT02		-32	0	0	0	0	0	0	.00	1.00	.00					
		THRM01																
120	SPR	WT01	7DB-H77	140	0	0	0	0	0	0	.00	1.00	.00					
		WT02		38	0	0	0	0	0	0	.00	1.00	.00					
		THRM01																
125	SPR	WT01	7DB-H76	100	0	0	0	0	0	0	.00	1.00	.00					
		WT02		52	0	0	0	0	0	0	.00	1.00	.00					
		THRM01																

Calc. 1-1 R-1  
A1P.2, p 91

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES							
				FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY
145	RAD		BYP S VV SPPT														
		WT01		-26689	0	0	0	0	0	0	.00	1.00	.00				
		WT02		-26809	0	0	0	0	0	0	.00	1.00	.00				
		THRM01		-314	0	0	0	0	0	0	.00	1.00	.00				
146	RAD		BYP S VV SPPT														
		WT01		-30023	0	0	0	0	0	0	0	.00	1.00	.00			
		WT02		-30038	0	0	0	0	0	0	0	.00	1.00	.00			
		THRM01		509	0	0	0	0	0	0	0	.00	1.00	.00			
165	SPR		7DB-H74														
		WT01		9	0	0	0	0	0	0	0	.00	1.00	.00			
		WT02		-29	0	0	0	0	0	0	0	.00	1.00	.00			
		THRM01															
180	SPR		7DB-H75														
		WT01		-104	0	0	0	0	0	0	0	.00	1.00	.00			
		WT02		-150	0	0	0	0	0	0	0	.00	1.00	.00			
		THRM01															
250	SPR		7DB-H78														
		WT01		33	0	0	0	0	0	0	0	.00	1.00	.00			
		WT02		-52	0	0	0	0	0	0	0	.00	1.00	.00			
		THRM01															
MS2	SPD		MS2-MS3 SPR														
		WT01		-229593	0	0	0	0	0	0	0	.00	1.00	.00			
		WT02		-263967	0	0	0	0	0	0	0	.00	1.00	.00			
		THRM01															
AR5	RAD		REST-5														
		WT01		-5360	0	0	0	0	0	0	0	.00	1.00	.00			
		WT02		-6065	0	0	0	0	0	0	0	.00	1.00	.00			
		THRM01		-21700	0	0	0	0	0	0	0	.00	1.00	.00			
BR5	RAD		REST-5														
		WT01		-4597	0	0	0	0	0	0	0	.00	1.00	.00			
		WT02		-5426	0	0	0	0	0	0	0	.00	1.00	.00			
		THRM01		-21078	0	0	0	0	0	0	0	.00	1.00	.00			
CR5	RAD		REST-5														
		WT01		-3825	0	0	0	0	0	0	0	.00	1.00	.00			
		WT02		-4854	0	0	0	0	0	0	0	.00	1.00	.00			
		THRM01		-20523	0	0	0	0	0	0	0	.00	1.00	.00			

Calc 1-1 p.1  
A 11.2, P. 92

1-1

## RESTRAINT LOAD SUMMARY

ME101/N2 PECO/553967 (QB2422) 09/26/03 QB2422 PAGE 328

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASE :

DATA TYPE PT	LOAD RAD	TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
DR5	REST-5	WT01	-3844	0	0	0	0	0	0	.00	1.00	.00					
		WT02	-4796	0	0	0	0	0	0	.00	1.00	.00					
		THRM01	-20013	0	0	0	0	0	0	.00	1.00	.00					
ME101LC	Version N2	stop on 09/26/03 at 02:24:48															
ME101LC	Version N2	run time .25 seconds															
ME101SA	Version N2	start on 09/26/03 at 02:24:48															

Calc. 1-1 R.1  
 APP. 2, p. 93

TITLE : U3 MAIN STEAM LINES O/C  
 PROJECT NUMBER : 03-00525  
 PROBLEM NUMBER : 1-1  
 USER : KAZOUN  
 LOAD CASES : ALL

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
A05	TNGT	6803	7506	15000	0	0	0	0	0	0	0	5965	22500	0	0
A06			7234	15000		0	0	0	0	0	0	3082	22500	0	0
A06	TNGT	6803	7234	15000	0	0	0	0	0	0	0	3082	22500	0	0
A07			7092	15000		0	0	0	0	0	0	7687	22500	0	0
A07	TNGT	6803	7092	15000	0	0	0	0	0	0	0	7687	22500	0	0
A07A			6855	15000		0	0	0	0	0	0	1086	22500	0	0
A07A	TNGT	6803	6855	15000	0	0	0	0	0	0	0	1086	22500	0	0
A07B			6856	15000		0	0	0	0	0	0	1137	22500	0	0
A07B	TNGT	6803	6856	15000	0	0	0	0	0	0	0	1137	22500	0	0
A10_B			6856	15000		0	0	0	0	0	0	1193	22500	0	0
A10_B	BEND	6803	6896	15000	0	0	0	0	0	0	0	2811	22500	0	0
A10_M			6983	15000		0	0	0	0	0	0	2814	22500	0	0
A10_M	BEND	6803	6983	15000	0	0	0	0	0	0	0	2814	22500	0	0
A10_E			7261	15000		0	0	0	0	0	0	2670	22500	0	0
A10_E	TNGT	6803	7062	15000	0	0	0	0	0	0	0	1134	22500	0	0
A15			7228	15000		0	0	0	0	0	0	1071	22500	0	0
A15	TNGT	6803	7228	15000	0	0	0	0	0	0	0	1071	22500	0	0
A15A			7084	15000		0	0	0	0	0	0	840	22500	0	0
A15A	TNGT	6803	7084	15000	0	0	0	0	0	0	0	840	22500	0	0
A15B			7359	15000		0	0	0	0	0	0	651	22500	0	0
A15B	TNGT	6803	7359	15000	0	0	0	0	0	0	0	651	22500	0	0
A15C			7203	15000		0	0	0	0	0	0	549	22500	0	0
A15C	TNGT	6803	7203	15000	0	0	0	0	0	0	0	583	22500	0	0
A20			6990	15000		0	0	0	0	0	0				

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
App. 2, p. 94

## CODE B31S73

FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION				NON-REPEATED ANCHOR MOV	
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
A20	TNGT	6803	6990 6904	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	583 615	22500 22500	0 0	0 0
A25															
A25	TNGT	6803	6904 6844	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	615 662	22500 22500	0 0	0 0
A30 B	BEND	6803	6875 6853	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1560 1645	22500 22500	0 0	0 0
A30 M	BEND	6803	6853 6865	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1645 1626	22500 22500	0 0	0 0
A30 E	TNGT	6803	6838 6935	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	690 660	22500 22500	0 0	0 0
A35	TNGT	6803	6935 6965	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	660 596	22500 22500	0 0	0 0
A35A	TNGT	6803	6965 7138	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	596 535	22500 22500	0 0	0 0
A35B	TNGT	6803	7138 7454	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	535 480	22500 22500	0 0	0 0
A40	TNGT	6803	7454 6848	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	480 404	22500 22500	0 0	0 0
A40A	TNGT	6803	6848 7228	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	404 334	22500 22500	0 0	0 0
A40B	TNGT	6803	7228 7331	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	334 272	22500 22500	0 0	0 0
A40C	TNGT	6803	7331 7145	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	272 225	22500 22500	0 0	0 0
A40D	TNGT	6803	7145 6942	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	225 206	22500 22500	0 0	0 0
A40E	TNGT	6803	6942 7704	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	206 221	22500 22500	0 0	0 0
A45	TNGT	6803	7704 6991	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	221 264	22500 22500	0 0	0 0
A45A															

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 Rev.  
App. 2, p. 75

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION				NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 CALC PSI	ALLOW PSI	EQN *** CALC PSI	ALLOW PSI
A45A	TNGT	6803	6991	15000	0	0	0	0	0	0	0	264	22500	0	0	0
A45B			7046	15000		0	0	0	0	0	0	324	22500	0	0	0
A45B	TNGT	6803	7046	15000	0	0	0	0	0	0	0	324	22500	0	0	0
A45C			7179	15000		0	0	0	0	0	0	394	22500	0	0	0
A45C	TNGT	6803	7179	15000	0	0	0	0	0	0	0	394	22500	0	0	0
A45D			7024	15000		0	0	0	0	0	0	469	22500	0	0	0
A45D	TNGT	6803	7024	15000	0	0	0	0	0	0	0	469	22500	0	0	0
A45E			7034	15000		0	0	0	0	0	0	548	22500	0	0	0
A45E	TNGT	6803	7034	15000	0	0	0	0	0	0	0	548	22500	0	0	0
A50			7769	15000		0	0	0	0	0	0	628	22500	0	0	0
A50	TNGT	6803	7769	15000	0	0	0	0	0	0	0	628	22500	0	0	0
A50A			6962	15000		0	0	0	0	0	0	709	22500	0	0	0
A50A	TNGT	6803	6962	15000	0	0	0	0	0	0	0	709	22500	0	0	0
A50B			7169	15000		0	0	0	0	0	0	791	22500	0	0	0
A50B	TNGT	6803	7169	15000	0	0	0	0	0	0	0	791	22500	0	0	0
A50C			7399	15000		0	0	0	0	0	0	874	22500	0	0	0
A50C	TNGT	6803	7399	15000	0	0	0	0	0	0	0	874	22500	0	0	0
A50D			7338	15000		0	0	0	0	0	0	958	22500	0	0	0
A50D	TNGT	6803	7338	15000	0	0	0	0	0	0	0	958	22500	0	0	0
A50D			6989	15000		0	0	0	0	0	0	1042	22500	0	0	0
A50E			7338	15000		0	0	0	0	0	0	958	22500	0	0	0
A50E	TNGT	6803	7338	15000	0	0	0	0	0	0	0	1042	22500	0	0	0
A55			6989	15000		0	0	0	0	0	0	1042	22500	0	0	0
A55	TNGT	6803	6989	15000	0	0	0	0	0	0	0	1126	22500	0	0	0
A55			7263	15000		0	0	0	0	0	0	1126	22500	0	0	0
A60			7263	15000		0	0	0	0	0	0	1126	22500	0	0	0
A60	TNGT	6803	7263	15000	0	0	0	0	0	0	0	1213	22500	0	0	0
A65 B			6871	15000		0	0	0	0	0	0	1213	22500	0	0	0
A65 B	TNGT	6803	6871	15000	0	0	0	0	0	0	0	1292	22500	0	0	0
A65 M			6851	15000		0	0	0	0	0	0	1292	22500	0	0	0
A65 M	BEND	6803	6888	15000	0	0	0	0	0	0	0	3043	22500	0	0	0
A65 M			6894	15000		0	0	0	0	0	0	3078	22500	0	0	0
A65 E			6894	15000		0	0	0	0	0	0	3078	22500	0	0	0
A65 E	BEND	6803	7038	15000	0	0	0	0	0	0	0	3020	22500	0	0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
\*\* EXCEEDED ALLOWABLE

CAC.C. 1-1 R.  
A41.2, P. 75

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
A65 E	TNGT	6803	6936 7155	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1282 1219	22500 22500	0 0	0 0
A65A															
A65A	TNGT	6803	7155 7484	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1219 1155	22500 22500	0 0	0 0
A70	TNGT	6803	7484 6836	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1155 1051	22500 22500	0 0	0 0
A70A	TNGT	6803	6836 7187	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1051 947	22500 22500	0 0	0 0
A70B	TNGT	6803	7187 7293	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	947 843	22500 22500	0 0	0 0
A70C	TNGT	6803	7293 7118	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	843 739	22500 22500	0 0	0 0
A70D	TNGT	6803	7118 6952	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	739 635	22500 22500	0 0	0 0
A75	TNGT	6803	6952 7098	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	635 535	22500 22500	0 0	0 0
A75A	TNGT	6803	7098 7270	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	535 435	22500 22500	0 0	0 0
A75B	TNGT	6803	7270 7177	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	435 335	22500 22500	0 0	0 0
A75C	TNGT	6803	7177 6836	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	335 237	22500 22500	0 0	0 0
A80	TNGT	6803	6836 6846	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	237 136	22500 22500	0 0	0 0
A80A	TNGT	6803	6846 7065	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	136 67	22500 22500	0 0	0 0
A85	TNGT	6803	7065 6990	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	67 67	22500 22500	0 0	0 0
A88 B	BEND	6803	7134 6983	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	157 209	22500 22500	0 0	0 0
A88 M															

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc 1-1 L.1  
A/H.2, p. 97

## CODE B31S73

ELEMENT FROM TO	TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
A88 M	BEND	6803	6983 7068	15000 15000	0	0	0	0	0	0	0	209 293	22500 22500	0	0
A88 E					0	0	0	0	0	0	0			0	0
A88 E	TNGT	6803	6953 7049	15000 15000	0	0	0	0	0	0	0	125 268	22500 22500	0	0
A90					0	0	0	0	0	0	0			0	0
A90 A	TNGT	6803	7015 6917	15000 15000	0	0	0	0	0	0	0	218 210	22500 22500	0	0
A90A					0	0	0	0	0	0	0			0	0
A95 A	TNGT	6803	6917 7175	15000 15000	0	0	0	0	0	0	0	210 309	22500 22500	0	0
A95 A					0	0	0	0	0	0	0			0	0
A95A	TNGT	6803	7175 7021	15000 15000	0	0	0	0	0	0	0	309 365	22500 22500	0	0
A95A					0	0	0	0	0	0	0			0	0
ASV	TNGT	6803	7021 6994	15000 15000	0	0	0	0	0	0	0	365 421	22500 22500	0	0
ASV					0	0	0	0	0	0	0			0	0
A97 A	TNGT	5866	5893 5906	15000 15000	0	0	0	0	0	0	0	59 67	22500 22500	0	0
A97					0	0	0	0	0	0	0			0	0
MS1	TNGT	5866	6820 5866	15000 15000	0	0	0	0	0	0	0	55 0	22500 22500	0	0
MS1					0	0	0	0	0	0	0			0	0
S02	TNGT	5866	5866 5866	15000 15000	0	0	0	0	0	0	0	0 0	22500 22500	0	0
A97					0	0	0	0	0	0	0			0	0
GA1	TNGT	4198	4387 4859	15000 15000	0	0	0	0	0	0	0	363 279	22500 22500	0	0
GA1					0	0	0	0	0	0	0			0	0
CV1	TNGT	4198	4972 4198	15000 15000	0	0	0	0	0	0	0	0 0	22500 22500	0	0
GA1					0	0	0	0	0	0	0			0	0
GA1A	TNGT	5421	5735 5744	15000 15000	0	0	0	0	0	0	0	721 674	22500 22500	0	0
GA1A					0	0	0	0	0	0	0			0	0
GA1B	TNGT	5421	5744 5754	15000 15000	0	0	0	0	0	0	0	674 632	22500 22500	0	0
GA1B					0	0	0	0	0	0	0			0	0
GA2 B	TNGT	5421	5754 5766	15000 15000	0	0	0	0	0	0	0	632 595	22500 22500	0	0
GA2 B					0	0	0	0	0	0	0			0	0
GA2 M	BEND	5421	5949 5769	15000 15000	0	0	0	0	0	0	0	1214 1164	22500 22500	0	0
GA2 M					0	0	0	0	0	0	0			0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.  
11/2/98

## CODE B31S73

ELEMENT FROM TO		SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV			
		TYPE TITLE	PD/4T PSI	EQN 11 CALC PSI	ALLOW PSI	PD/4T PSI	LEVEL B EQN 12 CALC PSI	ALLOW PSI	LEVEL C EQN 12 CALC PSI	ALLOW PSI	LEVEL D EQN 12 CALC PSI	ALLOW PSI	EQNS 13/14 CALC PSI	ALLOW PSI	EQN *** CALC PSI	ALLOW PSI
GA2 M	BEND	5421	5769	15000	0	0	0	0	0	0	0	0	1164	22500	0	0
GA2 E			5559	15000		0	0	0	0	0	0	0	1117	22500	0	0
GA2 E	TNGT	5421	5511	15000	0	0	0	0	0	0	0	0	548	22500	0	0
GA2A			5887	15000		0	0	0	0	0	0	0	534	22500	0	0
GA2A	TNGT	5421	5887	15000	0	0	0	0	0	0	0	0	534	22500	0	0
GA2B			6139	15000		0	0	0	0	0	0	0	550	22500	0	0
GA2C	TNGT	5421	6139	15000	0	0	0	0	0	0	0	0	593	22500	0	0
GA2D			6237	15000		0	0	0	0	0	0	0	659	22500	0	0
GA2C	TNGT	5421	6237	15000	0	0	0	0	0	0	0	0	593	22500	0	0
GA2D			6181	15000		0	0	0	0	0	0	0	659	22500	0	0
GA2D	TNGT	5421	6181	15000	0	0	0	0	0	0	0	0	740	22500	0	0
GA2E			5971	15000		0	0	0	0	0	0	0	659	22500	0	0
GA2E	TNGT	5421	5971	15000	0	0	0	0	0	0	0	0	740	22500	0	0
GA2E			5611	15000		0	0	0	0	0	0	0	833	22500	0	0
GA4 B	BEND	5421	5712	15000	0	0	0	0	0	0	0	0	1698	22500	0	0
GA4 M			5548	15000		0	0	0	0	0	0	0	1785	22500	0	0
GA4 M	BEND	5421	5548	15000	0	0	0	0	0	0	0	0	1785	22500	0	0
GA4 E			5703	15000		0	0	0	0	0	0	0	1788	22500	0	0
GA4 E	TNGT	5421	5606	15000	0	0	0	0	0	0	0	0	878	22500	0	0
GA4 A			5595	15000		0	0	0	0	0	0	0	835	22500	0	0
GA4 A	TNGT	5421	5595	15000	0	0	0	0	0	0	0	0	797	22500	0	0
GA4 B			5595	15000		0	0	0	0	0	0	0	835	22500	0	0
GA4 B	TNGT	5421	5589	15000	0	0	0	0	0	0	0	0	797	22500	0	0
GA4 C			5589	15000		0	0	0	0	0	0	0	763	22500	0	0
GA4 C	TNGT	5421	5589	15000	0	0	0	0	0	0	0	0	797	22500	0	0
GA4 D			5587	15000		0	0	0	0	0	0	0	763	22500	0	0
GA4 D	TNGT	5421	5587	15000	0	0	0	0	0	0	0	0	735	22500	0	0
GA4 D			5590	15000		0	0	0	0	0	0	0	763	22500	0	0
GA4 E			5590	15000		0	0	0	0	0	0	0	735	22500	0	0
GA4 E	TNGT	5421	5590	15000	0	0	0	0	0	0	0	0	714	22500	0	0
GA4 E			5596	15000		0	0	0	0	0	0	0	714	22500	0	0
GA4 F			5607	15000		0	0	0	0	0	0	0	699	22500	0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
App. 2, p. 99

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN *** CALC PSI	ALLOW PSI
GA4 F	TNGT	5421	5607	15000	0	0	0	0	0	0	0	699	22500	0	0
GA4 G			5621	15000	0	0	0	0	0	0	0	692	22500	0	0
GA4 G	TNGT	5421	5621	15000	0	0	0	0	0	0	0	692	22500	0	0
GA5 B	TNGT	5421	5637	15000	0	0	0	0	0	0	0	692	22500	0	0
GA5 B	BEND	5421	5854	15000	0	0	0	0	0	0	0	1849	22500	0	0
GA5 M	BEND	5421	5673	15000	0	0	0	0	0	0	0	1885	22500	0	0
GA5 M			7091	15000	0	0	0	0	0	0	0	1971	22500	0	0
GA5 E	TNGT	5421	6255	15000	0	0	0	0	0	0	0	738	22500	0	0
GA6			6557	15000	0	0	0	0	0	0	0	751	22500	0	0
B05	TNGT	6803	7528	15000	0	0	0	0	0	0	0	5939	22500	0	0
B06			7240	15000	0	0	0	0	0	0	0	3116	22500	0	0
B06	TNGT	6803	7240	15000	0	0	0	0	0	0	0	3116	22500	0	0
B07	TNGT	6803	6887	15000	0	0	0	0	0	0	0	7184	22500	0	0
B07 A			6818	15000	0	0	0	0	0	0	0	1015	22500	0	0
B07 A	TNGT	6803	6818	15000	0	0	0	0	0	0	0	1015	22500	0	0
B07 B	TNGT	6803	6818	15000	0	0	0	0	0	0	0	1069	22500	0	0
B07 B			6817	15000	0	0	0	0	0	0	0	1069	22500	0	0
B10 B	TNGT	6803	6817	15000	0	0	0	0	0	0	0	1131	22500	0	0
B10 M	BEND	6803	6827	15000	0	0	0	0	0	0	0	2664	22500	0	0
B10 M			6903	15000	0	0	0	0	0	0	0	2682	22500	0	0
B10 M	BEND	6803	6903	15000	0	0	0	0	0	0	0	2682	22500	0	0
B10 E	BEND	6803	7223	15000	0	0	0	0	0	0	0	2553	22500	0	0
B10 E			7223	15000	0	0	0	0	0	0	0	1024	22500	0	0
B15	TNGT	6803	7041	15000	0	0	0	0	0	0	0	1084	22500	0	0
B15			7228	15000	0	0	0	0	0	0	0	1024	22500	0	0
B15 A	TNGT	6803	7228	15000	0	0	0	0	0	0	0	1024	22500	0	0
B15 A			7010	15000	0	0	0	0	0	0	0	807	22500	0	0
B15 B	TNGT	6803	7010	15000	0	0	0	0	0	0	0	642	22500	0	0
B15 B			7197	15000	0	0	0	0	0	0	0	807	22500	0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R. 1  
A112, p. 100

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV			
		PD/4T PSI	EQN 11 CALC PSI	ALLOW PSI	PD/4T PSI	LEVEL B EQN 12 CALC PSI	ALLOW PSI	LEVEL C EQN 12 CALC PSI	ALLOW PSI	LEVEL D EQN 12 CALC PSI	ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN *** CALC PSI	ALLOW PSI	
B15B	TNGT	6803	7197	15000	0	0	0	0	0	0	0	642	22500	0	0	
B15C			6940	15000		0	0	0	0	0	0	577	22500	0	0	
B15C	TNGT	6803	6940	15000	0	0	0	0	0	0	0	577	22500	0	0	
B20			7368	15000		0	0	0	0	0	0	643	22500	0	0	
B20	TNGT	6803	7368	15000	0	0	0	0	0	0	0	643	22500	0	0	
B25			6931	15000		0	0	0	0	0	0	768	22500	0	0	
B30 B	TNGT	6803	6931	15000	0	0	0	0	0	0	0	811	22500	0	0	
B30 B	BEND	6803	6899	15000	0	0	0	0	0	0	0	1910	22500	0	0	
B30 M			6845	15000		0	0	0	0	0	0	2011	22500	0	0	
B30 M	BEND	6803	6845	15000	0	0	0	0	0	0	0	1982	22500	0	0	
B30 E			6878	15000		0	0	0	0	0	0	2011	22500	0	0	
B30 E	TNGT	6803	6846	15000	0	0	0	0	0	0	0	842	22500	0	0	
B30A			6821	15000		0	0	0	0	0	0	800	22500	0	0	
B30A	TNGT	6803	6821	15000	0	0	0	0	0	0	0	768	22500	0	0	
B35			6898	15000		0	0	0	0	0	0	0	768	22500	0	0
B35A			6965	15000		0	0	0	0	0	0	655	22500	0	0	
B35A	TNGT	6803	6965	15000	0	0	0	0	0	0	0	655	22500	0	0	
B40			7382	15000		0	0	0	0	0	0	552	22500	0	0	
B40 A	TNGT	6803	7382	15000	0	0	0	0	0	0	0	466	22500	0	0	
B40 A			6839	15000		0	0	0	0	0	0	466	22500	0	0	
B40A B	TNGT	6803	6839	15000	0	0	0	0	0	0	0	384	22500	0	0	
B40B			7184	15000		0	0	0	0	0	0	384	22500	0	0	
B40B	TNGT	6803	7184	15000	0	0	0	0	0	0	0	308	22500	0	0	
B40C			7273	15000		0	0	0	0	0	0	308	22500	0	0	
B40C	TNGT	6803	7273	15000	0	0	0	0	0	0	0	243	22500	0	0	
B40D			7101	15000		0	0	0	0	0	0	243	22500	0	0	
B40D	TNGT	6803	7101	15000	0	0	0	0	0	0	0	202	22500	0	0	
B40E			6940	15000		0	0	0	0	0	0	0	202	22500	0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc. 1-1 R. 1  
Att. 2, p. 101

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
B40E B45	TNGT	6803	6940 7632	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	202 198	22500 22500	0 0	0 0
B45	TNGT	6803	7632 6946	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	198 236	22500 22500	0 0	0 0
B45A B45B	TNGT	6803	6946 7060	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	236 303	22500 22500	0 0	0 0
B45B B45C	TNGT	6803	7060 7166	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	303 383	22500 22500	0 0	0 0
B45C B45D	TNGT	6803	7166 6983	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	383 469	22500 22500	0 0	0 0
B45D B45E	TNGT	6803	6983 7100	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	469 560	22500 22500	0 0	0 0
B45E B50	TNGT	6803	7100 7864	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	560 652	22500 22500	0 0	0 0
B50 B50A	TNGT	6803	7864 6986	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	652 745	22500 22500	0 0	0 0
B50A B50B	TNGT	6803	6986 7211	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	745 839	22500 22500	0 0	0 0
B50B B50C	TNGT	6803	7211 7509	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	839 935	22500 22500	0 0	0 0
B50C B50D	TNGT	6803	7509 7517	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	935 1031	22500 22500	0 0	0 0
B50D B50E	TNGT	6803	7517 7235	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1031 1128	22500 22500	0 0	0 0
B50E B55	TNGT	6803	7235 6947	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1128 1225	22500 22500	0 0	0 0
B55 B60	TNGT	6803	6947 6927	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1225 1419	22500 22500	0 0	0 0
B60 B65 B	TNGT	6803	6927 6864	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1419 1448	22500 22500	0 0	0 0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

calc 1-1 R.!  
A11.2, p. 102

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN 11 CALC PSI	ALLOW PSI	PD/4T PSI	LEVEL B EQN 12 CALC PSI	ALLOW PSI	LEVEL C EQN 12 CALC PSI	ALLOW PSI	LEVEL D EQN 12 CALC PSI	ALLOW PSI	EQNS 13/14 CALC PSI	ALLOW PSI	EQN *** CALC PSI	ALLOW PSI
B65 B B65 M	BEND	6803	6911 6923	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	3411 3443	22500 22500	0 0	0 0
B65 M B65 E	BEND	6803	6923 7203	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	3443 3356	22500 22500	0 0	0 0
B65 E B70	TNGT	6803	7030 7420	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1425 1326	22500 22500	0 0	0 0
B70 B70A	TNGT	6803	7420 6957	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1326 1188	22500 22500	0 0	0 0
B70A B70B	TNGT	6803	6957 6986	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1188 1050	22500 22500	0 0	0 0
B70B B70C	TNGT	6803	6986 6958	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1050 912	22500 22500	0 0	0 0
B70C B70D	TNGT	6803	6958 7049	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	912 774	22500 22500	0 0	0 0
B70D B75	TNGT	6803	7049 7615	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	774 637	22500 22500	0 0	0 0
B75 B75A	TNGT	6803	7615 6923	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	637 465	22500 22500	0 0	0 0
B75A B75B	TNGT	6803	6923 7200	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	465 295	22500 22500	0 0	0 0
B75B B75C	TNGT	6803	7200 7152	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	295 129	22500 22500	0 0	0 0
B75C B80	TNGT	6803	7152 6995	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	129 76	22500 22500	0 0	0 0
B80 B85 B	TNGT	6803	6995 6950	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	76 97	22500 22500	0 0	0 0
B85 B B85 M	BEND	6803	7063 7082	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	228 368	22500 22500	0 0	0 0
B85 M B85 E	BEND	6803	7082 7181	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	368 495	22500 22500	0 0	0 0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.  
APP. 2, p. 103

## CODE B31S73

ELEMENT FROM TO	TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV			
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	CALC PSI	LEVEL B EQN 12 CALC PSI	LEVEL C EQN 12 CALC PSI	LEVEL D EQN 12 CALC PSI	EQNS CALC PSI	13/14 CALC PSI	ALLOW PSI	EQN CALC PSI	*** ALLOW PSI		
B85 E	TNGT	6803	7017 7122	15000 15000	0	0 0	0 0	0 0	0 0	210 439	22500 22500	0 0	0 0	0 0		
B890																
B90	TNGT	6803	7321 6848	15000 15000	0	0 0	0 0	0 0	0 0	385 289	22500 22500	0 0	0 0	0 0		
B90A	TNGT	6803	6848 7382	15000 15000	0	0 0	0 0	0 0	0 0	289 376	22500 22500	0 0	0 0	0 0		
B95	TNGT	6803	7382 7363	15000 15000	0	0 0	0 0	0 0	0 0	376 442	22500 22500	0 0	0 0	0 0		
B95A	TNGT	6803	7363 7474	15000 15000	0	0 0	0 0	0 0	0 0	442 508	22500 22500	0 0	0 0	0 0		
BSV	TNGT	5866	5960 5992	15000 15000	0	0 0	0 0	0 0	0 0	72 80	22500 22500	0 0	0 0	0 0		
B97	TNGT	4198	4521 4806	15000 15000	0	0 0	0 0	0 0	0 0	160 162	22500 22500	0 0	0 0	0 0		
GB1	TNGT	4198	4942 4198	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	22500 22500	0 0	0 0	0 0	
GB1 CV2	TNGT	5421	5774 5761	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	419 427	22500 22500	0 0	0 0	0 0
GB1A	TNGT	5421	5761 5748	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	427 480	22500 22500	0 0	0 0	0 0
GB1B GB1B	TNGT	5421	5748 5735	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	480 564	22500 22500	0 0	0 0	0 0
GB1B GB2 B	TNGT	5421	5901 5697	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1150 1234	22500 22500	0 0	0 0	0 0
GB2 B GB2 M	BEND	5421	5697 5561	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1234 1262	22500 22500	0 0	0 0	0 0
GB2 M GB2 E	BEND	5421	5513 5916	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	619 629	22500 22500	0 0	0 0	0 0
GB2 E GB2A	TNGT	5421	5916 6165	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	629 663	22500 22500	0 0	0 0	0 0
GB2A GB2B	TNGT	5421														

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc. 1-1 Rev. 1  
Att. 2, p. 104

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
GB2B	TNGT	5421	6165 6261	15000 15000	0	0	0	0	0	0	0	663 719	22500 22500	0	0
GB2C	TNGT	5421	6261 6201	15000 15000	0	0	0	0	0	0	0	719 792	22500 22500	0	0
GB2D	TNGT	5421	6201 5987	15000 15000	0	0	0	0	0	0	0	792 877	22500 22500	0	0
GB2E	TNGT	5421	5987 5618	15000 15000	0	0	0	0	0	0	0	877 972	22500 22500	0	0
GB4 B	BEND	5421	5723 5510	15000 15000	0	0	0	0	0	0	0	1981 2089	22500 22500	0	0
GB4 M	BEND	5421	5510 5700	15000 15000	0	0	0	0	0	0	0	2089 2147	22500 22500	0	0
GB4 E	TNGT	5421	5603 5614	15000 15000	0	0	0	0	0	0	0	1054 1075	22500 22500	0	0
GB4 A	TNGT	5421	5614 5624	15000 15000	0	0	0	0	0	0	0	1075 1108	22500 22500	0	0
GB4 B	TNGT	5421	5624 5635	15000 15000	0	0	0	0	0	0	0	1108 1152	22500 22500	0	0
GB4 C	TNGT	5421	5635 5645	15000 15000	0	0	0	0	0	0	0	1152 1205	22500 22500	0	0
GB4 D	TNGT	5421	5645 5656	15000 15000	0	0	0	0	0	0	0	1205 1266	22500 22500	0	0
GB4 E	TNGT	5421	5656 5666	15000 15000	0	0	0	0	0	0	0	1266 1334	22500 22500	0	0
GB4 F	TNGT	5421	5666 5677	15000 15000	0	0	0	0	0	0	0	1334 1408	22500 22500	0	0
GB4 G	TNGT	5421	5677 5687	15000 15000	0	0	0	0	0	0	0	1408 1488	22500 22500	0	0
C05	TNGT	6803	7550 7246	15000 15000	0	0	0	0	0	0	0	5945 3184	22500 22500	0	0
C06	TNGT														

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 L.1  
App. 2, p. 105

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 CALC PSI	ALLOW PSI	EQN *** CALC PSI
C06	TNGT	6803	7246 7146	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	3184 7337	22500 22500	0 0	0 0
C07															
C07	TNGT	6803	7146 6864	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	7337 1022	22500 22500	0 0	0 0
C07A															
C07A	TNGT	6803	6864 6863	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1022 1071	22500 22500	0 0	0 0
C07B															
C07B	TNGT	6803	6863 6863	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1071 1136	22500 22500	0 0	0 0
C10_B															
C10_B	BEND	6803	6908 6836	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	2676 2699	22500 22500	0 0	0 0
C10_M															
C10_M	BEND	6803	6836 7180	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	2699 2564	22500 22500	0 0	0 0
C10_E															
C10_E	TNGT	6803	7017 7220	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1089 1025	22500 22500	0 0	0 0
C15															
C15	TNGT	6803	7220 6868	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1025 841	22500 22500	0 0	0 0
C15A															
C15A	TNGT	6803	6868 7072	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	841 690	22500 22500	0 0	0 0
C15B															
C15B	TNGT	6803	7072 7001	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	690 597	22500 22500	0 0	0 0
C15C															
C15C	TNGT	6803	7001 6952	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	597 591	22500 22500	0 0	0 0
C15D															
C15D	TNGT	6803	6952 7573	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	591 674	22500 22500	0 0	0 0
C20															
C20	TNGT	6803	7573 6838	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	674 979	22500 22500	0 0	0 0
C25															
C25	TNGT	6803	6838 6826	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	979 1000	22500 22500	0 0	0 0
C30_B															
C30_B	TNGT	6803	6843 6819	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	2355 2483	22500 22500	0 0	0 0
C30_M															
C30_M	BEND	6803	6843 6819	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	2355 2483	22500 22500	0 0	0 0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
Ap. 2, p. 106

## CODE B31S73

ELEMENT FROM TO	TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV	
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	13/14 CALC PSI	13/14 ALLOW PSI	EQN *** CALC PSI	*** ALLOW PSI
C30 M	BEND	6803	6819 6851	15000 15000	0	0 0	0 0	0 0	0 0	0 0	2483 2451	22500 22500	0 0	0 0
C30 E														
C30 E	TNGT	6803	6830 7042	15000 15000	0	0 0	0 0	0 0	0 0	0 0	1041 949	22500 22500	0 0	0 0
C35														
C35 C35A	TNGT	6803	7042 6914	15000 15000	0	0 0	0 0	0 0	0 0	0 0	949 837	22500 22500	0 0	0 0
C35A C35B	TNGT	6803	6914 6954	15000 15000	0	0 0	0 0	0 0	0 0	0 0	837 725	22500 22500	0 0	0 0
C35B C35C	TNGT	6803	6954 6920	15000 15000	0	0 0	0 0	0 0	0 0	0 0	725 615	22500 22500	0 0	0 0
C35C C40	TNGT	6803	6920 7494	15000 15000	0	0 0	0 0	0 0	0 0	0 0	615 507	22500 22500	0 0	0 0
C40 C40A	TNGT	6803	7494 6820	15000 15000	0	0 0	0 0	0 0	0 0	0 0	507 405	22500 22500	0 0	0 0
C40A C40B	TNGT	6803	6820 7184	15000 15000	0	0 0	0 0	0 0	0 0	0 0	405 309	22500 22500	0 0	0 0
C40B C40C	TNGT	6803	7184 7285	15000 15000	0	0 0	0 0	0 0	0 0	0 0	309 227	22500 22500	0 0	0 0
C40C C40D	TNGT	6803	7285 7097	15000 15000	0	0 0	0 0	0 0	0 0	0 0	227 177	22500 22500	0 0	0 0
C40D C40E	TNGT	6803	7097 6987	15000 15000	0	0 0	0 0	0 0	0 0	0 0	177 189	22500 22500	0 0	0 0
C40E C45	TNGT	6803	6987 7754	15000 15000	0	0 0	0 0	0 0	0 0	0 0	189 254	22500 22500	0 0	0 0
C45 C45A	TNGT	6803	7754 6990	15000 15000	0	0 0	0 0	0 0	0 0	0 0	254 341	22500 22500	0 0	0 0
C45A C45B	TNGT	6803	6990 7092	15000 15000	0	0 0	0 0	0 0	0 0	0 0	341 440	22500 22500	0 0	0 0
C45B C45C	TNGT	6803	7092 7275	15000 15000	0	0 0	0 0	0 0	0 0	0 0	440 546	22500 22500	0 0	0 0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc 1-1 R-1  
A.R. 2 / P. 107

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION				NON-REPEATED ANCHOR MOV	
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
C45C	TNGT	6803	7275 7168	15000 15000	0	0	0	0	0	0	0	546 654	22500 22500	0 0	0 0
C45D					0	0	0	0	0	0	0				
C45D	TNGT	6803	7168 6840	15000 15000	0	0	0	0	0	0	0	654 764	22500 22500	0 0	0 0
C45E					0	0	0	0	0	0	0				
C50	TNGT	6803	6840 7524	15000 15000	0	0	0	0	0	0	0	764 875	22500 22500	0 0	0 0
C50					0	0	0	0	0	0	0				
C50A	TNGT	6803	7524 6822	15000 15000	0	0	0	0	0	0	0	875 968	22500 22500	0 0	0 0
C50A					0	0	0	0	0	0	0				
C50B	TNGT	6803	6822 7277	15000 15000	0	0	0	0	0	0	0	968 1063	22500 22500	0 0	0 0
C50B					0	0	0	0	0	0	0				
C50C	TNGT	6803	7277 7525	15000 15000	0	0	0	0	0	0	0	1063 1158	22500 22500	0 0	0 0
C50C					0	0	0	0	0	0	0				
C50D	TNGT	6803	7525 7542	15000 15000	0	0	0	0	0	0	0	1158 1254	22500 22500	0 0	0 0
C50D					0	0	0	0	0	0	0				
C50D	TNGT	6803	7542 7327	15000 15000	0	0	0	0	0	0	0	1254 1351	22500 22500	0 0	0 0
C50E					0	0	0	0	0	0	0				
C50E	TNGT	6803	7327 6881	15000 15000	0	0	0	0	0	0	0	1351 1448	22500 22500	0 0	0 0
C55					0	0	0	0	0	0	0				
C55	TNGT	6803	6881 7192	15000 15000	0	0	0	0	0	0	0	1448 1518	22500 22500	0 0	0 0
C60					0	0	0	0	0	0	0				
C60	TNGT	6803	7192 6974	15000 15000	0	0	0	0	0	0	0	1518 1596	22500 22500	0 0	0 0
C65 B	BEND	6803	7105 7009	15000 15000	0	0	0	0	0	0	0	3759 3786	22500 22500	0 0	0 0
C65 M					0	0	0	0	0	0	0				
C65 M	BEND	6803	7009 6998	15000 15000	0	0	0	0	0	0	0	3786 3665	22500 22500	0 0	0 0
C65 E					0	0	0	0	0	0	0				
C65 E	TNGT	6803	6913 6924	15000 15000	0	0	0	0	0	0	0	1556 1445	22500 22500	0 0	0 0
C65A					0	0	0	0	0	0	0				
C65A	TNGT	6803	6924 7051	15000 15000	0	0	0	0	0	0	0	1445 1334	22500 22500	0 0	0 0
C70					0	0	0	0	0	0	0				

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
\*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
A/P.2, P.108

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
C70 C70A	TNGT	6803	7051 6977	15000 15000	0	0	0	0	0	0	0	1334 1158	22500 22500	0	0
C70A C70B	TNGT	6803	6977 7065	15000 15000	0	0	0	0	0	0	0	1158 982	22500 22500	0	0
C70B C70C	TNGT	6803	7065 6942	15000 15000	0	0	0	0	0	0	0	982 806	22500 22500	0	0
C70C C75	TNGT	6803	6942 7141	15000 15000	0	0	0	0	0	0	0	806 631	22500 22500	0	0
C75 C75A	TNGT	6803	7141 6983	15000 15000	0	0	0	0	0	0	0	631 451	22500 22500	0	0
C75A C75B	TNGT	6803	6983 7163	15000 15000	0	0	0	0	0	0	0	451 272	22500 22500	0	0
C75B C75C	TNGT	6803	7163 7100	15000 15000	0	0	0	0	0	0	0	272 93	22500 22500	0	0
C75C C80	TNGT	6803	7100 6925	15000 15000	0	0	0	0	0	0	0	93 87	22500 22500	0	0
C80 C85 B	TNGT	6803	6925 6912	15000 15000	0	0	0	0	0	0	0	87 124	22500 22500	0	0
C85 B C85 M	BEND	6803	6996 7034	15000 15000	0	0	0	0	0	0	0	291 491	22500 22500	0	0
C85 M C85 E	BEND	6803	7034 7042	15000 15000	0	0	0	0	0	0	0	491 652	22500 22500	0	0
C85 E C90	TNGT	6803	6939 6965	15000 15000	0	0	0	0	0	0	0	277 571	22500 22500	0	0
C90 C95	TNGT	6803	7087 7032	15000 15000	0	0	0	0	0	0	0	525 407	22500 22500	0	0
C95 C96	TNGT	6803	7032 6952	15000 15000	0	0	0	0	0	0	0	407 535	22500 22500	0	0
C96 CSV	TNGT	6803	6952 6974	15000 15000	0	0	0	0	0	0	0	535 556	22500 22500	0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

C.H.C. 1-1 R. 1  
APP. 2, P. 109

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION				NON-REPEATED ANCHOR MOV	
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
CSV C97	TNGT	5866	5890 5911	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	78 88	22500 22500	0 0	0 0
C97 GC1	TNGT	4198	4481 4818	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	267 194	22500 22500	0 0	0 0
GC1 CV3	TNGT	4198	4952 4198	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	22500 22500	0 0	0 0
GC1 GC1A	TNGT	5421	5769 5759	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	501 379	22500 22500	0 0	0 0
GC1A GC1B	TNGT	5421	5759 5748	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	379 414	22500 22500	0 0	0 0
GC1B GC2 B	TNGT	5421	5748 5737	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	414 579	22500 22500	0 0	0 0
GC2 B GC2 M	BEND	5421	5904 5702	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1181 1366	22500 22500	0 0	0 0
GC2 M GC2 E	BEND	5421	5702 5554	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1366 1437	22500 22500	0 0	0 0
GC2 E GC2A	TNGT	5421	5508 5912	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	705 709	22500 22500	0 0	0 0
GC2A GC2B	TNGT	5421	5912 6162	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	709 732	22500 22500	0 0	0 0
GC2B GC2C	TNGT	5421	6162 6257	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	732 771	22500 22500	0 0	0 0
GC2C GC2D	TNGT	5421	6257 6197	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	771 824	22500 22500	0 0	0 0
GC2D GC2E	TNGT	5421	6197 5983	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	824 889	22500 22500	0 0	0 0
GC2E GC4 B	TNGT	5421	5983 5614	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	889 963	22500 22500	0 0	0 0
GC4 B GC4 M	BEND	5421	5717 5517	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1963 2038	22500 22500	0 0	0 0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R. 1  
App. 2, p. 110

## CODE B31S73

ELEMENT FROM TO	TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
GC4 M	BEND	5421	5517 5704	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	2038 2080	22500 22500	0 0	0 0
GC4 E															
GC4 E	TNGT	5421	5606 5615	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1021 1057	22500 22500	0 0	0 0
GC4A															
GC4A	TNGT	5421	5615 5624	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1057 1132	22500 22500	0 0	0 0
GC4B															
GC4B	TNGT	5421	5624 5632	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1132 1237	22500 22500	0 0	0 0
GC4C															
GC4C	TNGT	5421	5632 5641	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1237 1367	22500 22500	0 0	0 0
GC4D															
GC4D	TNGT	5421	5641 5650	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1367 1514	22500 22500	0 0	0 0
GC4E															
GC4E	TNGT	5421	5650 5659	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1514 1675	22500 22500	0 0	0 0
GC4F															
GC4F	TNGT	5421	5659 5667	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1675 1845	22500 22500	0 0	0 0
GC4G															
GC4G	TNGT	5421	5667 5676	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1845 2022	22500 22500	0 0	0 0
D05															
D05	TNGT	6803	7570 7259	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	5992 3301	22500 22500	0 0	0 0
D06															
D06	TNGT	6803	7259 7515	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	3301 8334	22500 22500	0 0	0 0
D07															
D07	TNGT	6803	7515 6933	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	8334 1138	22500 22500	0 0	0 0
D07A															
D07A	TNGT	6803	6933 6935	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1138 1175	22500 22500	0 0	0 0
D07B															
D07B	TNGT	6803	6935 6937	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1175 1237	22500 22500	0 0	0 0
D10 B															
D10 B	BEND	6803	7039 6985	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	2913 2927	22500 22500	0 0	0 0
D10 M															

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc. 1-1 R-1  
APP-2, P-11

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION				NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 CALC PSI	ALLOW PSI	EQN *** CALC PSI	ALLOW PSI
D10 M	BEND	6803	6985 7156	15000 15000	0	0	0	0	0	0	0	2927 2765	22500 22500	0	0	0
D10 E															0	0
D10 E	TNGT	6803	7003 7188	15000 15000	0	0	0	0	0	0	0	1174 1100	22500 22500	0	0	0
D15															0	0
D15 A	TNGT	6803	7188 7028	15000 15000	0	0	0	0	0	0	0	1100 830	22500 22500	0	0	0
D15 A	TNGT	6803	7028 7162	15000 15000	0	0	0	0	0	0	0	830 626	22500 22500	0	0	0
D15 B	TNGT	6803	7162 6916	15000 15000	0	0	0	0	0	0	0	626 563	22500 22500	0	0	0
D15 C	TNGT	6803	6916 7468	15000 15000	0	0	0	0	0	0	0	563 682	22500 22500	0	0	0
D15 C	D20														0	0
D20	TNGT	6803	7468 7123	15000 15000	0	0	0	0	0	0	0	682 913	22500 22500	0	0	0
D20 A															0	0
D20 A	TNGT	6803	7123 7199	15000 15000	0	0	0	0	0	0	0	913 1197	22500 22500	0	0	0
D25	TNGT	6803	7199 7131	15000 15000	0	0	0	0	0	0	0	1197 1223	22500 22500	0	0	0
D30 B	BEND	6803	7382 6974	15000 15000	0	0	0	0	0	0	0	2881 3042	22500 22500	0	0	0
D30 M	BEND	6803	6974 7098	15000 15000	0	0	0	0	0	0	0	3042 3014	22500 22500	0	0	0
D30 E	BEND	6803	6974 7098	15000 15000	0	0	0	0	0	0	0	3042 3014	22500 22500	0	0	0
D30 E	TNGT	6803	6970 7184	15000 15000	0	0	0	0	0	0	0	1280 1194	22500 22500	0	0	0
D30 A	TNGT	6803	7184 7271	15000 15000	0	0	0	0	0	0	0	1194 1115	22500 22500	0	0	0
D33	TNGT	6803	7271 7208	15000 15000	0	0	0	0	0	0	0	1115 1032	22500 22500	0	0	0
D33	D35														0	0
D35	TNGT	6803	7208 7332	15000 15000	0	0	0	0	0	0	0	1032 906	22500 22500	0	0	0
D35 A															0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc. 1-1 c.1  
App. 2, p. 112

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV			
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI	
D35A	TNGT	6803	7332	15000	0	0	0	0	0	0	0	906	22500	0	0	
D35B		7169	15000		0	0	0	0	0	0	0	781	22500	0	0	
D35B	TNGT	6803	7169	15000	0	0	0	0	0	0	0	781	22500	0	0	
D35C		6893	15000		0	0	0	0	0	0	0	659	22500	0	0	
D35C	TNGT	6803	6893	15000	0	0	0	0	0	0	0	659	22500	0	0	
D40		7631	15000		0	0	0	0	0	0	0	542	22500	0	0	
D40	TNGT	6803	7631	15000	0	0	0	0	0	0	0	427	22500	0	0	
D40A		6913	15000		0	0	0	0	0	0	0	427	22500	0	0	
D40A	TNGT	6803	6913	15000	0	0	0	0	0	0	0	317	22500	0	0	
D40B		7124	15000		0	0	0	0	0	0	0	221	22500	0	0	
D40B	TNGT	6803	7124	15000	0	0	0	0	0	0	0	317	22500	0	0	
D40C		7260	15000		0	0	0	0	0	0	0	221	22500	0	0	
D40C	TNGT	6803	7260	15000	0	0	0	0	0	0	0	166	22500	0	0	
D40D		7105	15000		0	0	0	0	0	0	0	166	22500	0	0	
D40D	TNGT	6803	7105	15000	0	0	0	0	0	0	0	190	22500	0	0	
D40E		6951	15000		0	0	0	0	0	0	0	190	22500	0	0	
D40E	TNGT	6803	6951	15000	0	0	0	0	0	0	0	274	22500	0	0	
D45		7688	15000		0	0	0	0	0	0	0	0	274	22500	0	0
D45	TNGT	6803	7688	15000	0	0	0	0	0	0	0	378	22500	0	0	
D45A		6961	15000		0	0	0	0	0	0	0	0	274	22500	0	0
D45A	TNGT	6803	6961	15000	0	0	0	0	0	0	0	378	22500	0	0	
D45B		7085	15000		0	0	0	0	0	0	0	0	378	22500	0	0
D45B	TNGT	6803	7085	15000	0	0	0	0	0	0	0	492	22500	0	0	
D45C		7232	15000		0	0	0	0	0	0	0	612	22500	0	0	
D45C	TNGT	6803	7232	15000	0	0	0	0	0	0	0	492	22500	0	0	
D45D		7089	15000		0	0	0	0	0	0	0	612	22500	0	0	
D45D	TNGT	6803	7089	15000	0	0	0	0	0	0	0	733	22500	0	0	
D45E		6954	15000		0	0	0	0	0	0	0	0	733	22500	0	0
D45E	TNGT	6803	6954	15000	0	0	0	0	0	0	0	856	22500	0	0	
D50		7677	15000		0	0	0	0	0	0	0	0	980	22500	0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
App. 2, p. 113

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD			LEVEL B EQN 12			LEVEL C EQN 12			LEVEL D EQN 12			THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	CALC PSI	ALLOW PSI	PD/4T PSI	CALC PSI	ALLOW PSI	PD/4T PSI	CALC PSI	ALLOW PSI	PD/4T PSI	CALC PSI	ALLOW PSI	EQNS CALC PSI	13/14 CALC PSI	ALLOW PSI	EQN *** CALC PSI	ALLOW PSI	
D50 D50A	TNGT	6803 6929	7677 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	980 1084	22500 22500	0 0	0 0		
D50A D50B	TNGT	6803 7200	6929 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1084 1189	22500 22500	0 0	0 0		
D50B D50C	TNGT	6803 7486	7200 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1189 1296	22500 22500	0 0	0 0		
D50C D50D	TNGT	6803 7540	7486 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1296 1403	22500 22500	0 0	0 0		
D50D D50E	TNGT	6803 7363	7540 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1403 1511	22500 22500	0 0	0 0		
D50E D55	TNGT	6803 6956	7363 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1511 1619	22500 22500	0 0	0 0		
D55 D60	TNGT	6803 7090	6956 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1619 1697	22500 22500	0 0	0 0		
D60 D65 B	TNGT	6803 7069	7090 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1697 1706	22500 22500	0 0	0 0		
D65 B D65 M	BEND	6803 7135	7273 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	4019 4039	22500 22500	0 0	0 0		
D65 M D65 E	BEND	6803 7114	7135 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	4039 3878	22500 22500	0 0	0 0		
D65 E D65 A	TNGT	6803 6978	6979 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1646 1566	22500 22500	0 0	0 0		
D65 A D70	TNGT	6803 6974	6978 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1566 1486	22500 22500	0 0	0 0		
D70 D70A	TNGT	6803 7173	6974 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1486 1291	22500 22500	0 0	0 0		
D70A D70B	TNGT	6803 7296	7173 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1291 1095	22500 22500	0 0	0 0		
D70B D70C	TNGT	6803 7239	7296 15000	15000	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1095 900	22500 22500	0 0	0 0		

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
App. 2, p. 114

## CODE B31S73

ELEMENT FROM TO	TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
D70C D75	TNGT	6803	7239 7026	15000 15000	0	0	0	0	0	0	0	900 704	22500 22500	0	0
D75 D75A	TNGT	6803	7026 7203	15000 15000	0	0	0	0	0	0	0	704 473	22500 22500	0	0
D75A D75B	TNGT	6803	7203 7154	15000 15000	0	0	0	0	0	0	0	473 242	22500 22500	0	0
D75B D80	TNGT	6803	7154 6975	15000 15000	0	0	0	0	0	0	0	242 13	22500 22500	0	0
D80 D85 B	TNGT	6803	6975 6980	15000 15000	0	0	0	0	0	0	0	13 97	22500 22500	0	0
D85 B D85 M	BEND	6803	7115 7119	15000 15000	0	0	0	0	0	0	0	228 475	22500 22500	0	0
D85 M D85 E	BEND	6803	7119 7077	15000 15000	0	0	0	0	0	0	0	475 665	22500 22500	0	0
D85 E D90	TNGT	6803	6958 7035	15000 15000	0	0	0	0	0	0	0	282 587	22500 22500	0	0
D90 D95	TNGT	6803	6980 7168	15000 15000	0	0	0	0	0	0	0	529 357	22500 22500	0	0
D95 D96	TNGT	6803	7168 7391	15000 15000	0	0	0	0	0	0	0	357 520	22500 22500	0	0
D96 DSV	TNGT	6803	7391 7452	15000 15000	0	0	0	0	0	0	0	520 542	22500 22500	0	0
DSV D97	TNGT	5866	5957 6002	15000 15000	0	0	0	0	0	0	0	76 89	22500 22500	0	0
D97 MS4	TNGT	5866	6880 5866	15000 15000	0	0	0	0	0	0	0	8 0	22500 22500	0	0
D97 GD1	TNGT	4198	4446 4846	15000 15000	0	0	0	0	0	0	0	163 173	22500 22500	0	0
GD1 CV4	TNGT	4198	4953 4198	15000 15000	0	0	0	0	0	0	0	0 0	22500 22500	0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
4/11/2002 p. 115

## CODE B31S73

ELEMENT FROM TO	TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION				NON-REPEATED ANCHOR MOV	
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
GD1	TNGT	5421	5731 5742	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	447 473	22500 22500	0 0	0 0
GD1A															
GD1A	TNGT	5421	5742 5756	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	473 522	22500 22500	0 0	0 0
GD1B															
GD1B	TNGT	5421	5756 5771	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	522 589	22500 22500	0 0	0 0
GD2 B	BEND	5421	5956 5783	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1200 1264	22500 22500	0 0	0 0
GD2 M															
GD2 M	BEND	5421	5783 5583	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1264 1282	22500 22500	0 0	0 0
GD2 E															
GD2 E	TNGT	5421	5527 5886	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	629 621	22500 22500	0 0	0 0
GD2A															
GD2A	TNGT	5421	5886 6134	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	621 615	22500 22500	0 0	0 0
GD2B															
GD2B	TNGT	5421	6134 6229	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	615 614	22500 22500	0 0	0 0
GD2C															
GD2C	TNGT	5421	6229 6171	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	614 615	22500 22500	0 0	0 0
GD2D															
GD2D	TNGT	5421	6171 5959	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	615 621	22500 22500	0 0	0 0
GD2E															
GD2E	TNGT	5421	5959 5593	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	621 630	22500 22500	0 0	0 0
GD4 R															
GD4 M	BEND	5421	5685 5548	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1283 1284	22500 22500	0 0	0 0
GD4 M															
GD4 E	BEND	5421	5548 5713	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	1284 1271	22500 22500	0 0	0 0
GD4 E															
GD4 A	TNGT	5421	5612 5598	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	624 617	22500 22500	0 0	0 0
GD4 A															
GD4B	TNGT	5421	5598 5588	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	617 632	22500 22500	0 0	0 0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R1  
App. 2, P. 11b

## CODE B31S73

ELEMENT FROM TO	TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN *** CALC PSI	ALLOW PSI
GD4B	TNGT	5421	5588	15000	0	0	0	0	0	0	0	632	22500	0	0
GD4C			5582	15000	0	0	0	0	0	0	0	666	22500	0	0
GD4C	TNGT	5421	5582	15000	0	0	0	0	0	0	0	666	22500	0	0
GD4D			5582	15000	0	0	0	0	0	0	0	717	22500	0	0
GD4D	TNGT	5421	5582	15000	0	0	0	0	0	0	0	717	22500	0	0
GD4E			5587	15000	0	0	0	0	0	0	0	781	22500	0	0
GD4E	TNGT	5421	5587	15000	0	0	0	0	0	0	0	781	22500	0	0
GD4F			5597	15000	0	0	0	0	0	0	0	856	22500	0	0
GD4F	TNGT	5421	5597	15000	0	0	0	0	0	0	0	856	22500	0	0
GD4G			5611	15000	0	0	0	0	0	0	0	939	22500	0	0
GD4G	TNGT	5421	5611	15000	0	0	0	0	0	0	0	939	22500	0	0
GD5_B	BEND	5421	5611	15000	0	0	0	0	0	0	0	1028	22500	0	0
GD5_B			5628	15000	0	0	0	0	0	0	0	1028	22500	0	0
GD5_M	BEND	5421	5835	15000	0	0	0	0	0	0	0	2746	22500	0	0
GD5_M			5641	15000	0	0	0	0	0	0	0	2837	22500	0	0
GD5_E	BEND	5421	5641	15000	0	0	0	0	0	0	0	2837	22500	0	0
GD5_E			7088	15000	0	0	0	0	0	0	0	2915	22500	0	0
GD5_E	TNGT	5421	6253	15000	0	0	0	0	0	0	0	1092	22500	0	0
GD6			6557	15000	0	0	0	0	0	0	0	1099	22500	0	0
A90	TNGT	4383	4585	15000	0	0	0	0	0	0	0	321	22500	0	0
105_B			4564	15000	0	0	0	0	0	0	0	202	22500	0	0
105_B	BEND	4383	4625	15000	0	0	0	0	0	0	0	360	22500	0	0
105_M			4584	15000	0	0	0	0	0	0	0	319	22500	0	0
105_M	BEND	4383	4584	15000	0	0	0	0	0	0	0	319	22500	0	0
105_E			4551	15000	0	0	0	0	0	0	0	296	22500	0	0
105_E	TNGT	4383	4509	15000	0	0	0	0	0	0	0	166	22500	0	0
105A			4888	15000	0	0	0	0	0	0	0	157	22500	0	0
105A	TNGT	4383	4888	15000	0	0	0	0	0	0	0	157	22500	0	0
110			5507	15000	0	0	0	0	0	0	0	154	22500	0	0
110	TNGT	4383	5507	15000	0	0	0	0	0	0	0	166	22500	0	0
110A			4857	15000	0	0	0	0	0	0	0	154	22500	0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
Ann. 2, p. 117

## CODE B31S73

ELEMENT FROM TO	TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	13/14 CALC PSI	13/14 ALLOW PSI	EQN *** CALC PSI	13/14 ALLOW PSI	
110A 115	TNGT	4383	4857	15000	0	0	0	0	0	0	0	166	22500	0	0
			4585	15000		0	0	0	0	0	0	224	22500	0	0
115	TNGT	4534	5110	15000	0	0	0	0	0	0	0	112	22500	0	0
115A			4872	15000		0	0	0	0	0	0	56	22500	0	0
115A 115B	TNGT	4534	4872	15000	0	0	0	0	0	0	0	56	22500	0	0
			4721	15000		0	0	0	0	0	0	36	22500	0	0
115B 120	TNGT	4534	4721	15000	0	0	0	0	0	0	0	36	22500	0	0
			5536	15000		0	0	0	0	0	0	22	22500	0	0
120	TNGT	4534	5536	15000	0	0	0	0	0	0	0	22	22500	0	0
120A			4920	15000		0	0	0	0	0	0	24	22500	0	0
120A 120B	TNGT	4534	4920	15000	0	0	0	0	0	0	0	24	22500	0	0
			4613	15000		0	0	0	0	0	0	39	22500	0	0
120B 120C	TNGT	4534	4613	15000	0	0	0	0	0	0	0	39	22500	0	0
			4598	15000		0	0	0	0	0	0	58	22500	0	0
120C 125	TNGT	4534	4598	15000	0	0	0	0	0	0	0	58	22500	0	0
			5604	15000		0	0	0	0	0	0	464	22500	0	0
125	TNGT	4534	5604	15000	0	0	0	0	0	0	0	464	22500	0	0
130 R			4618	15000		0	0	0	0	0	0	89	22500	0	0
130 B 130 M	BEND	4534	4649	15000	0	0	0	0	0	0	0	163	22500	0	0
			4755	15000		0	0	0	0	0	0	173	22500	0	0
130 M 130 E	BEND	4534	4755	15000	0	0	0	0	0	0	0	173	22500	0	0
			4807	15000		0	0	0	0	0	0	175	22500	0	0
130 E 133 B	TNGT	4534	4734	15000	0	0	0	0	0	0	0	96	22500	0	0
			4742	15000		0	0	0	0	0	0	96	22500	0	0
133 B 133 M	BEND	4534	4905	15000	0	0	0	0	0	0	0	229	22500	0	0
			4910	15000		0	0	0	0	0	0	225	22500	0	0
133 M 135	BEND	4534	4910	15000	0	0	0	0	0	0	0	225	22500	0	0
			4899	15000		0	0	0	0	0	0	215	22500	0	0
135	TNGT	4534	4738	15000	0	0	0	0	0	0	0	90	22500	0	0
140			4738	15000		0	0	0	0	0	0	89	22500	0	0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
AM. 2, P. 118

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN *** CALC PSI	*** ALLOW PSI
140 144	TNGT	4534	4738 4740	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	89 86	22500 22500	0 0	0 0
144 145	TNGT	4534	4740 5327	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	86 77	22500 22500	0 0	0 0
145 146	TNGT	4534	5327 5960	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	77 151	22500 22500	0 0	0 0
146 147	TNGT	4534	5960 5211	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	151 134	22500 22500	0 0	0 0
147 150	TNGT	4534	5211 5192	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	134 132	22500 22500	0 0	0 0
150 155 M	BEND	4534	5711 5649	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	316 307	22500 22500	0 0	0 0
155 M 155 E	BEND	4534	5649 5600	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	307 301	22500 22500	0 0	0 0
155 E 160 B	TNGT	4534	5130 5052	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	126 115	22500 22500	0 0	0 0
160 B 160 M	BEND	4534	5241 5237	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	209 203	22500 22500	0 0	0 0
160 M 160 E	BEND	4534	5237 5241	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	203 193	22500 22500	0 0	0 0
160 E 165	TNGT	4534	5051 5112	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	106 88	22500 22500	0 0	0 0
165 165A	TNGT	4534	5112 4847	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	88 50	22500 22500	0 0	0 0
165A 165B	TNGT	4534	4847 5388	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	50 21	22500 22500	0 0	0 0
165B 165C	TNGT	4534	5388 5579	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	21 38	22500 22500	0 0	0 0
165C 170	TNGT	4534	5579 5505	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	38 108	22500 22500	0 0	0 0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
AM-2, p. 119

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION				NON-REPEATED ANCHOR MOV		
		PD/4T PSI	EQN CALC PSI	EQN 11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	LEVEL B EQN 12 ALLOW PSI	LEVEL C EQN CALC PSI	LEVEL C EQN 12 ALLOW PSI	LEVEL D EQN CALC PSI	LEVEL D EQN 12 ALLOW PSI	EQNS CALC PSI	13/14 CALC PSI	ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
170 175	TNGT	4534	5527 5554	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	110 130	22500 22500	0 0	0 0	
175 180	TNGT	4383	6496 4683	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	270 96	22500 22500	0 0	0 0	
180 230 B	TNGT	4383	4683 4622	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	96 98	22500 22500	0 0	0 0	
230 B 230 M	BEND	4383	4702 4722	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	175 191	22500 22500	0 0	0 0	
230 M 230 E	BEND	4383	4722 4728	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	191 211	22500 22500	0 0	0 0	
230 E 230 A	TNGT	4383	4641 4667	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	119 139	22500 22500	0 0	0 0	
230 A 235 B	TNGT	4383	4667 4848	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	139 161	22500 22500	0 0	0 0	
235 B 235 M	BEND	4383	5005 5189	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	287 306	22500 22500	0 0	0 0	
235 M 235 E	BEND	4383	5189 5271	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	306 311	22500 22500	0 0	0 0	
235 E D90	TNGT	4383	5047 5097	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	175 266	22500 22500	0 0	0 0	
115 240	TNGT	4534	5055 5249	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	138 149	22500 22500	0 0	0 0	
240 240 A	TNGT	4383	5865 5121	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	309 89	22500 22500	0 0	0 0	
240 A 245 B	TNGT	4383	5121 4573	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	89 129	22500 22500	0 0	0 0	
245 B 245 M	BEND	4383	4637 4433	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	229 268	22500 22500	0 0	0 0	
245 M 245 E	BEND	4383	4433 4746	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	268 282	22500 22500	0 0	0 0	

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R-1  
A1P.2, A. 120

## CODE B31S73

ELEMENT FROM TO	ELEMENT TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION				NON-REPEATED ANCHOR MOV	
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 ALLOW PSI	EQN CALC PSI	*** ALLOW PSI
245 250	E TNGT	4383	4654 5035	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	158 154	22500 22500	0 0	0 0
250 255 B	TNGT	4383	5035 4752	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	154 141	22500 22500	0 0	0 0
255 B 255 M	BEND	4383	4876 4881	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	251 236	22500 22500	0 0	0 0
255 M 255 E	BEND	4383	4881 4905	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	236 213	22500 22500	0 0	0 0
255 E C90	TNGT	4383	4774 4823	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	120 171	22500 22500	0 0	0 0
170 170A	TNGT	4383	4515 4529	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	211 169	22500 22500	0 0	0 0
170A 170B	TNGT	4383	4529 4451	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	169 178	22500 22500	0 0	0 0
170B 260 B	TNGT	4383	4451 4766	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	178 205	22500 22500	0 0	0 0
260 B 260 M	BEND	4383	4895 5118	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	365 388	22500 22500	0 0	0 0
260 M 260 E	BEND	4383	5118 5227	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	388 415	22500 22500	0 0	0 0
260 E B90	TNGT	4383	5015 5096	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	233 384	22500 22500	0 0	0 0
B97 S01	TNGT	5866	6107 6442	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	202 183	22500 22500	0 0	0 0
S01 A97	TNGT	5866	6442 6806	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	183 167	22500 22500	0 0	0 0
C97 MS2	TNGT	5866	6193 7083	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	180 172	22500 22500	0 0	0 0
MS2 B97	TNGT	5866	7083 6123	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	172 165	22500 22500	0 0	0 0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED  
 \*\* EXCEEDED ALLOWABLE

Calc. 1-1 R.1  
App. 2, p. 121

## CODE B31S73

ELEMENT FROM TO	TYPE TITLE	SUSTAINED LOAD				OCCASIONAL LOAD				THERMAL EXPANSION			NON-REPEATED ANCHOR MOV			
		PD/4T PSI	EQN CALC PSI	11 ALLOW PSI	PD/4T PSI	LEVEL B EQN CALC PSI	12 ALLOW PSI	LEVEL C EQN CALC PSI	12 ALLOW PSI	LEVEL D EQN CALC PSI	12 ALLOW PSI	EQNS CALC PSI	13/14 CALC PSI	ALLOW PSI	EQN *** CALC PSI	ALLOW PSI
D97 S00	TNGT	5866	6843 6519	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	29 30	22500 22500	0 0	0 0	0 0
S00 C97	TNGT	5866	6519 6173	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	30 31	22500 22500	0 0	0 0	0 0
A07 AR5	TNGT	4753	4753 4753	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	22500 22500	0 0	0 0	0 0
B07 BR5	TNGT	4753	4753 4753	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	22500 22500	0 0	0 0	0 0
C07 CR5	TNGT	4753	4753 4753	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	22500 22500	0 0	0 0	0 0
D07 DR5	TNGT	4753	4753 4753	15000 15000	0	0 0	0 0	0 0	0 0	0 0	0 0	0 0	22500 22500	0 0	0 0	0 0

\* EXCEEDED ALLOWABLE IN EQUATION 13, EQUATION 14 USED

\*\* EXCEEDED ALLOWABLE

calc. 1-1 R.1  
app-2, p. 122

## ANALYSIS INPUT DATA

## PROJECT

JOB NO. 03-00525 PLANT DESIGN GROUP

SYSTEM U3 MAIN STEAM LINES O/C

CALC NO 1-1 ISO NO REV NO

CASES: WT02 THRM01

PIPING DATA	1	2	3	4
2) MATERIAL				
3) E (PSI)	.260+08	.260+08	.260+08	.260+08
4) PIPE OD (IN)	26.000	48.000	36.000	28.000
5) NOM WALL (IN)	.950	2.000	2.000	1.250
6) DESN PRES (PSI)	1115.000	1115.000	1115.000	1115.000
7) PEAK PRES (PSI)	1337.000	1337.000	1337.000	1337.000
8) TEMP (DEG-F)				
9) EXPAN (IN/100-FT)				
10) EXPAN (IN/IN)				
11) WT PIPE (LB/FT)	.000	.000	.000	.000
12) WT CONTNT (LB/FT)	.000	.000	.000	.000
13) WT INSUL (LB/FT)	.000	.000	.000	.000
14) WT MISC. (LB/FT)	284.000	284.000	284.000	389.000
15) TOTAL WT (LB/FT)	284.000	284.000	284.000	389.000

## VALVE DATA

- 1) VALVE SZ & NO
- 2) LENGTH (E-E) (IN)
- 3) OPR YOKE LEN (IN)
- 4) WT BODY (LB)
- 5) WT OPERATOR (LB)
- 6) WT CONTENTS (LB)
- 7) WT INSUL (LB)
- 8) TOTAL WT (LB)

## INPUT SOURCE DOCUMENTS

- 1) PIPING SPECIFICATION
- 2) VALVE DRAWINGS

NAME SIGNATURE DATE

PREPARED BY

REVIEWED BY

APPROVED BY

Calc. 1-1 Rev. 1  
App. 2, P. 123

## ANALYSIS INPUT DATA

## PROJECT

JOB NO. 03-00525 PLANT DESIGN GROUP

SYSTEM U3 MAIN STEAM LINES O/C

CALC NO 1-1 ISO NO REV NO

CASES: WT02 THRM01

## PIPING DATA

		5	6	7	8
2) MATERIAL					
3) E (PSI)	.260+08	.260+08	.260+08	.260+08	
4) PIPE OD (IN)	14.000	18.000	18.000	48.000	
5) NOM WALL (IN)	.750	.937	.937	2.000	
6) DESN PRES (PSI)	1115.000	1115.000	1115.000	1115.000	
7) PEAK PRES (PSI)	1337.000	1337.000	1337.000	1337.000	
8) TEMP (DEG-F)					
9) EXPAN (IN/100-FT)					
10) EXPAN (IN/IN)					
11) WT PIPE (LB/FT)	.000	.000	.000	.000	
12) WT CONTNT (LB/FT)	.000	.000	.000	.000	
13) WT INSUL (LB/FT)	.000	.000	.000	.000	
14) WT MISC. (LB/FT)	124.000	193.000	3621.000	.000	
15) TOTAL WT (LB/FT)	124.000	193.000	3621.000	.000	

## VALVE DATA

1) VALVE SZ & NO	
2) LENGTH (E-E) (IN)	
3) OPR YOKE LEN (IN)	
4) WT BODY (LB)	
5) WT OPERATOR (LB)	
6) WT CONTENTS (LB)	
7) WT INSUL (LB)	
8) TOTAL WT (LB)	

## INPUT SOURCE DOCUMENTS

- 1) PIPING SPECIFICATION
- 2) VALVE DRAWINGS

NAME SIGNATURE DATE

PREPARED BY

REVIEWED BY

APPROVED BY

Calc. 1-1 R-1  
App. 2, p. 124

## ANALYSIS INPUT DATA

## PROJECT

JOB NO. 03-00525 PLANT DESIGN GROUP  
 SYSTEM U3 MAIN STEAM LINES O/C  
 CALC NO 1-1 ISO NO REV NO

CASES: WT02 THRM01

PIPING DATA 9  
 2) MATERIAL  
 3) E (PSI) .260+08  
 4) PIPE OD (IN) 20.000  
 5) NOM WALL (IN) 1.000  
 6) DESN PRES (PSI) 1115.000  
 7) PEAK PRES (PSI) 1337.000  
 8) TEMP (DEG-F)  
 9) EXPAN (IN/100-FT)  
 10) EXPAN (IN/IN)  
 11) WT PIPE (LB/FT) .000  
 12) WT CONTNT (LB/FT) .000  
 13) WT INSUL (LB/FT) .000  
 14) WT MISC. (LB/FT) 209.000  
 15) TOTAL WT (LB/FT) 209.000

## VALVE DATA

- 1) VALVE SZ & NO
- 2) LENGTH (E-E) (IN)
- 3) OPR YOKE LEN (IN)
- 4) WT BODY (LB)
- 5) WT OPERATOR (LB)
- 6) WT CONTENTS (LB)
- 7) WT INSUL (LB)
- 8) TOTAL WT (LB)

## INPUT SOURCE DOCUMENTS

- 1) PIPING SPECIFICATION
- 2) VALVE DRAWINGS

NAME	SIGNATURE	DATE
------	-----------	------

PREPARED BY

REVIEWED BY

APPROVED BY

Calc. 1-1 R.  
 APP. 2, p. 125

ANSI-B31.1

## PROJECT

JOB NO. 03-00525 PLANT DESIGN GROUP  
 SYSTEM U3 MAIN STEAM LINES O/C  
 CALC NO 1-1 ISO NO REV NO

DESIGN CONDITION	LEVEL	LOCATION OF MAXIMUM END ELEMENT	MAXIMUM COMPUTED STRESS (PSI)	ALLOWABLE STRESS (PSI)	COMPUTED ALLOWABLE
SUSTAINED LOADS EQN. 11	B50	B45E B50	7864	15000	SH .524
THERMAL EXPANSION EQN. 13	D07	D06 D07	8334	22500	SA .370

## REFERENCE CALCULATIONS:

WEIGHT	SEISMIC-INERTIA PORTION	OTHERS
THERMAL EXP.	SEISMIC-ANCHOR MOVEMENT	
	DYNAMIC	

NAME	SIGNATURE	DATE
------	-----------	------

PREPARED BY

REVIEWED BY

APPROVED BY

ME101SA Version N2 stop on 09/26/03 at 02:24:48  
 ME101SA Version N2 run time .45 seconds

\* FOR Complete ME101 output,  
 See page 107 of APP-I microfiche  
 (Job 24236, dated 02/12/04)

Calc. 1-1 R-1  
 App. 2 P. 126 of  
 926

