

**ATTACHMENT 3**

**Peach Bottom Atomic Power Station  
Units 2 and 3  
Docket Nos. 50-277 and 50-278**

**License Amendment Request  
Response to Request for Additional Information**

**Alternative Source Term (AST)**

**PBAPS Calculation PS-049, Revision 2, "*Seismic Evaluation of  
Consoles 2(3)0C05A, 2(3)0C04A and 2(3)0C03 for Mod 955*"**



NUCLEAR ENGINEERING  
DEPARTMENT  
M-20599 Rev. 2/89  
DOCTYPE 061

# CALCULATION COVER SHEET

1. Calculation No. PS-049

Page 1 of 70 ~~78~~ <sup>70</sup> ~~60~~ <sup>72</sup>

2.  LGS  
 PBAPS

UNIT(S) 2 & 3

Attachment 1, Pg 1, 2 <sup>B</sup>

3. Initiating Document: Mod# 955

4. Responsible Branch:  
Computers Branch

5. Total No. of Sheets: 81 ~~270~~ <sup>70</sup> ~~70~~ <sup>A</sup>

6. Last Sheet No: Appendix 1, Pg 10

7.  Safety Related  
 Non-Safety Related

8. Description: Seismic Evaluation of Consoles 2(3)0C05A, 2(3)0C04A 1nd 2(3)0C03 for MOD. 955

9. System No: N/A 70 <sup>B</sup>

Structure: CONTROL RM/RADWASTE BLDG.

Component: 2(3)0C05A, 2(3)0C04A, 2(3)0C03

## RECORD OF REVISIONS

10. No.	11. Description of Revision	12. Vendor Calc.		13. Other Calcs Requiring Revision	14. Signatures		
		Number	Rev.		Preparer	Reviewer	Approver/Date
0	issue for use	19597-NM(C) PS-049	A	N/A	C.H. Chen M. Golarte	J. Howal W. Wang (IR)	NSM/8-8-90 11/10/90
*1	Added recorder and various misc. changes	19597-NM(C) PS-049	B	N/A	C.H. Chen M. Golarte	J. Howal	NSM/10-15-90 11/10/90
*2	Added computer trend recorder	N/A	N/A	N/A	A. G. M. G. G.	J. Howal	NSM/12/1/90
*Note: This copy includes the Rev 1 + Rev. 2 versions of this calculation as noted herein.							

15. Related Calc. Numbers	Provides info to:	N/A	16. Manual <input checked="" type="checkbox"/> Manual <input type="checkbox"/> Computer Computer program and version
	Receives info from:	N/A	
	Supersedes:	N/A	

	MAN. CALC.	COMP. CALC.	ATTRIBUTES *	REV. 0	REV. 1	REV. 2	REV. 3	REV. 4	REV. 5	REV. 8	REV. 7	
1.	X	X	SOURCES OF DATA & FORMULAE WERE REVIEWED AND VERIFIED TO BE CORRECT AND COMPLETE.	JK	FIB MC	JRW						
2.	X	X	INPUT DATA FROM SOURCES IN ITEM 1, ABOVE, IS CORRECT AND PROPERLY EMPLOYED IN THE CALC.	JK	FIB MC	JRW						
3.	X	X	CALCULATION ASSUMPTIONS WERE REVIEWED AND FOUND TO BE COMPLETE AND VALID.	JK	FIB MC	JRW						
4.	X		THE ANALYTICAL METHOD EMPLOYED IN THE CALC. HAS BEEN CONSIDERED AND IS PROPER FOR THE INTENDED USE OF THE CALCULATION.	JK	FIB MC	JRW						
5.	X		MATHEMATICAL ACCURACY HAS BEEN CHECKED AND IS CORRECT (INDICATE METHOD USED): a) COMPLETE CHECK OF EACH COMPUTATION b) SPOT-CHECK OF SELECTED COMPUTATIONS WHICH ARE INITIALED IN THE CALCULATION c) PERFORMANCE OF ALTERNATE OR APPROXIMATION CALCULATION PER ERDP 39 CALC. IS ATTACHED.	JK	FIB MC	N/A						
					N/A	N/A						
					N/A	N/A						
6.	X	X	CALCULATION RESULTS WERE CHECKED AGAINST APPLICABLE, DOCUMENTED DESIGN CRITERIA AND FOUND TO BE IN CONFORMANCE.	JK	N/A	N/A						
7.	X	X	EXISTING CALCULATION WHICH REQUIRE REVISION BECAUSE OF THIS CALCULATION HAVE BEEN IDENTIFIED.	N/A	FIB MC	JRW						
8.		X	THE ANALYTICAL METHOD DESCRIBED IN THE COMPUTER CALCULATION SUMMARY IS PROPER FOR THE INTENDED USE OF THE CALCULATION.	N/A	N/A	N/A						
9.		X	COMPUTATIONAL ACCURACY HAS BEEN CHECKED AND FOUND CORRECT (INDICATE METHOD USED): a) CHECK SAMPLE CALC. USING DATA OTHER THAN USED IN SAMPLE. b) PERFORMANCE OF ALTERNATE OR APPROXIMATE CALCULATION PER ERDP 39 CALC. IS ATTACHED. c) DESCRIBE OTHER METHOD IF 9.A OR 9.B IS NOT USED.		N/A	N/A						
					N/A	N/A						
					N/A	N/A						
10.		X	OUTPUT IS REASONABLE CONSIDERING THE INPUT.	JK	FIB MC	N/A						

SWEC QA ACCEPTED  
COMPUTER PROGRAM

\* THESE ARE THE MINIMUM ATTRIBUTES AND ARE NOT INTENDED TO LIMIT THE INITIATIVE OF THE CHECKER TO REVIEW OTHER ATTRIBUTES. ATTRIBUTES APPLICABLE TO MANUAL AND COMPUTER CALCULATIONS ARE NOTED BY AN (X) IN THE APPROPRIATE COLUMN. FOR CHECKING OF REVISIONS TO MANUAL CALCULATIONS, THE ATTRIBUTES MAY BE LIMITED TO ONLY REVISED PORTIONS OF THE CALCULATION. CHECKER SHALL INITIAL EACH ATTRIBUTE COMPLETED.

19507-NM(C)-PS-049

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION TITLE PAGE

CLIENT PROJECT PHILADELPHIA ELECTRIC CO. PEACH BOTTOM ATOMIC POWER STATION - UNIT				PAGE 3 OF 70 78   A 60   2			
CALCULATION TITLE (Indicative of the Objective): Seismic Evaluation of Consoles 2(3)0005A 2(3)0004A and 2(3)0003 for MOD 955						QA CATEGORY (A) ✓ I - NUCLEAR SAFETY RELATED _ II _ III _ OTHER	
CALCULATION IDENTIFICATION NUMBER						OPTIONAL WORK PACKAGE NO.	
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE		WORK PACKAGE NO.		
19597	NM(C)	PS-049	N/A		N/A		
* APPROVALS SIGNATURE & DATE <i>Intind motiwala 8/8/90</i>				REV. NO. OR NEW CALC. NO.	SUPERSEDE *CALC. NO OR REV. NO	CONFIRM *REQD (A) YES NO	
PREPARER(S) / DATE(S)	REVIEWER(S) / DATE(S)	INDEPENDENT REVIEWER(S) / DATE(S)					
<i>C H Chen C H Chen 8/2/90 Pages 1 ~ 54 N A Goldstein N A Goldstein 8/2/90 pages 55 - 60 Appendix 1 - pgs 1-10</i>	<i>J Kowal L. KOWAL 8-8-90</i>	<i>W. WANG J Kowal 8/8/90</i>		A	N/A	✓	
<i>C H Chen C H Chen 10/15/90 Pages 1 ~ 54 Attachment 1 N A Goldstein N A Goldstein 10/15/90 Pages 55 ~ 60 Appendix 1: pgs 1-10</i>	<i>J Kowal L. KOWAL 10-15-90</i>	<i>J Kowal L. KOWAL 10-15-90</i>		B		✓	
APPROVED BY: <i>Intind motiwala 10/15/90</i>							
<i>F. Z. McCrossin 12/4/90 (PECO)</i>	N/A	<i>J Kowal 12/4/90</i>		2	N/A	✓	
DISTRIBUTION *							
GROUP	NAME & LOCATION	COPY	GROUP	NAME & LOCATION	COPY		
RECORD MGMT. FILES / FIRE FILE IF NONE	BOSTON 245/02						
PROJECT FILE	CHOC						

CALCULATION SHEET

5010.65

1a

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049	N/A	4

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

Table of Contents

	page
PECo Title Page	1-2
SWEC Title Page	3
Table of Contents	4, 4a <sup>A</sup>
Revision Status Table	5
1.0 Introduction	6
2.0 Objective	10
3.0 Design Input	11
4.0 References	34
5.0 Conclusions	35
6.0 Qualification of Modification (MOD) 955 Supports/Braces	36
6.1 Method	36
6.2 Analysis	38
6.2.1 Qualification of Support for 13 in. RWM CRT	38
6.2.2 Qualification of Panel Switch Support	48
6.2.3 Qualification of Supports for Digital Displays with Associated Electronics (Console 05A)	49
6.2.4 Support for RWM Cable Connectors	51
6.2.5 Supports for Power Supplies (Console 05A) Supports for Electronics Boxes and Power Supplies (Consoles 04A and 03)	51
6.2.6 Comparison of Calculated Stresses with Allowable Stresses	52
6.2.7 Deviation of Support Design for 13 in. RWM CRT for Unit 2 Console 20C05A	52a, 52b, 52c <sup>B</sup>
6.2.8 Qualification of support for 6"x6" tracor westronics multipens recorder	52d, 52e
6.2.9 Qualification of support for new 6"x6" computer trend recorder	52d, 52f, 52g <sup>2</sup>
7.0 Assessment of the Impact of the Modification on the Existing Q Consoles and Q Devices	53

**CALCULATION SHEET**





5010.65

1b

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	4a

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

Table of Contents

	page
8.0 Assessment of the Impact of Non Q Devices on the Q Devices and Consoles and Recommendation for any Modification if Required (for console 05A only).	55
9.0 Seismic Capability Limits of Existing Q Devices from SWEC/Vendor Data Bases (for console 05A only).	58
Appendix 1 Photographs of Walkdown	1-10
Attachment 1 Voided pages	1,2   
	<del>78</del>   
Total pages	<del>78</del>   
	81   

CALCULATION SHEET

5010.65

ct

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	5

Revision Status Table

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

Rev No	Page No.	Description/reason
A		Original issue - <i>Cover sheet Rev. 0 from 1/10/80</i>
		This revision is made to include the following changes:
B	52a 52b 52c	1. Deviation of support design for RWM CRT for unit 2 console 20C05A. This change is required due to space availability of unit 2 console.
	52d 52e	2. Addition of a modification--replacement of a Gemax 6"x6" computer trend recorder with a 6"x6" tracor westronics multipens recorder. This modification was not originally planed for installation during the upcoming outage.
	16 25	3. Material changes for bolts, nuts, washers and screws to accomodate vendor deviation request. Replace page 16 with a new page.
	58	4. Revise seismic capability limits of existing Q devices for clarification, and replace with revised page.
		Editorial changes related to the above revision are identified below:
	1, 2 3	Update page number.
	4	Update table of contents to include changes for items 1 & 2 above.
	4a	Update table of contents to include Attachment 1.
	6	Change note to read from "items 4 & 5" to "item 4".
	11	Add weight of tracor westronics multipens recorder.
	Atta. 1	
	1, 2	Attach voided pages 16 and 58 as Attachment 1 for record.
2		Revision 2 includes the following changes:
	6, 11 52d 52f 52g 54	1. Removal of the existing RWM operator interface and replacement with a new 6" x 6" computer trend recorder.
		Editorial changes related to revision 2 are identified below.
	1, 2, 3	Update page numbers.
	4&4a	Update table of contents.
	5	Update revision sheet.

## CALCULATION SHEET

5010.69

2

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	6

## 1.0 INTRODUCTION

PECo Nuclear Engineering Department intends to install additional devices on control room consoles 2(3)0C05A, 2(3)0C04A and 2(3)0C03 (hereafter referred to as 05A, 04A and 03) during the upcoming outage in October, 1990 (ref. 1). This installation is identified as modification (MOD) 955, which involves mounting of the following devices:

05A

1. Remove the existing computer trend Gemax recorder and install a new 13 in. Rod Worth Minimizer (RWM) CRT
2. Install a panel switch
3. Install two digital displays with associated electronics and power supplies.
4. Remove old RWM operator interface and install a 6"x6" computer trend recorder.
5. Remove Gemax 6"x6" computer trend recorder and replace with 6"x6" Tracor Westronics multipen recorder

Note: Items 4 and 5 will not be installed during the upcoming outage. Therefore, qualification of supports for these items will not be performed in this calculation.

04A

1. Install a digital display with its associated electronics and power supply.

03


1. Same as 04A

The locations of the above modifications are identified on the attached sketches (pages 7, 8 AND 9).









19597-NM(C)-PS-049



See reference 3 drawing

19597-NM(C)-PS-049

PANEL 03



8 3/8"

See reference 4 drawing

PANEL 04A

## CALCULATION SHEET

5010.85

3

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	10

1  
2  
3 The above modifications involve cutouts of the console panel  
4 to provide openings for mounting the devices, and attachment  
5 of the devices to console structural members, etc. Therefore,  
6 the impacts that may arise from the modifications need to be  
7 addressed, which are stated in the "Objective" section.  
8  
9

10 2.0 OBJECTIVE

11 The objectives of this calculation are:

- 12  
13  
14 1. To demonstrate the adequacy of MOD 955 supports/braces.  
15  
16 2. To address the impact of the modifications on the existing  
17 consoles and devices.  
18  
19 3. To assess the impact of non Q devices on the Q devices and  
20 consoles and provide resolution as necessary (for console  
21 05A only).  
22  
23 4. To provide seismic capability limits of existing Q devices  
24 from SWEC/Vendor data bases (for console 05A only).  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

CALCULATION SHEET

5010.65



16

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049	N/A	11

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

3.0 Design Input

Weight of Devices (provided by PECO)

Rod Worth Minimizer (RWM) CRT	35 lb	
Panel switch	5	
RWM cable connector	2	
Digital display	1	
Electronic box	2	
6"X6" Computer Trend Recorder	20	
Power supply	4	
Tracor westronics multipens recorder	20	

<u>Material</u>	Sy ksi	Su ksi	Ref.
A-569 sheet metal	25		*
Bolt, A-307	--	60	5
Stud, A-108 Gr. 1010 or 1018		40-60	**
Screw, A-193, Gr B7	105	125	5
Unistrut A-570, Gr 33	33	52	7


\* Metal Handbook, 8th ed. American Society for Metals  
 \*\* KSM Structural Eng. Aspects of Headed Concrete Anchor and Deformed Bar Anchors in the Concrete Construction Industry.

<u>Allowable Stresses, ksi</u>	Tensile	Shear	Ref.
A-569 sheet metal	0.6 Sy(15)	0.4 Sy(10)	6
Bolt, A-307	26 - 1.8 fv	20	6
Stud, A-108 Gr. 1010 or 1018	0.33 Su(13.2)	0.17 Su(6.8)	6
Screw, A-193, Gr B7	0.33 Su(41)	0.17 Su(21)	6
Unistrut A-570, Gr 33	0.6 Sy(19.8)	0.4 Sy(13.2)	6

Support Sketches

see attached sheets (pages 12 to 26--console 05A,  
 pages 27 to 29--console 04A,  
 pages 30 to 33--panel 03)





SECTION M-M


① 13" RWM CRT  
 ② Panel switch

NOTES:


ALL CONNECTIONS USING UNISTRUT BOLTS SHALL BE TORQUED TO THE FOLLOWING VALUES UNLESS OTHERWISE NOTED:

- 1/4" BOLT 6 FT-LB.
- 1/2" BOLT 50 FT-LB.

ITEM NUMBER	PART DISCRIPTION	CAT. NUMBER
①	HEX HEAD BOLT 1/2" X 1 3/16"	HHCS050119EG
②	1/2" WASHER	HFLW050EG
③	FLAT PLATE	P1064
④	1/2" SPRING NUT	P4010
⑤	1/2" NUT	HXXN050EG




DETAIL 1




NOTE: SNUG TIGHT FIRST NUT & TORQUE SECOND NUT TO 10 FT-LB.

DETAIL 2




NOTE: SNUG TIGHT FIRST NUT & TORQUE SECOND NUT TO 10 FT-LB.

DETAIL 3




DETAIL 4




SECTION N-N







*Cutout for 13" CRT and panel switch*



*Cutout for Digital Displays*



ROUTE 25011




THIS IDCN SUPERSEDES  
M-1-EE-124 SHEET 8  
IDCN "M"

INTERIM DRAWING CHANGE NOTICE					
STATION		UNIT			
PBAPS	LGS	C	1	2	3
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
PHILADELPHIA ELECTRIC COMPANY					
MOD	DRAWING	SHEET	REV.	IDCN	
955G	M-1-EE-124	8	59	W	
PRELIMINARY	DRAFT	MOD	MOD		
ISSUE <input type="checkbox"/>	ISSUE <input type="checkbox"/>	ISSUE <input type="checkbox"/>	ISSUE <input checked="" type="checkbox"/>		
DATE	DESIGN	CHKD.	APPR.	STRL.	


DESCRIPTION: 86150041 0239955  
 MOD 955G  
 ADDED: ASSEMBLY DETAIL FOR DEVICE  
 XIS-80193 & XIS-90193

XIS-80193 & XIS-90193 ASSEMBLY DETAIL




TRAY FRONT VIEW


TRAY RIGHT SIDE VIEW




TRAY TOP VIEW




TRAY REAR VIEW



TRAY LEFT SIDE VIEW




COLLAR SIDE VIEW




COLLAR FRONT VIEW





ENCLOSURE SIDE VIEW




ENCLOSURE REAR VIEW






ITEM NUMBER	PART DISCRIPTION	CAT. NUMBER
①	HEX HEAD BOLT 1/4" X 1 1/2" (TRIM TO 1" LENGTH)	HHCS025150EG
②	1/4" WASHER	HFLW02SEG
③	FLAT PLATE	P1062
④	1/4" SPRING NUT	P4006-1420

CONNECTION PER MANUFACTURER'S REQUIREMENTS



DETAIL 2




DETAIL 1


NOTES:

# ASSEMBLY DETAILS

ALL WELDING SHALL BE PER USING LOW HYDROGEN E-70X) ELECTRODE IN ACCORDANCE AWS D9-1 OR AWS D1-1 CODE




TRAY SIDE VIEW




TRAY TOP VIEW

④ Digital Displays & Electronics Boxes  
 Console 05A


# FABRICATION DETAILS



TRAY FRONT VIEW



TRAY SIDE VIEW



TRAY REAR VIEW

# ROUTE 25011

## INTERIM DRAWING CHANGE NOTICE

STATION		UNIT			
PBAPS	LGS	C	1	2	3
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

PHILADELPHIA ELECTRIC COMPANY


MOD	DRAWING	SHEET	REV.	IDCN
955G	M-1-EE-67	1	29	D

PRELIMINARY ISSUE	DRAFT MOD ISSUE	MOD ISSUE
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

DATE	DESIGN	CHKD.	APPR.	STRL.
------	--------	-------	-------	-------


OF 1

E.A. 8615.0041  
 REF. 0239955 MOD 955G  
 ADDED: SECTIONS E-E & F-F




19597-NM(C)-PS-049 page 27


CONSOLE 04A ( page 27 - 29 )




SECTION F-F



SECTION E-E




DETAIL 1



DETAIL 2

ROUTE 25011



PANEL 03 (pages 30 - 33)

INTERIM DRAWING NOTICE

UNIT C 1 2 3

PHILADELPHIA ELECTRIC COMPANY

MOD	DRAWING	SHEET	REV.	IDCN
955G	M-1-EE-100	4	60	J


PRELIMINARY ISSUE  DRAFT MOD ISSUE  MOD ISSUE

DATE	DESIGN	CHKD.	APPR.	STRL.
	CRK	YK	JL	


DESCRIPTION:  
 E.A. 8615.0041  
 REF. 0239955 MOD 955G  
 ADDED: SECTIONS P-P & Q-Q

PAGE 1 OF 1





② Electronics box  
 ③ power supply



1  
ROUTE 25011

NOTES:


1. ALL CONNECTIONS USING UNISTRUT BOLTS SHALL BE TORQUED TO THE FOLLOWING VALUES UNLESS OTHERWISE NOTED.

1/4" BOLT 6 FT-LB.

1/2" BOLT 50 FT-LB.


ITEM NUMBER	PART DISCRIPTION	CAT. NUMBER
①	HEX HEAD BOLT 1/4" X 1 1/2" (CUT TO 1" LENGTH)	HHCS025150EG
②	1/4" WASHER	HFLW02SEG
③	FLAT PLATE	P106Z
④	1/4" SPRING NUT	P4006-1420
⑤	HEX HEAD BOLT 1/4" X 3/4"	HHCS02507SEG
⑥	1/4" NUT	HHXN02SEG

CONNECTION PER MANUFACTURER'S REQUIREMENTS




NOTE: DRILL 5/16" HOLE IN P3300 STRUT FOR BOLT PLACEMENT

DETAIL 1




SECTION R-R



NOTE: DRILL 5/16" HOLE IN P3300 STRUT FOR BOLT PLACEMENT

DETAIL 2



DETAIL 4

## CALCULATION SHEET

5010.85

17

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049	N/A	34

## 4.0 References

1. TSD for Seismic Evaluation of Consoles 2(3)0C05A, 2(3)0C04A and 2(3)0C03 for MOD 955, Peach Bottom Atomic Power Station, Units 2 & 3. TSD no. P-0048.
2. PECO drawing 6280-M-1-EE-124(1), rev. 58. console 05A
3. PECO drawing 6280-M-1-EE-67, rev. 29. console 04A
4. PECO drawing 6280-M-1-EE-100, console 03
5. ASME Boiler and Pressure Vessel, Division 1, Section III, Appendix I, 1980
6. AISC-Manual of Steel Construction, 8th ed., 1980
7. Unistrut General Engineering Catalog No. 9, 1981
8. Final Safety Analysis Report. Vol. 1, Peach Bottom Atomic Power Station, Units 2 & 3.
9. Seismic Qualification of Class 1 Electrical Equipment, NEDO-10678,72NED81, Class 1, Nov. 1972, GE
10. General Project Requirements for Seismic Design and Analysis of Equipment and Equipment Supports for Peach Bottom Atomic Power Station, Units 2 & 3, PECO Spec. 11187-G-14.
11. Formulas for Stress and Strain, Roark and Young, 5th ed. McGraw-Hill.
12. Marks' Standard Handbook for Mechanical Engineers, 8th ed. McGraw-Hill.
13. Bechtel Corp letter to Philadelphia Electric Company, E.A.Patel to T.E.Shannon, "Contol Panel Anchorage Modification 2376," September 16, 1988, BLP 24646, Document Control No. 024749
14. General Electric Company Drawing No. 730E696, file no. 6280-M-I-EE-124-(2)-rev-59: annotated by PECO in three versions to highlight:
  - a. All Q-list items per QLAR #115
  - b. Equipment types and locations
  - c. Panel known modifications
15. General Electric Seismic Qualification Reevaluation Class 1E Equipment, Rev. 4, 4/11/86.

## CALCULATION SHEET

5010.65

24

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	35

1  
2  
3 5.0 Conclusions  
4

5 Based on the analysis and evaluation presented in this  
6 calculation, the following conclusions can be made:

- 7  
8 1. The mounting supports for the installation of new  
9 devices identified in MOD 955 are atructurally adequate  
10 to withstand earthquake loads.  
11  
12 2. The modifications to the consoles have been designed and  
13 proven to have no impact on the structural integrity of  
14 the consoles and the existing device qualifications.  
15  
16 3. Console 05A is concluded to have no unacceptable II/I  
17 interaction.  
18  
19 4. Seismic capability limits of existing Q devices on  
20 console 05A are tabulated in Section 9.0.  
21  
22 5. The support designs for the installation of new devices  
23 identified in MOD 955 are acceptable for units 2 and 3  
24 consoles. However, for unit 2 console modifications,  
25 constructibility shall be reviewed to ensure that  
26 sufficient spaces are available at the identified  
27 locations for the installation of the new devices.  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

## CALCULATION SHEET

5010.85

4

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	36

1  
2  
3 6.0 Qualification of MOD 955 Supports/Braces  
4

5 Support designs for MOD 955 proposed by PECO as stated in  
6 the previous section are shown on the attached  
7 sketches (section 3.0) in the order listed below:  
8

9 Console 05A

- 10  
11 1. 13 in. RWM CRT  
12  
13 2. Panel switch  
14  
15 3. RWM cable connector  
16  
17 4. Digital displays and associated electronics  
18  
19 5. Power supplies

20  
21 Console 04A

- 22  
23 1. Digital display  
24  
25 2. Electronics  
26  
27 3. Power supply  
28

29 Console 03

30  
31 Same as 04A  
32

33 6.1 Method  
34

35 In this section, conceptual designs for MOD 955 supports  
36 provided by PECO will be analyzed to the requirements of  
37 AISC (ref. 6) to ensure that they are structurally adequate  
38 to withstand seismic loads. In addition, these supports  
39 will also be verified to ensure that they are sufficiently  
40 rigid so that local modifications will not affect the nearby  
41 existing device qualifications.  
42

43 To this end, the frequencies of the local frames or  
44 mounting plates will be verified to show that they are in  
45 the rigid range of seismic response spectra.  
46

CALCULATION SHEET

5010.65

4a

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PM-049	N/A	37

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

Seismic Loads

Control room consoles are located at floor elevation 165 ft. in the Radwaste Building. For this analysis response spectra at elev. 165 ft. for maximum credible earthquake are used with a 2 % damping value for welded steel assemblies (ref. 8).

The appropriate acceleration values to be used depend on the frequency of the console to which the devices are mounted. The consoles are supplied by GE and are qualified with generic method as stated in reference 9. Based on this reference and the past experience with other operating plants, the consoles are most likely in the rigid range. However, for the evaluation of these modifications peak accelerations are used, since specific information regarding these consoles is not available.

$$\text{Horizontal } A = 1.32 \times 2.4 \times (1.5) = 4.75 \text{ g} \quad (\text{ref. 8,10})$$

$$\text{Vertical } A_v = (2/3) A = 3.2 \text{ g}$$

Supports are analyzed for seismic loads in N-S and vertical directions, and E-W and vertical directions. For each case, responses due to the horizontal and the vertical directions are added absolutely.

## CALCULATION SHEET

5010.65

5

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	38

1  
2  
3 6.2 Analysis  
4  
5 6.2.1 Qualification of support for 13 in. RWM CRT (see sketches on  
6 pages 12 to 22)  
7  
8 The configuration for CRT support is shown on the attached  
9 sketches. The CRT is enclosed in a can (box) which is  
10 mounted at the front panel and supported at the back by a  
11 support frame. For qualification of this support, the  
12 following three parts of analyses will be performed:  
13  
14 Frequency evaluation  
15 Support frame qualification  
16 CRT can and tray mounting qualification  
17  
18 Frequency evaluation  
19  
20 a. Weight of CRT and mounting devices  
21  
22 Tray: 12 gage sheet metal  $t = .1046$  in. (ref. 6)  
23  
24  $13 \times 14 = 182$  sq in.  
25  $2((1/2)(10 + 3) \times 13) = \frac{169}{351} \times .1046 \times .283 = 10.4$  lb  
26  
27  
28 Tray flange: 10 gage sheet metal  $t = .1345$  in. (ref. 6)  
29  
30  $2[1/2(18 - 13.75) \times 12.5] = 53$   
31  $14 \times 1 = \frac{14}{67} \times .1345 \times .283 = 2.6$  lb  
32  
33  
34 Can: 12 gage  
35  
36  $2 \times 16.75 \times (12.5 + 17.125) = 992.4$   
37  $\times .1046 \times .283 = 29.4$  lb  
38  
39 Can flange: 12 gage  
40  $12 \times 1 \times 2 = 24$   
41  $17.125 \times 1 = \frac{17}{41} \times .1046 \times .283 = 1.2$  lb  
42  
43  
44  
45  
46



CALCULATION SHEET

5010.85

6

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	39

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

Collar flange: 10 gage

$$\begin{aligned}
 12.5 \times 1.435 \times 2 &= 36 \\
 16 \times 1 &= 16 \\
 \hline
 52 \times .1345 \times .283 &= 2.0
 \end{aligned}$$

Total	45.6 lb
Weight of CRT	35 lb
Miscellaneous	9.4 lb
<b>Total</b>	<b>90 lb</b>

b. Frequency of supporting frame in X- direction

Consider that the total weight is equally distributed to the front panel and the unistrut frame.

$$W = 90/2 = 45 \text{ lb}$$

$$f = 1/(2\pi) \times \text{sqrt}[g/\Delta] \quad (\text{ref. 11})$$

$$\begin{aligned}
 \Delta &= wa^2b^3(3L+a)/(12EIL^3) \quad (\text{ref. 6}) \\
 &= .000733 \text{ in.}
 \end{aligned}$$

where

$$I = .181 \text{ for P3301 (ref. 7)}$$

$$E = 29000000. \text{ psi}$$

$$W = 45/2 = 22.5 \text{ lb}$$


$$L = 26 \text{ in.}$$

$$a = 10 \text{ in.}$$

$$b = 16 \text{ in.}$$

$$g = 386.4 \text{ in/sq sec.}$$

$$f = 115 \text{ Hz.}$$



## CALCULATION SHEET


5010.85

7

CALCULATION IDENTIFICATION NUMBER				PAGE 40
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	

c. Frequency of supporting frame in Z-direction  
(front-to-back)

The CRT is supported by the panel at the front and by the unistrut frame at the back. In the front-to-back direction, the front panel is braced with a box made of sheet metal, which is then connected to the frame. Thus, the front panel and the frame support unite together in resisting the motion in the Z-direction. For frequency estimation, however, the rigidity of the front panel will be totally neglected and the total weight will be conservatively attributed to the frame support and applied at a single point (not distributed +/- 3").



$$f = 1/(2 \pi) \times \text{sqrt} (g/\Delta)$$

$$\Delta = Wa^2 b^2 / (3EIL) = .001732 \text{ in}$$

where

$$W = 45 \text{ lb}$$

$$a = 10 \text{ in.}$$

$$b = 16 \text{ in.}$$

$$I = .294 \text{ in}^4$$

$$L = 26 \text{ in.}$$

$$f = 75 \text{ Hz.}$$

Noted that the flexibility of the cross piece has been neglected by virtue of the other conservatisms.

d. Frequency of supporting frame in the vertical direction

Based on the support configuration, the support is much stiffer in the vertical direction than in the horizontal directions, since the frame is stiff in the vertical direction, and is connected to an existing unistrut which is welded to the top panel. Thus, the frequency in the vertical direction is higher than that in the horizontal directions.

CALCULATION SHEET

5010.65

8

CALCULATION IDENTIFICATION NUMBER			
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE
19597	NM (C)	PS-049	N/A
			PAGE 41

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

Support Frame Qualification

a. Support loads

The vertical bench board and support frame are slanted 20 degrees from the vertical. Therefore, support loads in x, y and z directions will be converted into the directions in line with the supporting directions.

Dead weight  $W = 90 \text{ lb}$

$F_1 = W \sin 20 = 31 \text{ lb}$

$F_2 = W \cos 20 = 85 \text{ lb}$

Seismic loads

y-direction

$F_y = 90 \times 3.2 = 288 \text{ lb}$

$F_1 = 99 \text{ lb}$

$F_2 = 271 \text{ lb}$

z-direction

$F_z = 90 \times 4.75 = 427$


$F_1 = 427 \times \cos 20 = 401 \text{ lb}$

$F_2 = 427 \times \sin 20 = 146 \text{ lb}$

x-direction

$F_x = 90 \times 4.75 = 427 \text{ lb}$

$F_3 = 427 \text{ lb}$



Dead wt.+seismic load(x + y)

Dead wt.+seismic load(y + z)

$F_1 = 31+99 = 130 \text{ lb}$

$F_1 = 31+99+401 = 531 \text{ lb}$

$F_2 = 85+271 = 356$

$F_2 = 85+271+146 = 502$

$F_3 = 427$

$F_3 = 0$

CALCULATION SHEET

5010.66

9

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	42

b. Frame analysis due to dead wt. + seismic load(x +y)

The loads are considered equally distributed to the front panel and the support frame and then equally distributed to each of the two vertical members.

$F1 = 130/4 = 32.5 \text{ lb}$

$F2 = 356/4 = 89$

$F3 = 427/4 = 107$

Vertical member-- P3301 (ref. 7)

$A = .794 \text{ sq in.}$

$Z1 = .207 \text{ cu in.}$

$Z3 = .362 \text{ cu in.}$

$R1 = F1 \times 16/26 = 20 \text{ lb}$

$R2 = F2/2 = 44.5$

$R3 = F3 \times b^2 / (2L^3) \times (a + 2L)$   
 $= 48$

$M3 = R1 \times 10 = 200 \text{ in-lb}$


$M1 = R3 \times 10 = 480$

$R2/A = 56 \text{ psi}$

$M3/Z3 = 552$

$M1/Z1 = 2319$

Total = 2927 psi



Horizontal member--P3300 (ref. 7)

$A = .397 \text{ sq in.}$

$Z1 = .078 \text{ cu in.}$

$Z2 = .181 \text{ cu in.}$

$M1 = R2 \times 8.6 = 382.7 \text{ in-lb}$


$M2 = R1 \times 8.6 = 172$

$R3/A = 121 \text{ psi}$

$M1/Z1 = 4909$

$M2/Z2 = 950$

Total = 5980 psi



STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.85

10

CALCULATION IDENTIFICATION NUMBER			
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE
19597	NM (C)	PS-049	N/A

PAGE  
43

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

Brace member--P3300

A = .397 sq in.  
 Z1 = .078 cu in.  
 Z2 = .181 cu in.


P1 = 2(R1 sin 25 + R2 cos 25)  
 = 98 lb

P3 = 2(R1 cos 25 + R2 sin 25)  
 = 74 lb

M2 = P1 x 6 = 588 in-lb  
 M1 = 2R3 x 6 = 576

P3/A = 186 psi  
 M2/Z2 = 3249  
 M1/Z1 = 7385

Total = 10820 psi



**CALCULATION SHEET**

5010.85

11

CALCULATION IDENTIFICATION NUMBER			
JOB NUMBER 19597	DIVISION & GROUP NM (C)	CALCULATION NO. PS-049	OPTIONAL TASK CODE N/A
			PAGE 44

c. Frame analysis due to dead wt. + seismic load(y +z)

The loads are considered equally distributed to the front panel and the support frame and then equally distributed to each of the two vertical members.

$F1 = 531/4 = 133 \text{ lb}$

$F2 = 502/4 = 126$

$F3 = 0$

Vertical member-- P3301 (ref. 7)

$A = .794 \text{ sq in.}$

$Z1 = .207 \text{ cu in.}$

$Z3 = .362 \text{ cu in.}$

$R1 = F1 \times 16/26 = 82 \text{ lb}$

$R2 = F2/2 = 63$


$R3 = 0$

$M3 = R1 \times 10 = 820 \text{ in-lb}$

$R2/A = 79 \text{ psi}$

$M3/Z3 = 2265$

Total = 2344 psi



Horizontal member--P3300 (ref. 7)

$A = .397 \text{ sq in.}$

$Z1 = .078 \text{ cu in.}$

$Z2 = .181 \text{ cu in.}$

$M1 = R2 \times 8.6 = 542 \text{ in-lb}$


$M2 = R1 \times 8.6 = 705$

$R3/A = 0 \text{ psi}$

$M1/Z1 = 6949$

$M2/Z2 = 3895$

Total = 10844 psi



CALCULATION SHEET

5010.85

12

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	45

Brace member--P3300

A = .397 sq in.  
 Z1 = .078 cu in.  
 Z2 = .181 cu in.


$P1 = 2(R1 \sin 25 + R2 \cos 25)$   
 = 184 lb

$P3 = 2(R1 \cos 25 + R2 \sin 25)$   
 = 202 lb

$M2 = P1 \times 6 = 1104 \text{ in-lb}$

$P3/A = 509 \text{ psi}$   
 $M2/Z2 = 6099$

Total = 6608 psi



d. Unistrut Connections

The above analyses show that unistrut members are subjected to a maximum applied load of less than 150 lbs. The design load data for typical unistrut channel connections as shown in reference 7 are 1000 lbs or larger. Therefore, the connection parts used in the support designs are adequate.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

CALCULATION SHEET

5010.85

13

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	46

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

CRT can and tray qualification

The CRT is mounted to the bottom sheet metal of the tray by four screws. The tray is connected to two tracks, one on each side of the tray. The tracks are then mounted to the can which is mounted at the front panel and supported at the back by a frame. The detailed configuration is shown on the attached sketches.

a. CRT mounting

Weight of CRT = 35 lb

Dead wt + seismic load(y+z)                      Dead wt + seismic load(x+y)

* F1 = 206	* F1 = 50
F2 = 195	F2 = 138
	F3 = 166

CRT mounting screws: 4- 1/4" dia. screws

A = .0362 sq in. (ref. 12)

Tensile stress =  $F2/(4A) = 1347$  psi  
 Shear stress =  $(F1 + F3)/(4A) = 1492$  psi

\* These loads derived using same methodology found in the previous section.

Sheet metal bearing stress

12 gage, t = .1046 in.

Bearing stress =  $(F1 + F3)/(4td) = 2065$  psi

b. Tray mounting

Weight of tray = 10.4 + 2.6 = 13 lb  
 Weight of CRT = 35  
 Total 48 lb

Dead wt + seismic load(y+z)                      Dead wt + seismic load(x+y)

* F1 = 283	* F1 = 69
F2 = 268	F2 = 190
	F3 = 228



## CALCULATION SHEET

5010.85

14

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	47
19597	NM (C)	PS-049	N/A	

1  
2 Force F2 is resisted by the tracks, and force F1 is resisted  
3 by the tray flange which bears against the front panel.  
4 Force F3 does not induce any load to the connecting screws  
5 between the tray and the tracks, since both sides of the  
6 tray bear against the tracks.  
7  
8 Tray mounting screws: 6-#5 screws, A = .0082 sq in. (ref. 12)  
9  
10 shear stress =  $F2/(6A) = 5447$  psi  
11  
12 Track mounting screws: 8-1/4"-28 screws, A = .0362 sq in.  
13  
14 shear stress =  $(F2+F3)/(8A) = 1443$  psi  
15  
16 Tray flange: 10 gage, t = .1345 in.  
17  
18 Tray opening H = 13 3/4"  
19 Collar opening H = 15 1/8"  
20 Moment arm a =  $(15\ 1/8 - 13\ 3/4)/2 = .6875$  in.  
21  
22 M =  $F1 \times a / 2 = 97$  in-lb  
23 Z =  $1/6 (bt^2) = 1/6 \times [(10) (.1345)^2] = .03$  cu in.  
24 M/Z = 3243 psi  
25 Weld: 1/8" fillet weld on two vertical sides is adequate  
26  
27 c. Can mounting  
28  
29 Dead wt + seismic load(y+z)      Dead wt + seismic load(x+y)  
30  
31 F1 = 531 lb      F1 = 130 lb  
32 F2 = 502      F2 = 356  
33 F3 = 427  
34  
35 Connection between can and unistrut P3301  
36  
37 six 1/2" bolts: bolt strength is more than adequate.  
38  
39 Sheet metal bearing stress =  $[(F1+F2)/2]/(6td) = 1644$  psi  
40  
41 Connection between can, console pl. and collar flange  
42  
43 Twelve 1/4" studs: bolt strength is more than adequate.  
44  
45 Sheet metal bearing stress =  $[(F2+F3)/2]/(12td) = 1248$  psi  
46

## CALCULATION SHEET

5010.65

15

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	48

## 6.2.2 Qualification of Panel Switch Support

Panel switch is mounted to two brackets beneath the bottom sheet metal of the CRT can as shown on the attached sketches. The switch weighs 5 lb.

Frequency Evaluation

Moment of inertia of the brackets

$$I = 1/12 (2) (1/4)^3 = .0026$$

$$f = 1.732 / (2 \pi) \times \text{sqrt}[EIg / (WL^3)] = 413 \text{ Hz (ref. 11)}$$

where

$$L = 2.75/2 = 1.375 \text{ in.}$$

$$W = 5 \text{ lb}$$

Panel Switch Mounting

Dead + seismic load(y+z)      Dead + seismic load(x+y)

$$F1 = 30 \text{ lb}$$

$$F1 = 7 \text{ lb}$$

$$F2 = 28$$

$$F2 = 20$$

$$F3 = 24$$

Brackets

$$A = 1 \times .25 = .25 \text{ sq in}$$

$$Z = (1) (1/4)^2 / 6 = .0104 \text{ cu in.}$$

$$M = 30 \times 2.75/2 = 41.3 \text{ in-lb}$$

$$F2 / (2A) = 56 \text{ psi}$$

$$M / (2Z) = 1986$$

$$\text{Total} \quad 2042 \text{ psi}$$

Sheet metal

$$Z = (1) (.1046)^2 / 6 = .00182$$

$$M / (2Z) = 11346 \text{ psi}$$

Weld: 1/8" fillet weld on both sides of the brackets is adequate.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

18

CALCULATION IDENTIFICATION NUMBER				PAGE 49
JOB NUMBER 19597	DIVISION & GROUP NM (C)	CALCULATION NO. PS-049	OPTIONAL TASK CODE N/A	

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

6.2.3 Qualification of Support for Digital Displays with Associated Electronics (Console 05A)

This design provides support for two digital displays and two electronics boxes. The digital displays are mounted on a cover plate and the electronics are mounted on a tray which is welded to the cover plate as shown in the attached sketches.

Weight of tray

cover plate: 10 gage

$$6 \frac{7}{8} \times 9 \frac{1}{8} = 63 \text{ sq in.}$$

$$\times .1345 \times .283 = 2.4 \text{ lb}$$

sides	2(4 x 9 3/8) = 75	
bottom	6.75 x 9 3/8 = 63	
	<u>138</u>	x .1046 x .283 = 4.1

top tray	2(1.5 x 7) = 21	
	6.75 x 7 = 47	
	<u>68</u>	x .1046 x .283 = 2 lb


subtotal 9 lb

Digital displays  
2 x 1 = 2

Electronics  
2 x 2 = 4

Total 15 lb

Frequency Evaluation



$$y = 2(4 \times 2) / (8 + 6.75) = 1.08 \text{ in.}$$

$$I3 = 2[(4)^3 / 12] = 10.67$$

$$2(4)(.92)^2 = 6.77$$

$$6.75 \times (1.08)^2 = 7.87$$


$$\underline{25.31 \times .1046 = 2.65}$$

CALCULATION SHEET

5010.65

19

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	50
19597	NM (C)	PS-049	N/A	



$$W = 15 - 2 - 2.4 = 10.6 \text{ lb}$$

$$f = 1.732 / (2\pi) \times \text{sqrt}[EIG / (WL^3)] = 546 \text{ Hz}$$

Tray Mounting

Dead wt + seismic load(y+z)

Dead wt + seismic load(x+y)

$$F1 = 89 \text{ lb}$$

$$F1 = 22 \text{ lb}$$

$$F2 = 84$$

$$F2 = 59$$

$$F3 = 0$$

$$F3 = 71$$

Envelope load

$$F1 = 89 \text{ lb}$$

$$F2 = 84$$

$$F3 = 71$$

Mounting studs: four 1/4"-20 studs A = .0317 sq in.

Due to F2

$$M3 = 84 \times 6.2 = 521 \text{ in-lb}$$

$$T = M3 / [2(4 \ 7/8)] = 53 \text{ lb}$$

$$V = 84 / 4 = 21$$

Due to F1

$$T = 89 / 4 = 22$$

Due to F3

$$M2 = 71 \times 6.2 = 440 \text{ in-lb}$$

$$T = M2 / [2(7.125)] = 31$$

$$V = 71 / 4 = 18$$

Total

$$T = 53 + 22 + 31 = 106 \text{ lb}$$

$$V = 21 + 18 = 39$$

$$\text{Tensile stress} = T/A = 3344 \text{ psi}$$

$$\text{Shear stress} = V/A = 1230$$

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET


5010.65

20

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	51

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

Weld



$$A = 8$$

$$Z2 = 4 \times 6.75 = 27$$

$$Z3 = 16/3 = 5.33$$

$$f = \text{sqrt}[(F1/A + M2/Z2 + M3/Z3)^2 + (F2/A)^2 + (F3/A)^2]$$

$$= 126 \text{ lb per in}$$

$$w = f / (.707 \times 18000) = .01 \text{ in.}$$

1/8" fillet weld is adequate.

6.2.4 Support for RWM Cable Connectors

Two cable connectors have the same weight as a power supply. This support is acceptable by comparison of the support configuration with the support for the power supply on console 04A, which is qualified in the next section.

6.2.5 Support for Power Supplies (Console 05A)

Supports for Electronics Boxes and Power supplies (Consoles 04A and 03)

Power supplies on console 05A, and electronics boxes and power supplies on consoles 04A & 03 are mounted separately from the associated digital displays. These supports are similar in configuration. Review of the individual device weights and their mounting configurations as shown in the sketches concludes that the support for power supply on console 04A is the governing case which envelops the remaining cases.

Frequency Evaluation

Mounting plate: 12 gage

$$I = (1/12) (9) (.1046)^3 = .000858$$

Weight

plate	9x6.63x.1046x.283	= 1.8 lb
power supply		4
		<u>5.8 lb</u>

## CALCULATION SHEET

5010.65

21

CALCULATION IDENTIFICATION NUMBER			
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE
19597	NM (C)	PS-049	N/A

PAGE  
52

$$f = 1.732 / (2 \pi) \times \text{sqrt}[EIg / (WL^3)] \quad L = 6.63 / 2 = 3.32 \text{ in.}$$

$$= 59 \text{ Hz}$$

Plate stress

$$M = (5.8 \times 4.75) \times 3.32 = 91.5 \text{ in-lb}$$

Moment due to eccentricity (1") of the power supply

$$= (4 \times 3.2) (1) = 12.8$$

$$\text{Total} = 104.3$$

$$F = 5.8 \times 3.2 = 18.6 \text{ lb}$$

$$Z = I / (t/2) = .0164$$

$$A = 9 \times .1046 = .941 \text{ sq in}$$

$$M/Z = 6360 \text{ psi}$$

$$F/A = \frac{20}{6380} \text{ psi}$$

Note: The mounting plate has been revised from 12 gage to 11 gage as shown on the drawing. This change is on the conservative side, and therefore, is acceptable.

## 6.2.6 Comparison of Calculated Stresses with Allowable Stresses

The calculated stresses shown above for sheet metals, screws and bolts are much lower than the allowable stresses given in section 3.0. Therefore, these device mounting supports are acceptable.

CALCULATION SHEET

5010.65

26

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	52a


1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

6.2.7 Deviation of Support Design for 13 in. RWM CRT for unit 2 Console 20C05A

The RWM CRT support for unit 2 console deviates slightly from the same support for unit 3 console. This deviation includes the orientation of the brace member to the support frame (see attached support sketches), ie., (1) the connection of the brace with the existing horizontal P3301 strut is approximately 2 ft. (instead of 1 ft. 4 in. for unit 3) from the back vertical panel, (2) the cross-sectional orientation of the brace is 180 degrees opposite to the brace for unit 3 console. This deviation is necessary because of the space availability of unit 2 console.



Review of the CRT support qualification for unit 3 console concludes that a sufficient design margin exists to compensate for the negligible effect caused by the minor deviation described above. Therefore, the CRT support design for unit 2 console is acceptable.




SECTION M-M


ITEM NUMBER	PART DISCRIPTION	CAT. NUMBER
①	HEX HEAD BOLT 1/2" X 1 3/16"	HHCS050119EG
②	1/2" WASHER	HFLW050EG
③	FLAT PLATE	P1054
④	1/2" SPRING NUT	P4010
⑤	1/2" NUT	HHXN050EG
⑥	HEX HEAD BOLT 1/2" X 1 3/4"	HHCS050175EG
⑦	HEX HEAD BOLT 1/4" X 3/4"	HHCS025075EG
⑧	1/4" SPRING NUT	P4006-1420
⑨	1/4" WASHER	HFLW025EG

20C05A







DETAIL 1




DETAIL 2




SECTION N-N



DETAIL 3



DETAIL 4



DETAIL 5

19597-NM(C)-PS-049

page 52c

## CALCULATION SHEET

5010.85

27

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	52d

1  
2  
3 6.2.8 Qualification of support for 6"x6" tracor  
4 westronics multipens recorder

5  
6 This modification involves replacement of the  
7 existing 6"x6" computer trend recorder with 6"x6"  
8 tracor westronics multipens recorder. The  
9 existing recorder weighs approximately 40 lbs,  
10 while the new recorder weighs only 20 lbs. The  
11 new recorder is mounted at the front panel and  
12 supported at the back by a support frame as shown  
13 on the attached sketches. Thus, the new recorder is  
14 better supported than the old one before the  
15 modification. Therefore, this modification will  
16 not affect the adjacent device qualification.

17  
18 Judging from the sizes of the structural members  
19 and bolts, the support frame is structurally  
20 adequate to support the new recorder, which weighs  
21 only 20 lbs.


22 6.2.9 Qualification of support for 6" x 6" computer  
23 trend recorder

24  
25 This modification involves the replacement of the  
26 existing RWM operator interface with a non-Q 6"x6"  
27 computer trend recorder. The new recorder weighs 20  
28 lbs. and it is judged that the existing RWM weighs  
29 more than 20 lbs. since it is much larger in size.  
30 The cut out in the panel skin due to the RWM will be  
31 covered by an 11 gauge plate with mounting  
32 bolts/holes similar to the RWM installation. A  
33 smaller cut out in this 11 gauge plate will be made  
34 to accommodate the installation of the new trend  
35 recorder. The new recorder is mounted at the front  
36 of the panel and supported at the back by a support  
37 frame as shown on the sketches on pages 52f and 52g.  
38 Thus, the new recorder is better supported than the  
39 old one prior to this modification. Therefore, the  
40 installation of this computer trend recorder will not  
41 affect the adjacent device qualification.

42 Judging from the sizes of the structural  
43 members and bolts, the support frame is structurally  
44 adequate to support the new trend recorder, which  
45 weighs only 20 lbs.  
46


B

2




SECTION P-P

ITEM NUMBER	PART DISCIPTION	CAT. NUMBER
①	HEX HEAD BOLT 1/2" X 2 1/2"	HHCS050250EG
②	1/2" WASHER	HFLW050EG
③	FLAT PLATE	P1064
④	1/2" SPRING NUT	P4010
⑤	HEX HEAD BOLT 1/4" X 1 1/2"	HHCS025150EG
⑥	1/4" WASHER	HFLW025EG
⑦	1/4" SPRING NUT	P4006-1420
⑧	1/4" NUT	HHXN025EG




SECTION S-S

20C05A & 30C05A



DETAIL 4



DETAIL 5

B




NUCLEAR GROUP

CALCULATION SHEET

DOCTYPE:000

CALC NO PS-049 REV 2  
 PAGE 52F OF 60  
 ORIGINATOR J.M. Clark DATE 12-4-90  
 REVIEWER J.P. White DATE 12-4-90


20C05A & 30C05A



SECTION Q-Q


ITEM NUMBER	PART DESCRIPTION
①	HEX HEAD BOLT 1/2" X 1 1/2" A-307 *
②	1/2" SPRING NUT
③	FLAT PLATE P1064
④	HEX HEAD BOLT 1/4" X 1" A-307 *
⑤	1/4" SPRING NUT
⑥	1/4" NUT

\* BOLT LENGTH MAY BE TRIMMED AS REQ'D, PROVIDED FULL NUT ENGAGEMENT IS MAINTAINED.




NOTE: UNLESS OTHERWISE NOTED, ALL DIMENSIONS SHALL HAVE A TOLERANCE OF  $\pm 1/16"$

SECTION T-T



DETAIL 6



DETAIL 7

2





NUCLEAR GROUP

# CALCULATION SHEET

DOCTYPE:000

CALC NO PS-049 REV 2  
 PAGE 52 OF 60  
 ORIGINATOR J. McCann DATE 12-4-90  
 REVIEWER J. [Signature] DATE 12-4-90

## 20C05A & 30C05A





NOTE: UNLESS OTHERWISE NOTED, ALL DIMENSIONS SHALL HAVE A TOLERANCE OF  $\pm 1/16$ ".

### DETAIL F-8

Location of new computer trend recorder

Location RWM operator interface which is being removed.

2



### MOUNTING DETAIL XR-80188B & XR-90188B

## CALCULATION SHEET

5010.65

22

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	53

1  
2  
3 7.0 Assessment of the Impact of the Modification on the  
4 Existing Q Console and Q Devices

5  
6 MOD 955 involves replacement of the existing computer trend  
7 Gemax recorder with a new 13 inch RWM CRT, and  
8 installations of several other small devices such as, a  
9 panel switch, cable connectors, digital displays and  
10 associated electronics boxes and power supplies. The  
11 following sections assess the impact of these modifications on  
12 the existing console and devices.

13  
14 7.1 13 inch RWM CRT

15  
16 The existing computer trend Gemax recorder weighs  
17 approximately 40 lbs, and its size is 6"x6" with 22  
18 inches protruded into the back of the panel. The  
19 replacement with the new CRT weighs 90 lbs (including the  
20 mounting tray and can), and it requires a cutout of 14"  
21 x 15" on the front panel to provide an opening for  
22 mounting this device. Larger opening weakens the panel,  
23 and heavier weight increases the mass to be supporting  
24 structure. This, in turn, might alter the local dynamic  
25 characteristics of the panel if proper measures are not  
26 taken.

27  
28 To minimize such effect, a support frame is installed at  
29 the back of the panel to share the load and thereby  
30 reduce the load at the front panel to approximately the  
31 same as was before the modification. The front panel is  
32 further reinforced by the CRT support can which is  
33 connected to the support frame at the back. In  
34 addition, the support frame is braced to ensure that the  
35 frequencies in all three directions are in the rigid  
36 range of seismic response spectra, and that the support  
37 frame is structurally adequate to withstand seismic  
38 loads.

39  
40 Thus, incorporation of the above design into the  
41 modification assures that the support structure is  
42 rigid, and that the front panel is properly reinforced  
43 and supports the same weight as it did before the  
44 modification. Therefore, the response of the new device  
45 due to seismic excitations will at least remain the  
46

## CALCULATION SHEET

5010.85

23

CALCULATION IDENTIFICATION NUMBER				PAGE
JOB NUMBER	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM (C)	PS-049	N/A	54

1  
2  
3 same as or smaller than it was before the modification,  
4 and thus, the adjacent devices and the console will not be  
5 affected by this modification.  
6

7 The closest Q device to this modification is a single GE CR  
8 2940 switch located approximately 1 ft. from the cutout and  
9 near a panel edge which provides a stiff support for the  
10 switch. This and other Q devices in the upper panel of the  
11 console are all switches and push buttons with very high  
12 seismic capacities in any event.  
13

14 The overall weight being added to the console is negligible  
15 and no change can be expected in the overall console  
16 response as well.  
17

#### 18 7.2 Other Small Devices

19  
20 Other modifications involve installation of small devices  
21 such as digital displays, panel switch, etc., which weigh  
22 from 1 lb to 5 lbs.  
23

24 The mounting supports for these devices are made rigid to  
25 ensure that seismic responses are not amplified. In  
26 addition, the weights of the devices are negligibly small  
27 compared to the total weight of the console, therefore,  
28 the responses of these devices will be negligible and will  
29 not affect the integrity of the console and the adjacent  
30 devices.  
31  
32

#### 33 7.3 6" x 6" Computer Trend Recorder

34  
35 This new device is smaller and is judged to weigh less  
36 than the device it is replacing, the RWM operator  
37 interface. The new recorder also has a new rear  
38 support bracket further strengthen its mounting.  
39 Therefore, the installation of the computer trend  
40 recorder in place of the RWM operator interface will  
41 not impact the existing qualification of the Q devices  
42 in panel 05A.  
43  
44  
45  
46

47  
48

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>55</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		

1  
2  
3 8.0 ASSESSMENT OF THE IMPACT OF THE FAILURE OF NON-Q DEVICES ON THE Q DEVICES  
4 AND THE CONSOLES AND RECOMMENDATIONS FOR ANY MODIFICATIONS IF REQUIRED (FOR  
5 05A ONLY)

6 The installed console was seismically qualified with all  
7 devices in their original configuration. All original devices are  
8 therefore concluded to be acceptable from a II/I consideration. This  
9 includes confirmation of both structural integrity and the absence of  
10 unacceptable spatial interactions not involved with structural failure  
11 (breaking loose). Console modifications completed after installation have  
12 been assessed using information (1) provided by PECO and (2) obtained  
13 during a walkdown of the this specific console as well as other seismically  
14 qualified consoles and cabinets. Section 6.0 above confirms the integrity  
15 of Modification (MOD) 955. Console 05A is concluded to have no  
16 unacceptable II/I interactions.

17 8.1 DISCUSSION

18 The conclusion stated above is derived from the following:

19  
20 8.1.1 The console and all devices installed at the time of plant  
21 installation were seismically qualified as a part of the original  
22 seismic qualification of the console. (The Task Scoping document,  
23 ref 1, states that "PECO has established that the  
24 existing consoles are Q commodities seismically qualified with all  
25 the devices attached.")

26 8.1.2 Console modifications performed subsequent to the installation of  
27 the seismically qualified configuration have been characterized as  
28 minor. This means either:

- 29 a. Minor changes involving inconsequential structural  
30 modifications (small holes being drilled or covered, or  
31  
32 b. Additions (or deletions) of inconsequential weight and/or size  
33 to the console, or  
34  
35 c. The exchange of like item for like item in which the new item  
36 is sufficiently similar to the replaced item (in size, weight,  
37 anchorage details, etc.) to be a basis to conclude that  
38 equivalent and satisfactory structural integrity exists.

39 The purpose of the walkdown is to confirm that such modifications  
40 are not significant for a II/I interaction assessment.

41 8.1.3 Reference 13 confirms basic console anchorage. No further assessment  
42 is required.  
43  
44  
45  
46



## CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>56</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		

8.1.4 The process of review of non-Q modifications to console 05A is as follows:

- a. As a result of the walkdown of this console and its prior seismic qualification, it was judged that spatial interaction (rattling) of any of the non-Q modifications with Q-devices was not credible. Structural failure (and falling) would be the only necessary concern as a precursor to any unacceptable II/I interaction.
- b. With information from the walkdown, the non-Q modifications to the original configuration are confirmed as minor and, therefore, judged to be capable of remaining integral during an earthquake. Subsequent steps are also applied since it was not possible to precisely identify every modification. No II/I concern is concluded.
- c. If the non-Q modification is sufficiently distant from any Q device(s) to be of no concern (even if structural failure and associated falling were to take place), an acceptable condition could be concluded to exist. Because potential failure paths could include safety-related wiring or interior devices not apparent from either the walkdown or available drawings, this option was not used for II/I assessment of this console.
- d. If Q devices are inside the potential failure path of the non-Q modification (or if it is desirable to assure against possible structural failure) the non-Q modification must be assured against structural failure and any unacceptable spatial interaction by one of the following methods:
  - (1) Comparison with other devices qualified in this or other plant consoles combined with a judgement regarding panel location dependent response. Many added devices are identical (or sufficiently similar) to qualified devices. Structural integrity is easily inferred.
  - (2) If necessary and/or appropriate, utilize information from other plants (experience) to confirm structural integrity.
  - (3) Perform a case specific evaluation by either:
    - calculation, or
    - engineering judgement (insufficient weight, etc.).
 All indicating lights are judged to be of sufficient weight/strength so as to be incapable of structural failure due to earthquake loading.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>57</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

8.1.5 Modifications to the original installation were concluded to result in an acceptable console configuration. No potential II/I interactions were identified.

8.1.6 The modification (MOD) 955 outlined in Section 1.0 and the calculations presented in Section 6.0 confirm the structural integrity of the design and confirm an acceptable console configuration. No potential II/I interactions will result from this MOD.

8.2 DETAILED DISCUSSION

The upper (vertical) panel of the console contains the following Q-devices: (identification and location (X, Y) coordinates are according to Ref. 14, view F; locations of device clusters are approximate and provided for reference and information; see Figure 8-1 attached)

1. 2ea manual scram push buttons (84, 22)
2. 6ea GE CR2940 switches (160, 18)
3. 2ea GE CR115 switches (158, 15)
4. 1ea GE CR2940 switch (142.75, 2)

These devices are sufficiently isolated above or beside any identified modification to assure against any potential interaction. Structural failure of any non-Q device on the vertical panel will not occur and therefore will not create any unacceptable interaction with Q devices located below. Non-Q dial indicators (37ea G.E. 180), recorders (15ea 6x6 multipen), and local power indicators (16ea) are concluded to be structurally qualified because they are either (1) original equipment, or (2) similar to Q or non-Q devices installed in another Q commodity (e.g. ECCS panel or console 04A). Remaining non-Q devices (pushbutton switches, indicator lights, etc., were judged structurally qualified because they are either (1) original equipment, or (2) low weight, compact items with sufficient strength.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>58</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		

The lower (horizontal) panel of the console contains the following Q-devices: (identification and location (X, Y) coordinates are according to Ref. 14, view E; locations of device clusters are approximate and provided for reference and information; see Figure 8-1 attached)

- 5. 5ea GE CR2940 switches (159, 6) Unit 3; 4ea on Unit 2
- 6. 1ea SBLC pump switch (152, 15)
- 7. 2ea GE SBM switches (142, 14.84)
- 8. 3ea Neutron Monitoring System switches (129.75, 10)
- 9. 4ea IRM Power Range switch (110, 10)
- 10. 4ea IRM Power Range switch (58. 10)
- 11. 1ea GE SBM switch (96, 3.6)
- 12. 1ea Reactor Mode switch (70.75, 3.8)
- 13. 2ea GE SBM switches (24, 4.84)

These devices are concluded to be sufficiently isolated from any identified modification to assure against any potential interaction. Structural failure of any non-Q device on the horizontal panel will not occur and therefore will not create any unacceptable interaction with Q devices located below. Major non-Q devices include: the Manual/Auto HCS Stations (8ea 7-GEMAC, 1-L&N), the rod select matrix, switches (18ea G.E. SBM; 5 additional SBM switches are Q qualified), and Neutron Monitoring System bypass switches (6ea).

9.0 SEISMIC CAPABILITY LIMITS OF EXISTING Q DEVICES FROM SWEC/VENDOR DATA BASE (FOR 05A ONLY)

Reference 9 addresses the seismic qualification of "Class I" electric equipment on all standard product line reactors. It summarizes qualification data obtained by methods which "did not differ markedly" from IEEE 344-1971. Reference 15 provides data for switches similar to those used for the Peach Bottom consoles and represents test to more current requirements (i.e. multi-axis testing, etc.). Certain data have been extracted and compared below.

DEVICE	REFERENCE	MALFUNCTION LIMIT			DEVICE CLUSTER (FIG. 8-1)
		HOR-1	HOR-2	VERTICAL	
Switch, type CR2940	15 9	209 20	209 20	209 20	2, 4, 5
Switch SB-1	9	10	10	10	G.E. (typical)
Switch SBM	9	25	25	25	7, 11, 13
Range Switch	9	8.5	8.5	8.5	9, 10

All devices, including the remaining Q device clusters (1, 3, 6, 8, and 12) are seismically qualified to at least the specified plant levels.



STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>59</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

TABLE 8-1

SUMMARY TABLE OF EQUIPMENT FOR CONSOLE(S) 2(3)OC05(A)  
(extracted from Ref. 14 in the same order as annotations)

UPPER (VERTICAL) PANEL

LOWER (HORIZONTAL) PANEL

- 15- 6x6 MULTIPEN RECORDERS
- 37- G.E. INDICATORS
- 22- G.E. CR2940 SWITCHES  
(7- Q)

- 23- G.E. CR2940 SWITCHES  
(5- Q)
- 23- G.E. SBM SWITCHES  
(5- Q)

- 16- LOCAL POWER INDICATORS

- 8- MANUAL/AUTO HCS STATIONS
- 8- IRM POWER RANGE SWITCHES  
(8- Q)
- 6- NEUTRON MONITORING SYSTEM  
BYPASS SWITCHES  
(3- Q)
- 2- VALVE POSITION INDICATORS

- RWM OPERATOR INTERFACE (1)  
(DELETED BY MOD 955)

- 1- REACTOR MODE SWITCH (2)  
(1- Q)
- 1- SBLC PUMP SWITCH (3)  
(1- Q)
- 4- RFPT LOCKOUT RELAYS (4)

- 2- MANUAL SCRAM PB's (5)  
(2- Q)

- 1- ROD SELECT MATRIX (6)
- 4- ARI PUSH BUTTONS (7)

- 4- ROD DISPLAY INDICATORS (8)
- 2- G.E. CR115 SWITCHES (9)  
(2- Q)







STONE & WEBSTER ENGINEERING CORPORATION  
 CALCULATION SHEET

Appendix 1

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>1</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46



30605A (2)

(REACTOR) 30605A ← | → (REG/RC/RWC) 306004A




30605A (1)

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET


Appendix 1

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>2</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NMCC	PS-049		




30C05A (6)



30C05A (5)



30C05A (4)



30C05A (3)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46




STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

Appendix 1

▲ 5010.65


CALCULATION IDENTIFICATION NUMBER				PAGE <u>3</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		



30C05A Q-devices



30C05A Q-Devices



30C05A Q-devices

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46


STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

Appendix 1

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>4</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46



30305A Framing



STONE & WEBSTER ENGINEERING CORPORATION  
 CALCULATION SHEET

Appendix 1


▲ 5010.65

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 19597	DIVISION & GROUP NM(C)	CALCULATION NO. PS-049	OPTIONAL TASK CODE
			PAGE <u>5</u>


1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46



30C05A (device detail)



30C05A (device detail from inside)



30C05A



30C05A (NON-Q device suppt detail SAME)


STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

Appendix 1

▲ 5010.65


CALCULATION IDENTIFICATION NUMBER				PAGE <u>6</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NMCC	PS-049		

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46



30C05A (From back, switch detail)

30C05A ~~??~~




STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

Appendix 1


5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>7</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NMCC	PS-049		


1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46



30 C004A (A-device detail)



30 C004A (A-device detail)



30C004A (A-device detail)


STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

Appendix 1

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>8</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46



30C07A (Q-console  
suppt detail save)


STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

Appendix 1

▲ 5010.65


CALCULATION IDENTIFICATION NUMBER				PAGE <u>9</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	117(C)	PS-017		

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46



ZOCOSA

(1)



ZOCOSA

(2)

ROUTE 25011

PANEL FRONT

1/4"-20 HEX NUT A-307 & WASHER  
(TYP. 12 PLACES)

CRT mounting  
collar

XIS-90193

1/4"-28 FLAT HEAD SCREW 3/4" LONG  
A-307, (TYP 2 PLACES)

ENCLOSURE

1/4"-28X 1 1/4" LONG FLAT HEAD MACHINE  
SCREW A-193 GR B7 & TWO (2) 1/4" NUTS  
A-194 GR 2H (TYP 8 PLACES)

TRAY

CONNECTION PER MANUFACTURER'S  
REQUIREMENTS

APPROX.  
1 11/16"

NOTE: CONNECTION OF TRAY TO CRT CHASSIS  
PER MANUFACTURER'S REQUIREMENTS

CONNECTION PER MANUFACTURER'S  
REQUIREMENTS

### XIS-90193 ASSEMBLY DETAIL

Attachmen 1 voided pages  
page 1  
VOID

#### INTERIM DRAWING CHANGE NOTICE

STATION

UNIT

PBAPS LGS

C 1 2 3

PHILADELPHIA ELECTRIC COMPANY

MOD

DRAWING

SHEET

REV.

IDCN

955G

M-1-EE-124

8

59

M

PRELIMINARY

DRAFT

MOD

ISSUE

ISSUE

ISSUE

DATE

DESIGN

CHKD.

APPR.

STRL.

~~DATE~~ *KW*

*9/15*

*0/15*

*JY*

*CHC*

DESCRIPTION:

PAGE 1 OF 1

86150041 0239955

MOD 955G

ADDED: ASSEMBLY DETAIL FOR DEVICE  
XIS-90193



STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>58</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
19597	NM(C)	PS-049		

*Attachment 1 Voided Pages page 2*

The lower (horizontal) panel of the console contains the following Q-devices: (identification and location (X, Y) coordinates are according to Ref. 14, view E; locations of device clusters are approximate and provided for reference and information; see Figure 8-1 attached)

5. 5ea GE CR2940 switches (159, 6) Unit 3; 4ea on Unit 2
6. 1ea SBLC pump switch (152, 15)
7. 2ea GE SBM switches (142, 14.84)
8. 3ea Neutron Monitoring System switches (129.75, 10)
9. 4ea IRM Power Range switch (110, 10)
10. 4ea IRM Power Range switch (58, 10)
11. 1ea GE SBM switch (96, 3.6)
12. 1ea Reactor Mode switch (70.75, 3.8)
13. 2ea GE SBM switches (24, 4.84)

VOID

These devices are concluded to be sufficiently isolated from any identified modification to assure against any potential interaction. Structural failure of any non-Q device on the horizontal panel will not occur and therefore will not create any unacceptable interaction with Q devices located below. Major non-Q devices include: the Manual/Auto HCS Stations (8ea 7-GEMAC, 1-L&N), the rod select matrix, switches (18ea G.E. SBM; 5 additional SBM switches are Q qualified), and Neutron Monitoring System bypass switches (6ea).

**9.0 SEISMIC CAPABILITY LIMITS OF EXISTING Q DEVICES FROM SWEC/VENDOR DATA BASE (FOR 05A ONLY)**

Reference 9 addresses the seismic qualification of "Class I" electric equipment on all standard product line reactors. It summarizes qualification data obtained by methods which "did not differ markedly" from IEEE 344-1971. Reference 15 provides data for devices similar to those used for the Peach Bottom consoles and represents test to more current requirements (i.e. multi-axis testing, etc.). Certain data have been extracted and compared below.

DEVICE	REFERENCE	MALFUNCTION LIMIT		
		HOR-1	HOR-2	VERTICAL
Switch type CR2940	9	20 g	20 g	20 g
	15	20	20	20
Switch SB-1	15	10	10	10
Switch SBM	15	25	25	25
Range Switch	15	8.5	8.5	8.5