

**ATTACHMENT 6**

**Peach Bottom Atomic Power Station  
Units 2 and 3**

**Docket Nos. 50-277 and 50-278**

**License Amendment Request  
Response to Request for Additional Information**

**Alternative Source Term (AST)**

**PBAPS Calculation 49-48/H, Revision 0, *"Heating and Ventilation -  
Seismic Analysis for Anchor Bolts"***



NUCLEAR  
GROUP  
M-20599 Rev. 3/93  
DOCTYPE 081

# CALCULATION COVER SHEET

1. Calculation No. 49-48/H

Page 1

2.  LGS  
 PBAPS

UNIT(S) 2 & 3

3. MOD/NGR/ECR No.:  
Other: CALC. TURN OVER TO DS

4. Responsible Branch: SECS

5. Total No. of Pages: 39

6. Last Page No: 28

7.  Safety Related  
 Non-Safety Related

8. Description:  
HEATING AND VENTILATION - SEISMIC ANALYSIS FOR ANCHOR BOLTS.

9. System/Topic No.: 70,901

Structure: ---

Component: ---

## RECORD OF REVISIONS

10. Rev. No.	11. Description of Revision	12. Vendor Calc.		13. Assumptions		14. Signatures		
		Number	Rev.	Yes	No	Preparer	Reviewer	Approver/Date
0	THIS CALCULATION HAS NOT BEEN VALIDATED FOR TECHNICAL CONTENT. IT HAS BEEN ADMINISTRATIVELY PROCESSED AND ACCEPTED FOR PIMS INDEXING. SINCE THE CALCULATION MAY OR MAY NOT REFLECT THE CURRENT AS-BUILT CONFIGURATION, THE USER MUST REVIEW THE CALCULATION FOR TECHNICAL ADEQUACY AND THE CURRENT CONFIGURATION NEEDED TO SUPPORT OTHER CALCULATIONS OR DESIGN ACTIVITIES IN PROGRESS.							"APPROVED FOR RECORD" FM/MKS-UE 9/22/93

15. Related Calc. Numbers	Provides Info to:						
	Receives Info from:						
	Supersedes:						

16.  
 Manual  
 Computer  
Computer program and version  
\_\_\_\_\_



CLASS I SYSTEMS & EQUIPMENTS

Signature W.W. LEONG

PEACH BOTTOM APS UNITS 2&3

Date 9/18/72

BECHTEL JOB NO. 6280

Sheet No. 1 of 5

40/H

TAG NO.	SPEC. NO.	SYSTEM/EQUIPMENT	BLDG.	BASE ELEV.	REMARK
<u>HEATING &amp; VENTILATION</u>					
0AV20	M-51	Standby Gas Treatment Fan	Radw.	91'	
0BV20	"	" " " "	"	91'	
0CV20	"	" " " "	"	91'	
0AV30	"	Control Rm. Vent. Supply Fan	"	165'	
0BV30	"	" " " "	"	165'	
0AV34	M-49-3	Emer. Switchgr. Fan	"	165'	
0BV34	M-49-11	" " " "	"	171'	
0AV35	M-51	" " " "	"	165'	
0BV35	"	" " " "	"	165'	
0AV36	"	Battery Rm. Exh. Fan	"	165'	
0BV36	"	" " " "	"	165'	
0AV52	"	Diesel Gen. Bldg. Pump Room Fan	D. Gen.	151'	
0BV52	"	" " " "	"	151'	
0AV60	M-70	Pump Structure Fan	Intake	122'	
0BV60	"	" " " "	"	122'	
0AV61	"	" " " "	"	122'	
0BV61	"	" " " "	"	122'	
0AV64	M-51	Diesel Gen. Bldg. Fan	D. Gen.	151'	
0BV64	"	" " " "	"	151'	
0CV64	"	" " " "	"	151'	
0DV64	"	" " " "	"	151'	

0000014575

00076

207



CLASS I SYSTEMS & EQUIPMENTS

46/H

TAG NO.	SPEC. NO.	SYSTEM/EQUIPMENT	BLDG.	BASE ELEV.	REMARK
<u>HEATING &amp; VENTILATION</u>					
2FV26	M-77	Drywell Cooler	R'ctor	128'	
2GV26	"	" " "	"	130'	
0AF34	M-54	Standby Gas Treatm't Filter	Radw.	91'	
0BF34	"	" " " " "	"	91'	
0AF35	"	" " " " "	"	91'	
0BF35	"	" " " " "	"	91'	
0AF36	"	" " " " "	"	91'	
0BF36	"	" " " " "	"	91'	
0AF37	"	" " " " "	"	91'	
0BF37	"	" " " " "	"	91'	
0AE65	"	" " " " "	"	91'	
0BE65	"	" " " " "	"	91'	
0AF40	"	Control Rm. Vent.	"	165'	
0BF40	"	" " " "	"	165'	
0AF41	"	Control Rm. Vent. Filter	"	165'	
0BF41	"	" " " " "	"	165'	
0AF50	"	" " " " "	"	165'	
0BF50	"	" " " " "	"	165'	
0AE42	"	" " " " "	"	165'	
0BE42	"	" " " " "	"	165'	

0000014577  
2157

60078

209



CLASS I SYSTEMS & EQUIPMENTS

40/H

TAG NO.	SPEC. NO.	SYSTEM/EQUIPMENT	BLDG.	BASE ELEV.	REMARK
2AE58	M-77	RHR Compartm't Coolers	Reactor	91'-6	
2BE58	"	" " "	"	"	
2CE58	"	" " "	"	"	
2DE58	"	" " "	"	"	
2EE58	"	" " "	"	"	
2FE58	"	" " "	"	"	
2GE58	"	" " "	"	"	
2HE58	"	" " "	"	"	
0AP57	M-11	Service Water Pump	Pmp.Struct.	113'-0	
0BP57	"	" " "	"	"	
<u>ADDIT. ITEMS (NOT DIRECTLY ASSOC.)</u>					
	E-7	Control Panel			
		Emer. Switchgear Panels			
		Battery Rack			

EMER.  
SERVICE  
WATER.  
(Cont'd)

U U U U U 1 4 5 7 7  
2 1 5 9

211

CC680





DATE 9/19/72

DESIGN BY WILSON W. LEONG

DATE

CHECKED BY *REH*

SHEET NO. 1

PROJECT P.B. APS UNITS NO. 2 & 3

JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS

FILE NO. 48/H


STANDBY GAS TREATMENT FAN (OAV 20, OBV 20 & OCV 20)

REFERENCES :

VENDOR PRINTS (SPEC. NO.) M-51-87 & M-51-152

EQUIPMENT SCHEDULE M-480 SHT. NO. 1 & 2 (LOADING TABLE)

RADWASTE BLDG. @ EL 91'-6



EQUIPMENT TOTAL WT.  $W = 141 \# + 1500 \# = 1641 \#$

DAMPING  $\gamma = 5 \%$

HORIZONTAL ACCELERATION (D.B.E) = 0.20g (MIN. REQ'D)

MAX. CREDIBLE EARTHQUAKE (M.C.E) =  $2.4 \times 0.20g = 0.48g$  (HORIZ. ACCL)

$\therefore$  HORIZONTAL FORCE  $F_H = ma = \frac{W}{g} \times 0.48g = \frac{1641}{g} \times 0.48g = 790 \#$

SHEAR  $f_v = \frac{790 \#}{10 \text{ BOLTS}} = 79 \#/\text{BOLT} < \text{ALLOWABLE SHEAR } F_v = 1000 \#/\text{5/8" } \phi \text{ A.B.}$

UPLIFT  $F_u = F_H \times \frac{H}{L} - \frac{W}{2} = 790 \times \frac{33.5}{26.75} - \frac{1641}{2} = 990 \# - 820 \#$   
 $= 170 \#$  (OK)

REQ'D TENSION STRESS  $f_t = \frac{170}{5} = 34 \#/\text{BOLT} < 1480 \#/\text{5/8" } \phi \text{ A.B. (OK)}$

212

00081

0000014580  
2160




DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY P. H. HAY SHEET NO. 2 1/1  
 PROJECT P.B. APS. UNITS NO 2 & 3 JOB NO. 6280  
 SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

CONTROL ROOM VENT SUPPLY FAN (OAV 30 & OBV 30)

REFERENCES :

- VENDOR PRINTS (SPEC. NO.) M-51-30 & M-51-65
- EQUIPMENT SCHEDULE (FOR LOADING) M-480 SHT. NO. 1 & 2
- KADWASTE BLDG AT EL 16520
- SEISMIC ANALYSIS REPORT (COMPUTER OUTPUT)



EQUIPMENT TOTAL WT.  $W = 780 \#$

DAMPING = 5% (SEE P. B-24 ON SEISMIC REPORT FOR

HORIZ. ACC'L (D.B.E.) = 0.62g (PEAK) RAD. BLDG.)

TOTAL ANCHOR BOLTS = 10 - 1/2"  $\phi$

MAX. CREDIBLE EARTHQUAKE (M.C.E.) = 0.62g x 2.4 = 1.48g (HORIZ. ACC'L)

MAX. HORIZ. FORCE  $F_H = 1.48g \times \frac{780 \#}{g} = 1160 \#$

SHEAR  $f_v = \frac{1160 \#}{10 \text{ BOLTS}} = 116 \#/\text{BOLT} < \text{ALLOWABLE SHEAR } F_v = 750 \#/\frac{1}{2} \text{ " } \phi \text{ A.B.}$   
(OK)

UPLIFT FORCE  $F_u = 1160 \# \times \frac{24.5 \text{ "}}{19.5 \text{ "}} - \frac{780 \#}{2} = 1070 \#$

TENSION STRESS  $f_t = \frac{1070 \#}{5 \text{ BOLTS}} = 214 \#/\text{BOLT}$  (OK)

ALLOWABLE TENSION STRESS FOR 1/2"  $\phi$  A.B :  $F_t = \sum \phi u d_i J = 204 (A-H) J$

$F_t = 1.6 \text{ " } \times 250 \#/\text{D} \times (10 \text{ " } - 6 \text{ "}) \times 0.875 = 1400 \#/\frac{1}{2} \text{ " } \phi \text{ A.B.}$

0000014581  
2161

243

00082



DATE 9/19/72

DESIGN BY WILSON W. LEONG

DATE

CHECKED BY [Signature]

SHEET NO 3

1/3

PROJECT P.B. APS UNITS NO. 2 & 3

JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLT

FILE NO. 48/H

EMER. SWICHGR. FAN (OAV34 & OBV34)

REFERENCES

EQUIPMENT SCHEDULE (LOADING) M-480 SHT. NO. 1 & 2


BLDG. — RADWASTE AT EL 165'-0 FOR OAV34, EL 171'-0 FOR OBV34.

VENDOR PRINT (SPEC. NO.) M-49-1 ; M-49-3 FOR OAV34 ;


M-49-11 FOR OBV34 ;

MECH. DWG. M-425 & M-426

0000014582  
2162



PLAN.



ELEV.

6 - C 3 x 1 1/4 (4.1 #/FT) ; A = 1.19 in<sup>2</sup>, I<sub>x</sub> = 1.6 in<sup>4</sup>, I<sub>y</sub> = 0.2 in<sup>4</sup>, S<sub>x</sub> = 1.1 in<sup>3</sup>, S<sub>y</sub> = 0.21 in<sup>3</sup>

4 - L 3 x 3 x 1/2 (9.4 #/FT) ; A = 2.75 in<sup>2</sup>, I<sub>x</sub> = 2.2 in<sup>4</sup> = I<sub>y</sub>, S<sub>x</sub> = S<sub>y</sub> = 1.1 in<sup>3</sup>

ANCHOR BOLTS : 4 - 3/4" φ AND 6 - 1/2" φ

00083

LOADING : WT. OF SUPPORTS (STEEL FRAMING) = 1140 #  
WT. OF EQUIPMENTS (OAV34 & OBV34) = 9860 # = 4930 x 2  
TOTAL W = 11000 #

FORMULAS : HORIZ. FORCE F<sub>H</sub> = ma =  $\frac{W}{g}$  x HORIZ. ACCELERATION (a)

214 ∴ HORIZ. SHEAR f<sub>v</sub> =  $\frac{F_H}{NO. OF BOLTS}$  ; TENSION f<sub>t</sub> =  $F_H \times \frac{h}{L} = \frac{W}{2}$  (TOTAL TENSION FORCE)



DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY [Signature] SHEET NO. 4  
 PROJECT P. B. APS. UNITS NO. 2 & 3 JOB NO. 6280  
 SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

(CONT'D) EMER. SWICHG'R FAN (OAV 34 & OBV 34)


DETERMINE HORIZ. ACC'L OF OAV 34 & OBV 34 AND STEEL FRAMING :

- (1) FIND THE EQUIPMENT (OAV 34 & OBV 34 AND FRAMING) FREQUENCY ON FLOOR ELEV 165-0.
- (2) REFER TO RADWASTE BLDG SEISMIC REPORTS PAGE B-20 W/ DAMPING = 2% TO GET HORIZ. ACC'L.

$$(1) f_{cps} = \frac{3.127}{\sqrt{\Sigma \Delta}} = \frac{3.127}{\sqrt{\Delta_v + \Delta_m}} \quad (\text{FREQUENCY})$$

$$\Delta_v = \frac{Wh}{A_v G} \quad ; \quad \Delta_m = \frac{Wh^3}{3EI} \quad (\text{FOR CANTILEVER STRUCT.})$$

WHERE,  $W = 11000 \#$  WEIGHT AT MASS POINT  
 $h = 74"$  HEIGHT OF MASS POINT TO GROUND (BASE)  
 $A_v =$  SHEAR AREA (IN EAST - WEST DIRECTION  $\downarrow$ )



$$= [(3" \times 3/16") \times 4] + [(1/4" \times 1/4") \times 4] + [2.75" \times 1/2 \times 4]$$

$$\therefore A_v = 9.0 \text{ in}^2$$

$$I_{(E-W)} \downarrow = (1.6 \text{ in}^4 \times 4 + 0.2 \text{ in}^4 \times 2) + (2.2 \text{ in}^4 \times 4) = 15.6 \text{ in}^4$$

$E = 29 \times 10^6 \text{ psi}$  YOUNG'S MODULUS FOR STEEL.

$G = 0.4 E = 0.4 \times 29 \times 10^6 = 11.6 \times 10^6 \text{ psi}$ , SHEAR MODULUS.

$\Delta =$  DEFLECTION

$$\Delta_v = \frac{Wh}{A_v G} = \frac{11000 \# \times 74"}{9.0 \text{ in}^2 \times 11.6 \times 10^6 \text{ psi}} = 0.008 \text{ in}$$

$$\Delta_m = \frac{Wh^3}{3EI} = \frac{11000 \# \times (74")^3}{3 \times 29 \times 10^6 \text{ psi} \times 15.6 \text{ in}^4} = 3.292 \text{ in} \quad \therefore \Sigma \Delta = 3.3 \text{ in}$$

$$\therefore \text{FREQUENCY } f_{cps} = \frac{3.127}{\sqrt{\Sigma \Delta}} = \frac{3.127}{\sqrt{3.3}} = 1.72 \text{ CPS}$$

00084

HORIZ. ACCELERATION "a" (EAST - WEST DIRECTION)

REFER TO RADWASTE BLDG SEISMIC REPORT PAGE B-20 W/ 2% DAMPING

AND FREQUENCY  $f_{cps} = 1.72 \text{ CPS}$ , WE HAVE, HORIZ. ACC'L " $a$ " =  $\frac{0.27 g}{(FOR D. B.E.)}$

(CONSERVATIVE = 3 ACTUALLY LESS)

215

0000014583  
2163



DATE \_\_\_\_\_

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY PE Horvath SHEET NO. 5 3/3

PROJECT P.B. APS UNITS NO. 2 & 3 JOB NO. 0280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

(CONT'D.) CHECK ANCHOR BOLTS FOR OAV 34 & OBV 34

DESIGN BASIS EARTHQUAKE (D.B.E.) = 0.27g (HORIZ ACC'L)

MAX. CREDIBLE EARTHQUAKE (M.C.E.), HORIZ ACC'L = 0.27g x 2.4 = 0.648g

∴ HORIZONTAL FORCE:  $F_{H(D.B.E.)} = \frac{11000\#}{g} \times 0.27g = 2970\#$

$F_{H(M.C.E.)} = \frac{11000\#}{g} \times 0.648g = 7140\#$

ALLOWABLE SHEAR FORCE: 4 - 3/4" φ A.B. + 6 - 1/2" φ A.B.

∴  $F_v = 1500 \times 4 + 750\# \times 6 = 10500\# > F_H$  (OK)

VERTICAL TENSION FORCE: (EAST OR WEST SIDE)

$F_t = F_H \times \frac{h}{L} = \frac{W}{2} = \frac{7140\# \times 74"}{615} = \frac{11000}{2} = 3091\#$

ALLOWABLE TENSION: 2 - 3/4" φ A.B. + 3 - 1/2" φ A.B.

∴  $F_t = 2220\# \times 2 + 1400\# \times 3 = 8600\# > F_t$  (OK)

0000014584  
2164

00085

216



DATE 9/20/72

DESIGN BY WILSON W. LEONG

DATE

CHECKED BY *PE Hedrick*

SHEET NO 6

1/3

PROJECT P.B. ADS. UNITS NO. 2 & 3

JOB NO.

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS

FILE NO 48/H

EMER. SWITCH & R. FAN (OAV 35 & OBV 35)

REFERENCES :

VENDOR PRINTS (SPEC. NO.) M-51-31 & M-51-69

EQUIPMENT SCHEDULE M-480 SHT. NO. 1 & 2 (LOADING TABLE)

RADWASTE BLDG. BASE EL 165.0


REFER TO SEISMIC REPORT FOR RADWASTE BLDG  
(PAGE NO. 24 B) W/ 5% DAMPING TO GET  
HORIZONTAL ACC'L "a" = 0.62g (PEAK) FOR D.B.E.

OR 0.62g x 2.4 = 1.48g FOR M.C.E.

TOTAL WT. W = 4600# (SEE M-480)

∴ HORIZ. FORCE  $F_H = 1.48g \times \frac{4600\#}{g} = 6800\#$

PLATFORM BOLTS (TOTAL 6 - 1/2" φ BOLTS)



(SEE BACK PAGE FOR BASE)

SHEAR STRESS  $f_v = \frac{6800}{6} = 1133\#/\text{BOLT} < 750\#/\text{1/2" } \phi \times 1.89$   
(OK)

TENSION FORCE  $F_t = 6800\# \times \frac{62.5}{58} = 7320\#$

UPLIFT (TENSION STRESS) PER BOLT  $f_t = (7320 - \frac{4600}{2}) \times \frac{1}{3} = 1673 < 1400 \times 1.98$   
(OK)

BASE ANCHOR BOLTS (TOTAL 8 - 3/4" φ A.B.)

HORIZ. FORCE  $F_H = 6800\#$ , SHEAR STRESS  $f_v = \frac{6800}{8} = 850\#/\text{BOLT} < 1500\#/\text{3/4" } \phi \times 1.33$

TENSION FORCE =  $F_H \times \frac{H}{L} = 6800 \times \frac{62.5}{24} = 13700\#$  (OK)

UPLIFT =  $13700\# - \frac{4600}{2} = 11400\#$

∴ TENSION STRESS PER BOLT  $f_t = \frac{11400\#}{4 \text{ BOLTS}} = 2850\#/\text{BOLT} < 2220 \times 1.98 = 4400\#/\text{3/4" } \phi$   
(OK)

217

00086

0000014585  
2165



DATE \_\_\_\_\_

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY RE Hachroy SHEET NO. 7 <sup>2/3</sup>

PROJECT P.B. APS. UNITS NO. 2 & 3 JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

(CONT'D.) OAV 35 & DBV 35

IF WE ARE CONSIDERING ALL BOLTS (6 - 1/2" φ & 8 - 3/4" φ) EMBEDDED TO THE FLOOR (CONCRETE), WE HAVE:

SHEAR FORCE  $F_H = 6800 \# < \text{ALLOWABLE SHEAR} = 750 \times 6 + 1500 \times 8$   
 $= 4500 + 12000 = 16500 \#$   
 TENSION FORCE (UPLIFT) (OK)

$F_u = F_H \times \frac{h}{L} - \frac{W}{2}$ , ( $h = 62.5"$   $L = \frac{58" - 31"}{2} + 31" = 44.5"$ )

$F_u = 6800 \# \times \frac{62.5"}{44.5"} - \frac{4600 \#}{2} = 9550 \# - 2300 \# = 7250 \# < \text{ALLOWABLE } F_t$   
 (OK)

( $F_t = 1400 \# / \frac{1}{2}" \phi \times 3 + 2220 \# / \frac{3}{4}" \phi \times 4 = 13080 \#$ )

0000014586  
000002166

00087

218







DATE 9/21/72

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY *P. Hachay* SHEET NO. 8 1/3

PROJECT P.B. APS. UNITS NO. 2 & 3 JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

BATTERY ROOM EXHAUST FAN (OAV36 & OBV36)

REFERENCES :

VENDOR PRINTS (SPEC. NO.) M-51-43, M-51-70 & M-51-71

EQUIPMENT SCHEDULE (LOADING TABLE) M-480 SHT. NO. 1 & 2

RADWASTE BLDG BASE EL 165'0, DAMPING: 5%


HORIZ. ACC'L "a" = 0.62g (PEAK POINT) (FOR D.B.E.)

" " "a<sub>MAX</sub> = 0.62g x 2.4 = 1.48g (FOR M.C.E.)

TOTAL WT. W = 2100#

HORIZONTAL FORCE F<sub>H</sub> = 1.48g x  $\frac{2100\#}{g}$  = 3110# (M.C.E.)

ALLOWABLE SHEAR F<sub>V</sub> = 750 x 6 + 1500 x 8  
 = 4500# + 12000# = 16500# > F<sub>H</sub>  
 (OK)



TENSION FORCE (UPLIFT), F<sub>U</sub> = F<sub>U1</sub> + F<sub>U2</sub>, ASSUMED F<sub>U1</sub> = F<sub>U2</sub>

$F_{U1} \times 62" + F_{U2} \times 16.5" = F_H \times h$  ( F<sub>U1</sub> = F<sub>U2</sub> =  $\frac{1}{2}$  F<sub>U</sub> )

$\frac{1}{2} F_U (62" + 16.5") = 3110\# \times 41"$  (CONSERVATIVE)

$\therefore F_{U(NET)} = \frac{2 \times 3110\# \times 41"}{(62" + 16.5)} = 3260\# < \text{ALLOWABLE TENSION } F_t$   
 (OK)

( F<sub>t</sub> = 1400# /  $\frac{1}{2}$ "  $\phi$  x 3 + 2220# /  $\frac{3}{4}$ "  $\phi$  x 4 = 13080# )

0000014588  
 2160

220

00089



# MASON INDUSTRIAL Inc.

Manufacturers of Vibration Control Products

3315 192nd Place  
New York, New York 11437  
Area Code 212-932-2955

3315 East Pico Blvd.  
Los Angeles, California 90022  
Area Code 213-230-9557

CUST: AMERICAN STANDARD LTD. 221

P.O. # A-127

M.I. # 41346


NO. REQ'D: ONE TAG: 2210-3000-48/H

DATE: 11-10-70 DRAWING NO. P.8B

MAKE OF FAN: AMERICAN STANDARD								SPEC				DRIVE				MOTOR	
SIZE	CL.	W.	ARR.	ROT.	DIS.	BRG.	RPM	FEAT.	BELT	MOTOR	FAN	CENT.	HP	FRAME	POS.		
365			8	CU	US	BB	575							256T			


SLIDE RAILS: MASON SIZE — BY OTHERS — NTS: STEEL BASE — BASE MEN. 90 4/5

TYPE "SLF" BASE 1" SPECIFIED DEFLECTION  
LOCK CAP SCREW SEE DWG. A-3595



NON-SKID SURFACE ON BASE OF MOUNT.  
BOLTING TO FLOOR NOT NECESSARY.

0000014590  
2170



222

00091

BATTERY ROOM EXHAUST FAN - OBV36



DATE 9/21/72

DESIGN BY WILSON W. LEONG

DATE

CHECKED BY R. Hockney

SHEET NO. 9

PROJECT P.B. APS UNITS NO. 2 & 3

JOB NO. 6286

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS

FILE NO. 48/H

DIESEL GEN. BLDG. PUMP ROOM FAN (OAV 52 & OBY 52)

VENDOR PRINT: M-51-58 & M-51-84

BASE EL. 151'-0"

TOTAL WT. W = 800 #

DAMPING: 5%

ANCHOR BOLTS: 6-1/2" φ + 6-3/4" φ

TOTAL ALLOWABLE STRESS FOR A.B.


SHEAR = 750 x 6 + 1500 x 6 = 13500 #

TENSION = 1400 x 3 + 2220 x 3 = 10860 #

HORIZ. ACC'L "a" = 0.75 g (FOR D.B.E.)

OR a<sub>MAX</sub> = 0.75 g x 2.4 = 1.80 g (FOR M.C.E.)

HORIZ. (SHEAR) FORCE F<sub>H</sub> = 1.80 g x  $\frac{800 \#}{g}$  = 1440 # (M.C.E.)



3-1/2" φ A.B. EA. SIDE

3-3/4" φ A.B. EA. SIDE

BY INSPEC. ALL ANCHOR BOLTS ARE OK FOR SEISMIC.

0000014591  
2171

00092

223

**NASON INDUSTRIES, INC.**

Manufacturers of Vibration Control Products

3010 130th Place  
 Bayside, New York 11361  
 (Area Code 212) 523-3335

3333 East 10th Ave.  
 Los Angeles, California 90022  
 (Area Code 213) 203-9597


CUST: AMER N STAMPING CO INC DIR  
 P.O.# 7109 45TH  
 C.I.# 41348  
 NO. REQ'D: TWO TAG: CA182, 00V52  
 DATE: 4-12-72 DRAWING NO. 2-89737

MAKE OF FAN: <u>AMER N STAMPING CO</u>								DRIVE				MOTOR			
SIZE	CL	W	ARR	ROT	DIS	ERG	RPM	FEAT.	BELT	MOTOR	FAN	CENT	HP	FRAME	POS
<u>270</u>	<u>1</u>	<u>D</u>	<u>7</u>	<u>CC</u>	<u>TH</u>	<u>43</u>	<u>370</u>		<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>5</u>	<u>254T</u>	

SLIDE RAILS: NASON SIZE - BY OTHERS - MTS: STEEL BASE 27 BASE HEN. 33

TYPE "SLF" BASE 1 SPECIFIED DEFLECTION

EDGE CAP SCREW SEE DVG. A-3595



NON-SLIP SURFACE ON BASE OF MOUNT.  
 BOLTING TO FLOOR NOT NECESSARY.


P 9A 1/2

REF. DVG. 134-C-99

SLF NOTE:  
 PAINT BASE WITH  
 45% OF G. GRAY

0000014592  
 2172

NO CONCRETE FILL IN THIS BASE



224

DIESEL GEN. BLDG. PUMP ROOM FAN - OAV52 ORV!

M-51-84



DATE \_\_\_\_\_

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY R. H. H. H. SHEET NO. 10 1/2

PROJECT P.B. ADS UNITS NO. 2 & 3 JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS 1 EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

DIESEL GEN. BLDG. FAN (OAV 64, OBV 64, OCV 64 & ODV 64)

VENDOR PRINT : M-51-57 & M-51-85.

DIESEL GEN. BLDG. BASE EL 151'-0

TOTAL WT. W = 2200 #


ANCHOR BOLTS : 6-1/2" φ & 6-3/4" φ.

DAMPING : 5%

HORIZ. ACC'L "a" = 0.75g (FOR D.B.E.)

OR "a" MAX. = 0.75g x 2.4 = 1.80g (FOR M.C.E.)

HORIZ. FORCE FH = 1.80g x  $\frac{2200\#}{g}$  = 3960 # (FOR M.C.E.)



BY INSPEC. ALL ANCHOR BOLTS ARE OK FOR SEISMIC.

00094

225

00000014593  
2173





DATE 9/25/72

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY *R. Harvey* SHEET NO. 11

PROJECT P.B. APS. UNITS NO. 2 & 3 JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

PUMP STRUCTURE FAN (OAV60, OBV60, OAV61 & OBV61)

VENDOR PRINT: M-70-7

BLDG - PUMP STRUCTURE (INTAKE)

BASE EL 122'-0"

TOTAL WT. W = 1200# (SEE M-480)

ANCHOR BOLTS: 6 - 3/4" φ

DAMPING = 5%

HORIZ. ACC'L "a" = 0.50g (FOR D.B.E.)

OR "a" MAX = 0.5g x 2.4 = 1.2g (FOR M.C.E.)


(SEE P. D-12 IN SEISMIC REPORT FOR PUMP STRUCTURE)

HORIZ. FORCE  $F_H = 1.2g \times \frac{1200\#}{g} = 1440\#$

SHEAR STRESS  $f_v = 1440\# / 6 \text{ BOLTS} = 240\# / \text{BOLT} < 1500\# / 3/4" \phi \text{ A.B.}$   
(OK)

TENSION FORCE =  $1440\# \times \frac{33"}{53.75"} = 890\#$

UPLIFT (TENSION IN BOLT)  $f_t = (890 - \frac{1200}{2}) \times \frac{1}{3 \text{ BOLTS}} = 97\# < 2220\# / 3/4" \phi$   
(OK)



0000014595  
2175

00096

227





DATE \_\_\_\_\_

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY P. H. Hooley SHEET NO. 12

PROJECT P. B. APS. UNITS NO. 2 & 3 JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. US/H

SYSTEM/EQUIPMENT	WT. OF EQUIP.	VENDOR PRINT
RCIC ROOM COOLER (2AV22 & 2BV22)	1500 #	M-77-4
HPCI ROOM COOLER (2AV23 & 2BV23)	2600 #	M-77-5
CORE SPRAY RM. COOLER (2AV24 TO 2HV24)	1470 #	M-77-6
RHR ROOM COOLER (2AV25 TO 2HV25)	2500 #	M-77-7


THESE EQUIPMENTS ARE IN REACTOR BLDG. BASE ELEVATION BELOW EL 135'0 AND ABOVE EL 91'-0 (BETWEEN EL 96'0 & EL 119'-0) AND USE 2% DAMPING, FROM SEISMIC REPOR FOR REACTOR BLDG., WE HAVE HORIZONTAL ACCELERATION "a" = 0.57g (FOR P.B.E.)  
 = OR "a<sub>MAX</sub>" = 0.57g x 2.4 = 1.37g (FOR M.C.E.)

CHECK ANCHOR BOLTS IN WORST CASE — HPCI RM. COOLER (2AV23 & 2BV23)

$$\text{HORIZ. FORCE } F_H = 1.37g \times \frac{2600\#}{g} = 3560\#$$

$$\text{SHEAR STRESS } f_v = \frac{3560}{6 \text{ BOLTS}} = 594\#/\text{BOLT} < 750\#/\frac{1}{2}\text{"} \phi \times 1.89$$

(OK)



$$\text{UPLIFT } F_u = F_H \times \frac{h}{L} - \frac{W}{2}$$

$$= 3560\# \times \frac{41.5}{72.5} - \frac{2600}{2} = 2360 - 2300$$

$$= 60\#$$

$$\text{TENSION STRESS } f_t = \frac{60\#}{3 \text{ BOLTS}} = 20\#/\text{BOLT} < 1400\#/\frac{1}{2}\text{"} \phi \times 1.98$$

(OK)

00097

228

0000014596  
2176



DATE \_\_\_\_\_

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY R.F. Hadjilov SHEET NO. 13

PROJECT P.B. APS, UNITS NO. 2 & 3 JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H


DRYWELL COOLER ( 2AV26 @ EL 143'-0, 2BV26 @ EL 149'-0  
(REACTOR BLDG.) 2CV26 & 2DV26 @ EL 141'-0, 2EV26 @ EL 142'-0  
2FV26 @ EL 128'-0 & 2GV26 @ EL 130'-0)

VENDOR PRINT: M-77-B OR M-77-28

WT. OF EQUIPMENT  $W = 2220 \#$  , 2% DAMPING.

WORST. CONDITION (EL 149'-0) HORIZ. ACC'L "a" = 0.92g (FOR D.B.E.)  
 OR "a" MAX = 0.92 x 2.4 = 2.21g (FOR M.C.E.)

0000014597  
 000002177



$$\text{HORIZ. FORCE } F_H = 2.21g \times \frac{2220}{g} = 4900 \#$$

$$\text{SHEAR STRESS } f_v = \frac{4900}{6 \text{ BOLTS}} = 817 \#/\text{BOLT (OK)}$$

$$\text{ALLOWABLE SHEAR} = 750 \#/\frac{1}{2} \text{ inch A.B.} \times 1.33 = 1000 \#$$

$$\begin{aligned} \text{UPLIFT } F_u &= F_H \times \frac{h}{L} - \frac{W}{2} \\ &= 4900 \# \times \frac{23.5"}{70.5"} - \frac{2220 \#}{2} = 1633 - 1110 \\ &= 523 \# \end{aligned}$$

$$\text{TENSION STRESS } f_t = 523 \#/6 \text{ BOLTS} = 87 \#/\text{BOLT} < 1400 \#/\frac{1}{2} \text{ inch A.B.} \times 1.98$$

(OK)

00098

229



DATE \_\_\_\_\_

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY P. H. HARTMAN SHEET NO. 14 <sup>1/2</sup>

PROJECT P. B. APS UNITS NO. 2 & 3 JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

STANDBY GAS TREATMENT FILTER (OAF34 - OAF35 - OAF36 - OAF37 - OAF65)


(OBF34 - OBF35 - OBF36 - OBF37 - OBF65 ARE SIMILAR)

VENDOR PRINTS M-54-4 & M-54-37

P & I. D. NO. M-38B / 391 / 397

RADWASTE BLDG. SL 91-6 (FIN. GRAD ELEV. 116'-0)

0000014598  
2178



TOTAL WT. OF EQUIPMENTS  $W = 8000 \#$

DAMPING = 2%

HORIZ. ACC'L = 0.15g (GROUND PEAK) (FOR D.B.E.)  
(SEE RECOMMENDED RESPONSE SPECTRA)

MAX. HORIZ. ACC'L = 0.15g x 2.4 = 0.36g

MAX. HORIZ. FORCE  $F_H = 0.36g \times \frac{8000}{g} = 2880 \#$

SHEAR STRESS  $f_v = \frac{2880}{14 \text{ BOLTS}} = 206 \#/\text{BOLT} < 1500 \times 1.33$   
(OK)

UPLIFT FORCE  $F_u = \frac{2880 \times 4.6}{9.33} - \frac{8000}{2} = 1420 - 4000$   
(NEG.)

NO TENSION FORCES IN SUPPORTS (ANCHOR BOLTS)


00099

230

00000514599

107D-850583-E  
SHEET #1 OF 2

23112

AIR FLOW 

INLET VALVE

2'-2"

$\frac{3}{4}$ " DIA. ANCHOR BOLTS  
(14-REQ'D)

HOUSE

2'-10" 7'-6" 6'-9" 7'-6" 4'-10" 4'-3" P14A  
1/2

00100

FOUNDATION REQUIREMENTS

M-54-37

OAF 34 - OAF 35 - OAF 36 - OAF 37 - OAF 65, OR  
OBF 34 - OBF 35 - OBF 36 - OBF 37 - OBF 65

H/PA



DATE \_\_\_\_\_

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY R. Hachay SHEET NO. 15 <sup>1/1</sup>

PROJECT P. B. APS UNITS NO. 2 & 3 JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

CONTROL ROOM VENT. FILTER ( OAF 40 - OAF 41 - OAF 42 - OAF 50 )


( OBF 40 - OBF 41 - OBF 42 - OBF 50 ARE SIMILAR )

VENDOR PRINTS M-54-5 & M-54-38

P & I. D. NO. M-388 / 391 / 397

RADWASTE BLDG. EL 165'0

00000046002180



TOTAL WT. OF EQUIPMENT W = 1700 #

DAMPING = 2%

HORIZ. ACC'L = 1.32g (FOR D. B. E.)

MAX. HORIZ. ACC'L = 1.32g x 2.4 = 3.17g (FOR M. C. E.)

MAX. HORIZ. FORCE  $F_H = 3.17g \times \frac{1700}{g} = 5400 \#$

SHEAR STRESS  $f_v = \frac{F_H}{\text{BOLTS}} = \frac{5400}{8 \text{ BOLTS}} = 675 \#/\text{BOLT} < 1000 \times 1.89$   
(OK)

UPLIFT FORCE  $F_u = \frac{F_H \times h}{L} - \frac{W}{2} = \frac{5400 \times 4.06}{2.62} - \frac{1700}{2} = 7510 \#$

TENSION STRESS PER BOLT  $f_t = \frac{7510 \#}{4 \text{ BOLTS}} = 1880 \#/\text{BOLT} < 1480 \times 1.98$   
(OK)

00101

232



DATE 9/27/72

DESIGN BY R. Hachay

DATE

CHECKED BY W.W.L.

SHEET NO. 16 1/4

PROJECT RB ADS UNITS 2#3

JOB NO. 6280



SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIP ANCHOR BOLTS FILE NO. 48/H

HIGH PRESSURE WATER PUMPS (2AP42 thru 2DP42)

REFERENCES:

LOCATION & ORIENTATION M-272  
 VENDOR PRINT (SPEC. No.) M-11-AC-12  
 C.W. PUMP STRUCTURE BLDG @ EL 113'-0"  
 BOLT TYPE C-89-REV 8#9  
 LOCATION C-86

0000014601  
2181



PLAN of BASE PL'S

MOTOR WGT. = 6,800 #  
 PUMP WGT. = 6,850 #  
 DAMPING = 0.5%  
 HORIZ. ACC'L (D.B.E.) = 1.52g (PEAK)  
 " " (M.C.E.) = 1.52g(2.4) = 3.65g

$F_{H1} = 3.65(6800) = 24,800 \#$   
 $F_{H2} = 3.65(6850) = 25,000 \#$

$\sum M_B = 0 = -F_{H1}(11) + 155F_{H2} - 2.84A - Wgt.(1.42)$

$A = 1/2.84(-11(24800) + 155(25000) - 1.42(13650))$

$A = 33600 \# / 2 \text{ bolts} = 16800 \# / \text{bolt}$

233

ELEV

DESIGN BY R. Hachey

DATE

CHECKED BY W.W.L.

DATE 9/27/72

SHEET NO. 17 <sup>2/4</sup>

PROJECT B.P. APS UNITS 2 & 3

JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIP ANCHOR BOLTS


FILE NO. 4-8/H

$A = 16800 \#/\text{bolt} > 7530 (1.98) = 14910 \#/\text{bolt}$  allow tension  
 ← type 2 anchor bolt w/ 6" hook

DETERMINE HORIZONTAL ACCL

1) Find natural frequency of equipment assuming rigid base between pump and motor

Determine natural frequency of motor



Discharge Head 28" O.D., 3/8" thickness

$$I = 0.0491(d_o^4 - d_i^4) = 0.0491(28^4 - 27.625^4) = 1584.6 \text{ in}^4$$

$$\Delta_M = \frac{WL^3}{3EI} = \frac{6800 (11 \times 12)^3}{3(30 \times 10^6) 1584.6} = 0.11 \text{ in} = 0.0091 \text{ ft}$$

$$\Delta_v = \frac{WL}{A_v G} = \frac{6800 (11 \times 12)}{3.14 (28) (3.75) (11.6 \times 10^6)} = 0.00235 \text{ in} = 0.0002 \text{ ft}$$

small


$$\omega^2 = g / \epsilon \Delta = 32.2 / 0.0093 = 3462.36$$

$$\omega = 58.84 \quad ; \quad f = 58.84 / 6.28 = 9.369 \text{ cps}$$

$$\therefore a = 0.43g \quad ; \quad a_{max} = 0.43g (2.4) = 1.032g$$

Nat. freq. of pump is not equal to that of the motor. The worst condition is minimum acceleration of the pump.

Determine nat. freq. of pump



Pipe Col. 14" O.D., 3/8" thickness

CC003

234



DESIGN BY R. Hachay DATE \_\_\_\_\_ CHECKED BY W.W.L. SHEET NO. 18<sup>3/2</sup>  
 PROJECT B.P. APS UNITS 2#3 JOB NO. 6280  
 SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIP ANCHOR BOLTS FILE NO. 48/H

$$I = 0.0491 (d_1^4 - d_2^4) = 0.0491 (14^4 - 13.625^4) = 194.1 \text{ in}^4$$

$$\Delta_M = \frac{WL^3}{3EI} = \frac{6850 (15.5 \times 12)^3}{3(30 \times 10^6) 194} = 2.525 \text{ in} = 0.21 \text{ ft}$$

$$\omega^2 = 32.2 / 0.21 = 153.33 ; \omega = 12.38$$

$$f = 12.38 / 6.28 = 1.97 \text{ cps} \therefore a = 0.23g \text{ (D.B.E.)}$$

$$\Delta_{max} = 0.23g (2.4) = 0.55g \text{ (M.C.B.)}$$

Use minimum acceleration for motor

ANCHOR BOLT TENSION (CRITICAL CASE SHOWN ONLY)

$$F_{H1} = 1.032 [6800] = 7000 \# ; F_{H2} = 0.117 (2.4) [6850] = 1930 \#$$


$$A = \frac{1}{2} (2.84) [+11 (7000) - 15.5 (1930) - 1.42 (13650)] = 972 \# / 2 \text{ bolts}$$

$$A = 486 \# / \text{bolt} < 1.89 (2540) \text{ allow.}$$

Combined stress is O.K. by inspection since shear is low

$$V = [7000 + 1930] / 4 = 2220 \# / \text{bolt} < 1.89 (2500)$$

MACHINE BOLTS CONNECTING MOTOR BASE PL TO SOLE PL



00004





DESIGN BY R. Hachey DATE \_\_\_\_\_ CHECKED BY W.W.L. SHEET NO. 19 <sup>44</sup>

PROJECT B.P. APS UNITS 2 & 3 JOB NO. 8280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIP ANCHOR BOLTS FILE NO. 48/H

$$M_T = D = 36A + 22(.0611A) + 14(0.389A) + 18(6.8) - 132(7.D)$$

$$D = 55.80A - 1048.6$$

$$A = 18.8 \text{ K} / 2 \text{ bolts} = 9.4 \text{ K} / \text{bolt}$$

$$\text{Allowable} = 1.33 (13.92 \text{ K}) = 18.5 \text{ K} / \text{bolt}$$

O.K.

SHEAR (Max. condition possible)

$$V = [1.032(6800) + 0.55(6850)] / 4 = 2692 \# / \text{bolt}$$

$$\text{Allowable} = 1.39(2500) = 4730 \# / \text{bolt}$$

O.K.

00000  
00000  
00000  
14604  
2184

236

CC005



DATE 9/27/72

DESIGN BY R Hachey

DATE

CHECKED BY W.W.L.

SHEET NO 20 K

PROJECT P.B. APS UNITS NO. 2 & 3

JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIP ANCHOR BOLTS


FILE NO. 48/H

EMERGENCY DIESEL GENERATOR BLDG (DAG12, DBG12, DCG12, & DDG12)

REFERENCES:

VENDOR PRINTS (SPEC. NO.) E5-8  
EQUIPMENT SCHEDULE M-283  
EMERGENCY DIESEL GENERATOR BLDG AT EL 127'  
P. & I. STRUCTURAL DWGS S-551, S-552

010000014605  
2185



EQUIPMENT TOTAL WGT. = 115,700#  
DAMPING = 0.5%

237

00006



DESIGN BY R. Hachay DATE \_\_\_\_\_ CHECKED BY w.wl. SHEET NO. 21 <sup>2/2</sup>

PROJECT P.B. APS UNITS NO. 2#3 JOB NO. 6280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIP. ANCHOR BOLTS FILE NO. 48/H

FLOOR ACCELERATION - SAME AS EQUIPMENT \*

N-S	E-W	DIRECTION
0.158g	0.13g	D.B.E. FROM SEISMIC REPORT
0.2g	0.2g	D.B.E. FROM U.B.C.
0.48g	0.48g	M.C.E. BASED ON U.B.C.

MAX. HORIZ. FORCE = 0.48 (115,700) = 55,400 #

SHEAR

$$F_v = \frac{55400}{12 \text{ bolts}} = 4620 \#/\text{bolt} < 1.89(2500) = 4730 \#/\text{bolt} \text{ (OK)}$$

UPLIFT FORCE - NOW EXISTENT IN EITHER DIRECTION (N-S DIRECT. SHOWN)

$$F_u = \frac{55400(4.534)}{7.25} - \frac{115700}{2} = \text{ALL BOLTS COMPRESSION} \text{ (OK)}$$

\* SINCE THE FLOOR NAT. FREQ. IS GREATER THAN 20 CPS AND THE DIESEL GENERATOR IS CONNECTED TO THE FLOOR AS A RIGID BODY, USE THE HIGH FREQ. END OF THE ACCELERATION SPECTRA FOR CHECKING EQUIPMENT ANCHOR BOLTS.

238

00007

0000014606  
2186



CALCULATION SHEET

0510 (5-71)

DATE 9/28/72

DESIGN BY WILSON W. LEONG DATE \_\_\_\_\_ CHECKED BY \_\_\_\_\_ SHEET NO. 22

PROJECT P.B. APS UNITS NO. 2 & 3 JOB NO. 0280

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

2AE55 ( RCIC COMPARTMENT COOLERS ) ----- SIMILAR TO 2AV22

2BE55 ( " " " ) ----- SIMILAR TO 2BV22

2AE56 ( HPIC COMPARTMENT COOLERS ) ----- " " 2AV23

2BE56 ( " " " ) ----- " " 2BV23

2AE57 ( CORE SPRAY ROOM COOLERS ) ----- " " 2AV24

TO TO

2HE57 ( CORE SPRAY ROOM COOLERS ) ----- " " 2HV24

2AE58 ( RHR COMPARTMENT COOLERS ) ----- " " 2AV25

TO TO

2HE58 ( RHR COMPARTMENT COOLERS ) ----- " " 2HV25

REFER CALC. PAGE NO. 12

0000014607  
2187

239

00008



DATE 9/28/72

DESIGN BY R. Hachey

DATE

CHECKED BY W.W.L.

SHEET NO. 23 1/4

PROJECT P.B. ADS UNITS 2 & 3

JOB NO. 6280



SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIPMENT ANCHOR BOLTS FILE NO. 48/H

EMERGENCY SERVICE WATER PUMP (DAP57 & DBP57)

REFERENCES:

LOCATION & ORIENTATION M-272  
 VENDOR PRINT (SPEC. No.) M-11-AC-13  
 C.W. PUMP STRUCTURE BLDG @ EL. 113'-1"  
 BOLT TYPE - C-89-REV 8 & 9  
 LOCATION C-86

0000014608  
2188



PLAN of BASE PL'S

MOTOR WGT. = 3,000 #  
 PUMP WGT. = 5,500 #  
 DAMPING = 0.5%  
 HORIZ. Acc'L (D.B.E.) = 1.52g (PEAK)  
 " " (M.C.E.) = 1.52(2.4) = 3.65g

$F_{H1} = 3.65(3000) = 10,950 \#$   
 $F_{H2} = 3.65(5500) = 20,000 \#$

ELEV.

$$(+M_B = 0 = -F_{H1}(6.3) + 15F_{H2} - 3.16A - WGT(3.16/2)$$

$$A = -1.99F_{H1} + 4.75F_{H2} - 0.5 WGT$$

240

00009







CALCULATION SHEET

0510 (8-71)

DATE 9/28/72

DESIGN BY R. Hachay

DATE

CHECKED BY W.W.L.

SHEET NO. 28

4/4

PROJECT RB. APS UNITS 2 & 3

JOB NO. S28D

SUBJECT SEISMIC ANALYSIS FOR CLASS I EQUIP ANCHOR BOLTS FILE NO. 48/4

$1707 \#/\text{bolt} < 1.33(13.92 \text{ k}) \text{ allow - AISC O.K.}$

SHEAR (max condition possible)

$V = 0.56(3000) + 0.75(5500) = 5810 \#/\text{bolts}$

$V = 1452 \#/\text{bolt} < 1.89(2500) \#/\text{bolt allow}$

2191  
24611  
0000014611  
000000014611  
0000000014611  
00000000014611

243

00012