



Survey Unit Release Record

Design #	EP-PPH 105	Revision #	Original	Page 1 of 3
Survey Unit #(s)	PPH 105			
Description	<p>1) Embedded Pipe (EP) Survey Unit PPH 105 meets the definition of embedded pipe for Plum Brook Reactor Facility (PBRF) for those portions of piping embedded in the building foundation walls (PPH and Hot Pipe Tunnel). The portion of piping which transits in soil under and between the buildings does not meet the criteria for embedded piping. The complete piping will be grouted, the portions embedded in the building structure will remain embedded for any future reuse, those portions in the ground can be released for unrestricted use.</p> <p>2) EP PPH 105 is a Class 1, Group 1 survey unit as per the PBRF Final Status Survey Plan (FSSP) and Technical Basis Document (TBD)-06-004.</p> <p>3) Surveys in EP PPH 105 were performed using a scintillation detector optimized to measure gamma energies representative of Co-60. Sample #EP 3-9 from Survey Request (SR)-13 was referenced for this decision.</p> <p>4) Survey Instructions for this survey unit are incorporated into and performed in accordance with (IAW) the Babcock Services Incorporated (BSI)/LVS-002, Work Execution Package (WEP) 05-006. Survey instructions described in this document constitute "Special Methods" and the survey design used in the acquisition of survey measurements.</p> <p>5) Instrument efficiency determinations are developed in accordance with the BSI/LVS-002, WEP 05-006, these determinations are appropriate for the types of radiation involved and the media being surveyed.</p>			
Approval Signatures			Date:	
FSS/Characterization Engineer			3/2/08	
FSS/Characterization Manager	 <small>R. Case</small>		3/6/08	

Survey Unit: PPH 105

1.0 History/Description

- 1.1 The subject pipe is an 8" air exhaust line from PPH Room 4 to the HPT.
- 1.2 EP PPH 105 consists of 8" diameter piping that is approximately 174 feet in length.

2.0 Survey Design Information

- 2.1 EP PPH 105 was surveyed IAW Procedure #BSI/LVS-002.
- 2.2 100% of the 8" pipe was accessible for survey. The accessible 8" pipe was surveyed by static measurement at one foot increments, for a total of 174 survey measurements.
- 2.3 Surface area for the 8" piping is 1946 cm² for each foot of piping, corresponding to a total 8" piping surface area of 338604 cm² (33.9 m²) for the entire length of (approximately 174') of 8" piping.

3.0 Survey Unit Measurement Locations/Data

- 3.1 Pipe interior radiological survey forms are provided in Attachment 2 of this release record.

4.0 Survey Unit Investigations/Results

- 4.1 None

5.0 Data Assessment Results

- 5.1 Data assessment results are provided in the EP/Buried Pipe (BP) Survey Report provided in Attachment 1.
- 5.2 This survey unit was assessed as a building re-use scenario with all activity derived dose as a 100% Co60 nuclide distribution. This is the most conservative DCGL for the facility (11,000dpm/100cm²).
- 5.3 When implementing the Unity Rule, provided in Section 3.6.3 of the FSSP, four survey measurements exceeded unity. The survey unit that is constituted by EP PPH 105 passes FSS after application of Elevated Measurement Comparisons (EMC) and Elevated Measurement Tests (EMT). The EMC Unity sum was 0.105 of unity, and the EMT Unity sum was 0.559 of unity.
- 5.4 DCGL's for the building reuse scenario are used to demonstrate compliance with the release criterion for this release record. The DCGL's for embedded pipe are not applied, therefore the Structural Area Factors listed in Table 3-5 of the FSS are the appropriate area factors for EMC and EMT evaluations.
- 5.5 The area factor of 40.2 was utilized for this survey unit, this is the appropriate area factor listed in Table 3-5 of the PBRF FSSP.
- 5.6 Background was not subtracted from the survey measurements.

Survey Unit: PPH 105

5.7 Statistical Summary Table

Statistical Parameter	8" Pipe
Total Number of Survey Measurements	174
Number of Measurements >MDC	168
Number of Measurements Above 50% of DCGL	70
Number of Measurements Above DCGL	4
Mean	0.516
Median	0.436
Standard Deviation	0.235
Maximum	1.121
Minimum	0.062

6.0 Documentation of evaluations pertaining to compliance with the unrestricted use limit of 25 mrem/yr and dose contributions from Embedded Pipe and radionuclides contributing 10% in aggregate of the total dose for both structural scenarios and soils.

6.1 A review of the survey results has shown that the dose contribution for EP PPH 105 to be less than 25 mrem/yr. The dose contribution is estimated to be 12.9 mrem/yr based on the average of the actual gross counts measured.

7.0 Attachments

Attachment 1 – BSI EP/BP Survey Report

Attachment 2 – Pipe Interior Radiological Survey Form

Attachment 3 – DQA Worksheet

Attachment 4 – EP PPH 105 SURR & Spreadsheet Disc

**SECTION 7
ATTACHMENT 1
6 PAGES**



BSI EP/BP SURVEY REPORT

Pipe ID	PPH 105	Survey Location	HPT to PPH RM 4
Survey Date	5-18-06, 6-14-06, 6-15-06	2350-1 #	212223 / 203488
Survey Time	See Survey Sheets	Detector-Sled #	LVS1-107
Pipe Size	8"	Detector Efficiency	0.00015
DCGL (dpm/100cm2)	1.10E+04	Pipe Area Incorporated by Detector Efficiency (in cm2)	1946
Pipe Area Incorporated by Survey Data (m ²)	33.9	Field BKG (cpm)	See Survey Sheets
Routine Survey	X	Field MDCR (cpm)	See Survey Sheets
QA Survey		Nominal MDC (dpm/100cm2)	3,394
Survey Measurement Results			
Total Number of Survey Measurements		174	
Number of Measurements >MDC		168	
Number of Measurements Above 50% DCGL		70	
Number of Measurements Above DCGL		4	
Mean		0.516	
Median		0.436	
Standard Deviation		0.235	
Maximum		1.121	
Minimum		0.062	
Survey Technician(s)	STOCK		
Survey Unit Classification		1	
TBD 06-004 Piping Group		1	
SR-13 Radionuclide Distribution Sample		EP 3-9	
Measured Nuclide		Co-60	
Area Factor/EMC Used		Yes	
Pass/Fail FSS		Pass	
MREM/YR Contribution		<25	
COMMENTS:			
ACTIVITY VALUES NOT BACKGROUND CORRECTED.			
RP Engineer Date	<i>Wood</i> / 3-2-08		

PPH 105
8" Pipe
TBD 06-004 Group 1

Measurement #	gcpm	ncpm	Co-60 activity (total dpm)	Co-60 activity (dpm/100cm2)	Unity	EMC Unity	EMT Unity	
1	15	15	100,000	5,139	0.467		0.467	
2	21	21	140,000	7,194	0.654		0.654	
3	16	16	106,667	5,481	0.498		0.498	
4	13	13	86,667	4,454	0.405		0.405	
5	19	19	126,667	6,509	0.592		0.592	
6	17	17	113,333	5,824	0.529		0.529	
7	17	17	113,333	5,824	0.529		0.529	
8	13	13	86,667	4,454	0.405		0.405	
9	13	13	86,667	4,454	0.405		0.405	
10	10	10	66,667	3,426	0.311		0.311	
11	11	11	73,333	3,768	0.343		0.343	
12	12	12	80,000	4,111	0.374		0.374	
13	15	15	100,000	5,139	0.467		0.467	
14	14	14	93,333	4,796	0.436		0.436	
15	18	18	120,000	6,166	0.561		0.561	
16	17	17	113,333	5,824	0.529		0.529	
17	16	16	106,667	5,481	0.498		0.498	
18	18	18	120,000	6,166	0.561		0.561	
19	20	20	133,333	6,852	0.623		0.623	
20	12	12	80,000	4,111	0.374		0.374	
21	22	22	146,667	7,537	0.685		0.685	
22	15	15	100,000	5,139	0.467		0.467	
23	12	12	80,000	4,111	0.374		0.374	
24	18	18	120,000	6,166	0.561		0.561	
25	12	12	80,000	4,111	0.374		0.374	
26	22	22	146,667	7,537	0.685		0.685	
27	17	17	113,333	5,824	0.529		0.529	
28	20	20	133,333	6,852	0.623		0.623	
29	22	22	146,667	7,537	0.685		0.685	
30	17	17	113,333	5,824	0.529		0.529	
31	24	24	160,000	8,222	0.747		0.747	
32	20	20	133,333	6,852	0.623		0.623	
33	19	19	126,667	6,509	0.592		0.592	
34	21	21	140,000	7,194	0.654		0.654	
35	17	17	113,333	5,824	0.529		0.529	
36	32	32	213,333	10,963	0.997		0.997	
37	30	30	200,000	10,277	0.934		0.934	
38	29	29	193,333	9,935	0.903		0.903	
39	33	33	220,000	11,305	1.028	0.026		0.013

PPH 105
8" Pipe
TBD 06-004 Group 1

Measurement #	gcpm	ncpm	Co-60 activity (total dpm)	Co-60 activity (dpm/100cm2)	Unity	EMC Unity	EMT Unity	
40	31	31	206,667	10,620	0.965		0.965	
41	29	29	193,333	9,935	0.903		0.903	
42	15	15	100,000	5,139	0.467		0.467	
43	29	29	193,333	9,935	0.903		0.903	
44	26	26	173,333	8,907	0.810		0.810	
45	22	22	146,667	7,537	0.685		0.685	
46	32	32	213,333	10,963	0.997		0.997	
47	30	30	200,000	10,277	0.934		0.934	
48	21	21	140,000	7,194	0.654		0.654	
49	29	29	193,333	9,935	0.903		0.685	
50	33	33	220,000	11,305	1.028	0.026		0.013
51	30	30	200,000	10,277	0.934		0.934	
52	36	36	240,000	12,333	1.121	0.028		0.015
53	32	32	213,333	10,963	0.997		0.997	
54	28	28	186,667	9,592	0.872		0.997	
55	25	25	166,667	8,565	0.779		0.872	
56	23	23	153,333	7,879	0.716		0.779	
57	30	30	200,000	10,277	0.934		0.716	
58	30	30	200,000	10,277	0.934		0.934	
59	26	26	173,333	8,907	0.810		0.934	
60	25	25	166,667	8,565	0.779		0.810	
61	29	29	193,333	9,935	0.903		0.779	
62	20	20	133,333	6,852	0.623		0.903	
63	27	27	180,000	9,250	0.841		0.623	
64	29	29	193,333	9,935	0.903		0.841	
65	24	24	160,000	8,222	0.747		0.747	
1	14	14	93,333	4,796	0.436		0.436	
2	14	14	93,333	4,796	0.436		0.436	
3	13	13	86,667	4,454	0.405		0.405	
4	12	12	80,000	4,111	0.374		0.374	
5	13	13	86,667	4,454	0.405		0.405	
6	13	13	86,667	4,454	0.405		0.405	
7	8	8	53,333	2,741	0.249		0.249	
8	18	18	120,000	6,166	0.561		0.561	
9	21	21	140,000	7,194	0.654		0.654	
10	14	14	93,333	4,796	0.436		0.436	
11	10	10	66,667	3,426	0.311		0.311	
12	12	12	80,000	4,111	0.374		0.374	
13	17	17	113,333	5,824	0.529		0.529	
14	12	12	80,000	4,111	0.374		0.374	

PPH 105
8" Pipe
TBD 06-004 Group 1

Measurement #	gcpm	ncpm	Co-60 activity (total dpm)	Co-60 activity (dpm/100cm ²)	Unity	EMC Unity	EMT Unity
15	10	10	66,667	3,426	0.311		0.311
16	21	21	140,000	7,194	0.654		0.654
17	24	24	160,000	8,222	0.747		0.747
18	18	18	120,000	6,166	0.561		0.561
19	15	15	100,000	5,139	0.467		0.467
20	15	15	100,000	5,139	0.467		0.467
21	15	15	100,000	5,139	0.467		0.467
22	14	14	93,333	4,796	0.436		0.436
23	26	26	173,333	8,907	0.810		0.810
24	27	27	180,000	9,250	0.841		0.841
25	28	28	186,667	9,592	0.872		0.872
1	14	14	93,333	4,796	0.436		0.436
2	10	10	66,667	3,426	0.311		0.311
3	9	9	60,000	3,083	0.280		0.280
4	9	9	60,000	3,083	0.280		0.280
5	10	10	66,667	3,426	0.311		0.311
6	14	14	93,333	4,796	0.436		0.436
7	7	7	46,667	2,398	0.218		0.218
8	11	11	73,333	3,768	0.343		0.343
9	11	11	73,333	3,768	0.343		0.343
10	16	16	106,667	5,481	0.498		0.498
11	7	7	46,667	2,398	0.218		0.218
12	6	6	40,000	2,055	0.187		0.187
13	11	11	73,333	3,768	0.343		0.343
14	10	10	66,667	3,426	0.311		0.311
15	8	8	53,333	2,741	0.249		0.249
16	10	10	66,667	3,426	0.311		0.311
17	9	9	60,000	3,083	0.280		0.280
18	11	11	73,333	3,768	0.343		0.343
19	14	14	93,333	4,796	0.436		0.436
20	10	10	66,667	3,426	0.311		0.311
21	11	11	73,333	3,768	0.343		0.343
22	15	15	100,000	5,139	0.467		0.467
23	11	11	73,333	3,768	0.343		0.343
24	12	12	80,000	4,111	0.374		0.374
1	10	10	66,667	3,426	0.311		0.311
2	16	16	106,667	5,481	0.498		0.498
3	13	13	86,667	4,454	0.405		0.405
4	6	6	40,000	2,055	0.187		0.187
5	12	12	80,000	4,111	0.374		0.374

PPH 105
8" Pipe
TBD 06-004 Group 1

Measurement #	gcpm	ncpm	Co-60 activity (total dpm)	Co-60 activity (dpm/100cm2)	Unity	EMC Unity	EMT Unity
6	13	13	86,667	4,454	0.405		0.405
7	11	11	73,333	3,768	0.343		0.343
8	10	10	66,667	3,426	0.311		0.311
9	9	9	60,000	3,083	0.280		0.280
10	17	17	113,333	5,824	0.529		0.529
11	12	12	80,000	4,111	0.374		0.374
12	13	13	86,667	4,454	0.405		0.405
13	13	13	86,667	4,454	0.405		0.405
14	10	10	66,667	3,426	0.311		0.311
15	7	7	46,667	2,398	0.218		0.218
16	10	10	66,667	3,426	0.311		0.311
17	2	2	13,333	685	0.062		0.062
18	11	11	73,333	3,768	0.343		0.343
19	15	15	100,000	5,139	0.467		0.467
20	13	13	86,667	4,454	0.405		0.405
21	12	12	80,000	4,111	0.374		0.374
22	11	11	73,333	3,768	0.343		0.343
23	14	14	93,333	4,796	0.436		0.436
24	14	14	93,333	4,796	0.436		0.436
25	7	7	46,667	2,398	0.218		0.218
26	8	8	53,333	2,741	0.249		0.249
27	12	12	80,000	4,111	0.374		0.374
28	8	8	53,333	2,741	0.249		0.249
29	10	10	66,667	3,426	0.311		0.311
30	12	12	80,000	4,111	0.374		0.374
31	8	8	53,333	2,741	0.249		0.249
32	11	11	73,333	3,768	0.343		0.343
33	8	8	53,333	2,741	0.249		0.249
34	6	6	40,000	2,055	0.187		0.187
35	9	9	60,000	3,083	0.280		0.280
36	12	12	80,000	4,111	0.374		0.374
37	10	10	66,667	3,426	0.311		0.311
38	10	10	66,667	3,426	0.311		0.311
39	16	16	106,667	5,481	0.498		0.498
40	9	9	60,000	3,083	0.280		0.280
41	13	13	86,667	4,454	0.405		0.405
42	10	10	66,667	3,426	0.311		0.311
43	19	19	126,667	6,509	0.592		0.592
44	10	10	66,667	3,426	0.311		0.311
45	9	9	60,000	3,083	0.280		0.280

PPH 105
8" Pipe
TBD 06-004 Group 1

Measurement #	gcpm	ncpm	Co-60 activity (total dpm)	Co-60 activity (dpm/100cm2)	Unity	EMC Unity	EMT Unity	
46	12	12	80,000	4,111	0.374		0.374	
47	18	18	120,000	6,166	0.561		0.561	
48	11	11	73,333	3,768	0.343		0.343	
49	10	10	66,667	3,426	0.311		0.311	
50	14	14	93,333	4,796	0.436		0.436	
51	7	7	46,667	2,398	0.218		0.218	
52	22	22	146,667	7,537	0.685		0.343	
53	17	17	113,333	5,824	0.529		0.685	
54	34	34	226,667	11,648	1.059	0.026		0.014
55	30	30	200,000	10,277	0.934		0.934	
56	30	30	200,000	10,277	0.934		0.934	
57	24	24	160,000	8,222	0.747		0.934	
58	21	21	140,000	7,194	0.654		0.747	
59	31	31	206,667	10,620	0.965		0.965	
60	32	32	213,333	10,963	0.997		0.997	
				5,538		0.105	0.559	
				MEAN	0.516	EMC Unity	EMT Unity	
				MEDIAN	0.436			
				STD DEV	0.235			
				MAX	1.121			
				MIN	0.062			

**SECTION 7
ATTACHMENT 2
14 PAGES**

Pipe Interior Radiological Survey Form

Date: 5/18/06 Time: 1027
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: HOT PIPE TUNNEL
 Building: FAN HOUSE Elevation: -12' System: ~~FAN HOUSE~~ AIR EXHAUST

Type of Survey Investigation Characterization Final Survey Other

Gross Co60 Cs

Detector ID# / Sled ID# BICRON IMGI LVS-1 / 107
 Detector Cal Date: 12/20/05 Detector Cal Due Date: 12/20/06
 Instrument: 2350-1 Instrument ID #: 212223
 Instrument Cal Date: 11/7/05 Instrument Cal Due Date: 11/7/06

From the Daily Pipe Survey Detector Control Form for the Selected Detector

Background Value 22 cpm
 MDCR_{static} 19.2 cpm
 Efficiency Factor for Pipe Diameter 0.00015 (from detector efficiency determination)
 MDC_{static} 3394 dpm/ 100 cm²
 Is the MDC_{static} acceptable? Yes No (if no, adjust sample count time and recalculate MDCR_{static})
 Comments: INITIAL SURVEY
EP3-7

Technician Signature [Signature]

Pipe Interior Radiological Survey

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
1	1	1	15	15	na	n/a
2	2	↓	21	21	↓	↓
3	3		16	16		
4	4		13	13		
5	5		19	19		
6	6		17	17		
7	7		17	17		
8	8		13	13		
9	9		13	13		
10	10		10	10		



Pipe Interior Radiological Survey Form (Continuation Form)

Date: 5/18/06
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: FAN HOUSE -12'
 Building: FAN HOUSE Elevation: -12' System: AIR EXHAUST

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
11	11	1	11	11	N/A	N/A
12	12		12	12		
13	13		15	15		
14	14		14	14		
15	15		18	18		
16	16		17	17		
17	17		16	16		
18	18		18	18		
19	19		20	20		
20	20		12	12		
21	21		22	22		
22	22		15	15		
23	23		12	12		
24	24		18	18		
25	25		12	12		
26	26		22	22		
27	27		17	17		
28	28		20	20		
29	29		22	22		
30	30		17	17		
31	31		24	24		
32	32		20	20		
33	33		19	19		
34	34		21	21		
35	35		17	17		
36	36		32	32		
37	37		30	30		
38	38		29	29		
39	39		33	33		
40	40		31	31		
41	41		29	29		
42	42		15	15		
43	43		29	29		
44	44		26	26		
45	45		22	22		

Package Page 2 of 4









Pipe Interior Radiological Survey Form (Continuation Form)

Date: 5/18/06
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: FAN HOUSE 12'
 Building: FAN HOUSE Elevation: -12' System: AIR EXHAUST

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
46	46	1	34	32	n/a	n/a
47	47	↓	30	30	↓	↓
48	48		21	21		
49	49		29	29		
50	50		33	33		
51	51		30	30		
52	52		36	36		
53	53		32	32		
54	54		28	28		
55	55		25	25		
56	56		23	23		
57	57		30	30		
58	58		30	30		
59	59		26	26		
60	60		25	25		
61	61		29	29		
62	62		20	20		
63	63		27	27		
64	64	29	29			
65	65	24	24			





Drawing PF-00778

-00778

REFERENCE COPY

Pages 4 of 4

[Pink highlight] = pipe surveyed

SCALE	REFERENCES	INITIAL	DATE	CHANGE
1/8" = 1'-0"	CF-122651	DR. BZ	3/2002	NA
	CF-114850	CK. BVD	3/1995	
	CF-114857	DR. ENG. V		

Pipe Interior Radiological Survey Form

Date: 6/14/06 Time: 1251
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: PPH Rm #4
 Building: PPH Elevation: -3 System: AIR EXHAUST

Type of Survey Investigation _____ Characterization _____ Final Survey X Other ✓

Gross _____ Co60 ✓ Cs _____

Detector ID# / Sled ID# RIKRON IMG1 LVS-11 107

Detector Cal Date: 12/20/05 Detector Cal Due Date: 12/20/06

Instrument: 2350-1 Instrument ID #: 203486

Instrument Cal Date: 11/17/05 Instrument Cal Due Date: 11/17/06

From the Daily Pipe Survey Detector Control Form for the Selected Detector

Background Value 17.7 cpm

MDCR_{static} 17.5 cpm

Efficiency Factor for Pipe Diameter 0.00015 (from detector efficiency determination)

MDC_{static} 3394 dpm/ 100 cm²


Is the MDC_{static} acceptable? Yes No (if no, adjust sample count time and recalculate MDC_{static})

Comments: CONTINUATION SURVEY

Technician Signature [Signature]

Pipe Interior Radiological Survey

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
1	1	1	14	14	n/a	n/a
2	2	↓	14	14	↓	↓
3	3		13	13		
4	4		12	12		
5	5		13	13		
6	6		13	13		
7	7		8	8		
8	8		18	18		
9	9		21	21		
10	10		14	14		



Pipe Interior Radiological Survey Form (Continuation Form)


Date: 6/14/06
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: PPH Rm #4
 Building: PPH Elevation: -3' System: Air EXHAUST

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
11	11	1	10	10	n/a	n/a
12	12	↓	12	12	↓	↓
13	13		17	17		
14	14		12	12		
15	15		10	10		
16	16		21	21		
17	17		24	24		
18	18		18	18		
19	19		15	15		
20	20		15	15		
21	21		15	15		
22	22		14	14		
23	23		26	26		
24	24		27	27		
25	25		28	28		
26	26		N/A	N/A		
N A						







PIPE SURVEY ED PPH-105

200 G.P.M. PUMP 4" DISCH.
(FAIRBANKS-MORSE & CO.
TYPE 31C)



500 G.P.M. PUMP 6" DISCH.
(FAIRBANKS-MORSE & CO.
TYPE 10LC)



REFERENCE COPY

3 of 3
PAGE

Pipe Interior Radiological Survey Form

Date: 6/14/06 Time: 1335
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: PPH Rm # 4
 Building: PPH Elevation: -3 System: AIR EXHAUST

Type of Survey Investigation Characterization Final Survey Other
 Gross Co60 Cs

Detector ID# / Sled ID# BICRON IMGI LVS-1 / 107

Detector Cal Date: 12/20/05 Detector Cal Due Date: 12/20/06

Instrument: 2350-1 Instrument ID #: 203488

Instrument Cal Date: 11/17/05 Instrument Cal Due Date: 11/17/06

From the Daily Pipe Survey Detector Control Form for the Selected Detector

Background Value 17.7 cpm


MDCR_{static} 17.5 cpm

Efficiency Factor for Pipe Diameter 0.00015 (from detector efficiency determination)

MDC_{static} 3394 dpm/ 100 cm²

Is the MDC_{static} acceptable? Yes No (if no, adjust sample count time and recalculate MDCR_{static})

Comments: CONTINUATION SURVEY

Technician Signature 

Pipe Interior Radiological Survey

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
1	1	1	14	14	n/a	n/a
2	2		10	10		
3	3		9	9		
4	4		9	9		
5	5		10	10		
6	6		14	14		
7	7		7	7		
8	8		11	11		
9	9		11	11		
10	10		16	16		



Pipe Interior Radiological Survey Form (Continuation Form)



Date: 6/14/06
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: PPH Rm #4
 Building: PPH Elevation: -3' System: AIR EXHAUST

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
11	11	1	7	7	n/a	n/a
12	12	↓	6	6	↓	↓
13	13		11	11		
14	14		10	10		
15	15		8	8		
16	16		10	10		
17	17		9	9		
18	18		11	11		
19	19		14	14		
20	20		10	10		
21	21		11	11		
22	22		15	15		
23	23		11	11		
24	24		12	12		
<div style="display: flex; justify-content: space-around; align-items: center;"> N A </div>						


PIPE SURVEYED
PPH-105

200 G.P.M. PUMP - 4" DISCH.
(FAIRBANKS-MORSE & CO.
TYPE 51C)

PAGE
3 of 3



REFERENCE COPY



Pipe Interior Radiological Survey Form

Date: 6/15/06 Time: 1116
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: PPH Rm #4
 Building: PPH Elevation: 0 System: AIR EXHAUST

Type of Survey Investigation Characterization Final Survey Other
 Gross Co60 Cs

Detector ID# / Sled ID# BEKON1M61 LUS-11 107
 Detector Cal Date: 12-20-05 Detector Cal Due Date: 12-20-06
 Instrument: 2350-1 Instrument ID #: 203488
 Instrument Cal Date: 11/17/05 Instrument Cal Due Date: 11/17/06

From the Daily Pipe Survey Detector Control Form for the Selected Detector

Background Value 17.9 cpm
 MDCR_{static} 17.6 cpm
 Efficiency Factor for Pipe Diameter 0.00015 (from detector efficiency determination)
 MDC_{static} 3394 dpm/ 100 cm²
 Is the MDC_{static} acceptable? Yes No (if no, adjust sample count time and recalculate MDCR_{static})
 Comments: CONTINUATION SURVEY EP3-7 COMPLETE

Technician Signature [Signature]

Pipe Interior Radiological Survey

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
1	25	1	10	10	n/a	n/a
2	26	↓	16	16	↓	↓
3	27		13	13		
4	28		6	6		
5	29		12	12		
6	30		13	13		
7	31		11	11		
8	32		10	10		
9	33		9	9		
10	34		17	17		



Pipe Interior Radiological Survey Form (Continuation Form)

Date: 6/15/06
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: PPH Rm #4
 Building: PPH Elevation: 0' System: AIR EXHAUST

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
11	35	1	12	12	n/a	n/a
12	36		13	13		
13	37		13	13		
14	38		10	10		
15	39		7	7		
16	40		10	10		
17	41		2	2		
18	42		11	11		
19	43		15	15		
20	44		13	13		
21	45		12	12		
22	46		11	11		
23	47		14	14		
24	48		14	14		
25	49		7	7		
26	50		8	8		
27	51		12	12		
28	52		8	8		
29	53		10	10		
30	54		12	12		
31	55		8	8		
32	56		11	11		
33	57		8	8		
34	58		6	6		
35	59		9	9		
36	60		12	12		
37	61		10	10		
38	62		10	10		
39	63		16	16		
40	64		9	9		
41	65		13	13		
42	66		10	10		
43	67		19	19		
44	68		10	10		
45	69		9	9		



Pipe Interior Radiological Survey Form (Continuation Form)






Date: 6/15/86
 Pipe ID#: PPH-105 Pipe Diameter: 8" Access Point Area: PPH-RA
 Building: PPH Elevation: 0' System: AIR EXHAUST

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm ²
46	70	1	12	12	n/a	n/a
47	71	↓	18	18	↓	↓
48	72		11	11		
49	73		10	10		
50	74		14	14		
51	75		7	7		
52	25 76		22	22		
53	77		17	17		
54	78		34	34		
55	79		30	30		
56	80		30	30		
57	81		24	24		
58	82		21	21		
59	83		31	31		
60	84	32	32			

Package Page 3 of 4

REFERENCE COPY

REFERENCE COPY



GENERAL NOTES

1. FOR SCHEDULE OF DRAWINGS SEE PPH-00450.
2. ALL FLOOR DRAIN PIPING SHALL BE SUTHERLAND VENT SYSTEM SCHEDULE 40 W.P. PIPE WITH WELDED FITTINGS.
3. ALL VENT SYSTEM PIPING SHALL BE SUTHERLAND VENT SYSTEM SCHEDULE 40 W.P. PIPE WITH WELDED FITTINGS.
4. SEE DRAWING PPH-00450 FOR PIPE SCHEDULES AND WALLS.

NO.	DESCRIPTION	DATE	BY	CHK.
A	ADDED PUMP LEAKAGE COMPARTMENT AIR PER CODES 29	12/17
B
C
D
E
F
G
H
I
J
K
L
M
N
O
P
Q
R
S
T
U
V
W
X
Y
Z

PPH floor drain - PF-00514

NASA PLUM BRACK REACTOR FAC. 1144
REACTOR-PRIMARY PUMP WOLVIC-PH-105
FLOOR DRAIN & VENT SYSTEM
PLAN - SECTIONS & DETAILS
REVISIONS: QUANTITY FOR ISSUANCE
LEADS PLUM PERFORMER LIMITED
OCTOBER, 1968

PE00514

- PIPE SURVEYED
PPH - 105

**SECTION 7
ATTACHMENT 3
1 PAGE**

DQA Check Sheet

Design #	EP PPH-105	Revision #	Original	
Survey Unit #	EP PPH-105			

Preliminary Data Review

Answers to the following questions should be fully documented in the Survey Unit Release Record	Yes	No	N/A
1. Have surveys been performed in accordance with survey instructions in the Survey Design?	X		
2. Is the instrumentation MDC for structure static measurements below the DCGL _w for Class 1 and 2 survey units, or below 0.5 DCGL _w for Class 3 survey units?			X
3. Is the instrumentation MDC for embedded/buried piping static measurements below the DCGL _w ?	X		
4. Was the instrumentation MDC for structure scan measurements, soil scan measurements, and embedded/buried piping scan measurements below the DCGL _w , or, if not, was the need for additional static measurements or soil samples addressed in the survey design?			X
5. Was the instrumentation MDC for volumetric measurements and smear analysis < 10% DCGL _w ?			X
6. Were the MDCs and assumptions used to develop them appropriate for the instruments and techniques used to perform the survey?	X		
7. Were the survey methods used to collect data proper for the types of radiation involved and for the media being surveyed?	X		
8. Were "Special Methods" for data collection properly applied for the survey unit under review?	X		
9. Is the data set comprised of qualified measurement results collected in accordance with the survey design, which accurately reflects the radiological status of the facility?	X		

Graphical Data Review

1. Has a posting plot been created?			X
2. Has a histogram (or other frequency plot) been created?			X
3. Have other graphical data tools been created to assist in analyzing the data?			X

Data Analysis

1. Are all sample measurements below the DCGL _w (Class 1 & 2), or 0.5 DCGL _w (Class 3)?		X	
2. Is the mean of the sample data < DCGL _w ?	X		
3. If elevated areas have been identified by scans and/or sampling, is the average activity in each elevated area < DCGL _{EMC} (Class 1), < DCGL _w (Class 2), or < 0.5 DCGL _w (Class 3)?	X		
4. Is the result of the Elevated Measurements Test < 1.0?	X		
5. Is the result of the statistical test (S+ for Sign Test or W_r for WRS Test) ≥ the critical value?			X

Comments:

See Section 5 of this Survey Unit Release Record

FSS/Characterization Engineer (print/sign)	<i>C. Wood / [Signature]</i>	Date	3/2/08
FSS/ Characterization Manager (print/sign)	R. Case <i>[Signature]</i>	Date	3/6/08

Form
CS-09/2
Rev 0

**SECTION 7
ATTACHMENT 4
1 DISC**