

## 1.7 Drawings

The information in this section of the reference ABWR DCD, including all tables and figures, is incorporated by reference with the following site-specific supplements.

Table 1.7-6 is a supplemental tabulation of additional or updated instrumentation and control (I&C) functional diagrams and electrical one-line diagrams, including legends for electrical power, I&C, lighting, and communication drawings.

Table 1.7-7 is a supplemental tabulation of system drawings and system designators for systems not included in the reference ABWR DCD. The information includes the applicable drawing legends and notes.

### 1.7.6 COL License Information

#### 1.7.6.1 P&ID Pipe Schedules

The following standard supplement addresses COL License Information Item 1.2.

The minimum pipe schedule for ANSI nominal pipe sizes are identified below for any individual piping system shown on a Piping and Instrumentation Diagram (P&ID).

	ASME Section III	ASME B31.1
Carbon Steel and Alloy Pipe		
50mm (2 inch) and smaller	Schedule 80	Schedule 80
65mm (2-1/2 inch) and larger	Standard Weight	Standard Weight
Stainless Steel Pipe		
50mm (2 inch) and smaller	Schedule 40S	Schedule 40S
65mm (2-1/2 inch) through 150mm (6 inch)	Schedule 10S	Schedule 10S
200mm (8 inch) through 300mm (12 inch)	Schedule 40S	Schedule 40S
350mm (14 inch) and larger	10mm (0.375 inch)	10mm (0.375 inch)

**Table 1.7-6 Additional or Updated I&C and Electrical Drawings**

Figure No.	Title	Type
5.2-8	Leak Detection and Isolation System	IED
7.2-9	Reactor Protection System	IED
7.2-10	Reactor Protection System	IBD
7.3-1	High Pressure Core Flooder System	IBD
7.3-2	Nuclear Boiler System	IBD
7.3-3	Reactor Core Isolation Cooling System	IBD
7.3-4	Residual Heat Removal System	IBD
7.3-5	Leak Detection and Isolation System	IBD
7.3-7	Reactor Building Cooling Water/Reactor Service Water System	IBD
7.3-9	HVAC Emergency Cooling Water System	IBD
7.3-10	High Pressure Nitrogen Gas System	IBD
7.4-1	Standby Liquid Control System	IBD
7.4-2	Remote Shutdown System	IED
7.4-3	Remote Shutdown System	IBD
7.6-1	Neutron Monitoring System	IED
7.6-2	Neutron Monitoring System	IBD
7.6-5	Process Radiation Monitoring System	IED
7.6-8	Containment Atmosphere Monitoring System	IBD
7.6-11	Suppression Pool Temperature Monitoring System	IED
7.6-12	Suppression Pool Temperature Monitoring System	IBD
7.7-2	Rod Control and Information System	IED
7.7-3	Rod Control and Information System	IBD
7.7-5	Recirculation Flow Control System	IED
7.7-7	Recirculation Flow Control System	IBD
7.7-8	Feedwater Control System	IED
7.7-9	Feedwater Control System	IBD
7.7-12	Steam Bypass and Pressure Control System	IED
7.7-13	Steam Bypass and Pressure Control System	IBD
7.7-14	Fuel Pool Cooling and Cleanup System	IBD

**Table 1.7-6 Additional or Updated I&C and Electrical Drawings (Continued)**

Figure No.	Title	Type
8.2-3	345 kV Switchyard Single Line Diagram [New Drawing]	SLD
8.3-1	Electrical Power Distribution System	SLD
8.3-2	Instrument and Control Power Supply System	SLD

**Table 1.7-7 System Drawings Not Included in the ABWR DCD**

Figure No.	Title	Type
9.2-18	Potable & Sanitary Water System	P&ID
9.3-10	Breathing Air System	P&ID
9.3-11	Radioactive Drain Transfer System	P&ID
9.3-12	Non-Radioactive Drainage System	P&ID
11.2-2	Liquid Radwaste System	P&ID

