

**19QB DHR Reliability Study**

The information in this appendix of the reference ABWR DCD, including all subsections and tables, is incorporated by reference with the following departure.

STD DEP 5.4-1

**19QB.5 Decay Heat Removal Capability of CUW and FPC**

The STP 3 & 4 RWCU design includes two 100% pumps instead of the reference ABWR DCD design of two 50% pumps. The two 100% RWCU pumps represent an improvement in the reliability of the RWCU system and a decrease in shutdown risk.