



BRUCE H HAMILTON
Vice President
McGuire Nuclear Station

Duke Energy Corporation
MG01VP / 12700 Hagers Ferry Road
Huntersville, NC 28078

704-875-5333
704-875-4809 fax
bhhamilton@duke-energy.com

March 4, 2008

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Duke Power Company LLC d/b/a
Duke Energy Carolinas, LLC (Duke)
McGuire Nuclear Station
Docket Nos. 50-370
Unit 2, Cycle 19, Revision 0
Core Operating Limits Report

Pursuant to McGuire Technical Specification (TS) 5.6.5.d, please find enclosed Revision 0 of the McGuire Unit 2 Cycle 19 Core Operating Limits Report (COLR). This revision will become effective prior to entering Mode 6 which begins Cycle 19.

Questions regarding this submittal should be directed to Kay Crane, McGuire Regulatory Compliance at (704) 875-4306.

Bruce H. Hamilton

Attachment

A001

LRR

U. S. Nuclear Regulatory Commission
March 4, 2008
Page 2

cc: Mr. John Stang, Project Manager
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

Mr. Victor McCree, Acting Regional Administrator
U. S. Nuclear Regulatory Commission, Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, GA 30323

Mr. Joe Brady
Senior Resident Inspector
McGuire Nuclear Station

McGuire Unit 2 Cycle 19
Core Operating Limits Report

Revision 0
February 2008

Calculation Number: MCC-1553.05-00-0478 (Rev. 0)

Duke Energy

		Date
Prepared By:	<u>Nicholas R Hager</u>	<u>2/21/08</u>
Checked By:	<u>ML Elcor</u>	<u>2/21/08</u>
Checked By:	<u>[Signature]</u> (Sections 2.2 and 2.10 – 2.17)	<u>02/21/2008</u>
Approved By:	<u>RC Hawley</u>	<u>2/21/08</u>

QA Condition 1

The information presented in this report has been prepared and issued in accordance with McGuire Technical Specification 5.6.5.

McGuire 2 Cycle 19 Core Operating Limits Report

INSPECTION OF ENGINEERING INSTRUCTIONS

Inspection Waived By: RC Hamer
(Sponsor)Date: 2/21/08CATAWBAInspection
Waived

MCE (Mechanical & Civil)	<input type="checkbox"/>	Inspected By/Date: _____
RES (Electrical Only)	<input type="checkbox"/>	Inspected By/Date: _____
RES (Reactor)	<input type="checkbox"/>	Inspected By/Date: _____
MOD	<input type="checkbox"/>	Inspected By/Date: _____
Other (_____)	<input type="checkbox"/>	Inspected By/Date: _____

OCONEEInspection
Waived

MCE (Mechanical & Civil)	<input type="checkbox"/>	Inspected By/Date: _____
RES (Electrical Only)	<input type="checkbox"/>	Inspected By/Date: _____
RES (Reactor)	<input type="checkbox"/>	Inspected By/Date: _____
MOD	<input type="checkbox"/>	Inspected By/Date: _____
Other (_____)	<input type="checkbox"/>	Inspected By/Date: _____

MCGUIREInspection
Waived

MCE (Mechanical & Civil)	<input checked="" type="checkbox"/>	Inspected By/Date: _____
RES (Electrical Only)	<input checked="" type="checkbox"/>	Inspected By/Date: _____
RES (Reactor)	<input checked="" type="checkbox"/>	Inspected By/Date: _____
MOD	<input checked="" type="checkbox"/>	Inspected By/Date: _____
Other (_____)	<input type="checkbox"/>	Inspected By/Date: _____

McGuire 2 Cycle 19 Core Operating Limits Report

Implementation Instructions For Revision 0

Revision Description and PIP Tracking

Revision 0 of the McGuire Unit 2 COLR contains limits specific to the McGuire 2 Cycle 19 reload core. There is no PIP associated with this revision.

Implementation Schedule

Revision 0 may become effective any time during No Mode between Cycles 18 and 19 but must become effective prior to entering Mode 6, which starts Cycle 19.

The McGuire Unit 2 Cycle 19 COLR will cease to be effective during No MODE between Cycle 19 and 20.

Data files to be Implemented

No data files are transmitted as part of this document.

McGuire 2 Cycle 19 Core Operating Limits Report**REVISION LOG**

<u>Revision</u>	<u>Effective Date</u>	<u>Pages Affected</u>	<u>COLR</u>
0	February 2008	1-32, Appendix A*	M2C19 COLR, Rev. 0

* Appendix A contains power distribution monitoring factors used in Technical Specification Surveillance. Appendix A is included only in the electronic COLR copy sent to the NRC.

McGuire 2 Cycle 19 Core Operating Limits Report

1.0 Core Operating Limits Report

This Core Operating Limits Report (COLR) has been prepared in accordance with the requirements of Technical Specification 5.6.5. The Technical Specifications that reference the COLR are summarized below.

<u>TS Number</u>	<u>Technical Specifications</u>	<u>COLR Parameter</u>	<u>COLR Section</u>	<u>EI Page</u>
1.1	Requirements for Operational Mode 6	Mode 6 Definition	2.1	9
2.1.1	Reactor Core Safety Limits	RCS Temperature and Pressure Safety Limits	2.2	9
3.1.1	Shutdown Margin	Shutdown Margin	2.3	9
3.1.3	Moderator Temperature Coefficient	MTC	2.4	11
3.1.4	Rod Group Alignment Limits	Shutdown Margin	2.3	9
3.1.5	Shutdown Bank Insertion Limits	Shutdown Margin	2.3	9
3.1.5	Shutdown Bank Insertion Limits	Shutdown Bank Insertion Limit	2.5	11
3.1.6	Control Bank Insertion Limits	Shutdown Margin	2.3	9
3.1.6	Control Bank Insertion Limits	Control Bank Insertion Limit	2.6	11
3.1.8	Physics Tests Exceptions	Shutdown Margin	2.3	9
3.2.1	Heat Flux Hot Channel Factor	F _q , AFD, OTΔT and Penalty Factors	2.7	15
3.2.2	Nuclear Enthalpy Rise Hot Channel Factor	FAH, AFD and Penalty Factors	2.8	20
3.2.3	Axial Flux Difference	AFD	2.9	21
3.3.1	Reactor Trip System Instrumentation	OTΔT and OPΔT Constants	2.10	24
3.4.1	RCS Pressure, Temperature, and Flow DNB limits	RCS Pressure, Temperature and Flow	2.11	26
3.5.1	Accumulators	Max and Min Boron Conc.	2.12	26
3.5.4	Refueling Water Storage Tank	Max and Min Boron Conc.	2.13	26
3.7.14	Spent Fuel Pool Boron Concentration	Min Boron Concentration	2.14	28
3.9.1	Refueling Operations – Boron Concentration	Min Boron Concentration	2.15	28
5.6.5	Core Operating Limits Report (COLR)	Analytical Methods	1.1	6

The Selected Licensee Commitments that reference this report are listed below:

<u>SLC Number</u>	<u>Selected Licensing Commitment</u>	<u>COLR Parameter</u>	<u>COLR Section</u>	<u>EI Page</u>
16.9.14	Borated Water Source – Shutdown	Borated Water Volume and Conc. for BAT/RWST	2.16	29
16.9.11	Borated Water Source – Operating	Borated Water Volume and Conc. for BAT/RWST	2.17	30

McGuire 2 Cycle 19 Core Operating Limits Report

1.1 Analytical Methods

The analytical methods used to determine core operating limits for parameters identified in Technical Specifications and previously reviewed and approved by the NRC, as specified in Technical Specification 5.6.5, are as follows.

1. WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," (W Proprietary).

Revision 0

Report Date: July 1985

Not Used for M2C19

2. WCAP-10054-P-A, "Westinghouse Small Break ECCS Evaluation Model using the NOTRUMP Code," (W Proprietary).

Revision 0

Report Date: August 1985

3. WCAP-10266-P-A, "The 1981 Version Of Westinghouse Evaluation Model Using BASH Code", (W Proprietary).

Revision 2

Report Date: March 1987

Not Used for M2C19

4. WCAP-12945-P-A, Volume 1 and Volumes 2-5, "Code Qualification Document for Best-Estimate Loss of Coolant Analysis," (W Proprietary).

Revision: Volume 1 (Revision 2) and Volumes 2-5 (Revision 1)

Report Date: March 1998

5. BAW-10168P-A, "B&W Loss-of-Coolant Accident Evaluation Model for Recirculating Steam Generator Plants," (B&W Proprietary).

Revision 1

SER Date: January 22, 1991

Revision 2

SER Dates: August 22, 1996 and November 26, 1996.

Revision 3

SER Date: June 15, 1994.

Not Used for M2C19

6. DPC-NE-3000PA, "Thermal-Hydraulic Transient Analysis Methodology," (DPC Proprietary).

Revision 3

SER Date: September 24, 2003

McGuire 2 Cycle 19 Core Operating Limits Report

1.1 Analytical Methods (continued)

7. DPC-NE-3001PA, "Multidimensional Reactor Transients and Safety Analysis Physics Parameter Methodology," (DPC Proprietary).

Revision 0

Report Date: November 15, 1991 (Republished December 2000)

8. DPC-NE-3002A, "FSAR Chapter 15 System Transient Analysis Methodology".

Revision 4

SER Date: April 6, 2001

9. DPC-NE-2004P-A, "Duke Power Company McGuire and Catawba Nuclear Stations Core Thermal-Hydraulic Methodology using VIPRE-01," (DPC Proprietary).

Revision 1

SER Date: February 20, 1997

10. DPC-NE-2005P-A, "Thermal Hydraulic Statistical Core Design Methodology," (DPC Proprietary).

Revision 3

SER Date: September 16, 2002

11. DPC-NE-2008P-A, "Fuel Mechanical Reload Analysis Methodology Using TACO3," (DPC Proprietary).

Revision 0

SER Date: April 3, 1995

Not Used for M2C19

12. DPC-NE-2009-P-A, "Westinghouse Fuel Transition Report," (DPC Proprietary).

Revision 2

SER Date: December 18, 2002

13. DPC-NE-1004A, "Nuclear Design Methodology Using CASMO-3/SIMULATE-3P."

Revision 1

SER Date: April 26, 1996

Not Used for M2C19

McGuire 2 Cycle 19 Core Operating Limits Report

1.1 Analytical Methods (continued)

14. DPC-NF-2010A, "Duke Power Company McGuire Nuclear Station Catawba Nuclear Station Nuclear Physics Methodology for Reload Design."

Revision 2

SER Date: June 24, 2003

15. DPC-NE-2011PA, "Duke Power Company Nuclear Design Methodology for Core Operating Limits of Westinghouse Reactors," (DPC Proprietary).

Revision 1

SER Date: October 1, 2002

16. DPC-NE-1005-P-A, "Nuclear Design Methodology Using CASMO-4 / SIMULATE-3 MOX," (DPC Proprietary).

Revision 0

SER Date: August 20, 2004

McGuire 2 Cycle 19 Core Operating Limits Report

2.0 Operating Limits

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC approved methodologies specified in Section 1.1.

2.1 Requirements for Operational Mode 6

The following condition is required for operational mode 6.

- 2.1.1 The Reactivity Condition requirement for operational mode 6 is that k_{eff} must be less than, or equal to 0.95.

2.2 Reactor Core Safety Limits (TS 2.1.1)


- 2.2.1 The Reactor Core Safety Limits are shown in Figure 1.

2.3 Shutdown Margin - SDM (TS 3.1.1, TS 3.1.4, TS 3.1.5, TS 3.1.6 and TS 3.1.8)

- 2.3.1 For TS 3.1.1, SDM shall be $\geq 1.3\% \Delta K/K$ in mode 2 with $k_{eff} < 1.0$ and in modes 3 and 4.
- 2.3.2 For TS 3.1.1, SDM shall be $\geq 1.0\% \Delta K/K$ in mode 5.
- 2.3.3 For TS 3.1.4, SDM shall be $\geq 1.3\% \Delta K/K$ in modes 1 and 2.
- 2.3.4 For TS 3.1.5, SDM shall be $\geq 1.3\% \Delta K/K$ in mode 1 and mode 2 with any control bank not fully inserted.
- 2.3.5 For TS 3.1.6, SDM shall be $\geq 1.3\% \Delta K/K$ in mode 1 and mode 2 with $K_{eff} \geq 1.0$.
- 2.3.6 For TS 3.1.8, SDM shall be $\geq 1.3\% \Delta K/K$ in mode 2 during Physics Testing.

McGuire 2 Cycle 19 Core Operating Limits Report

Figure 1
Reactor Core Safety Limits
Four Loops in Operation



McGuire 2 Cycle 19 Core Operating Limits Report

2.4 Moderator Temperature Coefficient - MTC (TS 3.1.3)

2.4.1 The Moderator Temperature Coefficient (MTC) Limits are:

The MTC shall be less positive than the upper limits shown in Figure 2. The BOC, ARO, HZP MTC shall be less positive than $0.7E-04 \Delta K/K/^{\circ}F$.

The EOC, ARO, RTP MTC shall be less negative than the $-4.3E-04 \Delta K/K/^{\circ}F$ lower MTC limit.

2.4.2 The 300 ppm MTC Surveillance Limit is:

The measured 300 PPM ARO, equilibrium RTP MTC shall be less negative than or equal to $-3.65E-04 \Delta K/K/^{\circ}F$.

2.4.3 The 60 PPM MTC Surveillance Limit is:

The 60 PPM ARO, equilibrium RTP MTC shall be less negative than or equal to $-4.125E-04 \Delta K/K/^{\circ}F$.

Where,

BOC = Beginning of Cycle (Burnup corresponding to the most positive MTC)

EOC = End of Cycle

ARO = All Rods Out

HZP = Hot Zero Power

RTP = Rated Thermal Power


PPM = Parts per million (Boron)

2.5 Shutdown Bank Insertion Limit (TS 3.1.5)

2.5.1 Each shutdown bank shall be withdrawn to at least 222 steps. Shutdown banks are withdrawn in sequence and with no overlap.

2.6 Control Bank Insertion Limits (TS 3.1.6)

2.6.1 Control banks shall be within the insertion, sequence, and overlap limits shown in Figure 3. Specific control bank withdrawal and overlap limits as a function of the fully withdrawn position are shown in Table 1.


McGuire 2 Cycle 19 Core Operating Limits Report**Figure 2****Moderator Temperature Coefficient Upper Limit Versus Power Level**

NOTE: Compliance with Technical Specification 3.1.3 may require rod withdrawal limits.
Refer to OP/2/A/6100/22 Unit 2 Data Book for details.

McGuire 2 Cycle 19 Core Operating Limits Report

Figure 3

Control Bank Insertion Limits Versus Percent Rated Thermal Power



The Rod Insertion Limits (RIL) for Control Bank D (CD), Control Bank C (CC), and Control Bank B (CB) can be calculated by:

$$\text{Bank CD RIL} = 2.3(P) - 69 \quad \{30 \leq P \leq 100\}$$

$$\text{Bank CC RIL} = 2.3(P) + 47 \quad \{0 \leq P \leq 80\}$$

$$\text{Bank CB RIL} = 2.3(P) + 163 \quad \{0 \leq P \leq 29.6\}$$

where $P = \% \text{ Rated Thermal Power}$

NOTE: Compliance with Technical Specification 3.1.3 may require rod withdrawal limits. Refer to OP/2/A/6100/22 Unit 2 Data Book for details.

McGuire 2 Cycle 19 Core Operating Limits Report

Table 1
RCCA Withdrawal Steps and Sequence

Fully Withdrawn at 222 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
222 Stop	106	0	0
222	116	0 Start	0
222	222 Stop	106	0
222	222	116	0 Start
222	222	222 Stop	106

Fully Withdrawn at 224 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
224 Stop	108	0	0
224	116	0 Start	0
224	224 Stop	108	0
224	224	116	0 Start
224	224	224 Stop	108

Fully Withdrawn at 226 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
226 Stop	110	0	0
226	116	0 Start	0
226	226 Stop	110	0
226	226	116	0 Start
226	226	226 Stop	110

Fully Withdrawn at 228 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
228 Stop	112	0	0
228	116	0 Start	0
228	228 Stop	112	0
228	228	116	0 Start
228	228	228 Stop	112

Fully Withdrawn at 230 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
230 Stop	114	0	0
230	116	0 Start	0
230	230 Stop	114	0
230	230	116	0 Start
230	230	230 Stop	114

Fully Withdrawn at 223 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
223 Stop	107	0	0
223	116	0 Start	0
223	223 Stop	107	0
223	223	116	0 Start
223	223	223 Stop	107

Fully Withdrawn at 225 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
225 Stop	109	0	0
225	116	0 Start	0
225	225 Stop	109	0
225	225	116	0 Start
225	225	225 Stop	109

Fully Withdrawn at 227 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
227 Stop	111	0	0
227	116	0 Start	0
227	227 Stop	111	0
227	227	116	0 Start
227	227	227 Stop	111

Fully Withdrawn at 229 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
229 Stop	113	0	0
229	116	0 Start	0
229	229 Stop	113	0
229	229	116	0 Start
229	229	229 Stop	113

Fully Withdrawn at 231 Steps			
Control Bank A	Control Bank B	Control Bank C	Control Bank D
0 Start	0	0	0
116	0 Start	0	0
231 Stop	115	0	0
231	116	0 Start	0
231	231 Stop	115	0
231	231	116	0 Start
231	231	231 Stop	115

McGuire 2 Cycle 19 Core Operating Limits Report

2.7 Heat Flux Hot Channel Factor - $F_Q(X,Y,Z)$ (TS 3.2.1)

2.7.1 $F_Q(X,Y,Z)$ steady-state limits are defined by the following relationships:

$$\begin{aligned} F_Q^{RTP} * K(Z)/P & \quad \text{for } P > 0.5 \\ F_Q^{RTP} * K(Z)/0.5 & \quad \text{for } P \leq 0.5 \end{aligned}$$

where,

$$P = (\text{Thermal Power})/(\text{Rated Power})$$

Note: The measured $F_Q(X,Y,Z)$ shall be increased by 3% to account for manufacturing tolerances and 5% to account for measurement uncertainty when comparing against the LCO limits. The manufacturing tolerance and measurement uncertainty are implicitly included in the F_Q surveillance limits as defined in COLR Sections 2.7.5 and 2.7.6.

2.7.2 $F_Q^{RTP} = 2.60 \times K(BU)$

2.7.3 $K(Z)$ is the normalized $F_Q(X,Y,Z)$ as a function of core height. The $K(Z)$ function for Westinghouse RFA fuel is provided in Figure 4.

2.7.4 $K(BU)$ is the normalized $F_Q(X,Y,Z)$ as a function of burnup. $K(BU)$ for Westinghouse RFA fuel is 1.0 for all burnups.

The following parameters are required for core monitoring per the Surveillance Requirements of Technical Specification 3.2.1:

2.7.5 $F_Q^L(X,Y,Z)^{OP} = \frac{F_Q^D(X,Y,Z) * M_Q(X,Y,Z)}{UMT * MT * TILT}$

where:

$F_Q^L(X,Y,Z)^{OP}$ = Cycle dependent maximum allowable design peaking factor that ensures the $F_Q(X,Y,Z)$ LOCA limit will be preserved for operation within the LCO limits. $F_Q^L(X,Y,Z)^{OP}$ includes allowances for calculation and measurement uncertainties.

$F_Q^D(X,Y,Z)$ = Design power distribution for F_Q . $F_Q^D(X,Y,Z)$ is provided in Appendix Table A-1 for normal operating conditions, and in

McGuire 2 Cycle 19 Core Operating Limits Report

Appendix Table A-4 for power escalation testing during initial startup operation.

$M_Q(X,Y,Z)$ = Margin remaining in core location X,Y,Z to the LOCA limit in the transient power distribution. $M_Q(X,Y,Z)$ is provided in Appendix Table A-1 for normal operating conditions, and in Appendix Table A-4 for power escalation testing during initial startup operation.

UMT = Total Peak Measurement Uncertainty. (UMT = 1.05)

MT = Engineering Hot Channel Factor. (MT = 1.03)

TILT = Peaking penalty that accounts for the peaking increase from an allowable quadrant power tilt ratio of 1.02. (TILT = 1.035)

$$2.7.6 \quad F_Q^L(X,Y,Z)^{RPS} = \frac{F_Q^D(X,Y,Z) * M_C(X,Y,Z)}{UMT * MT * TILT}$$

where:

$F_Q^L(X,Y,Z)^{RPS}$ = Cycle dependent maximum allowable design peaking factor that ensures the $F_Q(X,Y,Z)$ Centerline Fuel Melt (CFM) limit will be preserved for operation within the LCO limits. $F_Q^L(X,Y,Z)^{RPS}$ includes allowances for calculation and measurement uncertainties.

$F_Q^D(X,Y,Z)$ = Design power distributions for F_Q . $F_Q^D(X,Y,Z)$ is provided in Appendix Table A-1 for normal operating conditions, and in Appendix Table A-4 for power escalation testing during initial startup operation.

$M_C(X,Y,Z)$ = Margin remaining to the CFM limit in core location X,Y,Z in the transient power distribution. $M_C(X,Y,Z)$ is provided in Appendix Table A-2 for normal operating conditions, and in Appendix Table A-5 for power escalation testing during initial startup operation.

McGuire 2 Cycle 19 Core Operating Limits Report

UMT = Total Peak Measurement Uncertainty (UMT = 1.05)

MT = Engineering Hot Channel Factor (MT = 1.03)

TILT = Peaking penalty that accounts for the peaking increase from an allowable quadrant power tilt ratio of 1.02. (TILT = 1.035)

2.7.7 KSLOPE = 0.0725


where:

KSLOPE is the adjustment to the K_1 value from the OTAT trip setpoint required to compensate for each 1% that $F_Q^M(X,Y,Z)$ exceeds $F_Q^L(X,Y,Z)^{RPS}$.

2.7.8 $F_Q(X,Y,Z)$ penalty factors for Technical Specification Surveillance's 3.2.1.2 and 3.2.1.3 are provided in Table 2.

McGuire 2 Cycle 19 Core Operating Limits Report

Figure 4
 $K(Z)$, Normalized $F_Q(X,Y,Z)$ as a Function of
Core Height for Westinghouse RFA Fuel



McGuire 2 Cycle 19 Core Operating Limits Report

Table 2
 $F_Q(X,Y,Z)$ and $F_{\Delta H}(X,Y)$ Penalty Factors
For Technical Specification Surveillance's 3.2.1.2, 3.2.1.3 and 3.2.2.2

<u>Burnup (EFPD)</u>	<u>$F_Q(X,Y,Z)$ Penalty Factor (%)</u>	<u>$F_{\Delta H}(X,Y,Z)$ Penalty Factor (%)</u>
0	2.00	2.00
4	2.00	2.00
12	2.00	2.00
25	2.00	2.00
50	2.00	2.00
75	2.00	2.00
100	2.00	2.00
125	2.00	2.00
150	2.00	2.00
175	2.00	2.00
200	2.00	2.00
225	2.00	2.00
250	2.00	2.00
275	2.00	2.00
300	2.00	2.00
325	2.00	2.00
350	2.00	2.00
375	2.00	2.00
400	2.00	2.00
425	2.00	2.00
445	2.00	2.00
470	2.00	2.00
488	2.00	2.00
498	2.00	2.00
513	2.00	2.00

Note: Linear interpolation is adequate for intermediate cycle burnups. All cycle burnups outside of the range of the table shall use a 2% penalty factor for both $F_Q(X,Y,Z)$ and $F_{\Delta H}(X,Y)$ for compliance with the Technical Specification Surveillances 3.2.1.2, 3.2.1.3 and 3.2.2.2.

McGuire 2 Cycle 19 Core Operating Limits Report

2.8 Nuclear Enthalpy Rise Hot Channel Factor - $F_{\Delta H}(X,Y)$ (TS 3.2.2)

The $F_{\Delta H}$ steady-state limits referred to in Technical Specification 3.2.2 is defined by the following relationship.

$$2.8.1 \quad F_{\Delta H}^L(X,Y)^{LCO} = \text{MARP}(X,Y) * \left[1.0 + \frac{1}{\text{RRH}} * (1.0 - P) \right]$$

where:

$F_{\Delta H}^L(X,Y)^{LCO}$ is defined as the steady-state, maximum allowed radial peak.

$F_{\Delta H}^L(X,Y)^{LCO}$ includes allowances for calculation/measurement uncertainty.

$\text{MARP}(X,Y) =$ Cycle-specific operating limit Maximum Allowable Radial Peaks. $\text{MARP}(X,Y)$ radial peaking limits are provided in Table 3.

$$P = \frac{\text{Thermal Power}}{\text{Rated Thermal Power}}$$

$\text{RRH} =$ Thermal Power reduction required to compensate for each 1% that the measured radial peak, $F_{\Delta H}^M(X,Y)$, exceeds its limit. RRH also is used to scale the MARP limits as a function of power per the $[F_{\Delta H}^L(X,Y)]^{LCO}$ equation. ($\text{RRH} = 3.34$ ($0.0 < P \leq 1.0$))

The following parameters are required for core monitoring per the Surveillance requirements of Technical Specification 3.2.2.

$$2.8.2 \quad F_{\Delta H}^L(X,Y)^{SURV} = \frac{F_{\Delta H}^D(X,Y) \times M_{\Delta H}(X,Y)}{\text{UMR} \times \text{TILT}}$$

where:

$F_{\Delta H}^L(X,Y)^{SURV} =$ Cycle dependent maximum allowable design peaking factor that ensures the $F_{\Delta H}(X,Y)$ limit will be preserved for operation within the LCO limits. $F_{\Delta H}^L(X,Y)^{SURV}$ includes allowances for calculation/measurement uncertainty.

McGuire 2 Cycle 19 Core Operating Limits Report

$F_{\Delta H}^D(X,Y)$ = Design radial power distribution for $F_{\Delta H}$. $F_{\Delta H}^D(X,Y)$ is provided in Appendix Table A-3 for normal operation, and in Appendix Table A-6 for power escalation testing during initial startup operation.

$M_{\Delta H}(X,Y)$ = The margin remaining in core location X,Y relative to the Operational DNB limits in the transient power distribution. $M_{\Delta H}(X,Y)$ is provided in Appendix Table A-3 for normal operation, and in Appendix Table A-6 for power escalation testing during initial startup operation.

UMR = Uncertainty value for measured radial peaks. UMR is set to 1.0 since a factor of 1.04 is implicitly included in the variable $M_{\Delta H}(X,Y)$.

TILT = Peaking penalty that accounts for the peaking increase for an allowable quadrant power tilt ratio of 1.02 (TILT = 1.035).

2.8.3 RRH = 3.34

where:

RRH = Thermal power reduction required to compensate for each 1% that the measured radial peak, $F_{\Delta H}^M(X,Y)$ exceeds its limit. ($0 < P \leq 1.0$)

2.8.4 TRH = 0.04

where:

TRH = Reduction in the OTΔT K_1 setpoint required to compensate for each 1% that the measured radial peak, $F_{\Delta H}^M(X,Y)$ exceeds its limit.

2.8.5 $F_{\Delta H}(X,Y)$ penalty factors for Technical Specification Surveillance 3.2.2.2 are provided in Table 2.

2.9 Axial Flux Difference – AFD (TS 3.2.3)


2.9.1 The Axial Flux Difference (AFD) Limits are provided in Figure 5.

McGuire 2 Cycle 19 Core Operating Limits Report

Table 3
Maximum Allowable Radial Peaks (MARPS)

RFA MARPS

<u>Core Ht (ft.)</u>	<u>Axial Peak</u>												
	<u>1.05</u>	<u>1.1</u>	<u>1.2</u>	<u>1.3</u>	<u>1.4</u>	<u>1.5</u>	<u>1.6</u>	<u>1.7</u>	<u>1.8</u>	<u>1.9</u>	<u>2.1</u>	<u>3.0</u>	<u>3.25</u>
0.12	1.809	1.855	1.949	1.995	1.974	2.107	2.050	2.009	1.933	1.863	1.778	1.315	1.246
1.2	1.810	1.854	1.940	1.995	1.974	2.107	2.019	1.978	1.901	1.831	1.785	1.301	1.224
2.4	1.809	1.853	1.931	1.978	1.974	2.074	1.995	1.952	1.876	1.805	1.732	1.463	1.462
3.6	1.810	1.851	1.920	1.964	1.974	2.050	1.966	1.926	1.852	1.786	1.700	1.468	1.387
4.8	1.810	1.851	1.906	1.945	1.974	2.006	1.944	1.923	1.854	1.784	1.671	1.299	1.258
6.0	1.810	1.851	1.892	1.921	1.946	1.934	1.880	1.863	1.802	1.747	1.671	1.329	1.260
7.2	1.807	1.844	1.872	1.893	1.887	1.872	1.809	1.787	1.733	1.681	1.598	1.287	1.220
8.4	1.807	1.832	1.845	1.857	1.816	1.795	1.736	1.709	1.654	1.601	1.513	1.218	1.158
9.6	1.807	1.810	1.809	1.791	1.738	1.718	1.657	1.635	1.581	1.530	1.444	1.143	1.091
10.8	1.798	1.787	1.761	1.716	1.654	1.632	1.574	1.557	1.509	1.462	1.383	1.101	1.047
11.4	1.789	1.765	1.725	1.665	1.606	1.583	1.529	1.510	1.464	1.422	1.346	1.067	1.014

McGuire 2 Cycle 19 Core Operating Limits Report**Figure 5****Percent of Rated Thermal Power Versus Percent Axial Flux Difference Limits**

NOTE: Compliance with Technical Specification 3.2.1 may require more restrictive AFD limits. Refer to OP/2/A/6100/22 Unit 2 Data Book for more details.

McGuire 2 Cycle 19 Core Operating Limits Report

2.10 Reactor Trip System Instrumentation Setpoints (TS 3.3.1) Table 3.3.1-1

2.10.1 Overtemperature ΔT Setpoint Parameter Values

<u>Parameter</u>	<u>Value</u>
Nominal T_{avg} at RTP	$T' \leq 585.1^{\circ}\text{F}$
Nominal RCS Operating Pressure	$P' = 2235 \text{ psig}$
Overtemperature ΔT reactor trip setpoint	$K_1 \leq 1.1978$
Overtemperature ΔT reactor trip heatup setpoint penalty coefficient	$K_2 = 0.0334/^{\circ}\text{F}$
Overtemperature ΔT reactor trip depressurization setpoint penalty coefficient	$K_3 = 0.001601/\text{psi}$
Time constants utilized in the lead-lag compensator for ΔT	$\tau_1 \geq 8 \text{ sec.}$ $\tau_2 \leq 3 \text{ sec.}$
Time constant utilized in the lag compensator for ΔT	$\tau_3 \leq 2 \text{ sec.}$
Time constants utilized in the lead-lag compensator for T_{avg}	$\tau_4 \geq 28 \text{ sec.}$ $\tau_5 \leq 4 \text{ sec.}$
Time constant utilized in the measured T_{avg} lag compensator	$\tau_6 \leq 2 \text{ sec.}$
$f_1(\Delta I)$ "positive" breakpoint	$= 19.0 \% \Delta I$
$f_1(\Delta I)$ "negative" breakpoint	$= \text{N/A}^*$
$f_1(\Delta I)$ "positive" slope	$= 1.769 \% \Delta T_0 / \% \Delta I$
$f_1(\Delta I)$ "negative" slope	$= \text{N/A}^*$

- * The $f_1(\Delta I)$ "negative" breakpoints and the $f_1(\Delta I)$ "negative" slope are less restrictive than the OPAT $f_2(\Delta I)$ negative breakpoint and slope. Therefore, during a transient which challenges the negative imbalance limits, the OPAT $f_2(\Delta I)$ limits will result in a reactor trip before the OTAT $f_1(\Delta I)$ limits are reached. This makes implementation of the OTAT $f_1(\Delta I)$ negative breakpoint and slope unnecessary.

McGuire 2 Cycle 19 Core Operating Limits Report

2.10.2 Overpower ΔT Setpoint Parameter Values

<u>Parameter</u>	<u>Value</u>
Nominal T_{avg} at RTP	$T'' \leq 585.1^{\circ}\text{F}$
Overpower ΔT reactor trip setpoint	$K_4 \leq 1.0864$
Overpower ΔT reactor trip Penalty	$K_5 = 0.02/^{\circ}\text{F}$ for increasing T_{avg} $K_5 = 0.0$ for decreasing T_{avg}
Overpower ΔT reactor trip heatup setpoint penalty coefficient	$K_6 = 0.001179/^{\circ}\text{F}$ for $T > T''$ $K_6 = 0.0$ for $T \leq T''$
Time constants utilized in the lead-lag compensator for ΔT	$\tau_1 \geq 8 \text{ sec.}$ $\tau_2 \leq 3 \text{ sec.}$
Time constant utilized in the lag compensator for ΔT	$\tau_3 \leq 2 \text{ sec.}$
Time constant utilized in the measured T_{avg} lag compensator	$\tau_6 \leq 2 \text{ sec.}$
Time constant utilized in the rate-lag controller for T_{avg}	$\tau_7 \geq 5 \text{ sec.}$
$f_2(\Delta I)$ "positive" breakpoint	$= 35.0 \% \Delta I$
$f_2(\Delta I)$ "negative" breakpoint	$= -35.0 \% \Delta I$
$f_2(\Delta I)$ "positive" slope	$= 7.0 \% \Delta T_0 / \% \Delta I$
$f_2(\Delta I)$ "negative" slope	$= 7.0 \% \Delta T_0 / \% \Delta I$

McGuire 2 Cycle 19 Core Operating Limits Report

2.11 RCS Pressure, Temperature and Flow Limits for DNB (TS 3.4.1)

2.11.1 The RCS pressure, temperature and flow limits for DNB are shown in Table 4.

2.12 Accumulators (TS 3.5.1)

2.12.1 Boron concentration limits during modes 1 and 2, and mode 3 with RCS pressure >1000 psi:

<u>Parameter</u>	<u>Limit</u>
Cold Leg Accumulator minimum boron concentration.	2,475 ppm
Cold Leg Accumulator maximum boron concentration.	2,875 ppm

2.13 Refueling Water Storage Tank - RWST (TS 3.5.4)

2.13.1 Boron concentration limits during modes 1, 2, 3, and 4:

<u>Parameter</u>	<u>Limit</u>
Refueling Water Storage Tank minimum boron concentration.	2,675 ppm
Refueling Water Storage Tank maximum boron concentration.	2,875 ppm

McGuire 2 Cycle 19 Core Operating Limits Report

Table 4

Reactor Coolant System DNB Parameters

Parameter	Indication	No. Operable Channels	Limits
1. Indicated RCS Average Temperature	meter	4	$\leq 587.2^{\circ}\text{F}$
	meter	3	$\leq 586.9^{\circ}\text{F}$
	computer	4	$\leq 587.7^{\circ}\text{F}$
	computer	3	$\leq 587.5^{\circ}\text{F}$
2. Indicated Pressurizer Pressure	meter	4	$\geq 2219.8 \text{ psig}$
	meter	3	$\geq 2222.1 \text{ psig}$
	computer	4	$\geq 2215.8 \text{ psig}$
	computer	3	$\geq 2217.5 \text{ psig}$
3. RCS Total Flow Rate			$\geq 388,000 \text{ gpm}$

McGuire 2 Cycle 19 Core Operating Limits Report

2.14 Spent Fuel Pool Boron Concentration (TS 3.7.14)

2.14.1 Minimum boron concentration limit for the spent fuel pool. Applicable when fuel assemblies are stored in the spent fuel pool.

<u>Parameter</u>	<u>Limit</u>
Spent fuel pool minimum boron concentration.	2,675 ppm

2.15 Refueling Operations - Boron Concentration (TS 3.9.1)

2.15.1 Minimum boron concentration limit for the filled portions of the Reactor Coolant System, refueling canal, and refueling cavity for mode 6 conditions. The minimum boron concentration limit and plant refueling procedures ensure that the Keff of the core will remain within the mode 6 reactivity requirement of $K_{eff} \leq 0.95$.

<u>Parameter</u>	<u>Limit</u>
Minimum Boron concentration of the Reactor Coolant System, the refueling canal, and the refueling cavity.	2,675 ppm

McGuire 2 Cycle 19 Core Operating Limits Report**2.16 Borated Water Source – Shutdown (SLC 16.9.14)**

2.16.1 Volume and boron concentrations for the Boric Acid Tank (BAT) and the Refueling Water Storage Tank (RWST) during mode 4 with any RCS cold leg temperature ≤ 300 °F and modes 5 and 6.

<u>Parameter</u>	<u>Limit</u>
Boric Acid Tank minimum contained borated water volume	10,599 gallons 13.6% Level

Note: When cycle burnup is > 460 EFPD, Figure 6 may be used to determine the required BAT minimum level.
--

Boric Acid Tank minimum boron concentration	7,000 ppm
Boric Acid Tank minimum water volume required to maintain SDM at 7,000 ppm	2,300 gallons
Refueling Water Storage Tank minimum contained borated water volume	47,700 gallons 41 inches
Refueling Water Storage Tank minimum boron concentration	2,675 ppm
Refueling Water Storage Tank minimum water volume required to maintain SDM at 2,675 ppm	8,200 gallons

McGuire 2 Cycle 19 Core Operating Limits Report**2.17 Borated Water Source - Operating (SLC 16.9.11)**

2.17.1 Volume and boron concentrations for the Boric Acid Tank (BAT) and the Refueling Water Storage Tank (RWST) during modes 1, 2, 3, and mode 4 with all RCS cold leg temperature > 300 °F.

<u>Parameter</u>	<u>Limit</u>
Boric Acid Tank minimum contained borated water volume	22,049 gallons 38.0% Level

Note: When cycle burnup is > 460 EFPD, Figure 6 may be used to determine the required BAT minimum level.
--


Boric Acid Tank minimum boron concentration	7,000 ppm
Boric Acid Tank minimum water volume required to maintain SDM at 7,000 ppm	13,750 gallons
Refueling Water Storage Tank minimum contained borated water volume	96,607 gallons 103.6 inches
Refueling Water Storage Tank minimum boron concentration	2,675 ppm
Refueling Water Storage Tank maximum boron concentration (TS 3.5.4)	2,875 ppm
Refueling Water Storage Tank minimum water volume required to maintain SDM at 2,675 ppm	57,107 gallons

McGuire 2 Cycle 19 Core Operating Limits Report

Figure 6
Boric Acid Storage Tank Indicated Level Versus
RCS Boron Concentration

(Valid When Cycle Burnup is > 460 EFPD)

This figure includes additional volumes listed in SLC 16.9.14 and 16.9.11



McGuire 2 Cycle 19 Core Operating Limits Report

NOTE: Appendix A contains power distribution monitoring factors used in Technical Specification Surveillance. This data was generated in the McGuire 2 Cycle 19 Maneuvering Analysis calculation file, MCC-1553.05-00-0472. Due to the size of the monitoring factor data, Appendix A is controlled electronically within Duke and is not included in the Duke internal copies of the COLR. The Plant Nuclear Engineering Section will control this information via computer file(s) and should be contacted if there is a need to access this information.

Appendix A is included in the COLR copy transmitted to the NRC.