

March 14, 2008

Mr. James J. Sheppard
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric Generating Station
P.O. Box 289
Wadsworth, TX 77483

SUBJECT: SOUTH TEXAS PROJECT, UNIT 1 - EVALUATION OF NEW INFORMATION
RELATED TO ALLOY 82/182 PRESSURIZER BUTT WELD INSPECTIONS RE:
CONFIRMATORY ACTION LETTER NRR-07-009 (TAC NO. MD7296)

Dear Mr. Sheppard:

On March 27, 2007, the U.S. Nuclear Regulatory Commission (NRC) issued Confirmatory Action Letter (CAL) No. NRR-07-009 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML070790336) regarding dissimilar metal welds in the pressurizer surge, spray, and safety/relief nozzle-to-safe end welds at South Texas Project (STP), Unit 1. The CAL and the supporting commitment letter (ADAMS Accession No. ML070600123) indicate that inspection and mitigation actions may be conducted during your spring 2008 refueling outage, contingent on the industry providing an analysis that demonstrates an acceptable level of safety to the NRC for the operation of these welds until spring 2008.

The NRC received MRP-216, Rev. 1, "Materials Reliability Program: Advanced FEA [Finite Element Analysis] Evaluation of Growth of Postulated Circumferential PWSCC [Primary Water Stress-Corrosion Cracking] Flaws in Pressurizer Nozzle Dissimilar Metal Welds," on August 13, 2007 (ADAMS Accession No. ML072410235). Based on our review of this report, NRC concluded that the analysis provided adequate justification to permit inspections during your spring 2008 refueling outage, and that the analysis was applicable to STP, Unit 1. On September 7, 2007, the NRC issued a letter to STP Nuclear Operating Company (ADAMS Accession No. ML072480004), informing you that a plant shutdown by December 31, 2007, was no longer needed and STP, Unit 1 could continue to operate until the spring 2008 outage.

On March 4, 2008, the NRC became aware of emerging information regarding certain welds in nozzles on a retired pressurizer from a pressurized-water reactor facility. This was related to new reports (ADAMS Accession Nos. ML080701017 and ML080701020) on weld examinations of those nozzles. This information raised questions regarding the technical basis for the September 7, 2007, letter. The NRC dispatched technical experts in non-destructive examination to independently review industry analyses and actions regarding this matter. On March 13, 2008, a public meeting was held in NRC Headquarters, Rockville, MD, with representatives of the eight licensees whose plants had not yet shut down for spring 2008 outages and who are subject to commitments to inspect or mitigate similar welds during spring 2008 outages.

The NRC has evaluated the non-destructive automated phased array ultrasonic examination performed since March 4, 2008, and concluded there is reasonable assurance that there is no structurally significant service-related degradation in those nozzles that would alter the conclusions provided in our letter dated September 7, 2007, that allowed continued operation of STP, Unit 1 until the spring 2008 refueling outage. The NRC will continue to evaluate new information as it becomes available. All other requirements of the CAL and the supporting commitment letter regarding enhanced inspection and leakage monitoring requirements for the reactor coolant system and associated reports remain valid.

The CAL will remain open until all CAL commitments pertaining to STP, Unit 1 are complete.

Current NRC guidance regarding CALs is contained in the NRC Enforcement Policy and the NRC Enforcement Manual, which are available at the NRC web site at <http://www.nrc.gov/about-nrc/regulatory/enforcement.html> (click on Enforcement Policy or Enforcement Guidance) or by contacting the Government Printing Office (GPO) toll-free at 1-888-293-6498. The GPO is open from 7:00 a.m. to 9:00 p.m. EST, Monday through Friday (except Federal holidays).

In accordance with Title 10 of the *Code of Federal Regulations*, Part 2, Section 390, of the NRC's "Rules of Practice," a copy of this letter will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm.html>.

Sincerely,

/RA by Tim McGinty for/

Catherine Haney, Director
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. STN 50-498

cc: See next page

The NRC has evaluated the non-destructive automated phased array ultrasonic examination performed since March 4, 2008, and concluded there is reasonable assurance that there is no structurally significant service-related degradation in those nozzles that would alter the conclusions provided in our letter dated September 7, 2007, that allowed continued operation of STP, Unit 1 until the spring 2008 refueling outage. The NRC will continue to evaluate new information as it becomes available. All other requirements of the CAL and the supporting commitment letter regarding enhanced inspection and leakage monitoring requirements for the reactor coolant system and associated reports remain valid.

The CAL will remain open until all CAL commitments pertaining to STP, Unit 1 are complete.

Current NRC guidance regarding CALs is contained in the NRC Enforcement Policy and the NRC Enforcement Manual, which are available at the NRC web site at <http://www.nrc.gov/about-nrc/regulatory/enforcement.html> (click on Enforcement Policy or Enforcement Guidance) or by contacting the Government Printing Office (GPO) toll-free at 1-888-293-6498. The GPO is open from 7:00 a.m. to 9:00 p.m. EST, Monday through Friday (except Federal holidays).

In accordance with Title 10 of the *Code of Federal Regulations*, Part 2, Section 390, of the NRC's "Rules of Practice," a copy of this letter will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm.html>.

Sincerely,

/RA by Tim McGinty for/

Catherine Haney, Director
 Division of Operating Reactor Licensing
 Office of Nuclear Reactor Regulation

Docket No. STN 50-498

cc: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDir	RidsRgn4MailCenter
LPL4 R/F	RidsNrrDorl	WMaier, RIV SLO
RidsAcrsAcnw&mMailCenter	RidsNrrDorlLpl4	DPelton, EDO RIV
RidsEdoMailCenter	RidsNrrLAJBurkhardt	VDricks, OPA RIV
RidsNrrOd	RidsNrrPMMThadani	TSullivan, NRR/DCI/CPNB
RidsNrrDci	RidsOEMailCenter	
RidsNrrDciCpnb	RidsOgcRp	

ADAMS Accession No. ML080740356 (*) by e-mail (**) see previous concurrence NRR-106

OFFICE	DCI/CPNB	DCI/CPNB/BC	DORL/LPL4/PM	DORL/LPL4/LA
NAME	TSullivan	TChan	MThadani, MTM	JBurkhardt
DATE	3/14/08, w/comments	3/14/08	3/14/08	3/14/08
OFFICE	DORL/LPL4/BC	NRR/DCI/D	DRP/D, R-III	NRR/DORL/D
NAME	THiltz	MEvans	DChamberlain, e-mail	Chaney, TJM for
DATE	3/14/08	3/14/08	3/14/08	3/14/08

OFFICIAL AGENCY RECORD

South Texas Project, Units 1 and 2

12/5/2007

cc:

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 289
Wadsworth, TX 77483

S. M. Head, Manager, Licensing
STP Nuclear Operating Company
P.O. Box 289, Mail Code: N5014
Wadsworth, TX 77483

C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

C. T. Bowman, General Manager, Oversight
STP Nuclear Operating Company
P.O. Box 289
Wadsworth, TX 77483

J. J. Nesrsta/R. K. Temple
E. Alercon/Kevin Pollo
CPS Energy
P.O. Box 1771
San Antonio, TX 78296

Ms. Marilyn Kistler
Senior Staff Specialist, Licensing
STP Nuclear Operating Company
P.O. Box 289, Mail Code 5014
Wadsworth, TX 77483

INPO
Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Environmental and Natural Resources
Policy Director
P.O. Box 12428
Austin, TX 78711-3189

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Mr. Jon C. Wood
Cox, Smith, & Matthews
112 East Pecan, Suite 1800
San Antonio, TX 78205

Steve Winn/Christie Jacobs
Eddy Daniels/Marty Ryan
NRC Energy, Inc.
211 Carnegie Center
Princeton, NJ 08540

Director, Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of State Health Services
1100 West 49th Street
Austin, TX 78756

Mr. Nate McDonald
County Judge for Matagorda County
1700 7th Street, Room 301
Bay City, TX 77414

Mr. Ted Enos
4200 South Hulen
Suite 422
Ft. Worth, TX 76109

A. H. Gutterman, Esq.
Morgan, Lewis & Bockius
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Mr. Brian Almon
Public Utility Commission of Texas
P.O. Box 13326
Austin, TX 78711-3326

E. D. Halpin, Site Vice President
STP Nuclear Operating Company
South Texas Project Electric Generating Station
P.O. Box 289
Wadsworth, TX 77483

South Texas Project, Units 1 and 2

12/5/2007

Ms. Susan M. Jablonski
Office of Permitting, Remediation
and Registration
Texas Commission on Environmental Quality
MC-122
P.O. Box 13087
Austin, TX 78711-3087

Mr. Anthony P. Jones, Chief Boiler Inspector
Texas Department of Licensing and Regulation
Boiler Division
E.O. Thompson State Office Building
P.O. Box 12157
Austin, TX 78711

Mr. Ken Coates, Plant General Manager
STP Nuclear Operating Company
South Texas Project Electric Generating Station
P.O. Box 289
Wadsworth, TX 77483