

March 14, 2008

Mr. Randall K. Edington
Executive Vice President Nuclear/CNO
Mail Station 7602
Arizona Public Service Company
P.O. Box 52034
Phoenix, AZ 85072-2034

SUBJECT: PALO VERDE NUCLEAR GENERATING STATION, UNIT 2 - EVALUATION OF
NEW INFORMATION RELATED TO ALLOY 82/182 PRESSURIZER BUTT
WELD INSPECTIONS RE: CONFIRMATORY ACTION LETTER NRR-07-004
(TAC NO. MD7291)

Dear Mr. Edington:

On March 15, 2007, the U.S. Nuclear Regulatory Commission (NRC) issued Confirmatory Action Letter (CAL) No. NRR-07-004 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML070660298) regarding dissimilar metal welds in the pressurizer surge, spray, and safety/relief nozzle-to-safe end welds at Palo Verde Nuclear Generating Station (Palo Verde), Unit 2. The CAL and the supporting commitment letter (ADAMS Accession No. ML070590212) indicate that inspection and mitigation actions may be conducted during your spring 2008 refueling outage, contingent on the industry providing an analysis that demonstrates an acceptable level of safety to the NRC for the operation of these welds until spring 2008.

The NRC received MRP-216, Rev. 1, "Materials Reliability Program: Advanced FEA [Finite Element Analysis] Evaluation of Growth of Postulated Circumferential PWSCC [Primary Water Stress-Corrosion Cracking] Flaws in Pressurizer Nozzle Dissimilar Metal Welds," on August 13, 2007 (ADAMS Accession No. ML072410235). Based on our review of this report, NRC concluded that the analysis provided adequate justification to permit inspections during your spring 2008 refueling outage, and that the analysis was applicable to Palo Verde, Unit 2. On September 7, 2007, the NRC issued a letter to Arizona Public Service Company (ADAMS Accession No. ML072420004), informing you that a plant shutdown by December 31, 2007, was no longer needed and Palo Verde, Unit 2 could continue to operate until the spring 2008 outage.

On March 4, 2008, the NRC became aware of emerging information regarding certain welds in nozzles on a retired pressurizer from a pressurized-water reactor facility. This was related to new reports (ADAMS Accession Nos. ML080701017 and ML080701020) on weld examinations of those nozzles. This information raised questions regarding the technical basis for the September 7, 2007, letter. The NRC dispatched technical experts in non-destructive examination to independently review industry analyses and actions regarding this matter. On March 13, 2008, a public meeting was held in NRC Headquarters, Rockville, MD, with representatives of the eight licensees whose plants had not yet shut down for spring 2008 outages and who are subject to commitments to inspect or mitigate similar welds during spring 2008 outages.

The NRC has evaluated the non-destructive automated phased array ultrasonic examination performed since March 4, 2008, and concluded there is reasonable assurance that there is no structurally significant service-related degradation in those nozzles that would alter the conclusions provided in our letter dated September 7, 2007, that allowed continued operation of Palo Verde 2 until the spring 2008 refueling outage. The NRC will continue to evaluate new information as it becomes available. All other requirements of the CAL and the supporting commitment letter regarding enhanced inspection and leakage monitoring requirements for the reactor coolant system and associated reports remain valid.

The CAL will remain open until all CAL commitments pertaining to Palo Verde, Unit 2 are complete.

Current NRC guidance regarding CALs is contained in the NRC Enforcement Policy and the NRC Enforcement Manual, which are available at the NRC web site at <http://www.nrc.gov/about-nrc/regulatory/enforcement.html> (click on Enforcement Policy or Enforcement Guidance) or by contacting the Government Printing Office (GPO) toll-free at 1-888-293-6498. The GPO is open from 7:00 a.m. to 9:00 p.m. EST, Monday through Friday (except Federal holidays).

In accordance with Title 10 of the *Code of Federal Regulations*, Part 2, Section 390, of the NRC's "Rules of Practice," a copy of this letter will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm.html>.

Sincerely,

/RA by Tim McGinty for/

Catherine Haney, Director
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. STN 50-529

cc: See next page

The NRC has evaluated the non-destructive automated phased array ultrasonic examination performed since March 4, 2008, and concluded there is reasonable assurance that there is no structurally significant service-related degradation in those nozzles that would alter the conclusions provided in our letter dated September 7, 2007, that allowed continued operation of Palo Verde 2 until the spring 2008 refueling outage. The NRC will continue to evaluate new information as it becomes available. All other requirements of the CAL and the supporting commitment letter regarding enhanced inspection and leakage monitoring requirements for the reactor coolant system and associated reports remain valid.

The CAL will remain open until all CAL commitments pertaining to Palo Verde, Unit 2 are complete.

Current NRC guidance regarding CALs is contained in the NRC Enforcement Policy and the NRC Enforcement Manual, which are available at the NRC web site at <http://www.nrc.gov/about-nrc/regulatory/enforcement.html> (click on Enforcement Policy or Enforcement Guidance) or by contacting the Government Printing Office (GPO) toll-free at 1-888-293-6498. The GPO is open from 7:00 a.m. to 9:00 p.m. EST, Monday through Friday (except Federal holidays).

In accordance with Title 10 of the *Code of Federal Regulations*, Part 2, Section 390, of the NRC's "Rules of Practice," a copy of this letter will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (ADAMS), accessible from the NRC Web site at <http://www.nrc.gov/reading-rm.html>.

Sincerely,

/RA by Tim McGinty for
 Catherine Haney, Director
 Division of Operating Reactor Licensing
 Office of Nuclear Reactor Regulation

Docket No. STN 50-529

cc: See next page

DISTRIBUTION:

| | | |
|--------------------------|---------------------|-------------------------|
| PUBLIC | RidsNrrDirs | RidsRgn4MailCenter |
| LPL4 R/F | RidsNrrDorl | WMaier, RIV SLO |
| RidsAcrsAcnw&mMailCenter | RidsNrrDorlLpl4 | DPelton, EDO RIV |
| RidsEdoMailCenter | RidsNrrLAJBurkhardt | VDricks, OPA R-IV |
| RidsNrrOd | RidsNrrPMMMarkley | TSullivan, NRR/DCI/CPNB |
| RidsNrrDci | RidsOEMailCenter | |
| RidsNrrDciCpnb | RidsOgcRp | |

ADAMS Accession No. ML080740360 (*) by e-mail (**) see previous concurrence NRR-106

| | | | | |
|--------|----------------|-------------|------------------|-----------------|
| OFFICE | DCI/CPNB | DCI/CPNB/BC | DORL/LPL4/PM | DORL/LPL4/LA |
| NAME | TSullivan (**) | TChan (**) | MMarkley (**) | JBurkhardt (**) |
| DATE | 3/14/08 | 3/14/08 | 3/14/08 | 3/14/08 |
| OFFICE | DORL/LPL4/BC | NRR/DCI/D | DRP/D, R-IV | NRR/DORL/D |
| NAME | THiltz (**) | MEvans (**) | DChamberlain (*) | Chaney, TJM for |
| DATE | 3/14/08 | 3/14/08 | 3/14/08 | 3/14/08 |

OFFICIAL AGENCY RECORD

Palo Verde Nuclear Generating Station

10/19/2007

cc:

Mr. Steve Olea
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, AZ 85007

Mr. Douglas Kent Porter
Senior Counsel
Southern California Edison Company
Law Department, Generation Resources
P.O. Box 800
Rosemead, CA 91770

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 40
Buckeye, AZ 85326

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavillion
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Chairman
Maricopa County Board of Supervisors
301 W. Jefferson, 10th Floor
Phoenix, AZ 85003

Mr. Aubrey V. Godwin, Director
Arizona Radiation Regulatory Agency
4814 South 40 Street
Phoenix, AZ 85040

Mr. Scott Bauer, Director
Regulatory Affairs
Palo Verde Nuclear Generating Station
Mail Station 7636
P.O. Box 52034
Phoenix, AZ 85072-2034

Mr. Dwight C. Mims
Vice President
Regulatory Affairs and Plant Improvement
Palo Verde Nuclear Generating Station
Mail Station 7605
P.O. Box 52034
Phoenix, AZ 85072-2034

Mr. Matthew Benac
Assistant Vice President
Nuclear & Generation Services
El Paso Electric Company
340 East Palm Lane, Suite 310
Phoenix, AZ 85004

Mr. John Taylor
Public Service Company of New Mexico
2401 Aztec NE, MS Z110
Albuquerque, NM 87107-4224

Mr. Geoffrey M. Cook
Southern California Edison Company
5000 Pacific Coast Hwy Bldg D21
San Clemente, CA 92672

Mr. Robert Henry
Salt River Project
6504 East Thomas Road
Scottsdale, AZ 85251

Mr. Jeffrey T. Weikert
Assistant General Counsel
El Paso Electric Company
Mail Location 167
123 W. Mills
El Paso, TX 79901

Mr. John Schumann
Los Angeles Department of Water & Power
Southern California Public Power Authority
P.O. Box 51111, Room 1255-C
Los Angeles, CA 90051-0100

Mr. Brian Almon
Public Utility Commission
William B. Travis Building
P.O. Box 13326
1701 North Congress Avenue
Austin, TX 78701-3326

Ms. Karen O'Regan
Environmental Program Manager
City of Phoenix
Office of Environmental Programs
200 West Washington Street
Phoenix AZ 85003