



FPL

FEB 22 2008

L-2008-037
10 CFR 50.36

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555-0001

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
2007 Annual Report of Reactor Coolant Specific Activity Limits

In accordance with Technical Specification 6.9.1.2 the reactor coolant specific activity limits of 100/E-bar microcuries per gram of gross radioactivity, and 1.0 microcurie per gram Dose Equivalent I-131 defined by Technical Specification 3.4.8 for Units 3 and 4, were not exceeded during 2007.

Should there be any questions regarding this information, please contact Paul Infanger at (305) 246-6632.

Sincerely,

William Jefferson
Vice President
Turkey Point Nuclear Plant

SM

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

4001
NRR