



March 27, 2008

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2378

Serial No.: 07-0450E
NLOS/MAE R2
Docket No.: 50-423
License No.: NPF-49

DOMINION NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNIT 3
SUPPLEMENTAL INFORMATION REGARDING STRETCH POWER UPRATE
LICENSE AMENDMENT REQUEST

Dominion Nuclear Connecticut, Inc. (DNC) submitted a stretch power uprate (SPU) license amendment request (LAR) for Millstone Power Station Unit 3 (MPS3) in letters dated July 13, 2007 (Serial Nos. 07-0450 and 07-0450A), and supplemented the submittal by letters dated September 12, 2007 (Serial No. 07-0450B), December 13, 2007 (Serial No. 07-0450C) and March 5, 2008 (Serial No. 07-0450D). The NRC staff forwarded requests for additional information (RAIs) in October 29, 2007, November 26, 2007, December 14, 2007 and December 20, 2007 letters. DNC responded to the RAIs in letters dated November 19, 2007 (Serial No. 07-0751), December 17, 2007 (Serial No. 07-0799), January 10, 2008 (Serial Nos. 07-0834, 07-0834A, 07-0834C, and 07-0834F), January 11, 2008 (Serial Nos. 07-0834B, 07-0834E, 07-0834G, and 07-0834H), January 14, 2008 (Serial No. 07-0834D), January 18, 2008 (Serial Nos. 07-0846, 07-0846A, 07-0846B, 07-0846C, and 07-0846D), January 31, 2008 (Serial No. 07-0834I), February 25, 2008 (Serial Nos. 07-0799A and 07-0834J), March 10, 2008 (Serial Nos. 07-0846E and 07-0846F) and March 25, 2008 (Serial No. 07-0834K).

In the Licensing Report (Attachment 5 to DNC's July 13, 2007 letter, Serial No. 07-450), an inconsistency was discovered between two different sections in the report. In Section 2.8.5.6.3.2.5.3 page 2.8-446, it is correctly stated: "In summary, the MPS3 SPU Post LOCA boric acid precipitation calculations used conservative methodology to establish a 3- to 5- hour timeframe to realign the ECCS to provide SI flow to the hot legs." However, in Section 2.11.1.2 page 2.11-4 it is incorrectly stated "1. The time allowed for installation of hot and cold leg recirculation to minimize boron precipitation for large break LOCAs is reduced from nine (9) to six (6) hours." It should read "1. The time allowed for installation of hot and cold leg recirculation to minimize boron precipitation for large break LOCAs is reduced from nine (9) to five (5) hours." This is consistent with Section 2.8.5.6.3.2.5.3 as shown above.


This change to Section 2.11.1.2 has no impact on the conclusions given in Section 2.11.1.2. Specifically, it is still concluded that the changes do not significantly impact normal operator actions or off-normal event mitigation strategies. The changes will be appropriately proceduralized and the operators will receive formal classroom and simulator training for their implementation. Since operator training for this SPU procedure change has not yet been implemented, the error in Section 2.11 has not

resulted in the operators receiving incorrect training. The Millstone Power Station Unit 3 (MPS3) emergency operating procedures (EOPs) are in the process of being revised to implement the 3 to 5 hour range for hot leg injection. This change will be incorporated into the EOPs prior to the startup of the first SPU cycle.

The information provided by this letter does not affect the conclusions of the significant hazards consideration discussion in the December 13, 2007 DNC letter (Serial No. 07-0450C).

Should you have any questions in regard to this submittal, please contact Ms. Margaret Earle at 804-273-2768.

Sincerely,



Leslie N. Hartz
Vice President - Nuclear Support Services


COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by Leslie N. Hartz, who is Vice President - Nuclear Support Services of Dominion Nuclear Connecticut, Inc. She has affirmed before me that she is duly authorized to execute and file the foregoing document in behalf of that Company, and that the statements in the document are true to the best of her knowledge and belief.

Acknowledged before me this 27th day of March, 2008.

My Commission Expires: August 31, 2008.

Margaret B. Bennett
Notary Public



Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region I
Regional Administrator
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. J. G. Lamb
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop O-8B1A
Rockville, MD 20852-2738

Mr. J. D. Hughey
Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop O-8B3
Rockville, MD 20852-2738

NRC Senior Resident Inspector
Millstone Power Station

Director
Bureau of Air Management
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127