

March 28, 2008

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Limerick Generating Station, Unit 2  
Facility Operating License No. NPF-85  
NRC Docket No. 50-353

Subject: Withdrawal of Exelon Generation Company, LLC, License Amendment Request Related to Proposed One-Time Changes to Technical Specifications Section 3.4.3.1, Reactor Coolant System Leakage Detection Systems

Reference: Letter dated November 16, 2007, from P. B. Cowan, Exelon Generation Company, LLC, to USNRC, "Proposed One-Time Changes to Technical Specifications Section 3.4.3.1, Reactor Coolant System Leakage Detection Systems"

In the referenced letter, Exelon Generation Company, LLC (Exelon), requested one-time changes to the Technical Specifications (TS), Appendix A of Operating License No. NPF-85 for Limerick Generating Station (LGS), Unit 2. Specifically, the one-time changes were proposed because the drywell unit cooler condensate flow rate monitoring system became inoperable and could not be repaired on line. The proposed one-time changes were requested to be in effect until the next refuel outage currently scheduled for the Spring of 2009, or the next shutdown of sufficient duration to allow for drywell unit cooler condensate flow rate monitoring system repairs, whichever came first.


On February 1, 2008, an automatic actuation of the Limerick, Unit 2, reactor protection system occurred. The decision was made to bring the unit to cold shutdown and make a containment entry to effect repairs on, among other things, the drywell unit cooler condensate flow rate monitoring system. The repairs were successful and the drywell unit cooler condensate flow

License Amendment Request Withdrawal  
One-Time Changes to TS 3.4.3.1 (RCS Leakage Detection Systems)  
Docket No. 50-353  
March 28, 2008  
Page 2

rate monitoring system was declared operable on February 4, 2008. Therefore, Exelon hereby withdraws the referenced license amendment request.

If you have any questions or require additional information, please contact Glenn Stewart at 610-765-5529.

Respectfully,

A handwritten signature in cursive script, appearing to read "Pamela B. Cowan", is written over a solid horizontal line.

Pamela B. Cowan  
Director, Licensing & Regulatory Affairs  
Exelon Generation Company, LLC

cc: Regional Administrator - NRC Region I  
NRC Senior Resident Inspector - Limerick Generating Station  
NRC Project Manager, NRR - Limerick Generating Station  
Director, Bureau of Radiation Protection - Pennsylvania Department  
of Environmental Protection