



HITACHI

GE Hitachi
Nuclear Energy

LaTonya Mahlahla
Vallecitos Nuclear Center

6705 Vallecitos Rd
Sunol, CA 94586
USA

T 925 862 4360
F 910-341-2972
Latonya.mahlala@ge.com

U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2738
Attn: Document Control Desk

March 28, 2008

Subject: Annual Report for GETR, 2007
Reference: License TR-1, Docket 50-70
Enclosure: Annual Report No. 49

Enclosed is the Annual Report No. 49 for the deactivated General Electric Test Reactor (GETR) located at Vallecitos Nuclear Center near Sunol, California.

If there are any questions or additional information required, please contact me at the number above.

Sincerely Yours,

LaTonya L. Mahlahla
Date: *LaTonya Mahlahla*
2008.03.28
11:27:04 -07'00'

LaTonya L. Mahlahla
Mgr., Regulatory Compliance & EHS

cc: John Buckley (email)

NMSSD/

NMSS



HITACHI

GE Hitachi Nuclear Energy

*Vallecitos Nuclear Center
Sunol, California*

**GENERAL ELECTRIC TEST REACTOR
(DEACTIVATED)**

**ANNUAL REPORT NO. 49
FOR THE YEAR 2007**

**LICENSE TR-1
DOCKET 50-70**

MARCH 2008

**General Electric Test Reactor
(Deactivated)****Annual Report No. 49**

General Electric Company has maintained the General Electric Test Reactor (GETR) in a deactivated status under the authority of Amendment No. 16 to License TR-1, Docket 50-70, issued September 30, 1992. In this annual report, a summary of the status of the facility for the period of January 1, 2007 to December 31, 2007 is presented.

1.0 SUMMARY

The facility remains in essentially the same condition described in Annual Report No. 48. Entry into the reactor building was made for routine radiation surveys and a general examination of conditions throughout the building.

Radiation levels remain essentially unchanged.

2.0 STATUS OF FACILITY

In accordance with written procedures, the Facility Manager controls access to the containment building and general systems. The facility continues to be in deactivated status. There were no changes authorized by the Facility Manager pursuant to 10CFR50.59(a) and completed in 2007.

3.0 RADIATION AND CONTAMINATION

Complete radiation and contamination surveys of the facility indicate that levels remain low. Results of the surveys are presented in Table 1. The radiation/contamination levels listed are representative but not necessarily maximum values.

The data below are from sample and dosimeter results accumulated during 2007. These data are for the entire VNC site and include the effects of operations other than GETR.

3.1 GETR Stack

Not operated.

**3.2 Air Monitors** (Yearly average of all meteorological stations.)

Four environmental air monitoring stations are positioned approximately 90 degrees apart around the operating facilities of the site. Each station is equipped with a membrane filter that is changed weekly and analyzed for gross alpha and gross beta-gamma.

Alpha Concentration:

Weekly Maximum, $5.13 \text{ E-13 } \mu\text{Ci/cc}$ Weekly Average, $4.03 \text{ E-14 } \mu\text{Ci/cc}$

Beta Concentration:

Weekly Maximum, $6.15 \text{ E-12 } \mu\text{Ci/cc}$ Weekly Average, $9.35 \text{ E-14 } \mu\text{Ci/cc}$ **3.3 Gamma Radiation**

The yearly dose results for the year 2007 as determined from evaluation of site perimeter environmental monitoring dosimeters showed no departure from normal stable backgrounds.

3.4 Vegetation

No alpha, beta or gamma activity attributable to activities at the GETR facility was found on or in vegetation in the vicinity of the site.

3.5 Off-Site

Samples taken off the site indicate normal background for the area.

4.0 ACTIVITIES

Routine inspections were conducted during this report period. There were no preventive or corrective maintenance activities performed having safety significance during the reporting period.



HITACHI

GE Hitachi
Nuclear Energy

5.0 ORGANIZATION

The management and operations organization for the GETR is described in Technical Specification 6 (Figure 1) of License TR-1. The organizational structure remained the same in 2007. The Level 1 Organizational Head for 2007 was D. W. Turner. The Level 2 Facility Manager during 2006 was C. W. Bassett.

6.0 CONCLUSION

GE Hitachi Nuclear Energy concludes that the deactivated GETR is being maintained in a safe shutdown condition. The inspections, access control, and administratively controlled activities ensure maximum protection for the public health and safety. The procedures will be continued to maintain this high level of protection.

GE Hitachi Nuclear Energy
Vallecitos Operations

C. W. Bassett, Manager
Facilities Maintenance and QA



Table 1
Radiation and Contamination Level Data
General Electric Test Reactor (Deactivated)

Date of Measurement:	Contamination Levels					
	Radiation Levels (mR/h Gamma)		Surface Smears Beta-Gamma ¹ (cpm/ft ²)		Airborne Beta-Gamma ² ($\mu\text{Ci/cc} \times 10^{-10}$)	
	12/06	12/07	12/06	12/07	12/06	12/07
Reactor Enclosure						
Canal (field reading min.-max.)	<1 / 2.6	<1 / 2.2	--	--	--	--
3 rd Floor Zone (field reading min.-max.)	<1 / 2.8	<1 / 2.5	25K	7.6K	--	--
3 rd Floor Clean Area	--	--	200	<100	--	--
Top of Missile Shield (Point A)	<1 / 2.2	<1 / <1	<100	<100	0.028	0.009
2 nd Floor (field reading min.-max.)	<1 / 8	<1 / 78	--	--	--	--
2 nd Floor Clean Area	--	--	200	<100	--	--
1 st Floor Zone (field reading min.-max.)	<1 / 2.5	<1 / 2.5	10K	1.4K	--	--
1 st Floor Clean Area	--	--	1K	200	--	--
Basement, Rod Work Area	<1 / 7	<1 / 8	10K	1.2K	0.021	0.008
Basement Clean Area	--	--	1K	700	--	--

Note:

Radiation levels, surface smears, and air samples may vary from survey to survey as they are taken in general areas rather than at specific locations.

¹ For conversion to d/m, assume an instrument efficiency of 20%.

² 24-hour decayed values