

Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Rope Ferry Road, Waterford, CT 06385



Dominion®

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Serial No.	07-0017A
MPS Lic/TGC	R0
Docket No.	50-336
License No.	DPR-65

MAR 28 2008

DOMINION NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNIT 2
CANCELLATION OF LICENSEE EVENT REPORT MP2-2006-007-00

On January 22, 2007, Dominion Nuclear Connecticut, Inc., (DNC) submitted Licensee Event Report (LER) MP2-2006-007-00 pursuant to 10 CFR 50.73(a)(2)(i)(B) and 10 CFR 50.73(a)(2)(vii). This LER documented a condition at Millstone Power Station Unit 2 in which redundant 480V emergency load centers required by Technical Specification 3.8.2 were declared inoperable when it was discovered that required ventilation systems were not performing as required. Subsequent to the submittal of the LER, a technical evaluation was completed that concluded that while the supporting ventilation system was degraded, the 480V emergency load centers remained operable in the as-found condition. Therefore, DNC is formally withdrawing LER MP2-2006-007-00.

If you have any questions or require additional information, please contact Mr. William D. Bartron at (860) 444-4301.

Sincerely,

J. Alan Price
Site Vice President - Millstone

JE22
NRR

Attachments: None

Commitments made in this letter: None.

cc: U.S. Nuclear Regulatory Commission
Region I Regional Administrator
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. J. D. Hughey
Project Manager
U.S. Nuclear Regulatory Commission, Mail Stop 08 B3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

NRC Senior Resident Inspector
Millstone Power Station